

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM : 15.06.21 TO 21.6.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	15-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	15-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOIDED
3	15-Jun-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	15-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
5	15-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
6	15-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	15-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	15-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
9	15-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
10	15-Jun-2021	BAGALKOT	110	JAMAKAHANDI- (PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12 (04.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
11	15-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
12	15-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
13	15-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
14	15-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
15	15-Jun-2021	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED SIRSI_220	15:38	16:16	0:38	HAND TRIPPED
16	15-Jun-2021	BAGALKOT	110	SIRSI220-SIRSI2(IDLE3)	STATION NOT AFFECTED SIRSI_220	12:24	15:29	3:05	LINE CLEAR AVOIDED
17	15-Jun-2021	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	12:24	15:27	3:03	LINE CLEAR AVOIDED
18	15-Jun-2021	BAGALKOT	110	ANNIGERI-GADAG	STATION NOT AFFECTED ANNIGERI_110	18:43	21:29	2:46	LINE FAULT
19	15-Jun-2021	BAGALKOT	110	MAMADAPUR-BABLESHWAR	BABLESHWAR_110	14:55	14:58	0:03	HAND TRIPPED
20	15-Jun-2021	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:34 (15.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
21	15-Jun-2021	BAGALKOT	220	220/110KV,HV3,LV3	RABAKAVI_110,BANAHATTI_110, STATION NOT AFFECTED MAHALINGAPUR_220	11:45	12:32	0:47	LINE CLEAR AVOIDED
22	15-Jun-2021	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	11:34	12:20	0:46	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
23	15-Jun-2021	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	8:14	10:12	1:58	TRANSFORMER FAULT
24	15-Jun-2021	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	12:07	12:16	0:09	TRANSFORMER FAULT
25	15-Jun-2021	BAGALKOT	110	SOUDATTI-RAMDURGA1(NARGUND)	STATION NOT AFFECTED SOUDATTI 220	8:53	15:11	6:18	LINE FAULT
26	15-Jun-2021	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	10:53	12:32	1:39	LINE CLEAR AVOIDED
27	15-Jun-2021	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	13:42	15:28	1:46	LINE CLEAR AVOIDED
28	15-Jun-2021	BAGALKOT	110	SIRSI-SIRSI220(1)	STATION NOT AFFECTED SIRSI_110	15:58 (15.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
29	15-Jun-2021	BAGALKOT	110	SIRSI-SIRSI220(2)	STATION NOT AFFECTED SIRSI_110	15:58 (15.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
30	15-Jun-2021	BAGALKOT	110	110/11KV,HV1	UDYAMBAG_110	14:04 (15.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
31	15-Jun-2021	BENGALURU	66	A STATION 66 - A STATION 1	A STATION 66	12:33	12:38	0:05	LOAD CHANGE OVER
32	15-Jun-2021	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	17:22	17:26	0:04	TRANSFORMER FAULT
33	15-Jun-2021	BENGALURU	220	MYLSANDRA 400 - YARANDANAHALLI 220	YARANDANAHALLI 220	17:09	17:44	0:35	LINE FAULT
34	15-Jun-2021	BENGALURU	66	HV2	TELECOM LAYOUT	13:05	13:18	0:13	LINE CLEAR AVOIDED
35	15-Jun-2021	BENGALURU	66	HV1	TELECOM LAYOUT	12:40	12:51	0:11	LINE CLEAR AVOIDED
36	15-Jun-2021	BENGALURU	220	YARANDANAHALLI 220 - MYLSANDRA 400	YARANDANAHALLI 220	17:09	17:47	0:38	MAIN SUPPLY FAILURE
37	15-Jun-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	17:09	17:47	0:38	MAIN SUPPLY FAILURE
38	15-Jun-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	17:09	17:47	0:38	MAIN SUPPLY FAILURE
39	15-Jun-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	17:09	17:47	0:38	MAIN SUPPLY FAILURE
40	15-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	17:09	17:47	0:38	MAIN SUPPLY FAILURE
41	15-Jun-2021	BENGALURU	220	JIGANI 220 - MYLSANDRA 220	JIGANI 220	17:09	17:37	0:28	MAIN SUPPLY FAILURE
42	15-Jun-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	17:09	17:37	0:28	LOAD CHANGE OVER
43	15-Jun-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 220	17:53	18:02	0:09	LOAD CHANGE OVER
44	15-Jun-2021	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	17:08	17:35	0:27	LOAD CHANGE OVER
45	15-Jun-2021	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	17:52	18:08	0:16	LOAD CHANGE OVER
46	15-Jun-2021	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	8:16	8:24	0:08	LOAD CHANGE OVER
47	15-Jun-2021	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	17:10	17:30	0:20	LOAD CHANGE OVER
48	15-Jun-2021	BENGALURU	66	ATTIBELE - YARANDANAHALLI 220	ATTIBELE	17:05	17:25	0:20	LOAD CHANGE OVER
49	15-Jun-2021	BENGALURU	66	HV1	PATH PALYA	2:05	2:10	0:04	TRANSFORMER FAULT
50	15-Jun-2021	BENGALURU	66	HV1	MALLASANDRA	7:28	8:55	1:26	LINE CLEAR AVOIDED
51	15-Jun-2021	BENGALURU	66	HV2	DODDABELAVANGALA	15:00	15:17	0:17	LINE CLEAR AVOIDED
52	15-Jun-2021	BENGALURU	66	HV1	DODDABELAVANGALA	10:35	15:05	4:30	LINE CLEAR AVOIDED
53	15-Jun-2021	BENGALURU	66	HV1	BANGARPET	8:23	8:35	0:11	LINE CLEAR AVOIDED
54	15-Jun-2021	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	12:57	13:05	0:07	LINE CLEAR AVOIDED
55	15-Jun-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:15	8:55	0:40	LINE CLEAR AVOIDED
56	15-Jun-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:25	17:29	0:04	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
57	15-Jun-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	15:12	16:13	1:01	LINE CLEAR AVAILED
58	15-Jun-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:09	16:13	1:04	LINE CLEAR AVAILED
59	15-Jun-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	13:27	13:40	0:13	LINE FAULT
60	15-Jun-2021	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	15:15	15:50	0:35	MAIN SUPPLY FAILURE
61	15-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	13:47(14-06-2021)	14:30:00(15-6-2021)	24:42HRS	LINE CHARGED
62	15-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:36:00(15-6-2021)			LINE OPEN, LINE FAULT
63	15-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
64	15-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
65	15-Jun-2021	GULBARGA	220	HV2	MUNIRABAD_220	9:18	11:03	1:45	TRANSFORMER FAULT
66	15-Jun-2021	GULBARGA	220	HV1	MUNIRABAD_220	9:18	11:54	2:36	LINE CLEAR AVAILED
67	15-Jun-2021	GULBARGA	220	SINDHANOOR-LINGAPUR	LINGAPUR_220	9:15	10:53	1:38	LINE FAULT
68	15-Jun-2021	GULBARGA	220	HV2	RAICHUR_220	10:40	14:02	3:22	LINE CLEAR AVAILED
69	15-Jun-2021	GULBARGA	220	ALIPUR-BTPSG	BTPSG_220	9:14	11:47	2:33	LINE FAULT
70	15-Jun-2021	GULBARGA	220	HV2	KUSHTAGI_220	11:08	11:29	0:21	TRANSFORMER FAULT
71	15-Jun-2021	GULBARGA	220	LINGAPUR-BTPSG	BTPS_220,ALIPUR_220	9:14	11:39	2:25	LINE FAULT
72	15-Jun-2021	GULBARGA	220	LINGAPUR-SINDHANOOR	SINDHANOOR_220	9:14	10:53	1:39	LINE FAULT
73	15-Jun-2021	GULBARGA	220	LINGAPUR-KUSTAGI	KUSHTAGI_220	9:14	11:08	1:54	LINE FAULT
74	15-Jun-2021	GULBARGA	220	LINGAPUR-GDHALLI 1	GDHALLI_220	9:14	11:35	2:21	LINE FAULT
75	15-Jun-2021	GULBARGA	220	LINGAPUR-GDHALLI 2	GDHALLI_220	9:14	11:25	2:11	LINE FAULT
76	15-Jun-2021	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	9:14	11:54	2:40	LINE FAULT
77	15-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWAR_110	23:52(15.06.2021)			LINE OPEN, LINE FAULT
78	15-Jun-2021	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	23:57(14.06.2021)	0:04(15.06.2021)	00:07HRS	LINE CHARGED
79	15-Jun-2021	GULBARGA	110	HV3	GULBARGASOUTH_110	10:30(14.06.2021)	18:30(15.06.2021)	8:00HRS	TRANSFORMER CHARGED
80	15-Jun-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	5:20	5:40	0:20	LINE FAULT
81	15-Jun-2021	GULBARGA	110	SANKLAPUR-MUNIRABAD	SANKLAPUR_110	9:12	14:52	5:40	MAIN SUPPLY FAILURE
82	15-Jun-2021	GULBARGA	110	MUNIRABAD-KEREHALLI	KEREHALLI_110	9:15	11:10	1:55	MAIN SUPPLY FAILURE
83	15-Jun-2021	GULBARGA	110	STAR METALLIC- MUNIRABAD	MUNIRABAD_220	9:18	11:12	1:54	LINE FAULT
84	15-Jun-2021	GULBARGA	110	HV1	BENNUR_110	13:25	13:40	0:15	TRANSFORMER FAULT
85	15-Jun-2021	GULBARGA	110	HV2	DEODURGA_110	12:00	12:50	0:50	LINE CLEAR AVAILED
86	15-Jun-2021	GULBARGA	110	HV1	SIRWAR_110	0:25	2:05	1:40	LINE CLEAR AVAILED
87	15-Jun-2021	GULBARGA	110	HV1	SIRWAR_110	11:10	11:35	0:25	LINE CLEAR AVAILED
88	15-Jun-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	5:20	5:50	0:30	LINE FAULT
89	15-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110	3:59	4:07	0:08	LINE FAULT
90	15-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	16:00	16:05	0:05	TRANSFORMER FAULT
91	15-Jun-2021	GULBARGA	110	KAPNOOR-KADGANCHI	KADAGANCHI_110	20:05	20:10	0:05	LINE CLEAR AVAILED
92	15-Jun-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:26	5:40	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
93	15-Jun-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	8:10	8:50	0:40	MAIN SUPPLY FAILURE
94	15-Jun-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	9:15	12:00	2:45	MAIN SUPPLY FAILURE
95	15-Jun-2021	GULBARGA	66	BADALADKU-KUDLIGI	KUDLIGI_66	8:25	11:38	3:13	LINE CLEAR AVAILED
96	15-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:16(14.06.2021)	7:19(15.06.2021)	8:03hrs	LINE CHARGED
97	15-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:19(15.06.2021)			LINE OPEN,LINE CLEAR AVAILED
98	15-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:13	13:09	1:56	LINE CLEAR AVAILED
99	15-Jun-2021	HASSAN	220	HV3	KEMAR_220	12:56	14:13	1:17	LINE CLEAR AVAILED
100	15-Jun-2021	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	14:47	15:37	0:50	LINE CLEAR AVAILED
101	15-Jun-2021	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	15:39	16:24	0:45	LINE CLEAR AVAILED
102	15-Jun-2021	HASSAN	110	LV3	KEMAR_220	12:54	14:13	1:19	LINE CLEAR AVAILED
103	15-Jun-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	14:47	15:37	0:50	NFBC ISSUED
104	15-Jun-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	15:39	16:24	0:45	NFBC ISSUED
105	15-Jun-2021	HASSAN	110	HV3	PUTTUR_110	20:21	20:28	0:07	TRANSFORMER FAULT
106	15-Jun-2021	HASSAN	110	HV1	HALADY_110	16:31	17:59	1:28	TRANSFORMER FAULT
107	15-Jun-2021	HASSAN	110	HV1	MOODABIDRE_110	10:39	11:56	1:17	LINE CLEAR AVAILED
108	15-Jun-2021	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_220	10:22	17:38	7:16	LINE CLEAR AVAILED
109	15-Jun-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	17:17	19:43	2:26	LINE CLEAR AVAILED
110	15-Jun-2021	HASSAN	66	HV1	KANDLI_66	11:19	14:37	3:18	LINE CLEAR AVAILED
111	15-Jun-2021	HASSAN	66	HV2	KANDLI_66	12:00	13:03	1:03	LINE CLEAR AVAILED
112	15-Jun-2021	HASSAN	66	HASSAN1	UDDURKOPLU_66	17:25	19:43	2:18	NFBC ISSUED
113	15-Jun-2021	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	12:29	13:00	0:31	TRANSFORMER FAULT
114	15-Jun-2021	MYSURU	66	HV1	KIKKERI_66	13:10	13:40	0:30	LINE CLEAR AVAILED
115	15-Jun-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	13:36	13:45	0:09	LINE FAULT
116	15-Jun-2021	MYSURU	66	NANJANGUDU-THANDYA	NO STATIONS EFFECTED	9:32	9:41	0:08	LINE FAULT
117	15-Jun-2021	MYSURU	66	NANJANGUDU-THANDYA	NO STATIONS EFFECTED	16:41	16:43	0:01	LINE FAULT
118	15-Jun-2021	MYSURU	66	PERIYAPATNA-KAMPALAPURA	KAMPALAPURA_66	5:57	6:05	0:07	LINE FAULT
119	15-Jun-2021	MYSURU	66	HV1	PONNAMPETE_66	18:53	20:12	1:18	TRANSFORMER FAULT
120	15-Jun-2021	MYSURU	66	YALANDUR-MAMBALLI	NO STATIONS EFFECTED	18:56	19:13	0:16	LINE FAULT
121	15-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
122	15-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
123	15-Jun-2021	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	12:56	15:42	2:46	LINE CLEAR AVAILED
124	15-Jun-2021	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	23:17	23:38	0:20	LINE FAULT
125	15-Jun-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110 , TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	23:17	23:38	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
126	15-Jun-2021	TUMKUR	110	TR-1	MAYASANDRA_110	14:18	15:59	1:40	LINE CLEAR AVAILED
127	15-Jun-2021	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	9:34	10:02	0:28	HAND TRIPPED
128	15-Jun-2021	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	14:30	15:22	0:51	HAND TRIPPED
129	15-Jun-2021	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	9:52	14:45	4:53	LINE CLEAR AVAILED
130	15-Jun-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:16	10:44	0:27	LINE FAULT
131	15-Jun-2021	TUMKUR	66	TR-1(LV-1)	DAVANGERE_SRS_220	11:42	12:02	0:20	HAND TRIPPED
132	15-Jun-2021	TUMKUR	66	TR-1	HAGALWADI_66	12:17	12:45	0:28	LINE CLEAR AVAILED
133	15-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:49	9:03	0:13	LINE FAULT
134	15-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:10	9:32	0:21	LINE FAULT
135	15-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:28	15:03	0:34	LINE FAULT
136	15-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:29	15:58	0:28	LINE FAULT
137	15-Jun-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	14:16	14:28	0:12	LINE FAULT
138	15-Jun-2021	TUMKUR	66	TR-2	KOLALA_66	8:34	10:17	1:43	LINE CLEAR AVAILED
139	15-Jun-2021	TUMKUR	66	TR-2	SANIKERE_66	14:04	14:24	0:20	TRANSFORMER FAULT
140	15-Jun-2021	TUMKUR	66	TR-2	SANIKERE_66	14:26	14:37	0:11	TRANSFORMER FAULT
141	15-Jun-2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	15:05	15:08	0:02	HAND TRIPPED
142	15-Jun-2021	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	11:25	14:17	2:52	LINE CLEAR AVAILED
143	15-Jun-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:13	8:37	0:24	LINE FAULT
144	15-Jun-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:40	10:51	0:11	LINE FAULT
145	15-Jun-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:16	14:16	1:00	LINE FAULT
146	15-Jun-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	8:33	8:39	0:05	HAND TRIPPED
147	15-Jun-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	8:39	10:16	1:36	LINE FAULT
148	15-Jun-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	13:16	14:17	1:00	LINE FAULT
149	16-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
150	16-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
151	16-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
152	16-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
153	16-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
154	16-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
155	16-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
156	16-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
157	16-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
158	16-Jun-2021	BAGALKOT	110	JAMAKAHANDI- (PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12 (04.06.2021)	11:27 (16.06.2021)	286:15HRS	LINE CHARGED
159	16-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
160	16-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
161	16-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN,LINE CLEAR AVAILED
162	16-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
163	16-Jun-2021	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:34 (15.06.2021)	20:17 (16.06.2021)	27:43HRS	LINE CHARGED
164	16-Jun-2021	BAGALKOT	110	SIRSI-SIRSI220(1)	STATION NOT AFFECTED SIRSI_110	15:58 (15.06.2021)	19:48 (16.06.2021)	27:50HRS	LINE CHARGED
165	16-Jun-2021	BAGALKOT	110	SIRSI-SIRSI220(2)	STATION NOT AFFECTED SIRSI_110	15:58 (15.06.2021)	19:48 (16.06.2021)	27:50HRS	LINE CHARGED
166	16-Jun-2021	BAGALKOT	110	110/11KV,HV1	UDYAMBAG_110	14:04 (15.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
167	16-Jun-2021	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	6:52	18:46	11:54	LINE FAULT
168	16-Jun-2021	BAGALKOT	110	110/11KV,HV1	BIJAPUR CITY_110	15:57	17:24	1:27	LINE CLEAR AVAILED
169	16-Jun-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	3:27	3:40	0:13	LINE FAULT
170	16-Jun-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	19:20	19:30	0:10	LINE FAULT
171	16-Jun-2021	BAGALKOT	220	HAVERI220-HANAGAL-(TILUVALI)	HANAGAL_110	17:26	17:36	0:10	LINE FAULT
172	16-Jun-2021	BAGALKOT	110	HUKKERI-KOTAWAGI LIS	KOTAWAGI LIS_110	3:51	11:33	7:42	LINE FAULT
173	16-Jun-2021	BAGALKOT	110	MRUTHYUNJAYANAGAR- UAS(NARENDRA2)	STATION NOT AFFECTED MRUTHYUNJAYANAGAR_110	8:14	12:26	4:12	LINE CLEAR AVAILED
174	16-Jun-2021	BAGALKOT	110	110/33KV,HV3	BATKAL_33,KASARKOD_33 STATION NOT AFFECTED MURDESHWAR_110	11:53	12:23	0:30	LINE CLEAR AVAILED
175	16-Jun-2021	BAGALKOT	110	HUBLI-RAMANAKOPPA	STATION NOT AFFECTED RAMANAKOPPA_110	8:03	15:55	7:52	LINE CLEAR AVAILED
176	16-Jun-2021	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	11:44	13:45	2:01	LINE CLEAR AVAILED
177	16-Jun-2021	BAGALKOT	110	110/11KV,HV2(HV3)	RATTIHALLI_110	13:45	17:33	3:48	LINE CLEAR AVAILED
178	16-Jun-2021	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	7:51	16:35	8:44	LINE CLEAR AVAILED
179	16-Jun-2021	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	16:59 (16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
180	16-Jun-2021	BAGALKOT	220	VAJRAMATTI- BAGALKOT1	VAJRAMATTI_220	12:29	12:45	0:16	LINE FAULT
181	16-Jun-2021	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	10:18	10:26	0:08	TRANSFORMER FAULT
182	16-Jun-2021	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	10:27	15:44	5:17	LINE CLEAR AVAILED
183	16-Jun-2021	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	6:31	6:36	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
184	16-Jun-2021	BAGALKOT	110	110/11KV, HV2	TODALBAGI_110	12:25	14:38	2:13	LINE CLEAR AVAILED
185	16-Jun-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	3:55 (16.06.2021)			LINE OPEN, LINE FAULT
186	16-Jun-2021	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	7:44	10:05	2:21	TRANSFORMER FAULT
187	16-Jun-2021	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	12:46	17:10	4:24	LINE FAULT
188	16-Jun-2021	BAGALKOT	110	HUBLI220- RAMANKOPPA	RAMANKOPPA_110	7:44	14:44	7:00	LINE FAULT
189	16-Jun-2021	BAGALKOT	110	SOUDATTI220- MMCL	SOUDATTI_220	2:14	2:38	0:24	LINE FAULT
190	16-Jun-2021	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	3:44	3:47	0:03	HAND TRIPPED
191	16-Jun-2021	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIDDAPUR_110	5:21	14:00	8:39	LINE FAULT
192	16-Jun-2021	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	11:07	12:58	1:51	LINE CLEAR AVAILED
193	16-Jun-2021	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	14:55 (16.06.2021)			LINE OPEN, LINE FAULT
194	16-Jun-2021	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220	7:55	8:45	0:50	TRANSFORMER FAULT
195	16-Jun-2021	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	7:56	8:26	0:30	LINE FAULT
196	16-Jun-2021	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	8:30	9:02	0:32	LINE FAULT
197	16-Jun-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	RABAKAVI_110	8:30	8:57	0:27	HAND TRIPPED
198	16-Jun-2021	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	8:30	9:03	0:33	HAND TRIPPED
199	16-Jun-2021	BENGALURU	66	A STATION 66 - A STATION 1	A STATION 66	7:52	7:56	0:04	LOAD CHANGE OVER
200	16-Jun-2021	BENGALURU	66	HEBBALA 220 - MATHIKERE	NO STATION AFFECTED	16:16	18:16	2:00	LINE FAULT
201	16-Jun-2021	BENGALURU	66	HV1	ISRO LAYOUT	3:32	3:45	0:13	TRANSFORMER FAULT
202	16-Jun-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	12:01	12:06	0:05	LINE CLEAR AVAILED
203	16-Jun-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	12:17	12:25	0:08	LINE CLEAR AVAILED
204	16-Jun-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	12:22	12:36	0:14	LINE CLEAR AVAILED
205	16-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	12:22	12:50	0:28	LINE CLEAR AVAILED
206	16-Jun-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	14:22	15:02	0:40	TRANSFORMER FAULT
207	16-Jun-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	16:20	16:25	0:05	TRANSFORMER FAULT
208	16-Jun-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	16:56	17:01	0:05	LINE CLEAR AVAILED
209	16-Jun-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	17:00	17:05	0:05	LINE CLEAR AVAILED
210	16-Jun-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	17:01	17:05	0:04	LINE CLEAR AVAILED
211	16-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	16:47	16:55	0:08	LINE CLEAR AVAILED
212	16-Jun-2021	BENGALURU	220	JIGANI 220 - MYLSANDRA 220	JIGANI 220	12:25	12:40	0:15	LOAD CHANGE OVER
213	16-Jun-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	12:25	12:53	0:28	LOAD CHANGE OVER
214	16-Jun-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 220	16:59	17:07	0:08	LOAD CHANGE OVER
215	16-Jun-2021	BENGALURU	66	MANDIKAL - GOWRIBIDANUR 220	MANDIKAL	12:30	15:50	3:19	LINE CLEAR AVAILED
216	16-Jun-2021	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	11:45	11:52	0:07	LOAD CHANGE OVER
217	16-Jun-2021	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	17:00	17:08	0:08	LOAD CHANGE OVER
218	16-Jun-2021	BENGALURU	66	HV2	SRINIVASPURA	14:40	15:00	0:20	TRANSFORMER FAULT
219	16-Jun-2021	BENGALURU	66	HV1	SIDDALAGATTA	16:28	16:57	0:28	LINE CLEAR AVAILED
220	16-Jun-2021	BENGALURU	66	HV2	NELEMANGALA 66	12:25	12:28	0:02	LINE CLEAR AVAILED
221	16-Jun-2021	BENGALURU	66	HV2	HOSKOTE 66	15:27	15:53	0:26	LINE CLEAR AVAILED
222	16-Jun-2021	BENGALURU	66	HV1	DALASNUR	11:08	15:00	3:52	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
223	16-Jun-2021	BENGALURU	66	HV1	BANGARPET	16:45	16:56	0:11	LINE CLEAR AVAILED
224	16-Jun-2021	BENGALURU	66	HV1	BANGARPET	19:33	19:41	0:07	LINE CLEAR AVAILED
225	16-Jun-2021	BENGALURU	66	SRINIVASPURA - CHINTAMANI	SRINIVASPURA	14:40	15:00	0:20	LINE FAULT
226	16-Jun-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	1:10	1:37	0:27	LINE FAULT
227	16-Jun-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	1:10	1:34	0:24	LINE FAULT
228	16-Jun-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:31	14:53	1:22	LINE FAULT
229	16-Jun-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	12:27	13:56	1:28	LINE CLEAR AVAILED
230	16-Jun-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	18:41	18:48	0:06	LINE FAULT
231	16-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:36:00(15-6-2021)	12:27(16-6-2021)	21:50HRS	LINE CHARGED
232	16-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	13:41:00(16-6-2021)			LINE OPEN, LINE FAULT
233	16-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
234	16-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
235	16-Jun-2021	GULBARGA	220	HV1	KUDALIGI_220	13:45	14:09	0:24	TRANSFORMER FAULT
236	16-Jun-2021	GULBARGA	220	HV2	KUDALIGI_220	13:45	13:56	0:11	TRANSFORMER FAULT
237	16-Jun-2021	GULBARGA	220	HV1	RAICHUR_220	10:22	18:06	7:44	LINE CLEAR AVAILED
238	16-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	0:05	6:13	6:08	LINE CLEAR AVAILED
239	16-Jun-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	22:10(16.06.2021)			LINE OPEN, LINE CLEAR AVAILED
240	16-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	3:19	3:51	0:32	LINE FAULT
241	16-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWAR_110	23:52(15.06.2021)	00:02(16.06.2021)	00:10HRS	LINE CHARGED
242	16-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:11	4:25	0:14	LINE FAULT
243	16-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_1 10	19:10	19:13	0:03	LINE FAULT
244	16-Jun-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	14:15	14:35	0:20	LINE FAULT
245	16-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWAR_110	1:47	1:57	0:10	LINE FAULT
246	16-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	14:10	14:30	0:20	TRANSFORMER FAULT
247	16-Jun-2021	GULBARGA	110	HV1	SINDHANOOR_110	13:55	14:10	0:15	TRANSFORMER FAULT
248	16-Jun-2021	GULBARGA	110	HV2	JEEWARGI_110	14:15	15:30	1:15	LINE CLEAR AVAILED
249	16-Jun-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	13:00	13:15	0:15	LINE FAULT
250	16-Jun-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	12:50	13:10	0:20	LINE CLEAR AVAILED
251	16-Jun-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	11:30	13:08	1:38	LINE CLEAR AVAILED
252	16-Jun-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:11	18:26	0:15	LINE CLEAR AVAILED
253	16-Jun-2021	GULBARGA	110	STAR METALLIC- MUNIRABAD	MUNIRABAD_220	15:47	16:05	0:18	LINE FAULT
254	16-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG AON_110,DIGGI_110	5:45	5:50	0:05	LINE FAULT
255	16-Jun-2021	GULBARGA	110	HALBARGHA-BHALKI	BHALKI_110	5:45	5:50	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
256	16-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:19(15.06.2021)	6:51 (16.06.2021)	7:31 hrs	LINE CHARGED
257	16-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:42 (16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
258	16-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
259	16-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
260	16-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:14	7:03	4:49	LINE FAULT
261	16-Jun-2021	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	15:17	15:36	0:19	HAND TRIPPED
262	16-Jun-2021	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	15:20	15:38	0:18	HAND TRIPPED
263	16-Jun-2021	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	15:18	15:37	0:19	HAND TRIPPED
264	16-Jun-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRS MG_220	15:20	15:38	0:18	HAND TRIPPED
265	16-Jun-2021	HASSAN	66	MRSSHM-BD-1	MRS MG_220	18:32	19:22	0:50	LINE FAULT
266	16-Jun-2021	HASSAN	66	MRSSHM-DVG2	MRS MG_220	10:59	11:03	0:04	HAND TRIPPED
267	16-Jun-2021	HASSAN	110	HV3	PUTTUR_110	9:48	10:09	0:21	LINE CLEAR AVAILED
268	16-Jun-2021	HASSAN	110	HV4	PUTTUR_110	10:25	11:31	1:06	LINE CLEAR AVAILED
269	16-Jun-2021	HASSAN	110	HV2	HALADY_110	8:23	8:41	0:18	TRANSFORMER FAULT
270	16-Jun-2021	HASSAN	110	HV2	ANAVATTI_110	20:53	21:16	0:23	TRANSFORMER FAULT
271	16-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	14:44	15:20	0:36	LINE FAULT
272	16-Jun-2021	HASSAN	110	JOG-NK1	mghejog_gen	19:44	19:50	0:06	LINE FAULT
273	16-Jun-2021	HASSAN	110	HV1	KONAJE_110	11:27	11:31	0:04	HAND TRIPPED
274	16-Jun-2021	HASSAN	110	HV2	KONAJE_110	11:27	11:31	0:04	HAND TRIPPED
275	16-Jun-2021	HASSAN	110	HV3	KONAJE_110	11:27	11:31	0:04	HAND TRIPPED
276	16-Jun-2021	HASSAN	110	HV2	MANIPAL_110	10:15	10:33	0:18	LINE CLEAR AVAILED
277	16-Jun-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	9:18	12:35	3:17	LINE CLEAR AVAILED
278	16-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	14:44	15:25	0:41	LINE FAULT
279	16-Jun-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:37	13:15	1:38	NFBC ISSUED
280	16-Jun-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:50	14:12	0:22	HAND TRIPPED
281	16-Jun-2021	HASSAN	110	SORABA-SHR220	SORABA_110	9:46	9:50	0:04	HAND TRIPPED
282	16-Jun-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	5:41	6:40	0:59	LINE FAULT
283	16-Jun-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	8:21	9:47	1:26	LINE CLEAR AVAILED
284	16-Jun-2021	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	18:32	19:22	0:50	LINE FAULT
285	16-Jun-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	4:55	9:50	4:55	LINE FAULT
286	16-Jun-2021	HASSAN	66	HV1	MAGGE_66	4:55	9:52	4:57	MAIN SUPPLY FAILURE
287	16-Jun-2021	HASSAN	66	HV2	MAGGE_66	4:55	9:52	4:57	MAIN SUPPLY FAILURE
288	16-Jun-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:15	10:31	0:16	LINE FAULT
289	16-Jun-2021	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	4:55	9:51	4:56	LINE FAULT
290	16-Jun-2021	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	8:20	9:45	1:25	NFBC ISSUED
291	16-Jun-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	13:40	14:19	0:39	LINE FAULT
292	16-Jun-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	16:12	16:23	0:11	LINE FAULT
293	16-Jun-2021	HASSAN	66	HV2	SHRAVANABELAGOLA_66	14:30	15:02	0:32	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
294	16-Jun-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	10:19	10:36	0:17	LINE FAULT
295	16-Jun-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	11:41	11:55	0:14	LINE FAULT
296	16-Jun-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	12:21	12:50	0:29	LINE FAULT
297	16-Jun-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	13:50	14:06	0:16	LINE FAULT
298	16-Jun-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	14:11	14:26	0:15	LINE FAULT
299	16-Jun-2021	HASSAN	66	HV1	SIGEBAGI_66	11:01	11:40	0:39	LINE CLEAR AVAILED
300	16-Jun-2021	MYSURU	66	HV1	ELAVALA_66	13:53	14:46	0:52	LINE CLEAR AVAILED
301	16-Jun-2021	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATIONS EFFECTED	13:42	13:47	0:05	LINE FAULT
302	16-Jun-2021	MYSURU	66	HV2	HONNALLY_MYS_66	5:00	5:24	0:24	TRANSFORMER FAULT
303	16-Jun-2021	MYSURU	66	HV2	KADAKOLA_220	2:57	4:08	1:10	TRANSFORMER FAULT
304	16-Jun-2021	MYSURU	66	HV2	KADAKOLA_220	5:45	6:40	0:54	LINE CLEAR AVAILED
305	16-Jun-2021	MYSURU	66	HV1	SANIVARASANTHE_66	9:57	10:09	0:11	TRANSFORMER FAULT
306	16-Jun-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	8:56	9:07	0:11	LINE FAULT
307	16-Jun-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 TARIPURA_66 GAMANAHALLY_66	22:16	22:20	0:04	LINE FAULT
308	16-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
309	16-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
310	16-Jun-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	11:33(16.6.21)			LINE OPEN,LINE CLEAR AVAILED
311	16-Jun-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	17:06	17:26	0:19	LINE CLEAR AVAILED
312	16-Jun-2021	TUMKUR	110	TR-1	HONNAVALI_110	16:06	17:01	0:54	LINE CLEAR AVAILED
313	16-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	KOLALA_66, URDIGERE_66	15:20	16:03	0:43	LINE FAULT
314	16-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220kv- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKE RE_66,BELADARA_66	15:20	16:22	1:02	LINE FAULT
315	16-Jun-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	12:53	12:58	0:05	TRANSFORMER FAULT
316	16-Jun-2021	TUMKUR	66	CHITRADURGA 66kv- DAVANGERE 2	CHITRADURGA_66	15:57	16:06	0:08	LINE FAULT
317	16-Jun-2021	TUMKUR	66	CHITRADURGA 66kv- DAVANGERE 2	CHITRADURGA_66	16:30	19:14	2:43	LINE CLEAR AVAILED
318	16-Jun-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON1_IPP_66	ENERCON1_IPP_66	13:08	13:14	0:05	LINE FAULT
319	16-Jun-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	11:26	11:43	0:16	HAND TRIPPED
320	16-Jun-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	11:26	11:43	0:16	HAND TRIPPED
321	16-Jun-2021	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	12:01	16:00	3:58	LINE CLEAR AVAILED
322	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:17	10:35	0:18	LINE FAULT
323	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:19	12:36	0:17	HAND TRIPPED
324	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:47	13:10	0:22	LINE FAULT
325	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:15	13:16	0:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
326	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:44	13:47	0:02	LINE FAULT
327	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:18	14:21	0:02	LINE FAULT
328	16-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:42	15:32	0:50	HAND TRIPPED
329	16-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	21:47	21:55	0:07	LINE FAULT
330	16-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	14:48	14:57	0:08	LINE FAULT
331	16-Jun-2021	TUMKUR	66	TR-1	LINGADAHALLY_66	9:22	10:16	0:54	LINE CLEAR AVAILED
332	16-Jun-2021	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	11:51	14:12	2:20	LINE CLEAR AVAILED
333	16-Jun-2021	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	12:15	14:13	1:57	LINE CLEAR AVAILED
334	16-Jun-2021	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	14:58	15:05	0:07	LINE CLEAR AVAILED
335	16-Jun-2021	TUMKUR	66	TAVAREKERE (H)- PATNAYAKANAHALLI	TAVAREKERE(H)_66	12:36	12:46	0:09	LINE CLEAR AVAILED
336	16-Jun-2021	TUMKUR	66	TAVAREKERE (H)- PATNAYAKANAHALLI	TAVAREKERE(H)_66	13:01	14:12	1:10	LINE CLEAR AVAILED
337	16-Jun-2021	TUMKUR	66	TAVAREKERE (H)- PATNAYAKANAHALLI	TAVAREKERE(H)_66	15:58	16:08	0:10	LINE FAULT
338	16-Jun-2021	TUMKUR	66	TR-1	TUMKUR_66	11:17	11:28	0:11	TRANSFORMER FAULT
339	16-Jun-2021	TUMKUR	66	TR-1	HONNUDIKE_66	12:20	20:20	7:59	LINE CLEAR AVAILED
340	16-Jun-2021	TUMKUR	66	TR-2	HONNUDIKE_66	12:20	20:21	8:00	LINE CLEAR AVAILED
341	16-Jun-2021	TUMKUR	66	MELKOTE-MELEKOTE	MELKOTE_66	12:20	20:21	8:00	LINE CLEAR AVAILED
1	17-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	17-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	17-Jun-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	17-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
5	17-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	17-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	17-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	17-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	17-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	17-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
11	17-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
12	17-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN,LINE CLEAR AVAILED
13	17-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
14	17-Jun-2021	BAGALKOT	110	110/11KV,HV1	UDYAMBAG_110	14:04 (15.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
15	17-Jun-2021	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	16:59 (16.06.2021)	14:29 (17.06.2021)	21:28HRS	LINE CHARGED
16	17-Jun-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	3:55 (16.06.2021)	14:10 (17.06.2021)	34:15HRS	LINE CHARGED
17	17-Jun-2021	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	14:55 (16.06.2021)	17:39 (17.06.2021)	26:44HRS	LINE CHARGED
18	17-Jun-2021	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	6:26	6:40	0:14	LINE FAULT
19	17-Jun-2021	BAGALKOT	110	BAGALKOT-NEERBUDIHAI	NEERBUDIHAI_110	15:57	16:10	0:13	LINE FAULT
20	17-Jun-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	5:44	9:50	4:06	LINE FAULT
21	17-Jun-2021	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	23:47	23:56	0:09	LINE FAULT
22	17-Jun-2021	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	15:36 (17.06.2021)			LINE OPEN,LINE CLEAR AVAILED
23	17-Jun-2021	BAGALKOT	110	KARAWAR-SOLARIS	BINAGA_110	14:16	15:27	1:11	LINE CLEAR AVAILED
24	17-Jun-2021	BAGALKOT	110	KARAWAR-ARAG	ARAG_110	14:21	15:41	1:20	LINE CLEAR AVAILED
25	17-Jun-2021	BAGALKOT	110	UTTUR- MAHALINGAPUR(RANNABELAGALI)	RANNABELAGALI_110	4:33	4:48	0:15	LINE FAULT
26	17-Jun-2021	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	6:25	6:50	0:25	LINE FAULT
27	17-Jun-2021	BAGALKOT	110	110/11KV, HV1	TUMMINKATTI_110	16:15	16:25	0:10	LINE CLEAR AVAILED
28	17-Jun-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	10:14	13:33	3:19	LINE CLEAR AVAILED
29	17-Jun-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	10:12	13:30	3:18	LINE CLEAR AVAILED
30	17-Jun-2021	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	10:21	21:41	11:20	LINE CLEAR AVAILED
31	17-Jun-2021	BAGALKOT	110	BIDNAL220- NAVALGUND	NAVALGUND_110	5:26	10:25	4:59	LINE FAULT
32	17-Jun-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	10:36	11:58	1:22	LINE CLEAR AVAILED
33	17-Jun-2021	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	14:37	14:53	0:16	LINE FAULT
34	17-Jun-2021	BAGALKOT	110	110/11KV, HV2	KUDACHI_110	2:54	3:03	0:09	TRANSFORMER FAULT
35	17-Jun-2021	BENGALURU	66	HV3	AUSTIN TOWN	11:11	12:37	1:26	LINE CLEAR AVAILED
36	17-Jun-2021	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	11:01	11:10	0:09	LOAD CHANGE OVER
37	17-Jun-2021	BENGALURU	66	BRIGADE MEADOWS - SUBRAMANYAPURA 220	BRIGADE MEADOWS	17:25	17:34	0:09	LOAD CHANGE OVER
38	17-Jun-2021	BENGALURU	66	HV1	MEI LAYOUT	10:56	10:58	0:02	LINE CLEAR AVAILED
39	17-Jun-2021	BENGALURU	66	HV2	MEI LAYOUT	12:56	13:01	0:05	LINE CLEAR AVAILED
40	17-Jun-2021	BENGALURU	66	SHOBHA FOREST - SOMANAHALLI 220	SHOBHA FOREST	10:41	10:59	0:18	LOAD CHANGE OVER
41	17-Jun-2021	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	17:36	17:40	0:04	LOAD CHANGE OVER
42	17-Jun-2021	BENGALURU	66	ATTUR YELAHANKA - DG3	ABBIGERE	18:16	18:32	0:16	LINE FAULT
43	17-Jun-2021	BENGALURU	66	WELCASTE - SRS PEENYA 220	WELCASTE	20:52	20:56	0:04	LOAD CHANGE OVER
44	17-Jun-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	19:23	19:27	0:04	LOAD CHANGE OVER
45	17-Jun-2021	BENGALURU	66	HV2	TADIGOLU	11:19	11:59	0:39	LINE CLEAR AVAILED
46	17-Jun-2021	BENGALURU	66	HV1	SIDDALAGATTA	16:07	17:04	0:57	LINE CLEAR AVAILED
47	17-Jun-2021	BENGALURU	66	HV2	MELUR	8:35	8:40	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
48	17-Jun-2021	BENGALURU	66	HV2	KGF	14:50	15:50	1:00	LINE CLEAR AVAILED
49	17-Jun-2021	BENGALURU	66	HV2	HOSKOTE 66	17:33	17:55	0:21	LINE CLEAR AVAILED
50	17-Jun-2021	BENGALURU	66	HV1	HONNIGANAHALLI	16:35	16:40	0:05	TRANSFORMER FAULT
51	17-Jun-2021	BENGALURU	66	HV2	HONNIGANAHALLI	13:00	13:35	0:35	LINE CLEAR AVAILED
52	17-Jun-2021	BENGALURU	66	HV2	GANJIGUNTE	15:20	15:40	0:19	LINE CLEAR AVAILED
53	17-Jun-2021	BENGALURU	66	HV1	GANJIGUNTE	13:10	13:15	0:05	TRANSFORMER FAULT
54	17-Jun-2021	BENGALURU	66	HV1	GANJIGUNTE	13:20	13:25	0:05	TRANSFORMER FAULT
55	17-Jun-2021	BENGALURU	66	HV1	GANJIGUNTE	14:00	14:10	0:10	TRANSFORMER FAULT
56	17-Jun-2021	BENGALURU	66	HV2	DODDALAHALLI	12:30	12:52	0:22	TRANSFORMER FAULT
57	17-Jun-2021	BENGALURU	66	HV2	DODDALAHALLI	13:15	13:33	0:18	TRANSFORMER FAULT
58	17-Jun-2021	BENGALURU	220	HV1	DB PURA 220	11:48	15:15	3:27	LINE CLEAR AVAILED
59	17-Jun-2021	BENGALURU	66	TADIGOLU - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI, GOWNPALLI	11:10	11:18	0:08	LINE FAULT
60	17-Jun-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	16:55	17:07	0:12	LINE FAULT
61	17-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	10:41	11:58	1:17	LINE CLEAR AVAILED
62	17-Jun-2021	BENGALURU	66	HV2	DEVANAHALLI	13:00	13:17	0:17	TRANSFORMER FAULT
63	17-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	15:16	15:21	0:05	LINE CLEAR AVAILED
64	17-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	15:16	15:21	0:05	LINE CLEAR AVAILED
65	17-Jun-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	15:16	15:24	0:08	LINE CLEAR AVAILED
66	17-Jun-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:16	15:20	0:04	LINE CLEAR AVAILED
67	17-Jun-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	15:16	15:24	0:08	LINE CLEAR AVAILED
68	17-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	11:48	11:53	0:05	LINE CLEAR AVAILED
69	17-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:48	11:53	0:05	LINE CLEAR AVAILED
70	17-Jun-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	11:48	11:53	0:05	LINE CLEAR AVAILED
71	17-Jun-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:48	11:53	0:05	LINE CLEAR AVAILED
72	17-Jun-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:48	11:53	0:05	LINE CLEAR AVAILED
73	17-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
74	17-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	13:41:00(16-6-2021)	9:29(17-6-2021)	19:47HRS	LINE CHARGED
75	17-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:10:00(17-6-2021)			LINE OPEN, LINE FAULT
76	17-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
77	17-Jun-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	4:10(15.06.2021)			LINE OPEN,LINE CLEAR AVAILED
78	17-Jun-2021	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	3:50	7:50	4:00	LINE FAULT
79	17-Jun-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	22:10(16.06.2021)	5:59(17.06.2021)	7:49HRS	LINE CHARGED
80	17-Jun-2021	GULBARGA	220	HV1	SHAHABAD_220	3:48	4:18	0:30	TRANSFORMER FAULT
81	17-Jun-2021	GULBARGA	220	HV1	SHAHABAD_220	4:30	4:50	0:20	TRANSFORMER FAULT
82	17-Jun-2021	GULBARGA	220	SINDHANOOR-LINGAPUR	LINGAPUR_220	17:55	20:15	2:20	LINE FAULT
83	17-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	2:24	6:04	3:40	LINE CLEAR AVAILED
84	17-Jun-2021	GULBARGA	220	SEDAM-RTPS1	RTPS_220	5:25	5:52	0:27	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
85	17-Jun-2021	GULBARGA	220	HV2	KAPNOOR_220	4:30	5:01	0:31	TRANSFORMER FAULT
86	17-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	12:30	12:40	0:10	LINE FAULT
87	17-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	12:51	13:02	0:11	LINE FAULT
88	17-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD2	HALBARGA_220	11:40	13:02	1:22	LINE CLEAR AVAIED
89	17-Jun-2021	GULBARGA	220	SINDHANOOR-THURVIHAL	THURVIHAL_110	3:40	3:50	0:10	LINE FAULT
90	17-Jun-2021	GULBARGA	220	SINDHANOOR-THURVIHAL	THURVIHAL_110	21:50	22:00	0:10	LINE FAULT
91	17-Jun-2021	GULBARGA	220	SINDHANOOR-RAICHUR2	ADVIAMARESHWAR_110	23:05	23:15	0:10	LINE FAULT
92	17-Jun-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:22	10:35	0:13	TRANSFORMER FAULT
93	17-Jun-2021	GULBARGA	110	HV2	SINDHANOOR_110	1:59	2:08	0:09	TRANSFORMER FAULT
94	17-Jun-2021	GULBARGA	110	HV2	KAVITHAL_110	8:16	8:22	0:06	TRANSFORMER FAULT
95	17-Jun-2021	GULBARGA	110	KAVITAL-GMSH_IPP	KAVITHAL_110	8:16	8:23	0:07	LINE FAULT
96	17-Jun-2021	GULBARGA	110	HV2	JEEWARGI_110	3:46	4:13	0:27	TRANSFORMER FAULT
97	17-Jun-2021	GULBARGA	110	HV2	JEWARGI_110	4:58	5:00	0:02	TRANSFORMER FAULT
98	17-Jun-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	0:30	0:35	0:05	MAIN SUPPLY FAILURE
99	17-Jun-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	3:45	4:10	0:25	MAIN SUPPLY FAILURE
100	17-Jun-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	4:30	5:00	0:30	MAIN SUPPLY FAILURE
101	17-Jun-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	4:42	10:20	5:38	LINE FAULT
102	17-Jun-2021	GULBARGA	110	HV1	NIRNA_110	10:55	11:40	0:45	LINE CLEAR AVAIED
103	17-Jun-2021	GULBARGA	110	HV2	NIRNA_110	14:50	15:00	0:10	TRANSFORMER FAULT
104	17-Jun-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	10:24	10:49	0:25	MAIN SUPPLY FAILURE
105	17-Jun-2021	GULBARGA	110	YELBURGA-PRPJSR	YELBURGA_110	11:09	11:26	0:17	LINE CLEAR AVAIED
106	17-Jun-2021	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110	11:26	11:44	0:18	LINE CLEAR AVAIED
107	17-Jun-2021	GULBARGA	110	HV1	TEKKALKOTE_110	16:30	16:50	0:20	LINE CLEAR AVAIED
108	17-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	16:30	16:50	0:20	LINE CLEAR AVAIED
109	17-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	16:30	16:50	0:20	TRANSFORMER FAULT
110	17-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	11:25	11:35	0:10	TRANSFORMER FAULT
111	17-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	12:20	12:40	0:20	TRANSFORMER FAULT
112	17-Jun-2021	GULBARGA	110	HV3	TEKKALKOTE_110	16:30	16:50	0:20	LINE CLEAR AVAIED
113	17-Jun-2021	GULBARGA	110	TEKKALKOTE-SHAHI_SLR	TEKKALKOTE_110	16:30	16:50	0:20	LINE CLEAR AVAIED
114	17-Jun-2021	GULBARGA	110	TEKKALKOTE-AMGN_IPP	TEKKALKOTE_110	16:30	17:00	0:30	LINE CLEAR AVAIED
115	17-Jun-2021	GULBARGA	110	HV2	HATTI_110	16:53	16:57	0:04	TRANSFORMER FAULT
116	17-Jun-2021	GULBARGA	110	HV1	CHINCHOLI	15:32	17:15	1:43	LINE CLEAR AVAIED
117	17-Jun-2021	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARAGUT TI_110	14:13	14:39	0:26	LINE FAULT
118	17-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAIED
119	17-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAIED
120	17-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:42 (16.06.2021)	10:47 (17.06.2021)	25:05hrs	LINE CHARGED
121	17-Jun-2021	HASSAN	400	UPCLHASSAN2	upcl_gen	0:10	6:56	6:46	LINE CLEAR AVAIED
122	17-Jun-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:32	17:57	4:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
123	17-Jun-2021	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	0:16	13:55	13:39	LINE FAULT
124	17-Jun-2021	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	0:16	13:55	13:39	LINE FAULT
125	17-Jun-2021	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	17:05	19:32	2:27	LINE FAULT
126	17-Jun-2021	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	10:57	13:39	2:42	LINE CLEAR AVAILED
127	17-Jun-2021	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	10:57	14:58	4:01	LINE CLEAR AVAILED
128	17-Jun-2021	HASSAN	220	HV1	SHIRALKOPPA_220	10:43	14:01	3:18	LINE CLEAR AVAILED
129	17-Jun-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	10:57	13:39	2:42	NFBC ISSUED
130	17-Jun-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	10:56	14:58	4:02	NFBC ISSUED
131	17-Jun-2021	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:33	17:50	4:17	LINE FAULT
132	17-Jun-2021	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_400	17:01	22:29	5:28	LINE FAULT
133	17-Jun-2021	HASSAN	110	HV2	HALADY_110	16:36	16:40	0:04	TRANSFORMER FAULT
134	17-Jun-2021	HASSAN	110	HV2	HALADY_110	19:12	19:21	0:09	TRANSFORMER FAULT
135	17-Jun-2021	HASSAN	110	HV2	HALADY_110	19:44	19:47	0:03	TRANSFORMER FAULT
136	17-Jun-2021	HASSAN	110	HV1	ARASIKERE_110	12:01	13:15	1:14	LINE CLEAR AVAILED
137	17-Jun-2021	HASSAN	110	HV1	BANAVARA_110	13:36	13:45	0:09	HAND TRIPPED
138	17-Jun-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	14:01	15:03	1:02	MAIN SUPPLY FAILURE
139	17-Jun-2021	HASSAN	110	JOG-JST1	mghejog_gen	3:18	3:40	0:22	LINE FAULT
140	17-Jun-2021	HASSAN	110	JOG-JST1	mghejog_gen	9:53	10:24	0:31	LINE FAULT
141	17-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	3:18	3:43	0:25	LINE FAULT
142	17-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	9:53	10:34	0:41	LINE FAULT
143	17-Jun-2021	HASSAN	110	HV2	KUNDAPURA_110	18:02	18:15	0:13	TRANSFORMER FAULT
144	17-Jun-2021	HASSAN	110	HV2	KUNDAPURA_110	21:54	22:08	0:14	TRANSFORMER FAULT
145	17-Jun-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:44	15:00	1:16	LINE FAULT
146	17-Jun-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	15:02	15:12	0:10	LINE FAULT
147	17-Jun-2021	HASSAN	110	HV2	SAGARA_110	16:57	17:39	0:42	LINE CLEAR AVAILED
148	17-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	3:17	3:42	0:25	LINE FAULT
149	17-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	9:53	10:34	0:41	LINE FAULT
150	17-Jun-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:12	13:40	3:28	NFBC ISSUED
151	17-Jun-2021	HASSAN	110	LV1	SHIRALKOPPA_110	10:41	14:01	3:20	LINE CLEAR AVAILED
152	17-Jun-2021	HASSAN	110	HV1	SORABA_110	12:22	12:31	0:09	LINE CLEAR AVAILED
153	17-Jun-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	8:45	15:22	6:37	LINE CLEAR AVAILED
154	17-Jun-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	8:45	15:19	6:34	LINE CLEAR AVAILED
155	17-Jun-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	8:31	15:16	6:45	LINE FAULT
156	17-Jun-2021	HASSAN	66	HV1	ALDUR_66	9:49	10:08	0:19	TRANSFORMER FAULT
157	17-Jun-2021	HASSAN	66	HV1	ARAKALGUD_66	7:13	7:29	0:16	LINE CLEAR AVAILED
158	17-Jun-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	16:01	16:07	0:06	HAND TRIPPED
159	17-Jun-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	12:57	13:21	0:24	LINE CLEAR AVAILED
160	17-Jun-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:01	10:05	0:04	HAND TRIPPED
161	17-Jun-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:58	12:58	2:00	LINE CLEAR AVAILED
162	17-Jun-2021	HASSAN	66	HV1	HOLEHONNUR_66	14:55	16:38	1:43	LINE CLEAR AVAILED
163	17-Jun-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:43	13:30	2:47	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
164	17-Jun-2021	HASSAN	66	HV1	MAGGE_66	10:55	13:32	2:37	MAIN SUPPLY FAILURE
165	17-Jun-2021	HASSAN	66	HV2	MAGGE_66	10:55	13:32	2:37	MAIN SUPPLY FAILURE
166	17-Jun-2021	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:00	10:05	0:05	MAIN SUPPLY FAILURE
167	17-Jun-2021	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:00	13:10	2:10	MAIN SUPPLY FAILURE
168	17-Jun-2021	HASSAN	66	HV1	MALALI_66	10:01	10:09	0:08	MAIN SUPPLY FAILURE
169	17-Jun-2021	HASSAN	66	HV1	MALALI_66	11:00	13:00	2:00	MAIN SUPPLY FAILURE
170	17-Jun-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:44	10:54	0:10	LINE FAULT
171	17-Jun-2021	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	8:30	15:20	6:50	MAIN SUPPLY FAILURE
172	17-Jun-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:00	10:02	0:02	MAIN SUPPLY FAILURE
173	17-Jun-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:58	13:10	2:12	MAIN SUPPLY FAILURE
174	17-Jun-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPUA_66	10:43	13:31	2:48	LINE FAULT
175	17-Jun-2021	HASSAN	66	HV1	SHANTHIGRAMA_66	10:00	10:02	0:02	MAIN SUPPLY FAILURE
176	17-Jun-2021	HASSAN	66	HV1	SHANTHIGRAMA_66	11:00	13:35	2:35	MAIN SUPPLY FAILURE
177	17-Jun-2021	HASSAN	66	HV2	SHANTHIGRAMA_66	10:00	10:02	0:02	MAIN SUPPLY FAILURE
178	17-Jun-2021	HASSAN	66	HV2	SHANTHIGRAMA_66	11:00	13:35	2:35	MAIN SUPPLY FAILURE
179	17-Jun-2021	HASSAN	66	KIADB H-HASAN I\C	KIADB_HASSAN_66	8:45	15:17	6:32	MAIN SUPPLY FAILURE
180	17-Jun-2021	MYSURU	66	HV1	BESAGARAHALLI_66	11:00	13:30	2:29	LINE CLEAR AVAILED
181	17-Jun-2021	MYSURU	66	HV2	BESAGARAHALLI_66	13:10	14:35	1:25	LINE CLEAR AVAILED
182	17-Jun-2021	MYSURU	66	HV1	BETTADHAPURA_66	14:09	15:34	1:24	LINE CLEAR AVAILED
183	17-Jun-2021	MYSURU	66	HV1	HDKOTE_66	19:25	19:34	0:09	TRANSFORMER FAULT
184	17-Jun-2021	MYSURU	66	HV2	HUNSUR_66	18:28	18:50	0:22	HAND TRIPPED
185	17-Jun-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	11:16	11:29	0:13	TRANSFORMER FAULT
186	17-Jun-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	20:45	20:55	0:10	TRANSFORMER FAULT
187	17-Jun-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	21:01	21:08	0:06	TRANSFORMER FAULT
188	17-Jun-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	21:39	21:50	0:10	TRANSFORMER FAULT
189	17-Jun-2021	MYSURU	66	HV1	TARIPURA_66	10:45	11:30	0:45	LINE CLEAR AVAILED
190	17-Jun-2021	MYSURU	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 & ARAKERE_66	0:36	0:41	0:05	LINE FAULT
191	17-Jun-2021	MYSURU	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 & ARAKERE_66	15:50	15:54	0:04	LINE FAULT
192	17-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
193	17-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
194	17-Jun-2021	TUMKUR	220	TR-1	KBCROSS_220	9:28	15:10	5:41	LINE CLEAR AVAILED
195	17-Jun-2021	TUMKUR	220	TR-3	KBCROSS_220	12:34	17:26	4:51	LINE CLEAR AVAILED
196	17-Jun-2021	TUMKUR	220	TR-2	KBCROSS_220	15:47	19:08	3:21	LINE CLEAR AVAILED
197	17-Jun-2021	TUMKUR	110	TR-1	DODDAGUNI_110	12:20	14:30	2:10	LINE CLEAR AVAILED
198	17-Jun-2021	TUMKUR	110	TR-2	DODDAGUNI_110	12:10	15:00	2:50	LINE CLEAR AVAILED
199	17-Jun-2021	TUMKUR	110	TR-1(LV-1)	KBCROSS_220	9:28	15:10	5:41	LINE CLEAR AVAILED
200	17-Jun-2021	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	15:47	19:09	3:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
201	17-Jun-2021	TUMKUR	110	TR-3(LV SIDE)	KBCROSS_220	12:34	17:26	4:51	LINE CLEAR AVAILED
202	17-Jun-2021	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_11 0,	12:33	12:38	0:05	HAND TRIPPED
203	17-Jun-2021	TUMKUR	110	KB CROSS 220kV-TURUVEKERE110	TURUVEKERE_110,TANDAGA _110,NONAVINAKERE_110,G UNGURMALE_110	12:32	12:37	0:05	HAND TRIPPED
204	17-Jun-2021	TUMKUR	110	KB CROSS 220kV-TURUVEKERE110	TURUVEKERE_110,TANDAGA _110,NONAVINAKERE_110,G UNGURMALE_110	17:23	17:27	0:04	HAND TRIPPED
205	17-Jun-2021	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_11 0,	17:24	17:28	0:04	HAND TRIPPED
206	17-Jun-2021	TUMKUR	66	TR-1(LV-1)	ANTHRASANAHALLI_220	10:44	14:12	3:27	LINE CLEAR AVAILED
207	17-Jun-2021	TUMKUR	66	TR-2	CHITRAHALLI_66	9:15	10:00	0:44	LINE CLEAR AVAILED
208	17-Jun-2021	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	15:34	18:25	2:51	NFBC ISSUED
209	17-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	19:08	19:18	0:10	LINE FAULT
210	17-Jun-2021	TUMKUR	66	TR-2	MALEBENNUR_66	12:00	13:21	1:20	TRANSFORMER FAULT
211	17-Jun-2021	TUMKUR	66	TR-2	MALEBENNUR_66	13:27	14:18	0:50	TRANSFORMER FAULT
212	17-Jun-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	11:50	12:00	0:10	TRANSFORMER FAULT
213	17-Jun-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	15:40	16:00	0:20	LINE CLEAR AVAILED
214	17-Jun-2021	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE	HIREMALLANAHOLE_66,ACCI ONA WIND ENERGY_IPP_66	8:50	9:14	0:24	NFBC ISSUED
215	17-Jun-2021	TUMKUR	66	TR-1	PUNABHAGHATTA_66	12:37	13:37	1:00	LINE CLEAR AVAILED
216	17-Jun-2021	TUMKUR	66	TR-2	PUNABHAGHATTA_66	12:14	13:38	1:23	LINE CLEAR AVAILED
217	17-Jun-2021	TUMKUR	66	TR-2	SIRA_66	13:59	14:05	0:05	MAIN SUPPLY FAILURE
218	17-Jun-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	15:35	18:21	2:46	LINE CLEAR AVAILED
219	17-Jun-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEI DIAMOND SOLAR_IPP_66	5:44	8:57	3:12	LINE CLEAR AVAILED
220	17-Jun-2021	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	5:47	8:58	3:11	LINE CLEAR AVAILED
221	17-Jun-2021	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	5:44	9:06	3:21	LINE CLEAR AVAILED
222	17-Jun-2021	TUMKUR	66	THALLAK 220kV- P R PURA	MADHUGIRI_220	15:35	18:27	2:51	LINE CLEAR AVAILED
223	17-Jun-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	15:35	18:26	2:50	LINE CLEAR AVAILED
1	18-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	18-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	18-Jun-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	18-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
5	18-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	18-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	18-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	18-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	18-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	18-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
11	18-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
12	18-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN,LINE CLEAR AVAILED
13	18-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
14	18-Jun-2021	BAGALKOT	110	110/11KV,HV1	UDYAMBAG_110	14:04 (15.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
15	18-Jun-2021	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	15:36 (17.06.2021)	16:09 (18.06.2021)	24:33HRS	LINE CHARGED
16	18-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	12:16	13:58	1:42	LINE FAULT
17	18-Jun-2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	15:51	15:54	0:03	TRANSFORMER FAULT
18	18-Jun-2021	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	14:19	17:02	2:43	LINE FAULT
19	18-Jun-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	13:17	14:44	1:27	LINE CLEAR AVAILED
20	18-Jun-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	1:49	1:57	0:08	LINE FAULT
21	18-Jun-2021	BAGALKOT	110	110/33KV,HV3	GOPANAKOPPA_110 & KUSUGAL_33	10:45	11:47	1:02	LINE CLEAR AVAILED
22	18-Jun-2021	BAGALKOT	110	HIREHAL-MFR SLR	HIREHAL_110	15:05	15:06	0:01	HAND TRIPPED
23	18-Jun-2021	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	8:25	8:36	0:11	TRANSFORMER FAULT
24	18-Jun-2021	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	15:53	19:04	3:11	LINE CLEAR AVAILED
25	18-Jun-2021	BAGALKOT	110	HUKKERI-KOTAWAGI	HUKKERI_110	2:00	8:19	6:19	LINE FAULT
26	18-Jun-2021	BAGALKOT	110	KERUR-BADAMI	KERUR_110	15:24	17:14	1:50	LINE CLEAR AVAILED
27	18-Jun-2021	BAGALKOT	110	KERUR-BAGALKOT	KERUR_110	15:24	17:05	1:41	LINE CLEAR AVAILED
28	18-Jun-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:30	15:34	4:04	LINE FAULT
29	18-Jun-2021	BAGALKOT	110	110/33KV, HV2	HUBLI_220	11:56	15:34	3:38	LINE CLEAR AVAILED
30	18-Jun-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	10:28	13:02	2:34	LINE FAULT
31	18-Jun-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	22:27 (18.06.2021)			LINE OPEN, LINE FAULT
32	18-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	1:50	2:14	0:24	HAND TRIPPED
33	18-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN,LINE CLEAR AVAILED
34	18-Jun-2021	BAGALKOT	110	RON- GAMESHA	RON_110	2:14	2:27	0:13	HAND TRIPPED
35	18-Jun-2021	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(B)_110	13:15	13:22	0:07	TRANSFORMER FAULT
36	18-Jun-2021	BAGALKOT	110	KUDALSANGAM- HUNGUND	KUDALSANGAM_110	12:57	13:03	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
37	18-Jun-2021	BAGALKOT	220	KADRA2- KARWAR	KARWAR_220	13:35	16:11	2:36	LINE CLEAR AVAILED
38	18-Jun-2021	BAGALKOT	110	KARWAR220- SOLARIS(BINAGA)	KARWAR_220	13:16	13:29	0:13	HAND TRIPPED
39	18-Jun-2021	BAGALKOT	110	220/110KV, LV1	KARWAR_220	13:20	16:23	3:03	LINE CLEAR AVAILED
40	18-Jun-2021	BAGALKOT	110	UDIKERI- NOKAR SOLAR	UDIKERI_110	15:34	15:40	0:06	LINE FAULT
41	18-Jun-2021	BAGALKOT	110	UDIKERI- NOKAR SOLAR	UDIKERI_110	15:45	16:22	0:37	LINE FAULT
42	18-Jun-2021	BAGALKOT	110	UDIKERI- NOKAR SOLAR	UDIKERI_110	17:23	17:36	0:13	HAND TRIPPED
43	18-Jun-2021	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	12:28	12:43	0:15	LINE FAULT
44	18-Jun-2021	BENGALURU	66	JAYADEVA - ADUGODI	NO STATION AFFECTED	12:28	12:44	0:16	LINE FAULT
45	18-Jun-2021	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	16:11	16:38	0:27	TRANSFORMER FAULT
46	18-Jun-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	7:22	7:30	0:08	LOAD CHANGE OVER
47	18-Jun-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	12:05	12:10	0:05	LOAD CHANGE OVER
48	18-Jun-2021	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:21	12:45	0:24	LINE FAULT
49	18-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	11:39	11:57	0:18	LOAD CHANGE OVER
50	18-Jun-2021	BENGALURU	66	HV1	BANGARPET	12:50	13:35	0:45	TRANSFORMER FAULT
51	18-Jun-2021	BENGALURU	66	HV1	GUDEMARANAHALLI	12:30	13:02	0:32	LINE CLEAR AVAILED
52	18-Jun-2021	BENGALURU	66	HV2	MAASTHI	7:05	7:12	0:07	TRANSFORMER FAULT
53	18-Jun-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	16:02	16:06	0:03	LINE FAULT
54	18-Jun-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	12:14	12:23	0:08	LINE FAULT
55	18-Jun-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:25	14:55	0:30	LINE CLEAR AVAILED
56	18-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	14:25	14:55	0:30	LINE CLEAR AVAILED
57	18-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
58	18-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:10:00(17-6-2021)	14:24:46(18-6-2021)	24:13HRS	LINE CHARGED
59	18-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN, LINE FAULT
60	18-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
61	18-Jun-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	4:10(15.06.2021)	11:27(18.06.2021)	80:32HRS	LINE CHARGED
62	18-Jun-2021	GULBARGA	220	SINDHANOOR-LINGAPUR	LINGAPUR_220	10:55	11:20	0:25	LINE FAULT
63	18-Jun-2021	GULBARGA	220	MUNIRABAD-LINGAPUR	MUNIRABAD_220	10:50	11:25	0:35	MAIN SUPPLY FAILURE
64	18-Jun-2021	GULBARGA	220	LINGAPUR-GDHALLI1	GDHALLI_220	10:50	11:41	0:51	LINE FAULT
65	18-Jun-2021	GULBARGA	220	LINGAPUR-GDHALLI2	GDHALLI_220	10:50	11:47	0:57	LINE FAULT
66	18-Jun-2021	GULBARGA	220	HV1	LINGAPUR_220	10:50	11:18	0:28	TRANSFORMER FAULT
67	18-Jun-2021	GULBARGA	220	HV2	LINGAPUR_220	10:50	11:22	0:32	TRANSFORMER FAULT
68	18-Jun-2021	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	10:50	11:48	0:58	LINE FAULT
69	18-Jun-2021	GULBARGA	220	LINGAPUR-SINDHANOOR	SINDHANOOR_220	10:50	11:15	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
70	18-Jun-2021	GULBARGA	220	LINGAPUR-GADAG2	DHONI_IPP,XINDIA,DHRUVA DESH,GADAG_220	10:50	11:56	1:06	LINE FAULT
71	18-Jun-2021	GULBARGA	220	LINGAPUR-BTPS	BTPS_220,ALIPUR_220	10:50	11:39	0:49	LINE FAULT
72	18-Jun-2021	GULBARGA	220	LINGAPUR-JINDAL1	LINGAPUR_220	10:50	11:24	0:34	LINE FAULT
73	18-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	3:00	6:34	3:34	LINE CLEAR AVAILED
74	18-Jun-2021	GULBARGA	220	ITTAGI-EMBESSY_IPP	ITTAGI_220	11:13	11:55	0:42	LINE CLEAR AVAILED
75	18-Jun-2021	GULBARGA	110	HV2	KAMPLI_GLB_110	5:32	5:40	0:08	TRANSFORMER FAULT
76	18-Jun-2021	GULBARGA	110	HV1	MADIYAL_110	11:00	11:05	0:05	TRANSFORMER FAULT
77	18-Jun-2021	GULBARGA	110	MUNIRABAD-STARMETALLIC	MUNIRABAD_220	10:53	11:30	0:37	LINE FAULT
78	18-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWAR_110	23:50	0:00	0:10	LINE FAULT
79	18-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG AON_110,DIGGI_110	23:14	23:20	0:06	LINE FAULT
80	18-Jun-2021	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARAGUT TI_110	16:40	16:48	0:08	LINE FAULT
81	18-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	10:50	12:00	1:10	MAIN SUPPLY FAILURE
82	18-Jun-2021	GULBARGA	110	KAMPLI-MUNIRABAD	KAMPLI_GLB_110	10:50	11:30	0:40	MAIN SUPPLY FAILURE
83	18-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	23:14	23:19	0:05	LINE FAULT
84	18-Jun-2021	GULBARGA	110	STAR METALLIC- MUNIRABAD	MUNIRABAD_220	10:53	11:30	0:37	LINE FAULT
85	18-Jun-2021	GULBARGA	110	HV1	MANVI_110	17:41	17:45	0:04	TRANSFORMER FAULT
86	18-Jun-2021	GULBARGA	110	HV1,HV2	MYLAR_110	4:10	4:40	0:30	LINE CLEAR AVAILED
87	18-Jun-2021	GULBARGA	110	HV1	MYLAR_110	10:30	11:50	1:20	LINE CLEAR AVAILED
88	18-Jun-2021	GULBARGA	110	HV2	MYLAR_110	10:30	11:15	0:45	LINE CLEAR AVAILED
89	18-Jun-2021	GULBARGA	110	HV1	MADIYAL_110	11:00	11:05	0:05	TRANSFORMER FAULT
90	18-Jun-2021	GULBARGA	66	HV1	HANASI_66	15:50	16:00	0:10	LINE CLEAR AVAILED
91	18-Jun-2021	GULBARGA	66	ITTAGI-RENWSOLAR_IPP	ITTAGI_220	11:25	11:35	0:10	LINE CLEAR AVAILED
92	18-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
93	18-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
94	18-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	10:32	14:51	4:19	LINE CLEAR AVAILED
95	18-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:26	18:55	0:29	LINE CLEAR AVAILED
96	18-Jun-2021	HASSAN	220	HV2	CRPATNA_220	12:15	14:11	1:56	LINE CLEAR AVAILED
97	18-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:34	16:54	1:20	LINE CLEAR AVAILED
98	18-Jun-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	6:10	6:22	0:12	LINE FAULT
99	18-Jun-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	6:22	16:53	10:31	LINE FAULT
100	18-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:34	16:54	1:20	NFBC ISSUED
101	18-Jun-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	6:22	16:54	10:32	LINE FAULT
102	18-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:28	10:40	1:12	LINE CLEAR AVAILED
103	18-Jun-2021	HASSAN	110	HV3	HIRIYADKA_110	16:34	16:39	0:05	TRANSFORMER FAULT
104	18-Jun-2021	HASSAN	110	HV1	HOSANGADI_110	15:45	16:20	0:35	LINE CLEAR AVAILED
105	18-Jun-2021	HASSAN	110	HV1	HOSANGADI_110	16:40	17:41	1:01	LINE CLEAR AVAILED
106	18-Jun-2021	HASSAN	110	JOG-JST1	mghejog_gen	14:38	14:50	0:12	LINE FAULT
107	18-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	14:38	16:04	1:26	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
108	18-Jun-2021	HASSAN	110	LPH-MGHE 2	lph_gen	14:42	15:09	0:27	HAND TRIPPED
109	18-Jun-2021	HASSAN	110	HV3	SAGARA_110	11:10	12:36	1:26	LINE CLEAR AVAILED
110	18-Jun-2021	HASSAN	110	SAGARA- JST2	SAGARA_110	14:39	16:02	1:23	LINE FAULT
111	18-Jun-2021	HASSAN	110	SALATHU-BNTWAL	HOSANGADI_110	10:51	14:21	3:30	LINE CLEAR AVAILED
112	18-Jun-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	15:30	15:44	0:14	HAND TRIPPED
113	18-Jun-2021	HASSAN	66	LV2	CRPATNA_220	12:14	14:11	1:57	LINE CLEAR AVAILED
114	18-Jun-2021	HASSAN	66	HV1	ALDUR_66	11:19	13:16	1:57	LINE CLEAR AVAILED
115	18-Jun-2021	HASSAN	66	HV1	ALDUR_66	14:04	14:19	0:15	LINE CLEAR AVAILED
116	18-Jun-2021	HASSAN	66	HV1	BYACHANAHALLI_66	14:18	15:07	0:49	LINE CLEAR AVAILED
117	18-Jun-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	14:17	14:24	0:07	LINE CLEAR AVAILED
118	18-Jun-2021	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	12:46	12:48	0:02	HAND TRIPPED
119	18-Jun-2021	HASSAN	66	HV1	KANDLI_66	12:58	13:39	0:41	LINE CLEAR AVAILED
120	18-Jun-2021	HASSAN	66	HV2	KANDLI_66	11:36	12:56	1:20	LINE CLEAR AVAILED
121	18-Jun-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	7:55	8:10	0:15	LINE FAULT
122	18-Jun-2021	MYSURU	66	HV1	BYLUKUPPE_66	10:53	11:35	0:42	LINE CLEAR AVAILED
123	18-Jun-2021	MYSURU	66	HV2	CHANDAKAVADI_66	9:57	10:45	0:47	LINE CLEAR AVAILED
124	18-Jun-2021	MYSURU	66	HV1	GUNDULPET_66	9:30	9:50	0:20	LINE CLEAR AVAILED
125	18-Jun-2021	MYSURU	66	KADAKOLA-MANDAKALLI	MANDAKALLI_66	10:26	16:21	5:54	NFBC ISSUED
126	18-Jun-2021	MYSURU	66	KR PETE 220-BOOKANAKERE	SHEELUNERE_66 GANJIGERE_66 BOOKANAKERE_66 CHINAKURALI_66 BANANGADI_66	9:05	9:11	0:05	LINE FAULT
129	18-Jun-2021	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	13:11	13:19	0:08	LINE FAULT
130	18-Jun-2021	MYSURU	66	RK NAGARA-MANDAKALLI	MANDAKALLI_66	10:20	16:20	6:00	NFBC ISSUED
131	18-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
132	18-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
133	18-Jun-2021	TUMKUR	220	TR-1	CHITRADURGA_220	10:21	11:07	0:46	TRANSFORMER FAULT
134	18-Jun-2021	TUMKUR	110	HONNAVALI 110-ADAN SOLAR_66	ADAN SOLAR_IPP_66	13:32	14:23	0:50	LINE CLEAR AVAILED
135	18-Jun-2021	TUMKUR	110	TR-1	HONNAVALI_110	13:04	14:34	1:30	LINE CLEAR AVAILED
136	18-Jun-2021	TUMKUR	110	TR-2	HONNAVALI_110	13:04	14:34	1:30	LINE CLEAR AVAILED
137	18-Jun-2021	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	13:29	14:15	0:45	LINE CLEAR AVAILED
138	18-Jun-2021	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	14:25	14:31	0:05	HAND TRIPPED
139	18-Jun-2021	TUMKUR	110	TR-1	SAMPIGE_110	15:02	15:31	0:28	LINE CLEAR AVAILED
140	18-Jun-2021	TUMKUR	110	TR-2	SAMPIGE_110	11:00	12:40	1:39	LINE CLEAR AVAILED
141	18-Jun-2021	TUMKUR	66	TR-2	BADDIHALLI_66	9:38	11:01	1:22	LINE CLEAR AVAILED
142	18-Jun-2021	TUMKUR	66	TR-2	BALENAHALLI_66	8:45	9:39	0:53	LINE CLEAR AVAILED
143	18-Jun-2021	TUMKUR	66	BENNEHALLI-SUZLON1_IPP_66,	SUZLON1_IPP_66,	17:05	17:17	0:11	HAND TRIPPED
144	18-Jun-2021	TUMKUR	66	TR-1	BENKIKERE_66	10:30	12:48	2:17	LINE CLEAR AVAILED
145	18-Jun-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	15:45	15:51	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
146	18-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_220	10:21	11:15	0:53	LINE FAULT
147	18-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA2	CHITRADURGA_220	11:06	11:15	0:09	LINE FAULT
148	18-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA3	CHITRADURGA_220	10:21	11:15	0:53	LINE FAULT
149	18-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	16:16	16:38	0:21	LINE FAULT
150	18-Jun-2021	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	10:21	11:08	0:46	TRANSFORMER FAULT
151	18-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP_66	5:28	5:34	0:06	HAND TRIPPED
152	18-Jun-2021	TUMKUR	66	TR-3	HARIYABBE_66	17:00	17:35	0:34	LINE CLEAR AVAILED
153	18-Jun-2021	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	5:37	10:12	4:35	MAIN SUPPLY FAILURE
154	18-Jun-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	5:37	10:12	4:34	MAIN SUPPLY FAILURE
155	18-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	2:54	2:59	0:05	MAIN SUPPLY FAILURE
156	18-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:04	8:14	0:10	MAIN SUPPLY FAILURE
157	18-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:22	9:03	0:41	MAIN SUPPLY FAILURE
158	18-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:23	11:37	0:13	MAIN SUPPLY FAILURE
159	18-Jun-2021	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	6:02	6:37	0:34	LINE FAULT
160	18-Jun-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	16:00	18:50	2:50	LINE CLEAR AVAILED
161	18-Jun-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	16:00	18:50	2:50	LINE CLEAR AVAILED
162	18-Jun-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 2	16:00	18:54	2:54	LINE CLEAR AVAILED
163	18-Jun-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 1	16:00	18:54	2:54	LINE CLEAR AVAILED
164	18-Jun-2021	TUMKUR	66	TR-2	SANIKERE_66	16:10	16:15	0:04	TRANSFORMER FAULT
1	19-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	19-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	19-Jun-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	19-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
5	19-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	19-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	19-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	19-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
9	19-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	19-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
11	19-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
12	19-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN,LINE CLEAR AVAILED
13	19-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
14	19-Jun-2021	BAGALKOT	110	110/11KV,HV1	UDYAMBAG_110	14:04 (15.06.2021)	19:17 (19.06.2021)	101:13hrs	TRANSFORMER CHARGED
15	19-Jun-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	22:27 (18.06.2021)			LINE OPEN, LINE FAULT
16	19-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN,LINE CLEAR AVAILED
17	19-Jun-2021	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	19:17	19:25	0:08	LOAD CURTAILMENT
18	19-Jun-2021	BAGALKOT	110	110/11KV,HV2	AKSHAYA COLONY_110	13:32	14:25	0:53	LINE CLEAR AVAILED
19	19-Jun-2021	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	15:08	16:32	1:24	NFBC ISSUED
20	19-Jun-2021	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	19:59	20:19	0:20	LINE FAULT
21	19-Jun-2021	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	20:24	21:00	0:36	LINE FAULT
22	19-Jun-2021	BAGALKOT	110	ATHANI220-THAUSHI(BALIGERI)	THAUSHI_110	19:59	20:19	0:20	LINE FAULT
23	19-Jun-2021	BAGALKOT	110	ATHANI220-THAUSHI(BALIGERI)	THAUSHI_110	20:24	21:00	0:36	LINE FAULT
24	19-Jun-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	19:18	19:29	0:11	LOAD CURTAILMENT
25	19-Jun-2021	BAGALKOT	220	BIDNAL-NAGJHARI(NAGJHARI2)	BIDNAL_220	6:47	7:53	1:06	LINE FAULT
26	19-Jun-2021	BAGALKOT	220	BIDNAL-NAGJHARI(NAGJHARI2)	BIDNAL_220	7:54	12:18	4:24	LINE FAULT
27	19-Jun-2021	BAGALKOT	110	110/11KV,HV2(HV4)	GAJENDRAGAD_110	19:18	19:33	0:15	LOAD CURTAILMENT
28	19-Jun-2021	BAGALKOT	110	GHATAPRABHA220- MANTUR(G)MUDALAGI)	MANTUR(G)_110	10:15	10:32	0:17	LINE FAULT
29	19-Jun-2021	BAGALKOT	110	110/11KV,HV1	GOKAK_110	12:07	12:08	0:01	LINE CLEAR AVAILED
30	19-Jun-2021	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	14:37	15:35	0:58	LINE CLEAR AVAILED
31	19-Jun-2021	BAGALKOT	110	110/33KV,HV1	PALA_33 HANAGAL_110	19:18	19:31	0:13	LOAD CURTAILMENT
32	19-Jun-2021	BAGALKOT	110	110/33KV,HV3	KOLIGUDDA_33 HIDIKAL_110	19:18	19:27	0:09	LOAD CURTAILMENT
33	19-Jun-2021	BAGALKOT	110	110/11KV,HV3	RUSTUMPUR LIS_33,BELGAUM W/S ST1_33,BELGAUM W/S ST 2&3 STATION NOT AFFECTED HIDIKAL DAM_110	16:37	17:06	0:29	HAND TRIPPED
34	19-Jun-2021	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	18:41	18:48	0:07	TRANSFORMER FAULT
35	19-Jun-2021	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	10:05	12:07	2:02	LINE CLEAR AVAILED
36	19-Jun-2021	BAGALKOT	110	110/11KV,HV1	KUDALA SANGAM_110	19:18	19:22	0:04	TRANSFORMER FAULT
37	19-Jun-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	17:22	21:05	3:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
38	19-Jun-2021	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	19:17	19:32	0:15	LOAD CURTAILMENT
39	19-Jun-2021	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	12:55	19:02	6:07	LOAD CURTAILMENT
40	19-Jun-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	0:17	0:30	0:13	LINE FAULT
41	19-Jun-2021	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	19:19	19:30	0:11	LOAD CURTAILMENT
42	19-Jun-2021	BAGALKOT	110	MUKARTHIHAL-NIDAGUNDI	NIDAGUNDI_110	22:17	22:26	0:09	LINE FAULT
43	19-Jun-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	6:59 (19.06.2021)			LINE OPEN, LINE FAULT
44	19-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	19:18	19:25	0:07	LOAD CURTAILMENT
45	19-Jun-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SAVALAGI_110	7:00	7:10	0:10	LOAD CURTAILMENT
46	19-Jun-2021	BAGALKOT	110	110/33KV, HV2(HV1)	KALABILAGI_33, TUNGAL LIS_33, STATION NOT AFFECTED SAVALAGI_110	19:18	19:35	0:17	LOAD CURTAILMENT
47	19-Jun-2021	BAGALKOT	110	110/11KV, HV3 (HV2)	STATION NOT AFFECTED SANKESHWAR_110	19:17	19:22	0:05	LOAD CURTAILMENT
48	19-Jun-2021	BAGALKOT	110	RON-GAMESH	GAMESH IPP_110 RON_110	16:38	16:42	0:04	HAND TRIPPED
49	19-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	9:22	9:42	0:20	TRANSFORMER FAULT
50	19-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	11:17	12:08	0:51	TRANSFORMER FAULT
51	19-Jun-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	6:58 (19.06.2021)			LINE OPEN, LINE FAULT
52	19-Jun-2021	BAGALKOT	110	SIRSI- KUMTA2	STATION NOT AFFECTED SIRSI_110	14:46	20:09	5:23	LINE FAULT
53	19-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	15:40	16:11	0:31	LINE FAULT
54	19-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	18:42	19:11	0:29	LINE FAULT
55	19-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	13:45	13:57	0:12	LOAD CHANGE OVER
56	19-Jun-2021	BENGALURU	66	HV2	KADUGODI	11:10	11:15	0:05	LINE CLEAR AVAILED
57	19-Jun-2021	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	11:33	11:50	0:17	LOAD CHANGE OVER
58	19-Jun-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	13:59	14:22	0:23	LOAD CHANGE OVER
59	19-Jun-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	17:42	17:50	0:08	LOAD CHANGE OVER
60	19-Jun-2021	BENGALURU	66	HV1	KORAMANGALA 220	8:40	9:10	0:30	TRANSFORMER FAULT
61	19-Jun-2021	BENGALURU	66	HV1	NAGANATHPURA 220	10:50	10:52	0:02	LINE CLEAR AVAILED
62	19-Jun-2021	BENGALURU	66	HV1	NAGANATHPURA 220	16:30	16:31	0:01	LINE CLEAR AVAILED
63	19-Jun-2021	BENGALURU	66	HV2	NAGANATHPURA 220	10:59	11:02	0:03	TRANSFORMER FAULT
64	19-Jun-2021	BENGALURU	66	HV1	DIVYASHREE TECH PARK	11:36	11:45	0:09	LINE CLEAR AVAILED
65	19-Jun-2021	BENGALURU	66	HV1	SHOBHA APARTMENT	15:12	15:17	0:05	LINE CLEAR AVAILED
66	19-Jun-2021	BENGALURU	66	HV2	SUBRAMANYAPURA 66	10:24	10:26	0:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
67	19-Jun-2021	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	17:21	19:10	1:49	LINE FAULT
68	19-Jun-2021	BENGALURU	66	HV1	KENGERI SATELLITE	12:58	13:15	0:17	LINE CLEAR AVAILED
69	19-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	11:20	11:50	0:30	LINE CLEAR AVAILED
70	19-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	13:37	13:48	0:11	LINE FAULT
71	19-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	20:15	21:15	1:00	LOAD CURTAILMENT
72	19-Jun-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	20:40	20:55	0:15	LOAD CURTAILMENT
73	19-Jun-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	20:55	21:13	0:18	LOAD CURTAILMENT
74	19-Jun-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	20:09	20:39	0:30	LOAD CURTAILMENT
75	19-Jun-2021	BENGALURU	66	HV1	ATTIBELE	11:49	12:00	0:10	LINE CLEAR AVAILED
76	19-Jun-2021	BENGALURU	66	HV1	ATTIBELE	19:50	20:25	0:35	TRANSFORMER FAULT
77	19-Jun-2021	BENGALURU	66	HV1	BANGARPET	11:43	11:47	0:03	LINE CLEAR AVAILED
78	19-Jun-2021	BENGALURU	66	HV3	BANGARPET	13:30	14:20	0:50	LINE CLEAR AVAILED
79	19-Jun-2021	BENGALURU	66	HV1	TEMAGONDALU	11:00	11:10	0:10	LINE CLEAR AVAILED
80	19-Jun-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	12:10	14:15	2:04	LINE FAULT
81	19-Jun-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	NO STATION AFFECTED	16:40 (19-06-2021)			LINE OPEN, LINE FAULT
82	19-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
83	19-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN, LINE FAULT
84	19-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
85	19-Jun-2021	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	0:53(19.6.21)			LINE OPEN, LINE FAULT
86	19-Jun-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:04(19.06.2021)			LINE OPEN, LINE CLEAR AVAILED
87	19-Jun-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	20:12(19.06.2021)			LINE OPEN, LINE CLEAR AVAILED
88	19-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	20:43(19.06.2021)			LINE OPEN, LINE CLEAR AVAILED
89	19-Jun-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	22:17(18.06.2021)	6:25(19.06.2021)	8:08HRS	LINE CHARGED
90	19-Jun-2021	GULBARGA	220	LINGAPUR-JINDAL1	LINGAPUR_220	9:26	15:42	6:16	NFBC ISSUED
91	19-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	2:32	6:28	3:56	LINE CLEAR AVAILED
92	19-Jun-2021	GULBARGA	220	HV2	SEDAM_220	19:14	21:22	2:08	LINE CLEAR AVAILED
93	19-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	21:08(19.06.2021)			LOAD CURTAILMENT
94	19-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:26	5:53	0:27	LINE FAULT
95	19-Jun-2021	GULBARGA	110	HV1	MANVI_110	1:50	3:55	2:05	TRANSFORMER FAULT
96	19-Jun-2021	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	8:00	8:10	0:10	LINE FAULT
97	19-Jun-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110	11:15	12:40	1:25	LINE CLEAR AVAILED
98	19-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:35	12:42	0:07	LINE FAULT
99	19-Jun-2021	GULBARGA	110	HV2	CHIDRI_110	21:30	21:55	0:25	TRANSFORMER FAULT
100	19-Jun-2021	GULBARGA	110	HV2	DEODURGA_110	11:40	14:00	2:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
101	19-Jun-2021	GULBARGA	110	HV2	ALIPUR_220	10:30	16:26	5:56	LINE CLEAR AVAILED
102	19-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG AON_110,DIGGI_110	5:26	5:31	0:05	LINE FAULT
103	19-Jun-2021	GULBARGA	110	HV1	MAHAGOAN_110	19:20	19:30	0:10	LOAD CURTAILMENT
104	19-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG AON_110,DIGGI_110	21:14	21:20	0:06	LINE FAULT
105	19-Jun-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	16:21	16:36	0:15	LINE FAULT
106	19-Jun-2021	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	12:20	17:32	5:12	NFBC ISSUED
107	19-Jun-2021	GULBARGA	66	BADALADUKU-KUDLIGI	KUDLIGI_66	3:40	4:00	0:20	MAIN SUPPLY FAILURE
108	19-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
109	19-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
110	19-Jun-2021	HASSAN	110	HV4	MANIPAL_110	12:45(19.06.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
111	19-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	11:27 (19.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
112	19-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:19	9:09	7:50	LINE CLEAR AVAILED
113	19-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:20	6:55	5:35	LINE CLEAR AVAILED
114	19-Jun-2021	HASSAN	220	HV2	KADUR_220	10:19	12:19	2:00	LINE CLEAR AVAILED
115	19-Jun-2021	HASSAN	110	LV2	KADUR_220	10:19	12:24	2:05	LINE CLEAR AVAILED
116	19-Jun-2021	HASSAN	110	HV2	KADUR_220	12:08	12:54	0:46	TRANSFORMER FAULT
117	19-Jun-2021	HASSAN	220	HV1	MSEZ_220	0:26	8:03	7:37	TRANSFORMER FAULT
118	19-Jun-2021	HASSAN	220	HV2	MSEZ_220	8:59	13:49	4:50	TRANSFORMER FAULT
119	19-Jun-2021	HASSAN	110	LV2	MSEZ_220	8:59	13:49	4:50	TRANSFORMER FAULT
120	19-Jun-2021	HASSAN	110	HV1	HALADY_110	19:18	19:39	0:21	TRANSFORMER FAULT
121	19-Jun-2021	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	12:33	14:23	1:50	LINE FAULT
122	19-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	10:46	13:19	2:33	LINE CLEAR AVAILED
123	19-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	16:13	16:50	0:37	LINE FAULT
124	19-Jun-2021	HASSAN	110	HV2	JOG_110	10:22	11:45	1:23	LINE CLEAR AVAILED
125	19-Jun-2021	HASSAN	110	HV2	JOG_110	11:50	12:20	0:30	HAND TRIPPED
126	19-Jun-2021	HASSAN	110	HV4	MANIPAL_110	10:04	12:36	2:32	LINE CLEAR AVAILED
127	19-Jun-2021	HASSAN	110	HV3	MANIPAL_110	15:03	15:05	0:02	HAND TRIPPED
128	19-Jun-2021	HASSAN	110	SAGARA-ALKLA	SAGARA_110	12:27	14:21	1:54	LINE FAULT
129	19-Jun-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:05	12:26	0:21	LINE CLEAR AVAILED
130	19-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	10:45	13:18	2:33	LINE CLEAR AVAILED
131	19-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	16:13	16:51	0:38	LINE FAULT
132	19-Jun-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:35	13:25	2:50	LINE CLEAR AVAILED
133	19-Jun-2021	HASSAN	66	HV2	HOLALUR_66	13:41	13:52	0:11	LINE CLEAR AVAILED
134	19-Jun-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:26	12:36	1:10	LINE CLEAR AVAILED
135	19-Jun-2021	HASSAN	66	HV1	MAGGE_66	12:18	12:40	0:22	LINE CLEAR AVAILED
136	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	12:18	18:35	6:17	LINE CLEAR AVAILED
137	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	18:55	19:05	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
138	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	19:50	20:01	0:11	TRANSFORMER FAULT
139	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	20:20	20:25	0:05	TRANSFORMER FAULT
140	19-Jun-2021	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	10:17	15:36	5:19	NFBC ISSUED
141	19-Jun-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:32	11:42	1:10	LINE CLEAR AVAILED
142	19-Jun-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:32	11:41	1:09	LINE CLEAR AVAILED
143	19-Jun-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:15	15:35	5:20	LINE CLEAR AVAILED
144	19-Jun-2021	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	10:22	15:35	5:13	LINE CLEAR AVAILED
145	19-Jun-2021	HASSAN	66	HV1	KIADB_66	10:30	16:37	6:07	LINE CLEAR AVAILED
146	19-Jun-2021	HASSAN	66	HV2	KIADB_66	10:30	16:37	6:07	LINE CLEAR AVAILED
147	19-Jun-2021	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	10:30	15:36	5:06	LINE CLEAR AVAILED
148	19-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
149	19-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
150	19-Jun-2021	HASSAN	110	HV4	MANIPAL_110	12:45(19.06.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
151	19-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	11:27 (19.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
152	19-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:19	9:09	7:50	LINE CLEAR AVAILED
153	19-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:20	6:55	5:35	LINE CLEAR AVAILED
154	19-Jun-2021	HASSAN	220	HV2	KADUR_220	10:19	12:19	2:00	LINE CLEAR AVAILED
155	19-Jun-2021	HASSAN	110	LV2	KADUR_220	10:19	12:24	2:05	LINE CLEAR AVAILED
156	19-Jun-2021	HASSAN	110	HV2	KADUR_220	12:08	12:54	0:46	TRANSFORMER FAULT
157	19-Jun-2021	HASSAN	220	HV1	MSEZ_220	0:26	8:03	7:37	TRANSFORMER FAULT
158	19-Jun-2021	HASSAN	220	HV2	MSEZ_220	8:59	13:49	4:50	TRANSFORMER FAULT
159	19-Jun-2021	HASSAN	110	LV2	MSEZ_220	8:59	13:49	4:50	TRANSFORMER FAULT
160	19-Jun-2021	HASSAN	110	HV1	HALADY_110	19:18	19:39	0:21	TRANSFORMER FAULT
161	19-Jun-2021	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	12:33	14:23	1:50	LINE FAULT
162	19-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	10:46	13:19	2:33	LINE CLEAR AVAILED
163	19-Jun-2021	HASSAN	110	JOG-JST2	mghejog_gen	16:13	16:50	0:37	LINE FAULT
164	19-Jun-2021	HASSAN	110	HV2	JOG_110	10:22	11:45	1:23	LINE CLEAR AVAILED
165	19-Jun-2021	HASSAN	110	HV2	JOG_110	11:50	12:20	0:30	HAND TRIPPED
166	19-Jun-2021	HASSAN	110	HV4	MANIPAL_110	10:04	12:36	2:32	LINE CLEAR AVAILED
167	19-Jun-2021	HASSAN	110	HV3	MANIPAL_110	15:03	15:05	0:02	HAND TRIPPED
168	19-Jun-2021	HASSAN	110	SAGARA-ALKLA	SAGARA_110	12:27	14:21	1:54	LINE FAULT
169	19-Jun-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:05	12:26	0:21	LINE CLEAR AVAILED
170	19-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	10:45	13:18	2:33	LINE CLEAR AVAILED
171	19-Jun-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	16:13	16:51	0:38	LINE FAULT
172	19-Jun-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:35	13:25	2:50	LINE CLEAR AVAILED
173	19-Jun-2021	HASSAN	66	HV2	HOLALUR_66	13:41	13:52	0:11	LINE CLEAR AVAILED
174	19-Jun-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:26	12:36	1:10	LINE CLEAR AVAILED
175	19-Jun-2021	HASSAN	66	HV1	MAGGE_66	12:18	12:40	0:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
176	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	12:18	18:35	6:17	LINE CLEAR AVAILED
177	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	18:55	19:05	0:10	TRANSFORMER FAULT
178	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	19:50	20:01	0:11	TRANSFORMER FAULT
179	19-Jun-2021	HASSAN	66	HV2	MAGGE_66	20:20	20:25	0:05	TRANSFORMER FAULT
180	19-Jun-2021	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	10:17	15:36	5:19	NFBC ISSUED
181	19-Jun-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:32	11:42	1:10	LINE CLEAR AVAILED
182	19-Jun-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:32	11:41	1:09	LINE CLEAR AVAILED
183	19-Jun-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:15	15:35	5:20	LINE CLEAR AVAILED
184	19-Jun-2021	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	10:22	15:35	5:13	LINE CLEAR AVAILED
185	19-Jun-2021	HASSAN	66	HV1	KIADB_66	10:30	16:37	6:07	LINE CLEAR AVAILED
186	19-Jun-2021	HASSAN	66	HV2	KIADB_66	10:30	16:37	6:07	LINE CLEAR AVAILED
187	19-Jun-2021	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	10:30	15:36	5:06	LINE CLEAR AVAILED
188	19-Jun-2021	MYSURU	66	HV2	ADDIHALLI_66	19:17	19:23	0:06	LOAD CURTAILMENT
189	19-Jun-2021	MYSURU	66	HV2	AKKIHEBBAL_66	19:17	19:23	0:06	LOAD CURTAILMENT
190	19-Jun-2021	MYSURU	66	HV1	BESAGARAHALLI_66	19:16	19:27	0:10	LOAD CURTAILMENT
191	19-Jun-2021	MYSURU	66	HV1	BGPURA_66	19:17	19:47	0:30	LOAD CURTAILMENT
192	19-Jun-2021	MYSURU	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBE_66	2:51	3:14	0:22	LINE FAULT
193	19-Jun-2021	MYSURU	66	HV1	DUNDANAHALLI_66	12:01	12:11	0:09	HAND TRIPPED
194	19-Jun-2021	MYSURU	66	HV1	GAMANAHALLY_66	14:34	15:48	1:13	LINE CLEAR AVAILED
195	19-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	2:15	2:50	0:34	LINE FAULT
196	19-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:03	19:17	13:13	LINE FAULT
197	19-Jun-2021	MYSURU	66	KUSHALNAGARA-RAMANATHAPURA 1	CB HALLI_66 ALUR SIDDAPUR_66 KANAGAL_66 RUDRAPATNA_66	14:02	14:08	0:05	HAND TRIPPED
198	19-Jun-2021	MYSURU	66	KUSHALNAGARA-RAMANATHAPURA 1	CB HALLI_66 ALUR SIDDAPUR_66 KANAGAL_66 RUDRAPATNA_66	14:36	14:38	0:01	HAND TRIPPED
199	19-Jun-2021	MYSURU	66	HV1	YELANDUR_66	19:16	19:20	0:03	LOAD CURTAILMENT
200	19-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
201	19-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
202	19-Jun-2021	TUMKUR	110	TR-1	DODDAGUNI_110	12:01	16:31	4:30	LINE CLEAR AVAILED
203	19-Jun-2021	TUMKUR	110	TR-2	DODDAGUNI_110	15:30	16:00	0:30	LINE CLEAR AVAILED
204	19-Jun-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	19:56	20:27	0:30	LOAD CURTAILMENT
205	19-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDDODDI_66	19:56	20:04	0:07	LOAD CURTAILMENT
206	19-Jun-2021	TUMKUR	66	BHARAMAGIRI-SRS HIRIYUR	BHARAMAGIRI_66	11:23	11:29	0:05	MAIN SUPPLY FAILURE
207	19-Jun-2021	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	5:32	5:47	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
208	19-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66,SOKKE_66	13:11	13:24	0:13	LINE FAULT
209	19-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	17:47	17:54	0:07	HAND TRIPPED
210	19-Jun-2021	TUMKUR	66	TR-1	HINDASGATTA_66	11:28	11:35	0:06	TRANSFORMER FAULT
211	19-Jun-2021	TUMKUR	66	TR-1	HIRIYUR_66	11:41	11:47	0:06	TRANSFORMER FAULT
212	19-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:27	9:40	0:13	LINE FAULT
213	19-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:39	17:56	0:16	LINE FAULT
214	19-Jun-2021	TUMKUR	66	HONNALLI 220kV- (LINGADAHALLI)CHANNAGIRI(NALLU R)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:05	6:15	0:09	LINE FAULT
215	19-Jun-2021	TUMKUR	66	TR-1	JIDDIGERE_66	14:57	15:43	0:46	LINE CLEAR AVAILED
216	19-Jun-2021	TUMKUR	66	TR-1	KATTIGE_66	13:08	13:22	0:13	TRANSFORMER FAULT
217	19-Jun-2021	TUMKUR	66	TR-1	KUNDUR_66	13:10	13:16	0:06	TRANSFORMER FAULT
218	19-Jun-2021	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	11:39	12:30	0:50	LINE CLEAR AVAILED
219	19-Jun-2021	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA(SIRA-2)	KALLAMBELLA_66, SIRA_66	11:00	12:10	1:10	LINE CLEAR AVAILED
220	19-Jun-2021	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66	11:00	12:10	1:10	LINE CLEAR AVAILED
221	19-Jun-2021	TUMKUR	66	TR-1	MADHUGIRI_66	6:06	6:10	0:04	TRANSFORMER FAULT
222	19-Jun-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	11:24	11:32	0:07	LOAD CURTAILMENT
223	19-Jun-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	9:07	9:14	0:06	TRANSFORMER FAULT
224	19-Jun-2021	TUMKUR	66	TR-2	SANIKERE_66	19:24	19:26	0:01	TRANSFORMER FAULT
225	19-Jun-2021	TUMKUR	66	TR-1	YADVANI_66	18:22	19:08	0:45	HAND TRIPPED
226	20-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
227	20-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
228	20-Jun-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
229	20-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
230	20-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
231	20-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
232	20-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
233	20-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
234	20-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
235	20-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)	11:39 (20.06.2021)	254:37hrs	LINE CHARGED
236	20-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
237	20-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN,LINE CLEAR AVAILED
238	20-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B) 110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
239	20-Jun-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	22:27 (18.06.2021)	14:46 (20.06.2021)	40:19hrs	LINE CHARGED
240	20-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN,LINE CLEAR AVAILED
241	20-Jun-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	6:59 (19.06.2021)	13:45 (20.06.2021)	30:46hrs	LINE CHARGED
242	20-Jun-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	6:58 (19.06.2021)	13:45 (20.06.2021)	30:47hrs	LINE CHARGED
243	20-Jun-2021	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	8:11	8:18	0:07	TRANSFORMER FAULT
244	20-Jun-2021	BAGALKOT	220	BAGEWADI-FORTUNE2	BAGEWADI_220	23:33 (20.06.2021)			LINE OPEN, LINE FAULT
245	20-Jun-2021	BAGALKOT	220	BAGEWADI-ADPH2	BAGEWADI_220	23:33 (20.06.2021)			LINE OPEN, LINE FAULT
246	20-Jun-2021	BAGALKOT	220	BAGEWADI-ATRIA1&2	BAGEWADI_220	23:33 (20.06.2021)			LINE OPEN, LINE FAULT
247	20-Jun-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	23:33 (20.06.2021)			LINE OPEN, LINE FAULT
248	20-Jun-2021	BAGALKOT	110	HAVERI220-TILUVALI(HANAGAL)	TILUVALI_110	9:19	9:42	0:23	LINE CLEAR AVAILED
249	20-Jun-2021	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	12:07	12:37	0:30	LINE CLEAR AVAILED
250	20-Jun-2021	BAGALKOT	110	110/11KV,HV1	LAKAMANAHALLI_110	15:26	16:39	1:13	LINE CLEAR AVAILED
251	20-Jun-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	10:46	13:15	2:29	LINE CLEAR AVAILED
252	20-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UDYAMBAG_110	11:46	12:59	1:13	LINE CLEAR AVAILED
253	20-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALI_110	9:10	12:53	3:43	TRANSFORMER FAULT
254	20-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	13:15 (20.06.2021)			LINE OPEN,LINE CLEAR AVAILED
255	20-Jun-2021	BAGALKOT	110	SIRSI- KUMTA1	STATION NOT AFFECTED SIRSI_110	17:25	20:10	2:45	LINE CLEAR AVAILED
256	20-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	10:49	11:07	0:18	LINE CLEAR AVAILED
257	20-Jun-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	14:35	14:58	0:23	LOAD CHANGE OVER
258	20-Jun-2021	BENGALURU	66	KORAMANGALA 220 -AUSTIN TOWN 2	NO STATION AFFECTED	14:10	15:56	1:46	LINE FAULT
259	20-Jun-2021	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	12:45	13:35	0:50	LINE FAULT
260	20-Jun-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	18:05	18:11	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
261	20-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	12:30	12:43	0:13	LINE FAULT
262	20-Jun-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:11	13:29	0:18	TRANSFORMER FAULT
263	20-Jun-2021	BENGALURU	66	HV1	HOSKOTE 66	13:55	14:03	0:08	TRANSFORMER FAULT
264	20-Jun-2021	BENGALURU	66	HV2	KACHMARANAHALLI	12:01	12:06	0:04	TRANSFORMER FAULT
265	20-Jun-2021	BENGALURU	66	HV1	TEMAGONDALU	7:40	7:50	0:10	LINE CLEAR AVAILED
266	20-Jun-2021	BENGALURU	66	BAGHMANE WTP - HAL 1	BAGHMANE WTP	12:40	12:45	0:05	LOAD CHANGE OVER
267	20-Jun-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	NO STATION AFFECTED	16:40 (19-06-2021)	0:52(20.6.21)	8:11HRS	LINE CHARGED
268	20-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
269	20-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN, LINE FAULT
270	20-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
271	20-Jun-2021	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	0:53(19.6.21)			LINE OPEN, LINE FAULT
272	20-Jun-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:04(19.06.2021)			LINE OPEN,LINE CLEAR AVAILED
273	20-Jun-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	20:12(19.06.2021)	5:43(20.06.2021)	9:31HRS	LINE CHARGED
274	20-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	20:43(19.06.2021)	5:53(20.06.2021)	9:10HRS	LINE CHARGED
275	20-Jun-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	21:45	22:10	0:25	MAIN SUPPLY FAILURE
276	20-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	21:08(19.06.2021)	6:00(20.06.2021)	8:52 HRS	LINE CHARGED
277	20-Jun-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	16:20	16:35	0:15	MAIN SUPPLY FAILURE
278	20-Jun-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	21:50	22:11	0:21	LINE FAULT
279	20-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	5:34	6:24	0:50	LINE FAULT
280	20-Jun-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	3:40	3:55	0:15	MAIN SUPPLY FAILURE
281	20-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
282	20-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
283	20-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	11:27 (19.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
284	20-Jun-2021	HASSAN	110	HV4	MANIPAL_110	12:45(19.06.2021)	16:14(20.6.2021)	27:28 hrs	TRANSFORMER CHARGED
285	20-Jun-2021	HASSAN	110	HV2	KADUR_220	14:25	14:56	0:31	TRANSFORMER FAULT
286	20-Jun-2021	HASSAN	220	HV1	KEMAR_220	4:05	4:26	0:21	TRANSFORMER FAULT
287	20-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:43	10:34	1:51	NFBC ISSUED
288	20-Jun-2021	HASSAN	110	LV1	KEMAR_220	4:05	4:27	0:22	TRANSFORMER FAULT
289	20-Jun-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	4:05	4:54	0:49	LINE FAULT
290	20-Jun-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	4:05	4:53	0:48	LINE FAULT
291	20-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:43	10:34	1:51	LINE CLEAR AVAILED
292	20-Jun-2021	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	7:09	7:22	0:13	LINE FAULT
293	20-Jun-2021	HASSAN	110	HV2	BANAVARA_110	19:15	19:20	0:05	TRANSFORMER FAULT
294	20-Jun-2021	HASSAN	110	HV1	HOSANGADI_110	12:00	14:16	2:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
295	20-Jun-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	5:53	16:51	10:58	LINE CLEAR AVOID
296	20-Jun-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	4:09	4:56	0:47	MAIN SUPPLY FAILURE
297	20-Jun-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:38	16:48	0:10	HAND TRIPPED
298	20-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	9:29	12:56	3:27	LINE CLEAR AVOID
299	20-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	16:16	16:26	0:10	HAND TRIPPED
300	20-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	9:29	12:56	3:27	LINE CLEAR AVOID
301	20-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	16:16	16:27	0:11	HAND TRIPPED
302	20-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	9:29	12:57	3:28	LINE CLEAR AVOID
303	20-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	16:16	16:28	0:12	HAND TRIPPED
304	20-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	9:29	16:28	6:59	LINE CLEAR AVOID
305	20-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	9:29	12:56	3:27	LINE CLEAR AVOID
306	20-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	16:16	16:27	0:11	HAND TRIPPED
307	20-Jun-2021	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	9:29	16:27	6:58	LINE CLEAR AVOID
308	20-Jun-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:16	11:02	0:46	LINE FAULT
309	20-Jun-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:16	10:44	0:28	LINE FAULT
310	20-Jun-2021	HASSAN	66	HV2	MAGGE_66	7:12	10:08	2:56	TRANSFORMER FAULT
311	20-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVOID
312	20-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVOID
313	20-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	11:27 (19.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
314	20-Jun-2021	HASSAN	110	HV4	MANIPAL_110	12:45(19.06.2021)	16:14(20.6.2021)	27:28 hrs	TRANSFORMER CHARGED
315	20-Jun-2021	HASSAN	110	HV2	KADUR_220	14:25	14:56	0:31	TRANSFORMER FAULT
316	20-Jun-2021	HASSAN	220	HV1	KEMAR_220	4:05	4:26	0:21	TRANSFORMER FAULT
317	20-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:43	10:34	1:51	NFBC ISSUED
318	20-Jun-2021	HASSAN	110	LV1	KEMAR_220	4:05	4:27	0:22	TRANSFORMER FAULT
319	20-Jun-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	4:05	4:54	0:49	LINE FAULT
320	20-Jun-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	4:05	4:53	0:48	LINE FAULT
321	20-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:43	10:34	1:51	LINE CLEAR AVOID
322	20-Jun-2021	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	7:09	7:22	0:13	LINE FAULT
323	20-Jun-2021	HASSAN	110	HV2	BANAVARA_110	19:15	19:20	0:05	TRANSFORMER FAULT
324	20-Jun-2021	HASSAN	110	HV1	HOSANGADI_110	12:00	14:16	2:16	LINE CLEAR AVOID
325	20-Jun-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	5:53	16:51	10:58	LINE CLEAR AVOID
326	20-Jun-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	4:09	4:56	0:47	MAIN SUPPLY FAILURE
327	20-Jun-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:38	16:48	0:10	HAND TRIPPED
328	20-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	9:29	12:56	3:27	LINE CLEAR AVOID
329	20-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	16:16	16:26	0:10	HAND TRIPPED
330	20-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	9:29	12:56	3:27	LINE CLEAR AVOID
331	20-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	16:16	16:27	0:11	HAND TRIPPED
332	20-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	9:29	12:57	3:28	LINE CLEAR AVOID

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
333	20-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	16:16	16:28	0:12	HAND TRIPPED
334	20-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	9:29	16:28	6:59	LINE CLEAR AVOIDED
335	20-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	9:29	12:56	3:27	LINE CLEAR AVOIDED
336	20-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	16:16	16:27	0:11	HAND TRIPPED
337	20-Jun-2021	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	9:29	16:27	6:58	LINE CLEAR AVOIDED
338	20-Jun-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:16	11:02	0:46	LINE FAULT
339	20-Jun-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:16	10:44	0:28	LINE FAULT
340	20-Jun-2021	HASSAN	66	HV2	MAGGE_66	7:12	10:08	2:56	TRANSFORMER FAULT
341	20-Jun-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	8:29	8:41	0:11	LINE FAULT
342	20-Jun-2021	MYSURU	66	KR PETE -HUYGONALLY 2	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	5:53	6:03	0:09	LINE FAULT
343	20-Jun-2021	MYSURU	66	KR PETE 220-KR PETE 1	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	5:53	6:02	0:09	LINE FAULT
344	20-Jun-2021	MYSURU	66	SFC SIVA-HV5	NO STATIONS EFFECTED	11:33	19:52	8:19	LINE CLEAR AVOIDED
345	20-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVOIDED
346	20-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVOIDED
347	20-Jun-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	10:29	15:51	5:21	LINE CLEAR AVOIDED
348	20-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON2_IPP_66	14:43	15:05	0:22	LINE FAULT
349	20-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:38	19:53	0:14	LINE FAULT
350	20-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	10:43	12:01	1:18	LINE CLEAR AVOIDED
351	20-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:37	10:43	0:05	LINE FAULT
352	20-Jun-2021	TUMKUR	66	TR-1	PDKOTE_66	11:26	11:37	0:11	TRANSFORMER FAULT
353	20-Jun-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA	PAVAGADA_220	21:44	21:47	0:03	HAND TRIPPED
354	20-Jun-2021	TUMKUR	66	RAMPURA66-WELSPUN SOLAR1	WELSPUN SOLAR_IPP_66	5:53	6:18	0:24	HAND TRIPPED
355	20-Jun-2021	TUMKUR	66	RAMPURA66-WELSPUN SOLAR1	WELSPUN SOLAR1_IPP_66	14:10	14:27	0:17	MAIN SUPPLY FAILURE
356	20-Jun-2021	TUMKUR	66	RAMPURA66-WELSPUN SOLAR2	WELSPUN SOLAR2_IPP_66	5:53	6:18	0:24	HAND TRIPPED
357	20-Jun-2021	TUMKUR	66	RAMPURA66-WELSPUN SOLAR2	WELSPUN SOLAR2_IPP_66	14:10	14:26	0:16	MAIN SUPPLY FAILURE
358	20-Jun-2021	TUMKUR	66	CHITRAHALLI-HDPURA	CHITRAHALLI_66	18:23	18:32	0:09	HAND TRIPPED
359	20-Jun-2021	TUMKUR	66	LOKEKERE-THYAVANAGI_66	LOKEKERE_66	9:23	9:39	0:15	LINE FAULT
360	21-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
361	21-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOIDED
362	21-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
363	21-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
364	21-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
365	21-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_ 220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
366	21-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_ 220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
367	21-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_ 110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
368	21-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_ 110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
369	21-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_ 220	21:02 (10.06.2021)			LINE OPEN,LINE CLEAR AVAILED
370	21-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_ 220	9:34 (11.06.2021)	12:18 (21.06.2021)	26:44hrs	LINE CHARGED
371	21-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_ 110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
372	21-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN,LINE CLEAR AVAILED
373	21-Jun-2021	BAGALKOT	220	BAGEWADI-FORTUNE2	BAGEWADI_ 220	23:33 (20.06.2021)	1:40 (21.06.2021)	2:07hrs	LINE CHARGED
374	21-Jun-2021	BAGALKOT	220	BAGEWADI-ADPH2	BAGEWADI_ 220	23:33 (20.06.2021)	2:12 (21.06.2021)	2:39hrs	LINE CHARGED
375	21-Jun-2021	BAGALKOT	220	BAGEWADI-ATRIA1&2	BAGEWADI_ 220	23:33 (20.06.2021)	1:30 (21.06.2021)	1:57hrs	LINE CHARGED
376	21-Jun-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_ 220	23:33 (20.06.2021)	1:29 (21.06.2021)	1:56hrs	LINE CHARGED
377	21-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_ 220	13:15 (20.06.2021)			LINE OPEN,LINE CLEAR AVAILED
378	21-Jun-2021	BAGALKOT	110	P G HUNSHYAL-MUDALAGI	MUDALAGI_110,NAGANUR_ 110,KULIGOD_ 110	8:32	8:39	0:07	LINE FAULT
379	21-Jun-2021	BAGALKOT	110	MR NAGAR-NARENDRA1&2	STATION NOT AFFECTED MRUTHYUNJAYANAGAR_110	5:18	15:29	10:11	LINE CLEAR AVAILED
380	21-Jun-2021	BAGALKOT	220	BAGEWADI-FORTUNE2	BAGEWADI_ 220	13:40	14:37	0:57	LINE CLEAR AVAILED
381	21-Jun-2021	BAGALKOT	220	BAGEWADI-FORTUNE2	BAGEWADI_ 220	16:47	17:10	0:23	LINE CLEAR AVAILED
382	21-Jun-2021	BAGALKOT	110	HAVERI(F1 C BREAKER0)- BASAVANAKATTI	STATION NOT AFFECTED BASAVANAKATTI_ 110	12:10	15:15	3:05	LINE CLEAR AVAILED
383	21-Jun-2021	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	14:10	15:07	0:57	LINE CLEAR AVAILED
384	21-Jun-2021	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	15:19	15:32	0:13	LINE CLEAR AVAILED
385	21-Jun-2021	BAGALKOT	110	JAMAKHANDI- SIDDAPUR(PRABHULINGESHWAR)	SIDDAPUR_110	5:59	7:04	1:05	LINE FAULT
386	21-Jun-2021	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)- JAMAKHANDI	JAMAKHANDI_110	6:14	6:21	0:07	HAND TRIPPED
387	21-Jun-2021	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_ 110	11:57	20:01	8:04	LINE CLEAR AVAILED
388	21-Jun-2021	BAGALKOT	110	KADANKOPPA-KAVALWADA	KADANAKOPPA_110	11:58 (21.06.2021)			LINE OPEN,LINE CLEAR AVAILED
389	21-Jun-2021	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	8:44	8:51	0:07	HAND TRIPPED
390	21-Jun-2021	BAGALKOT	110	MAHGALINGAPUR-BANAHATTI	BANAHATTI_110	5:59	6:17	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
391	21-Jun-2021	BAGALKOT	110	CHKKODI220-SADALAGA	SADALAGA_110	19:20	19:33	0:13	LINE FAULT
392	21-Jun-2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL 220	11:52	15:10	3:18	LINE FAULT
393	21-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI 110	16:57	17:13	0:16	TRANSFORMER FAULT
394	21-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SUARNASOUDHA 110	12:03	13:41	1:38	LINE CLEAR AVOIDED
395	21-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILIVALLI 110	13:01	13:28	0:27	LINE CLEAR AVOIDED
396	21-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILIVALLI 110	15:43	16:53	1:10	LINE CLEAR AVOIDED
397	21-Jun-2021	BENGALURU	66	HV2	HAL 220	10:45	10:50	0:05	LINE CLEAR AVOIDED
398	21-Jun-2021	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA, YEDUMADU, GODURU	18:36	19:20	0:44	MAIN SUPPLY FAILURE
399	21-Jun-2021	BENGALURU	220	HV2	KANAKAPURA 220	18:36	20:20	1:44	TRANSFORMER FAULT
400	21-Jun-2021	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	18:36	20:22	1:46	LINE CLEAR AVOIDED
401	21-Jun-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	18:36	20:22	1:46	LINE CLEAR AVOIDED
402	21-Jun-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNIGANAHALLI	18:36	20:35	1:59	LINE CLEAR AVOIDED
403	21-Jun-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI	18:36	20:22	1:46	LINE CLEAR AVOIDED
404	21-Jun-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	18:36	20:22	1:46	LINE CLEAR AVOIDED
405	21-Jun-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	18:36	20:22	1:46	LINE CLEAR AVOIDED
406	21-Jun-2021	BENGALURU	66	HV2	VIJAYANAGARA	14:48	14:59	0:11	LOAD CHANGE OVER
407	21-Jun-2021	BENGALURU	66	HV2	VIJAYANAGARA	16:13	16:19	0:06	LOAD CHANGE OVER
408	21-Jun-2021	BENGALURU	66	HV1	VIJAYANAGARA	16:23	16:25	0:02	LOAD CHANGE OVER
409	21-Jun-2021	BENGALURU	66	SHOBHA FOREST - SOMANAHALLI 220	SHOBHA FOREST	15:08	15:57	0:49	LINE FAULT
410	21-Jun-2021	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	NO STATION AFFECTED	15:02	18:53	3:51	LINE FAULT
411	21-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	6:20	6:29	0:08	LINE CLEAR AVOIDED
412	21-Jun-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	6:20	6:28	0:08	LINE CLEAR AVOIDED
413	21-Jun-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	6:16	6:23	0:07	LINE CLEAR AVOIDED
414	21-Jun-2021	BENGALURU	66	HV1	AVANI	14:00	14:05	0:04	LINE CLEAR AVOIDED
415	21-Jun-2021	BENGALURU	66	HV2	AVANI	12:15	12:20	0:05	LINE CLEAR AVOIDED
416	21-Jun-2021	BENGALURU	66	HV2	KIADB DB PURA 220	12:31	12:39	0:08	TRANSFORMER FAULT
417	21-Jun-2021	BENGALURU	66	HV2	KIADB DB PURA 220	13:02	13:29	0:27	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
418	21-Jun-2021	BENGALURU	66	HV1	KAMASAMUDRA	7:43	8:00	0:16	TRANSFORMER FAULT
419	21-Jun-2021	BENGALURU	66	HV2	MAASTHI	12:30	13:01	0:31	LINE CLEAR AVAILED
420	21-Jun-2021	BENGALURU	66	HV2	MAASTHI	21:01	21:05	0:04	TRANSFORMER FAULT
421	21-Jun-2021	BENGALURU	66	HV1	MULBAGLU	14:49	14:55	0:06	LINE CLEAR AVAILED
422	21-Jun-2021	BENGALURU	66	HV2	SOMAYAJJANAHALLI	17:05	18:00	0:54	LINE CLEAR AVAILED
423	21-Jun-2021	BENGALURU	66	HV2	YEDUMADU	15:25	15:30	0:05	LINE CLEAR AVAILED
424	21-Jun-2021	BENGALURU	66	HV1	YELAHANKA 220	12:48	12:51	0:02	LINE CLEAR AVAILED
425	21-Jun-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	6:19	6:26	0:06	LOAD CURTAILMENT
426	21-Jun-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	7:46	7:54	0:07	LINE FAULT
427	21-Jun-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	22:09	22:27	0:17	LOAD CURTAILMENT
428	21-Jun-2021	BENGALURU	220	HV1	KANAKAPURA 220	18:25(21/06/2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
429	21-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN, LINE FAULT
430	21-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN, LINE FAULT
431	21-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
432	21-Jun-2021	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	0:53(19.6.21)			LINE OPEN, LINE FAULT
433	21-Jun-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:04(19.06.2021)			LINE OPEN,LINE CLEAR AVAILED
434	21-Jun-2021	GULBARGA	220	LINGASUGUR-BAGEWAD1,2	LINGASUGUR_220	0:00	0:48	0:48	LINE CLEAR AVAILED
435	21-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	0:08	5:40	5:32	LINE CLEAR AVAILED
436	21-Jun-2021	GULBARGA	220	HV1	KAPNOOR_220	12:08	14:04	7:02	LINE CLEAR AVAILED
437	21-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:34(20.06.2021)	5:36(21.06.2021)	6:02HRS	LINE CHARGED
438	21-Jun-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	0:05	0:17	0:12	LINE FAULT
439	21-Jun-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MG SSK_IPP,BHALKI SUGAR_IPP	5:13	5:21	0:08	LINE FAULT
440	21-Jun-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	6:27	6:39	0:12	LINE FAULT
441	21-Jun-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	6:29	6:35	0:06	LINE FAULT
442	21-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	10:53	11:20	0:27	LINE CLEAR AVAILED
443	21-Jun-2021	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	11:34	16:25	4:51	NFBC ISSUED
444	21-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:44	15:50	4:06	LINE CLEAR AVAILED
445	21-Jun-2021	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MG SSK_IPP	12:17	13:06	0:49	LINE CLEAR AVAILED
446	21-Jun-2021	GULBARGA	110	HV1	GABBUR_110	12:25	12:30	0:05	LINE CLEAR AVAILED
447	21-Jun-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY	13:49	13:55	0:06	LINE FAULT
448	21-Jun-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	16:32	17:05	0:33	LINE FAULT
449	21-Jun-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	16:40	18:24	1:44	LINE CLEAR AVAILED
450	21-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	17:18	17:30	0:12	LINE CLEAR AVAILED
451	21-Jun-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	21:49	22:07	0:18	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
452	21-Jun-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	22:55	23:07	0:12	MAIN SUPPLY FAILURE
453	21-Jun-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	23:16	23:50	0:34	LINE FAULT
454	21-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAIED
455	21-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAIED
456	21-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	11:27 (19.06.2021)	20:45(21.06.2021)	57:18hrs	TRANSFORMER CHARGED
457	21-Jun-2021	HASSAN	110	GURUVAOKEMAR1	GURUVAYANAKERE_110	14:57	15:45	0:48	LINE FAULT
458	21-Jun-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	14:57	15:24	0:27	LINE FAULT
459	21-Jun-2021	HASSAN	110	HV2	KADUR_220	14:35	14:49	0:14	TRANSFORMER FAULT
460	21-Jun-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	14:57	15:44	0:47	LINE FAULT
461	21-Jun-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	14:57	15:21	0:24	LINE FAULT
462	21-Jun-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	14:10	14:15	0:05	HAND TRIPPED
463	21-Jun-2021	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	14:02	14:15	0:13	HAND TRIPPED
464	21-Jun-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	4:56	5:07	0:11	LINE FAULT
465	21-Jun-2021	HASSAN	66	HV1	MALLIPATNA_66	14:07	14:24	0:17	HAND TRIPPED
466	21-Jun-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	12:40	13:02	0:22	LINE FAULT
467	21-Jun-2021	HASSAN	66	HV1	SIGEBAGE_66	12:46	13:12	0:26	MAIN SUPPLY FAILURE
468	21-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAIED
469	21-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAIED
470	21-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	11:27 (19.06.2021)	20:45(21.06.2021)	57:18hrs	TRANSFORMER CHARGED
471	21-Jun-2021	HASSAN	110	GURUVAOKEMAR1	GURUVAYANAKERE_110	14:57	15:45	0:48	LINE FAULT
472	21-Jun-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	14:57	15:24	0:27	LINE FAULT
473	21-Jun-2021	HASSAN	110	HV2	KADUR_220	14:35	14:49	0:14	TRANSFORMER FAULT
474	21-Jun-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	14:57	15:44	0:47	LINE FAULT
475	21-Jun-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	14:57	15:21	0:24	LINE FAULT
476	21-Jun-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	14:10	14:15	0:05	HAND TRIPPED
477	21-Jun-2021	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	14:02	14:15	0:13	HAND TRIPPED
478	21-Jun-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	4:56	5:07	0:11	LINE FAULT
479	21-Jun-2021	HASSAN	66	HV1	MALLIPATNA_66	14:07	14:24	0:17	HAND TRIPPED
480	21-Jun-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	12:40	13:02	0:22	LINE FAULT
481	21-Jun-2021	HASSAN	66	HV1	SIGEBAGE_66	12:46	13:12	0:26	MAIN SUPPLY FAILURE
482	21-Jun-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	12:18	19:02	6:44	LINE FAULT
483	21-Jun-2021	MYSURU	66	HV3	KUSHALNAGARA_220	15:20	16:39	1:18	LINE CLEAR AVAIED
484	21-Jun-2021	MYSURU	66	ANEGOLA-HUYGONALLY	ANEGOLA_66	11:47	12:06	0:19	LINE FAULT
485	21-Jun-2021	MYSURU	66	HV1	BGNAGARA_66	12:30	12:49	0:18	LINE CLEAR AVAIED
486	21-Jun-2021	MYSURU	66	HV1	CHIKKA_MANDYA_66	12:06	13:10	1:04	LINE CLEAR AVAIED
487	21-Jun-2021	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	12:45	13:14	0:29	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
488	21-Jun-2021	MYSURU	66	HV2	HANNUR_66	17:56	18:19	0:22	TRANSFORMER FAULT
489	21-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
490	21-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
491	21-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAV ANI_66	6:15	6:26	0:11	LOAD CURTAILMENT
492	21-Jun-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	6:14	6:26	0:12	LOAD CURTAILMENT
493	21-Jun-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	22:00	22:06	0:05	LINE FAULT
494	21-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:58	9:14	3:16	NFBC ISSUED
495	21-Jun-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:01	14:26	0:25	LINE FAULT
496	21-Jun-2021	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	6:05	9:40	3:34	NFBC ISSUED
497	21-Jun-2021	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	7:10	9:40	2:29	NFBC ISSUED
498	21-Jun-2021	TUMKUR	66	TR-1	GUKEGENAHALLI_66	12:04	13:06	1:02	LINE CLEAR AVAILED
499	21-Jun-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	6:03	6:25	0:22	MAIN SUPPLY FAILURE
500	21-Jun-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:24	12:33	0:09	LINE FAULT
501	21-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	14:42	15:36	0:53	LINE CLEAR AVAILED
502	21-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	21:57	21:58	0:01	LINE FAULT
503	21-Jun-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	6:18	8:44	2:26	LINE FAULT
504	21-Jun-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	8:44	8:48	0:03	LINE FAULT
505	21-Jun-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	8:48	8:58	0:09	LINE FAULT
506	21-Jun-2021	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66,HOLAVINA HALLY_66	22:27	22:46	0:19	LINE FAULT
507	21-Jun-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	12:28	12:37	0:09	TRANSFORMER FAULT
508	21-Jun-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	14:11	14:20	0:08	TRANSFORMER FAULT
509	21-Jun-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA	SHYLAPURA_66	12:40	13:44	1:04	LINE CLEAR AVAILED
510	21-Jun-2021	TUMKUR	66	PAVAGADA220-YNHOSKOTE	YNHOSKOTE_66	12:40	13:44	1:04	LINE CLEAR AVAILED
511	21-Jun-2021	TUMKUR	66	TR-2	RAMAPURA_66	10:25	10:35	0:09	TRANSFORMER FAULT
512	21-Jun-2021	TUMKUR	66	TR-2	RAMAPURA_66	11:20	11:35	0:15	TRANSFORMER FAULT
513	21-Jun-2021	TUMKUR	66	TR-2	RAMAPURA_66	11:45	11:56	0:11	TRANSFORMER FAULT
514	21-Jun-2021	TUMKUR	66	SANIKERE- CHALLAKERE	SANIKERE_66	9:24	9:30	0:05	HAND TRIPPED
515	21-Jun-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	5:42	9:38	3:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
516	21-Jun-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	5:42	9:38	3:55	LINE CLEAR AVAILED
517	21-Jun-2021	TUMKUR	66	THALLAK 220-PRPURA	PRPURA_66,VVPURA_66,MY LANAHALLI_66,DYAVARANA HALLI_66	5:42	9:38	3:55	LINE CLEAR AVAILED
518	21-Jun-2021	TUMKUR	66	TR-1	SHYLAPURA_66	14:40	19:27	4:47	LINE CLEAR AVAILED