

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 03.08.21 TO 09.08.2021

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1	3-Aug-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	3-Aug-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
3	3-Aug-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
4	3-Aug-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
5	3-Aug-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
6	3-Aug-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
7	3-Aug-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
8	3-Aug-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
9	3-Aug-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
10	3-Aug-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
11	3-Aug-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
12	3-Aug-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
13	3-Aug-2021	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
14	3-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
15	3-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
16	3-Aug-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
17	3-Aug-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
18	3-Aug-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
19	3-Aug-2021	BAGALKOT	110	DAMBAL-AKHILAGYA	STATION NOT AFFECTED DAMBAL_110	17:05 (02.08.2021)	10:00 (03.08.2021)	16:55HRS	LINE CHARGED
20	3-Aug-2021	BAGALKOT	110	HUBLI220-RAMANKOPPA	STATION NOT AFFECTED HUBLI_220	23:11 (02.08.2021)	17:06 (03.08.2021)	17:55HRS	LINE CHARGED
21	3-Aug-2021	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	ALBAL_110	8:20	8:29	0:09	HAND TRIPPED
22	3-Aug-2021	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:50 (03.08.2021)			LINE OPEN:LINE CLEAR AVAILED
23	3-Aug-2021	BAGALKOT	220	NARENDRA-KANABARGI1	STATION NOT AFFECTED NARENDRA_220	11:24	15:32	4:08	LINE CLEAR VAILED
24	3-Aug-2021	BAGALKOT	110	110/11KV,HV1	BIDNAL_110	14:29	16:42	2:13	LINE CLEAR VAILED
25	3-Aug-2021	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	8:03	8:34	0:31	LINE CLEAR VAILED
26	3-Aug-2021	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	12:36	13:36	1:00	LINE CLEAR VAILED
27	3-Aug-2021	BAGALKOT	110	KAVALWADA-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	11:39	13:06	1:27	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
28	3-Aug-2021	BAGALKOT	110	110/11KV,HV1(3)	MACHE_110	7:27	7:41	0:14	LINE CLEAR VAILED
29	3-Aug-2021	BAGALKOT	110	110/11KV,HV2(4)	MACHE_110	7:00	11:10	4:10	LINE CLEAR VAILED
30	3-Aug-2021	BAGALKOT	110	110/11KV,HV1	NAVALGUND_110	15:44	15:52	0:08	HAND TRIPPED
31	3-Aug-2021	BAGALKOT	110	110/11KV,HV1	NAVALGUND_110	9:32	10:40	1:08	LINE CLEAR VAILED
32	3-Aug-2021	BAGALKOT	110	RANEBENNUR- RATTIHALI(TUMMINAKATTI)	STATION NOT AFFECTED RANEBENNUR_220	16:36	16:45	0:09	HAND TRIPPED
33	3-Aug-2021	BAGALKOT	110	MUNDAGOD(RAMANAKOPPA)- SIGGOAN	SIGGOAN_110	3:30	4:01	0:31	LINE FAULT
34	3-Aug-2021	BAGALKOT	110	SAVANUR-SIGGOAN	SIGGOAN_110	3:30	3:59	0:29	LINE FAULT
35	3-Aug-2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	8:15	8:22	0:07	TRANSFORMER FAULT
36	3-Aug-2021	BAGALKOT	110	TUMMINAKATTI-RANEBENNUR220	STATION NOT AFFECTED TUMMINAKATTI_110	16:37	17:24	0:47	HAND TRIPPED
37	3-Aug-2021	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI	12:25	12:30	0:05	LOAD CHANGE OVER
38	3-Aug-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	12:45	12:50	0:05	LOAD CHANGE OVER
39	3-Aug-2021	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI	13:30	13:50	0:20	LINE FAULT
40	3-Aug-2021	BENGALURU	66	BYADRAHALLI - T G HALLI	KODIGEHALLI, TAVAREKERE	13:30	14:48	1:18	LINE FAULT
41	3-Aug-2021	BENGALURU	66	HV1	DASHAVARA	12:30	12:35	0:05	TRANSFORMER FAULT
42	3-Aug-2021	BENGALURU	66	HV2	KHODAYS 220	13:05	13:07	0:02	LINE CLEAR VAILED
43	3-Aug-2021	BENGALURU	66	HV1	KUMBALAGODU	12:06	14:16	2:10	LINE CLEAR VAILED
44	3-Aug-2021	BENGALURU	66	HV2	CHAKAVELU	14:47	18:53	4:05	LINE CLEAR VAILED
45	3-Aug-2021	BENGALURU	66	HV2	GUDEMARANAHALLI	10:25	10:30	0:05	LINE CLEAR VAILED
46	3-Aug-2021	BENGALURU	66	HV3	KGF	16:15	16:29	0:13	LINE CLEAR VAILED
47	3-Aug-2021	BENGALURU	66	HV1	KGF	14:56	15:22	0:25	LINE CLEAR VAILED
48	3-Aug-2021	BENGALURU	66	HV1	KGF	15:35	15:45	0:10	LINE CLEAR VAILED
49	3-Aug-2021	BENGALURU	66	HV2	KGF	15:10	15:40	0:30	LINE CLEAR VAILED
50	3-Aug-2021	BENGALURU	66	HV1	MAASTHI	9:51	10:35	0:43	TRANSFORMER FAULT
51	3-Aug-2021	BENGALURU	66	HV2	SIDDALAGATTA	10:15	10:20	0:04	LINE CLEAR VAILED
52	3-Aug-2021	BENGALURU	66	HV2	SIDDALAGATTA	16:44	16:46	0:01	LINE CLEAR VAILED
53	3-Aug-2021	BENGALURU	66	HV1	SM MANGALA	16:16	16:28	0:11	LINE CLEAR VAILED
54	3-Aug-2021	BENGALURU	66	HV2	VIDHURASHWATHA	13:30	13:56	0:26	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
55	3-Aug-2021	BENGALURU	66	HV2	VIDHURASHWATHA	15:42	15:55	0:12	TRANSFORMER FAULT
56	3-Aug-2021	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	12:25	12:55	0:29	LINE CLEAR VAILED
57	3-Aug-2021	BENGALURU	66	HOSUR RAMAPURA - NITRALI	NITRALI	11:42	14:33	2:51	LINE CLEAR VAILED
58	3-Aug-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	10:13	10:21	0:08	LINE FAULT
59	3-Aug-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:46	17:50	0:13	LINE FAULT
60	3-Aug-2021	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	18:24	18:27	0:13	LOAD CHANGE OVER
61	3-Aug-2021	BENGALURU	66	HV2	NRS 220	4:55(3-8-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
62	3-Aug-2021	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	23:34(03/08/2021)			LINE OPEN:LINE FAULT
63	3-Aug-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
64	3-Aug-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	3:10(02.08.2021)	7:55(03.08.2021)	29:45HRS	LINE CHARGED
65	3-Aug-2021	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	21:17(02.08.2021)			LINE OPEN:LINE CLEAR AVAILED
66	3-Aug-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:06(03.08.2021)			LINE OPEN:LINE CLEAR AVAILED
67	3-Aug-2021	GULBARGA	220	SHAHABAD-RAICHUR1	JEWARGI_110	8:02	16:40	8:38	LINE CLEAR VAILED
68	3-Aug-2021	GULBARGA	220	RAICHUR-SHAHAPUR1	GOOGLE_110	6:28	6:38	0:10	LINE FAULT
69	3-Aug-2021	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	15:34	17:35	2:01	NFBC ISSUED
70	3-Aug-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	8:05	16:41	8:36	LINE CLEAR VAILED
71	3-Aug-2021	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
72	3-Aug-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
73	3-Aug-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	8:20	16:40	8:20	LINE CLEAR VAILED
74	3-Aug-2021	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:35	5:40	0:05	LINE FAULT
75	3-Aug-2021	GULBARGA	110	HV2	HATTI_110	21:30	21:32	0:02	TRANSFORMER FAULT
76	3-Aug-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	10:29	16:29	6:00	LINE CLEAR VAILED
77	3-Aug-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	1:54	2:06	0:12	LINE FAULT
78	3-Aug-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	1:58	2:06	0:08	LINE FAULT
79	3-Aug-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	19:07	19:13	0:06	LINE FAULT
80	3-Aug-2021	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	2:55	3:05	0:10	LINE FAULT
81	3-Aug-2021	GULBARGA	110	SINDHANOOR-ADVIAARESHWARA	ADVI AMRESHWARA_110	3:25	3:45	0:20	LINE FAULT
82	3-Aug-2021	GULBARGA	110	SINDHANOOR-ADVIAARESHWARA	ADVI AMRESHWARA_110	19:35	19:45	0:10	LINE FAULT
83	3-Aug-2021	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	22:55	23:05	0:10	LINE FAULT
84	3-Aug-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREH ALLI_110,MALLAPUR_110	9:28	9:44	0:16	LINE FAULT
85	3-Aug-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREH ALLI_110,MALLAPUR_110	11:03	11:13	0:10	LINE FAULT
86	3-Aug-2021	GULBARGA	110	MADLAPUR-BYAGAWAT2	MADLAPUR_110,MANVI_110	20:22	20:32	0:10	LINE FAULT
87	3-Aug-2021	GULBARGA	110	MADLAPUR-BYAGAWAT2	MADLAPUR_110,MANVI_110	23:14	23:24	0:10	LINE FAULT
88	3-Aug-2021	GULBARGA	110	MADLAPUR-BYAGAWAT2	MADLAPUR_110,MANVI_110	3:08	3:18	0:10	LINE FAULT
89	3-Aug-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	3:10	3:15	0:05	LINE FAULT
90	3-Aug-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	4:15	4:37	0:22	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
91	3-Aug-2021	GULBARGA	66	HV2	TAMBRAHALI_66	17:58	18:11	0:13	TRANSFORMER FAULT
92	3-Aug-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
93	3-Aug-2021	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
94	3-Aug-2021	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
95	3-Aug-2021	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
96	3-Aug-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:39 (2.08.2021)	6:40(03.08.2021)	7:01hrs	LINE CHARGED
97	3-Aug-2021	HASSAN	220	HV1	ARSK2	18:20 (2.08.2021)	18:12 (3.08.2021)	23:51 hrs	TRANSFORMER CHARGED
98	3-Aug-2021	HASSAN	110	LV1	ARSK2	18:20 (2.08.2021)	18:12 (3.08.2021)	23:51 hrs	TRANSFORMER CHARGED
99	3-Aug-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	10:14	11:50	1:36	LINE CLEAR VAILED
100	3-Aug-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	12:05	12:12	0:07	LINE FAULT
101	3-Aug-2021	HASSAN	220	HV2	MSEZ_220	9:44	16:31	6:47	LINE CLEAR VAILED
102	3-Aug-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	13:48	15:12	1:24	LINE FAULT
103	3-Aug-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	13:48	14:53	1:05	LINE FAULT
104	3-Aug-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	10:14	11:50	1:36	LINE CLEAR VAILED
105	3-Aug-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:48	14:07	0:19	MAIN SUPPLY FAILURE
106	3-Aug-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:48	14:07	0:19	MAIN SUPPLY FAILURE
107	3-Aug-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:48	14:06	0:18	MAIN SUPPLY FAILURE
108	3-Aug-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:48	14:07	0:19	MAIN SUPPLY FAILURE
109	3-Aug-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:48	14:08	0:20	MAIN SUPPLY FAILURE
110	3-Aug-2021	HASSAN	110	HV2	ANAVATTI_110	13:48	14:12	0:24	TRANSFORMER FAULT
111	3-Aug-2021	HASSAN	110	HV2	BANAVARA_110	12:35	13:15	0:40	LINE CLEAR VAILED
112	3-Aug-2021	HASSAN	110	LV2	MSEZ_220	9:44	16:31	6:47	LINE CLEAR VAILED
113	3-Aug-2021	HASSAN	110	HV1	NANDIKUR_110	18:50	18:53	0:03	TRANSFORMER FAULT
114	3-Aug-2021	HASSAN	110	HV2	NANDIKUR_110	18:50	20:40	1:50	TRANSFORMER FAULT
115	3-Aug-2021	HASSAN	110	NANDIKU-ISTR1	NANDIKUR_110	18:50	18:56	0:06	LINE FAULT
116	3-Aug-2021	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	18:50	18:54	0:04	LINE FAULT
117	3-Aug-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	18:50	18:53	0:03	LINE FAULT
118	3-Aug-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	18:50	18:56	0:06	LINE FAULT
119	3-Aug-2021	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	13:05	13:56	0:51	LINE CLEAR VAILED
120	3-Aug-2021	HASSAN	110	HV2	SHIKARIPURA_110	16:38	17:25	0:47	LINE CLEAR VAILED
121	3-Aug-2021	HASSAN	110	HV1	BRAHMAVARA_110	11:30	13:44	2:14	LINE CLEAR VAILED
122	3-Aug-2021	HASSAN	110	HV2	BRAHMAVARA_110	13:40	15:56	2:16	LINE CLEAR VAILED
123	3-Aug-2021	HASSAN	66	HV1	CHANNARAYAPATNA_66	10:19	16:02	5:43	LINE CLEAR VAILED
124	3-Aug-2021	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	12:05	12:13	0:08	LINE FAULT
125	3-Aug-2021	HASSAN	66	HV2	DIDIGA_66	10:30	11:54	1:24	LINE CLEAR VAILED
126	3-Aug-2021	HASSAN	66	HV1	BASAVAGHATTA_66	11:50	12:09	0:19	LINE CLEAR VAILED
127	3-Aug-2021	MYSURU	66	HV2	BILIKERE_66	10:59	13:00	2:00	LINE CLEAR VAILED
128	3-Aug-2021	MYSURU	66	HV2	CHINAKURALI_66 G	15:10	15:59	0:48	LINE CLEAR VAILED
129	3-Aug-2021	MYSURU	66	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	9:41	12:20	2:38	LINE CLEAR VAILED
130	3-Aug-2021	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:08	11:55	2:47	NFBC ISSUED
131	3-Aug-2021	MYSURU	66	G UKKADA-SR PATNA	SRIRANGAPATNA_66	12:30	15:56	3:25	LINE CLEAR VAILED
132	3-Aug-2021	MYSURU	66	HV2	KHBCOLONY_66	11:53	13:40	1:47	LINE CLEAR VAILED
133	3-Aug-2021	MYSURU	66	HV1	K_HONNALGERE_66	10:30	12:47	2:17	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
134	3-Aug-2021	MYSURU	66	HV2	K_HONNALGERE_66	12:28	14:26	1:57	LINE CLEAR VAILED
135	3-Aug-2021	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	14:51	17:15	2:24	LINE CLEAR VAILED
136	3-Aug-2021	MYSURU	220	KUSHALNAGARA 220-BASTIPURA 2	NO STATIONS EFFECTED	10:01	17:38	7:37	LINE CLEAR VAILED
137	3-Aug-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	20:43	20:52	0:09	LINE FAULT
138	3-Aug-2021	MYSURU	66	HV1	SINDHUVALLI_66	10:13	12:00	1:47	LINE CLEAR VAILED
139	3-Aug-2021	MYSURU	66	VIJAYANAGARA-HOOTAGALY	NO STATIONS EFFECTED	9:46	12:15	2:28	LINE CLEAR VAILED
140	3-Aug-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
141	3-Aug-2021	TUMKUR	110	TR-1	SHETTIKERE_110	12:25	12:45	0:20	LINE CLEAR VAILED
142	3-Aug-2021	TUMKUR	110	TR-2	SHETTIKERE_110	12:47	13:03	0:16	LINE CLEAR VAILED
143	3-Aug-2021	TUMKUR	110	TR-2	SHETTIKERE_110	17:00	17:52	0:51	LINE CLEAR VAILED
144	3-Aug-2021	TUMKUR	66	TR-2	AVAREGERE_66	11:02	16:36	5:34	LINE CLEAR VAILED
145	3-Aug-2021	TUMKUR	66	TR-1	HANGAL_66	10:39	14:35	3:56	LINE CLEAR VAILED
146	3-Aug-2021	TUMKUR	66	TR-2	HANGAL_66	14:19	17:00	2:40	LINE CLEAR VAILED
147	3-Aug-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	14:10	14:41	0:31	TRANSFORMER FAULT
148	3-Aug-2021	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66, SASALUHALLA_66	23:43	23:45	0:02	LINE FAULT
149	3-Aug-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	9:38	15:55	6:17	LINE CLEAR VAILED
150	3-Aug-2021	TUMKUR	66	TR-1	KALMARANAHALLI_66	13:08	13:33	0:24	LINE CLEAR VAILED
151	3-Aug-2021	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	4:54	5:31	0:36	LINE FAULT
152	3-Aug-2021	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	5:47	5:52	0:04	LINE FAULT
153	3-Aug-2021	TUMKUR	66	TR-1	PAVAGADA_220	9:33	9:40	0:06	TRANSFORMER FAULT
154	3-Aug-2021	TUMKUR	66	TR-1	PAVAGADA_220	13:07	13:10	0:03	TRANSFORMER FAULT
155	3-Aug-2021	TUMKUR	66	TR-2	YADVANI_66	9:03	12:34	3:31	LINE CLEAR VAILED
156	4-Aug-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
157	4-Aug-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
158	4-Aug-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
159	4-Aug-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
160	4-Aug-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
161	4-Aug-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
162	4-Aug-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
163	4-Aug-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
164	4-Aug-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
165	4-Aug-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
166	4-Aug-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
167	4-Aug-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
168	4-Aug-2021	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
169	4-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
170	4-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
171	4-Aug-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
172	4-Aug-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
173	4-Aug-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
174	4-Aug-2021	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:50 (03.08.2021)			LINE OPEN:LINE CLEAR AVAILED
175	4-Aug-2021	BAGALKOT	110	SAIPRIYA-ALBAL	ALBAL_110	16:10	19:39	3:29	LINE CLEAR VAILED
176	4-Aug-2021	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	16:10	19:39	3:29	LINE CLEAR VAILED
177	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	14:25	14:45	0:20	LINE CLEAR VAILED
178	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	ANKALI_110	19:07 (04.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
179	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	11:46	12:29	0:43	LINE CLEAR VAILED
180	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	KULIGERE CROSS_110	12:05	13:56	1:51	LINE CLEAR VAILED
181	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	8:04	13:52	5:48	TRANSFORMER FAULT
182	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	MUKARTHIHAL_110	10:34	10:50	0:16	TRANSFORMER FAULT
183	4-Aug-2021	BAGALKOT	110	NARGUND-BPCL	NARGUND_110	17:09	18:36	1:27	LINE FAULT
184	4-Aug-2021	BAGALKOT	110	110/11KV,HV2	NAVANAGAR(B)_110	11:10	14:32	3:22	LINE CLEAR VAILED
185	4-Aug-2021	BAGALKOT	110	110/11KV,HV4	SADALAGA_110	12:40	12:58	0:18	LINE CLEAR VAILED
186	4-Aug-2021	BAGALKOT	110	SIRSI220-SIRSI1(HUBLI)	SIRSI_110	13:56	15:11	1:15	LINE CLEAR VAILED
187	4-Aug-2021	BAGALKOT	110	SIRSI220-SIRSI2(KAVALWADA)	SIRSI_110	13:56	19:48	5:52	LINE CLEAR VAILED
188	4-Aug-2021	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,DHULKHED_33,NEV ARAGI_33 ZALKI_110	7:52	7:55	0:03	TRANSFORMER FAULT
189	4-Aug-2021	BENGALURU	66	HV2	B G ROAD	19:11	19:23	0:12	TRANSFORMER FAULT
190	4-Aug-2021	BENGALURU	66	HV2	B G ROAD	19:37	19:52	0:15	TRANSFORMER FAULT
191	4-Aug-2021	BENGALURU	66	HV2	B G ROAD	21:09	21:12	0:03	TRANSFORMER FAULT
192	4-Aug-2021	BENGALURU	66	HV2	BIDADI 220	11:25	11:27	0:02	LINE CLEAR VAILED
193	4-Aug-2021	BENGALURU	66	HV1	BIDADI 220	16:56	16:58	0:02	LINE CLEAR VAILED
194	4-Aug-2021	BENGALURU	66	HV2	BMTC	10:26	10:29	0:03	LINE CLEAR VAILED
195	4-Aug-2021	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT)	14:28	14:53	0:25	MAIN SUPPLY FAILURE
196	4-Aug-2021	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT)	14:28	15:00	0:32	MAIN SUPPLY FAILURE
197	4-Aug-2021	BENGALURU	66	GOKULA - HMT (EH)	HMT (EHT)	14:27	17:00	2:33	LINE FAULT
198	4-Aug-2021	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	14:27	17:00	2:33	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
199	4-Aug-2021	BENGALURU	66	GURUVINAPURA - BWSSB (EHT)	BWSSB (EHT)	7:13	7:27	0:14	LINE FAULT
200	4-Aug-2021	BENGALURU	66	KORMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY, NAL (EHT)	12:27	12:42	0:15	LINE CLEAR VAILED
201	4-Aug-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	14:27	14:31	0:04	LOAD CHANGE OVER
202	4-Aug-2021	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	15:20	15:25	0:05	LOAD CHANGE OVER
203	4-Aug-2021	BENGALURU	66	HV1	NANDINI LAYOUT	12:10	12:13	0:03	LINE CLEAR VAILED
204	4-Aug-2021	BENGALURU	220	HV2	NRS 220	11:02	11:20	0:18	TRANSFORMER FAULT
205	4-Aug-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	14:27	14:35	0:08	MAIN SUPPLY FAILURE
206	4-Aug-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	15:27	15:31	0:04	LOAD CHANGE OVER
207	4-Aug-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	14:26	14:45	0:19	LINE FAULT
208	4-Aug-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	14:26	14:45	0:19	LINE FAULT
209	4-Aug-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	8:45	17:15	8:30	LINE CLEAR VAILED
210	4-Aug-2021	BENGALURU	66	HV2	VIJAYANAGARA	11:31	11:51	0:20	MAIN SUPPLY FAILURE
211	4-Aug-2021	BENGALURU	66	HV1	VIJAYANAGARA	11:41	11:43	0:02	LOAD CHANGE OVER
212	4-Aug-2021	BENGALURU	66	HV1	VIJAYANAGARA	12:14	12:24	0:10	LOAD CHANGE OVER
213	4-Aug-2021	BENGALURU	66	HV2	VIJAYANAGARA	15:19	15:30	0:11	LOAD CHANGE OVER
214	4-Aug-2021	BENGALURU	66	VRISHABHAVATHI 220 - BANASHANKARI	BANASHANKARI	10:09	16:50	6:41	LINE CLEAR VAILED
215	4-Aug-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	NO STATION AFFECTED	8:29	12:55	4:26	LINE FAULT
216	4-Aug-2021	BENGALURU	66	HV1	PATH PALYA	10:27	10:48	0:21	LINE CLEAR VAILED
217	4-Aug-2021	BENGALURU	66	HV1	PATH PALYA	12:00	12:59	0:59	LINE CLEAR VAILED
218	4-Aug-2021	BENGALURU	66	HV2	MANCHENAHALLI	12:06	12:37	0:31	LINE CLEAR VAILED
219	4-Aug-2021	BENGALURU	66	HV2	CHAKAVELU	12:50	12:55	0:05	LINE CLEAR VAILED
220	4-Aug-2021	BENGALURU	66	VIDHURASTRVATHA - BAGEPALLI 2	NO STATION AFFECTED	19:52	19:55	0:03	LINE FAULT
221	4-Aug-2021	BENGALURU	66	SRINIVASPURA - DALASNUR	YELDUR	12:42	12:47	0:04	LINE FAULT
222	4-Aug-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	9:18	18:10	8:52	LINE CLEAR VAILED
223	4-Aug-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:04	17:23	0:18	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
224	4-Aug-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	10:00	18:09	8:09	LINE CLEAR VAILED
225	4-Aug-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	10:00	18:09	8:09	LINE CLEAR VAILED
226	4-Aug-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:12	13:20	0:08	TRANSFORMER FAULT
227	4-Aug-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	NO STATION AFFECTED	11:55	19:08	7:13	LINE CLEAR VAILED
228	4-Aug-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	11:55	19:06	7:11	LINE CLEAR VAILED
229	4-Aug-2021	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	23:34(03/08/2021)	00:52(04/08/2021)	1:18HRS	LINE CHARGED
230	4-Aug-2021	BENGALURU	66	HV2	NRS 220	4:55(3-8-2021)	22:06(04/08/2021)	17:11HRS	TRANSFORMER CHARGED
231	4-Aug-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
232	4-Aug-2021	BENGALURU	66	NRS 220 - IISc	NO STATION AFFECTED	4:00(04/08/2021)			LINE OPEN:LINE FAULT
233	4-Aug-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:06(03.08.2021)	6:22(04.08.2021)	9:16HRS	LINE CHARGED
234	4-Aug-2021	GULBARGA	220	ITTAGI-EMBASSEY_IPP,HARAKNAL_IPP	ITTAGI_220	18:50	18:55	0:05	LINE FAULT
235	4-Aug-2021	GULBARGA	220	HV1	KUSHTAGI_220	13:40	14:20	0:40	TRANSFORMER FAULT
236	4-Aug-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:06(04.08.2021)			LINE OPEN:LINE CLEAR AVAILED
237	4-Aug-2021	GULBARGA	220	HV2	KUDLIGI_220	6:00	6:40	0:40	TRANSFORMER FAULT
238	4-Aug-2021	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
239	4-Aug-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
240	4-Aug-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	0:05	0:21	0:16	LINE FAULT
241	4-Aug-2021	GULBARGA	110	HV3	KEREHALLI_110	6:16	6:26	0:10	TRANSFORMER FAULT
242	4-Aug-2021	GULBARGA	110	HV2	CHITAGUPPA_110	14:05	14:30	0:25	LINE CLEAR VAILED
243	4-Aug-2021	GULBARGA	110	HV1	CHITAGUPPA_110	14:40	15:20	0:40	LINE CLEAR VAILED
244	4-Aug-2021	GULBARGA	110	HV2	CHITAGUPPA_110	16:25	17:05	0:40	LINE CLEAR VAILED
245	4-Aug-2021	GULBARGA	110	HV2	TEKKALKOTE_110	15:00	15:05	0:05	TRANSFORMER FAULT
246	4-Aug-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	13:43	16:21	2:38	MAIN SUPPLY FAILURE
247	4-Aug-2021	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	13:55	14:07	0:12	LINE FAULT
248	4-Aug-2021	GULBARGA	110	HV1	MARAGUTTI_110	17:41	17:54	0:13	TRANSFORMER FAULT
249	4-Aug-2021	GULBARGA	110	HV3	KEREHALLI_110	12:25	12:30	0:05	TRANSFORMER FAULT
250	4-Aug-2021	GULBARGA	110	HV3	KEREHALLI_110	12:35	12:45	0:10	TRANSFORMER FAULT
251	4-Aug-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	23:48(04.08.2021)			LINE OPEN:LINE FAULT
252	4-Aug-2021	GULBARGA	110	HV2	KAVITAL_110	0:10	16:05	15:55	LINE CLEAR VAILED
253	4-Aug-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	20:11	20:30	0:19	MAIN SUPPLY FAILURE
254	4-Aug-2021	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	12:13	13:55	1:42	LINE CLEAR VAILED
255	4-Aug-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	1:58	2:06	0:08	LINE FAULT
256	4-Aug-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADVIAMARESHWAR_110	21:14	21:24	0:10	LINE FAULT
257	4-Aug-2021	GULBARGA	110	HV1	SHAHAPUR_220	17:40	17:50	0:10	TRANSFORMER FAULT
258	4-Aug-2021	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	12:04	12:19	0:15	LINE FAULT
259	4-Aug-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:08	1:33	0:25	LINE FAULT
260	4-Aug-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	5:21	5:31	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
261	4-Aug-2021	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	20:12	20:22	0:10	LINE FAULT
262	4-Aug-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	21:22	21:32	0:10	LINE FAULT
263	4-Aug-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	22:56	23:30	0:34	LINE FAULT
264	4-Aug-2021	GULBARGA	66	KUDLIGI-BANAVEKAL	BANAVEKAL_66	6:15	6:45	0:30	LINE FAULT
265	4-Aug-2021	GULBARGA	66	HV1,HV2	KOTTUR_66	10:31	14:57	4:26	LINE CLEAR VAILED
266	4-Aug-2021	GULBARGA	66	ITTAGI-RENEWSOLAR1&2_IPP,CLEANMAXSOLAR1&2_IPP	ITTAGI_220	18:50	18:55	0:05	LINE FAULT
267	4-Aug-2021	GULBARGA	66	HV1	ITTAGI_220	18:50	18:55	0:05	TRANSFORMER FAULT
268	4-Aug-2021	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
269	4-Aug-2021	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
270	4-Aug-2021	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
271	4-Aug-2021	HASSAN	110	JOG-NK2	mghejog_gen	15:10 (4.08.2021)			LINE OPEN:LINE CLEAR AVAILED
272	4-Aug-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)	14:15(4.08.2021)	67:58hrs	LINE CHARGED
273	4-Aug-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	9:51	14:58	5:07	LINE CLEAR VAILED
274	4-Aug-2021	HASSAN	110	HV2	BIRUR_110	11:00	12:45	1:45	LINE CLEAR VAILED
275	4-Aug-2021	HASSAN	110	HV2	BIRUR_110	16:34	18:05	1:31	LINE CLEAR VAILED
276	4-Aug-2021	HASSAN	110	HV1	BELAGUMBA_110	12:31	13:49	1:18	LINE CLEAR VAILED
277	4-Aug-2021	HASSAN	110	HV2	GERUMARA_110	17:02	17:37	0:35	LINE CLEAR VAILED
278	4-Aug-2021	HASSAN	110	KEMAR-BELMAN	KEMAR_220	6:16	9:49	3:33	LINE FAULT
279	4-Aug-2021	HASSAN	110	KEMAR-UPCL1	KEMAR_220	9:51	14:58	5:07	NFBC ISSUED
280	4-Aug-2021	HASSAN	110	HV1	KULASHEKARA_110	9:58	15:35	5:37	LINE CLEAR VAILED
281	4-Aug-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	17:05	17:50	0:45	LINE FAULT
282	4-Aug-2021	HASSAN	110	HV1	MOODABIDRE_110	17:05	17:50	0:45	TRANSFORMER FAULT
283	4-Aug-2021	HASSAN	110	HV2	MOODABIDRE_110	17:05	17:50	0:45	TRANSFORMER FAULT
284	4-Aug-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	17:05	17:50	0:45	LINE FAULT
285	4-Aug-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	17:05	17:50	0:45	HAND TRIPPED
286	4-Aug-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:05	17:50	0:45	HAND TRIPPED
287	4-Aug-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:24	14:13	3:49	LINE CLEAR VAILED
288	4-Aug-2021	HASSAN	110	HV1	SALATHUR_110	10:29	14:11	3:42	LINE CLEAR VAILED
289	4-Aug-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:29	14:11	3:42	LINE CLEAR VAILED
290	4-Aug-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	10:29	14:11	3:42	LINE CLEAR VAILED
291	4-Aug-2021	HASSAN	66	HV1	CRPATNA_66	10:15	16:06	5:51	LINE CLEAR VAILED
292	4-Aug-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:45	16:35	5:50	LINE CLEAR VAILED
293	4-Aug-2021	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	10:45	16:35	5:50	LINE CLEAR VAILED
294	4-Aug-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:43	12:43	2:00	LINE CLEAR VAILED
295	4-Aug-2021	HASSAN	66	HV1	KUDLIGERE_66	10:46	12:43	1:57	LINE CLEAR VAILED
296	4-Aug-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:43	12:42	1:59	LINE CLEAR VAILED
297	4-Aug-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:26	12:07	1:41	LINE CLEAR VAILED
298	4-Aug-2021	HASSAN	66	HV1	SIGEBAGE_66	10:43	12:43	2:00	LINE CLEAR VAILED
299	4-Aug-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:43	12:43	2:00	LINE CLEAR VAILED
300	4-Aug-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	10:30	12:43	2:13	NFBC ISSUED
301	4-Aug-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLY_66	9:50	9:55	0:05	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
302	4-Aug-2021	MYSURU	66	HV2	BGPURA_66	8:55	9:26	0:30	LINE CLEAR VAILED
303	4-Aug-2021	MYSURU	66	BOGADHI-HOOTGALLY	NO STATIONS EFFECTED	10:51	12:51	1:59	LINE CLEAR VAILED
304	4-Aug-2021	MYSURU	66	FTS-HOOTGALLY2	NO STATIONS EFFECTED	10:02	12:36	2:34	NFBC ISSUED
305	4-Aug-2021	MYSURU	66	HV1	JAKKANAHALLY_66	10:13	12:27	2:13	LINE CLEAR VAILED
306	4-Aug-2021	MYSURU	66	HV2	JAKKANAHALLY_66	12:10	13:56	1:46	LINE CLEAR VAILED
307	4-Aug-2021	MYSURU	66	HV1	KHBCOLONY_66	11:57	13:15	1:17	LINE CLEAR VAILED
308	4-Aug-2021	MYSURU	66	PANDAVAPURA-ATRIA1	NO STATIONS EFFECTED	17:31	17:33	0:01	HAND TRIPPED
309	4-Aug-2021	MYSURU	66	HV3	PONNAMPET_66	13:59	14:05	0:05	TRANSFORMER FAULT
310	4-Aug-2021	MYSURU	66	HV2	VIJAYANAGRAMYS_66	7:57	10:04	2:06	LINE CLEAR VAILED
311	4-Aug-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)	17:32 (04/08/2021)	1345:05 HRS	LINE CHARGED
312	4-Aug-2021	TUMKUR	220	TR-1	HONNALLI_220	12:58	14:28	1:30	LINE CLEAR VAILED
313	4-Aug-2021	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMPIGE_110	1:02	1:25	0:23	LINE FAULT
314	4-Aug-2021	TUMKUR	110	HONNAVALLI 110-KADUR220(ARASIKERE)	HONNAVALLI_110	18:46	19:10	0:23	LINE FAULT
315	4-Aug-2021	TUMKUR	110	HONNAVALLI 110-KADUR220(ARASIKERE)	HONNAVALLI_110	19:25	19:39	0:14	LINE FAULT
316	4-Aug-2021	TUMKUR	110	TR-2	HONNAVALLI_110	18:46	19:10	0:23	TRANSFORMER FAULT
317	4-Aug-2021	TUMKUR	110	TR-2	HONNAVALLI_110	19:25	19:39	0:14	TRANSFORMER FAULT
318	4-Aug-2021	TUMKUR	110	TR-2	TURUVEKERE_110	16:17	16:33	0:15	LINE CLEAR VAILED
319	4-Aug-2021	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	VIJAYA STEEL	10:01	16:58	6:57	LINE CLEAR VAILED
320	4-Aug-2021	TUMKUR	66	CHITRADURGA 220kV-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	10:49	12:15	1:25	LINE FAULT
321	4-Aug-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:07	15:17	0:10	LINE FAULT
322	4-Aug-2021	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	11:51	14:41	2:49	MAIN SUPPLY FAILURE
323	4-Aug-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	11:51	14:41	2:49	MAIN SUPPLY FAILURE
324	4-Aug-2021	TUMKUR	66	TR-3	HARIYABBE_66	17:09	17:17	0:08	TRANSFORMER FAULT
325	4-Aug-2021	TUMKUR	66	TR-1(HV-SIDE)	HAGALWADI_66	10:29	14:13	3:43	LINE CLEAR VAILED
326	4-Aug-2021	TUMKUR	66	TR-1(LV-SIDE)	HAGALWADI_66	10:29	14:12	3:43	LINE CLEAR VAILED
327	4-Aug-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:13	8:23	0:09	LINE FAULT
328	4-Aug-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:10	12:23	0:13	LINE FAULT
329	4-Aug-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	5:38	5:49	0:10	LINE FAULT
330	4-Aug-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:56	14:33	1:37	LINE CLEAR VAILED
331	4-Aug-2021	TUMKUR	66	TR-1(LV-SIDE)	HONNALLI_220	12:57	14:32	1:35	LINE CLEAR VAILED
332	4-Aug-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:56	14:34	1:37	LINE CLEAR VAILED
333	4-Aug-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	10:28	12:45	2:16	MAIN SUPPLY FAILURE
334	4-Aug-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	RAMCO CEMENT_EHT_66	6:07	6:12	0:05	LINE FAULT
335	4-Aug-2021	TUMKUR	66	TR-1	MATHOD_66	14:59	15:07	0:08	TRANSFORMER FAULT
336	4-Aug-2021	TUMKUR	66	TR-1	RAMAPURA_66	14:10	15:47	1:37	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
337	4-Aug-2021	TUMKUR	66	TR-2	RAMAPURA_66	6:56	9:33	2:36	LINE CLEAR VAILED
338	4-Aug-2021	TUMKUR	66	SASALUHALLA-CHIKKAJAJUR	SASALUHALLA_66	1:45	1:58	0:13	MAIN SUPPLY FAILURE
339	4-Aug-2021	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	0:40	1:42	1:01	LINE CLEAR VAILED
340	5-Aug-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
341	5-Aug-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
342	5-Aug-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
343	5-Aug-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
344	5-Aug-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
345	5-Aug-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
346	5-Aug-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
347	5-Aug-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
348	5-Aug-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
349	5-Aug-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
350	5-Aug-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
351	5-Aug-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
352	5-Aug-2021	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
353	5-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
354	5-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
355	5-Aug-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
356	5-Aug-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
357	5-Aug-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
358	5-Aug-2021	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:50 (03.08.2021)			LINE OPEN:LINE CLEAR AVAILED
359	5-Aug-2021	BAGALKOT	110	110/11KV,HV2	ANKALI_110	19:07 (04.08.2021)	16:56 (05.08.2021)	21:49HRS	TRANSFORMER CHARGED
360	5-Aug-2021	BAGALKOT	110	SAIPRIYA SUGAR -ALBAL	ALBAL_110	8:07	10:25	2:18	LINE CLEAR VAILED
361	5-Aug-2021	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	8:07	10:32	2:25	LINE CLEAR VAILED
362	5-Aug-2021	BAGALKOT	110	SAIPRIYA SUGAR -ALBAL	ALBAL_110	16:11	17:37	1:26	LINE CLEAR VAILED
363	5-Aug-2021	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	16:11	17:40	1:29	LINE CLEAR VAILED
364	5-Aug-2021	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	11:03	11:41	0:38	LINE CLEAR VAILED
365	5-Aug-2021	BAGALKOT	110	HAVERI-(TILUVALI)HANAGAL	HANAGAL_110	6:00	6:20	0:20	LINE FAULT
366	5-Aug-2021	BAGALKOT	110	110/11KV,HV1	MANTUR(G)_110	5:59	6:10	0:11	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
367	5-Aug-2021	BAGALKOT	110	110/11KV,HV2	MANTUR(G)_110	5:59	6:10	0:11	TRANSFORMER FAULT
368	5-Aug-2021	BAGALKOT	110	110/11KV,HV1	NAVALGUND_110	15:57	17:14	1:17	TRANSFORMER FAULT
369	5-Aug-2021	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	17:18	17:36	0:18	LINE CLEAR VAILED
370	5-Aug-2021	BAGALKOT	110	110/11KV,HV2(HV3)	RATTIHALI_110	21:22 (05.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
371	5-Aug-2021	BAGALKOT	110	SOUDATTI- (MUNAVALLI)SOUDATTI220(1)	STATION NOT AFFECTED SOUDATTI_110	11:21	13:12	1:51	NFBC ISSUED
372	5-Aug-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI1	STATION NOT AFFECTED SOUDATTI_220	11:21	13:12	1:51	LINE CLEAR VAILED
373	5-Aug-2021	BAGALKOT	110	SOUDATTI220-RAMDURGA1(NARGUND)	STATION NOT AFFECTED SOUDATTI_220	11:21	13:19	1:58	LINE CLEAR VAILED
374	5-Aug-2021	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMKHANDI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	2:49	11:01	8:12	LINE FAULT
375	5-Aug-2021	BAGALKOT	110	110/33KV. HV3	JRK SOLAR_33, BIDARI_33, HIREPADASALAGI_33 STATION NOT AFFECTED TODALBAGI_110	11:01	11:50	0:49	HAND TRIPPED
376	5-Aug-2021	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	10:45	15:52	5:07	LINE FAULT
377	5-Aug-2021	BAGALKOT	110	LOKAPUR-BAGALKOT220	STATION NOT AFFECTED LOKAPUR_110	11:35 (30.07.2021)	11:56 (05.08.2021)	144:21HRS	LINE CHARGED
378	5-Aug-2021	BENGALURU	66	RAMANAGARA - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA	9:25	20:05	10:40	LINE CLEAR VAILED
379	5-Aug-2021	BENGALURU	66	EXORA - CESSNA	EXORA	14:24	15:02	0:38	LINE FAULT
380	5-Aug-2021	BENGALURU	66	EXORA - KALYANI TECH PARK	KALYANI TECH PARK	14:24	15:50	1:26	LINE FAULT
381	5-Aug-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	10:08	10:11	0:03	LOAD CHANGE OVER
382	5-Aug-2021	BENGALURU	66	HV2	KHB	10:45	10:47	0:02	LINE CLEAR VAILED
383	5-Aug-2021	BENGALURU	66	HV2	KHB	13:23	13:25	0:02	LINE CLEAR VAILED
384	5-Aug-2021	BENGALURU	66	HV2	NRS 220	11:53	12:13	0:20	LINE CLEAR VAILED
385	5-Aug-2021	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	9:40	9:44	0:04	LOAD CHANGE OVER
386	5-Aug-2021	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	13:14	13:17	0:03	LOAD CHANGE OVER
387	5-Aug-2021	BENGALURU	66	SOBHA APARTMENT - HSR LAYOUT 220	SOBHA APARTMENT	14:24	14:50	0:26	LINE FAULT
388	5-Aug-2021	BENGALURU	66	SOBHA APARTMENT - CESSNA	CESSNA, EXORA,KALYANI TECH PARK	14:24	14:55	0:31	LINE FAULT
389	5-Aug-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	14:24	14:48	0:24	LINE FAULT
390	5-Aug-2021	BENGALURU	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	14:36	14:43	0:07	LINE FAULT
391	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	7:26	7:41	0:15	LINE FAULT
392	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	7:26	7:41	0:15	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
393	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	7:46	7:54	0:08	LINE CLEAR VAILED
394	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	7:46	8:08	0:22	LINE CLEAR VAILED
395	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:57	11:05	0:08	LINE FAULT
396	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:57	11:12	0:15	LINE FAULT
397	5-Aug-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:45	13:53	1:08	LINE CLEAR VAILED
398	5-Aug-2021	BENGALURU	66	HV1	VIJAYANAGARA	22:25	22:34	0:09	LOAD CHANGE OVER
399	5-Aug-2021	BENGALURU	66	HV2	VIJAYANAGARA	22:40	22:50	0:10	LOAD CHANGE OVER
400	5-Aug-2021	BENGALURU	66	TADIGOL - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	1:18	1:25	0:06	LINE FAULT
401	5-Aug-2021	BENGALURU	220	HV2	MALUR 220	5:30	5:50	0:20	TRANSFORMER FAULT
402	5-Aug-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	5:30	6:15	0:45	LINE FAULT
403	5-Aug-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	11:16	11:35	0:19	LINE CLEAR VAILED
404	5-Aug-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:30	5:55	0:25	MAIN SUPPLY FAILURE
405	5-Aug-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	5:30	5:51	0:21	MAIN SUPPLY FAILURE
406	5-Aug-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:45	10:50	0:05	LOAD CHANGE OVER
407	5-Aug-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	14:05	14:10	0:05	LOAD CHANGE OVER
408	5-Aug-2021	BENGALURU	66	HV1	VOLVO	22:16	22:59	0:43	TRANSFORMER FAULT
409	5-Aug-2021	BENGALURU	66	HV2	THAYALUR	8:30	8:47	0:17	LINE CLEAR VAILED
410	5-Aug-2021	BENGALURU	66	HV1	CHIKKENAHALLI	18:30	19:09	0:38	LINE CLEAR VAILED
411	5-Aug-2021	BENGALURU	66	HV1 CB	ARMY WELFARE	10:40	10:50	0:10	LINE CLEAR VAILED
412	5-Aug-2021	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	17:25	18:10	0:45	LINE CLEAR VAILED
413	5-Aug-2021	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	18:10	18:20	0:10	LINE FAULT
414	5-Aug-2021	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:15	9:30	0:15	LOAD CURTAILMENT
415	5-Aug-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	22:31(5-8-2021)			LINE OPEN:LINE FAULT
416	5-Aug-2021	BENGALURU	66	HEBBALA 220 - IISc	IISc	13:12(05/08/2021)			LINE OPEN:LINE FAULT
417	5-Aug-2021	BENGALURU	66	NRS 220 - A STATION 1	NO STATION AFFECTED	16:13(05/08/2021)			LINE OPEN:LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
418	5-Aug-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	23:58(05/08/2021)			LINE OPEN:LINE CLEAR AVAILED
419	5-Aug-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
420	5-Aug-2021	GULBARGA	400	BTPSG-RTPS	RTPS_400	10:45	19:59	9:14	LINE CLEAR VAILED
421	5-Aug-2021	GULBARGA	400	BTPSG-RTPS	RTPS_400	20:40	21:30	0:50	LINE FAULT
422	5-Aug-2021	GULBARGA	220	ALIPUR-RAGALPADU	NEELGUNDA_220,GUTTI_220	3:52	4:33	0:41	LINE FAULT
423	5-Aug-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:06(04.08.2021)	6:11(05.08.2021)	8:05HRS	LINE CHARGED
424	5-Aug-2021	GULBARGA	220	KUDLIGI-HM HOLE1	KUDLIGI_220	11:30	19:10	7:40	LINE CLEAR VAILED
425	5-Aug-2021	GULBARGA	220	KUDLIGI-HM HOLE2	KUDLIGI_220	12:05	19:10	7:05	LINE CLEAR VAILED
426	5-Aug-2021	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	3:50	6:30	2:40	LINE CLEAR VAILED
427	5-Aug-2021	GULBARGA	220	MALLAT-KAVITAL	KAVITAL_110	0:58	1:06	0:08	LINE FAULT
428	5-Aug-2021	GULBARGA	220	MALLAT-BYAGWAT	BYAGWAT_110	22:22	22:32	0:10	LINE FAULT
429	5-Aug-2021	GULBARGA	220	RAICHUR-SHAHAPUR1	GOOGLE_110	6:29	6:35	0:06	LINE FAULT
430	5-Aug-2021	GULBARGA	220	RAICHUR-JURALA2	JURALA2	19:18	22:10	2:52	LINE FAULT
431	5-Aug-2021	GULBARGA	220	RAICHUR-RTPS1	RTPS1	20:22	21:38	1:16	LINE FAULT
432	5-Aug-2021	GULBARGA	220	RAICHUR-RTPS2	RTPS2	20:22	22:14	1:52	LINE FAULT
433	5-Aug-2021	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
434	5-Aug-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
435	5-Aug-2021	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	3:54	4:30	0:36	MAIN SUPPLY FAILURE
436	5-Aug-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	3:31	3:39	0:08	LINE FAULT
437	5-Aug-2021	GULBARGA	110	GABUR-RAICHUR	GABUR_110	6:20	6:30	0:10	MAIN SUPPLY FAILURE
438	5-Aug-2021	GULBARGA	110	HV1	HANUMANAL_110	8:00	10:30	2:30	LINE CLEAR VAILED
439	5-Aug-2021	GULBARGA	110	HANUMNAL-KUSHTAGI	HANUMANAL_110	10:30	10:40	0:10	LINE CLEAR VAILED
440	5-Aug-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	23:48(04.08.2021)	0:04(05.08.2021)	0:16 HRS	LINE CHARGED
441	5-Aug-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	3:27	3:38	0:11	LINE FAULT
442	5-Aug-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	0:58	1:10	0:12	MAIN SUPPLY FAILURE
443	5-Aug-2021	GULBARGA	110	CHINCHOLI-MANEKHALI	CHINCHOLI_110	12:05	17:37	5:32	LINE CLEAR VAILED
444	5-Aug-2021	GULBARGA	110	CHINCHOLI-CHETINAD,RENEW SOLAR	CHINCHOLI_110	12:05	17:30	5:25	LINE CLEAR VAILED
445	5-Aug-2021	GULBARGA	110	HV1	CHINCHOLI_110	18:52	19:06	0:14	TRANSFORMER FAULT
446	5-Aug-2021	GULBARGA	110	HV2	SHAKTINAGAR_110	10:20	18:09	7:49	LINE CLEAR VAILED
447	5-Aug-2021	GULBARGA	110	HV1	SHAKTINAGAR_110	13:15	18:01	4:46	LINE CLEAR VAILED
448	5-Aug-2021	GULBARGA	110	SHAKTINAGAR-CHICKSUGUR,RAICHUR BIO MASS_IPP	SHAKTINAGAR_110	15:28	17:58	2:30	LINE CLEAR VAILED
449	5-Aug-2021	GULBARGA	110	HV1	CHIDRI_110	8:55	9:05	0:10	TRANSFORMER FAULT
450	5-Aug-2021	GULBARGA	110	HV1	KAMPLI_110	11:55	12:50	0:55	LINE CLEAR VAILED
451	5-Aug-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	3:45	3:59	0:14	LINE FAULT
452	5-Aug-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	3:10	3:15	0:05	LINE FAULT
453	5-Aug-2021	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	12:10	15:08	2:58	LINE CLEAR VAILED
454	5-Aug-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110	19:16	19:20	0:04	LINE FAULT
455	5-Aug-2021	GULBARGA	110	HV2	ALIPUR_220	4:36	4:50	0:14	TRANSFORMER FAULT
456	5-Aug-2021	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
457	5-Aug-2021	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
458	5-Aug-2021	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
459	5-Aug-2021	HASSAN	110	JOG-NK2	mghejog_gen	15:10 (4.08.2021)	17:32(5.8.2021)	26:22hrs	LINE CHARGED
460	5-Aug-2021	HASSAN	110	JOG-JLT4	mghejog_gen	23:42(5.8.2021)			LINE OPEN:LINE FAULT
461	5-Aug-2021	HASSAN	110	JOG110-MGHE	JOG_110	23:42(5.8.2021)			LINE OPEN:LINE FAULT
462	5-Aug-2021	HASSAN	110	LPH-MGHE 2	lph_gen	23:43(5.8.2021)			LINE OPEN:LINE FAULT
463	5-Aug-2021	HASSAN	66	HV2	ARAKALGUD_66	9:15(5.8.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
464	5-Aug-2021	HASSAN	110	HV2	AJJAMPURA_66	15:43	17:41	1:58	LINE CLEAR VAILED
465	5-Aug-2021	HASSAN	110	HV1	BANAVARA_110	10:20	18:20	8:00	LINE CLEAR VAILED
466	5-Aug-2021	HASSAN	110	HV2	BANAVARA_110	10:20	18:20	8:00	LINE CLEAR VAILED
467	5-Aug-2021	HASSAN	110	HV3	BANTWAL_110	14:43	16:48	2:05	LINE CLEAR VAILED
468	5-Aug-2021	HASSAN	110	HV2	GURUVAYANAKERE_110	9:54	18:50	8:56	LINE CLEAR VAILED
469	5-Aug-2021	HASSAN	110	HV1	JADE_110	13:05	13:24	0:19	LINE CLEAR VAILED
470	5-Aug-2021	HASSAN	110	HV2	JADE_110	13:20	13:30	0:10	LINE CLEAR VAILED
471	5-Aug-2021	HASSAN	110	JOG-JLT3	mghejog_gen	12:15	13:45	1:30	LINE CLEAR VAILED
472	5-Aug-2021	HASSAN	110	JOG-JLT4	mghejog_gen	13:39	14:22	0:43	LINE CLEAR VAILED
473	5-Aug-2021	HASSAN	110	JOG-JST1	mghejog_gen	15:14	16:00	0:46	LINE CLEAR VAILED
474	5-Aug-2021	HASSAN	110	JOG-JST2	mghejog_gen	16:01	16:39	0:38	LINE CLEAR VAILED
475	5-Aug-2021	HASSAN	110	JOG110-MGHE	JOG_110	12:15	13:47	1:32	LINE CLEAR VAILED
476	5-Aug-2021	HASSAN	110	KADUR-YGTI	KADUR_220	14:26	16:30	2:04	LINE CLEAR VAILED
477	5-Aug-2021	HASSAN	110	HV1	MADHUVANA_110	10:36	11:02	0:26	LINE CLEAR VAILED
478	5-Aug-2021	HASSAN	110	HV1	NANDIKUR_110	15:07	16:25	1:18	LINE CLEAR VAILED
479	5-Aug-2021	HASSAN	110	HV2	NANDIKUR_110	11:56	13:42	1:46	LINE CLEAR VAILED
480	5-Aug-2021	HASSAN	110	HV3	SAGARA_110	7:04	8:05	1:01	LINE CLEAR VAILED
481	5-Aug-2021	HASSAN	110	HV3	SAGARA_110	16:36	17:34	0:58	LINE CLEAR VAILED
482	5-Aug-2021	HASSAN	110	HV1	SHIKARIPURA_110	12:40	13:00	0:20	LINE CLEAR VAILED
483	5-Aug-2021	HASSAN	110	HV1	SHIRALKOPPA_220	11:50	14:39	2:49	LINE CLEAR VAILED
484	5-Aug-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:16	11:54	1:38	LINE CLEAR VAILED
485	5-Aug-2021	HASSAN	66	HV1	ARAKALGUD_66	10:27	13:08	2:41	LINE CLEAR VAILED
486	5-Aug-2021	HASSAN	66	HV1	HIRISAVE_66	11:40	12:39	0:59	LINE CLEAR VAILED
487	5-Aug-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:40	14:53	3:13	LINE CLEAR VAILED
488	5-Aug-2021	HASSAN	66	HV1	SAKLESH PURA_66	8:25	8:47	0:22	TRANSFORMER FAULT
489	5-Aug-2021	HASSAN	66	HV1	SAKLESH PURA_66	9:01	9:30	0:29	TRANSFORMER FAULT
490	5-Aug-2021	HASSAN	66	HV2	TAVARECHATNAHALLY_66	10:44	11:54	1:10	LINE CLEAR VAILED
491	5-Aug-2021	MYSURU	66	HV1	ANEGOLAL_66	11:01	11:07	0:06	HAND TRIPPED
492	5-Aug-2021	MYSURU	66	HV1	ANEGOLAL_66	13:39	13:40	0:01	HAND TRIPPED
493	5-Aug-2021	MYSURU	66	HV1	ARAKERE_66	21:02	21:05	0:02	TRANSFORMER FAULT
494	5-Aug-2021	MYSURU	66	DATAGALLI-HOOTAGALLI	NO STATIONS EFFECTED	10:47	11:58	1:11	NFBC ISSUED
495	5-Aug-2021	MYSURU	66	DR PETE-KUNTUR	MUGUR_66 TNARASIPURA_66 THAYURU_66 JANNUR_66 SANTHEMARAHALI_66	5:22	5:29	0:07	LINE FAULT
496	5-Aug-2021	MYSURU	66	DUNDANALLI-HULIYUR DURGA	DUNDANAHALLI_66	22:22	23:37	1:15	LINE CLEAR VAILED
497	5-Aug-2021	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	12:42(5.8.21)			LINE OPEN:LINE CLEAR AVAILED
498	5-Aug-2021	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	17:24	17:32	0:07	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
499	5-Aug-2021	MYSURU	66	HV1	JAKKANAHALLY_66	13:24	14:20	0:56	LINE CLEAR VAILED
500	5-Aug-2021	MYSURU	66	HV1	JAKKANAHALLY_66	15:30	17:43	2:13	LINE CLEAR VAILED
501	5-Aug-2021	MYSURU	66	JYOTHINAGARA-DK MAIDANA	NO STATIONS EFFECTED	9:42	12:20	2:38	LINE CLEAR VAILED
502	5-Aug-2021	MYSURU	66	HV1	JYOTHINAGARA_66	12:51	14:24	1:33	LINE CLEAR VAILED
503	5-Aug-2021	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	5:59	6:05	0:05	LINE FAULT
504	5-Aug-2021	MYSURU	66	K HONALAGERE-MADDUR	KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66 TUMBEKERE_66	9:05	9:20	0:14	HAND TRIPPED
505	5-Aug-2021	MYSURU	66	HV2	KMDODDI_66	12:27	14:45	2:17	LINE CLEAR VAILED
506	5-Aug-2021	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66 KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66 TALAGAVADI_66	7:53	8:03	0:09	HAND TRIPPED
507	5-Aug-2021	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	8:17	10:18	2:01	LINE CLEAR VAILED
508	5-Aug-2021	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	11:35	13:40	2:04	LINE CLEAR VAILED
509	5-Aug-2021	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66 K_HONNALGERE_66 TALAGAVADI_66	7:25	7:53	0:28	LINE FAULT
510	5-Aug-2021	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66 TALAGAVADI_66	10:56	11:10	0:14	LINE FAULT
511	5-Aug-2021	MYSURU	66	KUNTHUR-DR PETE	NO STATIONS EFFECTED	5:22	6:49	1:27	LINE FAULT
512	5-Aug-2021	MYSURU	66	KUSHALNAGARA-BYLUKUPPE	BYLUKUPPE_66	7:11	7:20	0:09	LINE FAULT
513	5-Aug-2021	MYSURU	66	MADDUR-KIADB MANDYA	NO STATIONS EFFECTED	13:57	14:07	0:10	HAND TRIPPED
514	5-Aug-2021	MYSURU	66	HV2	MYSORESOUTH_66	14:39	15:17	0:37	LINE CLEAR VAILED
515	5-Aug-2021	MYSURU	66	HV1	SANIVARASANTHE_66	13:15	13:39	0:24	LINE CLEAR VAILED
516	6-Aug-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
517	6-Aug-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
518	6-Aug-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
519	6-Aug-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
520	6-Aug-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
521	6-Aug-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
522	6-Aug-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
523	6-Aug-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
524	6-Aug-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
525	6-Aug-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
526	6-Aug-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
527	6-Aug-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
528	6-Aug-2021	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
529	6-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
530	6-Aug-2021	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
531	6-Aug-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
532	6-Aug-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
533	6-Aug-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
534	6-Aug-2021	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:50 (03.08.2021)			LINE OPEN:LINE CLEAR AVAILED
535	6-Aug-2021	BAGALKOT	110	110/11KV,HV2(HV3)	RATTIHALLI_110	21:22 (05.08.2021)	13:46 (06.08.2021)	16:24HRS	LINE CHARGED
536	6-Aug-2021	BAGALKOT	110	SAIPRIYA SUIGAR-ALBAL	ALBAL_110	8:41	11:01	2:20	LINE CLEAR VAILED
537	6-Aug-2021	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	8:43	11:01	2:18	LINE CLEAR VAILED
538	6-Aug-2021	BAGALKOT	110	SAIPRIYA SUIGAR-ALBAL	ALBAL_110	16:03	20:40	4:37	LINE CLEAR VAILED
539	6-Aug-2021	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	16:03	20:37	4:34	LINE CLEAR VAILED
540	6-Aug-2021	BAGALKOT	110	110/11KV,HV2	ANKALI_110	11:30	12:53	1:23	LINE CLEAR VAILED
541	6-Aug-2021	BAGALKOT	110	110/11KV,HV1	ANKALI_110	13:00	13:43	0:43	LINE CLEAR VAILED
542	6-Aug-2021	BAGALKOT	110	110/11KV,HV1	BIJAPUR_110	12:38	12:58	0:20	LINE CLEAR VAILED
543	6-Aug-2021	BAGALKOT	110	BASAVANAKATTI-ASPL	STATION NOT AFFECTED BASAVANAKATTI_110	9:18	11:54	2:36	NFBC ISSUED
544	6-Aug-2021	BAGALKOT	110	BASAVANAKATTI-ASPL	BASAVANAKATTI_110	11:56	11:59	0:03	NFBC ISSUED
545	6-Aug-2021	BAGALKOT	110	BASAVANAKATTI-ASPL	BASAVANAKATTI_110	12:14	14:27	2:13	LINE CLEAR VAILED
546	6-Aug-2021	BAGALKOT	110	110/11KV,HV2(4)	GAJENDRAGAD_110	7:10	7:32	0:22	LOAD CURTAILMENT
547	6-Aug-2021	BAGALKOT	110	110/33KV,HV1(3)	KUSUGAL_33,KMC_33 GOPANAKOPPA_110	10:01	18:25	8:24	LINE CLEAR VAILED
548	6-Aug-2021	BAGALKOT	110	110/33KV,HV2(4)	KUSUGAL_33,KMC_33 GOPANAKOPPA_110	10:02	16:41	6:39	LINE CLEAR VAILED
549	6-Aug-2021	BAGALKOT	110	110/11KV,HV3(1)	GOPANAKOPPA_110	10:01	13:39	3:38	LINE CLEAR VAILED
550	6-Aug-2021	BAGALKOT	110	110/11KV,HV4(2)	GOPANAKOPPA_110	10:01	14:30	4:29	LINE CLEAR VAILED
551	6-Aug-2021	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	10:02	13:38	3:36	LINE CLEAR VAILED
552	6-Aug-2021	BAGALKOT	110	110/33KV,HV2	NEERALAGI_33 GUTTAL_110	10:21	17:53	7:32	LINE CLEAR VAILED
553	6-Aug-2021	BAGALKOT	110	HAVERI220-GUTTAL	GUTTAL_110	14:45	16:15	1:30	LINE CLEAR VAILED
554	6-Aug-2021	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	11:46	13:09	1:23	LINE CLEAR VAILED
555	6-Aug-2021	BAGALKOT	220	KUDUCHI-CHIKKODI1	STATION NOT AFFECTED KUDUCHI_220	17:33	18:23	0:50	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
556	6-Aug-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	17:43	18:12	0:29	LINE FAULT
557	6-Aug-2021	BAGALKOT	110	110/11KV,HV1	KUDALSANGAM_110	7:10	7:16	0:06	LOAD CURTAILMENT
558	6-Aug-2021	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	15:49	15:59	0:10	LINE CLEAR VAILED
559	6-Aug-2021	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	12:01	13:15	1:14	LINE CLEAR VAILED
560	6-Aug-2021	BAGALKOT	110	110/11KV,HV2	MUKARTHIHAL_110	19:05	19:16	0:11	LINE CLEAR VAILED
561	6-Aug-2021	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	6:50	7:07	0:17	TRANSFORMER FAULT
562	6-Aug-2021	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	19:27	19:38	0:11	LOAD CURTAILMENT
563	6-Aug-2021	BAGALKOT	110	RAMDURG-(BAGALKOT)SOUDATTI2	STATION NOT AFFECTED RAMDURGA_110	10:16	12:57	2:41	NFBC ISSUED
564	6-Aug-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	14:21	14:24	0:03	LINE CLEAR VAILED
565	6-Aug-2021	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED SOUDATTI_220	13:51	14:29	0:38	LINE FAULT
566	6-Aug-2021	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	13:27	16:15	2:48	LINE FAULT
567	6-Aug-2021	BAGALKOT	110	110/33KV, HV4	DULAKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	7:13	7:18	0:05	TRANSFORMER FAULT
568	6-Aug-2021	BAGALKOT	110	110/33KV, HV4	DULAKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	7:52	7:56	0:04	TRANSFORMER FAULT
569	6-Aug-2021	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	1:54	6:31	4:37	LINE FAULT
570	6-Aug-2021	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	6:34	18:50	12:16	LINE FAULT
571	6-Aug-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	13:52	14:29	0:37	LINE CHARGED
572	6-Aug-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI2	STATION NOT AFFECTED SOUDATTI_220	10:14	12:58	2:44	LINE CLEAR VAILED
573	6-Aug-2021	BAGALKOT	110	SOUDATTI220-RAMDURG2	STATION NOT AFFECTED SOUDATTI_220	10:16	12:57	2:41	LINE CLEAR VAILED
574	6-Aug-2021	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	14:49	17:44	2:55	LINE FAULT
575	6-Aug-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SHIRGAON_110	9:27	14:59	5:32	LINE CLEAR VAILED
576	6-Aug-2021	BAGALKOT	110	TUMMINAKATTI-RANEENNUR220	STATION NOT AFFECTED TUMMINAKATTI_110	11:12 (06.08.2021)			LINE OPEN:LINE CLEAR AVAILED
577	6-Aug-2021	BAGALKOT	110	SOUDATTI-SOUDATTI220- 2(NARAGUND)	STATION NOT AFFECTED SOUDATTI_110	10:14	13:13	2:59	LINE CLEAR VAILED
578	6-Aug-2021	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	7:54	8:24	0:30	MAIN SUPPLY FAILURE
579	6-Aug-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	10:36	10:39	0:03	LOAD CHANGE OVER
580	6-Aug-2021	BENGALURU	66	ATTUR YELAHANKA - DG3	WELCASTE	7:54	8:05	0:11	LINE FAULT
581	6-Aug-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	12:08	12:11	0:03	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
582	6-Aug-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	16:19	16:22	0:03	LOAD CHANGE OVER
583	6-Aug-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	10:00	14:41	4:41	LINE CLEAR VAILED
584	6-Aug-2021	BENGALURU	66	HV1	GOLF LINK	13:33	13:35	0:02	LINE CLEAR VAILED
585	6-Aug-2021	BENGALURU	66	HV2	GOLF LINK	11:31	11:32	0:01	LINE CLEAR VAILED
586	6-Aug-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	17:04	18:33	1:29	LINE FAULT
587	6-Aug-2021	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	10:02	17:35	7:33	LINE CLEAR VAILED
588	6-Aug-2021	BENGALURU	66	HV1	KADUGODI	0:18	0:47	0:29	TRANSFORMER FAULT
589	6-Aug-2021	BENGALURU	66	HV1	KADUGODI	12:13	12:52	0:39	TRANSFORMER FAULT
590	6-Aug-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	18:00	18:10	0:10	LINE FAULT
591	6-Aug-2021	BENGALURU	66	HV1	RAJANUKUNTE	16:05	16:10	0:05	LINE CLEAR VAILED
592	6-Aug-2021	BENGALURU	66	HV1	VIJAYANAGARA	20:05	20:10	0:05	LOAD CHANGE OVER
593	6-Aug-2021	BENGALURU	66	HV1	VIJAYANAGARA	3:11	3:20	0:09	LOAD CHANGE OVER
594	6-Aug-2021	BENGALURU	66	HV2	VIJAYANAGARA	2:50	2:55	0:05	LOAD CHANGE OVER
595	6-Aug-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	0:01	2:04	2:03	LINE CLEAR VAILED
596	6-Aug-2021	BENGALURU	66	NRS 220 - VICTORIA	VICTORIA	0:01	2:42	2:41	LINE CLEAR VAILED
597	6-Aug-2021	BENGALURU	66	NRS 220 - A STATION 2	A STATION 66	0:11	2:21	2:10	LINE CLEAR VAILED
598	6-Aug-2021	BENGALURU	66	HV1	NRS 220	0:25	5:58	5:33	LINE CLEAR VAILED
599	6-Aug-2021	BENGALURU	66	HV2	NRS 220	0:25	5:59	5:34	LINE CLEAR VAILED
600	6-Aug-2021	BENGALURU	66	HV3	NRS 220	0:25	2:11	1:46	LINE CLEAR VAILED
601	6-Aug-2021	BENGALURU	66	HV4	NRS 220	0:32	1:58	1:26	LINE CLEAR VAILED
602	6-Aug-2021	BENGALURU	66	HV5	NRS 220	0:35	2:11	1:36	LINE CLEAR VAILED
603	6-Aug-2021	BENGALURU	220	HV1	NRS 220	0:35	3:06	2:31	LINE CLEAR VAILED
604	6-Aug-2021	BENGALURU	220	HV2	NRS 220	0:30	1:57	1:27	LINE CLEAR VAILED
605	6-Aug-2021	BENGALURU	66	HV1	VOLVO	15:33	16:01	0:28	TRANSFORMER FAULT
606	6-Aug-2021	BENGALURU	66	HV2	HOSKOTE 66	13:02	13:28	0:26	LINE CLEAR VAILED
607	6-Aug-2021	BENGALURU	66	VIDHURASTRAVATHA - BAGEPALLI	NO STATION AFFECTED	19:50	19:57	0:06	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
608	6-Aug-2021	BENGALURU	66	SRINIVASPURA - DALASNUR	YELDUR	12:51	12:56	0:04	LINE FAULT
609	6-Aug-2021	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	12:17	16:46	4:28	LINE CLEAR VAILED
610	6-Aug-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	16:45	17:11	0:25	LINE FAULT
611	6-Aug-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	2:07	2:14	0:06	LINE FAULT
612	6-Aug-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	19:24	20:01	0:37	LOAD CURTAILMENT
613	6-Aug-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	19:23	20:01	0:37	LOAD CURTAILMENT
614	6-Aug-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:01	18:15	8:14	LINE CLEAR VAILED
615	6-Aug-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:24	19:26	0:02	LOAD CURTAILMENT
616	6-Aug-2021	BENGALURU	66	ARMY - KONDASPURA	KONDASPURA	10:07	16:27	6:20	LINE CLEAR VAILED
617	6-Aug-2021	BENGALURU	66	HV1	KANAKAPURA 66	11:02	11:47	0:45	LINE CLEAR VAILED
618	6-Aug-2021	BENGALURU	66	WELCASTE STEEL - SRS PEENYA 220	WELCASTE STEEL	10:39	10:42	0:03	LOAD CHANGE OVER
619	6-Aug-2021	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	10:44	13:43	2:59	LINE CLEAR VAILED
620	6-Aug-2021	BENGALURU	66	HV1	KUTAGALU	12:53	15:06	2:12	LINE CLEAR VAILED
621	6-Aug-2021	BENGALURU	66	DABUSPETE 220 - NELMANGALA 66	NELMANGALA 66	10:20	10:33	0:13	LINE CLEAR VAILED
622	6-Aug-2021	BENGALURU	66	NRS 220 - IISc	NO STATION AFFECTED	4:00(04/08/2021)	7:12(06/08/2021)	33:12HRS	LINE CHARGED
623	6-Aug-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	23:58(05/08/2021)	2:05(06/08/2021)	2:07HRS	LINE CHARGED
624	6-Aug-2021	BENGALURU	66	HEBBALA 220 - IISc	IISc	13:12(05/08/2021)	4:54(06/08/2021)	15:01:00 HRS	LINE CHARGED
625	6-Aug-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
626	6-Aug-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	22:31(5-8-2021)	11:47(6-8-2021)	13:15HRS	LINE CHARGED
627	6-Aug-2021	GULBARGA	400	BTPSG-RTPS	RTPS_400	9:24	20:00	10:36	LINE CHARGED
628	6-Aug-2021	GULBARGA	400	BTPSG-RTPS	RTPS_400	22:51(05.08.2021)	02:02(06.08.2021)	6:11HRS	LINE CHARGED
629	6-Aug-2021	GULBARGA	400	BTPSG-RTPS	RTPS_400	2:05	9:24	7:19	LINE FAULT
630	6-Aug-2021	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	23:56(05.08.2021)	0:26(06.08.2021)	3:30HRS	LINE CHARGED
631	6-Aug-2021	GULBARGA	220	SHAHAPURO-SEDAM	SEDAM_220	20:36(06.08.2021)			LINE OPEN:LINE CLEAR AVAILED
632	6-Aug-2021	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
633	6-Aug-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
634	6-Aug-2021	GULBARGA	110	HV2	CHINCHOLI_110	7:10	7:20	0:10	LOAD CURTAILMENT
635	6-Aug-2021	GULBARGA	110	HV1	MAHAGOAN_110	7:08	7:33	0:25	LOAD CURTAILMENT
636	6-Aug-2021	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	5:12	5:30	0:18	LINE FAULT
637	6-Aug-2021	GULBARGA	110	HV3	YELBURGA_110	7:12	7:16	0:04	LOAD CURTAILMENT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
638	6-Aug-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	6:02	6:08	0:06	LINE FAULT
639	6-Aug-2021	GULBARGA	110	HV1	KURKUNTA_110	7:10	7:15	0:05	LOAD CURTAILMENT
640	6-Aug-2021	GULBARGA	110	HV3	CHIDRI_110	7:10	7:20	0:10	TRANSFORMER FAULT
641	6-Aug-2021	GULBARGA	110	HV3	ALAND_110	10:40	10:50	0:10	TRANSFORMER FAULT
642	6-Aug-2021	GULBARGA	110	HV1	GINIGERA_110	2:10	2:50	0:40	LINE CLEAR VAILED
643	6-Aug-2021	GULBARGA	110	HV2	HATTI_110	7:09	7:17	0:08	LOAD CURTAILMENT
644	6-Aug-2021	GULBARGA	110	HV1 & HV2	KOTTUR_110	7:10	7:20	0:10	LOAD CURTAILMENT
645	6-Aug-2021	GULBARGA	110	HV2	KOPPAP_110	10:50	11:12	0:22	LINE CLEAR VAILED
646	6-Aug-2021	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	20:01(06.08.2021)			LINE OPEN:LINE CLEAR AVAILED
647	6-Aug-2021	GULBARGA	110	HV3	LADHA_110	9:40	11:25	1:45	LINE CLEAR VAILED
648	6-Aug-2021	GULBARGA	110	HV1	LADHA_110	11:30	12:00	0:30	LINE CLEAR VAILED
649	6-Aug-2021	GULBARGA	110	HV3	KEREHALLI_110	11:00	11:10	0:10	TRANSFORMER FAULT
650	6-Aug-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	18:54	19:04	0:10	LINE FAULT
651	6-Aug-2021	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	19:02	19:09	0:07	LINE FAULT
652	6-Aug-2021	GULBARGA	110	LINGASUGUR-KAREPOWER	KAREPOWER_IPP,CHAYADEVI_IPP	21:05	21:10	0:05	LINE FAULT
653	6-Aug-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WA DAGERA_110,SANNATHI_IPP,COREG REENSUGARS_IPP	10:20	10:25	0:05	LINE FAULT
654	6-Aug-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	3:44	3:49	0:05	LINE FAULT
655	6-Aug-2021	GULBARGA	110	HV1 ,HV3	GULBARGAUNIVERSITY_110	12:40	13:30	0:50	LINE CLEAR VAILED
656	6-Aug-2021	GULBARGA	110	GABBUR_RAICHUR220	GABBUR_110	19:30	20:00	0:30	MAIN SUPPLY FAILURE
657	6-Aug-2021	GULBARGA	110	GABBUR_DEODURGA	GABBUR_110	23:15	23:25	0:10	LINE CLEAR VAILED
658	6-Aug-2021	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	18:55	19:05	0:10	MAIN SUPPLY FAILURE
659	6-Aug-2021	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	19:25	19:30	0:05	LINE FAULT
660	6-Aug-2021	GULBARGA	110	RAJESHWAR-SASTAPUR	RAJESHWAR_110	19:25	19:35	0:10	LINE FAULT
661	6-Aug-2021	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	20:52	21:02	0:10	LINE FAULT
662	6-Aug-2021	GULBARGA	110	HV1,HV2	MYLAR_110	16:06	16:40	0:34	LINE CLEAR VAILED
663	6-Aug-2021	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66	8:54	14:25	5:31	LINE CLEAR VAILED
664	6-Aug-2021	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKANAH ALLI_66,HAGARIBOMMANAHALLI_6 6,RR STEELS_IPP	6:02	6:07	0:05	LINE FAULT
665	6-Aug-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_110	8:10	8:25	0:15	MAIN SUPPLY FAILURE
666	6-Aug-2021	GULBARGA	66	HV1	BACHIGODANAHALLI_66	8:50	14:40	5:50	LINE CLEAR VAILED
667	6-Aug-2021	GULBARGA	66	BACHIGODANAHALLI-ITAGI	BACHIGODANAHALLI_66	8:55	14:30	5:35	MAIN SUPPLY FAILURE
668	6-Aug-2021	HASSAN	110	JOG-JLT4	mghejog_gen	23:42(5.8.2021)	14:48(6.8.2021)	15:05 hrs	LINE CHARGED
669	6-Aug-2021	HASSAN	110	JOG110-MGHE	JOG_110	23:42(5.8.2021)	12:19(6.8.2021)	12:36 hrs	LINE CHARGED
670	6-Aug-2021	HASSAN	110	LPH-MGHE 2	lph_gen	23:43(5.8.2021)	14:54(6.8.2021)	15:11 hrs	LINE CHARGED
671	6-Aug-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	23:04(6.8.2021)			LINE OPEN:LINE CLEAR AVAILED
672	6-Aug-2021	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
673	6-Aug-2021	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
674	6-Aug-2021	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
675	6-Aug-2021	HASSAN	110	JOG-NK2	mghejog_gen	15:10 (4.08.2021)			LINE OPEN:LINE CLEAR AVAILED
676	6-Aug-2021	HASSAN	66	HV2	ARAKALGUD_66	9:15(5.8.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
677	6-Aug-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	23:05(6.8.2021)			LINE OPEN:LINE CLEAR AVAILED
678	6-Aug-2021	HASSAN	110	HV1	HALADY_110	7:10	7:20	0:10	LOAD CURTAILMENT
679	6-Aug-2021	HASSAN	110	HV2	BANAVARA_110	7:10	7:24	0:14	LOAD CURTAILMENT
680	6-Aug-2021	HASSAN	110	HV1	HIRENALLUR_110	15:00	18:36	3:36	LINE CLEAR VAILED
681	6-Aug-2021	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	18:44	18:56	0:12	HAND TRIPPED
682	6-Aug-2021	HASSAN	110	HV1	KALLUSADARAHALLY_110	11:11	17:39	6:28	LINE CLEAR VAILED
683	6-Aug-2021	HASSAN	110	HV2	NANDIKUR_110	21:31	21:46	0:15	TRANSFORMER FAULT
684	6-Aug-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:22	15:32	3:10	LINE CLEAR VAILED
685	6-Aug-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:03	11:16	0:13	LINE FAULT
686	6-Aug-2021	HASSAN	110	SORABA-MAVALLI	SORABA_110	11:20	15:35	4:15	LINE CLEAR VAILED
687	6-Aug-2021	HASSAN	66	ARAKAL-HASSAN	ARKD_66	14:10	16:13	2:03	LINE FAULT
688	6-Aug-2021	HASSAN	66	HV2	ARKD_66	15:55	16:07	0:12	LINE CLEAR VAILED
689	6-Aug-2021	HASSAN	66	HV1	BAGUR_66	12:02	14:00	1:58	LINE CLEAR VAILED
690	6-Aug-2021	HASSAN	66	HV2	BAGUR_66	12:02	14:00	1:58	LINE CLEAR VAILED
691	6-Aug-2021	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	12:02	15:00	2:58	LINE CLEAR VAILED
692	6-Aug-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:49	9:53	0:04	LINE FAULT
693	6-Aug-2021	HASSAN	66	HV1	HALEBEEDU_66	12:57	13:52	0:55	LINE CLEAR VAILED
694	6-Aug-2021	HASSAN	66	HV2	MAGGE_66	10:30	10:44	0:14	LINE CLEAR VAILED
695	6-Aug-2021	HASSAN	66	HV1	RAMPURA_66	12:44	14:50	2:06	LINE CLEAR VAILED
696	6-Aug-2021	HASSAN	66	HV2	RAMPURA_66	12:44	15:42	2:58	LINE CLEAR VAILED
697	6-Aug-2021	HASSAN	66	HV2	SINGAPURA_66	7:10	7:20	0:10	LOAD CURTAILMENT
698	6-Aug-2021	HASSAN	66	HV2	TAVARECHATNAHALLI_66	15:47	16:46	0:59	LINE CLEAR VAILED
699	6-Aug-2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	11:58	14:59	3:01	LINE CLEAR VAILED
700	6-Aug-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:58	15:00	3:02	LINE CLEAR VAILED
701	6-Aug-2021	HASSAN	66	HV1	YESLUR_66	17:31	1812	6:29	LINE CLEAR VAILED
702	6-Aug-2021	HASSAN	66	YESLUR-SNVRSNT	YESLUR_66	17:31	18:11	0:40	LINE CLEAR VAILED
703	6-Aug-2021	MYSURU	66	HV1	AKKIHEBBAL_66	16:17	17:29	1:12	LINE CLEAR VAILED
704	6-Aug-2021	MYSURU	66	HV2	AKKIHEBBAL_66	7:09	7:20	0:11	LOAD CURTAILMENT
705	6-Aug-2021	MYSURU	66	DR PETE-KUNTHUR	NO STATIONS EFFECTED	11:01(6.8.21)			LINE OPEN:LINE CLEAR AVAILED
706	6-Aug-2021	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	16:17			LINE OPEN:LINE CLEAR AVAILED
707	6-Aug-2021	MYSURU	66	HV2	KMDODDI_66	13:48	14:27	0:39	LINE CLEAR VAILED
708	6-Aug-2021	MYSURU	66	HV2	KOLLEGALA_66	14:45	15:52	1:06	LINE CLEAR VAILED
709	6-Aug-2021	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	18:57	19:12	0:15	LINE FAULT
710	6-Aug-2021	MYSURU	66	HV1	MADDUR_66	12:13	13:55	1:42	LINE CLEAR VAILED
711	6-Aug-2021	MYSURU	66	HV1	NAGAMANGALA_66	7:10	7:14	0:03	LOAD CURTAILMENT
712	6-Aug-2021	MYSURU	66	HV1	PONNAMPET_66	15:42	15:49	0:06	TRANSFORMER FAULT
713	6-Aug-2021	MYSURU	66	HV1	SATHEGALA_66	7:10	7:19	0:09	LOAD CURTAILMENT
714	6-Aug-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	7:10	8:02	0:52	LOAD CURTAILMENT
715	6-Aug-2021	MYSURU	66	SHANIVARSANTE-YESSLUR	NO STATIONS EFFECTED	17:41	18:18	0:36	LINE CLEAR VAILED
716	6-Aug-2021	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	12:42 (05/08/2021)	18:14 (06/08/2021)	29:31 HRS	LINE CHARGED
717	6-Aug-2021	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	11:59	17:54	5:54	LINE CLEAR VAILED
718	6-Aug-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110,HULIYAR_110	14:12	14:36	0:23	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
719	6-Aug-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:59	13:01	0:01	LINE CLEAR VAILED
720	6-Aug-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	15:09	15:10	0:01	LINE CLEAR VAILED
721	6-Aug-2021	TUMKUR	110	TR-2	NITTUR_220	13:10	15:55	2:45	LINE CLEAR VAILED
722	6-Aug-2021	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	VIJAYA STEEL_EHT_66	12:09	13:44	1:35	LINE CLEAR VAILED
723	6-Aug-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	10:00	12:10	2:09	LINE CLEAR VAILED
724	6-Aug-2021	TUMKUR	66	TR-2	CHANNAGIRI_66	10:00	11:00	0:59	LINE CLEAR VAILED
725	6-Aug-2021	TUMKUR	66	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	10:00	10:58	0:58	LINE CLEAR VAILED
726	6-Aug-2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	6:11	6:29	0:17	LINE FAULT
727	6-Aug-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:17	6:30	0:13	LINE FAULT
728	6-Aug-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	10:04	14:49	4:45	LINE CLEAR VAILED
729	6-Aug-2021	TUMKUR	66	TR-1	HONNALI_66	2:13	3:00	0:47	TRANSFORMER FAULT
730	6-Aug-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	11:17	11:52	0:34	LINE CLEAR VAILED
731	6-Aug-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	10:25	10:40	0:15	LINE CLEAR VAILED
732	6-Aug-2021	TUMKUR	66	SANIKERE- HIRIYUR	SANIKERE_66	10:52	17:00	6:07	NFBC ISSUED
733	6-Aug-2021	TUMKUR	66	TR-2	SANIKERE_66	12:47	15:14	2:27	LINE CLEAR VAILED
734	6-Aug-2021	TUMKUR	66	TR-1	TUMKUR_66	10:51	11:42	0:50	LINE CLEAR VAILED
735	7-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
736	7-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
737	7-Aug-21	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	14:20	14:47	0:27	LINE CLEAR VAILED
738	7-Aug-21	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	6:36	6:41	0:05	LOAD CURTAILMENT
739	7-Aug-21	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	6:35	6:44	0:09	LOAD CURTAILMENT
740	7-Aug-21	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	6:36	6:59	0:23	LOAD CURTAILMENT
741	7-Aug-21	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	16:12	18:06	1:54	LINE CLEAR VAILED
742	7-Aug-21	BAGALKOT	110	110/11KV, HV2	TORVI_110	20:56	21:10	0:14	TRANSFORMER FAULT
743	7-Aug-21	BAGALKOT	110	110/11KV, HV2	ITANAL_110	7:55	8:04	0:09	TRANSFORMER FAULT
744	7-Aug-21	BAGALKOT	110	110/11KV, HV3	HIDIKAL_110, KOLIGUDDA_33	6:36	6:42	0:06	LOAD CURTAILMENT
745	7-Aug-21	BAGALKOT	110	110/11KV, HV4	KANABARGI LAYOUT_110	11:15	13:37	2:22	LINE CLEAR VAILED
746	7-Aug-21	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	6:36	6:57	0:21	LOAD CURTAILMENT
747	7-Aug-21	BAGALKOT	110	110/11KV,HV1	ARGA_110	9:36	12:10	2:34	LINE CLEAR VAILED
748	7-Aug-21	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	6:35	6:40	0:05	LOAD CURTAILMENT
749	7-Aug-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	6:35	6:43	0:08	LOAD CURTAILMENT
750	7-Aug-21	BAGALKOT	110	110/11KV,HV2	ALBAL_110	16:10	19:16	3:06	LINE CLEAR VAILED
751	7-Aug-21	BAGALKOT	110	110/33KV, HV1	HANGAL_110, PALA_33, BASAPUR_33	6:35	6:55	0:20	LOAD CURTAILMENT
752	7-Aug-21	BAGALKOT	110	110/33KV, HV1	HANGAL_110, PALA_33, BASAPUR_34	15:35	16:06	0:31	LINE CLEAR VAILED
753	7-Aug-21	BAGALKOT	110	110/33KV, HV2	SAVALGI_110, HIREPADASALAGI LIS_33, KALABILAGI_33	6:35	6:56	0:21	LOAD CURTAILMENT
754	7-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
755	7-Aug-21	BAGALKOT	110	ALBAL-RFE	ALBAL_110	16:12	19:16	3:04	LINE CLEAR VAILED
756	7-Aug-21	BAGALKOT	110	ALBAL-SPRS	ALBAL_110	16:12	19:16	3:04	LINE CLEAR VAILED
757	7-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
758	7-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
759	7-Aug-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)	18:15 (07.08.2021)	4:56 hrs	LINE CHARGED
760	7-Aug-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_110	6:45	7:04	0:19	LINE FAULT
761	7-Aug-21	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	2:34	2:46	0:12	LINE FAULT
762	7-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
763	7-Aug-21	BAGALKOT	110	HUBLI- BIDNAL2	HUBLI_220	17:08	17:28	0:20	LINE CLEAR VAILED
764	7-Aug-21	BAGALKOT	110	MUNDAGOD- SHIGGOAN	MUNDAGOD_110	5:55	6:18	0:23	HAND TRIPPED
765	7-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
766	7-Aug-21	BAGALKOT	110	RAMANKOPPA- SAVANUR (MUNDAGOD)	MUNDAGOD_110	5:50	6:31	0:41	LINE FAULT
767	7-Aug-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
768	7-Aug-21	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	18:05	18:20	0:15	HAND TRIPPED
769	7-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
770	7-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
771	7-Aug-21	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	5:50	6:22	0:32	LINE FAULT
772	7-Aug-21	BAGALKOT	110	TUMMINAKATTI-RANEBENNUR220	STATION NOT AFFECTED TUMMINAKATTI_110	11:12 (06.08.2021)	10:59 (07.08.2021)	23:47 hrs	LINE CHARGED
773	7-Aug-21	BAGALKOT	220	220/110KV, HV1& LV1	HUBLI_220	9:38	16:03	6:25	LINE CLEAR VAILED
774	7-Aug-21	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:50 (03.08.2021)			LINE OPEN:LINE CLEAR AVAILED
775	7-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
776	7-Aug-21	BAGALKOT	220	HUBLI- NAGJHARI2	HUBLI_220	12:27	19:14	6:47	LINE FAULT
777	7-Aug-21	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	14:05	15:24	1:19	LINE FAULT
778	7-Aug-21	BAGALKOT	220	KUDACHI- CHIKKODI1	KUDACHI_220	13:25	14:24	0:59	HAND TRIPPED
779	7-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
780	7-Aug-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	11:26	16:15	4:49	LINE FAULT
781	7-Aug-21	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	12:08	12:15	0:07	LINE FAULT
782	7-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
783	7-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
784	7-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)			LINE OPEN:LINE CLEAR AVAILED
785	7-Aug-21	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	5:36	6:04	0:28	LOAD CURTAILMENT
786	7-Aug-21	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	5:36	6:04	0:28	LOAD CURTAILMENT
787	7-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
788	7-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
789	7-Aug-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	9:15	12:03	2:48	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
790	7-Aug-21	BENGALURU	66	HV1	ELECTRONIC CITY P2 S1	10:10	17:54	7:44	LINE CLEAR VAILED
791	7-Aug-21	BENGALURU	66	HV1	SOMANAHALLI 220	11:05	11:12	0:07	LOAD CHANGE OVER
792	7-Aug-21	BENGALURU	66	HV1	SARJAPURA 220	9:01	18:33	9:32	MAIN SUPPLY FAILURE
793	7-Aug-21	BENGALURU	66	HV1	DALASNUR	11:16	11:29	0:12	LINE CLEAR VAILED
794	7-Aug-21	BENGALURU	66	HV2	CHATRA	14:46	16:04	1:18	LINE CLEAR VAILED
795	7-Aug-21	BENGALURU	66	HV2	ELECTRONIC CITY P2 S1	10:10	17:54	7:44	LINE CLEAR VAILED
796	7-Aug-21	BENGALURU	66	HV2	GOKULA	12:03	12:13	0:10	TRANSFORMER FAULT
797	7-Aug-21	BENGALURU	66	HV2	SOMANAHALLI 220	10:59	11:07	0:08	LOAD CHANGE OVER
798	7-Aug-21	BENGALURU	66	HV2	SOMANAHALLI 220	14:28	14:30	0:02	LOAD CHANGE OVER
799	7-Aug-21	BENGALURU	66	HV2	ATTUR YELAHANKA	15:49	16:13	0:24	LINE CLEAR VAILED
800	7-Aug-21	BENGALURU	66	HV2	CHAKAVELU	16:30	16:35	0:05	LINE CLEAR VAILED
801	7-Aug-21	BENGALURU	66	HV2	SARJAPURA 220	9:01	18:32	9:31	MAIN SUPPLY FAILURE
802	7-Aug-21	BENGALURU	66	HV3	ELECTRONIC CITY P2 S1	10:10	17:54	7:44	LINE CLEAR VAILED
803	7-Aug-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	11:07	19:23	8:16	LINE CLEAR VAILED
804	7-Aug-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	11:07	19:23	8:16	LINE CLEAR VAILED
805	7-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:31	19:34	0:03	LOAD CHANGE OVER
806	7-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	9:04	19:38	10:34	MAIN SUPPLY FAILURE
807	7-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:04	19:22	10:18	MAIN SUPPLY FAILURE
808	7-Aug-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	9:04	19:19	10:15	MAIN SUPPLY FAILURE
809	7-Aug-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	9:04	19:20	10:16	MAIN SUPPLY FAILURE
810	7-Aug-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	9:04	19:24	10:20	MAIN SUPPLY FAILURE
811	7-Aug-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	9:04	19:15	10:11	MAIN SUPPLY FAILURE
812	7-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	9:04	19:23	10:19	MAIN SUPPLY FAILURE
813	7-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	19:37	19:51	0:14	LINE FAULT
814	7-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	20:11(7-8-2021)			LINE OPEN:LINE FAULT
815	7-Aug-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	8:42	8:45	0:03	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
816	7-Aug-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:45	8:52	0:07	MAIN SUPPLY FAILURE
817	7-Aug-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:00	18:35	9:35	MAIN SUPPLY FAILURE
818	7-Aug-21	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	10:41	10:48	0:07	LOAD CHANGE OVER
819	7-Aug-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	19:03	19:05	0:01	LOAD CHANGE OVER
820	7-Aug-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:49	10:55	0:06	LOAD CHANGE OVER
821	7-Aug-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	8:45	9:47	1:02	LINE CLEAR VAILED
822	7-Aug-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	18:35	19:52	1:17	LINE CLEAR VAILED
823	7-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	9:01	9:37	0:36	LOAD CHANGE OVER
824	7-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	18:39	18:56	0:17	LOAD CHANGE OVER
825	7-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	9:01	9:37	0:36	LOAD CHANGE OVER
826	7-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	18:39	18:56	0:17	LOAD CHANGE OVER
827	7-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	9:01	9:37	0:36	LOAD CHANGE OVER
828	7-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:39	18:56	0:17	LOAD CHANGE OVER
829	7-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
830	7-Aug-21	BENGALURU	220	HV1	MALUR 220	9:04	19:05	10:01	MAIN SUPPLY FAILURE
831	7-Aug-21	BENGALURU	220	HV1	SARJAPURA 220	9:01	18:31	9:30	MAIN SUPPLY FAILURE
832	7-Aug-21	BENGALURU	220	HV2	MALUR 220	9:04	19:06	10:02	MAIN SUPPLY FAILURE
833	7-Aug-21	BENGALURU	220	HV2	SARJAPURA 220	9:01	18:33	9:32	MAIN SUPPLY FAILURE
834	7-Aug-21	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	9:04	18:24	9:20	LINE CLEAR VAILED
835	7-Aug-21	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220	9:01	18:25	9:24	LINE CLEAR VAILED
836	7-Aug-21	BENGALURU	220	LV1	MALUR 220	9:04	19:12	10:08	MAIN SUPPLY FAILURE
837	7-Aug-21	BENGALURU	220	LV2	MALUR 220	9:04	19:08	10:04	MAIN SUPPLY FAILURE
838	7-Aug-21	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	9:01	9:37	0:36	LOAD CHANGE OVER
839	7-Aug-21	GULBARGA	66	ITTAGI-HIREHADAGALI	HIREHADAGALI_66	6:34	6:43	0:09	LINE FAULT
840	7-Aug-21	GULBARGA	66	KUDLIGI-BANAVEKAL	BANAVEKAL_66	8:25	12:45	4:20	LINE CLEAR VAILED
841	7-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
842	7-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
843	7-Aug-21	GULBARGA	110	HV1	TEKKALKOTE_110	6:40	7:48	1:08	TRANSFORMER FAULT
844	7-Aug-21	GULBARGA	110	HV1	JEWARGI_110	6:35	6:55	0:20	LOAD CURTAILMENT
845	7-Aug-21	GULBARGA	110	HV1	BISIHALLI	6:34	6:40	0:06	TRANSFORMER FAULT
846	7-Aug-21	GULBARGA	110	HV1	LADHA_110	12:35	12:45	0:10	TRANSFORMER FAULT
847	7-Aug-21	GULBARGA	110	HV1	LADHA_110	14:50	15:00	0:10	TRANSFORMER FAULT
848	7-Aug-21	GULBARGA	110	HV1	LADHA_110	15:20	15:30	0:10	TRANSFORMER FAULT
849	7-Aug-21	GULBARGA	110	HV2	BISIHALLI	6:34	6:40	0:06	TRANSFORMER FAULT
850	7-Aug-21	GULBARGA	110	HV2	SHORAPUR_110	12:04	16:23	4:19	LINE CLEAR VAILED
851	7-Aug-21	GULBARGA	110	HV2,HV1	MYLAR_110	10:56	11:37	0:41	LINE CLEAR VAILED
852	7-Aug-21	GULBARGA	110	HV3	YELBURGA_110	6:35	6:55	0:20	LOAD CURTAILMENT
853	7-Aug-21	GULBARGA	110	HV3	SHORAPUR_110	15:40	16:25	0:45	LINE CLEAR VAILED
854	7-Aug-21	GULBARGA	110	MYLAR-GUTAL	MYLAR_110	10:56	11:37	0:41	LINE CLEAR VAILED
855	7-Aug-21	GULBARGA	110	NALWAR-SHAHABAD(LINE 3)	NALWAR_110	3:15	3:20	0:05	LINE FAULT
856	7-Aug-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	6:25	6:30	0:05	LINE FAULT
857	7-Aug-21	GULBARGA	110	RAJESHWAR-SASTAPUR	RAJESHWAR_110	6:25	6:40	0:15	LINE FAULT
858	7-Aug-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	0:40	0:45	0:05	LINE FAULT
859	7-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	5:05	5:15	0:10	LINE FAULT
860	7-Aug-21	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	20:01(06.08.2021)	3:49(7.08.2021)	7:48 hrs	LINE CHARGED
861	7-Aug-21	GULBARGA	220	HV2	SHAHAPUR_220	15:33	16:18	0:45	LINE CLEAR VAILED
862	7-Aug-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	21:07(07.08.2021)			LINE OPEN:LINE CLEAR AVAILED
863	7-Aug-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	16:30	16:38	0:08	LINE FAULT
864	7-Aug-21	GULBARGA	220	SHAHAPURO-SEDAM	SEDAM_220	20:36(06.08.2021)	6:12(07.08.2021)	9:36HRS	LINE CHARGED
865	7-Aug-21	GULBARGA	400	BTPSG-RTPS	RTPS_400	10:10	19:29	9:19	LINE CLEAR VAILED
866	7-Aug-21	GULBARGA	400	JINDAL-BPS	BPS_400	11:18	17:05	5:47	LINE CLEAR VAILED
867	7-Aug-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:13	11:22	0:09	LINE FAULT
868	7-Aug-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	13:09	16:10	3:01	LINE FAULT
869	7-Aug-21	HASSAN	66	HASSN22-HSN66	HASSAN_220	13:09	14:03	0:54	LINE FAULT
870	7-Aug-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	13:09	14:05	0:56	LINE FAULT
871	7-Aug-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	17:18	17:23	0:05	HAND TRIPPED
872	7-Aug-21	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:09	15:10	2:01	LINE FAULT
873	7-Aug-21	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	13:09	14:04	0:55	LINE FAULT
874	7-Aug-21	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
875	7-Aug-21	HASSAN	66	HV1	HASSAN_66	12:03	14:03	2:00	MAIN SUPPLY FAILURE
876	7-Aug-21	HASSAN	66	HV1	HOLALUR_66	13:36	14:06	0:30	LINE CLEAR VAILED
877	7-Aug-21	HASSAN	66	HV1	KUDLIGERE_66	14:43	16:31	1:48	LINE CLEAR VAILED
878	7-Aug-21	HASSAN	66	HV1	MAGGE_66	12:04	15:13	3:09	MAIN SUPPLY FAILURE
879	7-Aug-21	HASSAN	66	HV1	YESLUR_66	11:24	16:15	4:51	LINE CLEAR VAILED
880	7-Aug-21	HASSAN	66	HV1	MALLAPURA_66	13:40	14:14	0:34	LINE CLEAR VAILED
881	7-Aug-21	HASSAN	66	HV2	HASSAN_66	12:03	14:04	2:01	MAIN SUPPLY FAILURE
882	7-Aug-21	HASSAN	66	HV2	MAGGE_66	12:04	15:13	3:09	MAIN SUPPLY FAILURE
883	7-Aug-21	HASSAN	66	HV2	RAMNATHPURA_66	8:16	13:10	4:54	LINE CLEAR VAILED
884	7-Aug-21	HASSAN	66	HV2	SALAGAME_66	12:05	12:11	0:06	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
885	7-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN:LINE CLEAR AVAILED
886	7-Aug-21	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	14:42	16:31	1:49	LINE CLEAR VAILED
887	7-Aug-21	HASSAN	66	LV1	HASSAN_220	12:02	15:08	3:06	TRANSFORMER FAULT
888	7-Aug-21	HASSAN	66	LV2	HASSAN_220	13:09	14:02	0:53	TRANSFORMER FAULT
889	7-Aug-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
890	7-Aug-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	9:47	13:36	3:49	LINE CLEAR VAILED
891	7-Aug-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	14:23	16:16	1:53	LINE CLEAR VAILED
892	7-Aug-21	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	9:02	16:16	7:14	LINE CLEAR VAILED
893	7-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	14:41	14:49	0:08	LINE FAULT
894	7-Aug-21	HASSAN	66	YESLUR-SNVRST	YESLUR_66	11:25	15:10	3:45	LINE CLEAR VAILED
895	7-Aug-21	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	15:50	16:19	0:29	LINE CLEAR VAILED
896	7-Aug-21	HASSAN	110	BLGMBAA-AFT	BELAGUMBA_110	15:50	16:22	0:32	NFBC ISSUED
897	7-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
898	7-Aug-21	HASSAN	110	HV1	HALADY_110	6:39	6:49	0:10	LOAD CURTAILMENT
899	7-Aug-21	HASSAN	110	HV1	BELAGUMBA_110	15:50	16:27	0:37	NFBC ISSUED
900	7-Aug-21	HASSAN	110	HV1	HIENALLUR_110	13:40	13:45	0:05	HAND TRIPPED
901	7-Aug-21	HASSAN	110	HV1	KULASHEKARA_110	19:02	22:09	3:07	LINE CLEAR VAILED
902	7-Aug-21	HASSAN	110	HV2	BELAGUMBA_110	15:50	16:21	0:31	NFBC ISSUED
903	7-Aug-21	HASSAN	110	HV3	HIRIYADKA_110	0:58	1:02	0:04	TRANSFORMER FAULT
904	7-Aug-21	HASSAN	110	KAVOOR-KIOCL	KAVOOR_220	9:02	18:44	9:42	LINE CLEAR VAILED
905	7-Aug-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	21:09 (7.08.2021)			LINE OPEN:LINE FAULT
906	7-Aug-21	HASSAN	220	HASSN22-NITTUR	HASSAN_220	12:02	13:42	1:40	LINE FAULT
907	7-Aug-21	HASSAN	220	HASSN22-NITTUR	HASSAN_220	13:46	13:58	0:12	LINE FAULT
908	7-Aug-21	HASSAN	220	HASSN22-Shomoga	HASSAN_220	12:02	13:39	1:37	LINE FAULT
909	7-Aug-21	HASSAN	220	HASSN22-Shomoga	HASSAN_220	13:46	15:01	1:15	LINE FAULT
910	7-Aug-21	HASSAN	220	HV1	HASSAN_220	12:02	15:07	3:05	TRANSFORMER FAULT
911	7-Aug-21	HASSAN	220	HV2	HASSAN_220	12:02	14:01	1:59	TRANSFORMER FAULT
912	7-Aug-21	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	23:04(6.8.2021)	10:37 (7.08.2021)	11:33hrs	LINE CHARGED
913	7-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	21:09 (7.08.2021)			LINE OPEN:LINE FAULT
914	7-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	15:18	17:16	1:58	LINE CLEAR VAILED
915	7-Aug-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	23:05(6.8.2021)	10:37 (7.08.2021)	11:32hrs	LINE CHARGED
916	7-Aug-21	MYSURU	66	DR PETE-KUNTHUR	NO STATIONS EFFECTED	11:01 (06/08/2021)	17:20(7.08.21)	30:19 HRS	LINE CHARGED
917	7-Aug-21	MYSURU	66	DUNDANALLI-HULIYURDURGA	DUNDANAHALLI_66	12:05	13:15	1:10	LINE CLEAR VAILED
918	7-Aug-21	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	16:17 (06/08/2021)	14:47(7.8.21)	22:30 HRS	LINE CHARGED
919	7-Aug-21	MYSURU	66	GUKKADA-SRIRANGPATNA	SRIRANGAPATNA_66	0:30	0:42	0:11	LINE FAULT
920	7-Aug-21	MYSURU	66	HV1	MALAVALLI_66	15:27	15:54	0:26	LINE CLEAR VAILED
921	7-Aug-21	MYSURU	66	HV1	TARIPURA_66	10:10	14:47	4:37	LINE CLEAR VAILED
922	7-Aug-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	10:12	10:22	0:10	LINE FAULT
923	7-Aug-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	18:07	18:15	0:08	LINE FAULT
924	7-Aug-21	MYSURU	66	SHANIVARASANTE-YESSLUR	NO STATIONS EFFECTED	11:29	16:15	4:46	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
925	7-Aug-21	MYSURU	66	TUBINKERE-MANDYA2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66	6:58	7:58	1:00	LINE FAULT
926	7-Aug-21	MYSURU	66	TUBINKERE-MANDYA4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66	6:58	7:58	1:00	LINE FAULT
927	7-Aug-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	4:18	4:30	0:11	HAND TRIPPED
928	7-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	4:10	4:17	0:07	LINE FAULT
929	7-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	14:38	14:45	0:06	LINE FAULT
930	7-Aug-21	TUMKUR	66	KORA- ANTHRASANAHALLI	KADEHALLI_110	4:17	4:20	0:02	LINE FAULT
931	7-Aug-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	4:10	4:22	0:12	LINE FAULT
932	7-Aug-21	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	10:35	11:07	0:32	LINE CLEAR VAILED
933	7-Aug-21	TUMKUR	66	TR-1	NIDASALE_66	11:17	12:50	1:32	LINE CLEAR VAILED
934	7-Aug-21	TUMKUR	66	TR-2	BHARAMGIRI_66	10:40	12:13	1:33	LINE CLEAR VAILED
935	7-Aug-21	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	9:43	12:00	2:16	LINE CLEAR VAILED
936	7-Aug-21	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	6:00	9:47	3:47	LINE CLEAR VAILED
937	7-Aug-21	TUMKUR	110	HONNAVALLI 110- KADUR220(ARASEKERE)	HONNAVALLI_110	1:47	2:02	0:15	LINE FAULT
938	7-Aug-21	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUN SEGhatta_110	1:47	2:19	0:32	LINE FAULT
939	7-Aug-21	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUN SEGhatta_110	11:49	11:55	0:05	HAND TRIPPED
940	7-Aug-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	19:40	19:53	0:13	TRANSFORMER FAULT
941	7-Aug-21	TUMKUR	110	TR-2	SAMPIGE_110	17:04	18:40	1:35	LINE CLEAR VAILED
942	7-Aug-21	TUMKUR	220	MADHUGIRI 220kv- VASANTANARASAPURA 2	VASANTANARASAPURA LINE 2	11:16	17:38	6:22	LINE CLEAR VAILED
943	8-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
944	8-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD 220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
945	8-Aug-21	BAGALKOT	110	110/11KV, HV1	MANTUR_110	10:36	10:39	0:03	TRANSFORMER FAULT
946	8-Aug-21	BAGALKOT	110	110/11KV, HV2	MANTUR_110	10:36	10:43	0:07	TRANSFORMER FAULT
947	8-Aug-21	BAGALKOT	110	110/11KV, HV3	HIREKERUR_110	12:20	12:58	0:38	LINE CLEAR VAILED
948	8-Aug-21	BAGALKOT	110	110/11KV, HV4	KERUR_110	17:14	17:16	0:02	HAND TRIPPED
949	8-Aug-21	BAGALKOT	110	110/11KV,HV2	ALBAL_110	7:15	10:40	3:25	LINE CLEAR VAILED
950	8-Aug-21	BAGALKOT	110	110/11KV,HV2	ALBAL_110	15:55	20:06	4:11	LINE CLEAR VAILED
951	8-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL 110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
952	8-Aug-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	7:06	7:13	0:07	TRANSFORMER FAULT
953	8-Aug-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	8:02	9:13	1:11	LINE CLEAR VAILED
954	8-Aug-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	18:14 (08.08.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
955	8-Aug-21	BAGALKOT	110	ALBAL-RFE	ALBAL_110	7:15	10:40	3:25	LINE CLEAR VAILED
956	8-Aug-21	BAGALKOT	110	ALBAL-RFE	ALBAL_110	7:15	10:40	3:25	LINE CLEAR VAILED
957	8-Aug-21	BAGALKOT	110	ALBAL-SPRS	ALBAL_110	7:15	10:40	3:25	LINE CLEAR VAILED
958	8-Aug-21	BAGALKOT	110	ALBAL-SPRS	ALBAL_110	7:15	10:40	3:25	LINE CLEAR VAILED
959	8-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
960	8-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
961	8-Aug-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	10:25	10:40	0:15	LINE FAULT
962	8-Aug-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	12:45	12:55	0:10	LINE FAULT
963	8-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
964	8-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
965	8-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
966	8-Aug-21	BAGALKOT	110	SANKESHWAR- HIRA SUGARS1	SANKESHWAR_110	12:59	13:45	0:46	LINE CLEAR VAILED
967	8-Aug-21	BAGALKOT	110	SANKESHWAR- HIRA SUGARS2	SANKESHWAR_110	12:59	13:20	0:21	LINE CLEAR VAILED
968	8-Aug-21	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	10:41	10:45	0:04	HAND TRIPPED
969	8-Aug-21	BAGALKOT	110	SODATTI220- YARAGATTI	YARAGATTI_110	10:17	18:32	8:15	LINE CLEAR VAILED
970	8-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
971	8-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVAILED
972	8-Aug-21	BAGALKOT	110	VAJRAMATTI220- MANTUR1	MANTUR_110	11:12	11:36	0:24	LINE FAULT
973	8-Aug-21	BAGALKOT	220	220/110KV, HV1& LV1	SODATTI_220	10:42	13:48	3:06	LINE CLEAR VAILED
974	8-Aug-21	BAGALKOT	220	220/110KV, HV1& LV1	BELGAUM_220	11:12	14:24	3:12	LINE CLEAR VAILED
975	8-Aug-21	BAGALKOT	220	220/110KV, HV2& LV2	SODATTI_220	14:08	17:56	3:48	LINE CLEAR VAILED
976	8-Aug-21	BAGALKOT	220	220/110KV, HV2& LV2	HVERI_220	11:13	12:41	1:28	LINE CLEAR VAILED
977	8-Aug-21	BAGALKOT	220	ALAMATTI1-BAGALKOT	BAGALKOT_220	21:24	22:14	0:50	LINE FAULT
978	8-Aug-21	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	11:27	13:09	1:42	LINE CLEAR VAILED
979	8-Aug-21	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	11:17	13:11	1:54	LINE FAULT
980	8-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM_220	11:04 (08.08.2021)			LINE OPEN:LINE CLEAR AVAILED
981	8-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	11:05	17:30	6:25	LINE CLEAR VAILED
982	8-Aug-21	BAGALKOT	220	BELGAUM- NARENDRA1	BELGAUM_220	15:25	17:28	2:03	LINE CLEAR VAILED
983	8-Aug-21	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:50 (03.08.2021)	10:55 (08.08.2021)	13:05 hrs	LINE CHARGED
984	8-Aug-21	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	11:27	12:17	0:50	LINE FAULT
985	8-Aug-21	BAGALKOT	220	BIDNAL- NARENDRA	BIDNAL_220	6:57	12:40	5:43	LINE FAULT
986	8-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
987	8-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
988	8-Aug-21	BAGALKOT	220	NARENDRA- BIDNAL	NARENDRA_220	6:57	12:40	5:43	LINE FAULT
989	8-Aug-21	BAGALKOT	220	NARENDRA- KANABARGI1(BELGAUM1)	NARENDRA_220	11:07	13:16	2:09	NFBC ISSUED
990	8-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
991	8-Aug-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	11:46	12:35	0:49	LINE FAULT
992	8-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)	5:35 (08.08.2021)	11:29 hrs	LINE CHARGED
993	8-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN:LINE CLEAR AVAILED
994	8-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	18:04 (27.07.2021)	5:35 (08.08.2021)	11:29 hrs	LINE CHARGED
995	8-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN:LINE CLEAR AVAILED
996	8-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
997	8-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
998	8-Aug-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	19:15	19:20	0:05	LOAD CHANGE OVER
999	8-Aug-21	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1000	8-Aug-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	10:10	18:19	8:09	LINE CLEAR VAILED
1001	8-Aug-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	18:20	18:50	0:30	LINE CLEAR VAILED
1002	8-Aug-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1003	8-Aug-21	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1004	8-Aug-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	9:57	18:14	8:17	LINE CLEAR VAILED
1005	8-Aug-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1006	8-Aug-21	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1007	8-Aug-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	10:01	18:15	8:14	LINE CLEAR VAILED
1008	8-Aug-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1009	8-Aug-21	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	9:12	17:25	8:13	LINE CLEAR VAILED
1010	8-Aug-21	BENGALURU	66	HULLENAHALLI - KUDUR	KUDUR, SIRIGEREPURA	13:06	13:31	0:24	LINE CLEAR VAILED
1011	8-Aug-21	BENGALURU	66	HV1	HANUMANTHAGAR	11:15	15:05	3:49	LINE CLEAR VAILED
1012	8-Aug-21	BENGALURU	66	HV1	KENGERI SATELLITE	17:33	17:59	0:25	TRANSFORMER FAULT
1013	8-Aug-21	BENGALURU	66	HV1	SARJAPURA 220	16:10	16:44	0:34	TRANSFORMER FAULT
1014	8-Aug-21	BENGALURU	66	HV1	DABUSPETE 220	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1015	8-Aug-21	BENGALURU	66	HV1	RANGANDODDI	10:45	10:48	0:03	LINE CLEAR VAILED
1016	8-Aug-21	BENGALURU	66	HV1	MALLANAYAKANA HALLI	13:01	13:10	0:08	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1017	8-Aug-21	BENGALURU	66	HV1	MALLASANDRA	9:48	10:12	0:24	LINE CLEAR VAILED
1018	8-Aug-21	BENGALURU	66	HV1	MALLASANDRA	17:10	17:16	0:06	LINE CLEAR VAILED
1019	8-Aug-21	BENGALURU	66	HV2	DABUSPETE 220	18:44	18:50	0:06	MAIN SUPPLY FAILURE
1020	8-Aug-21	BENGALURU	66	HV2	RANGANDODDI	12:44	12:46	0:02	LINE CLEAR VAILED
1021	8-Aug-21	BENGALURU	66	KACHMARANAHALLI - DIVYASHREE TEC PARK	KACHMARANAHALLI	12:00	12:05	0:05	LOAD CHANGE OVER
1022	8-Aug-21	BENGALURU	66	KACHMARANAHALLI - DOMMASANDRA	KACHMARANAHALLI	17:50	17:55	0:05	LOAD CHANGE OVER
1023	8-Aug-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	23:23	23:59	0:36	LINE CLEAR VAILED
1024	8-Aug-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	23:23	23:59	0:36	LINE CLEAR VAILED
1025	8-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	13:43	13:56	0:13	LINE FAULT
1026	8-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	13:21	13:57	0:36	LINE CLEAR VAILED
1027	8-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	20:11(7-8-2021)	9:02(8-8-2021)	3:48 hrs	LINE CHARGED
1028	8-Aug-21	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	14:23	14:26	0:02	LOAD CHANGE OVER
1029	8-Aug-21	BENGALURU	66	SOMENAHALLI - AFTL SOLAR (IPP)	NO STATION AFFECTED	10:25	10:30	0:05	LINE FAULT
1030	8-Aug-21	BENGALURU	66	SOMENAHALLI - AFTL SOLAR (IPP)	NO STATION AFFECTED	10:40	10:45	0:05	LINE FAULT
1031	8-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
1032	8-Aug-21	BENGALURU	220	HV1	DABUSPETE 220	10:08	15:05	4:57	LINE CLEAR VAILED
1033	8-Aug-21	BENGALURU	220	HV1	DABUSPETE 220	18:44	18:49	0:05	TRANSFORMER FAULT
1034	8-Aug-21	BENGALURU	220	HV2	DABUSPETE 220	15:10	18:42	3:32	LINE CLEAR VAILED
1035	8-Aug-21	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66	5:11	5:19	0:08	LINE FAULT
1036	8-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1037	8-Aug-21	GULBARGA	110	HANUMNAL-HIREGONNAGAR	HANUMNAL_110	12:00	12:15	0:15	LINE FAULT
1038	8-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1039	8-Aug-21	GULBARGA	110	HV1	JEWARGI_110	3:30	3:54	0:24	LOAD CURTAILMENT
1040	8-Aug-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:06	5:10	0:04	LINE FAULT
1041	8-Aug-21	GULBARGA	110	MADIYAL-NSL SUGARS_IPP	MADIYAL_110	20:43	20:58	0:15	LINE FAULT
1042	8-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	4:15	4:35	0:20	LINE FAULT
1043	8-Aug-21	GULBARGA	110	MUNIRABAD-SINDHNOOR2	KAMPLI_110,KPC,MUKUNDA_110,K EREEHALLI_110,MALLAPUR_110	11:08	11:14	0:06	LINE FAULT
1044	8-Aug-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	0:45	0:50	0:05	LINE FAULT
1045	8-Aug-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:48	5:53	0:05	LINE FAULT
1046	8-Aug-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	0:58	1:02	0:04	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1047	8-Aug-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:02	4:10	0:08	LINE FAULT
1048	8-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	1:30	1:35	0:05	LINE FAULT
1049	8-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:30	20:39	0:09	LINE FAULT
1050	8-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	2:18	2:28	0:10	LINE FAULT
1051	8-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	2:28	5:25	2:57	LINE FAULT
1052	8-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	5:25	9:00	3:35	LINE CLEAR VAILED
1053	8-Aug-21	GULBARGA	220	MALLAT-RTPS	RTPS_220	22:07	22:33	0:26	LINE FAULT
1054	8-Aug-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	21:07(07.08.2021)	6:06(08.08.2021)	8:59HRS	LINE CHARGED
1055	8-Aug-21	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	18:13	18:49	0:36	MAIN SUPPLY FAILURE
1056	8-Aug-21	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	18:13	18:50	0:37	MAIN SUPPLY FAILURE
1057	8-Aug-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	18:13	18:50	0:37	MAIN SUPPLY FAILURE
1058	8-Aug-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	18:13	18:50	0:37	MAIN SUPPLY FAILURE
1059	8-Aug-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	18:13	18:48	0:35	MAIN SUPPLY FAILURE
1060	8-Aug-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:13	18:49	0:36	MAIN SUPPLY FAILURE
1061	8-Aug-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	18:13	18:49	0:36	MAIN SUPPLY FAILURE
1062	8-Aug-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	18:13	18:51	0:38	MAIN SUPPLY FAILURE
1063	8-Aug-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	18:13	18:48	0:35	MAIN SUPPLY FAILURE
1064	8-Aug-21	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1065	8-Aug-21	HASSAN	66	HV1	DODDAKADANUR_66	18:04	18:50	0:46	MAIN SUPPLY FAILURE
1066	8-Aug-21	HASSAN	66	HV1	HNPURA_66	18:05	18:49	0:44	MAIN SUPPLY FAILURE
1067	8-Aug-21	HASSAN	66	HV2	CHIKMAGALUR_66	15:30	16:32	1:02	LINE CLEAR VAILED
1068	8-Aug-21	HASSAN	66	HV2	HNPURA_66	18:05	18:49	0:44	MAIN SUPPLY FAILURE
1069	8-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN:LINE CLEAR AVAILED
1070	8-Aug-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
1071	8-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1072	8-Aug-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	9:59	10:20	0:21	HAND TRIPPED
1073	8-Aug-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:15	14:51	0:36	HAND TRIPPED
1074	8-Aug-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	9:59	10:19	0:20	HAND TRIPPED
1075	8-Aug-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:15	14:50	0:35	HAND TRIPPED
1076	8-Aug-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	9:59	10:18	0:19	HAND TRIPPED
1077	8-Aug-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:15	14:49	0:34	HAND TRIPPED
1078	8-Aug-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	9:59	10:32	0:33	HAND TRIPPED
1079	8-Aug-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	9:59	10:27	0:28	HAND TRIPPED
1080	8-Aug-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:15	14:51	0:36	HAND TRIPPED
1081	8-Aug-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	9:04	14:24	5:20	LINE FAULT
1082	8-Aug-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	21:09 (7.08.2021)	13:41 (8.08.2021)	16:32hrs	LINE CHARGED
1083	8-Aug-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:17	20:41	6:24	LINE CLEAR VAILED
1084	8-Aug-21	HASSAN	220	GOPALAP-HNPUR21	GOPALPURA_220	18:24	18:46	0:22	LINE FAULT
1085	8-Aug-21	HASSAN	220	GOPALAP-HNPUR22	GOPALPURA_220	18:24	18:47	0:23	LINE FAULT
1086	8-Aug-21	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	18:24	22:28	4:04	LINE FAULT
1087	8-Aug-21	HASSAN	220	HNPR2-GPLPR1	HOLENARASIPURA_220	18:02	18:36	0:34	MAIN SUPPLY FAILURE
1088	8-Aug-21	HASSAN	220	HNPR2-GPLPR2	HOLENARASIPURA_220	18:02	18:34	0:32	LINE FAULT
1089	8-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	9:04	14:24	5:20	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1090	8-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	12:32	16:31	3:59	LINE FAULT
1091	8-Aug-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:32	16:31	3:59	LINE FAULT
1092	8-Aug-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	9:58	13:52	3:54	LINE FAULT
1093	8-Aug-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	14:15	17:58	3:43	LINE FAULT
1094	8-Aug-21	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	11:46	12:36	0:50	LINE FAULT
1095	8-Aug-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	9:58	13:53	3:55	LINE FAULT
1096	8-Aug-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:14	17:58	3:44	LINE FAULT
1097	8-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	21:09 (7.08.2021)	13:41 (8.08.2021)	16:32hrs	LINE CHARGED
1098	8-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:06	19:26	5:20	LINE FAULT
1099	8-Aug-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:22(8.8.2021)			LINE OPEN:LINE CLEAR AVAILED
1100	8-Aug-21	MYSURU	66	CR NAGARA-GUNDLUPETE1	KABHALLY_66	10:40	18:04	7:24	NFBC ISSUED
1101	8-Aug-21	MYSURU	66	CR NAGARA-PANEDHUDI	PANDYADAHUNDI_66	11:42	17:45	6:03	LINE CLEAR VAILED
1102	8-Aug-21	MYSURU	66	GUNDLUPETE-CR NAGARA1	KABHALLY_66	10:15	18:05	7:50	NFBC ISSUED
1103	8-Aug-21	MYSURU	66	TUBINKERE-GUKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	0:04	0:12	0:08	LINE FAULT
1104	8-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	8:31	10:58	2:26	LINE CLEAR VAILED
1105	8-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	18:16	22:31	4:15	LINE CLEAR VAILED
1106	8-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA2	SHIVALLY_66	19:07	20:49	1:41	LINE CLEAR VAILED
1107	8-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA2	SHIVALLY_66	21:16	22:22	1:05	LINE CLEAR VAILED
1108	8-Aug-21	MYSURU	220	HV1	CRNAGAR_220	16:05	18:17	2:12	LINE CLEAR VAILED
1109	8-Aug-21	MYSURU	220	HV1	CRNAGAR_220	10:03	14:46	4:43	LINE CLEAR VAILED
1110	8-Aug-21	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	15:59	18:02	2:03	LINE CLEAR VAILED
1111	8-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:00	18:22	3:22	LINE CLEAR VAILED
1112	8-Aug-21	TUMKUR	66	DAVANGERE SRS-YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALI_66	17:50	18:45	0:55	HAND TRIPPED
1113	8-Aug-21	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	15:59	17:56	1:56	LINE CLEAR VAILED
1114	8-Aug-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	15:58	17:56	1:57	LINE CLEAR VAILED
1115	8-Aug-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	15:36	18:01	2:24	LINE CLEAR VAILED
1116	8-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:23	10:35	0:11	LINE FAULT
1117	8-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66, SASALUHALLA_66	10:23	10:35	0:11	LINE FAULT
1118	8-Aug-21	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	17:56	18:08	0:11	LINE FAULT
1119	8-Aug-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	10:12	17:28	7:15	LINE CLEAR VAILED
1120	8-Aug-21	TUMKUR	66	TR-1	HANGAL_66	15:58	17:56	1:57	LINE CLEAR VAILED
1121	8-Aug-21	TUMKUR	66	TR-1	RUMKUR	13:02	14:31	1:28	LINE CLEAR VAILED
1122	8-Aug-21	TUMKUR	66	TR-2	HANGAL_66	15:58	17:56	1:57	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1123	8-Aug-21	TUMKUR	66	TR-2	KUKKWADA_66	6:28	6:30	0:01	TRANSFORMER FAULT
1124	8-Aug-21	TUMKUR	66	TR-2(LV-2)	DAVANGERE_220	17:50	18:30	0:40	HAND TRIPPED
1125	8-Aug-21	TUMKUR	66	TR-3(LV SIDE)	DAVANGERE_220	17:50	18:05	0:15	HAND TRIPPED
1126	8-Aug-21	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	15:10	18:32	3:22	NFBC ISSUED
1127	8-Aug-21	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110,HULIYAR_110	13:33	14:15	0:41	MAIN SUPPLY FAILURE
1128	8-Aug-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:30	14:15	0:44	LOAD CHANGE OVER
1129	8-Aug-21	TUMKUR	110	TR-1	K B CROSS_220	13:43	14:15	0:31	LOAD CHANGE OVER
1130	8-Aug-21	TUMKUR	110	TR-2	K B CROSS_220	13:44	14:15	0:30	LOAD CHANGE OVER
1131	8-Aug-21	TUMKUR	220	MADHUGIRI 220kV- VASANTANARASAPURA 2	VASANTANARASAPURA LINE 2	10:11	18:02	7:50	LINE CLEAR VAILED
1132	8-Aug-21	TUMKUR	220	TR-1	KIADB_220	9:41	18:11	8:30	LINE CLEAR VAILED
1133	8-Aug-21	TUMKUR	220	TR-2	KIADB_220	9:56	20:02	10:05	LINE CLEAR VAILED
1134	8-Aug-21	TUMKUR	220	TR-3	DAVANGERE_220	17:50	18:20	0:30	TRANSFORMER FAULT
1135	9-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1136	9-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1137	9-Aug-21	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110	14:48	16:43	1:55	LINE CLEAR VAILED
1138	9-Aug-21	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	11:34	11:55	0:21	LINE CLEAR VAILED
1139	9-Aug-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED ALMELU_110	18:40	19:17	0:37	HAND TRIPPED
1140	9-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1141	9-Aug-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	12:22	12:27	0:05	TRANSFORMER FAULT
1142	9-Aug-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	12:48	12:50	0:02	TRANSFORMER FAULT
1143	9-Aug-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	18:14 (08.08.2021)	9:44 (09.08.2021)	15:30 hrs	TRANSFORMER CHARGED
1144	9-Aug-21	BAGALKOT	110	220/110KV, LV2	RANEENNUR_220	12:10	17:02	4:52	LINE CLEAR VAILED
1145	9-Aug-21	BAGALKOT	110	ALBAL-RFE (RAYS SOLAR)	STATION NOT AFFECTED ALMELU_110	15:58	18:51	2:53	LINE CLEAR VAILED
1146	9-Aug-21	BAGALKOT	110	ALBAL-SPRS (SAI PRIYA SUGARS)	STATION NOT AFFECTED ALMELU_110	15:57	18:51	2:54	LINE CLEAR VAILED
1147	9-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1148	9-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1149	9-Aug-21	BAGALKOT	110	BAGEWADI- MUDDEBIHAL	MUDDEBIHAL_110	6:02	6:38	0:36	LINE FAULT
1150	9-Aug-21	BAGALKOT	110	BIJAPUR220- BAGEWADI (ENERCON)	BIJAPUR_220	17:39	17:46	0:07	LINE FAULT
1151	9-Aug-21	BAGALKOT	110	BSNKT-F1CBreaker(HAVERI)	STATION NOT AFFECTED BASAVANKATTI_110	17:38 (09.08.2021)			LINE OPEN:LINE CLEAR AVAILED
1152	9-Aug-21	BAGALKOT	110	BSNKT-F3 Cbreaker (ASIAN FAB TECH)	STATION NOT AFFECTED BASAVANKATTI_110	17:18	18:38	1:20	NFBC ISSUED
1153	9-Aug-21	BAGALKOT	110	BYADAGI-RANEBEENUR	BYADAGI_110	15:32 (22.07.2021)	13:07 (09.08.2021)	21:35 hrs	LINE CHARGED
1154	9-Aug-21	BAGALKOT	110	BYADAGI-RANEBEENUR	BYADAGI_110	21:11 (09.08.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1155	9-Aug-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	12:16	12:35	0:19	LINE FAULT
1156	9-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVVKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
1157	9-Aug-21	BAGALKOT	110	HAVERI220- BYADAGI	BYADAGI_110	17:32	21:08	3:36	LINE CLEAR AVOIDED
1158	9-Aug-21	BAGALKOT	110	HAVERI220- HAVERI	HAVERI_110	17:05	18:01	0:56	LINE CLEAR AVOIDED
1159	9-Aug-21	BAGALKOT	110	HAVERI220- SAVANUR	SAVANUR_110	12:47 (09.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1160	9-Aug-21	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	5:05	6:00	0:55	LINE FAULT
1161	9-Aug-21	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	11:03	13:08	2:05	LINE CLEAR AVOIDED
1162	9-Aug-21	BAGALKOT	110	KIRUVATTI-SIRSI(AMBEWADI)	KIRUVATTI_110	14:10 (04.08.2021)	09:06 (09.08.2021)	18:56 hrs	LINE CHARGED
1163	9-Aug-21	BAGALKOT	110	NARENDRA220- BELUR1	BELUR_110	1:00	1:11	0:11	HAND TRIPPED
1164	9-Aug-21	BAGALKOT	110	NARENDRA220- BELUR2	BELUR_110	1:00	1:12	0:12	HAND TRIPPED
1165	9-Aug-21	BAGALKOT	110	NARENDRA220- KUD DHARWAD	KUD DHARWAD_110	1:00	1:13	0:13	HAND TRIPPED
1166	9-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
1167	9-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1168	9-Aug-21	BAGALKOT	110	SANKESHWAR- HIRA SUGARS2	SANKESHWAR_110	9:50	11:00	1:10	LINE CLEAR AVOIDED
1169	9-Aug-21	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	5:47	5:55	0:08	LINE FAULT
1170	9-Aug-21	BAGALKOT	110	SHIGGOAN- MUNDAGOD	SHIGGOAN_110	17:27	17:29	0:02	HAND TRIPPED
1171	9-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
1172	9-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
1173	9-Aug-21	BAGALKOT	110	UTTUR- YADAWAD	YADAWAD_110	10:55	11:35	0:40	HAND TRIPPED
1174	9-Aug-21	BAGALKOT	110	VAJRAMATTI220- MANTUR (MUDHOL)	MUDHOL_110	10:54	11:13	0:19	LINE FAULT
1175	9-Aug-21	BAGALKOT	220	220/110KV,HV2&LV2	NARENDRA_220	0:40	1:00	0:20	TRANSFORMER FAULT
1176	9-Aug-21	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	11:29	12:42	1:13	LINE FAULT
1177	9-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM_220	11:04 (08.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1178	9-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
1179	9-Aug-21	BAGALKOT	220	GUTTUR1- HAVERI	HAVERI_220	21:10 (09.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1180	9-Aug-21	BAGALKOT	220	GUTTUR2- HAVERI	HAVERI_220	20:19 (09.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1181	9-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
1182	9-Aug-21	BAGALKOT	220	NAGJHARI- BIDNAL	BIDNAL_220	12:48	17:47	4:59	LINE FAULT
1183	9-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1184	9-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1185	9-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1186	9-Aug-21	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	15:54 (09.08.2021)			LINE OPEN:LINE CLEAR AVOIDED
1187	9-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1188	9-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1189	9-Aug-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	19:45	19:50	0:05	LOAD CHANGE OVER
1190	9-Aug-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	11:20	11:30	0:10	LOAD CHANGE OVER
1191	9-Aug-21	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	18:35	18:50	0:15	LOAD CHANGE OVER
1192	9-Aug-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	11:22	11:27	0:05	LOAD CHANGE OVER
1193	9-Aug-21	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	14:28	14:36	0:08	LOAD CHANGE OVER
1194	9-Aug-21	BENGALURU	66	GOLF LINKS - HAL 220	GOLF LINKS	12:40	12:50	0:10	LOAD CHANGE OVER
1195	9-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL (EHT)	AFTL (EHT)	6:41	7:06	0:25	LINE FAULT
1196	9-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	6:45	6:55	0:10	LINE CLEAR VAILED
1197	9-Aug-21	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	11:35	12:35	0:59	LINE CLEAR VAILED
1198	9-Aug-21	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:02	14:01	0:59	LINE CLEAR VAILED
1199	9-Aug-21	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	18:54	19:51	0:57	LINE CLEAR VAILED
1200	9-Aug-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	15:07	15:13	0:05	LOAD CHANGE OVER
1201	9-Aug-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	13:24	14:00	0:36	MAIN SUPPLY FAILURE
1202	9-Aug-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	13:24	14:00	0:36	MAIN SUPPLY FAILURE
1203	9-Aug-21	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	15:08	15:14	0:05	LOAD CHANGE OVER
1204	9-Aug-21	BENGALURU	66	HV1	KHODAYS 220	11:04	14:58	3:53	LINE CLEAR VAILED
1205	9-Aug-21	BENGALURU	66	HV1	BAIRAKURU	23:13	23:20	0:06	LINE CLEAR VAILED
1206	9-Aug-21	BENGALURU	66	HV1	YEDUMADU	15:25	15:30	0:05	LINE CLEAR VAILED
1207	9-Aug-21	BENGALURU	66	HV1	SARJAPURA 220	13:44	14:35	0:51	MAIN SUPPLY FAILURE
1208	9-Aug-21	BENGALURU	66	HV1	SARJAPURA 220	18:36	18:43	0:07	LOAD CHANGE OVER
1209	9-Aug-21	BENGALURU	66	HV1	SM MANGALA	10:58	11:20	0:21	LOAD CHANGE OVER
1210	9-Aug-21	BENGALURU	66	HV2	KHODAYS 220	11:04	14:58	3:54	LINE CLEAR VAILED
1211	9-Aug-21	BENGALURU	66	HV2	BAIRAKURU	23:13	23:20	0:06	LINE CLEAR VAILED
1212	9-Aug-21	BENGALURU	66	HV2	HOSKOTE 66	13:25	14:04	0:39	LINE CLEAR VAILED
1213	9-Aug-21	BENGALURU	66	HV2	THAYALUR	19:10	19:53	0:42	TRANSFORMER FAULT
1214	9-Aug-21	BENGALURU	66	HV2	YEDUMADU	10:52	11:00	0:07	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1215	9-Aug-21	BENGALURU	66	HV2	SARJAPURA 220	13:44	14:35	0:51	MAIN SUPPLY FAILURE
1216	9-Aug-21	BENGALURU	66	HV2	SARJAPURA 220	18:36	18:43	0:07	LOAD CHANGE OVER
1217	9-Aug-21	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	13:24	14:05	0:41	MAIN SUPPLY FAILURE
1218	9-Aug-21	BENGALURU	66	KORMANGALA 220 - GOLF LINKS	GOLF LINKS	13:24	14:00	0:36	MAIN SUPPLY FAILURE
1219	9-Aug-21	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	13:24	14:05	0:41	MAIN SUPPLY FAILURE
1220	9-Aug-21	BENGALURU	66	MALUR 220 - VOKKALERI	VOKKALRI	13:39	14:47	1:08	LINE CLEAR VAILED
1221	9-Aug-21	BENGALURU	66	MELEHALLI - JALAMANGALA	JALAMANGALA, CHIKKAGANGANAWADI	16:00	16:02	0:02	MAIN SUPPLY FAILURE
1222	9-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	13:43	13:47	0:04	LINE FAULT
1223	9-Aug-21	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	13:24	14:06	0:42	MAIN SUPPLY FAILURE
1224	9-Aug-21	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	13:24	14:15	0:51	MAIN SUPPLY FAILURE
1225	9-Aug-21	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	13:28	16:23	2:55	MAIN SUPPLY FAILURE
1226	9-Aug-21	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	16:21	16:23	0:01	LOAD CHANGE OVER
1227	9-Aug-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:44	14:15	0:30	MAIN SUPPLY FAILURE
1228	9-Aug-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:44	14:25	0:41	MAIN SUPPLY FAILURE
1229	9-Aug-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:44	14:20	0:35	MAIN SUPPLY FAILURE
1230	9-Aug-21	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	16:52	17:05	0:12	LINE FAULT
1231	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:40	14:56	1:16	MAIN SUPPLY FAILURE
1232	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	18:37	18:55	0:18	LOAD CHANGE OVER
1233	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	18:37	18:55	0:18	LOAD CHANGE OVER
1234	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:40	14:56	1:16	MAIN SUPPLY FAILURE
1235	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	18:37	18:55	0:18	LOAD CHANGE OVER
1236	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:40	14:56	1:16	MAIN SUPPLY FAILURE
1237	9-Aug-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:37	18:55	0:18	LOAD CHANGE OVER
1238	9-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
1239	9-Aug-21	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220, KORMANGALA 220, NIMHANS 220	13:24	13:50	0:26	LINE FAULT
1240	9-Aug-21	BENGALURU	220	HV1	KORMANGALA	13:24	14:00	0:36	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1241	9-Aug-21	BENGALURU	220	HV1	NIMHANS 220	13:24	14:04	0:40	MAIN SUPPLY FAILURE
1242	9-Aug-21	BENGALURU	220	HV2	HSR LAYOUT 220	13:24	14:00	0:36	MAIN SUPPLY FAILURE
1243	9-Aug-21	BENGALURU	220	HV2	KORMANGALA	13:24	14:00	0:36	MAIN SUPPLY FAILURE
1244	9-Aug-21	BENGALURU	220	HV2	NIMHANS 220	13:24	14:04	0:40	MAIN SUPPLY FAILURE
1245	9-Aug-21	BENGALURU	220	KORMANGALA 220 - HSR LAYOUT	KORMANGALA 220	13:24	14:01	0:37	MAIN SUPPLY FAILURE
1246	9-Aug-21	BENGALURU	220	KORMANGALA 220 - NIMHANS 220	NIMHANS 220	13:24	14:03	0:39	MAIN SUPPLY FAILURE
1247	9-Aug-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:44	14:35	0:51	LINE FAULT
1248	9-Aug-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:35	14:56	0:20	LINE FAULT
1249	9-Aug-21	BENGALURU	220	NIMHANS 220 - HSR LAYOUT 220	NIMHANS 220	13:24	14:04	0:40	MAIN SUPPLY FAILURE
1250	9-Aug-21	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	13:44	14:35	0:51	LINE FAULT
1251	9-Aug-21	BENGALURU	220	SOMANAHALLI 220 - MYLASANDRA 400	NO STATION AFFECTEED	9:05	18:05	9:00	LINE FAULT
1252	9-Aug-21	GULBARGA	110	CHINCHOLI-MANEIKHELLI	CHINCHOLI_110	8:39	8:45	0:06	LINE FAULT
1253	9-Aug-21	GULBARGA	110	GABUR-RAICHUR	GABUR_110	9:20	18:50	9:30	MAIN SUPPLY FAILURE
1254	9-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1255	9-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1256	9-Aug-21	GULBARGA	110	HV1	KOLHAR_110	12:04	12:25	0:21	TRANSFORMER FAULT
1257	9-Aug-21	GULBARGA	110	HV1	KOLHAR_110	12:40	13:30	0:50	LINE CLEAR VAILED
1258	9-Aug-21	GULBARGA	110	HV1	KOLHAR_110	13:32	13:50	0:18	LINE CLEAR VAILED
1259	9-Aug-21	GULBARGA	110	HV2	HANUMNAL_110	8:00	9:00	1:00	LINE CLEAR VAILED
1260	9-Aug-21	GULBARGA	110	HV2	HANUMNAL_110	11:15	12:25	1:10	LINE CLEAR VAILED
1261	9-Aug-21	GULBARGA	110	HV2	HANUMNAL_110	8:00	9:00	1:00	LINE CLEAR VAILED
1262	9-Aug-21	GULBARGA	110	HV2	HANUMNAL_110	11:15	12:25	1:10	LINE CLEAR VAILED
1263	9-Aug-21	GULBARGA	110	HV2	KAVITAL_110	14:50	15:30	0:40	LINE CLEAR VAILED
1264	9-Aug-21	GULBARGA	110	HV3	CHINCHOLI_110	14:45	15:08	0:23	TRANSFORMER FAULT
1265	9-Aug-21	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	14:25	14:45	0:20	MAIN SUPPLY FAILURE
1266	9-Aug-21	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,CHOWDAPUR_110	21:00	21:07	0:07	LINE FAULT
1267	9-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	0:12	0:23	0:11	LINE FAULT
1268	9-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	1:02	5:20	4:18	LINE FAULT
1269	9-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	6:08	23:29	17:21	LINE FAULT
1270	9-Aug-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	3:55	4:05	0:10	MAIN SUPPLY FAILURE
1271	9-Aug-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:25	14:40	0:15	MAIN SUPPLY FAILURE
1272	9-Aug-21	GULBARGA	220	HV2	SINDHANOOR_220	3:50	6:30	2:40	TRANSFORMER FAULT
1273	9-Aug-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	21:30(09.08.2021)			LINE OPEN:LINE CLEAR AVAILED
1274	9-Aug-21	GULBARGA	220	SINDHANOOR-SINDHANOOR	LINGAPUR_220	3:45	4:40	0:55	LINE FAULT
1275	9-Aug-21	GULBARGA	400	BTPSG-RTPS	RTPS_400	10:30	19:55	9:25	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1276	9-Aug-21	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1277	9-Aug-21	HASSAN	66	HV2	ARAKALGUD_66	22:46	23:01	0:15	TRANSFORMER FAULT
1278	9-Aug-21	HASSAN	66	HV2	MAGGE_66	10:25	12:38	2:13	LINE CLEAR VAILED
1279	9-Aug-21	HASSAN	66	HV2	MAGGE_66	15:04	15:26	0:22	LINE CLEAR VAILED
1280	9-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN:LINE CLEAR AVAILED
1281	9-Aug-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)	17:32(9.8.2021)	363:49hrs	LINE CHARGED
1282	9-Aug-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	17:09	17:37	0:28	LINE CLEAR VAILED
1283	9-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	9:31	9:59	0:28	LINE FAULT
1284	9-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1285	9-Aug-21	HASSAN	110	HV1	MSEZ_220	10:13	14:27	4:14	LINE CLEAR VAILED
1286	9-Aug-21	HASSAN	110	LV1	KADUR_220	10:21	11:20	0:59	LINE CLEAR VAILED
1287	9-Aug-21	HASSAN	110	LV1	PUTTUR_220	11:44	14:13	2:29	LINE CLEAR VAILED
1288	9-Aug-21	HASSAN	110	LV1	SHIRALKOPPA_220	17:22	19:04	1:42	LINE CLEAR VAILED
1289	9-Aug-21	HASSAN	110	LV2	SHIRALKOPPA_220	10:26	17:20	6:54	LINE CLEAR VAILED
1290	9-Aug-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:52	12:28	0:36	HAND TRIPPED
1291	9-Aug-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:52	12:30	0:38	HAND TRIPPED
1292	9-Aug-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:52	12:29	0:37	HAND TRIPPED
1293	9-Aug-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:52	12:30	0:38	HAND TRIPPED
1294	9-Aug-21	HASSAN	220	HV1	KADUR_220	10:21	11:20	0:59	LINE CLEAR VAILED
1295	9-Aug-21	HASSAN	220	HV1	PUTTUR_220	11:44	14:13	2:29	LINE CLEAR VAILED
1296	9-Aug-21	HASSAN	220	HV1	SHIRALKOPPA_220	17:22	19:04	1:42	LINE CLEAR VAILED
1297	9-Aug-21	HASSAN	220	HV2	SHIRALKOPPA_220	10:26	17:20	6:54	LINE CLEAR VAILED
1298	9-Aug-21	HASSAN	220	KADUR-SHIMOGA	KADUR_220	10:04	20:24	10:20	LINE CLEAR VAILED
1299	9-Aug-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:28	15:17	3:49	LINE CLEAR VAILED
1300	9-Aug-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:37	15:18	2:41	LINE CLEAR VAILED
1301	9-Aug-21	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	10:02 (9.8.2021)			LINE OPEN:LINE CLEAR AVAILED
1302	9-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:33	14:25	2:52	LINE FAULT
1303	9-Aug-21	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:33	14:25	2:52	LINE FAULT
1304	9-Aug-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:52	12:28	0:36	LINE FAULT
1305	9-Aug-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:52	12:28	0:36	LINE FAULT
1306	9-Aug-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:28	15:17	3:49	NFBC ISSUED
1307	9-Aug-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:37	15:18	2:41	NFBC ISSUED
1308	9-Aug-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	3:08	9:02	5:54	LINE CLEAR VAILED
1309	9-Aug-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:22(8.8.2021)	7:21(9.8.2021)	12:59hrs	LINE CHARGED
1310	9-Aug-21	MYSURU	66	HANNUR-KOTHANURU	KOTHANUR_66	16:09	17:39	1:30	NFBC ISSUED
1311	9-Aug-21	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	2:53	3:04	0:10	LINE FAULT
1312	9-Aug-21	MYSURU	66	HV1	DODDINADUVADI_66	10:05	16:40	6:35	LINE CLEAR VAILED
1313	9-Aug-21	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	13:03	13:06	0:02	TRANSFORMER FAULT
1314	9-Aug-21	MYSURU	66	HV1	KUNTHUR_66	10:00	11:38	1:38	LINE CLEAR VAILED
1315	9-Aug-21	MYSURU	66	HV2	DODDINADUVADI_66	10:05	16:40	6:35	LINE CLEAR VAILED
1316	9-Aug-21	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	15:27	16:24	0:56	LINE CLEAR VAILED
1317	9-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:13	17:04	6:50	LINE CLEAR VAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1318	9-Aug-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	1:28	1:30	0:02	HAND TRIPPED
1319	9-Aug-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	1:42	1:44	0:01	HAND TRIPPED
1320	9-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	5:52	6:01	0:08	LINE FAULT
1321	9-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	13:02	13:15	0:12	LINE FAULT
1322	9-Aug-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	19:06	19:24	0:17	LINE FAULT
1323	9-Aug-21	TUMKUR	66	TR-1	CHITRADURGA_220	12:30	17:50	5:20	LINE CLEAR VAILED
1324	9-Aug-21	TUMKUR	66	TR-1	GARAGA_66	8:06	8:51	0:45	LINE CLEAR VAILED
1325	9-Aug-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	15:39	15:50	0:10	TRANSFORMER FAULT
1326	9-Aug-21	TUMKUR	66	TR-1	KATTIGE_66	8:24	8:29	0:05	TRANSFORMER FAULT
1327	9-Aug-21	TUMKUR	66	TR-1	KORA_66	10:57	13:00	2:03	LINE CLEAR VAILED
1328	9-Aug-21	TUMKUR	66	TR-2	BUKKAPATNA_66	13:03	14:24	1:20	LINE CLEAR VAILED
1329	9-Aug-21	TUMKUR	66	TR-2	CHITRADURGA_66	13:45	14:09	0:23	LINE CLEAR VAILED
1330	9-Aug-21	TUMKUR	66	TR-2	GARAGA_66	8:06	8:52	0:45	LINE CLEAR VAILED
1331	9-Aug-21	TUMKUR	66	TR-2	KORA_66	11:19	13:00	1:40	LINE CLEAR VAILED
1332	9-Aug-21	TUMKUR	66	TR-2	MATHOD_66	6:29	6:35	0:05	TRANSFORMER FAULT
1333	9-Aug-21	TUMKUR	66	TR-2	RAMPURA_66	13:30	14:36	1:05	LINE CLEAR VAILED
1334	9-Aug-21	TUMKUR	110	HONNAVALLI 110- KADUR220	HONNAVALLI_110	13:03	15:10	2:07	LINE CLEAR VAILED
1335	9-Aug-21	TUMKUR	110	HONNAVALLI 110- KADUR220	HONNAVALLI_110	17:55	18:00	0:05	LINE CLEAR VAILED
1336	9-Aug-21	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUN SEGHATTA_110	13:19	13:30	0:10	LINE CLEAR VAILED
1337	9-Aug-21	TUMKUR	220	TR-1	CHITRADURGA_220	12:30	17:38	5:08	LINE CLEAR VAILED
1338	9-Aug-21	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:33	11:58	1:24	LINE CLEAR VAILED
1339	9-Aug-21	TUMKUR	220	TR-1	DAVANGERE_SRS_220	12:06	12:50	0:44	LINE CLEAR VAILED