

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 16.03.2021 To 22.03.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	16-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
2	16-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
3	16-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
4	16-Mar-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
5	16-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
6	16-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVAILED
7	16-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
8	16-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
9	16-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVAILED
10	16-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI 110	7:13 (07.02.2021)	12:07 (16.03.2021)	892:54HRS	LINE CHARGED
11	16-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	10:47 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
12	16-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI 220	10:47:00 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
13	16-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVAILED
14	16-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
15	16-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
16	16-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
17	16-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD 110	16:57 (03.03.2021)			LINE OPEN: LINE CLEAR AVAILED
18	16-Mar-21	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI 220	11:07 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
19	16-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
20	16-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
21	16-Mar-21	BAGALKOT	110	KUMTA-SIRS1	STATION NOT AFFECTED KUMTA 110	12:34 (13.03.2021)			LINE OPEN: LINE CLEAR AVAILED
22	16-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT
23	16-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL 110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
24	16-Mar-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE 110	15:05 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
25	16-Mar-21	BAGALKOT	110	110/11KV,HV1	ANANADNAGAR 110	11:00	12:18	1:18	LINE CLEAR AVAILED
26	16-Mar-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR 110	04:49	05:01	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
27	16-Mar-21	BAGALKOT	110	110/11KV,HV1	THORVI_110	07:02	12:26	5:24	TRANSFORMER FAULT
28	16-Mar-21	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	22:20	22:48	0:28	LOAD CURTAILMENT
29	16-Mar-21	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	22:21	22:41	0:20	LOAD CURTAILMENT
30	16-Mar-21	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	22:21	22:38	0:17	LOAD CURTAILMENT
31	16-Mar-21	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	13:40	17:39	3:59	LINE FAULT
32	16-Mar-21	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	11:21	13:09	1:48	LINE CLEAR AVOIDED
33	16-Mar-21	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	13:12	14:42	1:30	LINE CLEAR AVOIDED
34	16-Mar-21	BAGALKOT	400	400/220KV,ICT2(HV/LV)	DHONI_400	14:47	17:56	3:09	LINE CLEAR AVOIDED
35	16-Mar-21	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	11:21	13:08	1:47	NFBC ISSUED
36	16-Mar-21	BAGALKOT	220	GADAG-DHONI2	STATION NOT AFFECTED GADAG_220	13:11	14:42	1:31	NFBC ISSUED
37	16-Mar-21	BAGALKOT	220	220/110KV,HV1,LV1	GADAG_220	15:03	16:10	1:07	LINE CLEAR AVOIDED
38	16-Mar-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,KANAD AL SOLAR_33,	16:14	16:22	0:08	LINE CLEAR AVOIDED
39	16-Mar-21	BAGALKOT	110	HUKKERI-KOTAWAGI LIS	HUKKERI_110,KOTAWAGI LIS_110	22:57	23:12	0:15	LINE FAULT
40	16-Mar-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110,BELGAUM W/S 1,BELGAUM W/S 2&3,RUSTUMPUR LIS_33	13:40	13:53	0:13	TRANSFORMER FAULT
41	16-Mar-21	BAGALKOT	110	MAMADAPUR-BABLESHWAR	BABLESHWAR_110	5:04	5:17	0:13	LINE FAULT
42	16-Mar-21	BAGALKOT	110	MAMADAPUR-BELGAUM SOLAR	MAMADAPUR_110	5:04	5:05	0:01	LINE FAULT
43	16-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	MK HUBLI_110	11:12	11:30	0:18	TRANSFORMER FAULT
44	16-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	MK HUBLI_110	11:55 (16.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
45	16-Mar-21	BAGALKOT	110	BAGEWADI220-MUDEDEBIHAL	MUDEDEBIHAL_110	11:43	12:39	0:56	LINE FAULT
46	16-Mar-21	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	06:49	07:50	1:01	LOAD CURTAILMENT
47	16-Mar-21	BAGALKOT	110	110/11KV, HV2(HV4)	STATION NOT AFFECTED HUBLI_220	10:36	13:47	3:11	LINE CLEAR AVOIDED
48	16-Mar-21	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	13:42	17:31	3:49	LINE FAULT
49	16-Mar-21	BAGALKOT	110	SOUDATTI220-MMCL	MMCL_110 STATION NOT AFFECTED SOUDATTI_220	13:42	14:00	0:18	LINE FAULT
50	16-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI_110	12:02			LINE OPEN: LINE CLEAR AVOIDED
51	16-Mar-21	BAGALKOT	110	SIRSI-JOG2 (SIDDAPUR2)	SIDDAPUR_110	12:02	12:12	0:10	HAND TRIPPED
52	16-Mar-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL_110	07:53	08:01	0:08	TRANSFORMER FAULT
53	16-Mar-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MELLIGERI_110	16:19	17:33	1:14	LINE CLEAR AVOIDED
54	16-Mar-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:07	12:29	0:21	MAIN SUPPLY FAILURE
55	16-Mar-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:07	12:29	0:21	MAIN SUPPLY FAILURE
56	16-Mar-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:07	12:29	0:21	MAIN SUPPLY FAILURE
57	16-Mar-21	BENGALURU	220	HV1	SARJAPURA 220	12:07	12:29	0:21	MAIN SUPPLY FAILURE
58	16-Mar-21	BENGALURU	220	HV2	SARJAPURA 220	12:07	12:29	0:21	MAIN SUPPLY FAILURE
59	16-Mar-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:38	14:32	0:53	MAIN SUPPLY FAILURE
60	16-Mar-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:38	14:32	0:53	MAIN SUPPLY FAILURE
61	16-Mar-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:38	14:32	0:53	MAIN SUPPLY FAILURE
62	16-Mar-21	BENGALURU	220	HV1	SARJAPURA 220	13:38	14:32	0:53	MAIN SUPPLY FAILURE
63	16-Mar-21	BENGALURU	220	HV2	SARJAPURA 220	13:38	14:32	0:53	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
64	16-Mar-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:56	16:00	1:03	MAIN SUPPLY FAILURE
65	16-Mar-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:56	16:00	1:03	MAIN SUPPLY FAILURE
66	16-Mar-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:56	16:00	1:03	MAIN SUPPLY FAILURE
67	16-Mar-21	BENGALURU	220	HV1	SARJAPURA 220	14:56	16:00	1:03	MAIN SUPPLY FAILURE
68	16-Mar-21	BENGALURU	220	HV2	SARJAPURA 220	14:56	16:00	1:03	MAIN SUPPLY FAILURE
69	16-Mar-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	20:49	20:53	0:04	LOAD CHANGEOVER
70	16-Mar-21	BENGALURU	66	HV1	MAASTHI	15:22	20:00	4:37	LINE CLEAR AVAILED
71	16-Mar-21	BENGALURU	66	HV1	KANAKAPURA 66	11:53	12:50	0:56	TRANSFORMER FAULT
72	16-Mar-21	BENGALURU	66	HV1	KAMASAMUDRA	13:42	16:14	2:31	LINE CLEAR AVAILED
73	16-Mar-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:07	12:29	0:21	LINE FAULT
74	16-Mar-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:38	14:32	0:53	LINE FAULT
75	16-Mar-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:56	16:00	1:03	LINE FAULT
76	16-Mar-21	BENGALURU	66	B G ROAD - SOMANAHALLI 220	B G ROAD , JIGANI LINK ROAD	19:57	21:56	1:59	MAIN SUPPLY FAILURE
77	16-Mar-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	16:24	19:25	3:01	LINE FAULT
78	16-Mar-21	BENGALURU	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220	12:01	12:28	0:27	LINE FAULT
79	16-Mar-21	BENGALURU	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220	13:38	14:22	0:44	LINE FAULT
80	16-Mar-21	BENGALURU	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220	14:55	15:44	0:49	LINE FAULT
81	16-Mar-21	BENGALURU	66	ISCON - SOMANAHALLI 220	ISCON, SUBRAMANYAPURA 66	19:57	20:30	0:33	LOAD CHANGEOVER
82	16-Mar-21	BENGALURU	66	ISCON - SUBRAMANYAPURA 220	ISCON, SUBRAMANYAPURA 66	22:41	22:49	0:08	LOAD CHANGEOVER
83	16-Mar-21	BENGALURU	66	KODIGEHALI - BYDRAHALI	KODIGEHALI, TAVAREKERE, T G HALLI	8:11	8:16	0:05	LINE FAULT
84	16-Mar-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	6:56	7:03	0:07	LINE FAULT
85	16-Mar-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	19:48	19:55	0:07	LINE FAULT
86	16-Mar-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	20:01	20:22	0:21	LINE FAULT
87	16-Mar-21	BENGALURU	66	HV1	PADMANABHANAGARA	9:31	9:36	0:05	LINE CLEAR AVAILED
88	16-Mar-21	BENGALURU	220	HV1	SOMANAHALLI 220	19:57	20:20	0:23	TRANSFORMER FAULT
89	16-Mar-21	BENGALURU	220	HV3	SOMANAHALLI 220	19:57	20:20	0:23	TRANSFORMER FAULT
90	16-Mar-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	19:57	20:25	0:28	LINE CLEAR AVAILED
91	16-Mar-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	19:57	20:25	0:28	LINE CLEAR AVAILED
92	16-Mar-21	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	19:57	20:25	0:28	LINE CLEAR AVAILED
93	16-Mar-21	BENGALURU	66	HV2	SUBRAMANYAPURA 66	22:55	23:00	0:05	LINE CLEAR AVAILED
94	16-Mar-21	BENGALURU	220	VIKAS TECH PARK - MALUR 220	VIKAS TECH PARK 220	12:02	12:37	0:35	MAIN SUPPLY FAILURE
95	16-Mar-21	BENGALURU	220	VIKAS TECH PARK - MALUR 220	VIKAS TECH PARK 220	13:38	14:32	0:54	MAIN SUPPLY FAILURE
96	16-Mar-21	BENGALURU	220	VIKAS TECH PARK - MALUR 220	VIKAS TECH PARK 220	14:55	16:37	1:42	MAIN SUPPLY FAILURE
97	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:02	12:37	0:35	LINE CLEAR AVAILED
98	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:38	14:32	0:54	LINE CLEAR AVAILED
99	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:55	16:37	1:42	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
100	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:02	12:37	0:35	LINE CLEAR AVAILED
101	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:38	14:32	0:54	LINE CLEAR AVAILED
102	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:55	16:37	1:42	LINE CLEAR AVAILED
103	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:02	12:37	0:35	LINE CLEAR AVAILED
104	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:38	14:32	0:54	LINE CLEAR AVAILED
105	16-Mar-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	14:55	16:37	1:42	LINE CLEAR AVAILED
106	16-Mar-21	BENGALURU	66	HV1	YARANDANAHALLI 220	19:25	19:28	0:03	LOAD CHANGEOVER
107	16-Mar-21	BENGALURU	66	HV1	YARANDANAHALLI 220	21:30	21:35	0:05	LOAD CHANGEOVER
108	16-Mar-21	BENGALURU	66	HV1	YARANDANAHALLI 220	21:50	21:56	0:06	LOAD CHANGEOVER
109	16-Mar-21	BENGALURU	66	HV1	YARANDANAHALLI 220	22:01	22:04	0:03	LOAD CHANGEOVER
110	16-Mar-21	BENGALURU	66	HV1	ANDERSONPETE	13:10	13:20	0:10	LINE CLEAR AVAILED
111	16-Mar-21	BENGALURU	66	HV2	ANDERSONPETE	14:15	14:20	0:05	LINE CLEAR AVAILED
112	16-Mar-21	BENGALURU	66	HV1	HOSKOTE 66	15:06	15:25	0:19	LINE CLEAR AVAILED
113	16-Mar-21	BENGALURU	66	HV1	HOSPALYA	11:30	11:40	0:10	LINE CLEAR AVAILED
114	16-Mar-21	BENGALURU	220	HV2	T K HALLI 220	11:50	11:55	0:05	TRANSFORMER FAULT
115	16-Mar-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	11:50	11:58	0:08	LINE CLEAR AVAILED
116	16-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:50	12:24	0:34	LINE CLEAR AVAILED
117	16-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:50	12:24	0:34	LINE CLEAR AVAILED
118	16-Mar-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	11:50	12:02	0:12	LINE CLEAR AVAILED
119	16-Mar-21	BENGALURU	66	HV2	T K HALLI 220	11:50	11:55	0:05	LINE CLEAR AVAILED
120	16-Mar-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	12:00	12:43	0:43	MAIN SUPPLY FAILURE
121	16-Mar-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	13:40	14:37	0:57	MAIN SUPPLY FAILURE
122	16-Mar-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	14:53	15:52	0:59	MAIN SUPPLY FAILURE
123	16-Mar-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	21:49	21:55	0:06	LOAD CHANGEOVER
124	16-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
125	16-Mar-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	NO STATION AFFECTED	19:57:00(16/03/2021)			LINE OPEN:LINE FAULT
126	16-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
127	16-Mar-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)			LINE OPEN:LINE FAULT
128	16-Mar-21	GULBARGA	400	JSWVL-GUTTUR	GUTTUR 400	13:09	19:20	06:11	LINE CLEAR AVAILED
129	16-Mar-21	GULBARGA	220	MALLAT-RTPS	MALLAT 220	02:15	02:42	00:27	LINE FAULT
130	16-Mar-21	GULBARGA	220	LINGAPUR-JVSL1	LINGAPUR 220	08:28	13:12	04:44	LINE CLEAR AVAILED
131	16-Mar-21	GULBARGA	220	ALIPUR-BTPS	ALIPUR 220	11:46	12:22	00:36	LINE CLEAR AVAILED
132	16-Mar-21	GULBARGA	220	LINGAPUR-BTPS	BTPS 220	11:50	12:19	00:29	LINE CLEAR AVAILED
133	16-Mar-21	GULBARGA	220	SEDAM-RTPS2	SEDAM 220	12:04	12:42	00:38	LINE FAULT
134	16-Mar-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR 220	12:04	12:35	00:31	LINE FAULT
135	16-Mar-21	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD 220	12:04	12:36	00:32	LINE FAULT
136	16-Mar-21	GULBARGA	220	HV2	SEDAM 220	12:04	12:47	00:43	TRANSFORMER FAULT
137	16-Mar-21	GULBARGA	220	HV1	SEDAM 220	13:55	14:08	00:13	TRANSFORMER FAULT
138	16-Mar-21	GULBARGA	220	HV2	SEDAM 220	13:55	14:16	00:21	TRANSFORMER FAULT
139	16-Mar-21	GULBARGA	110	HV1	MASKI 110	09:02	18:34	09:32	LINE CLEAR AVAILED
140	16-Mar-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI 110	04:57	05:33	00:36	MAIN SUPPLY FAILURE
141	16-Mar-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI 110	05:47	06:19	00:32	MAIN SUPPLY FAILURE
142	16-Mar-21	GULBARGA	110	HV1	BEVOOR 110	17:43	18:33	00:50	LINE CLEAR AVAILED
143	16-Mar-21	GULBARGA	110	HV2	MYLAR 110	16:55	21:00	04:05	TRANSFORMER FAULT
144	16-Mar-21	GULBARGA	110	MYLAR-GUTLA	MYLAR 110	16:55	18:15	01:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
145	16-Mar-21	GULBARGA	110	HV2	MYLAR_110	22:10	22:15	00:05	TRANSFORMER FAULT
146	16-Mar-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	00:41	00:55	00:14	MAIN SUPPLY FAILURE
147	16-Mar-21	GULBARGA	110	HV2	CHINCHOLI_110	13:50			TRANSFORMER OPEN:TRANSFORMER FAULT
148	16-Mar-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	14:00(16.03.2021)			LINE OPEN:LINE FAULT
149	16-Mar-21	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGLI_66,MAGALA_66,SOVE NHALLI_66,TUNGABHADRA_IPP	06:25	06:30	00:05	LINE FAULT
150	16-Mar-21	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGLI_66,MAGALA_66,SOVE NHALLI_66,TUNGABHADRA_IPP	07:03	13:14	06:11	LINE CLEAR AVAILED
151	16-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
152	16-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
153	16-Mar-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	23:46(16.3.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
154	16-Mar-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	18:01(14.3.2021)	9:00(16.3.2021)	14:58 hrs	LINE CHARGED
155	16-Mar-21	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	18:26(15.3.2021)	9:07(16.3.2021)	14:40 hrs	LINE CHARGED
156	16-Mar-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	18:26(15.3.2021)	9:07(16.3.2021)	14:40 hrs	LINE CHARGED
157	16-Mar-21	HASSAN	220	KADUR-DABUSET	KADUR_220	21:02 (13.03.2021)	17:18 (16.03.2021)	68:15 hrs	LINE CHARGED
158	16-Mar-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:45	15:08	03:23	LINE CLEAR AVAILED
159	16-Mar-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:45	15:08	03:23	LINE CLEAR AVAILED
160	16-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	08:39	08:57	00:18	LINE FAULT
161	16-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:09	10:11	00:02	LINE FAULT
162	16-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:37	11:51	00:14	LINE FAULT
163	16-Mar-21	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	11:45	15:08	03:23	LINE CLEAR AVAILED
164	16-Mar-21	HASSAN	220	SHRAVITY-SHIMOGA5	sharavathy_gen	11:44	15:08	03:24	LINE CLEAR AVAILED
165	16-Mar-21	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	12:01	18:30	06:29	LINE CLEAR AVAILED
166	16-Mar-21	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	12:02	18:30	06:28	LINE CLEAR AVAILED
167	16-Mar-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	11:51	15:13	03:22	LINE CLEAR AVAILED
168	16-Mar-21	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	11:51	15:13	03:22	LINE CLEAR AVAILED
169	16-Mar-21	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	09:21	12:52	03:31	MAIN SUPPLY FAILURE
170	16-Mar-21	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	11:19	13:38	02:19	LINE CLEAR AVAILED
171	16-Mar-21	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	11:19	14:09	02:50	LINE CLEAR AVAILED
172	16-Mar-21	HASSAN	110	HV2	BARANGI_110	14:17	18:10	03:53	LINE CLEAR AVAILED
173	16-Mar-21	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	09:29	12:48	03:19	LINE CLEAR AVAILED
174	16-Mar-21	HASSAN	110	KAVOOR-AMR	KAVOOR_220	11:29	13:35	02:06	NFBC ISSUED
175	16-Mar-21	HASSAN	110	HV2	MSEZ_220	10:01	13:35	03:34	LINE CLEAR AVAILED
176	16-Mar-21	HASSAN	110	HV2	NAVUNDA_110	12:12	12:30	00:18	LINE CLEAR AVAILED
177	16-Mar-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	06:44	07:17	00:33	LINE FAULT
178	16-Mar-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:34	12:21	01:47	LINE CLEAR AVAILED
179	16-Mar-21	HASSAN	66	HV1	DODDAKADANUR_66	12:00	16:03	04:03	LINE CLEAR AVAILED
180	16-Mar-21	HASSAN	66	HV1	HADAVANAHALLY_66	13:00	15:30	02:30	LINE CLEAR AVAILED
181	16-Mar-21	HASSAN	66	HV1	HANGARANAHALLY_66	09:28	14:44	05:16	LINE CLEAR AVAILED
182	16-Mar-21	HASSAN	66	HNP2-CRPTN	HOLENARASIPURA_220	09:41	13:05	03:24	LINE CLEAR AVAILED
183	16-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	13:27	18:31	05:04	LINE CLEAR AVAILED
184	16-Mar-21	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	13:27	18:31	05:04	LINE CLEAR AVAILED
185	16-Mar-21	HASSAN	66	TAVAREC-SORABA	TAVARECHATNAHALLI_66	10:14	10:18	00:04	MAIN SUPPLY FAILURE
186	16-Mar-21	HASSAN	66	TAVAREC-SORABA	TAVARECHATNAHALLI_66	11:55	12:03	00:08	MAIN SUPPLY FAILURE
187	16-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:00	18:49	08:49	LINE CLEAR AVAILED
188	16-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	09:59	18:44	08:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
189	16-Mar-21	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ARKALAWADI_66 ATTIGULIPURA_66	15:20	15:25	0:05	HAND TRIPPED
190	16-Mar-21	MYSURU	220	CR NAGARA-BEGUR 1	CRNAGAR_220 ATTIGULIPURA_66 BADANAGUPPE_66 BHARGI_66 BOMMALAPURA_66 CHANDAKAVADI_66 DODDARAYAPET_66 GUNDULPET_66 HANGLA_66 HARVEY_66 HONNALLY_MYS_66 KABHALLY_66 TERAKANAMBE_66 YELANDUR_66	11:50	12:16	0:26	MAIN SUPPLY FAILURE
191	16-Mar-21	MYSURU	220	CR NAGARA-BEGUR 2	CRNAGAR_220 ATTIGULIPURA_66 BADANAGUPPE_66 BHARGI_66 BOMMALAPURA_66 CHANDAKAVADI_66 DODDARAYAPET_66 GUNDULPET_66 HANGLA_66 HARVEY_66 HONNALLY_MYS_66 KABHALLY_66 TERAKANAMBE_66 YELANDUR_66	11:50	12:16	0:26	MAIN SUPPLY FAILURE
192	16-Mar-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATION EFFECTED	11:09	15:33	4:24	HAND TRIPPED
193	16-Mar-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	11:54	12:38	0:44	MAIN SUPPLY FAILURE
194	16-Mar-21	MYSURU	66	DB HALLI-TUBINKERE	DODDABYADARAHALLI_66	10:05	16:46	6:40	LINE CLEAR AVAILED
195	16-Mar-21	MYSURU	66	HANNUR-AJJIPURA	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	11:34	11:40	0:06	LINE FAULT
196	16-Mar-21	MYSURU	66	HANNUR-AJJIPURA	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	12:17	12:31	0:14	HAND TRIPPED
197	16-Mar-21	MYSURU	220	KADAKOLA-BEGUR 1	BEGUR_220 BEGUR_66 HARVEY_66 SINDHUVALLI_66	11:51	12:09	0:18	LINE FAULT
198	16-Mar-21	MYSURU	220	KADAKOLA-BEGUR 2	BEGUR_220 BEGUR_66 HARVEY_66 SINDHUVALLI_66	11:51	12:16	0:24	LINE FAULT
199	16-Mar-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	15:03	15:17	0:14	HAND TRIPPED
200	16-Mar-21	MYSURU	66	KADAKOLA-THANDYA	NO STATION EFFECTED	10:53	16:45	5:52	LINE CLEAR AVAILED
201	16-Mar-21	MYSURU	66	KADAKOLA-MANDAKALLI	MANDAKALLI_66	7:33	7:48	0:14	LINE FAULT
202	16-Mar-21	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATION EFFECTED	10:30	14:52	4:22	LINE CLEAR AVAILED
203	16-Mar-21	MYSURU	66	KADAKOLA-SARGUR 2	SANTHESARAGUR_66 DOORA_66 HURA_66 HULLAHALLI_66 CHANDRAVADI_66	11:51	12:18	0:27	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
204	16-Mar-21	MYSURU	66	KADAKOLA-SARGUR 2	SANTHESARAGUR_66 DOORA_66 HURA_66 HULLAHALLI_66 CHANDRAVADI_66	12:20	12:34	0:13	LINE FAULT
205	16-Mar-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	11:51	12:17	0:26	LINE FAULT
206	16-Mar-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	12:20	12:32	0:12	LINE FAULT
207	16-Mar-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	10:06	15:47	5:40	LINE CLEAR AVAILED
208	16-Mar-21	MYSURU	66	K HONNALAGERE-MADDUR	K_HONNALGERE_66	10:07	15:47	5:40	LINE CLEAR AVAILED
209	16-Mar-21	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATION EFFECTED	8:15	10:45	2:30	HAND TRIPPED
210	16-Mar-21	MYSURU	220	HV2	MADHUVANAHALLI_220	11:52	12:02	0:09	MAIN SUPPLY FAILURE
211	16-Mar-21	MYSURU	220	MADHUVANAHALLI-CR NAGARA 1	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	11:50	12:03	0:13	MAIN SUPPLY FAILURE
212	16-Mar-21	MYSURU	220	MADHUVANAHALLI-CR NAGARA 2	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	11:50	12:03	0:13	MAIN SUPPLY FAILURE
213	16-Mar-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:27	12:33	0:06	LINE FAULT
214	16-Mar-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATION EFFECTED	10:50	12:24	1:33	LINE CLEAR AVAILED
215	16-Mar-21	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATION EFFECTED	15:07	16:19	1:11	LINE CLEAR AVAILED
216	16-Mar-21	MYSURU	66	HV5	SFCSHIVA_66	12:18 (16/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
217	16-Mar-21	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	9:05	11:30	2:24	LINE CLEAR AVAILED
218	16-Mar-21	MYSURU	66	HV2	SHIVALLY_66	12:33	13:41	1:07	LINE CLEAR AVAILED
219	16-Mar-21	MYSURU	66	THANDYA-NANJANGUDU	NO STATION EFFECTED	16:46	18:32	1:46	HAND TRIPPED
220	16-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:17	11:23	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
221	16-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:30	11:35	0:05	HAND TRIPPED
222	16-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	14:44	14:50	0:05	LINE FAULT
223	16-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	22:11	22:17	0:05	LINE FAULT
224	16-Mar-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	1:25	1:35	0:10	LINE FAULT
225	16-Mar-21	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATION EFFECTED	17:35 (10/03/2021)			LINE OPEN: LINE CLEAR AVAILED
226	16-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
227	16-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	9:35:19 PM(16.03.2021)			LINE OPEN:LINE FAULT
228	16-Mar-21	TUMKUR	220	TR-2	KBCROSS_220	11:41	11:52	0:10	HAND TRIPPED
229	16-Mar-21	TUMKUR	220	NAGALAMADIKE- ATRIA IPP_66	NITTUR_220	10:53	16:48	5:54	HAND TRIPPED
230	16-Mar-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	21:16	21:31	0:14	HAND TRIPPED
231	16-Mar-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	21:12	21:30	0:18	HAND TRIPPED
232	16-Mar-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	21:12	21:59	0:47	HAND TRIPPED
233	16-Mar-21	TUMKUR	220	TR-2	DAVANGERE_SRS_220	10:58	15:25	4:26	LINE CLEAR AVAILED
234	16-Mar-21	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	21:35	22:28	0:52	HAND TRIPPED
235	16-Mar-21	TUMKUR	220	TR-3	THALLAKK_220	12:55	14:01	1:06	LINE CLEAR AVAILED
236	16-Mar-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,TALKERE_110	11:45	11:55	0:09	HAND TRIPPED
237	16-Mar-21	TUMKUR	110	TR-1	KBCROSS_220	16:06	16:11	0:04	HAND TRIPPED
238	16-Mar-21	TUMKUR	110	TR-2	NITTUR_220	16:06	16:11	0:04	HAND TRIPPED
239	16-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	21:52	22:34	0:41	HAND TRIPPED
240	16-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	21:51	22:33	0:41	HAND TRIPPED
241	16-Mar-21	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	21:52	22:12	0:20	HAND TRIPPED
242	16-Mar-21	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	21:52	22:12	0:20	HAND TRIPPED
243	16-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	21:51	22:32	0:40	HAND TRIPPED
244	16-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	21:51	22:32	0:40	HAND TRIPPED
245	16-Mar-21	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	21:35	22:29	0:53	HAND TRIPPED
246	16-Mar-21	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	21:35	22:28	0:53	HAND TRIPPED
247	16-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	21:52	22:30	0:38	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
248	16-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAYATTUR_66,	4:44	5:05	0:21	HAND TRIPPED
249	16-Mar-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66,HULLENAHALLI_66	9:53	10:23	0:29	HAND TRIPPED
250	16-Mar-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66,HULLENAHALLI_66	11:21	11:29	0:08	LINE FAULT
251	16-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	15:35	15:39	0:03	LINE FAULT
252	16-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	16:37	16:45	0:07	LINE FAULT
253	16-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	9:03	9:53	0:50	HAND TRIPPED
254	16-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	22:14	23:01	0:46	HAND TRIPPED
255	16-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGODDI_66	11:05	11:08	0:03	HAND TRIPPED
256	16-Mar-21	TUMKUR	66	TR-2	AVAREGERE_66	10:20	16:50	6:30	LINE CLEAR AVAILED
257	16-Mar-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITR AHALLI_66	3:34	4:07	0:32	LINE FAULT
258	16-Mar-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITR AHALLI_66	7:37	7:56	0:18	LINE FAULT
259	16-Mar-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITR AHALLI_66	10:16	10:30	0:13	LINE FAULT
260	16-Mar-21	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	3:35	4:07	0:31	LINE FAULT
261	16-Mar-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_ IPP_66	3:35	10:19	6:44	LINE FAULT
262	16-Mar-21	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_ EHT_66	21:38	21:40	0:01	MAIN SUPPLY FAILURE
263	16-Mar-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66, MALEBENNUR_66	21:39	21:41	0:01	MAIN SUPPLY FAILURE
264	16-Mar-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	7:06	7:14	0:08	MAIN SUPPLY FAILURE
265	16-Mar-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:40	13:25	0:44	MAIN SUPPLY FAILURE
266	16-Mar-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	21:39	21:46	0:07	MAIN SUPPLY FAILURE
267	16-Mar-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:07	16:04	5:57	LINE CLEAR AVAILED
268	16-Mar-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:38	15:35	1:56	LINE CLEAR AVAILED
269	16-Mar-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	11:35	11:45	0:10	HAND TRIPPED
270	16-Mar-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	15:32	15:49	0:16	HAND TRIPPED
271	16-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:07	16:05	5:58	LINE CLEAR AVAILED
272	16-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:42	19:53	0:11	LINE FAULT
273	16-Mar-21	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:58	15:25	4:26	HAND TRIPPED
274	16-Mar-21	TUMKUR	66	TR-2	DAVANGERE_SRS_220	12:21	15:16	2:54	HAND TRIPPED
275	16-Mar-21	TUMKUR	66	GUTUR 66-DAVANGERE SRS	GUTUR_66	13:56	15:11	1:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
276	16-Mar-21	TUMKUR	66	TR-3	HOLALKERE_66	9:54	10:34	0:40	TRANSFORMER FAULT
277	16-Mar-21	TUMKUR	66	TR-3	HOLALKERE_66	13:24	13:32	0:08	TRANSFORMER FAULT
278	16-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:04	0:12	0:07	HAND TRIPPED
279	16-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:15	18:28	0:12	HAND TRIPPED
280	16-Mar-21	TUMKUR	66	KANCHIPURA-MATHOD	KANCHIPURA_66	11:57	14:43	2:45	LINE CLEAR AVAILED
281	16-Mar-21	TUMKUR	66	TR-1	KANCHIPURA_66	11:57	14:43	2:45	LINE CLEAR AVAILED
282	16-Mar-21	TUMKUR	66	TR-1	KORA_66	12:09	12:16	0:07	TRANSFORMER FAULT
283	16-Mar-21	TUMKUR	66	TR-2	KORA_66	7:17	14:11	6:54	TRANSFORMER FAULT
284	16-Mar-21	TUMKUR	66	KUNDUR- RSOLAR	RENEW WIND ENERGY_IPP_66	11:48	17:35	5:46	LINE CLEAR AVAILED
285	16-Mar-21	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	12:50	16:57	4:07	LINE CLEAR AVAILED
286	16-Mar-21	TUMKUR	66	TR-1	SASALUHALLA_66	15:21	16:58	1:37	LINE CLEAR AVAILED
287	17-Mar-21	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_110	10:47	12:28	1:41	LINE CLEAR AVAILED
288	17-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
289	17-Mar-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI_110	22:06	22:19	0:13	TRANSFORMER FAULT
290	17-Mar-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	08:40	09:15	0:35	LINE CLEAR AVAILED
291	17-Mar-21	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	15:31	16:56	1:25	LINE CLEAR AVAILED
292	17-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:55 (16.03.2021)	11:25 (17.03.2021)	23:30	TRANSFORMER FAULT
293	17-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
294	17-Mar-21	BAGALKOT	110	110/33KV,HV3	GOKAK_110,RIDDI SIDDI_33,KOLAVI_33	9:45	16:59	7:14	LINE CLEAR AVAILED
295	17-Mar-21	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	4:11	4:27	0:16	LINE FAULT
296	17-Mar-21	BAGALKOT	110	ANNIGERI_GADAG	ANNIGERI_110	13:21	13:47	0:26	LINE FAULT
297	17-Mar-21	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	00:08	00:22	0:14	LINE FAULT
298	17-Mar-21	BAGALKOT	110	DAMBAL-EILS IPP	DAMBAL_110 EILS IPP_110	10:25	11:59	1:34	HAND TRIPPED
299	17-Mar-21	BAGALKOT	110	DAMBAL-MUNDARGI1	MUDARGI_110	10:25	11:56	1:31	HAND TRIPPED
300	17-Mar-21	BAGALKOT	110	DAMBAL-MUNDARGI2 (GADAG1)	MUDARGI_110	10:25	11:56	1:31	HAND TRIPPED
301	17-Mar-21	BAGALKOT	110	DAMBAL-SUZLON1 IPP	DAMBAL_110 SUZLON IPP_110	10:25	12:07	1:42	HAND TRIPPED
302	17-Mar-21	BAGALKOT	110	DAMBAL-SUZLON2 IPP	DAMBAL_110 SUZLON IPP_110	10:25	12:07	1:42	HAND TRIPPED
303	17-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
304	17-Mar-21	BAGALKOT	110	GADAG-DAMBAL	DAMBAL_110	06:14	12:11	5:57	LINE FAULT
305	17-Mar-21	BAGALKOT	110	GADAG-SAMBAPUR ROAD	SAMBAPUR ROAD_110	10:22	11:58	1:36	LINE CLEAR AVAILED
306	17-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN: LINE CLEAR AVAILED
307	17-Mar-21	BAGALKOT	110	GAMESH-KULIGOD	STATION NOT AFFECTED KULIGOD_110	6:29	6:45	0:16	LINE FAULT
308	17-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
309	17-Mar-21	BAGALKOT	110	HAVERI-TILUVALI	TILUVALI_110	22:33	22:36	0:03	HAND TRIPPED
310	17-Mar-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	4:11	4:17	0:06	LINE FAULT
311	17-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
312	17-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
313	17-Mar-21	BAGALKOT	110	KUMTA-SIRS1	STATION NOT AFFECTED KUMTA 110	12:34 (13.03.2021)			LINE OPEN: LINE CLEAR AVAILED
314	17-Mar-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE 110	15:05 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
315	17-Mar-21	BAGALKOT	110	MUDEDEBIHAL-BALAJI SUGARS	MUDEDEBIHAL 110	12:40	13:20	0:40	LINE FAULT
316	17-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
317	17-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL 110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
318	17-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVAILED
319	17-Mar-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
320	17-Mar-21	BAGALKOT	110	SAMBAPUR-DAMBAL	STATION NOT AFFECTED SAMBAPUR 110	13:10 (17.03.2021)			LINE OPEN:LINE FAULT
321	17-Mar-21	BAGALKOT	110	SAMBAPUR-GADAG	SAMBAPUR ROAD 110	10:22	12:07	1:45	NFBC ISSUED
322	17-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
323	17-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI 110	12:02 (16.03.2021)			LINE OPEN: LINE CLEAR AVAILED
324	17-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVAILED
325	17-Mar-21	BAGALKOT	220	220/110KV,HV1,LV1&,LV2	BAGEWADI_220,MAMADAPUR_110, MUDEDEBIHAL_110,UKKALI_110,CHI MMALAGI LIS 110	23:16	23:25	0:09	TRANSFORMER FAULT
326	17-Mar-21	BAGALKOT	220	220/110KV,HV1,LV1&HV2,LV2	BAGEWADI_220,MAMADAPUR_110, MUDEDEBIHAL_110,UKKALI_110,CHI MMALAGI LIS 110	12:38	13:10	0:32	TRANSFORMER FAULT
327	17-Mar-21	BAGALKOT	220	220/110KV,HV3,LV3	BAGEWADI_220,SINDAGI_110,NIDA GUNDI 110	12:38	13:10	0:32	TRANSFORMER FAULT
328	17-Mar-21	BAGALKOT	220	BAGEWADI-BALUTI LIS	BAGEWADI 220	12:38	21:20	8:42	LINE FAULT
329	17-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	10:47 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
330	17-Mar-21	BAGALKOT	220	BIDNAL-HUBLI3	STATION NOT AFFECTED BIDNAL 220	13:47	15:28	1:41	LINE CLEAR AVAILED
331	17-Mar-21	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL 220	12:08	13:20	1:12	LINE CLEAR AVAILED
332	17-Mar-21	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL 220	13:52	18:31	4:39	LINE FAULT
333	17-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI 220	10:47:00 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
334	17-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
335	17-Mar-21	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI 220	11:07 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
336	17-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
337	17-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
338	17-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
339	17-Mar-21	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI 220	12:10	13:19	1:09	LINE CLEAR AVOIDED
340	17-Mar-21	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI 220	13:52	18:31	4:39	LINE FAULT
341	17-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
342	17-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
343	17-Mar-21	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	19:36	20:03	00:27	LOAD CURTAILMENT
344	17-Mar-21	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	19:34	20:10	00:36	LOAD CURTAILMENT
345	17-Mar-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:36	19:15	00:39	LOAD CURTAILMENT
346	17-Mar-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:04	18:35	00:31	LOAD CURTAILMENT
347	17-Mar-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	19:40	20:12	00:32	LOAD CURTAILMENT
348	17-Mar-21	BENGALURU	66	HEBBALA 220 - BANASAWADI	NO STATION AFFECTED	08:33	10:56	02:23	LINE FAULT
349	17-Mar-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	10:08	10:11	00:03	LOAD CHANGEOVER
350	17-Mar-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	07:40	08:00	00:20	MAIN SUPPLY FAILURE
351	17-Mar-21	BENGALURU	66	HV1	EAST DIVISION COMPOUND	11:52	11:55	00:03	LINE CLEAR AVOIDED
352	17-Mar-21	BENGALURU	66	HV1	HANUMANTHNAGARA	17:10	17:50	00:40	LINE CLEAR AVOIDED
353	17-Mar-21	BENGALURU	66	HV1	HANUMANTHNAGARA	18:10	18:20	00:10	TRANSFORMER FAULT
354	17-Mar-21	BENGALURU	66	HV1	BANASAWADI	08:33	08:49	00:16	MAIN SUPPLY FAILURE
355	17-Mar-21	BENGALURU	66	HV1	BANASAWADI	10:45	10:49	00:04	LOAD CHANGEOVER
356	17-Mar-21	BENGALURU	66	HV1	DODDAKARI	07:21	07:44	00:22	LINE CLEAR AVOIDED
357	17-Mar-21	BENGALURU	66	HV1	MAASTHI	13:15	13:20	00:05	TRANSFORMER FAULT
358	17-Mar-21	BENGALURU	66	HV1	GUDIBAND3E	11:30	12:28	00:57	LINE CLEAR AVOIDED
359	17-Mar-21	BENGALURU	66	HV2	HANUMANTHNAGARA	17:10	17:50	00:40	LINE CLEAR AVOIDED
360	17-Mar-21	BENGALURU	66	HV2	BANASAWADI	11:38	11:48	00:10	MAIN SUPPLY FAILURE
361	17-Mar-21	BENGALURU	66	HV2	BANASAWADI	13:08	13:09	00:01	LOAD CHANGEOVER
362	17-Mar-21	BENGALURU	66	HV2	KHODAYS 220	15:32	15:40	00:08	TRANSFORMER FAULT
363	17-Mar-21	BENGALURU	66	HV2	YARANDANAHALLI 220	02:00	02:25	00:25	LINE CLEAR AVOIDED
364	17-Mar-21	BENGALURU	66	HV2	DODDAKARI	19:21	19:31	00:09	LINE CLEAR AVOIDED
365	17-Mar-21	BENGALURU	66	HV2	MAASTHI	02:05	02:10	00:05	TRANSFORMER FAULT
366	17-Mar-21	BENGALURU	66	HV2	GUDIBAND3E	10:16	10:25	00:09	TRANSFORMER FAULT
367	17-Mar-21	BENGALURU	66	HV3	BANASAWADI	08:33	08:49	00:16	MAIN SUPPLY FAILURE
368	17-Mar-21	BENGALURU	66	HV3	BANASAWADI	10:45	10:49	00:04	LOAD CHANGEOVER
369	17-Mar-21	BENGALURU	66	ITI 220 - BANASAWADI	NO STATION AFFECTED	11:38	12:55	01:17	LINE FAULT
370	17-Mar-21	BENGALURU	66	ITI 220 - DRDO(EHT)	DRDO(EHT)	07:38	10:08	02:30	LINE FAULT
371	17-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:45	19:23	00:38	LOAD CURTAILMENT
372	17-Mar-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	19:31	19:34	00:03	LOAD CURTAILMENT
373	17-Mar-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:09	18:45	00:35	LOAD CURTAILMENT
374	17-Mar-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	18:45	19:30	00:45	LOAD CURTAILMENT
375	17-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:31	20:02	00:30	LOAD CURTAILMENT
376	17-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:32	21:37	00:05	LOAD CURTAILMENT
377	17-Mar-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:45	19:10	00:25	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
378	17-Mar-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	21:40	22:20	00:40	LOAD CURTAILMENT
379	17-Mar-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)			LINE OPEN:LINE FAULT
380	17-Mar-21	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	21:57	22:24	00:26	LOAD CURTAILMENT
381	17-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	00:09	00:13	00:04	LINE FAULT
382	17-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	19:31	20:01	00:29	LOAD CURTAILMENT
383	17-Mar-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	00:19	01:24	01:04	LINE CLEAR AVAILED
384	17-Mar-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	00:19	01:24	01:04	LINE CLEAR AVAILED
385	17-Mar-21	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	05:46	05:51	00:05	LOAD CHANGEOVER
386	17-Mar-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	NO STATION AFFECTED	19:57:00(16/03/2021)	5:45(17/03/2021)	9:47HRS	LINE CHARGED
387	17-Mar-21	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	06:25	06:30	00:05	LOAD CHANGEOVER
388	17-Mar-21	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	06:50	18:35	11:45	LINE FAULT
389	17-Mar-21	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:15	19:38	00:23	LINE FAULT
390	17-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	02:00	02:27	00:27	LINE FAULT
391	17-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	02:00	02:25	00:25	LINE CLEAR AVAILED
392	17-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
393	17-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
394	17-Mar-21	BENGALURU	220	HV1	YARANDANAHALLI 220	02:00	02:25	00:25	TRANSFORMER FAULT
395	17-Mar-21	GULBARGA	110	CHICHOLI-CHETTINAD CEMENT IPP	CHINCHOLI_110	12:30	18:01	05:31	LINE CLEAR AVAILED
396	17-Mar-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	14:00(16.03.2021)			LINE OPEN:LINE FAULT
397	17-Mar-21	GULBARGA	110	HUMNABAD-BHALKI1	BHALKI_110,LADHA_110,MGSSK_IPP	06:59	09:18	02:19	LINE FAULT
398	17-Mar-21	GULBARGA	110	HV1	GURMITKAL_110	08:45	09:01	00:16	TRANSFORMER FAULT
399	17-Mar-21	GULBARGA	110	HV1	MASKI_110	18:17	18:27	00:10	LINE CLEAR AVAILED
400	17-Mar-21	GULBARGA	110	HV2	CHINCHOLI_110	13:50(16.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
401	17-Mar-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFACTORY,C HOWDAPUR_110	06:20	06:30	00:10	LINE FAULT
402	17-Mar-21	GULBARGA	110	RAJESHWAR-WARDA SOLAR IPP	RAJESHWAR_110	18:05	18:41	0,025	LINE CLEAR AVAILED
403	17-Mar-21	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	12:26	14:22	01:56	LINE CLEAR AVAILED
404	17-Mar-21	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	14:33	15:44	01:11	LINE CLEAR AVAILED
405	17-Mar-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:30	08:36	03:06	LINE FAULT
406	17-Mar-21	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	11:45	18:55	07:10	LINE CLEAR AVAILED
407	17-Mar-21	GULBARGA	220	HUMNABAD-SEDAM	HUMNABAD_220	11:40	13:25	01:45	LINE CLEAR AVAILED
408	17-Mar-21	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	20:20	20:39	00:19	LINE FAULT
409	17-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:12	17:35	07:23	LINE CLEAR AVAILED
410	17-Mar-21	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	08:40	09:01	00:21	LINE FAULT
411	17-Mar-21	HASSAN	66	HNP2-MYSOR2	HOLENARASIPURA_220	12:20	12:30	00:10	LINE FAULT
412	17-Mar-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	23:46(16.3.2021)	0:00 (17.03.2021)	0:13 hrs	TRANSFORMER CHARGED
413	17-Mar-21	HASSAN	66	HV1	DODDAKADANUR_66	12:22	12:31	00:09	LOAD CURTAILMENT
414	17-Mar-21	HASSAN	66	HV1	JUTTANAHALLI_66	10:05	10:10	00:05	TRANSFORMER FAULT
415	17-Mar-21	HASSAN	66	HV1	SAKLESHUPURA_66	17:48	18:05	00:17	TRANSFORMER FAULT
416	17-Mar-21	HASSAN	66	HV2	MATNAVILE_66	06:44	06:49	00:05	TRANSFORMER FAULT
417	17-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
418	17-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
419	17-Mar-21	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	20:20	20:39	00:19	LINE FAULT
420	17-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	13:37	15:31	01:54	LINE CLEAR AVAILED
421	17-Mar-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	13:37	15:31	01:54	LINE CLEAR AVAILED
422	17-Mar-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	09:46	10:12	00:26	LINE FAULT
423	17-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:14	17:37	07:23	LINE CLEAR AVAILED
424	17-Mar-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:26	14:44	00:18	HAND TRIPPED
425	17-Mar-21	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	14:20	14:34	00:14	LOAD CURTAILMENT
426	17-Mar-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	11:32	12:35	01:03	NFBC ISSUED
427	17-Mar-21	HASSAN	110	HV2	BARANGI_110	14:10	17:59	03:49	LINE CLEAR AVAILED
428	17-Mar-21	HASSAN	110	HV2	ESSUR_110	06:20	09:59	03:39	LINE CLEAR AVAILED
429	17-Mar-21	HASSAN	110	HV2	GERUMARA_110	11:02	11:59	00:57	LINE CLEAR AVAILED
430	17-Mar-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:32	12:35	01:03	LINE CLEAR AVAILED
431	17-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	09:21	17:44	08:23	LINE CLEAR AVAILED
432	17-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	09:21	17:44	08:23	LINE CLEAR AVAILED
433	17-Mar-21	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	14:16	14:35	00:19	HAND TRIPPED
434	17-Mar-21	HASSAN	110	MRSSHM-MPM	MRSMSG_220	08:04	11:40	03:36	LINE CLEAR AVAILED
435	17-Mar-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	13:30	16:15	02:45	LINE CLEAR AVAILED
436	17-Mar-21	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	14:16	14:35	00:19	HAND TRIPPED
437	17-Mar-21	HASSAN	220	VARAHI-KEMAR3	varahi_gen	13:30	16:15	02:45	NFBC ISSUED
438	17-Mar-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	14:15	14:35	00:20	HAND TRIPPED
439	17-Mar-21	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	12:40	14:17	1:37	HAND TRIPPED
440	17-Mar-21	MYSURU	66	HV1	ARAKERE_66	12:10	12:17	0:07	TRANSFORMER FAULT
441	17-Mar-21	MYSURU	66	HV1	BGPURA_66	11:01	11:04	0:03	TRANSFORMER FAULT
442	17-Mar-21	MYSURU	66	HV1	KHBCOLONY_66	3:18	16:13	12:54	TRANSFORMER FAULT
443	17-Mar-21	MYSURU	66	HV1	KHBCOLONY_66	16:40	17:55	1:14	LINE CLEAR AVAILED
444	17-Mar-21	MYSURU	66	HV1	KUNTHUR_66	12:29	14:00	1:30	LINE CLEAR AVAILED
445	17-Mar-21	MYSURU	66	HV1	SRIRANGAPATNA_66	12:17	17:23	5:05	LINE CLEAR AVAILED
446	17-Mar-21	MYSURU	66	HV1	YELANDUR_66	13:35	18:45	5:10	LINE CLEAR AVAILED
447	17-Mar-21	MYSURU	66	HV2	BILIKERE_66	11:57	12:04	0:06	TRANSFORMER FAULT
448	17-Mar-21	MYSURU	66	HV2	MADIKERI_66	10:31	16:23	5:52	LINE CLEAR AVAILED
449	17-Mar-21	MYSURU	66	HV5	SFCSHIVA_66	9:33	10:31	0:58	HAND TRIPPED
450	17-Mar-21	MYSURU	66	HV5	SFCSHIVA_66	12:18 (16/03/2021)	0:30 (17/03/2021)	12:12 HRS	TRANSFORMER CHARGED
451	17-Mar-21	MYSURU	66	KHB STATION-HV2	KHBCOLONY_66	14:10	14:59	0:49	LINE CLEAR AVAILED
452	17-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
453	17-Mar-21	MYSURU	66	KUNTHUR-DR PETE	NO STATION EFFECTED	6:10	6:15	0:05	LINE FAULT
454	17-Mar-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA 2	BYLUKUPPE_66	5:34	5:42	0:07	LINE FAULT
455	17-Mar-21	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	8:59	12:26	3:27	LINE CLEAR AVAILED
456	17-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	10:10	10:14	0:04	HAND TRIPPED
457	17-Mar-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATION EFFECTED	17:38	19:11	1:32	LINE CLEAR AVAILED
458	17-Mar-21	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATION EFFECTED	17:35 (10/03/2021)	14:31 (17/03/2021)	164:56 HRS	LINE CHARGED
459	17-Mar-21	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATION EFFECTED	11:18	11:41	0:22	HAND TRIPPED
460	17-Mar-21	MYSURU	220	HV2	MADHUVANAHALLI_220	9:27	19:51	10:24	LINE CLEAR AVAILED
461	17-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	21:23	21:39	0:15	LINE FAULT
462	17-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	21:23	21:39	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
463	17-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	21:23	21:39	0:16	HAND TRIPPED
464	17-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	21:23	21:39	0:16	HAND TRIPPED
465	17-Mar-21	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:05	12:55	1:50	LINE CLEAR AVAILED
466	17-Mar-21	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	19:36	19:51	0:15	LOAD CURTAILMENT
467	17-Mar-21	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:05	12:55	1:50	LINE CLEAR AVAILED
468	17-Mar-21	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	19:36	19:51	0:15	LOAD CURTAILMENT
469	17-Mar-21	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	DODDASARANGI_66, MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	21:35:19 (16.03.2021)	15:21:31 (17.03.2021)	17:46	LINE CLEAR AVAILED
470	17-Mar-21	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	DODDASARANGI_66, MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	21:35:19 (16.03.2021)	15:21:31 (17.03.2021)	17:46	LINE CLEAR AVAILED
471	17-Mar-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:09	18:17	0:08	LINE FAULT
472	17-Mar-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:47	21:53	0:06	LINE FAULT
473	17-Mar-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:09	18:17	0:08	LINE FAULT
474	17-Mar-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:47	21:53	0:06	LINE FAULT
475	17-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	02:12	02:18	0:06	LINE FAULT
476	17-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	02:12	02:18	0:06	LINE FAULT
477	17-Mar-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:07	18:13	0:06	LINE CLEAR AVAILED
478	17-Mar-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:07	18:13	0:06	LINE CLEAR AVAILED
479	17-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:02	20:16	0:13	MAIN SUPPLY FAILURE
480	17-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:17	20:22	0:04	MAIN SUPPLY FAILURE
481	17-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:02	10:16	0:13	MAIN SUPPLY FAILURE
482	17-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:02	20:16	0:13	MAIN SUPPLY FAILURE
483	17-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:17	20:22	0:04	MAIN SUPPLY FAILURE
484	17-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:02	10:16	0:13	MAIN SUPPLY FAILURE
485	17-Mar-21	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	08:05	08:18	0:13	LINE FAULT
486	17-Mar-21	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	08:05	08:18	0:13	LINE FAULT
487	17-Mar-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	08:32	08:44	0:11	LINE FAULT
488	17-Mar-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	08:32	08:44	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
489	17-Mar-21	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:04	11:13	0:08	LINE FAULT
490	17-Mar-21	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:04	11:13	0:08	LINE FAULT
491	17-Mar-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA)	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	17:32	18:09	0:37	LOAD CURTAILMENT
492	17-Mar-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA)	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	19:41	20:41	1:00	LOAD CURTAILMENT
493	17-Mar-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA)	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	17:32	18:09	0:37	LOAD CURTAILMENT
494	17-Mar-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA)	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	19:41	20:41	1:00	LOAD CURTAILMENT
495	17-Mar-21	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	18:06	18:15	0:09	LINE FAULT
496	17-Mar-21	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	18:06	18:15	0:09	LINE FAULT
497	17-Mar-21	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	18:06	18:27	0:20	LINE FAULT
498	17-Mar-21	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	18:06	18:27	0:20	LINE FAULT
499	17-Mar-21	TUMKUR	66	PAVAGADA220-PAVGD1(66KV PAVAGADA)	PAVAGADA_66	09:27	09:32	0:05	HAND TRIPPED
500	17-Mar-21	TUMKUR	66	PAVAGADA220-PAVGD1(66KV PAVAGADA)	PAVAGADA_66	09:27	09:32	0:05	HAND TRIPPED
501	17-Mar-21	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	09:27	09:43	0:15	HAND TRIPPED
502	17-Mar-21	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	09:27	09:43	0:15	HAND TRIPPED
503	17-Mar-21	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LIN GDHALLI_66,MANGALWADA_66	09:26	09:32	0:05	HAND TRIPPED
504	17-Mar-21	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LIN GDHALLI_66,MANGALWADA_66	09:26	09:32	0:05	HAND TRIPPED
505	17-Mar-21	TUMKUR	66	TR-1	BELADARA_66	11:15	11:36	0:21	LINE CLEAR AVAILED
506	17-Mar-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	10:38	10:45	0:06	TRANSFORMER FAULT
507	17-Mar-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	18:57	19:07	0:09	TRANSFORMER FAULT
508	17-Mar-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	18:07	18:14	0:06	TRANSFORMER FAULT
509	17-Mar-21	TUMKUR	66	TR-1	NYAMATHI_66	17:45	18:05	0:20	LINE CLEAR AVAILED
510	17-Mar-21	TUMKUR	66	TR-1	BELADARA_66	11:15	11:36	0:21	LINE CLEAR AVAILED
511	17-Mar-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	10:38	10:45	0:06	TRANSFORMER FAULT
512	17-Mar-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	18:57	19:07	0:09	TRANSFORMER FAULT
513	17-Mar-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	18:07	18:14	0:06	TRANSFORMER FAULT
514	17-Mar-21	TUMKUR	66	TR-1	NYAMATHI_66	17:45	18:05	0:20	LINE CLEAR AVAILED
515	17-Mar-21	TUMKUR	66	TR-2	BELADARA_66	11:38	12:11	0:32	LINE CLEAR AVAILED
516	17-Mar-21	TUMKUR	66	TR-2	MATHOD_66	07:21	07:31	0:09	TRANSFORMER FAULT
517	17-Mar-21	TUMKUR	66	TR-2	BELADARA_66	11:38	12:11	0:32	LINE CLEAR AVAILED
518	17-Mar-21	TUMKUR	66	TR-2	MATHOD_66	07:21	07:31	0:09	TRANSFORMER FAULT
519	17-Mar-21	TUMKUR	110	TR-1	SHETYKERE_110	12:00	12:06	0:06	TRANSFORMER FAULT
520	17-Mar-21	TUMKUR	110	TR-1	SHETYKERE_110	12:00	12:06	0:06	TRANSFORMER FAULT
521	17-Mar-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	10:33	14:39	4:05	HAND TRIPPED
522	17-Mar-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	10:33	14:39	4:05	HAND TRIPPED
523	17-Mar-21	TUMKUR	220	HONNALLI 220kv- DAVANAGERE 220kv	HONNALLI_220	10:33	14:47	4:13	LINE CLEAR AVAILED
524	17-Mar-21	TUMKUR	220	HONNALLI 220kv- DAVANAGERE 220kv	HONNALLI_220	10:33	14:47	4:13	LINE CLEAR AVAILED
525	17-Mar-21	TUMKUR	220	HONNALLI 220kv- SHIMOGA 220kv	HONNALLI_220	10:33	14:47	4:13	LINE CLEAR AVAILED
526	17-Mar-21	TUMKUR	220	HONNALLI 220kv- SHIMOGA 220kv	HONNALLI_220	10:33	14:47	4:13	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
527	17-Mar-21	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	10:44	11:47	1:02	HAND TRIPPED
528	17-Mar-21	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	1:04:30 PM(17.03.2021)			LINE OPEN: LINE CLEAR AVAILED
529	17-Mar-21	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	10:44	11:47	1:02	HAND TRIPPED
530	17-Mar-21	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	1:04:30 PM(17.03.2021)			LINE OPEN: LINE CLEAR AVAILED
531	17-Mar-21	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	10:12	17:15	7:03	HAND TRIPPED
532	17-Mar-21	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	10:12	17:15	7:03	HAND TRIPPED
533	18-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
534	18-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
535	18-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
536	18-Mar-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
537	18-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
538	18-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVAILED
539	18-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
540	18-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
541	18-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVAILED
542	18-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
543	18-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
544	18-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVAILED
545	18-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
546	18-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
547	18-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
548	18-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN: LINE CLEAR AVAILED
549	18-Mar-21	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:07 (05.03.2021)	20:14 (18.03.2021)	321:07HRS	LINE CHARGED
550	18-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
551	18-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
552	18-Mar-21	BAGALKOT	110	KUMTA-SIRS1	STATION NOT AFFECTED KUMTA_110	12:34 (13.03.2021)			LINE OPEN: LINE CLEAR AVAILED
553	18-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
554	18-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
555	18-Mar-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	15:05 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
556	18-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI_110	12:02 (16.03.2021)			LINE OPEN: LINE CLEAR AVAILED
557	18-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
558	18-Mar-21	BAGALKOT	110	SAMBAPUR ROAD -DAMBAL	STATION NOT AFFECTED SAMBAPUR ROAD_110	13:10 (17.03.2021)	14:14 (18.03.2021)	25:04HRS	LINE CHARGED
559	18-Mar-21	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	12:55	13:07	0:12	TRANSFORMER FAULT
560	18-Mar-21	BAGALKOT	110	AMBEWADI-SUPA2	STATION NOT AFFECTED AMBEWADI_220	14:14	14:40	0:26	LINE CLEAR AVAILED
561	18-Mar-21	BAGALKOT	110	AMBEWADI-SUPA1	STATION NOT AFFECTED AMBEWADI_220	14:14	14:40	0:26	LINE CLEAR AVAILED
562	18-Mar-21	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	14:14	14:17	0:03	LINE CLEAR AVAILED
563	18-Mar-21	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	14:14	14:17	0:03	LINE CLEAR AVAILED
564	18-Mar-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AMBEWADI_220	14:14	14:21	0:07	LINE CLEAR AVAILED
565	18-Mar-21	BAGALKOT	220	220/110KV,HV1LV1,HV2,LV2	BAGEWADI_220,MAMADAPUR_110, MUDEBIHAL_110	23:05	23:08	0:03	TRANSFORMER FAULT
566	18-Mar-21	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	STATION NOT AFFECTED BAGALKOT_220	10:55	11:46	0:51	LINE FAULT
567	18-Mar-21	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	18:04	18:11	0:07	LINE FAULT
568	18-Mar-21	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	18:26	18:46	0:20	LINE FAULT
569	18-Mar-21	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	10:56	14:19	3:23	NFBC ISSUED
570	18-Mar-21	BAGALKOT	110	DAMBAL-SUZLON1&2	DAMBAL_110	10:55	14:23	3:28	LINE CLEAR AVAILED
571	18-Mar-21	BAGALKOT	110	DAMBAL-EILS(ENERCON)	DAMBAL_110	10:55	14:25	3:30	LINE CLEAR AVAILED
572	18-Mar-21	BAGALKOT	110	DAMBAL-MUNDARGI	DAMBAL_110	10:40	15:43	5:03	LINE CLEAR AVAILED
573	18-Mar-21	BAGALKOT	110	GADAG220-DAMBAL	STATION NOT AFFECTED GADAG_220	10:53	14:30	3:37	LINE CLEAR AVAILED
574	18-Mar-21	BAGALKOT	110	110/11KV,HV3(HV2)	HALIYAL_110	10:05	14:20	4:15	LINE CLEAR AVAILED
575	18-Mar-21	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	STATION NOT AFFECTED HATTARAGI_110	19:18 (18.03.2021)			LINE OPEN:LINE FAULT
576	18-Mar-21	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	7:09	7:35	0:26	HAND TRIPPED
577	18-Mar-21	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	11:32	20:13	8:41	LINE CLEAR AVAILED
578	18-Mar-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110,DHULKED_33, NEVARGI_33,ALSANGI_33	10:52	11:00	0:08	TRANSFORMER FAULT
579	18-Mar-21	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220	10:56	11:25	0:29	TRANSFORMER FAULT
580	18-Mar-21	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220	10:56	11:25	0:29	TRANSFORMER FAULT
581	18-Mar-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110	11:18	11:39	0:21	HAND TRIPPED
582	18-Mar-21	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	LOKAPUR_110	11:18	12:13	0:55	HAND TRIPPED
583	18-Mar-21	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	MELLIGERI_110	11:18	11:38	0:20	HAND TRIPPED
584	18-Mar-21	BAGALKOT	110	VAJRAMATTI220- MANTUR	MANTUR_110	11:18	11:38	0:20	HAND TRIPPED
585	18-Mar-21	BAGALKOT	110	VAJRAMATTI220- JK CEMENT	VAJRAMATTI_220	11:18	11:32	0:14	HAND TRIPPED
586	18-Mar-21	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	11:18	11:34	0:16	HAND TRIPPED
587	18-Mar-21	BAGALKOT	110	SAVANUR- RAMANKOPPA (SHIGGOAN)	SHIGGOAN_110	07:12	07:40	0:28	HAND TRIPPED
588	18-Mar-21	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	18:13	18:23	0:10	HAND TRIPPED
589	18-Mar-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	10:22	10:34	0:12	TRANSFORMER FAULT
590	18-Mar-21	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	6:50	07:21	0:31	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
591	18-Mar-21	BAGALKOT	110	NARENDRA220- BELUR1	BELUR_110	6:51 (18.03.2021)			LINE OPEN:LINE FAULT
592	18-Mar-21	BAGALKOT	110	NARENDRA220- BELUR2	BELUR_110	6:51	06:55	0:04	HAND TRIPPED
593	18-Mar-21	BAGALKOT	110	NARENDRA220- KUD1	KUD DHARWAD_110	6:51	6:58	0:07	HAND TRIPPED
594	18-Mar-21	BAGALKOT	110	NARENDRA220- MRUTHYUNJAY NAGAR2	MRUTHYUNJANAGAR_110	7:00	7:24	0:24	HAND TRIPPED
595	18-Mar-21	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110,ALNAVAR_33	21:56	22:00	0:04	TRANSFORMER FAULT
596	18-Mar-21	BAGALKOT	110	110/33KV,HV2	HUNGUND_110, KARADI_33, AMINGAD_33	7:25	7:30	0:05	TRANSFORMER FAULT
597	18-Mar-21	BAGALKOT	110	VISHWANATH SUGARS- HUKKERI	HUKKERI_110	18:51	18:57	0:06	LINE FAULT
598	18-Mar-21	BAGALKOT	110	110/11KV, HV1	MELLIGERI_110	13:22	16:58	3:36	TRANSFORMER FAULT
599	18-Mar-21	BENGALURU	66	HV1	YEDUMADU	09:05	09:10	00:05	LINE CLEAR AVAILED
600	18-Mar-21	BENGALURU	66	HV1	HUKUNDA	15:21:05	15:26:52	00:05	LINE CLEAR AVAILED
601	18-Mar-21	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	14:48	15:10	00:22	LOAD CHANGEOVER
602	18-Mar-21	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	16:40	17:00	00:20	LOAD CHANGEOVER
603	18-Mar-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	06:24	06:58	00:34	MAIN SUPPLY FAILURE
604	18-Mar-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	21:07	21:10	00:03	LOAD CHANGEOVER
605	18-Mar-21	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	12:00	12:02	00:02	LOAD CHANGEOVER
606	18-Mar-21	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	15:32	15:35	00:03	LOAD CHANGEOVER
607	18-Mar-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI	10:20	10:46	00:26	LINE CLEAR AVAILED
608	18-Mar-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:04	11:14	00:10	LINE FAULT
609	18-Mar-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:20	15:40	00:20	LINE CLEAR AVAILED
610	18-Mar-21	BENGALURU	66	KORAMANGALA 220 -AUSTIN TOWN 2	NO STATION AFFECTED	07:42	09:57	02:15	LINE FAULT
611	18-Mar-21	BENGALURU	66	KORAMANGALA 220 -AUSTIN TOWN 1	NO STATION AFFECTED	10:13	10:21	00:08	LINE CLEAR AVAILED
612	18-Mar-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:28	13:30	00:02	LOAD CHANGEOVER
613	18-Mar-21	BENGALURU	66	HV2	SOMANAHALLI 220	13:35	13:40	00:05	LOAD CHANGEOVER
614	18-Mar-21	BENGALURU	66	HV2	SUBRAMANYAPURA 66	11:16	11:40	00:24	LINE CLEAR AVAILED
615	18-Mar-21	BENGALURU	66	DALASNUR - SRINIVASPURA	DALASNUR	05:45	06:05	00:20	MAIN SUPPLY FAILURE
616	18-Mar-21	BENGALURU	66	DALASNUR - SRINIVASPURA	DALASNUR	17:15	17:35	00:20	MAIN SUPPLY FAILURE
617	18-Mar-21	BENGALURU	66	DALASNUR - SRINIVASPURA	DALASNUR	19:10	19:25	00:15	MAIN SUPPLY FAILURE
618	18-Mar-21	BENGALURU	66	HV1	HOSKOTE 66	11:30	12:45	01:15	TRANSFORMER FAULT
619	18-Mar-21	BENGALURU	66	HV1	HOSKOTE 66	16:10	16:40	00:30	LINE CLEAR AVAILED
620	18-Mar-21	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	05:45	06:00	00:15	LOAD CURTAILMENT
621	18-Mar-21	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	07:30	08:00	00:30	LOAD CURTAILMENT
622	18-Mar-21	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	15:23	15:40	00:17	LINE FAULT
623	18-Mar-21	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	15:23	16:28	01:05	LINE FAULT
624	18-Mar-21	BENGALURU	220	HV2	T K HALLI 220	11:53	12:01	00:08	TRANSFORMER FAULT
625	18-Mar-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	11:53	12:04	00:11	LINE CLEAR AVAILED
626	18-Mar-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	11:53	12:05	00:12	LINE CLEAR AVAILED
627	18-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:53	12:33	00:40	LINE CLEAR AVAILED
628	18-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:53	12:33	00:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
629	18-Mar-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	11:53	12:08	00:15	LINE CLEAR AVALIED
630	18-Mar-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	T K HALLI 220	11:53	12:08	00:15	LINE CLEAR AVALIED
631	18-Mar-21	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	08:20	08:30	00:10	LOAD CURTAILMENT
632	18-Mar-21	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	17:15	17:40	00:25	LOAD CURTAILMENT
633	18-Mar-21	BENGALURU	66	SADALI - JULUPALYA	JULUPALYA	16:34	16:40	00:06	LINE FAULT
634	18-Mar-21	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	HENNUR CROSS	06:24	06:58	00:34	LINE FAULT
635	18-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
636	18-Mar-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)			LINE OPEN:LINE FAULT
637	18-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
638	18-Mar-21	GULBARGA	220	HV2	HUMNABAD_220	06:15	06:30	00:15	TRANSFORMER FAULT
639	18-Mar-21	GULBARGA	220	HV2	ITTAGI_220	12:30	15:05	02:35	LINE CLEAR AVALIED
640	18-Mar-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	05:30	06:03	00:33	LINE FAULT
641	18-Mar-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	06:15	06:40	00:25	LINE FAULT
642	18-Mar-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURA_110	06:15	06:32	00:17	LINE FAULT
643	18-Mar-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	07:08	07:40	00:32	LOAD CURTAILMENT
644	18-Mar-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_220	07:08	07:27	00:19	LINE FAULT
645	18-Mar-21	GULBARGA	110	HV2	HATTI_110	07:13	07:22	00:09	TRANSFORMER FAULT
646	18-Mar-21	GULBARGA	110	HV2	SINDHANOOR_110	13:35	13:45	00:10	TRANSFORMER FAULT
647	18-Mar-21	GULBARGA	110	HV1	MASKI_110	16:30	16:37	00:07	LINE CLEAR AVALIED
648	18-Mar-21	GULBARGA	110	HV1,HV2	SHAKTINAGAR_110	17:00	18:11	01:11	TRANSFORMER FAULT
649	18-Mar-21	GULBARGA	110	RAICHUR-MATAMARI	MATMARI_110	17:45	18:47	01:02	LINE FAULT
650	18-Mar-21	GULBARGA	110	CHINCHOLI-MANEKHALLI	CHINCHOLI_110	19:40	20:30	00:50	LINE FAULT
651	18-Mar-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	20:35	20:45	00:10	LINE FAULT
652	18-Mar-21	GULBARGA	110	HV2	CHINCHOLI_110	13:50(16.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
653	18-Mar-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	14:00(16.03.2021)	12:03(18.03.2021)	46:13 HRS	LINE FAULT
654	18-Mar-21	GULBARGA	66	HV1	KOTTUR_66	10:02	10:37	00:35	LINE CLEAR AVALIED
655	18-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVALIED
656	18-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVALIED
657	18-Mar-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	16:29	16:33	00:04	LINE FAULT
658	18-Mar-21	HASSAN	110	MSEZ-JSS2	MSEZ_220	10:06	14:58	04:52	LINE CLEAR AVALIED
659	18-Mar-21	HASSAN	110	HV4	PUTUR_110	09:58	15:25	05:27	LINE CLEAR AVALIED
660	18-Mar-21	HASSAN	110	HV1	BARANG_110	14:19	19:38	05:19	LINE CLEAR AVALIED
661	18-Mar-21	HASSAN	110	HV1	KULASHEKARA_110	10:35	18:47	08:12	LINE CLEAR AVALIED
662	18-Mar-21	HASSAN	110	HV2	KUNDAPURA_110	10:30	10:37	00:07	LINE CLEAR AVALIED
663	18-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	07:20	17:12	09:52	LINE CLEAR AVALIED
664	18-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	07:20	17:12	09:52	LINE CLEAR AVALIED
665	18-Mar-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:40	12:59	00:19	LINE FAULT
666	18-Mar-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	15:24	19:44	04:20	LINE FAULT
667	18-Mar-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	09:15	14:10	04:55	NFBC ISSUED
668	18-Mar-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	09:15	14:10	04:55	NFBC ISSUED
669	18-Mar-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:13	18:48	08:35	LINE CLEAR AVALIED
670	18-Mar-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:13	18:48	08:35	LINE CLEAR AVALIED
671	18-Mar-21	HASSAN	66	HV2	CHIKMAGLUR_66	14:13	16:16	02:03	LINE CLEAR AVALIED
672	18-Mar-21	HASSAN	66	HV1	HALEBEDU_66	12:09	13:01	00:52	LINE CLEAR AVALIED
673	18-Mar-21	HASSAN	66	HNP2HASS3	HOLENARASIPURA_220	04:09	11:32	07:23	LINE FAULT
674	18-Mar-21	HASSAN	66	HV1	HOLENARASIPURA_220	10:41	14:59	04:18	LINE CLEAR AVALIED
675	18-Mar-21	HASSAN	66	HNPRA	MOSALEHOSAHALLI_66	04:10	11:10	07:00	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
676	18-Mar-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	04:10	05:10	01:00	MAIN SUPPLY FAILURE
677	18-Mar-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:10	11:30	00:20	MAIN SUPPLY FAILURE
678	18-Mar-21	HASSAN	66	HV2	RAMNATHPURA_66	08:32	11:46	03:14	LINE CLEAR AVAILED
679	18-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	13:44	18:35	04:51	LINE CLEAR AVAILED
680	18-Mar-21	HASSAN	66	SAKALE-IIPCL2	SAKALESHPURA_66	13:44	18:35	04:51	LINE CLEAR AVAILED
681	18-Mar-21	HASSAN	66	HV2	SHRAVANABELAGOLA_66	13:03	14:17	01:14	LINE CLEAR AVAILED
682	18-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:13	18:45	08:32	LINE CLEAR AVAILED
683	18-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:00	18:45	08:45	LINE CLEAR AVAILED
684	18-Mar-21	MYSURU	66	HV1	BILIKERE_66	4:43	4:50	0:06	TRANSFORMER FAULT
685	18-Mar-21	MYSURU	66	HV1	BILIKERE_66	9:12	9:22	0:10	TRANSFORMER FAULT
686	18-Mar-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	CHUNCHUNKATTE_66	10:09	16:53	6:44	LINE CLEAR AVAILED
687	18-Mar-21	MYSURU	66	CR NAGARA-YALANDUR	NO STATION EFFECTED	8:15	8:17	0:01	HAND TRIPPED
688	18-Mar-21	MYSURU	66	DK MAIDANA-VAJMANGALA	NO STATION EFFECTED	13:52	14:32	0:39	HAND TRIPPED
689	18-Mar-21	MYSURU	66	HV2	HDKOTE_66	16:56	18:07	1:10	LINE CLEAR AVAILED
690	18-Mar-21	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATION EFFECTED	12:50	14:25	1:34	HAND TRIPPED
691	18-Mar-21	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATION EFFECTED	12:49	14:28	1:39	HAND TRIPPED
692	18-Mar-21	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	13:41	13:45	0:04	HAND TRIPPED
693	18-Mar-21	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	14:10	14:13	0:03	HAND TRIPPED
694	18-Mar-21	MYSURU	66	HOOTAGALLI-FTS1	NO STATION EFFECTED	13:28	14:28	0:59	HAND TRIPPED
695	18-Mar-21	MYSURU	220	KADAKOLA-BEGUR 1	NO STATION EFFECTED	11:02	11:11	0:08	LINE CLEAR AVAILED
696	18-Mar-21	MYSURU	66	KADAKOLA-SARGUR 2	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	11:53	11:58	0:04	LINE FAULT
697	18-Mar-21	MYSURU	66	KADAKOLA-SARGUR 1	SANTHESARAGUR_66 CHANDAKAVADI_66 DOORA_66 HURA_66 HULLAHALLI_66	11:54	11:57	0:03	LINE FAULT
698	18-Mar-21	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATION EFFECTED	13:53	14:01	0:07	LINE FAULT
699	18-Mar-21	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	12:25	12:32	0:07	LINE FAULT
700	18-Mar-21	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	13:00	13:12	0:12	LINE FAULT
701	18-Mar-21	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	14:17	14:29	0:12	LINE FAULT
702	18-Mar-21	MYSURU	66	HV1	KUNTHUR_66	9:58	17:11	7:12	LINE CLEAR AVAILED
703	18-Mar-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	11:06	16:57	5:50	NFBC ISSUED
704	18-Mar-21	MYSURU	66	MADDUR-HV1	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	11:54	12:33	0:39	HAND TRIPPED
705	18-Mar-21	MYSURU	66	MALLAVALLI-MANDYA	MALAVALLI_66	12:16	13:22	1:06	LINE CLEAR AVAILED
706	18-Mar-21	MYSURU	66	HV1	MANDGERE_66	9:25	9:30	0:05	TRANSFORMER FAULT
707	18-Mar-21	MYSURU	66	HV2	MEGALAPURA_66	12:34	12:48	0:14	TRANSFORMER FAULT
708	18-Mar-21	MYSURU	66	HV1	MYSORESOUTH_66	12:30	14:14	1:44	LINE CLEAR AVAILED
709	18-Mar-21	MYSURU	66	HV2	MYSORESOUTH_66	13:45	21:36	7:51	TRANSFORMER FAULT
710	18-Mar-21	MYSURU	66	NANJANGUDU-KADAKOLA 2	NO STATION EFFECTED	9:31	12:32	3:00	HAND TRIPPED
711	18-Mar-21	MYSURU	66	HV5	SFCSHIVA_66	12:06 (18/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
712	18-Mar-21	MYSURU	66	THANDYA-KADAKOLA	NO STATION EFFECTED	12:32 (18/03/2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
713	18-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	2:14	2:19	0:05	LINE FAULT
714	18-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:18	10:27	0:09	LINE FAULT
715	18-Mar-21	MYSURU	66	YELANDUR-CR NAGARA	NO STATION EFFECTED	1:39	9:16	7:37	HAND TRIPPED
716	18-Mar-21	MYSURU	66	220KV BEGUR -SARGUR	B MATKERE_66 SANTHESARAGUR_66,	11:54	12:03	0:09	TRANSFORMER FAULT
717	18-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
718	18-Mar-21	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	13:04:30 (17.03.2021)	17:47:32 (18.03.2021)	28:23:00	LINE CHARGED
719	18-Mar-21	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	12:35	13:05:55	0:30	HAND TRIPPED
720	18-Mar-21	TUMKUR	110	TR-2	KADEHALLI_110	9:00	9:10	0:10	TRANSFORMER FAULT
721	18-Mar-21	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110,DODDAGUNI_110	12:46	13:02	0:16	HAND TRIPPED
722	18-Mar-21	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	06:45	07:30	0:44	LOAD CURTAILMENT
723	18-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,	16:25	16:48	0:22	LOAD CURTAILMENT
724	18-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	19:03	19:12	0:09	LOAD CURTAILMENT
725	18-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	14:47	14:59	0:11	LOAD CURTAILMENT
726	18-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	16:27	17:02	0:35	LOAD CURTAILMENT
727	18-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	17:15	17:43	0:27	LOAD CURTAILMENT
728	18-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	19:03	22:45	3:42	LOAD CURTAILMENT
729	18-Mar-21	TUMKUR	66	TR-1	CHANNAGIRI_66	09:02	09:04	0:01	TRANSFORMER FAULT
730	18-Mar-21	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	08:46	12:08	3:21	HAND TRIPPED
731	18-Mar-21	TUMKUR	66	TR-1	CHIKKABANAGERE_66	11:38	12:09	0:30	LINE CLEAR AVAILED
732	18-Mar-21	TUMKUR	66	TR-1	CHIKKABANAGERE_66	14:06	14:40	0:34	LINE CLEAR AVAILED
733	18-Mar-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	11:34	13:22	1:48	LINE CLEAR AVAILED
734	18-Mar-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	13:29	14:38	1:08	LINE CLEAR AVAILED
735	18-Mar-21	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	15:21	16:17	0:56	LINE CLEAR AVAILED
736	18-Mar-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	07:37	08:00	0:22	LOAD CURTAILMENT
737	18-Mar-21	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	07:24	08:12	0:48	MAIN SUPPLY FAILURE
738	18-Mar-21	TUMKUR	66	TR-1	DEVARAHALLI_66	07:24	08:12	0:48	MAIN SUPPLY FAILURE
739	18-Mar-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	13:57	18:21	4:23	LINE CLEAR AVAILED
740	18-Mar-21	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	06:02	06:14	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
741	18-Mar-21	TUMKUR	66	TR-1	HIRIYUR_66	08:19	08:27	0:08	TRANSFORMER FAULT
742	18-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:59	18:35	0:35	HAND TRIPPED
743	18-Mar-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	10:00	10:06	0:05	MAIN SUPPLY FAILURE
744	18-Mar-21	TUMKUR	66	TR-2	SHYLAPURA_66	00:00	00:54	0:54	TRANSFORMER FAULT
745	18-Mar-21	TUMKUR	66	SHYLAPURA-PR PURA	SHYLAPURA_66	00:00	01:07	1:06	LINE FAULT
746	18-Mar-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	12:04	12:14	0:09	LINE FAULT
747	19-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
748	19-Mar-21	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	11:23	12:05	0:42	LINE CLEAR AVOIDED
749	19-Mar-21	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	22:19	22:22	0:03	LOAD CURTAILMENT
750	19-Mar-21	BAGALKOT	110	110/11KV,HV1	MALLIGERI_110	12:22	17:10	4:48	TRANSFORMER FAULT
751	19-Mar-21	BAGALKOT	110	110/11KV,HV1	MORATAGI_110	12:23	17:39	5:16	LINE CLEAR AVOIDED
752	19-Mar-21	BAGALKOT	110	110/11KV,HV1	MUDUGANUR_110	22:25	22:29	0:04	LOAD CURTAILMENT
753	19-Mar-21	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	23:23	23:35	0:12	TRANSFORMER FAULT
754	19-Mar-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	22:18	22:29	0:11	LOAD CURTAILMENT
755	19-Mar-21	BAGALKOT	110	110/11KV,HV2	ATHARGA_110	22:19	22:27	0:08	LOAD CURTAILMENT
756	19-Mar-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED ITNAL_110	9:20	18:30	9:10	LINE CLEAR AVOIDED
757	19-Mar-21	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	14:14	14:43	0:29	LINE CLEAR AVOIDED
758	19-Mar-21	BAGALKOT	110	110/11KV,HV2	UGARKHUD_110	12:55	15:26	2:31	LINE CLEAR AVOIDED
759	19-Mar-21	BAGALKOT	110	110/11KV,HV4(HV2)	GAJENDRAGAD_110	22:18	22:29	0:11	LOAD CURTAILMENT
760	19-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
761	19-Mar-21	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,KALABILAGI_33,HIRE PADASALAGI LIS_33,TUNGAL LIS_33	22:19	22:38	0:19	LOAD CURTAILMENT
762	19-Mar-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,MYTR A SOLAR_33	22:19	22:26	0:07	LOAD CURTAILMENT
763	19-Mar-21	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKED_33,HALASANGI 33,NEVARGI_33	9:21	9:25	0:04	TRANSFORMER FAULT
764	19-Mar-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	02:21	02:46	0:25	LINE FAULT
765	19-Mar-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	06:25	08:28	2:03	HAND TRIPPED
766	19-Mar-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	17:01	18:06	1:05	LINE CLEAR AVOIDED
767	19-Mar-21	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	10:30	17:06	6:36	LINE CLEAR AVOIDED
768	19-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVOIDED
769	19-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)	7:35 (19.03.2021)	374:38 HRS	LINE CHARGED
770	19-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
771	19-Mar-21	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	STATION NOT AFFECTED HATTARAGI_110	19:18 (18.03.2021)	4:53 (19.03.2021)	9:35 HRS	LINE CHARGED
772	19-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVOIDED
773	19-Mar-21	BAGALKOT	110	HAVERI220-SAVANUR	Savanur_110	6:33	7:16	0:43	HAND TRIPPED
774	19-Mar-21	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	4:31	05:31	1:00	HAND TRIPPED
775	19-Mar-21	BAGALKOT	110	HIREHAL-RON	HIREHAL_110,RON_110	14:49	14:51	0:02	HAND TRIPPED
776	19-Mar-21	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110	7:16	8:39	1:23	HAND TRIPPED
777	19-Mar-21	BAGALKOT	110	ITNAL-BORUKA	STATION NOT AFFECTED ITNAL_110	9:26	19:03	9:37	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
778	19-Mar-21	BAGALKOT	110	ITNAL-BPCL	STATION NOT AFFECTED ITNAL 110	9:25	18:50	9:25	LINE CLEAR AVOIDED
779	19-Mar-21	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED ITNAL 110	9:37	18:29	8:52	LINE CLEAR AVOIDED
780	19-Mar-21	BAGALKOT	110	ITNAL-RAIBAG2	STATION NOT AFFECTED ITNAL 110	9:37	18:29	8:52	LINE CLEAR AVOIDED
781	19-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVOIDED
782	19-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
783	19-Mar-21	BAGALKOT	110	KUMTA-SIRS1	STATION NOT AFFECTED KUMTA 110	12:34 (13.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
784	19-Mar-21	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD 110	07:35	13:49	6:14	HAND TRIPPED
785	19-Mar-21	BAGALKOT	110	LOKAPUR-SALAHALLI	LOKAPUR 110,SALAHALLI 110	13:25	14:48	1:23	LINE FAULT
786	19-Mar-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE 110	15:05 (14.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
787	19-Mar-21	BAGALKOT	110	NARAGUND-BPCL	STATION NOT AFFECTED NARGUND 110	18:19	18:42	0:23	LINE FAULT
788	19-Mar-21	BAGALKOT	110	NARENDRA220- BELUR1	STATION NOT AFFECTED BELUR 110	6:51 (18.03.2021)	10:36 (19.03.2021)	27:45 HRS	LINE CHARGED
789	19-Mar-21	BAGALKOT	110	NARENDRA220- BELUR1	BELUR 110	10:50	13:07	2:17	HAND TRIPPED
790	19-Mar-21	BAGALKOT	110	NARENDRA220- BELUR2	BELUR 110	8:17	10:35	2:18	LINE CLEAR AVOIDED
791	19-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVOIDED
792	19-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL 110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
793	19-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
794	19-Mar-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
795	19-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON 110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
796	19-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON 110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
797	19-Mar-21	BAGALKOT	110	RON-GAMESH	STATION NOT AFFECTED RON 110	14:56	14:58	0:02	HAND TRIPPED
798	19-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
799	19-Mar-21	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	STATION NOT AFFECTED KAGAWADA 110	12:07	13:10	1:03	LINE CLEAR AVOIDED
800	19-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI 110	12:02 (16.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
801	19-Mar-21	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI 110	4:59	7:18	2:19	HAND TRIPPED
802	19-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
803	19-Mar-21	BAGALKOT	110	TUMMINAKATTI-RATTIHALI	STATION NOT AFFECTED RATTIHALI 110	19:11 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
804	19-Mar-21	BAGALKOT	110	VAJRAMATTI-BILAGI	BILAGI_110	23:12 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
805	19-Mar-21	BAGALKOT	110	YARAGATTI-KATKOL	KATKOL 110	22:32	22:41	0:09	HAND TRIPPED
806	19-Mar-21	BAGALKOT	220	220/110KV,HV2,LV2	BAGALKOT_220,BAGALKOT_110,NAV ANAGAR1 110	13:22	14:04	0:42	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
807	19-Mar-21	BAGALKOT	220	220/110KV,HV2,LV3	BAGALKOT_220,KERUR_110,GULEDA DUDDA_110,_110,LOKAPUR_110	13:22	14:42	1:20	TRANSFORMER FAULT
808	19-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
809	19-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN: LINE CLEAR AVAILED
810	19-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
811	19-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
812	19-Mar-21	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	23:21 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
813	19-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
814	19-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
815	19-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
816	19-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
817	19-Mar-21	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	15:15	15:20	0:05	LOAD CHANGEOVER
818	19-Mar-21	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	12:40	13:10	0:30	LOAD CHANGEOVER
819	19-Mar-21	BENGALURU	66	HV1	HAL 220	13:35	13:56	0:21	LINE CLEAR AVAILED
820	19-Mar-21	BENGALURU	66	HV1	YEDUMADU	11:05	11:20	0:15	LINE CLEAR AVAILED
821	19-Mar-21	BENGALURU	66	HV1	MUDIYANUR	12:00	13:00	1:00	LINE CLEAR AVAILED
822	19-Mar-21	BENGALURU	66	HV1	GUDIBAND3E	12:30	12:40	0:10	LINE CLEAR AVAILED
823	19-Mar-21	BENGALURU	66	HV2	HAL 220	10:50	13:30	2:40	LINE CLEAR AVAILED
824	19-Mar-21	BENGALURU	66	HV2	CHATRA	10:31	10:37	0:06	LINE CLEAR AVAILED
825	19-Mar-21	BENGALURU	66	HV2	HANUMANTHNAGARA	16:18	16:56	0:38	LINE CLEAR AVAILED
826	19-Mar-21	BENGALURU	66	KODIGEHALLI - BYADRAHALLI	KODIGEHALLI, TAVAREKERE, T G HALLI	10:09	10:14	0:05	LINE FAULT
827	19-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	7:10	7:54	0:43	LOAD CURTAILMENT
828	19-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	19:19	19:51	0:31	LOAD CURTAILMENT
829	19-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	6:24	6:28	0:03	LINE FAULT
830	19-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	4:23	4:29	0:06	LINE FAULT
831	19-Mar-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	6:18	7:10	0:51	LOAD CURTAILMENT
832	19-Mar-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	19:41	20:15	0:34	LOAD CURTAILMENT
833	19-Mar-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:24	6:31	0:06	LINE FAULT
834	19-Mar-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	4:23	4:27	0:04	LINE FAULT
835	19-Mar-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	4:00	4:11	0:11	LINE CLEAR AVAILED
836	19-Mar-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	7:55	8:20	0:25	LOAD CURTAILMENT
837	19-Mar-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	19:08	19:40	0:32	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
838	19-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	6:40	7:35	0:54	LOAD CURTAILMENT
839	19-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	4:00	4:11	0:11	LINE CLEAR AVAILED
840	19-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	20:06	20:30	0:24	LOAD CURTAILMENT
841	19-Mar-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	7:35	8:20	0:45	LOAD CURTAILMENT
842	19-Mar-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	7:55	8:20	0:25	LOAD CURTAILMENT
843	19-Mar-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:36	20:06	0:30	LOAD CURTAILMENT
844	19-Mar-21	BENGALURU	66	KORAMANGALA 220 - HAL 2	NO STATION AFFECTED	13:39	14:16	0:37	LINE FAULT
845	19-Mar-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)			LINE OPEN:LINE FAULT
846	19-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:47	9:55	0:07	LINE FAULT
847	19-Mar-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:19	6:30	0:11	LINE FAULT
848	19-Mar-21	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI, T G HALLI	14:58	15:06	0:08	LINE FAULT
849	19-Mar-21	BENGALURU	66	T K HALLI 220 - BWSSB 2	NO STATION AFFECTED	11:42	11:54	0:12	LINE FAULT
850	19-Mar-21	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	12:48	13:10	0:21	LOAD CHANGEOVER
851	19-Mar-21	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	15:15	15:19	0:04	LOAD CHANGEOVER
852	19-Mar-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	14:56	15:09	0:13	LINE FAULT
853	19-Mar-21	BENGALURU	66	YENNIGADALE - BOMMEPALLI	YENNIGADALE, CHELUR, CHAKAVELU	11:15	12:35	1:20	LINE CLEAR AVAILED
854	19-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
855	19-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
856	19-Mar-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	19:59	22:07	02:08	LINE FAULT
857	19-Mar-21	GULBARGA	110	HV1	RAICHUR_220	10:54	14:06	03:12	LINE CLEAR AVAILED
858	19-Mar-21	GULBARGA	110	HV1	RAICHUR_220	14:45	15:50	01:05	LINE CLEAR AVAILED
859	19-Mar-21	GULBARGA	110	HV1	HUMNABAD_220	11:20	12:14	00:54	LINE CLEAR AVAILED
860	19-Mar-21	GULBARGA	110	HV1	HUMNABAD_220	13:18	14:14	00:56	LINE CLEAR AVAILED
861	19-Mar-21	GULBARGA	110	HV1	KURKUNTA_110	05:10	05:20	00:10	LOAD CURTAILMENT
862	19-Mar-21	GULBARGA	110	HV1	CHICKSUGUR_10	07:38	12:46	05:08	LINE CLEAR AVAILED
863	19-Mar-21	GULBARGA	110	HV2	CHINCHOLI_110	13:50(16.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
864	19-Mar-21	GULBARGA	110	HV2	KOLHAR_10	11:40	11:50	00:10	LINE CLEAR AVAILED
865	19-Mar-21	GULBARGA	110	HV2	HATTI_110	22:10	22:20	00:10	LINE CLEAR AVAILED
866	19-Mar-21	GULBARGA	110	HV2	JEWARGI_110	16:50	17:05	00:15	LINE CLEAR AVAILED
867	19-Mar-21	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARGUTTI_110	11:26	11:35	00:09	LINE CLEAR AVAILED
868	19-Mar-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFACTORY,C HOWDAPUR_110	02:11	02:16	00:05	LINE FAULT
869	19-Mar-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFACTORY,C HOWDAPUR_110	04:33	04:40	00:07	LINE FAULT
870	19-Mar-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	05:36	15:00	09:24	LINE CLEAR AVAILED
871	19-Mar-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR IPP	KUSHTAGI_220	04:54	11:00	06:06	LINE CLEAR AVAILED
872	19-Mar-21	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	19:30(19.3.2021)			LINE OPEN: LINE CLEAR AVAILED
873	19-Mar-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	18:42	19:55	01:13	LINE FAULT
874	19-Mar-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	20:36	20:55	00:19	LINE FAULT
875	19-Mar-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	22:52	23:00	00:08	LINE FAULT
876	19-Mar-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS IPP	SEDAM_220	08:34	18:39	10:05	LINE CLEAR AVAILED
877	19-Mar-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	21:12(19.03.2021)			LINE OPEN:LINE FAULT
878	19-Mar-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	21:12(19.03.2021)	7:56(20.03.2021)	10:44 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
879	19-Mar-21	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERAD ONA_110,SRERAMNAGAR_110,MALL APUR_110	22:50	23:05	00:15	LINE FAULT
880	19-Mar-21	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	12:10	12:50	00:40	LINE CLEAR AVOID
881	19-Mar-21	GULBARGA	220	HV1 & HV2	KAPNOOR_220	06:20	07:10	00:50	TRANSFORMER FAULT
882	19-Mar-21	HASSAN	66	BHADRA-KRNAGARA	DODDAKA	09:19	09:27	00:08	MAIN SUPPLY FAILURE
883	19-Mar-21	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA	10:25	10:32	00:07	LINE FAULT
884	19-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNAR	10:38	17:39	07:01	LINE CLEAR AVOID
885	19-Mar-21	HASSAN	66	HNPR2-MYSOR2	HNPR2	09:19	09:26	00:07	LINE FAULT
886	19-Mar-21	HASSAN	66	HV1	ATTICHO	10:39	17:45	07:06	LINE CLEAR AVOID
887	19-Mar-21	HASSAN	66	HV1	BALEHN	22:24	22:52	00:28	LOAD CURTAILMENT
888	19-Mar-21	HASSAN	66	HV1	SBELAG	22:17	22:28	00:11	LOAD CURTAILMENT
889	19-Mar-21	HASSAN	66	HV1	CHANNAR	15:50	16:24	00:34	LINE CLEAR AVOID
890	19-Mar-21	HASSAN	66	HV2	UDAYAP	12:52	12:56	00:04	TRANSFORMER FAULT
891	19-Mar-21	HASSAN	66	HV2	MAGGE	10:43	11:20	00:37	LINE CLEAR AVOID
892	19-Mar-21	HASSAN	66	HV2	RAMPUR	07:29	07:39	00:10	TRANSFORMER FAULT
893	19-Mar-21	HASSAN	66	HV2	RMWNGR	22:17	22:35	00:18	TRANSFORMER FAULT
894	19-Mar-21	HASSAN	66	HV2	SALAGAM	22:17	22:23	00:06	LOAD CURTAILMENT
895	19-Mar-21	HASSAN	66	HV2	CHANNAR	22:16	22:29	00:13	LOAD CURTAILMENT
896	19-Mar-21	HASSAN	66	HV2	BASAVAG	05:19	05:28	00:09	LOAD CURTAILMENT
897	19-Mar-21	HASSAN	66	KANDLI-HASSAN	KANDLI	15:53	16:06	00:13	LINE FAULT
898	19-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOID
899	19-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOID
900	19-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKALE	13:48	19:47	05:59	LINE CLEAR AVOID
901	19-Mar-21	HASSAN	66	SAKALE-IPCL2	SAKALE	13:48	19:47	05:59	LINE CLEAR AVOID
902	19-Mar-21	HASSAN	66	SHRLKP-HNPURA	ATTICHO	10:39	17:45	07:06	LINE CLEAR AVOID
903	19-Mar-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAG	17:01	18:11	01:10	LINE FAULT
904	19-Mar-21	HASSAN	66	TAVAREC-HONNALLI	TAVAREC	23:52(19.3.2021)			LOAD CURTAILMENT
905	19-Mar-21	HASSAN	66	TAVAREC-HONNALLI	TAVAREC	15:12	15:20	00:08	LINE FAULT
906	19-Mar-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAP	09:03	09:19	00:16	LINE FAULT
907	19-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAP	10:38	18:07	07:29	LINE CLEAR AVOID
908	19-Mar-21	HASSAN	110	ANAVATI-BARNGI	ANAVATI	13:43	13:55	00:12	LINE CLEAR AVOID
909	19-Mar-21	HASSAN	110	HV1	HALADY1	22:21	22:39	00:18	TRANSFORMER FAULT
910	19-Mar-21	HASSAN	110	HV1	BARANG	15:05	15:14	00:09	HAND TRIPPED
911	19-Mar-21	HASSAN	110	HV1	BARANG	16:03	18:47	02:44	LINE CLEAR AVOID
912	19-Mar-21	HASSAN	110	HV1	JAVAGA	11:55	14:06	02:11	LINE CLEAR AVOID
913	19-Mar-21	HASSAN	110	HV1	JAVAGA	22:17	22:28	00:11	LOAD CURTAILMENT
914	19-Mar-21	HASSAN	110	HV1	KARAYA	09:57	15:31	05:34	LINE CLEAR AVOID
915	19-Mar-21	HASSAN	110	HV1	KONDENA	22:18	22:22	00:04	LOAD CURTAILMENT
916	19-Mar-21	HASSAN	110	HV2	GANDAS	22:16	22:25	00:09	LOAD CURTAILMENT
917	19-Mar-21	HASSAN	110	KADUR-NERELEKERE	KADUR	06:51	07:22	00:31	LINE FAULT
918	19-Mar-21	HASSAN	110	KADUR-NERELEKERE	KADUR	10:39	10:46	00:07	LINE FAULT
919	19-Mar-21	HASSAN	110	KADUR-NGNHL	KADUR	06:27	07:26	00:59	LINE FAULT
920	19-Mar-21	HASSAN	110	KADUR-TNGL	KADUR	10:48	11:19	00:31	LINE FAULT
921	19-Mar-21	HASSAN	110	KADUR-YGTI	KADUR	10:39	10:46	00:07	LINE FAULT
922	19-Mar-21	HASSAN	110	LV1	KADUR	10:33	10:45	00:12	TRANSFORMER FAULT
923	19-Mar-21	HASSAN	110	LV2	KADUR	10:33	10:45	00:12	TRANSFORMER FAULT
924	19-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODAB	07:28	18:17	10:49	LINE CLEAR AVOID
925	19-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODAB	07:28	18:17	10:49	LINE CLEAR AVOID
926	19-Mar-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHRLKP	23:36(19.3.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
927	19-Mar-21	HASSAN	220	HV1	KADUR	10:33	10:44	00:11	TRANSFORMER FAULT
928	19-Mar-21	HASSAN	220	HV2	ARSK2	10:45(19.3.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
929	19-Mar-21	HASSAN	220	HV2	KADUR	10:33	10:45	00:12	TRANSFORMER FAULT
930	19-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGU	15:45(19.3.2021)			LINE OPEN:LINE FAULT
931	19-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGU	10:50	14:23	03:33	LINE CLEAR AVAILED
932	19-Mar-21	MYSURU	66	CR NAGARA-BADANKUPPE 2	BADANAGUPPE_66	10:02	12:41	2:39	LINE CLEAR AVAILED
933	19-Mar-21	MYSURU	66	CR NAGARA-PANYADAHUNDI	NO STATION EFFECTED	10:07	12:39	2:32	LINE CLEAR AVAILED
934	19-Mar-21	MYSURU	66	DR PETE-KUNTHUR	THAYURU_66 TNARASIPURA_66 JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66	11:42	12:30	0:48	LINE FAULT
935	19-Mar-21	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66 MYSORESOUTH_66	12:27	14:21	1:54	LINE FAULT
936	19-Mar-21	MYSURU	66	HOOTAGALLI-FTS1	FTS_66	12:34	12:40	0:05	LINE FAULT
937	19-Mar-21	MYSURU	66	HV1	BESAGARAHALLI_66	22:16	22:21	0:04	LOAD CURTAILMENT
938	19-Mar-21	MYSURU	66	HV1	BGNAGARA_66	5:19	5:24	0:04	LOAD CURTAILMENT
939	19-Mar-21	MYSURU	66	HV1	BGPURA_66	5:19	5:40	0:20	LOAD CURTAILMENT
940	19-Mar-21	MYSURU	66	HV1	BILIKERE_66	5:19	5:33	0:13	LOAD CURTAILMENT
941	19-Mar-21	MYSURU	66	HV1	DATTAGALLY_66	11:42	14:25	2:42	LINE CLEAR AVAILED
942	19-Mar-21	MYSURU	66	HV1	GAMANAHALLY_66	17:32	19:02	1:30	LINE CLEAR AVAILED
943	19-Mar-21	MYSURU	66	HV1	HANAGODU_66	22:16	22:20	0:03	LOAD CURTAILMENT
944	19-Mar-21	MYSURU	66	HV1	HANNUR_66	16:18	16:34	0:15	LINE CLEAR AVAILED
945	19-Mar-21	MYSURU	66	HV1	KRPET_66	22:17	22:20	0:02	LOAD CURTAILMENT
946	19-Mar-21	MYSURU	66	HV1	PANDAVAPURA_66	5:19	5:34	0:14	LOAD CURTAILMENT
947	19-Mar-21	MYSURU	66	HV1	PANDAVAPURA_66	22:17	22:20	0:02	LOAD CURTAILMENT
948	19-Mar-21	MYSURU	66	HV1	RAMAPURA_MYS_66	22:17	22:45	0:27	LOAD CURTAILMENT
949	19-Mar-21	MYSURU	66	HV1	YELANDUR_66	5:19	5:31	0:11	LOAD CURTAILMENT
950	19-Mar-21	MYSURU	66	HV1	YELANDUR_66	22:16	22:20	0:03	LOAD CURTAILMENT
951	19-Mar-21	MYSURU	66	HV2	ADDIHALLI_66	5:19	5:31	0:11	LOAD CURTAILMENT
952	19-Mar-21	MYSURU	66	HV2	AKKIHEBBAL_66	5:19	5:31	0:12	LOAD CURTAILMENT
953	19-Mar-21	MYSURU	66	HV2	AKKIHEBBAL_66	22:16	22:23	0:06	LOAD CURTAILMENT
954	19-Mar-21	MYSURU	66	HV2	BOOKANAKERE_66	5:19	5:29	0:10	LOAD CURTAILMENT
955	19-Mar-21	MYSURU	66	HV2	BOOKANAKERE_66	22:16	22:25	0:08	LOAD CURTAILMENT
956	19-Mar-21	MYSURU	66	HV2	CHINAKURALI_66	5:19	5:29	0:10	LOAD CURTAILMENT
957	19-Mar-21	MYSURU	66	HV2	CHINAKURALI_66	22:16	22:26	0:09	LOAD CURTAILMENT
958	19-Mar-21	MYSURU	66	HV2	GUNDULPET_66	22:16	22:25	0:08	LOAD CURTAILMENT
959	19-Mar-21	MYSURU	66	HV2	HANNUR_66	22:16	22:20	0:03	LOAD CURTAILMENT
960	19-Mar-21	MYSURU	66	HV2	KIRUGAVALU_66	22:17	22:32	0:14	LOAD CURTAILMENT
961	19-Mar-21	MYSURU	66	HV2	MALAVALLI_66	22:17	22:21	0:03	LOAD CURTAILMENT
962	19-Mar-21	MYSURU	66	HV5	SFCSHIVA_66	11:03	19:53	8:50	HAND TRIPPED
963	19-Mar-21	MYSURU	66	HV5	SFCSHIVA_66	12:06 (18/03/2021)	2:15 (19/03/2021)	14:08 HRS	TRANSFORMER CHARGED
964	19-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
965	19-Mar-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66	11:42	11:50	0:07	LINE FAULT
966	19-Mar-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	MALAVALLI_66	8:34	8:39	0:04	LINE FAULT
967	19-Mar-21	MYSURU	66	THANDYA-KADAKOLA	NO STATION EFFECTED	12:32 (18/03/2021)	9:38 (19/03/2021)	21:05 HRS	LINE CHARGED
968	19-Mar-21	MYSURU	66	THANDYA-NANJANGUDU	NO STATION EFFECTED	9:28	17:06	7:38	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
969	19-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	15:47	15:55	0:08	LINE FAULT
970	19-Mar-21	MYSURU	220	HOOTAGALLI-BASTIPURA 2	NO STATION EFFECTED	11:55	12:15	0:20	HAND TRIPPED
971	19-Mar-21	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATION EFFECTED	11:44	12:46	1:02	LINE CLEAR AVAILED
972	19-Mar-21	TUMKUR	66	ANCHEPALYA 220KV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	04:15	04:27	0:12	LOAD CURTAILMENT
973	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	1:02	2:05	1:03	HAND TRIPPED
974	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:30	14:33	4:03	LINE FAULT
975	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	1:01	1:26	0:24	HAND TRIPPED
976	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	2:11	2:43	0:32	HAND TRIPPED
977	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	18:30	18:44	0:14	LINE FAULT
978	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	2:05	2:44	0:39	HAND TRIPPED
979	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	2:05	2:44	0:39	HAND TRIPPED
980	19-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	6:07	6:29	0:21	LOAD CURTAILMENT
981	19-Mar-21	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	7:02	7:09	0:06	LINE FAULT
982	19-Mar-21	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	DYAVARANAHALLI_66	15:57	18:00	2:02	HAND TRIPPED
983	19-Mar-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	16:43	17:11	0:28	LINE CLEAR AVAILED
984	19-Mar-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:06	18:11	0:05	HAND TRIPPED
985	19-Mar-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	16:04	18:07	2:02	LINE CLEAR AVAILED
986	19-Mar-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	22:18	22:30	0:11	HAND TRIPPED
987	19-Mar-21	TUMKUR	66	SIRA- MADHUGIRI OLD(BADAVANAHALLI)	SIRA_66	11:32	11:40	0:08	LINE CLEAR AVAILED
988	19-Mar-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	0:24	0:30	0:05	TRANSFORMER FAULT
989	19-Mar-21	TUMKUR	66	TR-1	HANAGAL_66	7:00	11:20	4:20	LINE CLEAR AVAILED
990	19-Mar-21	TUMKUR	66	TR-1	LINGDHALLI_66	8:09	8:10	0:01	TRANSFORMER FAULT
991	19-Mar-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	6:17	8:32	2:15	LINE CLEAR AVAILED
992	19-Mar-21	TUMKUR	66	TR-1	SANTEMAVATTUR_66	22:16	22:20	0:04	HAND TRIPPED
993	19-Mar-21	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	1:02	2:41	1:39	LINE CLEAR AVAILED
994	19-Mar-21	TUMKUR	66	TR-2	CHELURU_66	15:16	15:33	0:17	TRANSFORMER FAULT
995	19-Mar-21	TUMKUR	66	TR-2	HANAGAL_66	11:20	12:12	0:52	LINE CLEAR AVAILED
996	19-Mar-21	TUMKUR	66	TR-2	HANAGAL_66	18:00	19:03	1:02	LINE CLEAR AVAILED
997	19-Mar-21	TUMKUR	66	TR-2	HANAGAL_66	22:17	22:25	0:08	LINE CLEAR AVAILED
998	19-Mar-21	TUMKUR	66	TR-2	HARAPPANAHALLI_66	14:56	15:17	0:21	TRANSFORMER FAULT
999	19-Mar-21	TUMKUR	66	TR-2	LINGDHALLI_66	16:32	16:43	0:10	TRANSFORMER FAULT
1000	19-Mar-21	TUMKUR	66	TR-2	SASALUHALLA_66	15:52	15:56	0:03	TRANSFORMER FAULT
1001	19-Mar-21	TUMKUR	66	TR-2	SASALUHALLA_66	16:10	16:12	0:02	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1002	19-Mar-21	TUMKUR	66	TR-2	URDIGERE 66	18:42	18:45	0:03	MAIN SUPPLY FAILURE
1003	19-Mar-21	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE 66	18:42	18:45	0:02	MAIN SUPPLY FAILURE
1004	19-Mar-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE 66	18:42	18:48	0:06	MAIN SUPPLY FAILURE
1005	19-Mar-21	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUN SEGhatta 110	12:18	12:26	0:08	HAND TRIPPED
1006	19-Mar-21	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR 110	6:21	7:16	0:55	LOAD CURTAILMENT
1007	19-Mar-21	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE 110, UNGRA 110	6:51	9:05	2:13	LOAD CURTAILMENT
1008	19-Mar-21	TUMKUR	110	TR-1	BIDARE 110	6:00	12:06	6:06	LINE CLEAR AVAILED
1009	19-Mar-21	TUMKUR	110	TR-2	SAMPIGE 110	11:39	12:17	0:37	LINE CLEAR AVAILED
1010	19-Mar-21	TUMKUR	110	TR-2	SAMPIGE 110	14:01	16:46	2:45	LINE CLEAR AVAILED
1011	19-Mar-21	TUMKUR	220	CHITRADURGA 220kv- THALLAK 220	CHITRADURGA 220	10:56	11:12	0:16	LINE FAULT
1012	19-Mar-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS 220	13:33	16:05	2:32	LINE FAULT
1013	19-Mar-21	TUMKUR	220	GUTUR 400-DAVANGERE SRS1	DAVANGERE_SRS 220	13:34	16:12	2:38	LINE FAULT
1014	20-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
1015	20-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
1016	20-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1017	20-Mar-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1018	20-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
1019	20-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1020	20-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1021	20-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1022	20-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1023	20-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	10:47 (09.2.2021)			LINE OPEN: LINE CLEAR AVAILED
1024	20-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI 220	10:47:00 (09.2.2021)			LINE OPEN: LINE CLEAR AVAILED
1025	20-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1026	20-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1027	20-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1028	20-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1029	20-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1030	20-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
1031	20-Mar-21	BAGALKOT	110	KUMTA-SIRS1	STATION NOT AFFECTED KUMTA 110	12:34 (13.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1032	20-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1033	20-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1034	20-Mar-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	15:05 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1035	20-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI_110	12:02 (16.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1036	20-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1037	20-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1038	20-Mar-21	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	23:21 (19.03.2021)	1:11 (20.03.2021)	1:50HRS	LINE CHARGED
1039	20-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1040	20-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1041	20-Mar-21	BAGALKOT	110	VAJRAMATTI-BILAGI	BILAGI_110	23:12 (19.03.2021)	00:25 (20.03.2021)	1:12HRS	LINE CHARGED
1042	20-Mar-21	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1043	20-Mar-21	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	14:20	15:01	0:41	LINE FAULT
1044	20-Mar-21	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 2	BAGEWADI_220	10:13	17:52	7:39	LINE CLEAR AVAILED
1045	20-Mar-21	BAGALKOT	110	110/11KV,HV2	TORVI_110	07:31	7:34	0:03	TRANSFORMER FAULT
1046	20-Mar-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	12:05	12:53	0:48	LINE CLEAR AVAILED
1047	20-Mar-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	12:05	12:53	0:48	LINE CLEAR AVAILED
1048	20-Mar-21	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	15:07	15:51	0:44	LINE CLEAR AVAILED
1049	20-Mar-21	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	13:38	16:07	2:29	LINE FAULT
1050	20-Mar-21	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	16:17	16:24	0:07	HAND TRIPPED
1051	20-Mar-21	BAGALKOT	110	110/11KV,HV1	KADANKOPPA_110	9:55	17:55	8:00	LINE CLEAR AVAILED
1052	20-Mar-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:04	13:36	1:32	LINE CLEAR AVAILED
1053	20-Mar-21	BAGALKOT	110	110/11KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	11:17	11:28	0:11	TRANSFORMER FAULT
1054	20-Mar-21	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	00:27	00:34	0:07	HAND TRIPPED
1055	20-Mar-21	BAGALKOT	110	110/11KV, HV2	TUMMINKATTI_110	14:10	16:30	2:20	LINE CLEAR AVAILED
1056	20-Mar-21	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	12:06	12:21	0:15	TRANSFORMER FAULT
1057	20-Mar-21	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMAWAD_33, IE_33	15:45	15:50	0:05	TRANSFORMER FAULT
1058	20-Mar-21	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	10:01	10:26	0:25	LINE CLEAR AVAILED
1059	20-Mar-21	BAGALKOT	110	HUBLI220- KADANKOPPA	KADANKOPPA_110	10:26	17:11	6:45	LINE CLEAR AVAILED
1060	20-Mar-21	BAGALKOT	110	HUBLI220- KALGHATAGI	STATION NOT AFFECTED KALGHATAGI_110	12:02	13:45	1:43	LINE CLEAR AVAILED
1061	20-Mar-21	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	17:12	17:22	0:10	TRANSFORMER FAULT
1062	20-Mar-21	BAGALKOT	110	110/33KV, HV3	MUNAVALLI_110, MUNAVALLI_33, MALLUR_33	14:56	15:18	0:22	TRANSFORMER FAULT
1063	20-Mar-21	BAGALKOT	220	220/110KV, HV1& LV1	KUDACHI_220, SHIRGUPPI_110	4:46	5:09	0:23	TRANSFORMER FAULT
1064	20-Mar-21	BAGALKOT	220	KUDACHI- CHIKKODI1 (GHATAPRABHA)	KUDACHI_220	15:09	15:51	0:42	LINE CLEAR AVAILED
1065	20-Mar-21	BENGALURU	66	HV2	BRIGADE METROPOLIS	10:04	10:10	00:06	LINE CLEAR AVAILED
1066	20-Mar-21	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-2, BIOCON(EHT)	10:50	11:20	00:30	MAIN SUPPLY FAILURE
1067	20-Mar-21	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - ELECTRONIC CITY PH-2 SEC-1	ELECTRONIC CITY PH-2 SEC-2, BIOCON(EHT)	17:29	17:45	00:16	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1068	20-Mar-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	12:37	12:47	00:10	LINE FAULT
1069	20-Mar-21	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	11:58	12:20	00:22	MAIN SUPPLY FAILURE
1070	20-Mar-21	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	12:45	12:55	00:10	LOAD CHANGEOVER
1071	20-Mar-21	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY PH-2 SEC-2	ELECTRONIC CITY PH-2 SEC-2, BIOCON(EHT)	18:46	18:54	00:08	LINE CLEAR AVAILED
1072	20-Mar-21	BENGALURU	220	HV2	T K HALLI 220	12:01	12:10	00:09	TRANSFORMER FAULT
1073	20-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:01	12:14	00:13	LINE CLEAR AVAILED
1074	20-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:01	12:14	00:13	LINE CLEAR AVAILED
1075	20-Mar-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	12:01	12:14	00:13	LINE CLEAR AVAILED
1076	20-Mar-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	12:01	12:14	00:13	LINE CLEAR AVAILED
1077	20-Mar-21	BENGALURU	66	HV2	VIJAYANAGARA	22:03	22:11	00:08	LOAD CHANGEOVER
1078	20-Mar-21	BENGALURU	66	HV2	YARANDANAHALLI 220	14:35	15:05	00:30	LINE CLEAR AVAILED
1079	20-Mar-21	BENGALURU	66	HV2	MAASTHI	12:29	12:32	00:03	TRANSFORMER FAULT
1080	20-Mar-21	BENGALURU	66	HV2	YEDUMADU	10:05	10:15	00:09	LINE CLEAR AVAILED
1081	20-Mar-21	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	06:14	08:16	02:01	LINE FAULT
1082	20-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	07:20	08:11	00:50	LOAD CURTAILMENT
1083	20-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:34	12:51	00:17	LINE FAULT
1084	20-Mar-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	07:02	07:45	00:42	LOAD CURTAILMENT
1085	20-Mar-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	12:34	12:52	00:18	LINE FAULT
1086	20-Mar-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	03:42	03:48	00:06	LOAD CURTAILMENT
1087	20-Mar-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	03:44	04:05	00:21	LOAD CURTAILMENT
1088	20-Mar-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	03:55	04:07	00:12	LOAD CURTAILMENT
1089	20-Mar-21	BENGALURU	66	KYALANUR - TALAGWARA	NO STATION AFFECTED	20:05	23:16	03:11	LINE FAULT
1090	20-Mar-21	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	20:05	23:15	03:10	LINE FAULT
1091	20-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	03:42	04:46	01:03	LOAD CURTAILMENT
1092	20-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:11	09:23	00:12	LINE FAULT
1093	20-Mar-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	03:44	04:38	00:54	LOAD CURTAILMENT
1094	20-Mar-21	BENGALURU	66	MANCHENAHALLI - GOWRIBIDANUR 220	MANCHENAHALLI	13:34	15:03	01:29	LINE CLEAR AVAILED
1095	20-Mar-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)	2:42(20/03/2021)	327:50HRS	LINE FAULT
1096	20-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
1097	20-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
1098	20-Mar-21	GULBARGA	400	RTPS-MEHBOOB NAGAR	MEHBOOB NAGAR_400	10:52	15:47	04:55	NFBC ISSUED
1099	20-Mar-21	GULBARGA	220	HV2	HALBARGA_220	15:10	16:10	01:00	LINE CLEAR AVAILED
1100	20-Mar-21	GULBARGA	110	HV2	CHINCHOLI_110	13:50(16.03.2021)	18:50(21.03.2021)	96:00 HRS	TRANSFORMER CHARGED
1101	20-Mar-21	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	19:30(19.3.2021)	2:05(20.03.2021)	6:35 HRS	LINE CHARGED
1102	20-Mar-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	21:12(19.03.2021)	7:56(20.03.2021)	10:44 HRS	LINE FAULT
1103	20-Mar-21	GULBARGA	110	HV2	KEREHALLI_110	12:03	15:40	03:37	LINE CLEAR AVAILED
1104	20-Mar-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	02:30	08:22	05:52	LINE FAULT
1105	20-Mar-21	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	06:06	07:20	01:14	LINE FAULT
1106	20-Mar-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	08:40	08:50	00:10	LINE FAULT
1107	20-Mar-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	18:58	21:40	02:42	LINE CLEAR AVAILED
1108	20-Mar-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	09:21	17:18	07:57	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1109	20-Mar-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	18:06	18:12	00:06	LINE CLEAR AVAILED
1110	20-Mar-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	13:20	13:25	00:05	LINE CLEAR AVAILED
1111	20-Mar-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	01:37	01:45	00:08	LINE FAULT
1112	20-Mar-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	06:18	06:25	00:07	LINE FAULT
1113	20-Mar-21	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	20:35(20.03.2021)	09:35(21.03.2021)	14:00HRS	LINE FAULT
1114	20-Mar-21	GULBARGA	110	SINDHANOOR110-RAICHUR2	VALKAMDINNI_110	18:45	18:55	00:10	LINE FAULT
1115	20-Mar-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	22:30	22:50	00:20	LINE FAULT
1116	20-Mar-21	GULBARGA	66	ITTAGGI-TAMBRAHALLI	TAMBRAHALLI_66	09:10	09:30	00:20	LINE FAULT
1117	20-Mar-21	GULBARGA	66	HV2	TAMBRAHALLI_66	14:05	14:10	00:05	TRANSFORMER FAULT
1118	20-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1119	20-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1120	20-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:21(20.3.2021)			LINE OPEN: LINE CLEAR AVAILED
1121	20-Mar-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	20:23(20.3.2021)			LINE OPEN:LINE FAULT
1122	20-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:45(19.3.2021)	13:19(20.3.2021)	21:33 hrs	LINE CHARGED
1123	20-Mar-21	HASSAN	220	HV2	ARASIKERE_220	10:45(19.3.2021)	16:38(20.03.2021)	29:52 hrs	TRANSFORMER CHARGED
1124	20-Mar-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHRLKP	23:36(19.3.2021)	0:03 (20.03.2021)	0:26 hrs	LOAD CURTAILMENT
1125	20-Mar-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	23:52(19.3.2021)	0:26(20.3.2021)	0:33 hrs	LINE CHARGED
1126	20-Mar-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	15:23	16:11	00:48	LINE FAULT
1127	20-Mar-21	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	13:10	13:19	00:09	LINE FAULT
1128	20-Mar-21	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	14:10	14:14	00:04	LINE FAULT
1129	20-Mar-21	HASSAN	220	HV1	KADUR_220	10:52	11:01	00:09	TRANSFORMER FAULT
1130	20-Mar-21	HASSAN	220	HV2	KADUR_220	10:52	11:02	00:10	TRANSFORMER FAULT
1131	20-Mar-21	HASSAN	110	LV1	KADUR_220	10:52	11:02	00:10	TRANSFORMER FAULT
1132	20-Mar-21	HASSAN	110	LV2	KADUR_220	10:52	11:02	00:10	TRANSFORMER FAULT
1133	20-Mar-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:59	11:09	00:10	HAND TRIPPED
1134	20-Mar-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	14:14	14:28	00:14	LINE FAULT
1135	20-Mar-21	HASSAN	110	KADUR-KADURNGNHL	KADUR_220	11:01	11:11	00:10	HAND TRIPPED
1136	20-Mar-21	HASSAN	110	KADUR-KADURNGNHL	KADUR_220	14:14	14:28	00:14	LINE FAULT
1137	20-Mar-21	HASSAN	110	KADUR-KADURTNGL	KADUR_220	14:14	14:28	00:14	LINE FAULT
1138	20-Mar-21	HASSAN	110	KADUR-KADURYGTI	KADUR_220	11:01	11:09	00:08	HAND TRIPPED
1139	20-Mar-21	HASSAN	110	KADUR-KADURYGTI	KADUR_220	12:28	12:43	00:15	HAND TRIPPED
1140	20-Mar-21	HASSAN	110	KADUR-YGTI	KADUR_220	14:14	14:28	00:14	LINE FAULT
1141	20-Mar-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:37	12:25	01:48	LINE FAULT
1142	20-Mar-21	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	14:01	14:36	00:35	LINE CLEAR AVAILED
1143	20-Mar-21	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	12:09	13:52	01:43	LINE CLEAR AVAILED
1144	20-Mar-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:43	10:48	00:05	HAND TRIPPED
1145	20-Mar-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:45	16:39	00:54	MAIN SUPPLY FAILURE
1146	20-Mar-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:20	16:30	01:10	MAIN SUPPLY FAILURE
1147	20-Mar-21	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	11:31	16:37	05:06	LINE CLEAR AVAILED
1148	20-Mar-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:45	16:39	00:54	LINE FAULT
1149	20-Mar-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:20	16:18	00:58	LINE FAULT
1150	20-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	07:31	19:44	12:13	LINE CLEAR AVAILED
1151	20-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	07:31	19:44	12:13	LINE CLEAR AVAILED
1152	20-Mar-21	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	06:08	06:16	00:08	MAIN SUPPLY FAILURE
1153	20-Mar-21	HASSAN	66	HV1	BANDISHETTYHALLI_66	06:09	06:17	00:08	MAIN SUPPLY FAILURE
1154	20-Mar-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	06:08	06:17	00:09	MAIN SUPPLY FAILURE
1155	20-Mar-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	06:06	06:12	00:06	LINE FAULT
1156	20-Mar-21	HASSAN	66	HV2	UDAYAPURA_66	10:45	10:51	00:06	TRANSFORMER FAULT
1157	20-Mar-21	HASSAN	66	HV2	UDAYAPURA_66	12:01	12:04	00:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1158	20-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:42	18:45	08:03	LINE CLEAR AVAILED
1159	20-Mar-21	MYSURU	220	KADAKOLA-BEGUR 1	NO STATION EFFECTED	11:56	12:12	0:16	HAND TRIPPED
1160	20-Mar-21	MYSURU	220	HV2	BEGUR_220	12:00	12:16	0:16	TRANSFORMER FAULT
1161	20-Mar-21	MYSURU	220	HV2	KUSHALNAGARA_220	18:34	19:47	1:13	TRANSFORMER FAULT
1162	20-Mar-21	MYSURU	220	KUSHALNAGARA 220-HV2	KUSHALNAGARA_220	23:54 (20/03/2021)			LINE OPEN:LINE FAULT
1163	20-Mar-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-2	PERIYAPATNA_66 BYLUKUPPE_66	11:30	14:21	2:51	LINE CLEAR AVAILED
1164	20-Mar-21	MYSURU	66	BYLUKUPPE-KUSHALNAGARA 220	BYLUKUPPE_66	10:06	14:05	3:58	LINE CLEAR AVAILED
1165	20-Mar-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-2	BYLUKUPPE_66	19:45	19:51	0:06	HAND TRIPPED
1166	20-Mar-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66	10:11	11:00	0:48	LINE CLEAR AVAILED
1167	20-Mar-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	19:42	19:51	0:09	HAND TRIPPED
1168	20-Mar-21	MYSURU	66	HV1	PERIYAPATNA_66	10:00	18:00	8:00	LINE CLEAR AVAILED
1169	20-Mar-21	MYSURU	66	HV2	PERIYAPATNA_66	10:00	18:00	8:00	LINE CLEAR AVAILED
1170	20-Mar-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATION EFFECTED	7:20	7:26	0:05	LINE FAULT
1171	20-Mar-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:48	12:53	0:05	LINE FAULT
1172	20-Mar-21	MYSURU	66	HV1	PONNAMPET_66	13:02	14:16	1:14	LINE CLEAR AVAILED
1173	20-Mar-21	MYSURU	66	VAJMANGALA-DEVNOOR(MYS)	DEVANOORMYS_66	11:51	16:55	5:04	NFBC ISSUED
1174	20-Mar-21	MYSURU	66	HV1	JAKKANAHALLY_66	16:50	17:15	0:25	TRANSFORMER FAULT
1175	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	0:15	0:25	0:10	LINE FAULT
1176	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	1:46	1:53	0:07	LINE FAULT
1177	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	2:10	2:20	0:10	LINE FAULT
1178	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:26	10:31	0:05	LINE FAULT
1179	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:17	11:25	0:08	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1180	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	12:01	12:05	0:04	LOAD CURTAILMENT
1181	20-Mar-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	17:05	17:10	0:05	LINE FAULT
1182	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:23	17:28	0:05	LINE FAULT
1183	20-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:46	17:51	0:05	LINE FAULT
1184	20-Mar-21	MYSURU	66	HV1	MADDUR_66	12:04	12:13	0:08	MAIN SUPPLY FAILURE
1185	20-Mar-21	MYSURU	66	HV2	MADDUR_66	12:04	12:13	0:08	MAIN SUPPLY FAILURE
1186	20-Mar-21	MYSURU	66	CR NAGARA-YALANDUR	NO STATION EFFECTED	14:42	15:39	0:57	LINE CLEAR AVAILED
1187	20-Mar-21	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATION EFFECTED	13:03	16:45	3:41	NFBC ISSUED
1188	20-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
1189	20-Mar-21	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	10:43:48 PM(20.03.2021)	7:01:22 AM(21.03.2021)	9:42HRS	LINE CHARGED
1190	20-Mar-21	TUMKUR	220	CHITRADURGA 220kv- THALLAK 220	CHITRADURGA_220	12:27	13:00	0:33	LINE FAULT
1191	20-Mar-21	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	10:10	16:40	6:30	HAND TRIPPED
1192	20-Mar-21	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	10:09	16:29	6:20	HAND TRIPPED
1193	20-Mar-21	TUMKUR	110	TR-2	NITTUR_220	11:20	11:30	0:10	TRANSFORMER FAULT
1194	20-Mar-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	4:13	4:21	0:08	HAND TRIPPED
1195	20-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	4:29	4:43	0:13	HAND TRIPPED
1196	20-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	4:13	4:29	0:15	HAND TRIPPED
1197	20-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	4:13	4:33	0:20	HAND TRIPPED
1198	20-Mar-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	4:13	4:35	0:22	HAND TRIPPED
1199	20-Mar-21	TUMKUR	66	TR-2	BALENAHALLI_66	10:34	10:41	0:07	TRANSFORMER FAULT
1200	20-Mar-21	TUMKUR	66	TR-1	CHALLAKERE_66	8:55	9:25	0:30	TRANSFORMER FAULT
1201	20-Mar-21	TUMKUR	66	TR-1	CHALLAKERE_66	13:05	14:16	1:11	LINE CLEAR AVAILED
1202	20-Mar-21	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	7:04	7:49	0:44	LOAD CURTAILMENT
1203	20-Mar-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	7:18	8:21	1:02	LOAD CURTAILMENT
1204	20-Mar-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	7:04	7:49	0:45	LOAD CURTAILMENT
1205	20-Mar-21	TUMKUR	66	TR-1	DEVARAHALLI_66	11:31	11:36	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1206	20-Mar-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:15	13:28	0:13	LINE FAULT
1207	20-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:17	14:56	0:39	LINE FAULT
1208	20-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:01	22:11	0:09	LINE FAULT
1209	20-Mar-21	TUMKUR	66	TR-2	GUTTUR_66	11:43	12:20	0:37	LINE CLEAR AVAILED
1210	20-Mar-21	TUMKUR	66	TR-2	HANAGAL_66	8:08	9:30	1:21	LINE CLEAR AVAILED
1211	20-Mar-21	TUMKUR	66	TR-1	HANAGAL_66	9:14	10:02	0:47	LINE CLEAR AVAILED
1212	20-Mar-21	TUMKUR	66	TR-1	HDPURA_66	10:07	10:16	0:08	TRANSFORMER FAULT
1213	20-Mar-21	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	10:14	13:48	3:33	LINE CLEAR AVAILED
1214	20-Mar-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	12:27	12:32	0:05	LINE FAULT
1215	20-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:32	12:34	0:02	HAND TRIPPED
1216	20-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	16:56	17:08	0:12	HAND TRIPPED
1217	20-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:40	19:54	0:14	HAND TRIPPED
1218	20-Mar-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:36	18:47	0:11	LINE FAULT
1219	20-Mar-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	16:46	17:13	0:26	LOAD CURTAILMENT
1220	21-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
1221	21-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
1222	21-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1223	21-Mar-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1224	21-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
1225	21-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1226	21-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1227	21-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1228	21-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1229	21-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (09.2.2021)			LINE OPEN: LINE CLEAR AVAILED
1230	21-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (09.2.2021)			LINE OPEN: LINE CLEAR AVAILED
1231	21-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1232	21-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1233	21-Mar-21	BAGALKOT	220	VAJRAMATTI-MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1234	21-Mar-21	BAGALKOT	220	VAJRAMATTI-MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1235	21-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1236	21-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1237	21-Mar-21	BAGALKOT	110	KUMTA-SIRS1	STATION NOT AFFECTED KUMTA_110	12:34 (13.03.2021)	19:25 (21.03.2021)	198:51HRS	LINE CHARGED
1238	21-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
1239	21-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
1240	21-Mar-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	15:05 (14.03.2021)	10:43 (21.03.2021)	163:38HRS	LINE CHARGED
1241	21-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI_110	12:02 (16.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
1242	21-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1243	21-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
1244	21-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
1245	21-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
1246	21-Mar-21	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
1247	21-Mar-21	BAGALKOT	110	ANKALAGI-BELGAUM2	ANKALAGI_110	18:08	20:37	2:29	LINE CLEAR AVOIDED
1248	21-Mar-21	BAGALKOT	110	ANKOLA-ARGA(L1)	STATION NOT AFFECTED ANKOLA_110	18:58 21.03.2021)			LINE OPEN:LINE FAULT
1249	21-Mar-21	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	09:44	19:23	9:39	LINE CLEAR AVOIDED
1250	21-Mar-21	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	05:58	06:11	0:13	LINE FAULT
1251	21-Mar-21	BAGALKOT	110	BAGEWADI-MAMADAPUR 2	MAMADAPUR_110	05:58	06:11	0:13	LINE FAULT
1252	21-Mar-21	BAGALKOT	110	TORVI-TIKOTA	TIKOTA_110	05:46	9:40	3:54	LINE CLEAR AVOIDED
1253	21-Mar-21	BAGALKOT	110	110/11KV,HV1&2	BELGAUM_110	12:41	15:46	3:05	LINE CLEAR AVOIDED
1254	21-Mar-21	BAGALKOT	110	110/11KV,HV2	CHIKKODI_110	18:31	18:37	0:06	TRANSFORMER FAULT
1255	21-Mar-21	BAGALKOT	220	220/110KV,HV2	CHIKKODI_220	17:22	18:22	1:00	TRANSFORMER FAULT
1256	21-Mar-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	17:22 (21.03.2021)			LINE OPEN:LINE FAULT
1257	21-Mar-21	BAGALKOT	220	220/110KV,HV1	CHIKKODI_220	17:22	18:11	0:49	TRANSFORMER FAULT
1258	21-Mar-21	BAGALKOT	220	CHIKKODI-MUDASHINGI	STATION NOT AFFECTED CHIKKODI_220	17:22 (21.03.2021)			LINE OPEN:LINE FAULT
1259	21-Mar-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	17:22	18:10	0:48	LINE FAULT
1260	21-Mar-21	BAGALKOT	220	CHIKKODI-KUDACHI_220	CHIKKODI_220	17:22	18:13	0:51	LINE FAULT
1261	21-Mar-21	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	17:17	19:15	1:58	LINE FAULT
1262	21-Mar-21	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	17:43	18:46	1:03	HAND TRIPPED
1263	21-Mar-21	BAGALKOT	110	220/110KV,LV 2	CHIKKODI_220	17:51	19:28	1:37	HAND TRIPPED
1264	21-Mar-21	BAGALKOT	110	CHIKKODI220-CHIKKODI110	CHIKKODI_110	17:51	18:24	0:33	HAND TRIPPED
1265	21-Mar-21	BAGALKOT	110	220/110KV,LV 1	CHIKKODI_220	17:51	18:11	0:20	HAND TRIPPED
1266	21-Mar-21	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	17:51	18:29	0:38	HAND TRIPPED
1267	21-Mar-21	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	17:51	18:43	0:52	HAND TRIPPED
1268	21-Mar-21	BAGALKOT	110	DAMBAL-SUZLON(2)	DAMBAL_110	6:27	16:32	10:05	LINE FAULT
1269	21-Mar-21	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	9:58	10:20	0:22	HAND TRIPPED
1270	21-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:19 (21.03.2021)			LINE OPEN:LINE FAULT
1271	21-Mar-21	BAGALKOT	110	BELGAUM -NEHRU NAGAR	NEHRU NAGAR_110	10:44	15:41	4:57	LINE CLEAR AVOIDED
1272	21-Mar-21	BAGALKOT	110	220/110KV,LV1&2	BELGAUM_220	17:50	18:36	0:46	HAND TRIPPED
1273	21-Mar-21	BAGALKOT	110	HUDLI-ANKLI	ANKLI_110	17:28	20:35	3:07	LINE FAULT
1274	21-Mar-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	16:53	17:00	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1275	21-Mar-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	19:11	19:21	0:10	TRANSFORMER FAULT
1276	21-Mar-21	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YAWAD_33, VANTAGOD_33	09:29	09:44	0:15	TRANSFORMER FAULT
1277	21-Mar-21	BAGALKOT	110	110/11KV, HV2	UDYAMBAG_110	09:29	15:27	5:58	LINE CLEAR AVAILED
1278	21-Mar-21	BAGALKOT	110	110/11KV, HV1	UDYAMBAG_110	15:33	18:48	3:15	LINE CLEAR AVAILED
1279	21-Mar-21	BAGALKOT	110	110/11KV, HV1	SUVARNASOUDA_110	09:18	15:25	6:07	LINE CLEAR AVAILED
1280	21-Mar-21	BAGALKOT	110	110/11KV, HV1	SUVARNASOUDA_110	09:18	15:26	6:08	LINE CLEAR AVAILED
1281	21-Mar-21	BAGALKOT	110	SUVARNASOUDA- MACHE	MACHE_110	09:22	09:30	0:08	HAND TRIPPED
1282	21-Mar-21	BAGALKOT	110	SUVARNASOUDA- MACHE	MACHE_110	13:45	14:00	0:15	HAND TRIPPED
1283	21-Mar-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	7:12	13:08	5:56	LINE CLEAR AVAILED
1284	21-Mar-21	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	17:26	18:45	1:19	HAND TRIPPED
1285	21-Mar-21	BAGALKOT	220	NARENDRA- HUBLI1&2	NARENDRA_220	06:35	08:02	1:27	LINE FAULT
1286	21-Mar-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	16:29	18:29	2:00	HAND TRIPPED
1287	21-Mar-21	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	16:31	18:29	1:58	HAND TRIPPED
1288	21-Mar-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	6:35	8:32	1:57	LINE FAULT
1289	21-Mar-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	9:44	19:24	9:40	LINE CLEAR AVAILED
1290	21-Mar-21	BAGALKOT	220	NARENDRA- HAVERI1	NARENDRA_220	6:35	8:06	1:31	LINE FAULT
1291	21-Mar-21	BAGALKOT	220	NARENDRA- HAVERI1	NARENDRA_220	14:45	18:31	3:46	HAND TRIPPED
1292	21-Mar-21	BAGALKOT	220	220/110KV, HV1, HV2, LV1, LV2	NARENDRA_220	14:11	18:39	4:28	HAND TRIPPED
1293	21-Mar-21	BAGALKOT	220	NARENDRA- BELGAUM1 (KANABARGI1)	NARENDRA_220	06:35	08:07	1:32	LINE FAULT
1294	21-Mar-21	BAGALKOT	220	NARENDRA- BELGAUM1 (KANABARGI1)	NARENDRA_220	14:27	18:28	4:01	HAND TRIPPED
1295	21-Mar-21	BAGALKOT	110	NARENDRA- BELUR1&2	BELUR_110	6:35	8:02	1:27	LINE FAULT
1296	21-Mar-21	BAGALKOT	110	NARENDRA- KUD1	KUD DHARWAD_110	6:35	8:03	1:28	LINE FAULT
1297	21-Mar-21	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	16:35	16:53	0:18	TRANSFORMER FAULT
1298	21-Mar-21	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	9:35	10:04	0:29	TRANSFORMER FAULT
1299	21-Mar-21	BAGALKOT	110	NARENDRA- MRUTHYUNJAY NAGAR1	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	13:00	18:49	5:49	LINE CLEAR AVAILED
1300	21-Mar-21	BAGALKOT	110	MAMADAPUR(B)- SHIRBUR	SHIRBUR_110	6:14	6:16	0:02	HAND TRIPPED
1301	21-Mar-21	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	3:49	4:03	0:14	LINE FAULT
1302	21-Mar-21	BAGALKOT	110	110/11KV, HV4	KERUR_110	14:21	14:31	0:10	TRANSFORMER FAULT
1303	21-Mar-21	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	17:23	18:31	1:08	TRANSFORMER FAULT
1304	21-Mar-21	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	17:23	18:37	1:14	TRANSFORMER FAULT
1305	21-Mar-21	BAGALKOT	110	RAIBAG- CHIKKODI1	RAIBAG_110	17:20	18:33	1:13	LINE FAULT
1306	21-Mar-21	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	09:35	09:45	00:10	LINE FAULT
1307	21-Mar-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR, YEDUMADU	17:10	17:15	00:05	MAIN SUPPLY FAILURE
1308	21-Mar-21	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR, YEDUMADU	19:05	19:15	00:10	LOAD CHANGEOVER
1309	21-Mar-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR, YEDUMADU	22:30	23:15	00:45	MAIN SUPPLY FAILURE
1310	21-Mar-21	BENGALURU	66	HOODY 220 - HOSKOTE 66	NO STATION AFFECTED	10:56	12:57	02:01	LINE FAULT
1311	21-Mar-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	14:02	15:06	01:04	LINE FAULT
1312	21-Mar-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	15:55	16:37	00:42	LINE FAULT
1313	21-Mar-21	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	KOTIPURA 220	12:15	12:39	00:24	MAIN SUPPLY FAILURE
1314	21-Mar-21	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	12:15	12:54	00:39	LOAD CHANGEOVER
1315	21-Mar-21	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	18:01	18:07	00:06	LOAD CHANGEOVER
1316	21-Mar-21	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	11:57	12:05	00:08	LINE CLEAR AVAILED
1317	21-Mar-21	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	16:56	17:08	00:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1318	21-Mar-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	17:52	18:05	00:13	LINE CLEAR AVAILED
1319	21-Mar-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	22:27	22:30	00:03	LOAD CHANGEOVER
1320	21-Mar-21	BENGALURU	220	HV2	SOMANAHALLI 220	17:52	18:05	00:13	TRANSFORMER FAULT
1321	21-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:26	15:35	00:09	LINE FAULT
1322	21-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:26	15:38	00:12	LINE FAULT
1323	21-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:40	18:50	00:10	LINE FAULT
1324	21-Mar-21	BENGALURU	66	HV2	VIJAYANAGARA	22:31	22:47	00:16	LOAD CHANGEOVER
1325	21-Mar-21	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	14:03	14:50	00:47	MAIN SUPPLY FAILURE
1326	21-Mar-21	BENGALURU	220	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	16:20	16:30	00:10	LOAD CHANGEOVER
1327	21-Mar-21	BENGALURU	220	HV2	YARANDANAHALLI 220	06:17	06:32	00:15	TRANSFORMER FAULT
1328	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	06:17	08:21	02:04	LINE FAULT
1329	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	06:17	06:57	00:40	LINE FAULT
1330	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	06:17	06:33	00:16	LINE FAULT
1331	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	07:56	08:51	00:55	LOAD CHANGEOVER
1332	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	07:56	08:24	00:28	LOAD CHANGEOVER
1333	21-Mar-21	BENGALURU	66	HV1	YARANDANAHALLI 220	08:02	08:22	00:20	LOAD CHANGEOVER
1334	21-Mar-21	BENGALURU	66	HV3	YARANDANAHALLI 220	08:02	08:22	00:20	LOAD CHANGEOVER
1335	21-Mar-21	BENGALURU	220	HV1	YARANDANAHALLI 220	08:03	08:18	00:15	LOAD CHANGEOVER
1336	21-Mar-21	BENGALURU	220	HV3	YARANDANAHALLI 220	08:03	08:18	00:15	LOAD CHANGEOVER
1337	21-Mar-21	BENGALURU	220	HV2	YARANDANAHALLI 220	08:03	08:18	00:15	LOAD CHANGEOVER
1338	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:27	18:12	02:45	LINE CLEAR AVAILED
1339	21-Mar-21	BENGALURU	66	HV1	YARANDANAHALLI 220	18:31	18:55	00:24	TRANSFORMER FAULT
1340	21-Mar-21	BENGALURU	220	HV2	YARANDANAHALLI 220	18:31	18:52	00:21	TRANSFORMER FAULT
1341	21-Mar-21	BENGALURU	220	HV3	YARANDANAHALLI 220	18:31	18:52	00:21	TRANSFORMER FAULT
1342	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	18:31	19:00	00:29	LINE CLEAR AVAILED
1343	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	20:48	21:03	00:15	LOAD CHANGEOVER
1344	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	20:48	21:03	00:15	LOAD CHANGEOVER
1345	21-Mar-21	BENGALURU	66	HV3	YARANDANAHALLI 220	20:48	21:03	00:15	LOAD CHANGEOVER
1346	21-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	20:56	21:03	00:07	LOAD CHANGEOVER
1347	21-Mar-21	BENGALURU	220	HV3	YARANDANAHALLI 220	20:48	21:03	00:15	LOAD CHANGEOVER
1348	21-Mar-21	BENGALURU	220	HV2	YARANDANAHALLI 220	20:48	21:03	00:15	LOAD CHANGEOVER
1349	21-Mar-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	07:42	07:52	00:10	LOAD CHANGEOVER
1350	21-Mar-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	21:00	21:06	00:06	LOAD CHANGEOVER
1351	21-Mar-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:20	17:25	00:05	LOAD CHANGEOVER
1352	21-Mar-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	07:30	07:40	00:10	LOAD CHANGEOVER
1353	21-Mar-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	20:15	20:35	00:20	LOAD CHANGEOVER
1354	21-Mar-21	BENGALURU	66	HV1	MUDIYANUR	14:28	16:14	01:46	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1355	21-Mar-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	07:17	07:30	00:12	LINE FAULT
1356	21-Mar-21	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HALAGUR	16:01	16:15	00:14	LINE FAULT
1357	21-Mar-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	00:15	00:19	00:04	LINE FAULT
1358	21-Mar-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	00:15	00:32	00:17	LINE FAULT
1359	21-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	00:11	00:20	00:09	LINE FAULT
1360	21-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	00:21	00:32	00:11	LINE FAULT
1361	21-Mar-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:41	15:49	00:07	LINE FAULT
1362	21-Mar-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	00:09	00:18	00:08	LINE FAULT
1363	21-Mar-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	02:07	02:16	00:09	LINE FAULT
1364	21-Mar-21	BENGALURU	66	SURYANAGAR - YERANDANAHALLI	SURYANAGAR	06:17	07:01	00:43	LINE FAULT
1365	21-Mar-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:03	15:02	00:58	MAIN SUPPLY FAILURE
1366	21-Mar-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:03	15:02	00:58	MAIN SUPPLY FAILURE
1367	21-Mar-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:03	15:02	00:58	MAIN SUPPLY FAILURE
1368	21-Mar-21	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	14:03	15:02	00:58	MAIN SUPPLY FAILURE
1369	21-Mar-21	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	19:14	19:15	00:01	LINE CLEAR AVOIDED
1370	21-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
1371	21-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
1372	21-Mar-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR 110	09:55	10:10	00:15	LINE FAULT
1373	21-Mar-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR IPP	KUSHTAGI 220	18:15	21:45	03:30	LINE CLEAR AVOIDED
1374	21-Mar-21	GULBARGA	110	SINDHANOOR-PGLR WIND	PGLR WIND IPP	21:30	21:40	00:10	LINE FAULT
1375	21-Mar-21	GULBARGA	110	HALBARGA-SANTTHAPUR	SANTHAPUR 110	11:48	11:55	01:10	LINE FAULT
1376	21-Mar-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA 110	13:02	13:16	00:14	LINE FAULT
1377	21-Mar-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI 110	12:18	19:25	07:07	LINE CLEAR AVOIDED
1378	21-Mar-21	GULBARGA	110	MUNIRABAD-STARMETTALLIC	STARMETTALLIC 110	21:10(20.03.2021)	22:20(21.03.2021)	25:10HRS	LINE CHARGED
1379	21-Mar-21	GULBARGA	66	HV2	HANASI 66	05:15	05:22	00:07	TRANSFORMER FAULT
1380	21-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA 400	13:21(20.3.2021)	15:02(21.3.2021)	25:40 hrs	LINE CHARGED
1381	21-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
1382	21-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
1383	21-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA 400	15:16(21.3.2021)			LINE OPEN:LINE FAULT
1384	21-Mar-21	HASSAN	220	CRPATNA-HUYGNH	CRPATNA 220	12:31	12:49	00:18	LINE FAULT
1385	21-Mar-21	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA 220	07:34	07:59	00:25	LINE FAULT
1386	21-Mar-21	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA 220	12:19	13:09	00:50	HAND TRIPPED
1387	21-Mar-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA 220	12:19	13:07	00:48	HAND TRIPPED
1388	21-Mar-21	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG 220	13:19	13:35	00:16	LINE FAULT
1389	21-Mar-21	HASSAN	110	HV1	BARANGI 110	08:27	09:02	00:35	LINE CLEAR AVOIDED
1390	21-Mar-21	HASSAN	110	HV2	BARANGI 110	08:56	09:39	00:43	LINE CLEAR AVOIDED
1391	21-Mar-21	HASSAN	110	HV1	ESSUR 110	17:54	18:14	00:20	LINE CLEAR AVOIDED
1392	21-Mar-21	HASSAN	110	HV1	HIRIYADKA 110	18:14	18:24	00:10	TRANSFORMER FAULT
1393	21-Mar-21	HASSAN	110	HV3	HIRIYADKA 110	08:16	08:25	00:09	TRANSFORMER FAULT
1394	21-Mar-21	HASSAN	110	HV3	HIRIYADKA 110	18:14	18:24	00:10	TRANSFORMER FAULT
1395	21-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE 110	07:28	12:36	05:08	LINE CLEAR AVOIDED
1396	21-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE 110	07:27	12:36	05:09	LINE CLEAR AVOIDED
1397	21-Mar-21	HASSAN	66	HV1	CHIKMAGALUR 66	06:21	12:37	06:16	TRANSFORMER FAULT
1398	21-Mar-21	HASSAN	66	HV1	DODDAKADANUR 66	09:09	09:20	00:11	MAIN SUPPLY FAILURE
1399	21-Mar-21	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR 66	11:05	11:11	00:06	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1400	21-Mar-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	09:43	09:51	00:08	LINE FAULT
1401	21-Mar-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:55	11:15	00:20	LINE FAULT
1402	21-Mar-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	11:15	11:23	00:08	LINE FAULT
1403	21-Mar-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	09:07	09:15	00:08	LINE FAULT
1404	21-Mar-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	01:05	11:10	10:05	LINE FAULT
1405	21-Mar-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	09:45	10:07	00:22	MAIN SUPPLY FAILURE
1406	21-Mar-21	HASSAN	66	HV1	MALALI_66	09:45	10:05	00:20	TRANSFORMER FAULT
1407	21-Mar-21	HASSAN	66	HV1	MALALI_66	10:57	11:08	00:11	TRANSFORMER FAULT
1408	21-Mar-21	HASSAN	66	HV1	MALALI_66	01:17	11:25	10:08	TRANSFORMER FAULT
1409	21-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	13:32	18:43	05:11	LINE CLEAR AVAILED
1410	21-Mar-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	13:32	18:43	05:11	LINE CLEAR AVAILED
1411	21-Mar-21	HASSAN	66	HV2	UDAYAPURA_66	09:02	09:09	00:07	TRANSFORMER FAULT
1412	21-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:29	18:18	07:49	LINE CLEAR AVAILED
1413	21-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:29	18:00	07:31	LINE CLEAR AVAILED
1414	21-Mar-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:50	11:24	00:34	LINE FAULT
1415	21-Mar-21	MYSURU	220	KR PETE 220-YACHANAHALLI	KRPET_220 AKKIHBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATAMPLE_66 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66	12:27	12:48	0:20	MAIN SUPPLY FAILURE
1416	21-Mar-21	MYSURU	220	KR PETE 220-TUBINAKERE	KRPET_220 AKKIHBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATAMPLE_66 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66	12:34	12:59	0:25	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1417	21-Mar-21	MYSURU	220	TUBINKERE-BASTIPURA	TUBINAKERE_220 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 DUNDANAHALLI_66 GARUDANAUKADDA_66 KOPPA_66 PANDAVAPURA_66 SRIRANGAPATNA_66 BESAGARAHALLI_66 DODDABYADARAHALLI_66	12:15	14:44	2:29	LINE FAULT
1418	21-Mar-21	MYSURU	220	TUBINKERE-YALIYUR	TUBINAKERE_220 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 DUNDANAHALLI_66 GARUDANAUKADDA_66 KOPPA_66 PANDAVAPURA_66 SRIRANGAPATNA_66 BESAGARAHALLI_66 DODDABYADARAHALLI_66	12:15	13:03	0:48	MAIN SUPPLY FAILURE
1419	21-Mar-21	MYSURU	220	TUBINKERE-KOTTIPURA	NO STATION EFFECTED	12:15	14:55	2:40	MAIN SUPPLY FAILURE
1420	21-Mar-21	MYSURU	66	HV1	ARAKERE_66	19:31	19:39	0:07	TRANSFORMER FAULT
1421	21-Mar-21	MYSURU	66	HV1	ARAKERE_66	21:20	21:24	0:03	TRANSFORMER FAULT
1422	21-Mar-21	MYSURU	66	HV2	DEVANOORNGUDU_66	15:28	15:40	0:12	TRANSFORMER FAULT
1423	21-Mar-21	MYSURU	66	HANGALA-GUNDLUPETE	HANGLA_66	9:35	9:55	0:20	HAND TRIPPED
1424	21-Mar-21	MYSURU	66	HOOTAGALLI-BEML	NO STATION EFFECTED	6:02	15:05	9:02	LINE CLEAR AVAILED
1425	21-Mar-21	MYSURU	66	HV1	KIADBMANDYA_66	15:26	15:35	0:08	MAIN SUPPLY FAILURE
1426	21-Mar-21	MYSURU	66	HV1	KIADBMANDYA_66	18:38	19:09	0:31	MAIN SUPPLY FAILURE
1427	21-Mar-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	18:38 (21/03/2021)			LINE OPEN:LINE FAULT
1428	21-Mar-21	MYSURU	66	HV1	KOLLEGALA_66	15:47	17:27	1:39	LINE CLEAR AVAILED
1429	21-Mar-21	MYSURU	66	HV2	KOLLEGALA_66	15:47	17:29	1:42	LINE CLEAR AVAILED
1430	21-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:12	16:19	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1431	21-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:00	11:06	0:06	LINE FAULT
1432	21-Mar-21	MYSURU	220	HV2	KUSHALNAGARA_220	23:54 (20/03/2021)	1:05 (21/03/2021)	1:10 HRS	TRANSFORMER CHARGED
1433	21-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
1434	21-Mar-21	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	20:43(20.03.2021)	21:11(21.03.2021)	7:06HRS	LINE CHARGED
1435	21-Mar-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	7:07	14:03	6:56	LINE CLEAR AVAILED
1436	21-Mar-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	7:08	16:08	8:59	LINE CLEAR AVAILED
1437	21-Mar-21	TUMKUR	220	TR-3	HIRIYUR_220	06:32:03	06:55:02	0:22	TRANSFORMER FAULT
1438	21-Mar-21	TUMKUR	220	TR-3	HIRIYUR_220	11:05:00	11:53:23	0:48	TRANSFORMER FAULT
1439	21-Mar-21	TUMKUR	220	HONNALLI 220kv- DAVANGERE 220kv	HONNALLI_220	7:00	14:14	7:13	LINE CLEAR AVAILED
1440	21-Mar-21	TUMKUR	220	KB CROSS 220kv- NELAMANGALA	KBCROSS_220	8:26	15:04	6:38	LINE CLEAR AVAILED
1441	21-Mar-21	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	8:31	14:44	6:13	HAND TRIPPED
1442	21-Mar-21	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	22:43:48 (20.03.2021)	7:04:40 (21.03.2021)	8:21HRS	LINE CHARGED
1443	21-Mar-21	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	03:25:17	13:52:39	10:27	LINE FAULT
1444	21-Mar-21	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	10:50	14:07	3:17	LINE CLEAR AVAILED
1445	21-Mar-21	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	2:45	4:22	1:36	LINE FAULT
1446	21-Mar-21	TUMKUR	110	TR2	KADEHALLI_110	3:30	3:43	0:12	TRANSFORMER FAULT
1447	21-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	9:52	10:06	0:13	HAND TRIPPED
1448	21-Mar-21	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	11:41	12:26	0:44	MAIN SUPPLY FAILURE
1449	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:05	6:15	0:10	LINE FAULT
1450	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA 1	CHITRADURGA_66	9:16	14:40	5:24	LINE CLEAR AVAILED
1451	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA2	CHITRADURGA_66	9:16	14:34	5:18	LINE CLEAR AVAILED
1452	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv- HGML	HGML_IPP_66	14:23	14:34	0:11	LINE FAULT
1453	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	10:34	10:53	0:19	LINE FAULT
1454	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	11:02	11:21	0:18	LINE FAULT
1455	21-Mar-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	12:59	13:37	0:37	LINE FAULT
1456	21-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:21	12:28	0:06	LINE FAULT
1457	21-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:06	14:17	0:11	LINE FAULT
1458	21-Mar-21	TUMKUR	66	TR1	HALURAMESHWARA_66	18:05	18:10	0:04	TRANSFORMER FAULT
1459	21-Mar-21	TUMKUR	66	TR1	HALURAMESHWARA_66	18:17	18:19	0:02	TRANSFORMER FAULT
1460	21-Mar-21	TUMKUR	66	TR3	HOLALKERE_66	19:50	19:56	0:06	HAND TRIPPED
1461	21-Mar-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	7:14	7:24	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1462	21-Mar-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:02	9:18	0:16	LINE FAULT
1463	21-Mar-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:15	13:10	0:55	LINE FAULT
1464	21-Mar-21	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	11:49	18:14	6:25	MAIN SUPPLY FAILURE
1465	21-Mar-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:44	9:56	0:12	LINE FAULT
1466	21-Mar-21	TUMKUR	66	TR2	HONNALLI_66	10:04	10:10	0:06	TRANSFORMER FAULT
1467	21-Mar-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	9:15	9:19	0:03	MAIN SUPPLY FAILURE
1468	21-Mar-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	12:03	12:08	0:04	MAIN SUPPLY FAILURE
1469	21-Mar-21	TUMKUR	66	TR1	MAVINAKATTE_66	15:58	16:04	0:06	TRANSFORMER FAULT
1470	21-Mar-21	TUMKUR	66	TR-2	SASALUHALLA_66	8:00	10:06	2:05	LINE CLEAR AVAILED
1471	21-Mar-21	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	6:05	6:20	0:14	LINE FAULT
1472	21-Mar-21	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	6:05	6:21	0:16	LINE FAULT
1473	22-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1474	22-Mar-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	18:55	19:01	0:06	LOAD CURTAILMENT
1475	22-Mar-21	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:09	14:18	4:09	LINE CLEAR AVAILED
1476	22-Mar-21	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	13:23	14:25	1:02	LINE CLEAR AVAILED
1477	22-Mar-21	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	18:56	19:03	0:07	LOAD CURTAILMENT
1478	22-Mar-21	BAGALKOT	110	110/11KV, HV2	AINAPUR_110	18:54	19:02	0:08	LOAD CURTAILMENT
1479	22-Mar-21	BAGALKOT	110	110/11KV, HV2	SIRSI_110	10:52	13:47	2:55	LINE CLEAR AVAILED
1480	22-Mar-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	8:56	09:21	0:25	LINE CLEAR AVAILED
1481	22-Mar-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:56	18:01	0:05	TRANSFORMER FAULT
1482	22-Mar-21	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	18:54	19:02	0:08	LOAD CURTAILMENT
1483	22-Mar-21	BAGALKOT	110	110/11KV, HV4(HV2)	GAJENDRAGAD_110	18:54	19:00	0:06	LOAD CURTAILMENT
1484	22-Mar-21	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	18:55	18:57	0:02	TRANSFORMER FAULT
1485	22-Mar-21	BAGALKOT	110	110/11KV,HV3	HIREKERUR_110	13:44	13:50	0:06	LINE CLEAR AVAILED
1486	22-Mar-21	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1487	22-Mar-21	BAGALKOT	110	110/33KV, HV2	KUDACHI_110, CHINCHALI_33	10:50	10:59	0:09	TRANSFORMER FAULT
1488	22-Mar-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DULKHED_33	12:21	12:24	0:03	TRANSFORMER FAULT
1489	22-Mar-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DULKHED_33	13:21	13:25	0:04	TRANSFORMER FAULT
1490	22-Mar-21	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	15:41	15:45	0:04	TRANSFORMER FAULT
1491	22-Mar-21	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	18:55	19:05	0:10	LOAD CURTAILMENT
1492	22-Mar-21	BAGALKOT	110	110/33KV,HV2	HANGAL_110,LAXMIPUR_33,AKKIAL URU_33,BELAGAL PETE_33,BOMMANAHALLI_33	07:48	7:59	0:11	TRANSFORMER FAULT
1493	22-Mar-21	BAGALKOT	110	110/33KV,HV2	HANGAL_110,LAXMIPUR_33,AKKIAL URU_33,BELAGAL PETE_33,BOMMANAHALLI_33	17:39	17:45	0:06	TRANSFORMER FAULT
1494	22-Mar-21	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINAGAD&KARADI_33	10:11	20:30	10:19	LINE CLEAR AVAILED
1495	22-Mar-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33&MYTRA SOLAR	18:55	18:59	0:04	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1496	22-Mar-21	BAGALKOT	110	AMBEWADI-NAGJHARI1	AMBEWADI_220	13:23	13:53	0:30	LINE FAULT
1497	22-Mar-21	BAGALKOT	110	AMBEWADI-NAGJHARI2	AMBEWADI_220	13:41	14:09	0:28	LINE FAULT
1498	22-Mar-21	BAGALKOT	110	AMBEWADI-NARENDRA1&2	AMBEWADI_220	07:40	17:52	10:12	LINE CLEAR AVAILED
1499	22-Mar-21	BAGALKOT	110	ANKOLA-ARGA(L1)	STATION NOT AFFECTED ANKOLA_110	18:58 21.03.2021)	8:45 (22.03.2021)	13:47	LINE FAULT
1500	22-Mar-21	BAGALKOT	110	ANKOLA-KUMTA(L2)	ANKOLA_110	08:15	10:33	2:18	LINE CLEAR AVAILED
1501	22-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1502	22-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1503	22-Mar-21	BAGALKOT	110	GAMESHA- RON	RON_110	0:20	0:26	0:06	HAND TRIPPED
1504	22-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
1505	22-Mar-21	BAGALKOT	110	HUKKERI-KOTABAGI	HUKKERI_110	6:23	7:41	1:18	LINE CLEAR AVAILED
1506	22-Mar-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)	13:05 22.03.2021)	1874:49 Hrs	LINE CHARGED
1507	22-Mar-21	BAGALKOT	110	KARAWAR-ARGA	STATION NOT AFFECTED ARGA_110	17:05 (22.03.2021)			LINE OPEN:LINE FAULT
1508	22-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
1509	22-Mar-21	BAGALKOT	110	KIRUVATTI-UMACHAGI	UMACHAGI_110	18:24	18:36	0:12	LINE FAULT
1510	22-Mar-21	BAGALKOT	110	KUMATA- SIRSI1	KUMATA_110	10:34	17:32	6:58	LINE CLEAR AVAILED
1511	22-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
1512	22-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1513	22-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1514	22-Mar-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1515	22-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1516	22-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1517	22-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1518	22-Mar-21	BAGALKOT	110	SIRSI220-SIRSI1 (IDLE3)	SIRSI_110	10:52	12:32	1:40	HAND TRIPPED
1519	22-Mar-21	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	10:52	12:32	1:40	HAND TRIPPED
1520	22-Mar-21	BAGALKOT	110	SIRSI-HUBLI1 (ESALE1)	SIRSI_110	10:52	12:33	1:41	LINE CLEAR AVAILED
1521	22-Mar-21	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI_110	12:02 (16.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1522	22-Mar-21	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	10:52	12:33	1:41	LINE CLEAR AVAILED
1523	22-Mar-21	BAGALKOT	110	SIRSI-KAVALAWADA (ESALE2)	SIRSI_110	10:52	12:33	1:41	LINE CLEAR AVAILED
1524	22-Mar-21	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	10:52	13:03	2:11	LINE CLEAR AVAILED
1525	22-Mar-21	BAGALKOT	110	SIRSI-SIDDAPUR (JOG1)	SIDDAPUR_110	10:52	12:33	1:41	LINE CLEAR AVAILED
1526	22-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1527	22-Mar-21	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)			LINE OPEN: LINE CLEAR AVAILED
1528	22-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (09.2.2021)	16:16 (22.03.2021)	317:29 Hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1529	22-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:19 (21.03.2021)	14:15 (22.03.2021)	28:56 Hrs	LINE CHARGED
1530	22-Mar-21	BAGALKOT	220	BIDNAL-HIREBEBDIGERI 1	BIDNAL_220	11:49	12:57	1:08	LINE CLEAR AVAILED
1531	22-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (09.2.2021)	16:06 (22.03.2021)	317:19 Hrs	LINE CHARGED
1532	22-Mar-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	17:22 (21.03.2021)	12:39 (22.03.2021)	19:17	LINE FAULT
1533	22-Mar-21	BAGALKOT	220	CHIKKODI-MUDASHINGI	STATION NOT AFFECTED CHIKKODI_220	17:22 (21.03.2021)	13:56 (22.03.2021)	20:34	LINE FAULT
1534	22-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
1535	22-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1536	22-Mar-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	07:40	17:51	10:11	LINE FAULT
1537	22-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
1538	22-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1539	22-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1540	22-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1541	22-Mar-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:01	19:31	00:30	LOAD CURTAILMENT
1542	22-Mar-21	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	19:08	19:38	00:30	LOAD CURTAILMENT
1543	22-Mar-21	BENGALURU	66	HV1	CHAKKAVELU	22:10	22:15	00:05	LINE CLEAR AVAILED
1544	22-Mar-21	BENGALURU	66	HV1	TYAMAGONDLU	16:38	16:40	00:02	LINE CLEAR AVAILED
1545	22-Mar-21	BENGALURU	66	HV1	HUKUNDA	08:02	08:06	00:04	TRANSFORMER FAULT
1546	22-Mar-21	BENGALURU	66	HV1	HUKUNDA	11:49	11:55	00:06	TRANSFORMER FAULT
1547	22-Mar-21	BENGALURU	66	HV2	KACHMARANAHALLI	11:47	11:52	00:05	TRANSFORMER FAULT
1548	22-Mar-21	BENGALURU	66	HV2	TYAMAGONDLU	17:31	17:55	00:24	LINE CLEAR AVAILED
1549	22-Mar-21	BENGALURU	66	HV2	MAASTHI	12:32	12:38	00:06	TRANSFORMER FAULT
1550	22-Mar-21	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	19:07	19:29	00:22	LOAD CURTAILMENT
1551	22-Mar-21	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI, TATA SOLAR(EHT)	07:59	08:25	00:26	LINE FAULT
1552	22-Mar-21	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN:LINE FAULT
1553	22-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
1554	22-Mar-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	13:15	13:25	00:10	LINE FAULT
1555	22-Mar-21	GULBARGA	110	HV1	TEKKALKOTE_110	18:54	19:00	00:06	LOAD CURTAILMENT
1556	22-Mar-21	GULBARGA	110	HV2	JEWARGI_110	18:54	19:20	00:26	LOAD CURTAILMENT
1557	22-Mar-21	GULBARGA	110	HV2	VALKAMDINNI_110	11:55	12:50	00:55	LOAD CURTAILMENT
1558	22-Mar-21	GULBARGA	110	JEWARGI-SHAHABAD	JEWARGI_110	08:15	18:15	10:00	LINE CLEAR AVAILED
1559	22-Mar-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	19:00	22:33	03:33	LINE CLEAR AVAILED
1560	22-Mar-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	08:15	18:15	10:00	NFBC ISSUED
1561	22-Mar-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	17:07	17:22	00:15	LINE FAULT
1562	22-Mar-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	08:55	17:10	08:15	LINE CLEAR AVAILED
1563	22-Mar-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:25	13:41	02:16	LINE CLEAR AVAILED
1564	22-Mar-21	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERAD ONA_110,SRERAMNAGAR_110,MALL APUR_110	13:44	13:59	00:15	LINE FAULT
1565	22-Mar-21	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110	12:30	14:40	02:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1566	22-Mar-21	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	12:25	12:40	00:15	MAIN SUPPLY FAILURE
1567	22-Mar-21	GULBARGA	220	HV2	ITTAGI_220	07:50	08:00	00:10	TRANSFORMER FAULT
1568	22-Mar-21	HASSAN	66	AKALE-IPCL2	SAKLESH PURA_66	13:31	18:41	05:10	LINE CLEAR AVAILED
1569	22-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	18:33	18:55	00:22	LINE CLEAR AVAILED
1570	22-Mar-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:31	10:44	00:13	LINE FAULT
1571	22-Mar-21	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	12:18	12:30	00:12	LINE FAULT
1572	22-Mar-21	HASSAN	66	HASSN22-HSN66	HASSAN_220	12:27	17:45	05:18	LINE CLEAR AVAILED
1573	22-Mar-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	09:15	09:22	00:07	LINE FAULT
1574	22-Mar-21	HASSAN	66	HV1	MALALI_66	09:16	09:23	00:07	MAIN SUPPLY FAILURE
1575	22-Mar-21	HASSAN	66	HV1	MALALI_66	11:24	12:26	01:02	TRANSFORMER FAULT
1576	22-Mar-21	HASSAN	66	HV1	SHANTHIGRAMMA_66	23:42	23:48	00:06	TRANSFORMER FAULT
1577	22-Mar-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	16:26	18:54	02:28	LINE CLEAR AVAILED
1578	22-Mar-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	18:55	19:00	00:05	LOAD CURTAILMENT
1579	22-Mar-21	HASSAN	66	HV2	RAMESHWARNAGARA_66	18:56	19:11	00:15	LOAD CURTAILMENT
1580	22-Mar-21	HASSAN	66	HV2	SALAGAME_66	18:56	19:04	00:08	LOAD CURTAILMENT
1581	22-Mar-21	HASSAN	66	HV2	SINGAPURA_66	18:53	19:08	00:15	LOAD CURTAILMENT
1582	22-Mar-21	HASSAN	66	HV2	UDAYAPURA_66	14:01	14:05	00:04	TRANSFORMER FAULT
1583	22-Mar-21	HASSAN	66	HV2	UDAYAPURA_66	14:18	14:20	00:02	TRANSFORMER FAULT
1584	22-Mar-21	HASSAN	66	HV2	UDAYAPURA_66	15:10	15:15	00:05	TRANSFORMER FAULT
1585	22-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1586	22-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1587	22-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	22:17(22.3.2021)			LINE OPEN:LINE FAULT
1588	22-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:28	10:33	00:05	LINE FAULT
1589	22-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:43	10:52	00:09	LINE FAULT
1590	22-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	13:31	18:41	05:10	LINE CLEAR AVAILED
1591	22-Mar-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:59	12:04	00:05	LINE FAULT
1592	22-Mar-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:02	18:35	08:33	LINE CLEAR AVAILED
1593	22-Mar-21	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	15:35	17:44	02:09	LINE CLEAR AVAILED
1594	22-Mar-21	HASSAN	110	HV1	JAVAGAL_110	12:44	13:28	00:44	LINE CLEAR AVAILED
1595	22-Mar-21	HASSAN	110	HV1	JAVAGAL_110	18:56	19:14	00:18	LOAD CURTAILMENT
1596	22-Mar-21	HASSAN	110	HV1	KONAJE_110	12:05	12:08	00:03	HAND TRIPPED
1597	22-Mar-21	HASSAN	110	HV1	KONAJE_110	13:11	13:15	00:04	HAND TRIPPED
1598	22-Mar-21	HASSAN	110	HV1	KONDENALU_110	18:57	19:05	00:08	LOAD CURTAILMENT
1599	22-Mar-21	HASSAN	110	HV1	MANIPAL_110	09:39	10:09	00:30	LINE CLEAR AVAILED
1600	22-Mar-21	HASSAN	110	HV2	BAIKAMPADI_110	10:16	11:45	01:29	LINE CLEAR AVAILED
1601	22-Mar-21	HASSAN	110	HV2	GANDSI_110	18:56	19:06	00:10	LOAD CURTAILMENT
1602	22-Mar-21	HASSAN	110	HV2	KONAJE_110	12:05	12:09	00:04	HAND TRIPPED
1603	22-Mar-21	HASSAN	110	HV2	KONAJE_110	13:11	13:15	00:04	HAND TRIPPED
1604	22-Mar-21	HASSAN	110	HV3	KONAJE_110	12:05	12:07	00:02	HAND TRIPPED
1605	22-Mar-21	HASSAN	110	HV3	KONAJE_110	13:11	13:15	00:04	HAND TRIPPED
1606	22-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	07:57	14:34	06:37	LINE CLEAR AVAILED
1607	22-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	07:57	14:34	06:37	LINE CLEAR AVAILED
1608	22-Mar-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	12:09	13:10	01:01	NFBC ISSUED
1609	22-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:16(21.3.2021)	14:24 (22.03.2021)	23:07 hrs	LINE CHARGED
1610	22-Mar-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:51(22.3.21)			LINE OPEN:LINE FAULT
1611	22-Mar-21	MYSURU	66	AC GIRI-TUBINKERE	ADICHUNCHANAGIRI_66	12:49	12:55	0:05	HAND TRIPPED
1612	22-Mar-21	MYSURU	66	HOOTAGALLI-BARC 2	NO STATION EFFECTED	16:47 (22/03/2021)			LINE OPEN: LINE CLEAR AVAILED
1613	22-Mar-21	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	13:00	13:55	0:55	LINE CLEAR AVAILED
1614	22-Mar-21	MYSURU	66	HV1	HANAGODU_66	18:56	19:03	0:07	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1615	22-Mar-21	MYSURU	66	HV1	HOOTAGALLY_220	9:53	10:00	0:06	LINE CLEAR AVAILED
1616	22-Mar-21	MYSURU	66	HV1	K_HONNALGERE_66	10:31	10:40	0:09	MAIN SUPPLY FAILURE
1617	22-Mar-21	MYSURU	66	HV1	KRPET_66	18:56	19:01	0:05	LOAD CURTAILMENT
1618	22-Mar-21	MYSURU	66	HV1	PANDAVAPURA_66	18:56	19:01	0:05	LOAD CURTAILMENT
1619	22-Mar-21	MYSURU	66	HV1	RAMAPURA_MYS_66	18:56	18:59	0:03	LOAD CURTAILMENT
1620	22-Mar-21	MYSURU	66	HV1	SATHEGALA_66	18:53	18:55	0:02	LOAD CURTAILMENT
1621	22-Mar-21	MYSURU	66	HV1	K_HONNALGERE_66	18:37 (21/03/2021)	1:52 (22/03/2021)	7:14 HRS	TRANSFORMER CHARGED
1622	22-Mar-21	MYSURU	66	HV2	ADICHUNCHANAGIRI_66	11:30	13:00	1:30	LINE CLEAR AVAILED
1623	22-Mar-21	MYSURU	66	HV2	AKKIHEBBAL_66	15:45	16:33	0:48	LINE CLEAR AVAILED
1624	22-Mar-21	MYSURU	66	HV2	AKKIHEBBAL_66	18:26	18:49	0:22	TRANSFORMER FAULT
1625	22-Mar-21	MYSURU	66	HV2	AKKIHEBBAL_66	18:53	19:02	0:08	LOAD CURTAILMENT
1626	22-Mar-21	MYSURU	66	HV2	BOOKANAKERE_66	13:07	13:16	0:09	TRANSFORMER FAULT
1627	22-Mar-21	MYSURU	66	HV2	BOOKANAKERE_66	18:53	19:01	0:07	LOAD CURTAILMENT
1628	22-Mar-21	MYSURU	66	HV2	CHINAKURALI_66	18:53	19:04	0:10	LOAD CURTAILMENT
1629	22-Mar-21	MYSURU	66	HV2	HANNUR_66	18:56	19:03	0:07	LOAD CURTAILMENT
1630	22-Mar-21	MYSURU	66	HV2	HOOTAGALLY_220	9:53 (22/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1631	22-Mar-21	MYSURU	66	HV2	KIRUGAVALU_66	18:56	19:20	0:24	LOAD CURTAILMENT
1632	22-Mar-21	MYSURU	66	HV2	MALAVALLI_66	18:56	19:02	0:05	LOAD CURTAILMENT
1633	22-Mar-21	MYSURU	66	HV2	SANTHEMARAHALLI_66	18:53	19:23	0:30	LOAD CURTAILMENT
1634	22-Mar-21	MYSURU	66	HV2	THALAKADU_66	18:53	19:09	0:15	LOAD CURTAILMENT
1635	22-Mar-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	1:44	1:52	0:08	HAND TRIPPED
1636	22-Mar-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	10:30	10:40	0:10	HAND TRIPPED
1637	22-Mar-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	8:52	9:03	0:11	HAND TRIPPED
1638	22-Mar-21	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	18:38 (21/03/2021)	1:36 (22/03/2021)	6:58 HRS	LINE CHARGED
1639	22-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
1640	22-Mar-21	MYSURU	66	PERIYAPATNA-HUNSUR	NO STATION EFFECTED	8:01	19:42	11:41	LINE CLEAR AVAILED
1641	22-Mar-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:33	6:39	0:06	LINE FAULT
1642	22-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:15	16:21	0:06	LINE FAULT
1643	22-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:32	16:39	0:06	LINE FAULT
1644	22-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:56	18:02	0:05	LINE FAULT
1645	22-Mar-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	15:38	16:04	0:25	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1646	22-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,	10:06	10:47	0:40	LOAD CURTAILMENT
1647	22-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDOODI_66	19:07	19:29	0:22	LOAD CURTAILMENT
1648	22-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	09:04	09:32	0:27	HAND TRIPPED
1649	22-Mar-21	TUMKUR	66	HARAPPANAHALLI-NEELAGUNDA	HARAPPANAHALLI_66	07:29	09:23	1:53	MAIN SUPPLY FAILURE
1650	22-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:23	19:26	0:03	HAND TRIPPED
1651	22-Mar-21	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:49	12:50	0:01	LINE FAULT
1652	22-Mar-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:42	15:50	0:08	LINE FAULT
1653	22-Mar-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:59	14:23	0:23	LINE CLEAR AVAILED
1654	22-Mar-21	TUMKUR	66	TR-1	KORATAGERE_66	09:25	09:34	0:08	TRANSFORMER FAULT
1655	22-Mar-21	TUMKUR	66	TR-1	KUKKAWADA_66	12:58	13:30	0:31	LINE CLEAR AVAILED
1656	22-Mar-21	TUMKUR	66	TR-1	MATHOD_66	08:08	08:18	0:10	TRANSFORMER FAULT
1657	22-Mar-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	01:23	01:26	0:02	TRANSFORMER FAULT
1658	22-Mar-21	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	06:40	09:25	2:45	LINE CLEAR AVAILED
1659	22-Mar-21	TUMKUR	66	TR-2	GUTTUR_66	11:01	11:02	0:01	HAND TRIPPED
1660	22-Mar-21	TUMKUR	66	TR-2	HOSADURGA_66	08:02	08:34	0:31	MAIN SUPPLY FAILURE
1661	22-Mar-21	TUMKUR	66	TR-2	TAVAREKERE(C)_66	08:04	08:06	0:02	TRANSFORMER FAULT
1662	22-Mar-21	TUMKUR	66	TR-3	HOLALKERE_66	18:55	19:00	0:05	TRANSFORMER FAULT
1663	22-Mar-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	19:13	19:21	0:08	LOAD CURTAILMENT
1664	22-Mar-21	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	09:02	14:12	5:10	LINE CLEAR AVAILED
1665	22-Mar-21	TUMKUR	110	TR-1	KALLUR_110	08:58	14:15	5:17	LINE CLEAR AVAILED
1666	22-Mar-21	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHARASAPURA 2	ANTHRASANAHALLI_220	06:26	09:51	3:25	LINE CLEAR AVAILED
1667	22-Mar-21	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	9:11:46 PM(21.03.2021)	9:28:11 AM(22.03.2021)	11:00	HAND TRIPPED
1668	22-Mar-21	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	09:29	17:18:44	7:49	HAND TRIPPED