

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:02.02.2021 TO 08.02.2021

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
1	2-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
2	2-Feb-2021	BAGALKOT	110	110/11KV, HV1(HV2)	STATION NOT AFFECTED TIKOTA_110	14:32	03:45	13:13	TRANSFORMER FAULT
3	2-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	20:49 (01.02.2021)	00:55 (02.02.2021)	4:06HRS	TRANSFORMER CHARGED
4	2-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	11:28	14:13	2:45	LINE CLEAR AVOIDED
5	2-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	14:29	14:46	0:17	LINE CLEAR AVOIDED
6	2-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL	14:11	14:43	0:32	HAND TRIPPED
7	2-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL	15:20	15:41	0:21	HAND TRIPPED
8	2-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
9	2-Feb-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	10:29	10:39	0:10	TRANSFORMER FAULT
10	2-Feb-2021	BAGALKOT	110	110/11KV,HV1	MORATAGI_110	12:10	14:27	2:17	LINE CLEAR AVOIDED
11	2-Feb-2021	BAGALKOT	110	110/33KV,HV3	GADAG_110,KAPPADAGUDDA_33,NAGAVI_33,MALLASAMUDRA_33,PIONEER_33	15:30	16:30	1:00	LINE CLEAR AVOIDED
12	2-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
13	2-Feb-2021	BAGALKOT	110	GADAG-DAMBAL	STATION NOT AFFECTED GADAG_220	15:25	18:03	2:38	LINE CLEAR AVOIDED
14	2-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
15	2-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
16	2-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
17	2-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
18	2-Feb-2021	BAGALKOT	110	HUNAGUND-KUDALASANGAM	STATION NOT AFFECTED KUDALASANGAM_110	18:24	18:40	0:16	LINE CLEAR AVOIDED
19	2-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
20	2-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
21	2-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03(2.02.21)			LINE OPEN, LINE CLEAR AVOIDED
22	2-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01(2.02.21)			LINE OPEN, LINE CLEAR AVOIDED
23	2-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
24	2-Feb-2021	BAGALKOT	110	MK HUBLI-KITTUR	STATION NOT AFFECTED MK HUBLI_110	12:29	19:00	6:31	LINE CLEAR AVOIDED
25	2-Feb-2021	BAGALKOT	110	MUDEBIHAL-BALAJISUGERS	STATION NOT AFFECTED MUDEBIHAL_110 BALAJISUGERS IPP_110	1:43	2:05	0:22	LINE FAULT
26	2-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
27	2-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
28	2-Feb-2021	BAGALKOT	110	SIRSI220(HUBLI1)-SIRSI	STATION NOT AFFECTED SIRSI_110	10:19	10:45	0:26	HAND TRIPPED
29	2-Feb-2021	BAGALKOT	110	ZALAKI-INCHIGERI(CHADACHAN)	INCHIGERI_110	12:32	14:25	1:53	LINE CLEAR AVOIDED
30	2-Feb-2021	BAGALKOT	220	ATHANI-MAHALINGAPUR	STATION NOT AFFECTED ATHANI_220	12:25	17:20	4:55	LINE CLEAR AVOIDED
31	2-Feb-2021	BAGALKOT	220	BAGEWADI-RBRK	STATION NOT AFFECTED BAGEWADI_220	16:42	16:49	0:07	LINE FAULT
32	2-Feb-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:52 (02.02.2021)			LOAD CURTAILMENT
33	2-Feb-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	21:51 (02.02.2021)			LOAD CURTAILMENT
34	2-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
35	2-Feb-2021	BAGALKOT	220	HUBLI-NAGJHARI1	STATION NOT AFFECTED HUBLI_220	10:50	16:09	5:19	LINE CLEAR AVOIDED
36	2-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
37	2-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
38	2-Feb-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	16:53	17:17	0:24	LINE FAULT
39	2-Feb-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	18:50	21:22	02:32	LINE FAULT
40	2-Feb-2021	BENGALURU	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE	20:25	20:30	00:05	LOAD CHANGE OVER
41	2-Feb-2021	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	10:07	10:13	00:06	LINE CLEAR AVOIDED
42	2-Feb-2021	BENGALURU	66	HV1	NIMHANS 66	13:43	13:47	00:04	LINE CLEAR AVOIDED
43	2-Feb-2021	BENGALURU	66	HV1	BAIRKUR	14:22	15:02	00:40	LINE CLEAR AVOIDED
44	2-Feb-2021	BENGALURU	66	HV1	MAGADI 66	13:18	15:59	02:41	LINE CLEAR AVOIDED
45	2-Feb-2021	BENGALURU	66	HV2	BAIRKUR	14:22	15:02	00:40	LINE CLEAR AVOIDED
46	2-Feb-2021	BENGALURU	66	HV2	GUNDAMGERE	14:18	14:28	00:10	TRANSFORMER FAULT
47	2-Feb-2021	BENGALURU	66	HV2	SOMAYAJANAHALLI	10:05	10:15	00:10	TRANSFORMER FAULT
48	2-Feb-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	11:33	12:02	00:29	LINE FAULT
49	2-Feb-2021	BENGALURU	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	18:37(29/01/2021)			LINE OPEN, LINE FAULT
50	2-Feb-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	13:24	13:30	00:06	LINE CLEAR AVOIDED
51	2-Feb-2021	GULBARGA	66	ITTAGI-HAMPASAGAR	HAMPASAGAR_66	13:39	14:01	00:22	MAIN SUPPLY FAILURE
52	2-Feb-2021	GULBARGA	110	ALIPUR-MUNIRABD	TORANGALU_110,KUDITINI_110,KURUGO D_110,SHATHVAHANA_IPP,AGARWAL_IPP ,SUZLON_IPP,KAMALAPUR_110MATRI_11 0,RBNSFACTORY	03:38	03:46	00:08	LINE FAULT
53	2-Feb-2021	GULBARGA	110	HV1	BEVOOR_110	12:40	13:20	00:40	LINE CLEAR AVOIDED
54	2-Feb-2021	GULBARGA	110	HV2	NALWAR_110	17:49	18:36	00:47	LINE CLEAR AVOIDED
55	2-Feb-2021	GULBARGA	110	HV3	GULBARGAWEST_110	13:03	13:08	00:05	MAIN SUPPLY FAILURE
56	2-Feb-2021	GULBARGA	110	HV3	SINDHNOOR_110	11:00	11:30	00:30	LINE CLEAR AVOIDED
57	2-Feb-2021	GULBARGA	110	HV3	SINDHNOOR_110	12:40	13:25	00:45	LINE CLEAR AVOIDED
58	2-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADLAPUR_110, KURDICROSS_110	05:54	06:24	00:30	LINE FAULT
59	2-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADLAPUR_110, KURDICROSS_110	06:26	06:36	00:10	LINE FAULT
60	2-Feb-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_11-,UGARSUGAR_IPP	03:39	03:49	00:10	LINE FAULT
61	2-Feb-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_11-,UGARSUGAR_IPP	06:25	06:33	00:08	LINE FAULT
62	2-Feb-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:56	22:01	00:05	LINE FAULT
63	2-Feb-2021	GULBARGA	220	LINGAPUR-JVSL1	LINGAPUR_220	08:48	17:00	08:12	NFBC ISSUED
64	2-Feb-2021	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	10:49	11:49	01:00	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
65	2-Feb-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	13:51	19:35	05:44	LINE CLEAR AVAILED
66	2-Feb-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:10(29.01.2021)	19:55(2.2.2021)	92:45 hrs	LINE CHARGED
67	2-Feb-2021	GULBARGA	400	JSWVL-BPS3	BPS3_400	12:10	13:54	01:44	LINE CLEAR AVAILED
68	2-Feb-2021	HASSAN	66	BELUR66-HASSAN	BELUR_66	00:11	00:37	00:26	MAIN SUPPLY FAILURE
69	2-Feb-2021	HASSAN	66	BELUR66-HASSAN	BELUR_66	05:42	05:53	00:11	HAND TRIPPED
70	2-Feb-2021	HASSAN	66	HAGARE-KALSAPURA	HAGARE_66	03:26	06:17	02:51	NFBC ISSUED
71	2-Feb-2021	HASSAN	66	HAGARE-KALSAPURA	HAGARE_66	06:17	06:23	00:06	LINE FAULT
72	2-Feb-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:44	12:17	00:33	HAND TRIPPED
73	2-Feb-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	18:37	18:43	00:06	LINE FAULT
74	2-Feb-2021	HASSAN	66	HV1	BANDISHETTYHALLI_66	18:38	18:44	00:06	MAIN SUPPLY FAILURE
75	2-Feb-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
76	2-Feb-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
77	2-Feb-2021	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	07:52	07:58	00:06	LINE FAULT
78	2-Feb-2021	HASSAN	110	HV1	ARASIKERE_110	10:27	11:16	00:49	LINE CLEAR AVAILED
79	2-Feb-2021	HASSAN	110	HV1	BANAVARA_110	16:00	16:30	00:30	LINE CLEAR AVAILED
80	2-Feb-2021	HASSAN	110	HV1	BELAGUMBA_110	13:49	14:09	00:20	LINE CLEAR AVAILED
81	2-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
82	2-Feb-2021	HASSAN	110	HV2	HALADY_110	21:20	21:33	00:13	TRANSFORMER FAULT
83	2-Feb-2021	HASSAN	110	HV2	BAIKAMPADI_110	13:25	14:10	00:45	LINE CLEAR AVAILED
84	2-Feb-2021	HASSAN	110	HV2	BELAGUMBA_110	13:11	13:17	00:06	LINE CLEAR AVAILED
85	2-Feb-2021	HASSAN	110	HV3	BANTWAL_110	09:26	16:07	06:41	LINE CLEAR AVAILED
86	2-Feb-2021	HASSAN	110	HV3	MANIPAL_110	17:29	23:03	05:34	LINE CLEAR AVAILED
87	2-Feb-2021	HASSAN	110	HV4	MANIPAL_110	13:29	13:46	00:17	LINE CLEAR AVAILED
88	2-Feb-2021	HASSAN	110	HV4	MANIPAL_110	17:31	18:18	00:47	LINE CLEAR AVAILED
89	2-Feb-2021	HASSAN	110	HV4	MANIPAL_110	19:41	21:42	02:01	LINE CLEAR AVAILED
90	2-Feb-2021	HASSAN	110	JOG110-AMBTR1	JOG_110	10:35	11:10	00:35	LINE CLEAR AVAILED
91	2-Feb-2021	HASSAN	110	JOG110-AMBTR2	JOG_110	00:00	10:30	10:30	LINE FAULT
92	2-Feb-2021	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	17:30	18:00	00:30	LINE CLEAR AVAILED
93	2-Feb-2021	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	11:38	12:44	01:06	LINE CLEAR AVAILED
94	2-Feb-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	11:40 (29.01.2021)	21:32 (2.2.2021)	105:51hrs	LINE CHARGED
95	2-Feb-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	09:08	11:11	02:03	LINE CLEAR AVAILED
96	2-Feb-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	09:08	11:11	02:03	LINE CLEAR AVAILED
97	2-Feb-2021	HASSAN	400	NELAMANGALA#2	TALAGUPPA_400	00:11	06:27	06:16	LINE CLEAR AVAILED
98	2-Feb-2021	MYSURU	66	AKKIHEBBAL-KAVERIHYDRO	NO STATION EFFECTED	13:59	14:21	0:22	LINE CLEAR AVAILED
99	2-Feb-2021	MYSURU	66	AKKIHEBBAL-KRPET 1	NO STATION EFFECTED	10:43	14:13	3:30	LINE CLEAR AVAILED
100	2-Feb-2021	MYSURU	66	AKKIHEBBAL-KRPET 2	NO STATION EFFECTED	14:30	16:55	2:25	LINE CLEAR AVAILED
101	2-Feb-2021	MYSURU	66	HV1	AKKIHEBBAL_66	10:43	14:25	3:42	LINE CLEAR AVAILED
102	2-Feb-2021	MYSURU	66	HV1	GUNDULPET_66	6:58	7:26	0:28	LINE CLEAR AVAILED
103	2-Feb-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	16:52 (01/02/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
104	2-Feb-2021	MYSURU	66	HV2	AKKIHEBBAL_66	14:27	16:55	2:27	LINE CLEAR AVAILED
105	2-Feb-2021	MYSURU	66	HV2	DATTAGALLY_66	9:59	18:40	8:40	LINE CLEAR AVAILED
106	2-Feb-2021	MYSURU	66	HV2	MADDUR_66	11:20	13:23	2:02	LINE CLEAR AVAILED
107	2-Feb-2021	MYSURU	66	HV2	CHANDAKAVADI_66	10:46	11:07	0:20	LINE CLEAR AVAILED
108	2-Feb-2021	MYSURU	66	HV2	PONNAMPET_66	20:23 (02/02/2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
109	2-Feb-2021	MYSURU	66	HV2	TERAKANAMBE_66	12:26	13:35	1:08	LINE CLEAR AVAILED
110	2-Feb-2021	MYSURU	66	HV2	DUNDANAHALLI_66	16:08	17:13	1:04	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
111	2-Feb-2021	MYSURU	66	HV5	SFCSHIVA_66	16:04 (02/02/2021)			TRANSFORMER OPEN,LINE CLEAR AVAIED
112	2-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAIED
113	2-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAIED
114	2-Feb-2021	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATION EFFECTED	6:58	7:03	0:04	LINE FAULT
115	2-Feb-2021	MYSURU	66	RK NAGARA-DATAGALLI	NO STATION EFFECTED	20:10 (30/01/2021)			LINE OPEN, LINE CLEAR AVAIED
116	2-Feb-2021	MYSURU	66	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE 66	12:35	12:40	0:05	LINE FAULT
117	2-Feb-2021	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	22:01	22:14	0:13	LINE FAULT
118	2-Feb-2021	TUMKUR	66	BALENAHALLI- FEFCWIND IPP 66	FEFCWIND_IPP_66	09:21	18:15	8:54	LINE CLEAR AVAIED
119	2-Feb-2021	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	11:38	12:05	0:26	LINE FAULT
120	2-Feb-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	06:51	06:57	0:06	LINE FAULT
121	2-Feb-2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	06:43	06:52	0:09	TRANSFORMER FAULT
122	2-Feb-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	14:28	17:26	2:57	LINE CLEAR AVAIED
123	2-Feb-2021	TUMKUR	66	TR-1	KATTIGE_66	22:03	22:06	0:03	TRANSFORMER FAULT
124	2-Feb-2021	TUMKUR	66	TR-1	KUNDUR_66	19:15	19:30	0:14	TRANSFORMER FAULT
125	2-Feb-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	14:28	17:26	2:57	LINE CLEAR AVAIED
126	2-Feb-2021	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	09:07	09:17	0:10	LINE FAULT
127	2-Feb-2021	TUMKUR	110	TR-1	NITTUR_220	18:31	18:36	0:05	TRANSFORMER FAULT
128	2-Feb-2021	TUMKUR	110	TR-2	SHETYKERE_110	14:22	15:22	1:00	LINE CLEAR AVAIED
129	2-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE OPEN, LINE CLEAR AVAIED
130	2-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	8:29:22 PM(02.02.2021)			LINE OPEN, LINE CLEAR AVAIED
131	2-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAIED
132	2-Feb-2021	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kv	HONNALLI_220	21:32	21:39	0:06	HAND TRIPPED
133	3-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
134	3-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAIED
135	3-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAIED
136	3-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
137	3-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAIED
138	3-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM 110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
139	3-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAIED
140	3-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAIED
141	3-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAIED
142	3-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA 110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAIED
143	3-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA 110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
144	3-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
145	3-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
146	3-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
147	3-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
148	3-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
149	3-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
150	3-Feb-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:52 (02.02.2021)	8:14 (03.02.2021)	10:22HRS	LINE CHARGED
151	3-Feb-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	21:51 (02.02.2021)	8:14 (03.02.2021)	10:23HRS	LINE CHARGED
152	3-Feb-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	16:17	17:24	1:07	LINE CLEAR AVOIDED
153	3-Feb-2021	BAGALKOT	110	SUPA2-AMBEWADI	STATION NOT AFFECTED AMBEWADI_220	22:28	23:54	1:26	LINE FAULT
154	3-Feb-2021	BAGALKOT	110	SUPA1-AMBEWADI	STATION NOT AFFECTED AMBEWADI_220	23:53 (03.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
155	3-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	09:09	21:07	11:58	LINE FAULT
156	3-Feb-2021	BAGALKOT	220	ATHANI-MAHALINGAPUR	STATION NOT AFFECTED ATHANI_220	10:38	19:51	9:13	LINE CLEAR AVOIDED
157	3-Feb-2021	BAGALKOT	220	KUDUCHI-ATHANI	STATION NOT AFFECTED KUDUCHI_220	11:33	17:17	5:44	LINE CLEAR AVOIDED
158	3-Feb-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	15:01	16:35	1:34	LINE CLEAR AVOIDED
159	3-Feb-2021	BAGALKOT	110	ENERCON(EILS)-DAMBAL	STATION NOT AFFECTED DAMBAL_110	11:00	13:41	2:41	LINE CLEAR AVOIDED
160	3-Feb-2021	BAGALKOT	110	ENERCON(EILS)-DAMBAL	STATION NOT AFFECTED DAMBAL_110	22:17	22:57	0:40	LINE FAULT
161	3-Feb-2021	BAGALKOT	110	AMBEWADI-KAVALAWADA	KAVALAWADA_110	12:20	16:14	3:54	LINE CLEAR AVOIDED
162	3-Feb-2021	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	11:31 (03.02.2021)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
163	3-Feb-2021	BAGALKOT	220	NARENDRA-AMBEWADI	STATION NOT AFFECTED NARENDRA_220	10:08 (03.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
164	3-Feb-2021	BAGALKOT	220	NAGJHARI2- HUBLI	NO STATION AFFECTED HUBLI_220	11:05	14:56	3:51	LINE CLEAR AVOIDED
165	3-Feb-2021	BAGALKOT	110	110/33KV, HV3	NO STATION AFFECTED HUBLI_220	15:57	17:49	1:52	LINE CLEAR AVOIDED
166	3-Feb-2021	BAGALKOT	110	110/33KV, HV1	SOUDATTI_110, UDIKERI_33, SUZLON_33	10:06	13:21	3:15	TRANSFORMER FAULT
167	3-Feb-2021	BAGALKOT	110	NARAGUNG-BPCL SOLAR	STATION NOT AFFECTED NARAGUND_110 BPCL IPP_110	01:01	02:18	1:17	LINE FAULT
168	3-Feb-2021	BAGALKOT	110	MUKARTIHAL-MATRIX SOLAR	STATION NOT AFFECTED MUKARTIHAL_110, MATRIX IPP_110	16:17	16:31	0:14	HAND TRIPPED
169	3-Feb-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MAMADAPUR_110	16:59	17:12	0:13	LINE CLEAR AVOIDED
170	3-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MAMADAPUR_110	15:05	16:52	1:47	LINE CLEAR AVOIDED
171	3-Feb-2021	BENGALURU	66	HV2	AMAR JYOTHI	13:44	13:50	00:06	LINE CLEAR AVOIDED
172	3-Feb-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	14:06	14:08	00:02	LOAD CHANGE OVER
173	3-Feb-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	18:26	18:28	00:02	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
174	3-Feb-2021	BENGALURU	66	HV2	HENNUR CROSS	14:47	16:04	01:17	LINE CLEAR AVAILED
175	3-Feb-2021	BENGALURU	66	HV1	HENNUR CROSS	15:06	15:19	00:13	LINE CLEAR AVAILED
176	3-Feb-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	15:20	15:34	00:14	LINE CLEAR AVAILED
177	3-Feb-2021	BENGALURU	66	MELLAHALLI - ADANI SOLAR (IPP)	NO STATION AFFECTED	03:35	05:05	01:30	LINE FAULT
178	3-Feb-2021	BENGALURU	66	HV1	NIMHANS 66	13:02	13:30	00:28	LINE CLEAR AVAILED
179	3-Feb-2021	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	12:20	12:25	00:05	LOAD CHANGE OVER
180	3-Feb-2021	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	12:25	13:00	00:35	LOAD CHANGE OVER
181	3-Feb-2021	BENGALURU	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	16:27	16:57	00:30	LINE CLEAR AVAILED
182	3-Feb-2021	BENGALURU	66	HV1	CHINTAMANI 66	10:26	10:33	00:07	LINE CLEAR AVAILED
183	3-Feb-2021	BENGALURU	66	HV2	KANAKAPURA 66	18:07	20:10	02:03	TRANSFORMER FAULT
184	3-Feb-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	07:28	07:39	00:11	LINE FAULT
185	3-Feb-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	09:14	09:20	00:06	LINE FAULT
186	3-Feb-2021	BENGALURU	66	TAYALUR - N G HULKUR	N G HULKUR	13:44	14:00	00:16	LINE FAULT
187	3-Feb-2021	BENGALURU	66	HV1	PATHPALYA	11:30	12:16	00:46	TRANSFORMER FAULT
188	3-Feb-2021	BENGALURU	66	SADALI - JULUPALYA	SADALI	08:45	08:52	00:07	LINE FAULT
189	3-Feb-2021	BENGALURU	66	HV1	SOMAYAJANAHALLI	16:17	16:35	00:18	LINE CLEAR AVAILED
190	3-Feb-2021	BENGALURU	66	HV2	SOMAYAJANAHALLI	16:35	17:00	00:25	LINE CLEAR AVAILED
191	3-Feb-2021	BENGALURU	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE	09:00	09:10	00:10	LOAD CHANGE OVER
192	3-Feb-2021	BENGALURU	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	18:37(29/01/2021)	4:27(03/02/2021)	106:50HRS	LINE CHARGED
193	3-Feb-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	11:12	13:13	02:01	LINE CLEAR AVAILED
194	3-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADLAPUR_110, KURDICROSS_110	6:50(3.02.21)			LINE OPEN, LINE FAULT
195	3-Feb-2021	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	10:05	10:33	00:28	MAIN SUPPLY FAILURE
196	3-Feb-2021	GULBARGA	110	HV2	GINIGERA_110	09:30	09:50	00:20	LINE CLEAR AVAILED
197	3-Feb-2021	GULBARGA	110	HV3	GULBARGAWEST_110	11:56	12:08	00:12	TRANSFORMER FAULT
198	3-Feb-2021	GULBARGA	110	HV3	GULBARGAWEST_110	12:15	12:23	00:08	TRANSFORMER FAULT
199	3-Feb-2021	GULBARGA	110	HV2	NALWAR_110	17:08	18:14	01:06	LINE CLEAR AVAILED
200	3-Feb-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR,GANGAVATHI_110,VENKATAGIRI_110	16:07	16:16	00:09	LINE FAULT
201	3-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
202	3-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
203	3-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
204	3-Feb-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	14:50	18:15	03:25	LINE CLEAR AVAILED
205	3-Feb-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	10:01	18:06	08:05	LINE CLEAR AVAILED
206	3-Feb-2021	HASSAN	110	HV1	ARASIKERE_110	13:35	14:22	00:47	LINE CLEAR AVAILED
207	3-Feb-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	14:56	15:04	00:08	HAND TRIPPED
208	3-Feb-2021	HASSAN	110	HV3	BHADRAVATHI_110	13:44	16:15	02:31	LINE CLEAR AVAILED
209	3-Feb-2021	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	10:24	12:53	02:29	LINE CLEAR AVAILED
210	3-Feb-2021	HASSAN	110	KAVOOR-AMR	KAVOOR_220	14:57	15:00	00:03	HAND TRIPPED
211	3-Feb-2021	HASSAN	110	MRSSHM-MYSORE	MRSMG_220	01:21	08:23	07:02	LINE FAULT
212	3-Feb-2021	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	11:27	12:16	00:49	LINE CLEAR AVAILED
213	3-Feb-2021	MYSURU	220	HV2	BEGUR_220	12:11	15:56	3:45	LINE CLEAR AVAILED
214	3-Feb-2021	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATION EFFECTED	11:58	12:40	0:41	LINE CLEAR AVAILED
215	3-Feb-2021	MYSURU	66	HOOTAGALLI-KHB STATION	NO STATION EFFECTED	9:21	12:11	2:50	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
216	3-Feb-2021	MYSURU	66	HV1	ARAKERE_66	13:30	15:58	2:28	LINE CLEAR AVAILED
217	3-Feb-2021	MYSURU	66	HV2	ARAKERE_66	12:35	14:00	1:25	LINE CLEAR AVAILED
218	3-Feb-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	6:52	6:58	0:06	LINE FAULT
219	3-Feb-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	11:49	11:54	0:05	LINE FAULT
220	3-Feb-2021	MYSURU	66	BASARALU-KASALGERE	BASARALU_66	12:00	12:40	0:40	LINE CLEAR AVAILED
221	3-Feb-2021	MYSURU	66	HV2	HARVEY_66	8:12	8:17	0:04	TRANSFORMER FAULT
222	3-Feb-2021	MYSURU	66	HV2	PONNAMPET_66	15:14	15:42	0:28	TRANSFORMER FAULT
223	3-Feb-2021	MYSURU	66	HV5	SFCSHIVA_66	7:45	12:15	4:29	LINE CLEAR AVAILED
224	3-Feb-2021	MYSURU	66	HV1	BYLUKUPPE_66	11:20	12:17	0:57	LINE CLEAR AVAILED
225	3-Feb-2021	MYSURU	66	HV2	BEGUR_220	15:58	17:01	1:03	LINE CLEAR AVAILED
226	3-Feb-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	16:52 (01/02/2021)	11:07(03.02.21)	42:15 HRS	TRANSFORMER CHARGED
227	3-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
228	3-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
229	3-Feb-2021	MYSURU	66	RK NAGARA-DATAGALLI	NO STATION EFFECTED	20:10 (30/01/2021)	10:15(03.02.21)	86:05 HRS	LINE CHARGED
230	3-Feb-2021	MYSURU	66	HV2	PONNAMPET_66	20:23 (02/02/2021)	12:58(03.02.21)	4:35 HRS	TRANSFORMER CHARGED
231	3-Feb-2021	MYSURU	66	HV5	SFCSHIVA_66	16:04 (02/02/2021)	7:45(03.02.21)	15:41 HRS	TRANSFORMER CHARGED
232	3-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE OPEN, LINE CLEAR AVAILED
233	3-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
234	3-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	20:29:22(02.02.2021)	13:35:02(03.02.2021)	17:06HRS	LINE CHARGED
235	3-Feb-2021	TUMKUR	66	TR-2	HONNALI_66	8:34:16 PM(03.02.2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
236	3-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:58	12:02	0:04	LINE CLEAR AVAILED
237	3-Feb-2021	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	13:44	14:40	0:55	HAND TRIPPED
238	3-Feb-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:16	13:31	0:15	LINE FAULT
239	3-Feb-2021	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	9:45	11:55	2:09	LINE CLEAR AVAILED
240	3-Feb-2021	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	9:06	9:19	0:12	LINE FAULT
241	3-Feb-2021	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:28	12:37	0:08	LINE CLEAR AVAILED
242	3-Feb-2021	TUMKUR	66	TR-1	BELLAVI_66	18:11	18:21	0:10	LINE CLEAR AVAILED
243	3-Feb-2021	TUMKUR	66	HONNALLI 66KV- HONNALLI	HONNALI_66	20:34	20:54	0:20	LINE FAULT
244	3-Feb-2021	TUMKUR	66	TR-1	HONNALI_66	20:52	20:55	0:03	TRANSFORMER FAULT
245	3-Feb-2021	TUMKUR	66	TR-3	HONNALI_66	20:52	20:55	0:03	TRANSFORMER FAULT
246	3-Feb-2021	TUMKUR	66	TR-1	KATTIGE_66	10:36	10:43	0:06	TRANSFORMER FAULT
247	3-Feb-2021	TUMKUR	66	TR-1	KATTIGE_66	11:40	11:48	0:08	TRANSFORMER FAULT
248	3-Feb-2021	TUMKUR	66	TR-2	KOLALA_66	14:02	14:45	0:43	LINE CLEAR AVAILED
249	3-Feb-2021	TUMKUR	66	TR-2	KORA_66	8:00	8:36	0:35	TRANSFORMER FAULT
250	3-Feb-2021	TUMKUR	66	TR-1	KUNDUR_66	12:02	12:14	0:12	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
251	3-Feb-2021	TUMKUR	66	TR-2	MATHOD_66	16:11	17:35	1:24	LINE CLEAR AVAILED
252	3-Feb-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	9:10	13:00	3:49	LINE CLEAR AVAILED
253	3-Feb-2021	TUMKUR	66	TR-2	SHYLAPURA_66	4:57	5:06	0:09	TRANSFORMER FAULT
254	3-Feb-2021	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	12:29	12:32	0:03	TRANSFORMER FAULT
255	3-Feb-2021	TUMKUR	66	TR-2	URDIGERE_66	8:00	8:58	0:58	LINE CLEAR AVAILED
256	3-Feb-2021	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	14:19	14:39	0:20	LINE CLEAR AVAILED
257	3-Feb-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:44	14:56	1:12	MAIN SUPPLY FAILURE
258	3-Feb-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:44	14:56	1:12	MAIN SUPPLY FAILURE
259	3-Feb-2021	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	13:44	14:56	1:11	MAIN SUPPLY FAILURE
260	3-Feb-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:44	14:56	1:12	MAIN SUPPLY FAILURE
261	3-Feb-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:37	16:48	0:10	HAND TRIPPED
262	4-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
263	4-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
264	4-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
265	4-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
266	4-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
267	4-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
268	4-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
269	4-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
270	4-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
271	4-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
272	4-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
273	4-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
274	4-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
275	4-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
276	4-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
277	4-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN, LINE CLEAR AVAILED
278	4-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN, LINE CLEAR AVAILED
279	4-Feb-2021	BAGALKOT	110	SUPA1-AMBEWADI	STATION NOT AFFECTED AMBEWADI_220	23:53 (03.02.2021)	12:58 (04.02.2021)	13:05HRS	LINE CHARGED
280	4-Feb-2021	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	11:31 (03.02.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
281	4-Feb-2021	BAGALKOT	220	NARENDRA-AMBEWADI	STATION NOT AFFECTED NARENDRA_220	10:08 (03.02.2021)	17:29 (04.02.2021)	31:20HRS	LINE CHARGED
282	4-Feb-2021	BAGALKOT	110	SUPA2 -AMBEWADI	AMBEWADI_220	10:55	12:58	2:03	LINE CLEAR AVAILED
283	4-Feb-2021	BAGALKOT	110	SUPA1 -AMBEWADI	AMBEWADI_220	15:29	16:15	0:46	LINE FAULT
284	4-Feb-2021	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	11:50	13:38	1:48	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
285	4-Feb-2021	BAGALKOT	110	110/11KV,HV 2	HANAGALL_110	10:18	18:00	7:42	LINE CLEAR AVAILED
286	4-Feb-2021	BAGALKOT	110	HAVERI220-HANAGAL	HANAGAL_110	10:34	18:03	7:29	LINE CLEAR AVAILED
287	4-Feb-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	12:59	18:27	5:28	LINE CLEAR AVAILED
288	4-Feb-2021	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	17:41 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
289	4-Feb-2021	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	11:05	11:15	0:10	LINE CLEAR AVAILED
290	4-Feb-2021	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	12:05	17:36	5:31	LINE CLEAR AVAILED
291	4-Feb-2021	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMINAGAD_33,KARADI_33,MYTRA SOLAR_33	16:34	16:43	0:09	TRANSFORMER FAULT
292	4-Feb-2021	BAGALKOT	110	SPV-MUKARTIHAL	STATION NOT AFFECTED MUKARTIHAL_110	13:01	13:20	0:19	LINE FAULT
293	4-Feb-2021	BAGALKOT	110	110/11KV,HV1	MUNDAGOD_110	12:47	13:07	0:20	LINE CLEAR AVAILED
294	4-Feb-2021	BAGALKOT	110	SIRSI-JOG2(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	10:35	10:41	0:06	HAND TRIPPED
295	4-Feb-2021	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	09:06	23:01	13:55	LINE CLEAR AVAILED
296	4-Feb-2021	BAGALKOT	110	HUBLI-NAGJHARI2	STATION NOT AFFECTED HUBLI_220	11:12	15:04	3:52	LINE CLEAR AVAILED
297	4-Feb-2021	BAGALKOT	110	ITNAL-RAIBAG2	STATION NOT AFFECTED ITNAL_110	17:40	18:04	0:24	HAND TRIPPED
298	4-Feb-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
299	4-Feb-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	STATION NOT AFFECTED MAHALINGAPUR_220	16:06	16:10	0:04	LINE FAULT
300	4-Feb-2021	BAGALKOT	220	220/110KV,HV3,LV3	NO STATION AFFECTED MAHALINGAPUR_220	12:58	17:26	4:28	LINE CLEAR AVAILED
301	4-Feb-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	9:00	17:22	8:22	LINE CLEAR AVAILED
302	4-Feb-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	09:26	09:54	00:28	LINE CLEAR AVAILED
303	4-Feb-2021	BENGALURU	66	HV1	B G ROAD	01:46	02:02	00:16	TRANSFORMER FAULT
304	4-Feb-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	10:21	10:33	00:12	MAIN SUPPLY FAILURE
305	4-Feb-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	17:15	17:20	00:05	LOAD CHANGE OVER
306	4-Feb-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	12:30	12:43	00:13	LINE CLEAR AVAILED
307	4-Feb-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	12:30	12:43	00:13	LINE CLEAR AVAILED
308	4-Feb-2021	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	12:30	12:43	00:13	LINE CLEAR AVAILED
309	4-Feb-2021	BENGALURU	66	HV2	HSR LAYOUT 220	12:30	12:43	00:13	LINE CLEAR AVAILED
310	4-Feb-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:23	13:43	00:20	LINE CLEAR AVAILED
311	4-Feb-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELA, BIJJAHALLI	16:09	16:35	00:26	LINE FAULT
312	4-Feb-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HAROBELA	16:38	20:07	03:29	LINE CLEAR AVAILED
313	4-Feb-2021	BENGALURU	66	HV2	TELECOM LAYOUT	14:55	15:02	00:07	TRANSFORMER FAULT
314	4-Feb-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	12:35	12:45	00:10	LINE CLEAR AVAILED
315	4-Feb-2021	BENGALURU	66	HV1	L R BANDE	12:50	12:58	00:08	LINE CLEAR AVAILED
316	4-Feb-2021	BENGALURU	66	HV2	L R BANDE	12:15	12:45	00:30	LINE CLEAR AVAILED
317	4-Feb-2021	BENGALURU	66	ACHALU - KANAKAPURA 220	ACHALU, HONNIGANAHALLI, DODDALAHALLI	16:10	16:25	00:15	LINE FAULT
318	4-Feb-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	16:26	16:47	00:21	LINE FAULT
319	4-Feb-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	02:02	02:21	00:19	LINE FAULT
320	4-Feb-2021	BENGALURU	66	HAROBELA - KODIHALLI	HUNSENAHALLI,BIJJAHALLI, KODIHALLI	20:07	20:55	00:48	LINE FAULT
321	4-Feb-2021	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI, ANDERSONPETE	11:20	12:20	01:00	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
322	4-Feb-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	12:30	14:15	01:45	LINE CLEAR AVAILED
323	4-Feb-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	12:45	14:45	02:00	LINE CLEAR AVAILED
324	4-Feb-2021	BENGALURU	66	HV1	LAKSHMIPURA	12:30	16:00	03:30	LINE CLEAR AVAILED
325	4-Feb-2021	BENGALURU	66	HV2	LAKSHMIPURA	12:30	14:30	02:00	LINE CLEAR AVAILED
326	4-Feb-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:18	09:22	00:04	LINE FAULT
327	4-Feb-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:54	16:01	00:07	LINE FAULT
328	4-Feb-2021	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	10:21	10:33	00:11	LINE FAULT
329	4-Feb-2021	BENGALURU	66	HV2	MULBAGALU	09:24	09:45	00:21	TRANSFORMER FAULT
330	4-Feb-2021	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI,BIJJAHALLI	20:07:00(04/02/2021)			LINE OPEN, LINE FAULT
331	4-Feb-2021	GULBARGA	400	RTPS-MEHBOOBNAGAR	MEHBOOBNAGAR_400	06:43	07:28	00:45	LINE FAULT
332	4-Feb-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	12:12	15:30	03:18	LINE CLEAR AVAILED
333	4-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADLAPUR_110, KURDICROSS_110	6:50(4.2.2021)			LINE OPEN, LINE FAULT
334	4-Feb-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITAL_110	00:13	00:23	00:10	LINE FAULT
335	4-Feb-2021	GULBARGA	110	GULBARGASOUTH-FARHATABAD	FARHATABAD_110	15:10(04.02.2021)	07:40(05.02.2021)	16:30 HRS	LINE CHARGED
336	4-Feb-2021	GULBARGA	110	STARMETALIC-MUNIRABAD	STARMETALIC_110	00:20	00:34	00:14	LINE FAULT
337	4-Feb-2021	GULBARGA	110	SHAHAPUR-SHORAPUR_110	SHORAPUR_110	03:49	03:54	00:05	LINE FAULT
338	4-Feb-2021	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	11:20	11:25	00:05	MAIN SUPPLY FAILURE
339	4-Feb-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_110,YERADONA_110,SR NAGAR_110,MADALAPUR_110	22:45	22:55	00:10	LINE FAULT
340	4-Feb-2021	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	17:08	17:18	00:10	LINE FAULT
341	4-Feb-2021	GULBARGA	110	SHAHAPUR-SHORAPUR_110	SHORAPUR_110	22:53	22:59	00:06	LINE FAULT
342	4-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	02:33	02:38	00:05	LINE FAULT
343	4-Feb-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	CURDICROSS_110,MADALAPUR_110,MANVI_110	06:42	06:47	00:05	LINE FAULT
344	4-Feb-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPURA_66,MAGALA_66	04:11	04:20	00:09	LINE FAULT
345	4-Feb-2021	GULBARGA	66	ITTAGGI-BENNEHALLI	BENNEHALLI_66,KOTTUR_66,UJJANI_66	16:53	19:52	02:59	LINE FAULT
346	4-Feb-2021	GULBARGA	66	KOTTUR-SUZLON	BENNEHALLI_66,KOTTUR_66,UJJANI_66	16:55	17:25	00:30	LINE FAULT
347	4-Feb-2021	GULBARGA	66	KOTTUR-SUZLON	BENNEHALLI_66,KOTTUR_66,UJJANI_66	19:05	19:25	00:20	LINE CLEAR AVAILED
348	4-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
349	4-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
350	4-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
351	4-Feb-2021	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	10:16	12:58	02:42	LINE CLEAR AVAILED
352	4-Feb-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:16	12:58	02:42	NFBC ISSUED
353	4-Feb-2021	HASSAN	110	HV1	HIRIYADKA_110	15:43	16:25	00:42	LINE CLEAR AVAILED
354	4-Feb-2021	HASSAN	110	HV1	JAVAGAL_110	14:08	14:28	00:20	HAND TRIPPED
355	4-Feb-2021	HASSAN	110	HV2	JAVAGAL_110	14:35	14:55	00:20	HAND TRIPPED
356	4-Feb-2021	HASSAN	110	HV2	KADUR_220	10:30	13:17	02:47	LINE CLEAR AVAILED
357	4-Feb-2021	HASSAN	66	HV1	HANGARANAHALLY_66	09:17	09:26	00:09	LOAD CURTAILMENT
358	4-Feb-2021	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	10:57	11:05	00:08	LINE FAULT
359	4-Feb-2021	HASSAN	66	HV2	TAVARECHATNAHALLI_66	14:23	16:52	02:29	TRANSFORMER FAULT
360	4-Feb-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	11:05	11:10	00:05	MAIN SUPPLY FAILURE
361	4-Feb-2021	MYSURU	220	HOOTAGALLY-KADAKOLA	NO STATION EFFECTED	8:18	18:47	10:28	NFBC ISSUED
362	4-Feb-2021	MYSURU	66	VAJMANGALA-DEV(MYS)	DEVANOORMYS_66	8:57	9:12	0:15	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
363	4-Feb-2021	MYSURU	66	DEVNUR(MYS)-RAJEEVNAGARA	RAJEEVNAGARA_66	8:58	9:15	0:17	HAND TRIPPED
364	4-Feb-2021	MYSURU	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	9:24	17:40	8:16	LINE CLEAR AVAILED
365	4-Feb-2021	MYSURU	66	CR NAGARA-BADANGUPPE 1	BADANAGUPPE_66	10:07	17:16	7:09	LINE CLEAR AVAILED
366	4-Feb-2021	MYSURU	66	CR NAGARA-BADANGUPPE 2	BADANAGUPPE_66	10:07	17:16	7:09	LINE CLEAR AVAILED
367	4-Feb-2021	MYSURU	66	CR NAGARA-PANNYADUNDI	PANDYADAHUNDI_66 KARYA_66	10:24	11:44	1:19	LINE CLEAR AVAILED
368	4-Feb-2021	MYSURU	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	11:55	12:34	0:38	HAND TRIPPED
369	4-Feb-2021	MYSURU	66	PANNYADUNDI-HEMERGALA	PANDYADAHUNDI_66 KARYA_66	10:30	13:15	2:45	LINE CLEAR AVAILED
370	4-Feb-2021	MYSURU	66	PANNYADUNDI-CR NAGARA	PANDYADAHUNDI_66 KARYA_66	10:20	13:15	2:55	LINE CLEAR AVAILED
371	4-Feb-2021	MYSURU	66	DB HALLI-TUBINKERE	DODDABYADARAHALLI_66	12:50	13:21	0:31	LINE CLEAR AVAILED
372	4-Feb-2021	MYSURU	66	HOOTAGALLY-ELWALA	NO STATION EFFECTED	10:05	12:41	2:36	LINE CLEAR AVAILED
373	4-Feb-2021	MYSURU	66	DATAGALLI-HOOTAGALLY	DATTAGALLY_66	10:00	15:54	5:54	LINE CLEAR AVAILED
374	4-Feb-2021	MYSURU	66	DATAGALLI-RK NAGARA	DATTAGALLY_66	10:00	16:00	6:00	LINE CLEAR AVAILED
375	4-Feb-2021	MYSURU	66	HV1	DATTAGALLY_66	10:00	17:28	7:28	LINE CLEAR AVAILED
376	4-Feb-2021	MYSURU	66	HV2	DATTAGALLY_66	10:00	17:28	7:28	LINE CLEAR AVAILED
377	4-Feb-2021	MYSURU	66	HV1	KABHALLY_66	10:28	17:06	6:37	LINE CLEAR AVAILED
378	4-Feb-2021	MYSURU	66	HV1	KIRUGAVALU_66	11:08	12:35	1:27	LINE CLEAR AVAILED
379	4-Feb-2021	MYSURU	66	HV2	KMDODDI_66	9:36	17:07	7:30	LINE CLEAR AVAILED
380	4-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	12:21	14:03	1:42	LINE CLEAR AVAILED
381	4-Feb-2021	MYSURU	66	HV2	PERIYAPATNA_66	10:00	18:04	8:04	LINE CLEAR AVAILED
382	4-Feb-2021	MYSURU	66	HV1	SFCSHIVA_66	16:51	19:32	2:41	LINE CLEAR AVAILED
383	4-Feb-2021	MYSURU	66	BEGUR 220-BEGUR 1	NO STATION EFFECTED	13:00	19:01	6:01	LINE CLEAR AVAILED
384	4-Feb-2021	MYSURU	66	BEGUR 220-BEGUR 2	NO STATION EFFECTED	13:00	19:01	6:01	LINE CLEAR AVAILED
385	4-Feb-2021	MYSURU	66	BEGUR-NANJANGUDU	BEGUR_66	12:15	19:00	6:45	LINE CLEAR AVAILED
386	4-Feb-2021	MYSURU	66	BEGUR-BEGUR 1	BEGUR_66	12:15	19:00	6:45	LINE CLEAR AVAILED
387	4-Feb-2021	MYSURU	66	BEGUR-BEGUR 2	BEGUR_66	12:15	19:00	6:45	LINE CLEAR AVAILED
388	4-Feb-2021	MYSURU	66	BEGUR-B MATAKERE	BEGUR_66	12:15	19:00	6:45	LINE CLEAR AVAILED
389	4-Feb-2021	MYSURU	66	HV1	BEGUR_220	10:40	16:00	5:20	LINE CLEAR AVAILED
390	4-Feb-2021	MYSURU	66	HEBBANI 220 -SFC 3	NO STATION EFFECTED	11:13	13:00	1:47	LINE CLEAR AVAILED
391	4-Feb-2021	MYSURU	66	HEBBANI 220 -SFC 4	NO STATION EFFECTED	11:13	13:00	1:47	LINE CLEAR AVAILED
392	4-Feb-2021	MYSURU	66	HEBBANI 220 -SFC 5	NO STATION EFFECTED	11:13	13:00	1:47	LINE CLEAR AVAILED
393	4-Feb-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	11:27	14:03	2:36	LINE CLEAR AVAILED
394	4-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
395	4-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
396	4-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
397	4-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
398	4-Feb-2021	TUMKUR	66	TR-2	HONNALI_66	20:34:16(03.02.2021)	22:25:36 (04.02.2020)	25:51HRS	TRANSFORMER CHARGED
399	4-Feb-2021	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	8:55	9:04	0:09	TRANSFORMER FAULT
400	4-Feb-2021	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	9:08	9:14	0:05	TRANSFORMER FAULT
401	4-Feb-2021	TUMKUR	110	TR-2	NITTUR_220	14:34	19:50	5:15	LINE CLEAR AVAILED
402	4-Feb-2021	TUMKUR	66	TR-2	AVAREGERE_66	15:48	17:27	1:38	LINE CLEAR AVAILED
403	4-Feb-2021	TUMKUR	66	BENNEHALLI-ITTAGI	BENNEHALLI_66	12:35	19:27	6:52	LINE CLEAR AVAILED
404	4-Feb-2021	TUMKUR	66	TR-2	CHANNAGIRI_66	7:10	9:33	2:23	TRANSFORMER FAULT
405	4-Feb-2021	TUMKUR	66	TR-2	DAVANAGERE_66	12:11	12:27	0:15	LINE CLEAR AVAILED
406	4-Feb-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:56	12:03	0:07	HAND TRIPPED
407	4-Feb-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:56	12:03	0:07	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
408	4-Feb-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:07	18:19	0:11	LINE FAULT
409	4-Feb-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:54	19:09	0:14	LINE FAULT
410	4-Feb-2021	TUMKUR	66	TR-2	GUTTUR_66	6:33	6:42	0:08	TRANSFORMER FAULT
411	4-Feb-2021	TUMKUR	66	TR-2	HANAGAL_66	11:54	12:13	0:18	LINE CLEAR AVAILED
412	4-Feb-2021	TUMKUR	66	HONNALLI 66KV- HONNALLI	HONNALLI_66	13:18	14:24	1:06	LINE FAULT
413	4-Feb-2021	TUMKUR	66	TR-1	HONNALLI_66	13:28	14:26	0:57	TRANSFORMER FAULT
414	4-Feb-2021	TUMKUR	66	TR-2	HONNALLI_66	14:11	14:13	0:02	TRANSFORMER FAULT
415	4-Feb-2021	TUMKUR	66	TR-2	HONNALLI_66	17:29	18:39	1:10	TRANSFORMER FAULT
416	4-Feb-2021	TUMKUR	66	TR-2	HONNALLI_66	22:13	22:25	0:12	TRANSFORMER FAULT
417	4-Feb-2021	TUMKUR	66	TR-3	HONNALLI_66	13:28	14:24	0:56	TRANSFORMER FAULT
418	5-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
419	5-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
420	5-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
421	5-Feb-2021	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:36	17:44	7:08	LINE CLEAR AVAILED
422	5-Feb-2021	BAGALKOT	220	HUBLI-NAGJHARI2	STATION NOT AFFECTED HUBLI_220	12:04	17:06	5:02	LINE CLEAR AVAILED
423	5-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
424	5-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
425	5-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
426	5-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
427	5-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
428	5-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
429	5-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
430	5-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
431	5-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
432	5-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
433	5-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
434	5-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
435	5-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN, LINE CLEAR AVAILED
436	5-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN, LINE CLEAR AVAILED
437	5-Feb-2021	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	11:31 (03.02.2021)	12:40 (05.02.2021)	1:09HRS	TRANSFORMER CHARGED
438	5-Feb-2021	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	17:41 (04.02.2021)	15:05 (05.02.2021)	10:42HRS	LINE CHARGED
439	5-Feb-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
440	5-Feb-2021	BAGALKOT	110	110/11KV,HV1	BILAGI_110	11:26	17:07	5:41	LINE CLEAR AVAILED
441	5-Feb-2021	BAGALKOT	110	BELGAUM-HUDALI	STATION NOT AFFECTED BELGAUM_220	08:33	19:07	10:34	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
442	5-Feb-2021	BAGALKOT	110	110/11KV,HV1	BIJAPUR CITY_110	13:43	16:48	3:05	LINE CLEAR AVAILED
443	5-Feb-2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED HAVERI_220	12:04	12:48	0:44	LINE CLEAR AVAILED
444	5-Feb-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	15:00	16:28	1:28	LINE CLEAR AVAILED
445	5-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN, LINE CLEAR AVAILED
446	5-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN, LINE CLEAR AVAILED
447	5-Feb-2021	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	18:11	18:56	0:45	LINE CLEAR AVAILED
448	5-Feb-2021	BAGALKOT	110	MK HUBLI-HIREBAGEWADI	STATION NOT AFFECTED MK HUBLI_220	14:30	17:40	3:10	LINE FAULT
449	5-Feb-2021	BAGALKOT	110	110/11KV,HV2	ITNAL_110	10:50	14:26	3:36	LINE CLEAR AVAILED
450	5-Feb-2021	BAGALKOT	110	ITNAL-RAIBAG2	ITNAL_110	17:25	17:34	0:09	HAND TRIPPED
451	5-Feb-2021	BAGALKOT	110	110/11KV,HV1	SIRSI_110	17:50	17:51	0:01	LINE CLEAR AVAILED
452	5-Feb-2021	BAGALKOT	110	110/11KV,HV2	SIRSI_110	17:39	20:10	2:31	LINE CLEAR AVAILED
453	5-Feb-2021	BAGALKOT	110	110/11KV,HV2	UTTUR_110	12:21	12:54	0:33	TRANSFORMER FAULT
454	5-Feb-2021	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	7:15	7:24	0:09	LINE CLEAR AVAILED
455	5-Feb-2021	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	7:38	07:41	0:03	LINE CLEAR AVAILED
456	5-Feb-2021	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	16:15 (05.02.2021)			LINE OPEN, LINE CLEAR AVAILED
457	5-Feb-2021	BENGALURU	66	HV1	B G ROAD	11:38	11:40	00:02	LINE CLEAR AVAILED
458	5-Feb-2021	BENGALURU	66	HV2	KADUBISANAHALLI	11:10	11:28	00:18	LINE CLEAR AVAILED
459	5-Feb-2021	BENGALURU	66	HV2	KADUBISANAHALLI	13:08	13:12	00:04	LINE CLEAR AVAILED
460	5-Feb-2021	BENGALURU	66	HV2	KADUBISANAHALLI	18:50	18:56	00:06	LINE CLEAR AVAILED
461	5-Feb-2021	BENGALURU	66	HV2	NIMHANS 66	16:05	16:07	00:02	LINE CLEAR AVAILED
462	5-Feb-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	11:24	11:50	00:26	LINE CLEAR AVAILED
463	5-Feb-2021	BENGALURU	66	V R DODDI - T K HALLI 220	V R DODDI	20:06	20:18	00:12	LOAD CHANGE OVER
464	5-Feb-2021	BENGALURU	66	HV2	CHAKAVELU	02:35	02:45	00:10	TRANSFORMER FAULT
465	5-Feb-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	7:11	7:23	00:12	LINE FAULT
466	5-Feb-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	17:09	17:44	00:35	LINE FAULT
467	5-Feb-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:28	16:00	00:32	LOAD CURTAILMENT
468	5-Feb-2021	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	10:29	10:33	00:04	LOAD CHANGE OVER
469	5-Feb-2021	BENGALURU	66	HV1	MAASTHI	11:18	11:25	00:06	TRANSFORMER FAULT
470	5-Feb-2021	BENGALURU	66	HV2	MAASTHI	7:24	7:45	00:20	TRANSFORMER FAULT
471	5-Feb-2021	BENGALURU	66	HV2	CHAKAVELU	2:35	2:45	00:10	TRANSFORMER FAULT
472	5-Feb-2021	BENGALURU	66	HV2	CHAKAVELU	7:50	8:00	00:10	TRANSFORMER FAULT
473	5-Feb-2021	BENGALURU	66	HV1	DODDABELAVANGALA	18:21	18:33	00:11	TRANSFORMER FAULT
474	5-Feb-2021	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI,BIJAHALLI	20:07:00(04/02/2021)	8:44(05/02/2021)	12:37HRS	LINE CHARGED
475	5-Feb-2021	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	NO STATION AFFECTED	11:20	15:08	03:48	LINE FAULT
476	5-Feb-2021	GULBARGA	220	BMM ISPAT-LINGAPUR	BMM ISPAT_IPP	09:40	13:34	03:54	NFBC ISSUED
477	5-Feb-2021	GULBARGA	220	LINGAPUR-HKT MINNING	HKT MINNING_IPP	09:39	13:34	03:55	LINE CLEAR AVAILED
478	5-Feb-2021	GULBARGA	220	HV1	KUSTAGI_220	16:33	17:58	01:25	LINE CLEAR AVAILED
479	5-Feb-2021	GULBARGA	220	HV2	KUSTAGI_220	17:38	23:55	06:17	TRANSFORMER FAULT
480	5-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADLAPUR_110, KURDICROSS_110	6:50(4.2.2021)	16:18(05.02.2021)	9:28HRS	LINE CHARGED
481	5-Feb-2021	GULBARGA	110	HV2	GINIGERA_110	10:25	12:15	01:50	LINE CLEAR AVAILED
482	5-Feb-2021	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110	06:21	06:31	00:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
483	5-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADLAPUR_110, KURDICROSS_110	19:41	19:51	00:10	LINE FAULT
484	5-Feb-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_110,YERADONA _110,SR NAGAR_110,MADALAPUR_110	01:40	01:50	00:10	LINE FAULT
485	5-Feb-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_110,YERADONA _110,SR NAGAR_110,MADALAPUR_110	05:55	06:05	00:10	LINE FAULT
486	5-Feb-2021	GULBARGA	110	SINDHANOOR-SIRAGUPPA	DHADESUGUR_110,SIRAGUPPA_110,TEKK ALKOTE_110,NSL SUGAR IPP	16:37	16:50	00:13	LINE FAULT
487	5-Feb-2021	GULBARGA	110	SHAHAPUR-WARADSOLAR	WARAD SOLAR_IPP	02:59	05:19	02:20	LINE FAULT
488	5-Feb-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNASIGI_110, UGAR SUGAR_IPP	06:35	06:41	00:06	LINE FAULT
489	5-Feb-2021	GULBARGA	110	SHAHAPUR-SHORAPUR_110	SHORAPUR_110	02:28	02:37	00:09	LINE FAULT
490	5-Feb-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	17:35	18:10	00:35	MAIN SUPPLY FAILURE
491	5-Feb-2021	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110	17:30	18:10	00:40	MAIN SUPPLY FAILURE
492	5-Feb-2021	GULBARGA	110	HV1	KUDITINI_110	17:31	17:36	00:05	TRANSFORMER FAULT
493	5-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
494	5-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
495	5-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
496	5-Feb-2021	HASSAN	220	HASSN22-SHIMOGA	HASSAN_220	11:17	13:40	02:23	NFBC ISSUED
497	5-Feb-2021	HASSAN	220	SHRAVITY-SIRISI2	sharavathy_gen	09:32	11:32	02:00	LINE FAULT
498	5-Feb-2021	HASSAN	110	HV2	ESSUR_110	13:06	13:34	00:28	LINE CLEAR AVAILED
499	5-Feb-2021	HASSAN	110	HV1	GURUPURA_110	10:15	18:07	07:52	LINE CLEAR AVAILED
500	5-Feb-2021	HASSAN	110	HV1	KADUR_220	10:19	12:28	02:09	LINE CLEAR AVAILED
501	5-Feb-2021	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:55	15:10	04:15	MAIN SUPPLY FAILURE
502	5-Feb-2021	HASSAN	110	KADUR	KALLUSADARAHALLY_110	10:55	15:10	04:15	MAIN SUPPLY FAILURE
503	5-Feb-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:04	14:53	00:49	LINE CLEAR AVAILED
504	5-Feb-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	14:04	14:53	00:49	LINE CLEAR AVAILED
505	5-Feb-2021	HASSAN	66	GANGUR-HASSAN	GANGUR_66	15:32	17:28	01:56	MAIN SUPPLY FAILURE
506	5-Feb-2021	HASSAN	66	HV1	GANGUR_66	15:32	17:29	01:57	MAIN SUPPLY FAILURE
507	5-Feb-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	15:03	15:08	00:05	LINE FAULT
508	5-Feb-2021	HASSAN	66	KATTEPURA_MINIH	RAMNATHPURA_66	05:40	05:50	00:10	LINE FAULT
509	5-Feb-2021	HASSAN	66	IDLE	TAVARECHATNAHALLI_66	17:36	18:04	00:28	LINE FAULT
510	5-Feb-2021	MYSURU	66	HV1	SINDHUVALI_66	10:35	15:15	4:39	LINE CLEAR AVAILED
511	5-Feb-2021	MYSURU	66	SUTTUR-DEVNUR(NANJ)	SUTTUR_66	10:00	16:00	5:59	LINE CLEAR AVAILED
512	5-Feb-2021	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATION EFFECTED	11:32	13:31	1:59	LINE CLEAR AVAILED
513	5-Feb-2021	MYSURU	66	HANNUR-GMSH_SLR	NO STATION EFFECTED	6:22	6:33	0:10	LINE FAULT
514	5-Feb-2021	MYSURU	66	HONNALLY-CR NAGARA	HONNALLY_MYS_66 ATTIGULIPURA_66	4:17	4:28	0:11	LINE FAULT
515	5-Feb-2021	MYSURU	66	HV1	MALAVALLI_66	12:27	14:31	2:03	LINE CLEAR AVAILED
516	5-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	12:27	17:46	5:19	LINE CLEAR AVAILED
517	5-Feb-2021	MYSURU	66	HV1	PERIYAPATNA_66	13:50	17:32	3:42	LINE CLEAR AVAILED
518	5-Feb-2021	MYSURU	66	HV2	PERIYAPATNA_66	11:00	13:55	2:54	LINE CLEAR AVAILED
519	5-Feb-2021	MYSURU	66	HV2	PERIYAPATNA_66	17:29	18:10	0:41	LINE CLEAR AVAILED
520	5-Feb-2021	MYSURU	66	AJJIPURA-HANNUR	AJJIPURA_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	8:20	8:35	0:14	LINE FAULT
521	5-Feb-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	10:18	10:24	0:06	TRANSFORMER FAULT
522	5-Feb-2021	MYSURU	66	HV5	SFCSHIVA_66	5:18 (5/02/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
523	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	11:41	11:45	0:03	LINE FAULT
524	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	12:05	12:10	0:05	LINE FAULT
525	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	12:20	12:25	0:05	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
526	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	12:30	14:40	2:10	LINE FAULT
527	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	16:50	16:55	0:05	LINE FAULT
528	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	16:53	17:38	0:45	LINE FAULT
529	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	17:50	17:55	0:05	LINE FAULT
530	5-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	17:56	18:00	0:04	LINE FAULT
531	5-Feb-2021	MYSURU	66	HEBBANI 220-SFC 3	NO STATION EFFECTED	12:17	12:44	0:27	LINE CLEAR AVAILED
532	5-Feb-2021	MYSURU	66	HEBBANI 220-SFC 4	NO STATION EFFECTED	10:32	12:44	2:12	LINE CLEAR AVAILED
533	5-Feb-2021	MYSURU	66	HEBBANI 220-SFC 5	NO STATION EFFECTED	12:33	12:46	0:13	LINE CLEAR AVAILED
534	5-Feb-2021	MYSURU	66	HEBBANI 220-VAJMANGALA	NO STATION EFFECTED	10:33	12:47	2:14	LINE CLEAR AVAILED
535	5-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
536	5-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
537	5-Feb-2021	MYSURU	220	HV1	TUBINAKERE_220	4:05	4:17	0:12	TRANSFORMER FAULT
538	5-Feb-2021	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATION EFFECTED	7:25	18:56	11:30	NFBC ISSUED
539	5-Feb-2021	TUMKUR	110	TR-1	HANDANKERE_110	11:03	11:49	0:45	LINE CLEAR AVAILED
540	5-Feb-2021	TUMKUR	66	DYAVARANAHALLI-CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	18:30	19:40	1:10	LINE FAULT
541	5-Feb-2021	TUMKUR	66	TR-1	HANAGAL_66	11:10	13:15	2:05	LINE CLEAR AVAILED
542	5-Feb-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	20:36	20:43	0:07	LINE FAULT
543	5-Feb-2021	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	8:30	8:33	0:02	LINE CLEAR AVAILED
544	5-Feb-2021	TUMKUR	66	TR-2	BADDIHALLI_66	10:44	11:30	0:46	LINE CLEAR AVAILED
545	5-Feb-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:47	8:56	0:08	LINE FAULT
546	5-Feb-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:23	10:42	0:19	LINE FAULT
547	5-Feb-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:33	20:45	0:12	LINE FAULT
548	5-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
549	5-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
550	6-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
551	6-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
552	6-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
553	6-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
554	6-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
555	6-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
556	6-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
557	6-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
558	6-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
559	6-Feb-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
560	6-Feb-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
561	6-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
562	6-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
563	6-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
564	6-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
565	6-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
566	6-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
567	6-Feb-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
568	6-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
569	6-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
570	6-Feb-2021	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	16:15 (05.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
571	6-Feb-2021	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
572	6-Feb-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA 1	GHATAPRABHA_220	10:01	18:09	8:08	NFBC ISSUED
573	6-Feb-2021	BAGALKOT	110	110/11KV,HV1	BIJAPUR_110	15:42	17:19	1:37	LINE CLEAR AVOIDED
574	6-Feb-2021	BAGALKOT	110	BELGAUM-KANABARGI	KANABARGI_110	08:50	10:14	1:24	LINE CLEAR AVOIDED
575	6-Feb-2021	BAGALKOT	110	HAVERI220-HAVERI	HAVERI_110	11:31	18:09	6:38	LINE CLEAR AVOIDED
576	6-Feb-2021	BAGALKOT	220	MAHALINGAPUR-NARENDRA 1	MAHALINGAPUR_220	14:40(6.2.2021)			LINE OPEN, LINE FAULT
577	6-Feb-2021	BAGALKOT	110	110/11KV,HV1	YELPARHATTI_110	14:50	15:40	0:50	LINE CLEAR AVOIDED
578	6-Feb-2021	BAGALKOT	110	UTTUR- MUDHOL	MUDHOL_110	06:44	06:56	0:12	LINE FAULT
579	6-Feb-2021	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	11:56	16:03	4:07	LINE CLEAR AVOIDED
580	6-Feb-2021	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	15:25	17:52	2:27	LINE CLEAR AVOIDED
581	6-Feb-2021	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	13:10	15:24	2:14	LINE CLEAR AVOIDED
582	6-Feb-2021	BAGALKOT	110	TARIHAL- TADASINKOPPA	STATION NOT AFFECTED TARIHAL_110	10:48	11:07	0:19	HAND TRIPPED
583	6-Feb-2021	BAGALKOT	110	110/11KV, HV3	TIKOTA_110	16:19	17:29	1:10	LINE CLEAR AVOIDED
584	6-Feb-2021	BAGALKOT	220	220/110KV, HV1& LV1	STATION NOT AFFECTED NARENDRA_220	11:38	19:33	7:55	LINE CLEAR AVOIDED
585	6-Feb-2021	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	13:10	15:15	2:05	LINE CLEAR AVOIDED
586	6-Feb-2021	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	10:43	17:22	6:39	LINE CLEAR AVOIDED
587	6-Feb-2021	BAGALKOT	66	66/11KV, HV2	HARIHAR HOSPET_66	14:19	14:27	0:08	LINE CLEAR AVOIDED
588	6-Feb-2021	BENGALURU	66	BRIGADE METROPOLIS - HOODY 220	BRIGADE METROPOLIS	10:30	14:50	4:20	LINE CLEAR AVOIDED
589	6-Feb-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	9:59	10:05	0:06	LOAD CHANGE OVER
590	6-Feb-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	17:57	18:06	0:09	LOAD CHANGE OVER
591	6-Feb-2021	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	8:55	9:00	0:05	LOAD CHANGE OVER
592	6-Feb-2021	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	17:30	17:35	0:05	LOAD CHANGE OVER
593	6-Feb-2021	BENGALURU	66	HOODY 220 - HOSKOTE 66	NO STATION AFFECTED	9:08	9:25	0:17	LINE FAULT
594	6-Feb-2021	BENGALURU	66	HV1	NELAKADRENAHALLI	13:00	13:05	0:05	LINE CLEAR AVOIDED
595	6-Feb-2021	BENGALURU	66	HV2	NELAKADRENAHALLI	14:37	14:45	0:08	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
596	6-Feb-2021	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	11:19	11:24	0:05	LOAD CHANGE OVER
597	6-Feb-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	10:05	10:10	0:05	LOAD CHANGE OVER
598	6-Feb-2021	BENGALURU	66	HV2	VIJAYANAGARA	11:00	11:05	0:05	LINE CLEAR AVOIDED
599	6-Feb-2021	BENGALURU	66	HV1	HOSKOTE 66	9:31	9:41	0:10	TRANSFORMER FAULT
600	6-Feb-2021	BENGALURU	66	KACHMARANAHALLI - DOMMASANDRA	NO STATION AFFECTED	12:06	13:00	0:54	LINE CLEAR AVOIDED
601	6-Feb-2021	BENGALURU	66	DOMMASANDRA - CHANDAPURA	DOMMASANDRA	12:08	13:01	0:52	MAIN SUPPLY FAILURE
602	6-Feb-2021	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	7:14	7:42	0:28	LINE FAULT
603	6-Feb-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:22	13:44	0:22	LINE CLEAR AVOIDED
604	6-Feb-2021	BENGALURU	66	HV1	TEMAGONDALU	11:05	12:30	1:25	TRANSFORMER FAULT
605	6-Feb-2021	BENGALURU	66	HV2	MAASTHI	3:29	3:35	0:06	TRANSFORMER FAULT
606	6-Feb-2021	BENGALURU	66	HV2	JIGANI LINK ROAD	15:45	15:48	0:02	LINE CLEAR AVOIDED
607	6-Feb-2021	BENGALURU	66	HV3	JIGANI LINK ROAD	15:13	15:18	0:05	LINE CLEAR AVOIDED
608	6-Feb-2021	BENGALURU	66	HV1	JIGANI LINK ROAD	17:00	17:30	0:30	LINE CLEAR AVOIDED
609	6-Feb-2021	BENGALURU	66	HV2	GUNDAMGERE	16:57	18:00	1:02	TRANSFORMER FAULT
610	6-Feb-2021	BENGALURU	220	HV2	CHINTAMANI 220	7:14	7:30	0:16	TRANSFORMER FAULT
611	6-Feb-2021	GULBARGA	220	HV2	ALIPUR_220	12:05	12:15	00:10	LINE CLEAR AVOIDED
612	6-Feb-2021	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110	08:35	08:41	00:06	LINE FAULT
613	6-Feb-2021	GULBARGA	110	HV3	KUSHTAGI_110	14:00	14:10	00:10	TRANSFORMER FAULT
614	6-Feb-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:30	13:59	02:29	LINE CLEAR AVOIDED
615	6-Feb-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	12:34	13:52	01:18	LINE CLEAR AVOIDED
616	6-Feb-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	04:45	05:03	00:18	LINE FAULT
617	6-Feb-2021	GULBARGA	110	HV2	GINIGERA_110	16:50	17:15	00:25	LINE CLEAR AVOIDED
618	6-Feb-2021	GULBARGA	110	HV1	MASKI_110	13:15	13:38	00:23	LINE CLEAR AVOIDED
619	6-Feb-2021	GULBARGA	110	HV2	YELBURGA_110	10:02	15:25	05:23	LINE CLEAR AVOIDED
620	6-Feb-2021	GULBARGA	110	HV3	YELBURGA_110	15:40	16:40	01:00	LINE CLEAR AVOIDED
621	6-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	24:00(06.02.2021)			LINE OPEN, LINE FAULT
622	6-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
623	6-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
624	6-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
625	6-Feb-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	18:00(6.2.2021)			LINE OPEN, LINE FAULT
626	6-Feb-2021	HASSAN	220	HV1	MSEZ_220	11:10	14:16	03:06	LINE CLEAR AVOIDED
627	6-Feb-2021	HASSAN	110	HV1	BARANGI_110	11:12	13:23	02:11	LINE CLEAR AVOIDED
628	6-Feb-2021	HASSAN	110	HV2	HOSANGADI_110	11:29	17:08	05:39	LINE CLEAR AVOIDED
629	6-Feb-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:17	13:27	02:10	LINE CLEAR AVOIDED
630	6-Feb-2021	HASSAN	110	HV2	MOODABIDRE_110	09:23	14:11	04:48	LINE CLEAR AVOIDED
631	6-Feb-2021	HASSAN	110	HV5	MRSMG_220	10:36	15:58	05:22	LINE CLEAR AVOIDED
632	6-Feb-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	10:01	16:53	06:52	LINE CLEAR AVOIDED
633	6-Feb-2021	HASSAN	110	HV1	SAGARA_110	11:15	11:45	00:30	LINE CLEAR AVOIDED
634	6-Feb-2021	HASSAN	66	HV4	BALEHONNUR_66	11:32	14:33	03:01	LINE CLEAR AVOIDED
635	6-Feb-2021	HASSAN	66	ANVRPP	KUDLIGERE_66	09:30	18:31	09:01	MAIN SUPPLY FAILURE
636	6-Feb-2021	HASSAN	66	HV1	KUDLIGERE_66	09:38	18:30	08:52	MAIN SUPPLY FAILURE
637	6-Feb-2021	HASSAN	66	SIGEBAGI	KUDLIGERE_66	09:38	18:22	08:44	MAIN SUPPLY FAILURE
638	6-Feb-2021	HASSAN	66	SANIVARSANTE	MALLIPATNA_66	04:06	04:14	00:08	LINE FAULT
639	6-Feb-2021	HASSAN	66	HV1	SIGEBAGE_66	10:03	17:56	07:53	LINE CLEAR AVOIDED
640	6-Feb-2021	HASSAN	66	KDLGRE	SIGEBAGE_66	10:07	18:29	08:22	LINE CLEAR AVOIDED
641	6-Feb-2021	HASSAN	66	HV1	SINGAPURA_66	11:57	13:22	01:25	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
642	6-Feb-2021	HASSAN	66	HV2	SINGAPURA_66	11:19	12:25	01:06	LINE CLEAR AVAILED
643	6-Feb-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	04:06	04:18	00:12	LINE FAULT
644	6-Feb-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:04	10:35	00:31	LINE FAULT
645	6-Feb-2021	MYSURU	66	HV1	AKKIHEBBAL_66	13:04	13:30	0:25	LINE CLEAR AVAILED
646	6-Feb-2021	MYSURU	66	HV1	GAMANAHALLY_66	12:15	14:16	2:01	LINE CLEAR AVAILED
647	6-Feb-2021	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATION EFFECTED	7:10	18:26	11:16	LINE CLEAR AVAILED
648	6-Feb-2021	MYSURU	66	HV2	GAMANAHALLY_66	11:00	14:15	3:15	LINE CLEAR AVAILED
649	6-Feb-2021	MYSURU	66	HV1	KIRUGAVALU_66	9:36	16:52	7:15	LINE CLEAR AVAILED
650	6-Feb-2021	MYSURU	66	HV2	KIRUGAVALU_66	16:52	17:11	0:18	LINE CLEAR AVAILED
651	6-Feb-2021	MYSURU	66	KR PETE 220-BOOKANAKERE	BANANGADI_66 BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66	11:17	11:31	0:14	LINE FAULT
652	6-Feb-2021	MYSURU	66	HV1	PERIYAPATNA_66	11:12	17:38	6:26	LINE CLEAR AVAILED
653	6-Feb-2021	MYSURU	66	HV1	SANTHEMARAHALLI_66	12:50	14:15	1:25	LINE CLEAR AVAILED
654	6-Feb-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	14:16	19:11	4:55	LINE CLEAR AVAILED
655	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	6:54	7:25	0:30	LINE FAULT
656	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	16:47	16:54	0:07	HAND TRIPPED
657	6-Feb-2021	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	6:54	7:08	0:13	LINE FAULT
658	6-Feb-2021	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	11:58	13:44	1:46	LINE FAULT
659	6-Feb-2021	MYSURU	66	SFC SIVA-PPCL	NO STATION EFFECTED	12:45	14:10	1:25	LINE CLEAR AVAILED
660	6-Feb-2021	MYSURU	66	SFC SIVA-5 MW	NO STATION EFFECTED	12:00	12:06	0:06	LINE FAULT
661	6-Feb-2021	MYSURU	66	SFC SIVA-10 MW	NO STATION EFFECTED	12:00	12:05	0:05	LINE FAULT
662	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN, LINE CLEAR AVAILED
663	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	16:42	16:46	0:04	HAND TRIPPED
664	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	14:24	14:28	0:04	HAND TRIPPED
665	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	14:31	14:33	0:01	HAND TRIPPED
666	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	16:39	16:41	0:02	HAND TRIPPED
667	6-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 7	NO STATION EFFECTED	16:55	16:58	0:02	HAND TRIPPED
668	6-Feb-2021	MYSURU	66	HV2	SUTTUR	8:35	9:29	0:54	LINE CLEAR AVAILED
669	6-Feb-2021	MYSURU	66	HV2	TUBINAKERE	13:48	15:55	2:06	LINE CLEAR AVAILED
670	6-Feb-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	5:06	5:16	0:09	LINE FAULT
671	6-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
672	6-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
673	6-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
674	6-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
675	6-Feb-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:01	14:43	3:41	LINE CLEAR AVAILED
676	6-Feb-2021	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAK_220	11:04	14:23	3:19	LINE CLEAR AVAILED
677	6-Feb-2021	TUMKUR	110	TR-1	TURUVEKERE_110	0:05	0:21	0:15	TRANSFORMER FAULT
678	6-Feb-2021	TUMKUR	110	TR-2	HULIYAR_110	10:20	10:22	0:01	HAND TRIPPED
679	6-Feb-2021	TUMKUR	110	TR-1	SHETYKERE_110	14:39	16:40	2:00	LINE CLEAR AVAILED
680	6-Feb-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:21	13:53	0:31	MAIN SUPPLY FAILURE
681	6-Feb-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	13:22	13:52	0:30	MAIN SUPPLY FAILURE
682	6-Feb-2021	TUMKUR	66	TR-1	HDPURA_66	8:08	8:11	0:03	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
683	6-Feb-2021	TUMKUR	66	TR-2	HONNUDIKE_66	12:49	18:09	5:19	LINE CLEAR AVAILED
684	6-Feb-2021	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	3:50	3:54	0:04	LINE FAULT
685	6-Feb-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	11:26	13:11	1:45	MAIN SUPPLY FAILURE
686	6-Feb-2021	TUMKUR	66	TR-1	KUKKAWADA_66	11:11	13:13	2:02	MAIN SUPPLY FAILURE
687	6-Feb-2021	TUMKUR	66	TR-2	KUKKAWADA_66	11:11	13:14	2:03	MAIN SUPPLY FAILURE
688	6-Feb-2021	TUMKUR	66	TR-1	LINGDHALLI_66(SHIMOGA)	9:47	11:45	1:58	LINE CLEAR AVAILED
689	6-Feb-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	7:20	7:31	0:11	HAND TRIPPED
690	6-Feb-2021	TUMKUR	66	TR-2	RAMPURA_66	14:08	14:45	0:36	TRANSFORMER FAULT
691	6-Feb-2021	TUMKUR	66	TR-2	RAMPURA_66	12:46	12:57	0:11	TRANSFORMER FAULT
692	6-Feb-2021	TUMKUR	66	TR-1	SOKKE_66	10:02	15:53	5:50	LINE CLEAR AVAILED
693	6-Feb-2021	TUMKUR	66	TR-1	UCHCHANGIDURGA_66	16:13	17:56	1:43	LINE CLEAR AVAILED
694	6-Feb-2021	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	13:19	13:47	0:28	LINE FAULT
695	6-Feb-2021	TUMKUR	66	THALLAK 220kV -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:19	13:47	0:28	LINE FAULT
696	6-Feb-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	13:32	13:44	0:12	HAND TRIPPED
697	6-Feb-2021	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	13:19	13:46	0:27	LINE FAULT
698	6-Feb-2021	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	13:19	13:35	0:16	TRANSFORMER FAULT
699	6-Feb-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	13:22	13:51	0:29	LINE FAULT
700	6-Feb-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:19	13:56	0:37	LINE FAULT
701	6-Feb-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:02	14:20	3:18	LINE CLEAR AVAILED
702	6-Feb-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:02	13:08	2:06	LINE CLEAR AVAILED
703	6-Feb-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	13:19	13:56	0:37	LINE FAULT
704	7-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
705	7-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
706	7-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
707	7-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
708	7-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)	13:20 (7.2.2021)	15:07HRS	LINE CHARGED
709	7-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
710	7-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
711	7-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
712	7-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
713	7-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)	9:27 (7.01.2021)	42:03HRS	LINE CHARGED
714	7-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)	9:27 (7.01.2021)	42:02HRS	LINE CHARGED
715	7-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
716	7-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
717	7-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
718	7-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
719	7-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
720	7-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
721	7-Feb-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
722	7-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
723	7-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
724	7-Feb-2021	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	16:15 (05.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
725	7-Feb-2021	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
726	7-Feb-2021	BAGALKOT	220	MAHALINGAPUR-NARENDRA 1	MAHALINGAPUR_220	14:40 (6.2.2021)	00:31 (7.2.2021)	9:51HRS	LINE CHARGED
727	7-Feb-2021	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	10:04	18:13	8:09	LINE CLEAR AVOIDED
728	7-Feb-2021	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	23:17 (07.02.2021)			LINE OPEN, LINE FAULT
729	7-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
730	7-Feb-2021	BAGALKOT	110	110/33KV,HV1	BAILHONGAL_110	10:10	17:47	7:37	LINE CLEAR AVOIDED
731	7-Feb-2021	BAGALKOT	110	110/11KV,HV3	BAILHONGAL_110	10:10	17:47	7:37	LINE CLEAR AVOIDED
732	7-Feb-2021	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	10:10	16:34	6:24	LINE CLEAR AVOIDED
733	7-Feb-2021	BAGALKOT	220	BIDNAL-NRNRD	STATION NOT AFFECTED BIDNAL_220	10:17	18:03	7:46	LINE CLEAR AVOIDED
734	7-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	02:25	02:44	0:19	LINE FAULT
735	7-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	03:33	05:44	2:11	LINE FAULT
736	7-Feb-2021	BAGALKOT	110	110/11KV,HV1	BIJAPUR_110	11:46	12:17	0:31	HAND TRIPPED
737	7-Feb-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKKODI_110	11:48	18:23	6:35	LINE CLEAR AVOIDED
738	7-Feb-2021	BAGALKOT	110	CHIKKODI-WIND MILL	CHIKKKODI_110	10:55	18:40	7:45	LINE CLEAR AVOIDED
739	7-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM	HUDLI_110 (NO STATION AFFECTED)	19:36 (7.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
740	7-Feb-2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	9:10	9:13	0:03	TRANSFORMER FAULT
741	7-Feb-2021	BAGALKOT	110	110/11KV,HV4	KULIGOD_110	14:46	18:49	4:03	TRANSFORMER FAULT
742	7-Feb-2021	BAGALKOT	110	MALAGHAN-BASAVA SUGARS	MALAGHAN(B)_110 (STATION NOT AFFECTED)	5:40	6:15	0:35	LINE FAULT
743	7-Feb-2021	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:01	18:08	8:07	LINE CLEAR AVOIDED
744	7-Feb-2021	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:02	18:08	8:06	LINE CLEAR AVOIDED
745	7-Feb-2021	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	18:16 (07.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
746	7-Feb-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:04	18:13	8:09	LINE CLEAR AVOIDED
747	7-Feb-2021	BAGALKOT	220	220/110KV, HV1& LV1	STATION NOT AFFECTED NARENDRA_220	9:53	18:22	8:29	LINE CLEAR AVOIDED
748	7-Feb-2021	BAGALKOT	220	220/110KV, HV2& LV2	STATION NOT AFFECTED NARENDRA_220	9:53	18:22	8:29	LINE CLEAR AVOIDED
749	7-Feb-2021	BAGALKOT	220	NARENDRA- BELGAUM1 (KANABARGI1)	STATION NOT AFFECTED NARENDRA_220	10:07	18:18	8:11	LINE CLEAR AVOIDED
750	7-Feb-2021	BAGALKOT	110	110/33KV, HV3	MUNAVALLI_110	13:21	14:35	1:14	LINE CLEAR AVOIDED
751	7-Feb-2021	BAGALKOT	110	NARENDRA1&2- MRUTHYUNJAY NAGAR	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	9:29	18:57	9:28	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
752	7-Feb-2021	BAGALKOT	110	MKHUBLI220- BAILHONGAL	BAILHONGAL_110	10:05	16:29	6:24	LINE CLEAR AVAILED
753	7-Feb-2021	BAGALKOT	110	MKHUBLI220- HIREBAGE WADI	STATION NOT AFFECTED HIREBAGEWADU_110	16:30	17:48	1:18	LINE CLEAR AVAILED
754	7-Feb-2021	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	21:53 (07.02.2021)			LINE OPEN, LINE CLEAR AVAILED
755	7-Feb-2021	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-1 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-1	10:35	10:48	0:13	LOAD CHANGE OVER
756	7-Feb-2021	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPURA 220	ELECTRONIC CITY P2 S2, BIOCON(EHT)	10:45	11:05	0:20	LOAD CHANGE OVER
757	7-Feb-2021	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - HSR LAYOUT 220	ELECTRONIC CITY P2 S2, BIOCON(EHT)	18:45	19:01	0:16	LOAD CHANGE OVER
758	7-Feb-2021	BENGALURU	66	HAL 220 - ADUGODI 2	AMARJYOTHI	11:05	11:40	0:35	LINE FAULT
759	7-Feb-2021	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	9:09	9:20	0:11	LINE FAULT
760	7-Feb-2021	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	13:00	13:10	0:10	LOAD CHANGE OVER
761	7-Feb-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	14:02	14:10	0:08	LOAD CHANGE OVER
762	7-Feb-2021	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	19:51	19:56	0:05	LINE FAULT
763	7-Feb-2021	BENGALURU	66	HV1	NAGANATHPURA 220	19:51	19:56	0:05	TRANSFORMER FAULT
764	7-Feb-2021	BENGALURU	220	HV1	NAGANATHPURA 220	18:48	19:00	0:12	LOAD CHANGE OVER
765	7-Feb-2021	BENGALURU	220	HV2	NAGANATHPURA 220	18:48	19:00	0:12	LOAD CHANGE OVER
766	7-Feb-2021	BENGALURU	220	HV3	NAGANATHPURA 220	18:48	19:00	0:12	LOAD CHANGE OVER
767	7-Feb-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	14:20	17:05	2:45	LINE CLEAR AVAILED
768	7-Feb-2021	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	6:35	6:40	0:05	LOAD CHANGE OVER
769	7-Feb-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	9:09	9:20	0:11	MAIN SUPPLY FAILURE
770	7-Feb-2021	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	11:20	11:23	0:03	LOAD CHANGE OVER
771	7-Feb-2021	BENGALURU	66	HV1	VIJAYANAGARA	9:28	9:32	0:04	LINE CLEAR AVAILED
772	7-Feb-2021	BENGALURU	66	HV2	AMARJYOTHI	11:05	11:35	0:30	TRANSFORMER FAULT
773	7-Feb-2021	BENGALURU	66	HV1	KIADB DB PURA 220	10:02	14:20	4:17	LINE CLEAR AVAILED
774	7-Feb-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 20	HOSKOTE 6	8:00	8:05	0:05	LOAD CHANGE OVER
775	7-Feb-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	9:55	17:46	7:51	LINE CLEAR AVAILED
776	7-Feb-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:55	17:50	7:54	LINE CLEAR AVAILED
777	7-Feb-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:05	11:28	0:23	LINE CLEAR AVAILED
778	7-Feb-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:55	17:48	7:52	LINE CLEAR AVAILED
779	7-Feb-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	10:00	17:44	7:44	LINE CLEAR AVAILED
780	7-Feb-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:05	11:30	0:25	LINE CLEAR AVAILED
781	7-Feb-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:26	11:45	0:18	LINE CLEAR AVAILED
782	7-Feb-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	7:31	7:39	0:08	LINE FAULT
783	7-Feb-2021	BENGALURU	66	HV1	KONDASPURA	17:08	18:01	0:52	LINE CLEAR AVAILED
784	7-Feb-2021	BENGALURU	66	HV1	HUKUNDA	8:21	8:50	0:28	TRANSFORMER FAULT
785	7-Feb-2021	BENGALURU	66	HV2	CHAKAVELU	12:48	12:52	0:04	TRANSFORMER FAULT
786	7-Feb-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURUDICRO SS_110	10:30(7.2.21)			LINE OPEN, LINE CLEAR AVAILED
787	7-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	24:00(06.02.2021)	00:05(07.02.2021)	00:05HRS	LINE CHARGED
788	7-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	03:40	03:50	00:10	LINE FAULT
789	7-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	04:30	04:35	00:05	LINE FAULT
790	7-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	05:50	06:22	00:32	LINE FAULT
791	7-Feb-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	00:12	00:14	00:02	LINE FAULT
792	7-Feb-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	02:26	06:47	04:21	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
793	7-Feb-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	11:20	11:30	00:10	LINE FAULT
794	7-Feb-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	06:25	06:35	00:10	LINE FAULT
795	7-Feb-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	02:02	02:22	00:20	LINE FAULT
796	7-Feb-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	02:50	03:10	00:20	LINE FAULT
797	7-Feb-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	04:52	04:59	00:07	LINE FAULT
798	7-Feb-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	06:24	06:34	00:10	LINE FAULT
799	7-Feb-2021	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	20:47	20:56	00:09	LINE FAULT
800	7-Feb-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGUR_110,TEKK ALKOTE_110,NSLSUGAR IPP	03:05	03:15	00:10	LINE FAULT
801	7-Feb-2021	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	05:14	05:24	00:10	LINE FAULT
802	7-Feb-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGUR_110,TEKK ALKOTE_110,NSLSUGAR IPP	06:06	06:19	00:13	LINE FAULT
803	7-Feb-2021	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110	13:38	13:50	00:12	LINE FAULT
804	7-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
805	7-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
806	7-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
807	7-Feb-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	18:00(6.2.2021)	7:07(7.2.2021)	13:06 hrs	LINE CHARGED
808	7-Feb-2021	HASSAN	220	HV3	KAVOOR_220	09:51	12:19	02:28	LINE CLEAR AVAILED
809	7-Feb-2021	HASSAN	110	MSEZ-GSS32	MSEZ_220	18:09	18:52	00:43	LINE CLEAR AVAILED
810	7-Feb-2021	HASSAN	110	HV1	HALADY_110	08:14	08:16	00:02	HAND TRIPPED
811	7-Feb-2021	HASSAN	110	HV1	HALADY_110	09:19	18:57	09:38	LINE CLEAR AVAILED
812	7-Feb-2021	HASSAN	110	HV2	ANANDAPURA_110	16:10	16:30	00:20	TRANSFORMER FAULT
813	7-Feb-2021	HASSAN	66	HV1	HANGRANAHALLY_66	09:46	09:55	00:09	TRANSFORMER FAULT
814	7-Feb-2021	HASSAN	66	HV1	HOLALUR_66	10:47	17:42	06:55	LINE CLEAR AVAILED
815	7-Feb-2021	HASSAN	66	HV2	HOLALUR_66	10:47	17:42	06:55	LINE CLEAR AVAILED
816	7-Feb-2021	HASSAN	66	HV2	UDAYAPURA_66	09:02	09:09	00:07	TRANSFORMER FAULT
817	7-Feb-2021	MYSURU	66	HV2	BILIKERE_66	11:36	11:47	0:11	TRANSFORMER FAULT
818	7-Feb-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	10:00	10:09	0:09	TRANSFORMER FAULT
819	7-Feb-2021	MYSURU	66	MADHUVANAHALLY-HEBBANI	NO STATION EFFECTED	6:00	6:07	0:07	LINE FAULT
820	7-Feb-2021	MYSURU	66	MADHUVANAHALLY-HEBBANI	NO STATION EFFECTED	18:27	18:38	0:10	LINE FAULT
821	7-Feb-2021	MYSURU	66	HV1	MANDGERE_66	10:25	11:11	0:46	LINE CLEAR AVAILED
822	7-Feb-2021	MYSURU	66	HV2	METAGALLY_66	9:45	20:09	10:24	LINE CLEAR AVAILED
823	7-Feb-2021	MYSURU	66	HV1	SANTHEMARAHALLI_66	14:15	14:20	0:05	HAND TRIPPED
824	7-Feb-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	14:10	14:46	0:36	LINE CLEAR AVAILED
825	7-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN, LINE CLEAR AVAILED
826	7-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
827	7-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
828	7-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
829	7-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
830	7-Feb-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	8:22	8:47	0:25	TRANSFORMER FAULT
831	7-Feb-2021	TUMKUR	110	TR-2	SHETKERE_110	22:07	22:55	0:48	LINE CLEAR AVAILED
832	7-Feb-2021	TUMKUR	66	TR-1	LINGDHALLI_66(SHYLAPURA)	16:54	16:56	0:01	TRANSFORMER FAULT
833	7-Feb-2021	TUMKUR	66	NEELAGUNDA220kv- HARPANAHALLI-1	HARAPPANAHALLI_66	8:25	11:21	2:56	LINE CLEAR AVAILED
834	7-Feb-2021	TUMKUR	66	TR-2	PRPURA_66	11:01	11:13	0:12	TRANSFORMER FAULT
835	7-Feb-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	3:18	3:30	0:12	LINE FAULT
836	7-Feb-2021	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	15:21	19:45	4:23	LINE CLEAR AVAILED
837	7-Feb-2021	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	3:18	21:26	18:07	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
838	7-Feb-2021	TUMKUR	66	TR-2	RAMPURA_66	11:01	11:13	0:12	TRANSFORMER FAULT
839	7-Feb-2021	TUMKUR	66	TR-1	THOVINAKERE_66	22:05	22:31	0:26	TRANSFORMER FAULT
840	8-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
841	8-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
842	8-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
843	8-Feb-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
844	8-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
845	8-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
846	8-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
847	8-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
848	8-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
849	8-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
850	8-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
851	8-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
852	8-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN, LINE CLEAR AVAILED
853	8-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN, LINE CLEAR AVAILED
854	8-Feb-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
855	8-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN, LINE CLEAR AVAILED
856	8-Feb-2021	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN, LINE CLEAR AVAILED
857	8-Feb-2021	BAGALKOT	110	ITNAL-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	16:15 (05.02.2021)	11:00 (08.02.2021)	18:45HRS	LINE CHARGED
858	8-Feb-2021	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN, LINE CLEAR AVAILED
859	8-Feb-2021	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	23:17 (07.02.2021)	16:47(8.2.2021)	17:30HRS	LINE CHARGED
860	8-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVAILED
861	8-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM	HUDLI_110(NO STATION AFFECTED)	19:36 (7.2.2021)	13:00 (08.02.2021)	17:24HRS	LINE CHARGED
862	8-Feb-2021	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	18:16 (07.02.2021)	16:26 (08.02.2021)	22:10HRS	LINE CHARGED
863	8-Feb-2021	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	21:53 (07.02.2021)	16:25 (08.02.2021)	18:32HRS	LINE CHARGED
864	8-Feb-2021	BAGALKOT	110	BAGALKOT-NAVANAGAR(B)1&2	NAVANAGAR(B)_110	14:51	14:55	0:04	HAND TRIPPED
865	8-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	04:52	05:17	0:25	LINE FAULT
866	8-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	04:52	05:17	0:25	LINE FAULT
867	8-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 2	MAMADAPUR_110	04:52	05:17	0:25	LINE FAULT
868	8-Feb-2021	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	04:01	04:16	0:15	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
869	8-Feb-2021	BAGALKOT	220	BIDNAL-HARTI	BIDNAL_220	16:12	17:00	0:48	HAND TRIPPED
870	8-Feb-2021	BAGALKOT	110	110/11KV,HV-1	HALIAYAL_110	10:37	12:55	2:18	LINE CLEAR AVAILED
871	8-Feb-2021	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	GHATAPRABHA_110	13:12	15:22	2:10	LINE CLEAR AVAILED
872	8-Feb-2021	BAGALKOT	110	HIDIKAL DAM-GHATAPRABHA	HIDIKAL DAM_110	12:59	15:32	2:33	LINE CLEAR AVAILED
873	8-Feb-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI1	STATION NOT AFFECTED SOUDATTI_110	11:17	17:09	5:52	LINE CLEAR AVAILED
874	8-Feb-2021	BAGALKOT	110	SOUDATTI220- RAMDURGA1	STATION NOT AFFECTED RAMDURGA_110	11:43	14:45	3:02	LINE CLEAR AVAILED
875	8-Feb-2021	BAGALKOT	110	SIRSI- JOG2(JOG)	SIRSI_110	02:09	13:38	11:29	LINE FAULT
876	8-Feb-2021	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	SIDDAPUR_110	11:50	13:38	1:48	LINE CLEAR AVAILED
877	8-Feb-2021	BAGALKOT	110	SIRSI- JOG2(JOG)	SIRSI_110	14:53	15:01	0:08	HAND TRIPPED
878	8-Feb-2021	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	SIDDAPUR_110	14:55	15:01	0:06	HAND TRIPPED
879	8-Feb-2021	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	8:18 (08.02.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
880	8-Feb-2021	BAGALKOT	110	RAIBAG- CHIKKODI2	STATION NOT AFFECTED RAIBAG_110	5:37	5:50	0:13	LINE FAULT
881	8-Feb-2021	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:27	9:41	0:14	HAND TRIPPED
882	8-Feb-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	11:37	16:48	5:11	LINE CLEAR AVAILED
883	8-Feb-2021	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED NARENDRA_220	15:33	17:56	2:23	LINE CLEAR AVAILED
884	8-Feb-2021	BAGALKOT	110	110/11KV, HV2	MALGHAN(S)_110	17:45	18:08	0:23	LINE CLEAR AVAILED
885	8-Feb-2021	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	13:39	13:46	0:07	TRANSFORMER FAULT
886	8-Feb-2021	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	16:07	16:13	0:06	TRANSFORMER FAULT
887	8-Feb-2021	BAGALKOT	220	GUTTUR2- HAVERI	STATION NOT AFFECTED HAVERI_220	10:38	17:58	7:20	LINE CLEAR AVAILED
888	8-Feb-2021	BENGALURU	66	HV3	ADUGODI	11:21	15:20	03:59	LINE CLEAR AVAILED
889	8-Feb-2021	BENGALURU	66	HV2	BMTC	11:05	15:58	04:53	LINE CLEAR AVAILED
890	8-Feb-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	17:17	17:23	00:06	LOAD CHANGE OVER
891	8-Feb-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	18:40	18:49	00:09	LOAD CHANGE OVER
892	8-Feb-2021	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-1 - ELECTRONIC CITY	ELECTRONIC CITY PH-2 SEC-1	06:54	07:04	00:10	LOAD CHANGE OVER
893	8-Feb-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	11:50	12:06	00:16	MAIN SUPPLY FAILURE
894	8-Feb-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	12:37	12:40	00:03	LOAD CHANGE OVER
895	8-Feb-2021	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	HENNUR CROSS	11:50	12:06	00:16	LINE FAULT
896	8-Feb-2021	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	11:45	12:45	01:00	LINE CLEAR AVAILED
897	8-Feb-2021	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	15:03	16:01	00:58	LINE CLEAR AVAILED
898	8-Feb-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBEL	05:26	05:47	00:21	LINE FAULT
899	8-Feb-2021	BENGALURU	66	HV2	MATHIKERE	13:18	13:20	00:02	LINE CLEAR AVAILED
900	8-Feb-2021	BENGALURU	66	HV2	MATHIKERE	14:34	14:45	00:11	LOAD CHANGE OVER
901	8-Feb-2021	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	09:27	09:35	00:08	LINE FAULT
902	8-Feb-2021	BENGALURU	66	T K HALLI 220 - BWSSB 2	BWSSB 2	23:00	23:32	00:32	LINE FAULT
903	8-Feb-2021	BENGALURU	66	HV1	VIJAYANAGARA	09:27	09:35	00:08	MAIN SUPPLY FAILURE
904	8-Feb-2021	BENGALURU	66	HV1	VIJAYANAGARA	14:41	14:44	00:03	LOAD CHANGE OVER
905	8-Feb-2021	BENGALURU	220	HV2	YARANDANAHALLI 220	16:48	17:30	00:42	TRANSFORMER FAULT
906	8-Feb-2021	BENGALURU	220	HV3	YARANDANAHALLI 220	16:48	18:30	01:42	TRANSFORMER FAULT
907	8-Feb-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	16:48	17:30	00:42	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
908	8-Feb-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	16:48	17:30	00:42	LINE CLEAR AVAILED
909	8-Feb-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	16:48	17:30	00:42	LINE CLEAR AVAILED
910	8-Feb-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	16:48	17:24	00:36	LINE CLEAR AVAILED
911	8-Feb-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	16:48	17:24	00:36	LINE CLEAR AVAILED
912	8-Feb-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	18:41	18:46	00:05	LOAD CHANGE OVER
913	8-Feb-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	18:41	18:46	00:05	LOAD CHANGE OVER
914	8-Feb-2021	BENGALURU	66	HV2	GUNDAMGERE	13:39	13:40	00:01	LINE CLEAR AVAILED
915	8-Feb-2021	BENGALURU	66	HV1	HOSKOTE 66	11:35	11:40	00:05	LINE CLEAR AVAILED
916	8-Feb-2021	BENGALURU	66	HV2	HOSKOTE 66	13:15	13:20	00:05	LINE CLEAR AVAILED
917	8-Feb-2021	BENGALURU	66	HV3	HOSKOTE 66	14:00	15:05	01:05	LINE CLEAR AVAILED
918	8-Feb-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	06:44	07:15	00:31	LINE FAULT
919	8-Feb-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	09:47	10:37	00:50	LINE FAULT
920	8-Feb-2021	BENGALURU	66	HV1	HOSUR RAMAPURA	11:25	11:35	00:10	LINE CLEAR AVAILED
921	8-Feb-2021	BENGALURU	66	HV1	KONDASPURA	12:20	14:40	02:20	LINE CLEAR AVAILED
922	8-Feb-2021	BENGALURU	66	HV1	KONDASPURA	16:20	17:55	01:35	LINE CLEAR AVAILED
923	8-Feb-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	05:51	05:56	00:05	LINE FAULT
924	8-Feb-2021	BENGALURU	66	HV1	MITTEMARI	17:51	17:57	0:06	TRANSFORMER FAULT
925	8-Feb-2021	BENGALURU	66	HV1	MITTEMARI	18:02	18:18	00:16	TRANSFORMER FAULT
926	8-Feb-2021	BENGALURU	66	HV1	RANGANADODDI	15:20	16:48	01:28	LINE CLEAR AVAILED
927	8-Feb-2021	BENGALURU	66	HV2	SARJAPURA 220	06:55	07:10	00:15	TRANSFORMER FAULT
928	8-Feb-2021	BENGALURU	66	HV2	SARJAPURA 220	09:27	09:39	00:12	TRANSFORMER FAULT
929	8-Feb-2021	GULBARGA	440	GUTTUR-KAIGA2	GUTTUR_440	13:28(8.02.21)			LINE OPEN, LINE CLEAR AVAILED
930	8-Feb-2021	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	9:45(8.2.21)			LINE OPEN, LINE CLEAR AVAILED
931	8-Feb-2021	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	11:59	14:08	02:09	LINE FAULT
932	8-Feb-2021	GULBARGA	220	HV1	KUSTAGI_220	06:05	06:20	00:15	TRANSFORMER FAULT
933	8-Feb-2021	GULBARGA	220	HV2	KUSTAGI_220	06:05	06:24	00:19	TRANSFORMER FAULT
934	8-Feb-2021	GULBARGA	220	HV2	KUSTAGI_220	16:06	18:40	02:34	LINE CLEAR AVAILED
935	8-Feb-2021	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	13:03	13:28	00:25	LINE FAULT
936	8-Feb-2021	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	16:02	16:03	00:01	LINE FAULT
937	8-Feb-2021	GULBARGA	110	HV3	KEREHALI_110	09:42	09:52	00:10	TRANSFORMER FAULT
938	8-Feb-2021	GULBARGA	110	HV3	KEREHALI_110	09:57	10:12	00:15	TRANSFORMER FAULT
939	8-Feb-2021	GULBARGA	110	HV3	KEREHALI_110	10:40	10:50	00:10	TRANSFORMER FAULT
940	8-Feb-2021	GULBARGA	110	HV1	JEWARGI_110	16:40	18:15	01:35	LINE CLEAR AVAILED
941	8-Feb-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	19:13	19:15	00:02	LINE FAULT
942	8-Feb-2021	GULBARGA	110	MUNIRABAD-STARMETALIC	STARMETALIC_IPP	13:04	13:44	00:40	LINE FAULT
943	8-Feb-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR,GANGAVATHI_110,VENKATAGIRI_110	10:15	13:30	03:15	NFBC ISSUED
944	8-Feb-2021	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HITREGONNAGAR_110,HANUMANAL_110	06:05	15:56	09:51	LINE FAULT
945	8-Feb-2021	GULBARGA	110	KUSTAGI-KANAKAGIRI	KUSTAGI_220	16:15	16:50	00:35	LINE FAULT
946	8-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
947	8-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
948	8-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
949	8-Feb-2021	HASSAN	220	HV1	MSEZ_220	09:41	17:52	08:11	LINE CLEAR AVAILED
950	8-Feb-2021	HASSAN	110	LV1	MSEZ_220	09:41	17:52	08:11	LINE CLEAR AVAILED
951	8-Feb-2021	HASSAN	110	HV1	HALADY_110	11:20	11:25	00:05	TRANSFORMER FAULT
952	8-Feb-2021	HASSAN	110	HV2	HALADY_110	09:00	18:55	09:55	LINE CLEAR AVAILED
953	8-Feb-2021	HASSAN	110	HV1	HIRENALLUR_110	12:20	13:15	00:55	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
954	8-Feb-2021	HASSAN	110	HV2	KADUR_220	17:35	18:05	00:30	TRANSFORMER FAULT
955	8-Feb-2021	HASSAN	110	HV1	KALLUSADARAHALLY_110	18:50	21:15	02:25	LINE CLEAR AVAILED
956	8-Feb-2021	HASSAN	66	HV2	RAMESHWARNAGAR_66	16:10	16:35	00:25	LINE CLEAR AVAILED
957	8-Feb-2021	HASSAN	66	HV1	MALLAPURA_66	12:40	15:30	02:50	LINE CLEAR AVAILED
958	8-Feb-2021	HASSAN	66	HV2	MALLAPURA_66	12:40	15:30	02:50	LINE CLEAR AVAILED
959	8-Feb-2021	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	12:40	15:30	02:50	LINE CLEAR AVAILED
960	8-Feb-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	18:06	18:11	00:05	HAND TRIPPED
961	8-Feb-2021	MYSURU	66	HV2	BILIKERE_66	9:43	9:56	0:12	TRANSFORMER FAULT
962	8-Feb-2021	MYSURU	66	HV2	BILIKERE_66	10:26	11:59	1:33	TRANSFORMER FAULT
963	8-Feb-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	7:52	8:02	0:09	TRANSFORMER FAULT
964	8-Feb-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	8:04	8:17	0:12	TRANSFORMER FAULT
965	8-Feb-2021	MYSURU	66	HV1	GAMANAHALLY_66	9:59	16:12	6:13	LINE CLEAR AVAILED
966	8-Feb-2021	MYSURU	66	HV1	HAMPAPURA_66	10:36	10:49	0:13	LINE CLEAR AVAILED
967	8-Feb-2021	MYSURU	66	HV1	HAMPAPURA_66	10:46	11:16	0:30	LINE CLEAR AVAILED
968	8-Feb-2021	MYSURU	66	HV1	HAMPAPURA_66	16:53	17:01	0:08	TRANSFORMER FAULT
969	8-Feb-2021	MYSURU	66	HV2	HAMPAPURA_66	16:53	17:01	0:08	TRANSFORMER FAULT
970	8-Feb-2021	MYSURU	66	HV1	HAMPAPURA_66	17:02	17:05	0:02	TRANSFORMER FAULT
971	8-Feb-2021	MYSURU	66	HV2	HAMPAPURA_66	17:02	17:05	0:03	TRANSFORMER FAULT
972	8-Feb-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	10:31	17:55	7:24	NFBC ISSUED
973	8-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	11:08	13:37	2:28	LINE CLEAR AVAILED
974	8-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	14:34	17:43	3:09	LINE CLEAR AVAILED
975	8-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	17:54	17:57	0:03	TRANSFORMER FAULT
976	8-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	18:02	18:15	0:12	LINE CLEAR AVAILED
977	8-Feb-2021	MYSURU	66	HV1	MYSORESOUTH_66	10:12	19:49	9:36	LINE CLEAR AVAILED
978	8-Feb-2021	MYSURU	66	HV1	SANIVARASANTHE_66	7:17	7:35	0:17	TRANSFORMER FAULT
979	8-Feb-2021	MYSURU	66	HV2	SFCSHIVA_66	13:39	15:29	1:49	LINE CLEAR AVAILED
980	8-Feb-2021	MYSURU	66	HV2	SFCSHIVA_66	16:24	16:30	0:06	HAND TRIPPED
981	8-Feb-2021	MYSURU	66	HV3	SFCSHIVA_66	16:49	16:57	0:08	HAND TRIPPED
982	8-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	13:05	14:33	1:28	NFBC ISSUED
983	8-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	11:17	12:45	1:27	NFBC ISSUED
984	8-Feb-2021	MYSURU	66	HV2	SFCSHIVA_66	12:58	14:56	1:58	LINE CLEAR AVAILED
985	8-Feb-2021	MYSURU	66	TUBINAKERE-MC- 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	8:37	8:44	0:07	LINE FAULT
986	8-Feb-2021	MYSURU	66	TUBINAKERE-MC- 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	10:07	10:11	0:04	LINE FAULT
987	8-Feb-2021	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN, LINE CLEAR AVAILED
988	8-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
989	8-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
990	8-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
991	8-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
992	8-Feb-2021	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	18:39	18:56	0:16	TRANSFORMER FAULT
993	8-Feb-2021	TUMKUR	220	MADHUGIRI 220KV- GOWRIBIDANUR220	MADHUGIRI 220kV	12:13	14:27	2:14	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
994	8-Feb-2021	TUMKUR	220	NEELAGUNDA220kV- GUTTUR 220kV	NEELAGUNDA_220	13:19	13:38	0:18	LINE CLEAR AVAILED
995	8-Feb-2021	TUMKUR	66	TR-1	BELLAVI_66	15:18	17:40	2:21	LINE CLEAR AVAILED
996	8-Feb-2021	TUMKUR	66	TR-2	HONNUDIKE_66	15:01	15:34	0:33	LINE CLEAR AVAILED
997	8-Feb-2021	TUMKUR	66	NEELAGUNDA 220kV- HULUVAGALU	HALUVAGALU_66	13:19	13:38	0:18	LINE CLEAR AVAILED
998	8-Feb-2021	TUMKUR	66	TR-2	SIRA_66	11:45	12:18	0:32	LINE CLEAR AVAILED
999	8-Feb-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	13:22	13:27	0:04	TRANSFORMER FAULT
1000	8-Feb-2021	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	6:03	6:35	0:31	LINE FAULT