

400/220/110/66 kV TRANSMISSION INTERRUPTIONS DUE TO LC, LS AND FAULTS : 31.05.2022 TO 06.06.2022

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	31-May-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
2	31-May-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55(28.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
3	31-May-2022	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54(19.05.2022)	19:03 (31.05.2022)	289:09HRS	LINE CHARGED
4	31-May-2022	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54(19.05.2022)	19:04 (31.05.2022)	289:10HRS	LINE CHARGED
5	31-May-2022	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
6	31-May-2022	BAGALKOT	110	110/11KV, HV2	ANKOLA_110	10:06	16:04	5:58	LINE CLEAR AVAILED
7	31-May-2022	BAGALKOT	110	110/11KV, HV1	ANKOLA_110	12:17	12:23	0:06	LINE CLEAR AVAILED
8	31-May-2022	BAGALKOT	110	AEQUS220- LN1(HUKKERI)	AEQUS_220	15:48	16:10	0:22	LINE CLEAR AVAILED
9	31-May-2022	BAGALKOT	110	BAGEWADI220- ACHANUR(MUDDEBIHAL)	STATION NOT AFFECTED BAGEWADI_220	10:36	12:42	2:06	LINE CLEAR AVAILED
10	31-May-2022	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	10:42	14:07	3:25	LINE CLEAR AVAILED
11	31-May-2022	BAGALKOT	110	110/11KV, HV4	GHATAPRABHA_110	6:49	6:56	0:07	TRANSFORMER FAULT
12	31-May-2022	BAGALKOT	220	BIJAPUR- BAGEWADI2 (GMR)	STATION NOT AFFECTED BIJAPUR_220	12:22	18:38	6:16	HAND TRIPPED
13	31-May-2022	BAGALKOT	110	HUKKERI- HATTARAGI(SANKESHWAR)	HUKKERI_110	15:46	15:50	0:04	HAND TRIPPED
14	31-May-2022	BAGALKOT	220	DHONI- LGPR2(HALVARTHI2)	STATION NOT AFFECTED DHONI_400	19:03 (31.05.2022)			LINE OPEN,LINE FAULT
15	31-May-2022	BAGALKOT	220	DHONI- LGPR1(HALVARTHI1)	STATION NOT AFFECTED DHONI_400	19:03 (31.05.2022)			LINE OPEN,LINE FAULT
16	31-May-2022	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_110	10:48	11:36	0:48	LINE CLEAR AVAILED
17	31-May-2022	BAGALKOT	110	110/11KV,HV2	SHIRBUR_110	14:05	14:55	0:50	LINE CLEAR AVAILED
18	31-May-2022	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	STATION NOT AFFECTED SAMBAPUR ROAD_110	19:42(31.05.2022)			LINE OPEN,LINE FAULT
19	31-May-2022	BAGALKOT	110	110/11KV,HV2	RANEENNUR_220	20:36	21:03	0:27	TRANSFORMER FAULT
20	31-May-2022	BAGALKOT	110	110/11KV,HV1	MRUTHYUNJAY NAGAR_110	12:26	14:12	1:46	LINE CLEAR AVAILED
21	31-May-2022	BAGALKOT	110	110/11KV,HV2	MRUTHYUNJAY NAGAR_110	14:16	14:46	0:30	LINE CLEAR AVAILED
22	31-May-2022	BAGALKOT	110	MK HUBLI220-KITTUR(MK HUBLI2)	MK HUBLI_110	9:55	10:05	0:10	LINE CLEAR AVAILED
23	31-May-2022	BAGALKOT	110	110/11KV,HV1	MANTUR(GHP)_110	18:37	18:43	0:06	TRANSFORMER FAULT
24	31-May-2022	BAGALKOT	110	110/11KV,HV2	MANTUR(GHP)_110	18:37	18:43	0:06	TRANSFORMER FAULT
25	31-May-2022	BAGALKOT	110	SIRSI-KUMTAI1	STATION NOT AFFECTED KUMTA_110	10:48	11:11	0:23	LINE CLEAR AVAILED
26	31-May-2022	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	12:19	14:00	1:41	LINE CLEAR AVAILED
27	31-May-2022	BAGALKOT	110	110/11KV, HV4(HV1)	STATION NOT AFFECTED CHIKKODI_110	13:05	13:55	0:50	LINE CLEAR AVAILED
28	31-May-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
29	31-May-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
30	31-May-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
31	31-May-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
32	31-May-2022	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
33	31-May-2022	BAGALKOT	110	110/11KV, HV1	RATTIHALI_110	10:40(28.05.2022)	20:15(31.05.2022)	81:35HRS	TRANSFORMER CHARGED
34	31-May-2022	BAGALKOT	110	SANKESHWAR-HUKKERI	STATION NOT AFFECTED SANKESHWAR_110	8:15(30.05.2022)	15:45(31.05.2022)	31:30HRS	LINE CHARGED
35	31-May-2022	BAGALKOT	110	BAGEWADI220- SINDAGI	BAGEWADI_220	23:30	23:50	0:20	LINE FAULT
36	31-May-2022	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED KARWAR_220	11:15	13:35	2:20	LINE CLEAR AVOIDED
37	31-May-2022	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), JAKKASANDRA	9:38	9:50	0:12	MAIN SUPPLY FAILURE
38	31-May-2022	BENGALURU	66	HV1	BG ROAD	9:30	9:35	0:05	LINE CLEAR AVOIDED
39	31-May-2022	BENGALURU	66	HV2	BG ROAD	15:00	16:10	1:10	LINE CLEAR AVOIDED
40	31-May-2022	BENGALURU	66	DEVARABISANAHALLI - GLOBAL TECH PARK	GLOBAL TECH PARK	12:45	12:59	0:14	LINE CLEAR AVOIDED
41	31-May-2022	BENGALURU	66	GOKULA - SRS PEENYA 1 220	GOKULA, BEL (EHT)	6:27	6:42	0:15	MAIN SUPPLY FAILURE
42	31-May-2022	BENGALURU	66	GOKULA - SRS PEENYA 2 220	GOKULA, BEL (EHT)	6:27	6:42	0:15	MAIN SUPPLY FAILURE
43	31-May-2022	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	6:27	7:21	0:54	LINE FAULT
44	31-May-2022	BENGALURU	66	HV1	GOKULA	11:42	11:44	0:02	LINE CLEAR AVOIDED
45	31-May-2022	BENGALURU	66	HV2	GOKULA	12:53	12:55	0:02	LINE CLEAR AVOIDED
46	31-May-2022	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), JAKKASANDRA	9:38	9:50	0:12	LINE FAULT
47	31-May-2022	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	6:27	6:42	0:15	MAIN SUPPLY FAILURE
48	31-May-2022	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	11:03	11:18	0:15	LOAD CHANGE OVER
49	31-May-2022	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	11:40	11:43	0:03	LOAD CHANGE OVER
50	31-May-2022	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	6:27	6:42	0:15	LINE FAULT
51	31-May-2022	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	6:27	6:42	0:15	LINE FAULT
52	31-May-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	8:35	9:27	0:52	LINE CLEAR AVOIDED
53	31-May-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	KUMBARANAHALLI	10:00	18:50	8:50	LINE CLEAR AVOIDED
54	31-May-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	17:54	18:22	0:28	LINE CLEAR AVOIDED
55	31-May-2022	BENGALURU	220	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	17:54	18:17	0:23	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
56	31-May-2022	BENGALURU	220	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	15:37	17:03	1:26	LINE CLEAR AVAILED
57	31-May-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	17:54	18:19	0:25	LINE CLEAR AVAILED
58	31-May-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:54	18:24	0:30	LINE CLEAR AVAILED
59	31-May-2022	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	17:54	18:25	0:31	LINE CLEAR AVAILED
60	31-May-2022	BENGALURU	220	HV2	YARANDANAHALLI 220	17:54	18:18	0:24	LINE CLEAR AVAILED
61	31-May-2022	BENGALURU	220	HV3	YARANDANAHALLI 220	17:54	18:18	0:24	LINE CLEAR AVAILED
62	31-May-2022	BENGALURU	66	LR BANDE - HBR LAYOUT 220	LR BANDE	13:48	13:51	0:03	LOAD CHANGE OVER
63	31-May-2022	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	15:05	15:08	0:03	LOAD CHANGE OVER
64	31-May-2022	BENGALURU	66	HBR LAYOUT 220 - HBR LAYOUT 66	HBR LAYOUT 66	14:05	14:24	0:19	LINE CLEAR AVAILED
65	31-May-2022	BENGALURU	66	HV1	DOMMASANDRA	13:30	14:09	0:39	LINE CLEAR AVAILED
66	31-May-2022	BENGALURU	66	HV1	DOMMASANDRA	2:00	2:50	0:49	LINE CLEAR AVAILED
67	31-May-2022	BENGALURU	66	DOMMASANDRA - EPIP 220	DOMMASANDRA	0:45	0:50	0:05	LOAD CHANGE OVER
68	31-May-2022	BENGALURU	66	HBR LAYOUT 66 - KONDASPURA	KONDASPURA	13:52	13:56	0:04	LINE CLEAR AVAILED
69	31-May-2022	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	14:50	14:53	0:03	LOAD CHANGE OVER
70	31-May-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	18:32	18:41	0:09	MAIN SUPPLY FAILURE
71	31-May-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	18:32	19:02	0:29	LINE FAULT
72	31-May-2022	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	3:06	3:15	0:09	LINE FAULT
73	31-May-2022	BENGALURU	66	HV2	CB PURA URBAN	6:45	6:59	0:14	TRANSFORMER FAULT
74	31-May-2022	BENGALURU	220	HV1	MAGADI 220	18:17	18:37	0:20	TRANSFORMER FAULT
75	31-May-2022	BENGALURU	220	HV2	MAGADI 220	18:17	18:38	0:20	TRANSFORMER FAULT
76	31-May-2022	BENGALURU	220	LV1	MAGADI 220	18:17	18:40	0:22	TRANSFORMER FAULT
77	31-May-2022	BENGALURU	66	HV2	JANGAMKOTE	13:00	13:05	0:04	LINE CLEAR AVAILED
78	31-May-2022	BENGALURU	66	HV1	HUKUNDA	12:49	13:00	0:10	TRANSFORMER FAULT
79	31-May-2022	BENGALURU	66	HV1	HUKUNDA	16:46	16:49	0:02	LINE CLEAR AVAILED
80	31-May-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	12:15	12:26	0:11	TRANSFORMER FAULT
81	31-May-2022	BENGALURU	220	HV1	JIGANI 220	15:35	17:05	1:30	MAIN SUPPLY FAILURE
82	31-May-2022	BENGALURU	220	HV2	JIGANI 220	15:35	17:05	1:30	MAIN SUPPLY FAILURE
83	31-May-2022	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	7:33	7:41	0:08	LOAD CHANGE OVER
84	31-May-2022	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	18:20	18:25	0:05	LOAD CHANGE OVER
85	31-May-2022	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	9:30	18:25	8:55	LINE CLEAR AVAILED
86	31-May-2022	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	6:45	6:55	0:10	LINE FAULT
87	31-May-2022	BENGALURU	66	HV1	ATTIBELE	19:42	19:48	0:05	LOAD CHANGE OVER
88	31-May-2022	BENGALURU	66	ANEKAL - YERANDANAHALLI 220	ANEKAL	8:35	18:45	10:10	LINE CLEAR AVAILED
89	31-May-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
90	31-May-2022	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN, LINE CLEAR AVAILED
91	31-May-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
92	31-May-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.5.22)			LINE OPEN, LINE CLEAR AVAILED
93	31-May-2022	GULBARGA	220	HALAWARTHI-DONI1	HALAWARTHI_220	19:03(31.05.2022)			LINE OPEN,LINE FAULT
94	31-May-2022	GULBARGA	220	HALAWARTHI-DONI2	HALAWARTHI_220	19:06(31.05.2022)			LINE OPEN,LINE FAULT
95	31-May-2022	GULBARGA	220	HV2,LV2	LINGASUGUR_220	0:20	1:09	0:49	TRANSFORMER FAULT
96	31-May-2022	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)	20:00(31.05.2022)	354:05HRS	LINE CHARGED
97	31-May-2022	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	0:20	2:12	1:52	LINE FAULT
98	31-May-2022	GULBARGA	110	SEDAM-SHREE CEMENT_IPP	SEDAM_220	12:15 (30.05.2022)			LINE OPEN, LINE CLEAR AVAILED
99	31-May-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_1 10,WADAGERA_110,SANNAT HI_IPP,COREGREENSUGARS_I PP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
100	31-May-2022	GULBARGA	110	HV3	TEKKALKOTE_110	9:15	9:30	0:15	LINE CLEAR AVAILED
101	31-May-2022	GULBARGA	110	HV2	CHOWDAPUR_110	10:00	10:05	0:05	TRANSFORMER FAULT
102	31-May-2022	GULBARGA	110	HV1	HANUMANAL_110	16:20	16:25	0:05	TRANSFORMER FAULT
103	31-May-2022	GULBARGA	110	HV1	YAKATPUR_110	11:30	13:00	1:30	LINE CLEAR AVAILED
104	31-May-2022	GULBARGA	110	HV2	CHITAGUPPA_110	9:05	9:10	0:05	MAIN SUPPLY FAILURE
105	31-May-2022	GULBARGA	110	LV1	LINGASUGUR_220	0:20	0:29	0:09	TRANSFORMER FAULT
106	31-May-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	12:36	12:43	0:07	LINE CLEAR AVAILED
107	31-May-2022	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	13:52	21:13	7:21	LINE CLEAR AVAILED
108	31-May-2022	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	22:40	23:04	0:24	LINE CLEAR AVAILED
109	31-May-2022	GULBARGA	110	ARUD-DONGARAGOA	DONGARAGOA_110	15:35	15:45	0:10	LINE FAULT
110	31-May-2022	GULBARGA	110	ARUD-DONGARAGOA	DONGARAGOA_110	14:00	16:10	2:10	LINE FAULT
111	31-May-2022	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	9:15	9:30	0:15	LINE CLEAR AVAILED
112	31-May-2022	GULBARGA	110	MADIYAL- TSSGOWDGA_RAILWAYLINE	TSSGOWDGA_RAILWAYLINE_ 110	12:13	13:26	1:13	LINE CLEAR AVAILED
113	31-May-2022	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110	23:59	6:35	0:36	MAIN SUPPLY FAILURE
114	31-May-2022	GULBARGA	110	CHITAGUPPA- HUMNABAD220	CHITAGUPPA_110,NIRNA_11 0,ACME SOLAR_IPP	8:30	8:50	0:20	LINE CLEAR AVAILED
115	31-May-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA N_110,DIGGI_110	15:37	15:50	0:13	LINE FAULT
116	31-May-2022	GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP,KAREPOWER IPP	0:20	1:57	1:37	LINE FAULT
117	31-May-2022	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER IPP	0:20	1:56	1:36	LINE FAULT
118	31-May-2022	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	0:20	1:13	0:53	LINE FAULT
119	31-May-2022	GULBARGA	66	BADELADUKU-BANVIKAL	BANVIKAL_66	20:05	20:55	0:50	LINE FAULT
120	31-May-2022	GULBARGA	66	BADELADUKU-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	20:10	21:15	1:05	LINE FAULT
121	31-May-2022	GULBARGA	66	PUNABGHATA- NEELAGUNDA	PUNABGHATA_66,UCCHANID URGA_66,BILCHOD_66	20:50	21:00	0:10	LINE FAULT
122	31-May-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	10:20	10:30	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
123	31-May-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
124	31-May-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN,LINE FAULT
125	31-May-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
126	31-May-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT
127	31-May-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
128	31-May-2022	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:10	14:27	4:17	LINE CLEAR AVAILED
129	31-May-2022	HASSAN	110	HV2	ALKOLA_110	13:25	14:45	1:20	LINE CLEAR AVAILED
130	31-May-2022	HASSAN	110	HV1	KEMAR_220	11:00	12:32	1:32	LINE CLEAR AVAILED
131	31-May-2022	HASSAN	110	HV1	KUNDAPURA_110	10:30	18:00	7:30	LINE CLEAR AVAILED
132	31-May-2022	HASSAN	110	HV2	KUNDAPURA_110	11:38	18:00	6:22	LINE CLEAR AVAILED
133	31-May-2022	HASSAN	110	HV3	KUNDAPURA_110	14:40	18:00	3:20	LINE CLEAR AVAILED
134	31-May-2022	HASSAN	110	SAGARA-JST2	SAGARA_110	10:10	16:55	6:45	NFBC ISSUED
135	31-May-2022	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	13:15	13:30	0:15	LINE FAULT
136	31-May-2022	HASSAN	66	HV2	MATTNAIL_66	14:30	15:15	0:45	LINE CLEAR AVAILED
137	31-May-2022	HASSAN	66	HV1	RAMPURA_66	22:05	22:10	0:05	TRANSFORMER FAULT
138	31-May-2022	HASSAN	66	HV2	RAMPURA_66	22:05	22:10	0:05	TRANSFORMER FAULT
139	31-May-2022	MYSURU	66	HV1	BGNAGARA_66	10:29	10:55	0:25	LINE CLEAR AVAILED
140	31-May-2022	MYSURU	66	HV2	HANAGODU_66	10:57	14:24	3:27	LINE CLEAR AVAILED
141	31-May-2022	MYSURU	66	HANAGODU-PONAMPETE	NO STATIONS EFFECTED	10:30	14:23	3:53	LINE CLEAR AVAILED
142	31-May-2022	MYSURU	66	HONNALLY-ATTAGULIPURA	ATTIGULIPURA_66	19:02	19:18	0:15	LINE FAULT
143	31-May-2022	MYSURU	66	HV1	KR NAGARA_66	11:30	13:32	2:01	LINE CLEAR AVAILED
144	31-May-2022	MYSURU	66	HV2	KR NAGARA_66	13:32	15:43	2:10	LINE CLEAR AVAILED
145	31-May-2022	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS EFFECTED	18:57	19:50	0:53	LINE FAULT
146	31-May-2022	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	6:27	6:31	0:04	LINE FAULT
147	31-May-2022	MYSURU	66	HV2	TERAKANAMBE_66	18:31	18:40	0:08	HAND TRIPPED
148	31-May-2022	MYSURU	66	HV1	MALAVALLI_66	11:14	11:33	0:19	LINE CLEAR AVAILED
149	31-May-2022	MYSURU	66	BEGUR 220-BEGUR 1	NO STATIONS EFFECTED	9:21	9:27	0:06	LINE FAULT
150	31-May-2022	MYSURU	66	KUSHALANAGARA-HARANGI	NO STATIONS EFFECTED	11:10	12:26	1:16	LINE CLEAR AVAILED
151	31-May-2022	MYSURU	66	HEBBANI-SFC 6	NO STATIONS EFFECTED	6:27	6:40	0:13	LINE FAULT
152	31-May-2022	MYSURU	66	KITTUR-RAVANDUR	RAVANDUR_66	13:15	13:35	0:20	LINE CLEAR AVAILED
153	31-May-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
154	31-May-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN, LINE CLEAR AVAILED
155	31-May-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	5:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
156	31-May-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
157	31-May-2022	TUMKUR	220	DAVANGERE 220-SHIVMOGA LINE 2	DAVANGERE_220	6:46	14:13	7:27	LINE FAULT
158	31-May-2022	TUMKUR	66	CHITRADURGA 220kv-SUZLON 1 &2	SUZLON2_IPP_66	11:47	16:50	5:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
159	31-May-2022	TUMKUR	66	DAVANGERE 220- DAVANGERE 66	DAVANGERE_220	11:54	12:06	0:12	LINE FAULT
160	31-May-2022	TUMKUR	66	DAVANGERE-220- DAVANGERE 66	DAVANGERE_220	12:06	12:23	0:17	HAND TRIPPED
161	31-May-2022	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	12:45	13:00	0:15	LINE CLEAR AVAILED
162	31-May-2022	TUMKUR	66	TR1	PAVAGADA_66	11:40	11:50	0:10	TRANSFORMER FAULT
163	31-May-2022	TUMKUR	66	DAVANGERE 220- DAVANGERE 66	DAVANGERE 66	6:46	14:13	7:27	MAIN SUPPLY FAILURE
164	1-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
165	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55(28.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
166	1-Jun-2022	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
167	1-Jun-2022	BAGALKOT	220	DHONI- LGPR2(HALVARTHI2)	STATION NOT AFFECTED DHONI_400	19:03 (31.05.2022)			LINE OPEN,LINE FAULT
168	1-Jun-2022	BAGALKOT	220	DHONI- LGPR1(HALVARTHI2)	STATION NOT AFFECTED DHONI_400	19:03 (31.05.2022)	17:24 (01.06.2022)	22:21HRS	LINE CHARGED
169	1-Jun-2022	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	STATION NOT AFFECTED SAMBAPUR ROAD_110	19:42(31.05.2022)	9:54(01.06.2022)	14:12HRS	LINE CHARGED
170	1-Jun-2022	BAGALKOT	110	110/11KV, HV2	BABLESHWAR_110	13:28	13:32	0:04	HAND TRIPPED
171	1-Jun-2022	BAGALKOT	110	110/11KV, HV2	BABLESHWAR_110	18:33	18:38	0:05	HAND TRIPPED
172	1-Jun-2022	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	10:34	17:10	6:36	LINE CLEAR AVAILED
173	1-Jun-2022	BAGALKOT	110	BAGEWADI- ACHANUR (MUDDEBIHAL)	BAGEWADI_220	5:33	5:42	0:09	LINE FAULT
174	1-Jun-2022	BAGALKOT	220	BAGEWADI- BIJAPUR1(NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	15:56	20:31	4:35	LINE CLEAR AVAILED
175	1-Jun-2022	BAGALKOT	110	DAMBAL- AKHILAGAYA SOLAR	DAMBAL_110	7:41	10:09	2:28	HAND TRIPPED
176	1-Jun-2022	BAGALKOT	110	DAMBAL- EILS	DAMBAL_110	7:41	10:02	2:21	HAND TRIPPED
177	1-Jun-2022	BAGALKOT	110	GADAG220- DAMBAL	DAMBAL_110	7:42	9:52	2:10	LINE CLEAR AVAILED
178	1-Jun-2022	BAGALKOT	110	DAMBAL- MUNDARAGI	DAMBAL_110	7:42	9:52	2:10	HAND TRIPPED
179	1-Jun-2022	BAGALKOT	110	DAMBAL- SUZLON1	DAMBAL_110	17:16	17:53	0:37	HAND TRIPPED
180	1-Jun-2022	BAGALKOT	110	DAMBAL- SUZLON2	DAMBAL_110	7:42	10:07	2:25	HAND TRIPPED
181	1-Jun-2022	BAGALKOT	110	GADAG220- DAMBAL2	GADAG_220	7:57	9:35	1:38	LINE CLEAR AVAILED
182	1-Jun-2022	BAGALKOT	110	110/11KV, HV1	HEBBALLI_110	14:46	14:56	0:10	TRANSFORMER FAULT
183	1-Jun-2022	BAGALKOT	110	110/11KV, HV1	HEBBALLI_110	16:39	16:48	0:09	TRANSFORMER FAULT
184	1-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	16:31	16:34	0:03	TRANSFORMER FAULT
185	1-Jun-2022	BAGALKOT	110	110/33KV, HV2	JAMKHANDI_110	6:05	10:40	4:35	LINE CLEAR AVAILED
186	1-Jun-2022	BAGALKOT	220	BIJAPUR- BAGEWADI1 (NANDIHAL1)	STATION NOT AFFECTED BIJAPUR_220	11:48	14:23	2:35	LINE CLEAR AVAILED
187	1-Jun-2022	BAGALKOT	220	BELGAUM- AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)			LINE CLEAR AVAILED
188	1-Jun-2022	BAGALKOT	400	400/220KV, ICT2	STATION NOT AFFECTED DHONI_400	10:58	15:16	4:18	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
189	1-Jun-2022	BAGALKOT	220	BIDNAL- NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	13:01	13:21	0:20	LINE FAULT
190	1-Jun-2022	BAGALKOT	110	110/11KV,HV1	UKKALI_110	12:01	12:34	0:33	LINE CLEAR AVOIDED
191	1-Jun-2022	BAGALKOT	110	110/11KV,HV3(HV2)	TIKOTA_110	18:40	18:58	0:18	LINE CLEAR AVOIDED
192	1-Jun-2022	BAGALKOT	110	110/11KV,HV1	YADAWAD_110	11:50	12:10	0:20	TRANSFORMER FAULT
193	1-Jun-2022	BAGALKOT	110	SHIGGOAN- RAMANAKOPPA(MUNDAGOD)	SHIGGOAN_110	14:22	17:54	3:32	NFBC ISSUED
194	1-Jun-2022	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110	9:02(01.06.2022)			LINE OPEN, LINE CLEAR AVOIDED
195	1-Jun-2022	BAGALKOT	110	110/11KV,HV1	RATHIHALLI_110	11:22	13:27	2:05	LINE CLEAR AVOIDED
196	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	RANEENNUR_220	11:07	12:51	1:44	LINE CLEAR AVOIDED
197	1-Jun-2022	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	10:42	16:24	5:42	LINE CLEAR AVOIDED
198	1-Jun-2022	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND	12:18	16:24	4:06	LINE CLEAR AVOIDED
199	1-Jun-2022	BAGALKOT	110	NEER BUDIHAL-KATARAKI	NEER BUDIHAL_110	21:25	21:41	0:16	LINE FAULT
200	1-Jun-2022	BAGALKOT	110	MURDESHWAR- HONNAVAR(KRCL RAILWAY)	MURDESHWAR_110	0:02	0:05	0:03	LINE FAULT
201	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	0:55	1:05	0:10	TRANSFORMER FAULT
202	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	8:52	9:08	0:16	TRANSFORMER FAULT
203	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	9:30	9:51	0:21	TRANSFORMER FAULT
204	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	14:17	15:08	0:51	TRANSFORMER FAULT
205	1-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	18:42	18:47	0:05	TRANSFORMER FAULT
206	1-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1(KRCL)	KUMTA_110	0:22	0:26	0:04	LINE FAULT
207	1-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1(KRCL)	KUMTA_110	13:39	13:44	0:05	LINE FAULT
208	1-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1(KRCL)	KUMTA_110	14:24	14:29	0:05	LINE FAULT
209	1-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1(KRCL)	KUMTA_110	16:45	16:51	0:06	LINE FAULT
210	1-Jun-2022	BAGALKOT	110	220/110KV,LV1	KARWAR_220	10:14	14:15	4:01	TRANSFORMER FAULT
211	1-Jun-2022	BAGALKOT	220	HUBLI-NAGJHARI1	STATION NOT AFFECTED HUBLI_220	14:15	18:45	4:30	LINE FAULT
212	1-Jun-2022	BAGALKOT	110	HUBLI-P H COMPOUND	STATION NOT AFFECTED HUBLI_220	12:32	16:15	3:43	NFBC ISSUED
213	1-Jun-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_110	11:47	13:51	2:04	LINE FAULT
214	1-Jun-2022	BAGALKOT	110	BAGALKOT220-KATARAKI (NEERABUDIHAL)	BAGALKOT_220	21:16	21:22	0:06	LINE FAULT
215	1-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANEENNUR_220	11:05	12:58	1:53	LINE CLEAR AVOIDED
216	1-Jun-2022	BAGALKOT	220	KADRA-KARWAR-1	STATION NOT AFFECTED KARWAR_220	10:17	14:10	3:53	NFBC ISSUED
217	1-Jun-2022	BAGALKOT	110	KARWAR220-BINAGA	STATION NOT AFFECTED KARWAR_220	10:12	10:30	0:18	HAND TRIPPED
218	1-Jun-2022	BAGALKOT	110	SAVADATTI-MUNAVALLI	MUNAVALLI_110	15:43	19:29	3:46	LINE FAULT
219	1-Jun-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT
220	1-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
221	1-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
222	1-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
223	1-Jun-2022	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
224	1-Jun-2022	BAGALKOT	110	RANEENNUR220-BYADAGI	STATION NOT AFFECTED RANEENNUR_220	11:45	19:08	7:23	LINE CLEAR AVOIDED
225	1-Jun-2022	BAGALKOT	220	KADRA-KARWAR-2	STATION NO TAFFECTED KARWAR_220	10:23	14:11	3:48	NFBC ISSUED
226	1-Jun-2022	BENGALURU	66	HV1	BANASAWADI	21:51	21:55	0:04	LOAD CHANGE OVER
227	1-Jun-2022	BENGALURU	66	HV3	BANASAWADI	21:51	21:55	0:04	LOAD CHANGE OVER
228	1-Jun-2022	BENGALURU	66	HV3	BANASAWADI	23:51	23:56	0:05	LOAD CHANGE OVER
229	1-Jun-2022	BENGALURU	66	HV3	BANASAWADI	23:51	23:56	0:05	LOAD CHANGE OVER
230	1-Jun-2022	BENGALURU	66	HV2	BG ROAD	12:17	12:31	0:14	TRANSFORMER FAULT
231	1-Jun-2022	BENGALURU	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK	12:22	12:30	0:08	LOAD CHANGE OVER
232	1-Jun-2022	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	19:27	19:42	0:15	MAIN SUPPLY FAILURE
233	1-Jun-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	21:30	21:33	0:03	LOAD CHANGE OVER
234	1-Jun-2022	BENGALURU	66	HV2	ST JOHN WOOD	15:52	15:54	0:02	LINE CLEAR AVOIDED
235	1-Jun-2022	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	5:43	6:08	0:25	LINE FAULT
236	1-Jun-2022	BENGALURU	66	LR BANDE - HBR LAYOUT 220	LR BANDE	19:27	19:35	0:08	MAIN SUPPLY FAILURE
237	1-Jun-2022	BENGALURU	66	HBR LAYOUT 220 - HENNUR CROSS	HENNUR CROSS	19:27	19:42	0:15	LINE FAULT
238	1-Jun-2022	BENGALURU	220	LV1	HBR LAYOUT 220	19:27	20:05	0:38	TRANSFORMER FAULT
239	1-Jun-2022	BENGALURU	66	HBR LAYOUT 220 - HBR LAYOUT 66	HBR LAYOUT 66	19:27	20:15	0:48	MAIN SUPPLY FAILURE
240	1-Jun-2022	BENGALURU	66	HBR LAYOUT 66 - LR BANDE	LR BANDE	19:27	19:35	0:08	LINE FAULT
241	1-Jun-2022	BENGALURU	66	HV2	BRIGADE GATEWAY	10:49	11:08	0:19	LINE CLEAR AVOIDED
242	1-Jun-2022	BENGALURU	66	RAMANAGARA - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA	8:30	8:40	0:10	LINE FAULT
243	1-Jun-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	5:55	6:06	0:11	LINE FAULT
244	1-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	18:54	19:11	0:17	LINE FAULT
245	1-Jun-2022	BENGALURU	66	TADIGOL CROSS - CHINTAMANI 220	TADIGOL CROSS	21:22	21:26	0:03	LINE FAULT
246	1-Jun-2022	BENGALURU	66	PERESANDRA - MITTEMARI 220	PERESANDRA	10:30	10:35	0:05	LOAD CHANGE OVER
247	1-Jun-2022	BENGALURU	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA	16:30	16:35	0:05	LOAD CHANGE OVER
248	1-Jun-2022	BENGALURU	66	SOMENAHALLI - PERESANDRA	NO STATION AFFECTED	10:43	16:10	5:26	LINE CLEAR AVOIDED
249	1-Jun-2022	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR (IPP)	NO STATION AFFECTED	21:20	21:33	0:13	LINE FAULT
250	1-Jun-2022	BENGALURU	66	HV1	PATHPALYA	16:16	16:43	0:27	LINE CLEAR AVOIDED
251	1-Jun-2022	BENGALURU	66	PALLICHERLU - ACME SOLAR (IPP)	NO STATION AFFECTED	20:42	21:06	0:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
252	1-Jun-2022	BENGALURU	66	PALLICHERLU - ACME SOLAR (IPP)	NO STATION AFFECTED	21:06	21:21	0:14	LINE FAULT
253	1-Jun-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	16:50	17:11	0:21	LINE FAULT
254	1-Jun-2022	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	20:42	21:05	0:23	LINE FAULT
255	1-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:04	10:05	0:01	LINE CLEAR AVAILED
256	1-Jun-2022	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	21:17	21:27	0:09	LINE FAULT
257	1-Jun-2022	BENGALURU	66	BANGARPETE - KOLAR 220	BANGARPETE	15:20	15:31	0:11	LOAD CHANGE OVER
258	1-Jun-2022	BENGALURU	66	HV1	KIADB DB PURA 220	13:33	13:41	0:07	TRANSFORMER FAULT
259	1-Jun-2022	BENGALURU	66	HV1	DALASNUR	15:50	21:28	5:38	LINE CLEAR AVAILED
260	1-Jun-2022	BENGALURU	66	TADIGOL CROSS - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	21:22	21:30	0:08	MAIN SUPPLY FAILURE
261	1-Jun-2022	BENGALURU	66	HAROBEL - KUNUR	HAROBEL, HUKUNDA, KODIHALLI, HUNSENAHALLI, BIJJAHALLI	18:15	18:35	0:20	LINE FAULT
262	1-Jun-2022	BENGALURU	66	BURUDAGUNTE - IRGAMPALLI	BURUDAGUNTE	20:45	7:05	10:20	LINE FAULT
263	1-Jun-2022	BENGALURU	66	DALSANUR - KOLAR 220	DALSANUR	15:50	16:05	0:15	LINE FAULT
264	1-Jun-2022	BENGALURU	66	KONDASPURA - HBR LAYOUT 220	KONDASPURA	19:27	20:02	0:35	MAIN SUPPLY FAILURE
265	1-Jun-2022	BENGALURU	66	HV2	NANDIGANAHALLI	10:30	10:40	0:10	LINE CLEAR AVAILED
266	1-Jun-2022	BENGALURU	66	HV1	NANDIGANAHALLI	10:30	10:40	0:10	LINE CLEAR AVAILED
267	1-Jun-2022	BENGALURU	66	HV3	DEVANAHALLI 66	23:50(1-6-2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
268	1-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN, LINE FAULT
269	1-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN, LINE FAULT
270	1-Jun-2022	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN, LINE CLEAR AVAILED
271	1-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.5.22)			LINE OPEN, LINE CLEAR AVAILED
272	1-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
273	1-Jun-2022	GULBARGA	220	HALAWARTHI-DONI1	HALAWARTHI_220	19:03(31.05.2022)			LINE OPEN, LINE FAULT
274	1-Jun-2022	GULBARGA	220	HV2, LV2	LINGASUGUR_220	0:20	1:09	0:49	TRANSFORMER FAULT
275	1-Jun-2022	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	0:20	2:12	1:52	LINE FAULT
276	1-Jun-2022	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)	18:30(01.06.2022)	39:55HRS	LINE CHARGED
277	1-Jun-2022	GULBARGA	220	HALAWARTHI-DONI2	HALAWARTHI_220	19:06(31.05.2022)	17:25(01.06.2022)	22:19HRS	LINE CHARGED
278	1-Jun-2022	GULBARGA	220	LINGAPUR-GDHALLI2	LINGAPUR_220	10:50	23:11	12:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
279	1-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
280	1-Jun-2022	GULBARGA	110	SEDAM-SHREE CEMENT_IPP	SEDAM_220	12:15 (30.05.2022)			LINE OPEN, LINE CLEAR AVAILED
281	1-Jun-2022	GULBARGA	110	HV2	DUBALAGUNDI_110	1:30	3:00	1:30	TRANSFORMER FAULT
282	1-Jun-2022	GULBARGA	110	HV2	CHOWDAPUR_110	10:15	10:20	0:05	TRANSFORMER FAULT
283	1-Jun-2022	GULBARGA	110	HV2	DEODURGA_110	18:45	19:00	0:15	TRANSFORMER FAULT
284	1-Jun-2022	GULBARGA	110	HV2	SREERAMANAGAR_110	10:25	10:36	0:11	TRANSFORMER FAULT
285	1-Jun-2022	GULBARGA	110	HV1	KUSTAGI_220	10:55	18:20	7:25	LINE CLEAR AVAILED
286	1-Jun-2022	GULBARGA	110	HV2	CHITGUPPA_110	11:00	11:10	0:10	TRANSFORMER FAULT
287	1-Jun-2022	GULBARGA	110	HV1	KAVITHAL_110	5:40	5:45	0:05	TRANSFORMER FAULT
288	1-Jun-2022	GULBARGA	110	LV1	LINGASUGUR_220	0:20	0:29	0:09	TRANSFORMER FAULT
289	1-Jun-2022	GULBARGA	110	MADIYAL-TSFGOWDGA_RAILWAYLINE	TSFGOWDGA_RAILWAYLINE_110	14:33	14:47	0:14	LINE FAULT
290	1-Jun-2022	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	3:50	5:19	1:29	LINE FAULT
291	1-Jun-2022	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	11:29	11:55	0:26	LINE CLEAR AVAILED
292	1-Jun-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:44	21:30	9:46	LINE CLEAR AVAILED
293	1-Jun-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,CHINCHOLI_110	19:45	19:59	0:14	LINE CLEAR AVAILED
294	1-Jun-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,CHINCHOLI_110	20:29	20:43	0:14	LINE CLEAR AVAILED
295	1-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA N 110,DIGGI 110	17:56	18:15	0:19	LINE FAULT
296	1-Jun-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:31	22:38	0:07	LINE FAULT
297	1-Jun-2022	GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP,KAREPOWER_IPP	0:20	1:57	1:37	LINE FAULT
298	1-Jun-2022	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_IPP	0:20	1:56	1:36	LINE FAULT
299	1-Jun-2022	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	0:20	1:13	0:53	LINE FAULT
300	1-Jun-2022	GULBARGA	66	HV1	HARAPANAHALLI_66	7:20	7:40	0:20	TRANSFORMER FAULT
301	1-Jun-2022	GULBARGA	66	HV1	HARAPANAHALLI_66	7:50	7:55	0:05	TRANSFORMER FAULT
302	1-Jun-2022	GULBARGA	66	HV1	HARAPANAHALLI_66	10:20	16:25	6:05	TRANSFORMER FAULT
303	1-Jun-2022	GULBARGA	66	HV2	HARAPANAHALLI_66	17:20	17:40	0:20	TRANSFORMER FAULT
304	1-Jun-2022	GULBARGA	66	HV2	PUNABGHATA_66	16:00	16:15	0:15	TRANSFORMER FAULT
305	1-Jun-2022	GULBARGA	66	HV1	BENNEHALLI_66	10:30	10:35	0:05	TRANSFORMER FAULT
306	1-Jun-2022	GULBARGA	66	HOSAHALLI-SML_WIND_IPP	HOSAHALLI_66	11:10	11:20	0:10	LINE CLEAR AVAILED
307	1-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE CLEAR AVAILED
308	1-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
309	1-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
310	1-Jun-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
311	1-Jun-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
312	1-Jun-2022	HASSAN	110	HV2	KUNDAPURA_110	0:01	0:40	0:39	TRANSFORMER FAULT
313	1-Jun-2022	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	6:15	7:20	1:05	LINE FAULT
314	1-Jun-2022	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	10:00	14:51	4:51	LINE CLEAR AVAILED
315	1-Jun-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:04	14:51	4:47	LINE CLEAR AVAILED
316	1-Jun-2022	HASSAN	110	HV2	GURUPURA_110	19:48	21:34	1:46	TRANSFORMER FAULT
317	1-Jun-2022	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	18:46	19:15	0:29	MAIN SUPPLY FAILURE
318	1-Jun-2022	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	19:21	19:44	0:23	MAIN SUPPLY FAILURE
319	1-Jun-2022	HASSAN	110	HV1	MOODABIDRE_110	19:25	19:47	0:22	TRANSFORMER FAULT
320	1-Jun-2022	HASSAN	110	HV1	MOODABIDRE_110	19:52	20:13	0:21	TRANSFORMER FAULT
321	1-Jun-2022	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	18:40	18:55	0:15	HAND TRIPPED
322	1-Jun-2022	HASSAN	110	MOODAB-KEMAR1	MOODABIDRE_110	18:40	18:55	0:15	LINE CLEAR AVAILED
323	1-Jun-2022	HASSAN	110	MOODAB-KEMAR1	MOODABIDRE_110	19:25	19:47	0:22	LINE FAULT
324	1-Jun-2022	HASSAN	110	HV2	VITTALA_110	10:10	14:36	4:26	LINE CLEAR AVAILED
325	1-Jun-2022	HASSAN	66	KIDLIGE-ANVRPP	KUDLIGERE_66	15:30	18:45	3:15	LINE FAULT
326	1-Jun-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	12:05	15:40	3:35	LINE CLEAR AVAILED
327	1-Jun-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	12:05	16:15	4:10	LINE CLEAR AVAILED
328	1-Jun-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	5:51	6:03	0:11	LINE FAULT
329	1-Jun-2022	MYSURU	66	KUSHALNAGARA-MERCERA-1	MADIKERI_66	5:50	6:02	0:12	LINE FAULT
330	1-Jun-2022	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	15:55	16:02	0:07	LINE FAULT
331	1-Jun-2022	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	11:03	11:08	0:05	LINE FAULT
332	1-Jun-2022	MYSURU	66	HEBBANI -TK HALLI	NO STATIONS EFFECTED	5:43	5:55	0:12	LINE FAULT
333	1-Jun-2022	MYSURU	66	BEGUR 220-BEGUR 1	NO STATIONS EFFECTED	1:40:00 PM (01/06/2022)			LINE OPEN,LINE FAULT
334	1-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
335	1-Jun-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN, LINE CLEAR AVAILED
336	1-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	5:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
337	1-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
338	1-Jun-2022	TUMKUR	220	TR3	ANTHRASANAHALLI_220	9:11	19:20	10:09	LINE CLEAR AVAILED
339	1-Jun-2022	TUMKUR	220	TR1	DAVANGERE_220	2:00	10:22	8:22	TRANSFORMER FAULT
340	1-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:26	18:37	1:11	LINE FAULT
341	1-Jun-2022	TUMKUR	66	ANCHEPALYA 220-ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	6:20	6:31	0:11	LINE FAULT
342	1-Jun-2022	TUMKUR	66	ANCHEPALYA 220- BG NAGARA	ANCHEPALYA 220	13:12	13:22	0:10	LINE FAULT
343	1-Jun-2022	TUMKUR	66	TR1 AND TR2	HD PURA	18:25	18:28	0:03	TRANSFORMER FAULT
344	1-Jun-2022	TUMKUR	66	TR2	HULIYUR DURGA_66	18:30	18:40	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
345	1-Jun-2022	TUMKUR	66	HONNALLI 220kV-KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE 66	8:46	8:57	0:11	LINE FAULT
346	1-Jun-2022	TUMKUR	66	HONNALLI 220kV-KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE 66	16:07	16:38	0:31	LINE FAULT
347	1-Jun-2022	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGI RI 66	16:19	16:38	0:19	LINE FAULT
348	1-Jun-2022	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANGIGUDI_66, KARGIL EHT 66	16:25	16:39	0:14	LINE FAULT
349	1-Jun-2022	TUMKUR	66	HONNALLI 220KV-NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	16:55	17:05	0:10	LINE FAULT
350	1-Jun-2022	TUMKUR	66	HONNALLI 220kV-KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE 66	17:10	17:20	0:10	LINE FAULT
351	2-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
352	2-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55(28.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
353	2-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
354	2-Jun-2022	BAGALKOT	220	DHONI-LGPR2(HALVARTHI1)	STATION NOT AFFECTED DHONI_400	19:03 (31.05.2022)	12:37(02.06.2022)	41:34HRS	LINE CHARGED
355	2-Jun-2022	BAGALKOT	220	BELGAUM-AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)			LINE CLEAR AVAILED
356	2-Jun-2022	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110	9:02(01.06.2022)			LINE OPEN, LINE CLEAR AVAILED
357	2-Jun-2022	BAGALKOT	110	HUBLI-AKSHYAYA COLONY	AKSHYAYA COLONY_110	17:0(02.06.2022)			LINE CLEAR AVAILED
358	2-Jun-2022	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	10:32	10:42	0:10	LINE CLEAR AVAILED
359	2-Jun-2022	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	15:44(02.06.2022)			LINE OPEN,LINE FAULT
360	2-Jun-2022	BAGALKOT	220	BIDNAL-HRTHI1	STATION NOT AFFECTED BIDNAL_220	16:01	22:47	6:46	LINE FAULT
361	2-Jun-2022	BAGALKOT	110	110/11KV,HV1	KIADB BIJAPUR_110	13:55	14:14	0:19	TRANSFORMER FAULT
362	2-Jun-2022	BAGALKOT	110	110/33KV,HV2	TEGGI_33 BISNAL_110	20:40	21:01	0:21	TRANSFORMER FAULT
363	2-Jun-2022	BAGALKOT	110	DAMBAL-AKHILAGYA SOLAR	DAMBAL_110	18:10	18:12	0:02	HAND TRIPPED
364	2-Jun-2022	BAGALKOT	110	DAMBAL-SUZLON2	DAMBAL_110	18:10	18:11	0:01	HAND TRIPPED
365	2-Jun-2022	BAGALKOT	110	DAMBAL-EILS(KNNL)	DAMBAL_110	18:10	18:13	0:03	HAND TRIPPED
366	2-Jun-2022	BAGALKOT	110	110/11KV,HV1	DEVARA GENNUR_110	20:06	20:27	0:21	TRANSFORMER FAULT
367	2-Jun-2022	BAGALKOT	110	GADAG-DAMBAL1 (SAMBAPUR ROAD)	SAMBAPUR ROAD_110	17:06	18:08	1:02	LINE FAULT
368	2-Jun-2022	BAGALKOT	110	110/33KV,HV1	PALA_33,BASAPUR_33 HANAGAL_110	18:42	19:03	0:21	TRANSFORMER FAULT
369	2-Jun-2022	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	16:12	16:24	0:12	LINE FAULT
370	2-Jun-2022	BAGALKOT	110	HAVERI-TILUVALI(HANAGAL)	STATION NOT AFFECTED HAVERI_220	12:06	12:34	0:28	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
371	2-Jun-2022	BAGALKOT	110	110/33KV,HV3	RUSTUMPUR LIS_33,BLG W/S1_33,BLGM W/S 2&3,GODACHINA MALKI LIS_33 MHIDIKAL DAM_110	20:04	21:42	1:38	TRANSFORMER FAULT
372	2-Jun-2022	BAGALKOT	110	110/33KV,HV3	RUSTUMPUR LIS_33,BLG W/S1_33,BLGM W/S 2&3,GODACHINA MALKI LIS_33 MHIDIKAL DAM_110	21:50	22:05	0:15	TRANSFORMER FAULT
373	2-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	22:38	22:42	0:04	TRANSFORMER FAULT
374	2-Jun-2022	BAGALKOT	220	DHONI- LGPR1(HALVARTHI2)	STATION NOT AFFECTED DHONI_400	9:27	12:38	3:11	LINE CLEAR AVOIDED
375	2-Jun-2022	BAGALKOT	110	UGARKHUD- UGAR SUGARS	UGARKHUD_110	19:31	19:49	0:18	LINE FAULT
376	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	10:00	14:06	4:06	LINE CLEAR AVOIDED
377	2-Jun-2022	BAGALKOT	110	TAKKALAKI- KNS SOLAR	TAKKALAKI_110	17:12	17:16	0:04	HAND TRIPPED
378	2-Jun-2022	BAGALKOT	110	SIRSI- KUMATA2	SIRSI_110	12:01	14:08	2:07	HAND TRIPPED
379	2-Jun-2022	BAGALKOT	110	SAMBAPUR ROAD- RAILWAY (RVNL)	STATION NOT AFFECTED SAMBAPUR ROAD_110	18:10	18:12	0:02	HAND TRIPPED
380	2-Jun-2022	BAGALKOT	110	RANNABELAGALI- MUDHOL (UTTUR)	STATION NOT AFFECTED RANNABELAGALI_110	11:32	12:51	1:19	LINE CLEAR AVOIDED
381	2-Jun-2022	BAGALKOT	110	MAHALINGAPUR- RANNABELAGALI	STATION NOT AFFECTED RANNABELAGALI_110	12:44	14:36	1:52	LINE CLEAR AVOIDED
382	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	13:53	14:36	0:43	LINE CLEAR AVOIDED
383	2-Jun-2022	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	15:14	15:57	0:43	LINE CLEAR AVOIDED
384	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	NAVALAGI_110	12:55	13:00	0:05	TRANSFORMER FAULT
385	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	NAVALGUND_110	11:36	13:24	1:48	LINE CLEAR AVOIDED
386	2-Jun-2022	BAGALKOT	110	BAGEWADI220- MAMADAPUR(B)1	MAMADAPUR(B)_110	22:39	22:58	0:19	LINE FAULT
387	2-Jun-2022	BAGALKOT	110	110/33KV, HV3	LOKAPUR_110, BATKURKI_33, RSSKN_33	17:37	23:00	5:23	TRANSFORMER FAULT
388	2-Jun-2022	BAGALKOT	110	LOKAPUR- DALMIYA CEMENT	LOKAPUR_110	17:37	23:00	5:23	LINE CLEAR AVOIDED
389	2-Jun-2022	BAGALKOT	110	KUMATA- KRCL (RAILWAY)	KUMATA_110	21:45	21:49	0:04	LINE FAULT
390	2-Jun-2022	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	9:40	14:25	4:45	LINE CLEAR AVOIDED
391	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	11:50	12:02	0:12	TRANSFORMER FAULT
392	2-Jun-2022	BAGALKOT	220	KUDACHI- CHIKKODI1	STATION NOT AFFECTED KUDACHI_220	11:10	14:53	3:43	LINE CLEAR AVOIDED
393	2-Jun-2022	BAGALKOT	110	VAJRAMATTI220_MELLIGER I	MELLIGERI_110	11:14	11:29	0:15	HAND TRIPPED
394	2-Jun-2022	BAGALKOT	220	HUBLI-NARENDRA 2	STATION NOT AFFECTED HUBLI_220	09:30	15:19	5:49	LINE CLEAR AVOIDED
395	2-Jun-2022	BAGALKOT	220	HUBLI-NAGZARI 1	STATION NOT AFFECTED HUBLI_220	12:42	15:31	2:49	LINE CLEAR AVOIDED
396	2-Jun-2022	BAGALKOT	220	AMBEWADI- PONDA-2	STATION NOT AFFECTED AMBEWADI_220	14:30:00(02.06.2022)			LINE OPEN,LINE FAULT
397	2-Jun-2022	BAGALKOT	220	AMBEWADI-NARENDRA 1	STATION NOT AFFECTED AMBEWADI_220	16:48:00(02.06.2022)			LINE OPEN,LINE FAULT
398	2-Jun-2022	BAGALKOT	220	AMBEWADI-NAGJHARI 2	STATION NOT AFFECTED AMBEWADI_220	10:48	11:11	0:23	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
399	2-Jun-2022	BAGALKOT	110	BAGALKOT220-KALADGI	KALADGI_110	20:38	21:05	0:27	LINE FAULT
400	2-Jun-2022	BAGALKOT	110	110/33KV, HV1	BAGALKOT_220, KATAGERI_33, GADDANAKERI_33 STATION NOT AFFECTED BAGALKOT_220	19:35	20:23	0:48	TRANSFORMER FAULT
401	2-Jun-2022	BAGALKOT	110	SOUDATTI220-MMCL	STATION NOT AFFECTED SOUNDATTI_220	16:54	17:37	0:43	LINE FAULT
402	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SOUNDATTI_220	17:38	18:32	0:54	TRANSFORMER FAULT
403	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SOUNDATTI_220	18:50	19:09	0:19	TRANSFORMER FAULT
404	2-Jun-2022	BAGALKOT	110	SOUDATTI220-MMCL	MMCL_110 STATION NOT AFFECTED SOUNDATTI_220	16:54	17:45	0:51	LINE FAULT
405	2-Jun-2022	BAGALKOT	220	BAGEWADI- BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	10:17	17:48	7:31	LINE CLEAR AVOIDED
406	2-Jun-2022	BAGALKOT	220	BAGEWADI- BIJAPUR2 (NANDIHAL2)	STATION NOT AFFECTED BAGEWADI_220	12:17	17:48	5:31	LINE CLEAR AVOIDED
407	2-Jun-2022	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED CHIKKODI_220	17:35	18:10	0:35	LINE CLEAR AVOIDED
408	2-Jun-2022	BAGALKOT	110	CHIKKODI220- SADALAGA	CHIKKODI_220	2:10	02:20	0:10	LINE FAULT
409	2-Jun-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT
410	2-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
411	2-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
412	2-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
413	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
414	2-Jun-2022	BAGALKOT	110	BAGEWADI220- MAMADAPUR(B)2	MAMADAPUR(B)_110	22:39	22:58	0:19	LINE FAULT
415	2-Jun-2022	BAGALKOT	110	DAMBAL-MUNDARAGI1&2	DAMBAL_110	17:10	18:12	1:02	HAND TRIPPED
416	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_220	19:15	19:25	0:10	TRANSFORMER FAULT
417	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_220	19:40	19:45	0:05	TRANSFORMER FAULT
418	2-Jun-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110, GIRISAGAR_110 TOLAMATTI_110 BISNAL_110	05:45	05:55	0:10	LINE FAULT
419	2-Jun-2022	BAGALKOT	110	110/11KV, HV2	BISNAL_110	20:40	21:00	0:20	TRANSFORMER FAULT
420	2-Jun-2022	BAGALKOT	220	ESALE220-SIRSI1	STATION NOT AFFECTED ESALE_220	11:30	11:32	0:02	HAND TRIPPED
421	2-Jun-2022	BAGALKOT	220	ESALE220-SIRSI2	STATION NOT AFFECTED ESALE_220	11:30	11:32	0:02	HAND TRIPPED
422	2-Jun-2022	BAGALKOT	220	INDI220- SAVALASANGA WINDI IPP	SAVALSANG WIND IPP_110 INDI_220	17:10	17:15	0:05	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
423	2-Jun-2022	BAGALKOT	220	INDI-VIJAYPUR-1	INDI_220	17:10	17:15	0:05	MAIN SUPPLY FAILURE
424	2-Jun-2022	BAGALKOT	220	INDI-VIJAYPUR-2	INDI_220	17:10	17:15	0:05	MAIN SUPPLY FAILURE
425	2-Jun-2022	BAGALKOT	110	INDI220-DEVARHIPPARGI	DEVARAHIPPARAGI_110 ATHARGA_110 HIREMASALI_110	17:10	17:15	0:05	MAIN SUPPLY FAILURE
426	2-Jun-2022	BAGALKOT	110	INDI220-INDI	INDI_110	17:10	17:15	0:05	MAIN SUPPLY FAILURE
427	2-Jun-2022	BAGALKOT	110	INDI220-LACHYAN	LACHYAN_110 HIREBENNUR_110 RODGI_110 DULAKHED_110	17:10	17:15	0:05	MAIN SUPPLY FAILURE
428	2-Jun-2022	BAGALKOT	110	INDI220-ZALKI 1 & 2	ZALKI_110 INCHEGERI_110 CHADACHAN_110	17:10	17:15	0:05	MAIN SUPPLY FAILURE
429	2-Jun-2022	BAGALKOT	220	220/110KV, HV1	INDI_220	17:10	17:15	0:05	MAIN SUPPLY FAILURE
430	2-Jun-2022	BAGALKOT	220	220/110KV, HV1	INDI_220	17:10	17:15	0:05	MAIN SUPPLY FAILURE
431	2-Jun-2022	BAGALKOT	110	KARAWAR220-KARWAR	KARWAR_110	13:55	16:02	2:07	LINE CLEAR AVAILED
432	2-Jun-2022	BAGALKOT	110	MUGALKHOD220-ITNAL3	STATION NOT AFFECTED MUGALKHOD_220	10:01	11:47	1:46	LINE FAULT
433	2-Jun-2022	BAGALKOT	220	CHIKKODI- KUDACHI1	STATION NOT AFFECTED CHIKKODI_220	11:10	14:53	3:43	LINE CLEAR AVAILED
434	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	CHIKKODI_220	15:30	18:11	2:41	LINE CLEAR AVAILED
435	2-Jun-2022	BAGALKOT	110	110/11KV, HV1	GALATAGA_110	17:30	17:40	0:10	TRANSFORMER FAULT
436	2-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	14:05	14:20	0:15	LOAD CHANGE OVER
437	2-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	14:36	14:48	0:12	LOAD CHANGE OVER
438	2-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	16:56	17:06	0:10	LOAD CHANGE OVER
439	2-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	17:23	17:28	0:05	LOAD CHANGE OVER
440	2-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	21:50	21:58	0:08	LOAD CHANGE OVER
441	2-Jun-2022	BENGALURU	66	HBR LAYOUT 66 - KONDASPURA	KONDASPURA, BELL CERAMIC	8:21	8:40	0:19	LINE FAULT
442	2-Jun-2022	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	12:41	12:45	0:04	LOAD CHANGE OVER
443	2-Jun-2022	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	JAYANAGARA	16:06	16:20	0:14	LOAD CHANGE OVER
444	2-Jun-2022	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, KODIGEHALI, SRIGANDAKAVALU	16:04	16:19	0:15	LINE FAULT
445	2-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	17:05	17:59	0:54	LINE FAULT
446	2-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	17:05	17:59	0:54	LINE FAULT
447	2-Jun-2022	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	7:31	7:38	0:07	LOAD CHANGE OVER
448	2-Jun-2022	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, VANDARGUPPE	18:34	18:44	0:10	LINE FAULT
449	2-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:50	13:00	1:10	LINE CLEAR AVAILED
450	2-Jun-2022	BENGALURU	66	HV1	DODDALAHALLI	11:40	12:00	0:20	LINE CLEAR AVAILED
451	2-Jun-2022	BENGALURU	66	HV2	DODDALAHALLI	13:00	14:40	1:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
452	2-Jun-2022	BENGALURU	66	HV1	DODDALAHALLI	13:00	14:40	1:40	LINE CLEAR AVAILED
453	2-Jun-2022	BENGALURU	66	HV2	HUKUNDA	15:10	17:10	2:00	LINE CLEAR AVAILED
454	2-Jun-2022	BENGALURU	66	HV1	HUKUNDA	18:40	18:45	0:05	TRANSFORMER FAULT
455	2-Jun-2022	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:04	18:15	0:11	LINE FAULT
456	2-Jun-2022	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	11:55	12:00	0:05	LOAD CHANGE OVER
457	2-Jun-2022	BENGALURU	66	HV2	YEDUMADU	23:55	23:59	0:04	TRANSFORMER FAULT
458	2-Jun-2022	BENGALURU	66	HV1	TAMAKA	13:20	14:00	0:40	LINE CLEAR AVAILED
459	2-Jun-2022	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	7:21	7:26	0:05	LOAD CHANGE OVER
460	2-Jun-2022	BENGALURU	66	KONDASPURA - HBR LAYOUT 220	KONDASPURA	8:21	8:40	0:20	MAIN SUPPLY FAILURE
461	2-Jun-2022	BENGALURU	66	HV1	GANJIGUNTE	16:00	17:27	1:27	LINE CLEAR AVAILED
462	2-Jun-2022	BENGALURU	66	KYASAMBALLY - T GOLLAHALLI 220	KYASAMBALLY, DODDAKARI	17:05	17:55	0:50	LINE FAULT
463	2-Jun-2022	BENGALURU	66	KYASAMBALLY - AFTL(SOLAR)	AFTL(SOLAR)	17:05	18:15	1:10	LINE FAULT
464	2-Jun-2022	BENGALURU	66	HV1	VIDHURASHWATHA	17:55	18:10	0:15	TRANSFORMER FAULT
465	2-Jun-2022	BENGALURU	66	HV3	DEVANAHALLI	12:30	12:40	0:10	TRANSFORMER FAULT
466	2-Jun-2022	BENGALURU	66	HV3	DEVANAHALLI	13:30	14:45	1:15	LINE CLEAR AVAILED
467	2-Jun-2022	BENGALURU	66	HV3	DEVANAHALLI 66	23:50(1-6-2022)	2:40(2-6-2022)	0:50HRS	TRANSFORMER CHARGED
468	2-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN,LINE FAULT
469	2-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.5.22)			LINE OPEN, LINE CLEAR AVAILED
470	2-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
471	2-Jun-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	18:52 (2.05.2022)			LINE OPEN,LINE FAULT
472	2-Jun-2022	GULBARGA	220	HV1,LV1 & HV2,LV2	MALLAT_220	19:15	19:29	0:14	TRANSFORMER FAULT
473	2-Jun-2022	GULBARGA	220	HV1,HV2	ITTAGI_220	1:36	1:45	0:09	TRANSFORMER FAULT
474	2-Jun-2022	GULBARGA	220	HV1	BADELADUKU_220 (KUDLIGI)	13:40	13:45	0:05	TRANSFORMER FAULT
475	2-Jun-2022	GULBARGA	220	HALAWARTHI-DONI1	HALAWARTHI_220	19:03(31.05.2022)	13:32(02.06.2022)	42:29HRS	LINE CHARGED
476	2-Jun-2022	GULBARGA	220	LINGAPUR-GDHALLI2	GDHALLI_220	10:09	18:56	8:47	LINE CLEAR AVAILED
477	2-Jun-2022	GULBARGA	220	LINGAPUR-MUNIRABAD POWER HOUSE	MUNIRABAD_220	5:51	6:31	0:40	LINE FAULT
478	2-Jun-2022	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	20:14	20:23	0:09	LINE FAULT
479	2-Jun-2022	GULBARGA	220	RAICHUR-RTPS_1	RAICHUR_220	19:24	20:13	0:49	LINE FAULT
480	2-Jun-2022	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	10:57	15:15	4:18	LINE CLEAR AVAILED
481	2-Jun-2022	GULBARGA	220	HALAWARTHI-DONI1,2	HALAWARTHI_220	9:27	12:38	3:11	NFBC ISSUED
482	2-Jun-2022	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	18:50	19:52	1:02	LINE FAULT
483	2-Jun-2022	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	18:54	19:35	0:41	LINE FAULT
484	2-Jun-2022	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	20:14	20:28	0:14	LINE FAULT
485	2-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
486	2-Jun-2022	GULBARGA	110	HV2	CHOWDAPUR_110	5:30	5:35	0:05	TRANSFORMER FAULT
487	2-Jun-2022	GULBARGA	110	HV1	MATAMARI_110	18:05	18:10	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
488	2-Jun-2022	GULBARGA	110	HV2	HATTI_110	20:23	20:26	0:03	TRANSFORMER FAULT
489	2-Jun-2022	GULBARGA	110	HV2	HATTI_110	23:22	23:24	0:02	TRANSFORMER FAULT
490	2-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	20:46	21:46	1:00	TRANSFORMER FAULT
491	2-Jun-2022	GULBARGA	110	HV1	ALIPUR_220	19:01	19:28	0:27	TRANSFORMER FAULT
492	2-Jun-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNA SAGI_110	2:17	2:20	0:03	LINE FAULT
493	2-Jun-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	12:11	12:20	0:09	LINE FAULT
494	2-Jun-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:15	21:10	0:55	LINE FAULT
495	2-Jun-2022	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	13:07	14:58	1:51	LINE CLEAR AVAILED
496	2-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	16:50	16:59	0:09	LINE FAULT
497	2-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	16:50	16:59	0:09	LINE FAULT
498	2-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	5:25	5:28	0:03	MAIN SUPPLY FAILURE
499	2-Jun-2022	GULBARGA	110	CHITAGUPPA-ACME SOLAR	CHITAGUPPA_110	23:59	3:21	3:22	LINE CLEAR AVAILED
500	2-Jun-2022	GULBARGA	110	AURAD-SANTHAPUR	AURADA_110,DONGARAGOA_110	21:15	21:35	0:20	MAIN SUPPLY FAILURE
501	2-Jun-2022	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	23:34	23:36	0:02	MAIN SUPPLY FAILURE
502	2-Jun-2022	GULBARGA	110	HATTI-SOMANAMARADI_IPP	HATTI_110	23:22	23:50	0:28	LINE FAULT
503	2-Jun-2022	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	5:54	6:04	0:10	LINE FAULT
504	2-Jun-2022	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	0:58	1:28	0:30	LINE FAULT
505	2-Jun-2022	GULBARGA	110	ADAVI AMARESHWAR-SINDHANOOR	ADAVI AMARESHWAR_110,JAWALGERA_110	22:07	22:30	0:23	MAIN SUPPLY FAILURE
506	2-Jun-2022	GULBARGA	110	SEDAM-SHREE CEMENT_IPP	SEDAM_220	12:15 (30.05.2022)	18:16 (2.05.2022)	78:01 HRS	LINE CHARGED
507	2-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	19:22	20:04	0:42	LINE FAULT
508	2-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:23	20:04	0:41	LINE FAULT
509	2-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:46	21:10	0:24	LINE FAULT
510	2-Jun-2022	GULBARGA	110	SEDAM-GURUMITKAL	GURMITKAL_110,KONKAL_110	11:25	12:46	1:21	LINE CLEAR AVAILED
511	2-Jun-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	13:30	23:35	10:05	LINE CLEAR AVAILED
512	2-Jun-2022	GULBARGA	110	SEDAM-VASAVADATTA CEMENT	SEDAM_220	14:50	14:55	0:05	LINE FAULT
513	2-Jun-2022	GULBARGA	110	SEDAM-VASAVADATTA CEMENT	SEDAM_220	15:05	15:10	0:05	LINE FAULT
514	2-Jun-2022	GULBARGA	110	SEDAM-VASAVADATTA CEMENT	SEDAM_220	15:18	15:25	0:07	LINE FAULT
515	2-Jun-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR1	BPCL_IPP,VENKATGIRI_110,ANGAVATHI_110,SRNAGAR_110,KARTAGI_110	5:57	6:33	0:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
516	2-Jun-2022	GULBARGA	110	MUNIRABAD-DONIMALAI1,2	DONIMALAI_110,NMDC FACTORY,STAR METALLIC_IPP,JINDAL PUMP HOUSE	9:58	13:32	3:34	LINE CLEAR AVAILED
517	2-Jun-2022	GULBARGA	110	LINGASUGUR-KAREPOWER	KAREPOWER_IPP,CHAYADEVI_IPP	21:31	21:37	0:06	LINE FAULT
518	2-Jun-2022	GULBARGA	110	LINGASUGUR-GURGUNTA	GURGUNTA_110,KHEL_IPP,LJ VL_IPP	22:15	22:30	0:15	LINE FAULT
519	2-Jun-2022	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVIT HAL_110,SOMANMARDI_IPP, GAMESHA_IPP	23:34	23:45	0:11	LINE FAULT
520	2-Jun-2022	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110,SIRUGUPPA_A_110,TEKKALKOTE_110,NSL SUGAR_IPP,SIRIGERE CROSS_110	21:16	21:36	0:20	LINE FAULT
521	2-Jun-2022	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110,SIRUGUPPA_A_110,TEKKALKOTE_110,NSL SUGAR_IPP,SIRIGERE CROSS_110	21:50	22:10	0:20	LINE FAULT
522	2-Jun-2022	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS ACC	19:01	19:28	0:27	LINE FAULT
523	2-Jun-2022	GULBARGA	66	HV1	BENNEHALLI_66	1:35	1:45	0:10	TRANSFORMER FAULT
524	2-Jun-2022	GULBARGA	66	HV1	BENNEHALLI_66	23:40(2.6.22)			TRANSFORMER OPEN,TRANSFORMER FAULT
525	2-Jun-2022	GULBARGA	66	HV2	HALAVAGALU_66	6:10	6:15	0:05	TRANSFORMER FAULT
526	2-Jun-2022	GULBARGA	66	HV2	HALAVAGALU_66	7:00	7:05	0:05	TRANSFORMER FAULT
527	2-Jun-2022	GULBARGA	66	ITTAGI-CLEANMAX_1_IPP	ITTAGI_220	1:36	7:05	5:29	LINE FAULT
528	2-Jun-2022	GULBARGA	66	ITTAGI-CLEANMAX_2_IPP	ITTAGI_220	1:36	2:32	0:56	LINE CLEAR AVAILED
529	2-Jun-2022	GULBARGA	66	HV2 (12.5MVA)	ITTAGI_220	11:30	12:15	0:45	LINE CLEAR AVAILED
530	2-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE CLEAR AVAILED
531	2-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
532	2-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
533	2-Jun-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT
534	2-Jun-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
535	2-Jun-2022	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	10:01	14:31	4:30	NFBC ISSUED
536	2-Jun-2022	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:17	12:49	1:32	LINE FAULT
537	2-Jun-2022	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	12:03	15:43	3:40	LINE FAULT
538	2-Jun-2022	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	11:17	12:47	1:30	LINE FAULT
539	2-Jun-2022	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	12:03	15:43	3:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
540	2-Jun-2022	HASSAN	110	HV2	BANAVARA_110	10:05	17:10	7:05	LINE CLEAR AVAILED
541	2-Jun-2022	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	10:02	15:05	5:03	LINE CLEAR AVAILED
542	2-Jun-2022	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	9:53	15:05	5:12	LINE CLEAR AVAILED
543	2-Jun-2022	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	9:53	15:33	5:40	LINE CLEAR AVAILED
544	2-Jun-2022	HASSAN	110	HV1	HOSANGADI_110	9:53	17:25	7:32	LINE CLEAR AVAILED
545	2-Jun-2022	HASSAN	110	HV2	HOSANGADI_110	9:53	15:10	5:17	LINE CLEAR AVAILED
546	2-Jun-2022	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	9:53	15:05	5:12	LINE CLEAR AVAILED
547	2-Jun-2022	HASSAN	110	HOSNGDVTRG2	HOSANGADI_110	9:53	15:33	5:40	LINE CLEAR AVAILED
548	2-Jun-2022	HASSAN	110	HULICA-KVR	HULICAL_110	10:25	14:40	4:15	NFBC ISSUED
549	2-Jun-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:27	10:34	0:07	HAND TRIPPED
550	2-Jun-2022	HASSAN	110	HV1	KALLUSADARAHALLI_110	12:25	14:30	2:05	MAIN SUPPLY FAILURE
551	2-Jun-2022	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLI_110	12:25	14:30	2:05	MAIN SUPPLY FAILURE
552	2-Jun-2022	HASSAN	110	HV	KITTADAHALLI_110	17:05	17:20	0:15	LINE CLEAR AVAILED
553	2-Jun-2022	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	14:15	16:13	1:58	LINE CLEAR AVAILED
554	2-Jun-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:42	15:16	0:34	LINE FAULT
555	2-Jun-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:42	15:15	0:33	LINE FAULT
556	2-Jun-2022	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:50	12:35	1:45	LINE CLEAR AVAILED
557	2-Jun-2022	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	10:50	12:35	1:45	NFBC ISSUED
558	2-Jun-2022	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	11:05	16:40	5:35	LINE CLEAR AVAILED
559	2-Jun-2022	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	11:05	15:10	4:05	LINE CLEAR AVAILED
560	2-Jun-2022	HASSAN	66	SALAGAM-HIREMANGLUR	SALGAME_66	10:09	15:23	5:14	LINE CLEAR AVAILED
561	2-Jun-2022	HASSAN	66	HV1	SALGAME_66	10:08	15:23	5:15	LINE CLEAR AVAILED
562	2-Jun-2022	HASSAN	66	HV2	SALGAME_66	10:09	15:23	5:14	LINE CLEAR AVAILED
563	2-Jun-2022	HASSAN	66	SALAGAM-UDURKOPPLU	SALGAME_66	10:09	15:18	5:09	LINE CLEAR AVAILED
564	2-Jun-2022	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	11:39	15:17	3:38	LINE CLEAR AVAILED
565	2-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-SUTTUR	SUTTUR_66	7:20	7:28	0:08	LINE FAULT
566	2-Jun-2022	MYSURU	66	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	8:44	8:55	0:11	LINE FAULT
567	2-Jun-2022	MYSURU	66	SHIVALLI-TUBINKERE	SHIVALLY_66	10:00	14:20	4:20	LINE CLEAR AVAILED
568	2-Jun-2022	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	9:22	18:22	9:00	LINE CLEAR AVAILED
569	2-Jun-2022	MYSURU	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	9:22	18:23	9:01	LINE CLEAR AVAILED
570	2-Jun-2022	MYSURU	66	HOOTAGALLI-KAGGERE HAMPAPURA	NO STATIONS EFFECTED	9:48	18:25	8:37	LINE CLEAR AVAILED
571	2-Jun-2022	MYSURU	220	HOOTAGALLI-HV-3	NO STATIONS EFFECTED	9:53	18:12	8:19	LINE CLEAR AVAILED
572	2-Jun-2022	MYSURU	220	KADAKOLA-BEGUR-2	NO STATIONS EFFECTED	10:52	18:48	7:56	LINE CLEAR AVAILED
573	2-Jun-2022	MYSURU	66	TUBINKERE-G UKKADA	NO STATIONS EFFECTED	11:34	14:32	2:58	LINE CLEAR AVAILED
574	2-Jun-2022	MYSURU	66	HV-1	THUMBLA_66	10:00	15:28	5:28	LINE CLEAR AVAILED
575	2-Jun-2022	MYSURU	66	HV-2	THUMBLA_66	10:00	15:28	5:28	LINE CLEAR AVAILED
576	2-Jun-2022	MYSURU	66	HEBBANI-MEGALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 TNARASIPURA_66	10:11	10:32	0:21	LINE FAULT
577	2-Jun-2022	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66 HADLI_66	10:20	14:06	3:46	NFBC ISSUED
578	2-Jun-2022	MYSURU	66	BEGUR 220-BEGUR 1	NO STATIONS EFFECTED	1:40:00 PM (01/06/2022)	11:59 (02/06/2022)	0:20HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
579	2-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
580	2-Jun-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN, LINE CLEAR AVAILED
581	2-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	5:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
582	2-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
583	2-Jun-2022	TUMKUR	220	TR3	CHITRADURGA_220	8:22	8:56	0:34	TRANSFORMER FAULT
584	2-Jun-2022	TUMKUR	66	CHITRADURGA 220kV-BALENAHALLI-66	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	8:32	11:01	2:29	LINE FAULT
585	2-Jun-2022	TUMKUR	220	CHITRADURGA 220-GUTTUR 220	CHITRADURGA_220	12:14	14:31	2:17	NFBC ISSUED
586	2-Jun-2022	TUMKUR	220	CHITRADURGA 220kV-THALLAK	CHITRADURGA_220	14:49	16:47	1:58	LINE CLEAR AVAILED
587	2-Jun-2022	TUMKUR	220	TR3	HIRIYUR_220	5:10	5:20	0:10	TRANSFORMER FAULT
588	2-Jun-2022	TUMKUR	66	HIRIYUR_220-PARSHAMPURA 66	HIRIYUR_220	5:10	0:00	18:50	LINE FAULT
589	2-Jun-2022	TUMKUR	220	THALLAK 220kV-CHITRADURGA_220	THALLAK_220	14:51	16:47	1:56	NFBC ISSUED
590	2-Jun-2022	TUMKUR	66	SIRA66-KALAMBELLA66	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	11:13	15:00	3:47	LINE CLEAR AVAILED
591	2-Jun-2022	TUMKUR	66	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110, TALKERE_110, KADEHALLI_110,	5:42	5:52	0:10	LINE FAULT
592	2-Jun-2022	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	17:10	18:15	1:05	MAIN SUPPLY FAILURE
593	2-Jun-2022	TUMKUR	66	TR1	HIRIYUR_66	17:15	17:30	0:15	TRANSFORMER FAULT
594	2-Jun-2022	TUMKUR	66	TR1	KALAMARANAHALLI 66	8:05	8:22	0:17	TRANSFORMER FAULT
595	2-Jun-2022	TUMKUR	66	TR1	KALAMARANAHALLI 66	17:05	17:38	0:33	MAIN SUPPLY FAILURE
596	2-Jun-2022	TUMKUR	66	TR2	KALAMARANAHALLI 66	17:05	17:38	0:33	MAIN SUPPLY FAILURE
597	2-Jun-2022	TUMKUR	66	TR2	NITRAHALLI_66	19:00	19:15	0:15	TRANSFORMER FAULT
598	2-Jun-2022	TUMKUR	66	TR2	MADHANAYAKANHALLI-66	11:15	11:20	0:05	LINE CLEAR AVAILED
599	2-Jun-2022	TUMKUR	66	TR1	PD KOTE	17:08	18:13	1:05	MAIN SUPPLY FAILURE
600	2-Jun-2022	TUMKUR	66	TR2	PD KOTE	17:08	18:13	1:05	MAIN SUPPLY FAILURE
601	2-Jun-2022	TUMKUR	66	SIRA66-KALAMBELLA66	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	11:20	15:00	3:40	LINE CLEAR AVAILED
602	2-Jun-2022	TUMKUR	66	TR1 AND TR2	SOKKE 66	11:30	13:45	2:15	LINE CLEAR AVAILED
603	2-Jun-2022	TUMKUR	66	TR2	THOVINAKERE 66	13:15	14:30	1:15	LINE CLEAR AVAILED
604	3-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
605	3-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
606	3-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
607	3-Jun-2022	BAGALKOT	220	BELGAUM-AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)			LINE CLEAR AVAILED
608	3-Jun-2022	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110	9:02(01.06.2022)			LINE OPEN, LINE CLEAR AVAILED
609	3-Jun-2022	BAGALKOT	110	HUBLI-AKSHYAYA COLONY	AKSHYAYA COLONY_110	17:00(02.06.2022)	07:02(03.06.2022)	14:02HRS	LINE CHARGED
610	3-Jun-2022	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	15:44(02.06.2022)	19:17 (03.06.2022)	27:33HRS	LINE CHARGED
611	3-Jun-2022	BAGALKOT	220	AMBEWADI- PONDA-2	STATION NOT AFFECTED AMBEWADI_220	14:30:00(02.06.2022)			LINE OPEN,LINE FAULT
612	3-Jun-2022	BAGALKOT	220	AMBEWADI-NARENDRA 1	STATION NOT AFFECTED AMBEWADI_220	16:48:00(02.06.2022)	12:09 (03.06.2022)	19:21HRS	LINE CHARGED
613	3-Jun-2022	BAGALKOT	110	BAGEWADI-UKKALI	UKKALI_110	8:24	12:50	4:26	NFBC ISSUED
614	3-Jun-2022	BAGALKOT	110	110/11KV,HV1	UKKALI_110	7:10	12:35	5:25	LINE CLEAR AVAILED
615	3-Jun-2022	BAGALKOT	110	110/11KV,HV1	UKKALI_110	12:35	14:25	1:50	TRANSFORMER FAULT
616	3-Jun-2022	BAGALKOT	110	IDLE(HUBLI)-TARIHAL2	TARIHAL_110	7:20	8:47	1:27	HAND TRIPPED
617	3-Jun-2022	BAGALKOT	110	HUBLI-TARIHAL1	STATION NOT AFFECTED TARIHAL_110	11:23	12:05	0:42	HAND TRIPPED
618	3-Jun-2022	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	10:00	17:25	7:25	LINE CLEAR AVAILED
619	3-Jun-2022	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	10:10	17:52	7:42	LINE CLEAR AVAILED
620	3-Jun-2022	BAGALKOT	110	110/11KV,HV1,HV2	SIRSI_110	10:00	18:07	8:07	LINE CLEAR AVAILED
621	3-Jun-2022	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	2:42	3:12	0:30	TRANSFORMER FAULT
622	3-Jun-2022	BAGALKOT	110	110/11KV,HV1(HV2)	RATTIHALI_110	12:03	12:55	0:52	LINE CLEAR AVAILED
623	3-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	7:43	7:46	0:03	TRANSFORMER FAULT
624	3-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	9:10	17:54	8:44	HAND TRIPPED
625	3-Jun-2022	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	0:23	0:48	0:25	HAND TRIPPED
626	3-Jun-2022	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	1:55	2:50	0:55	HAND TRIPPED
627	3-Jun-2022	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	9:05	9:36	0:31	HAND TRIPPED
628	3-Jun-2022	BAGALKOT	110	110/33KV,HV1	HIPPARAGI_33 JAMAKHANDI_110	6:21	9:50	3:29	LINE CLEAR AVAILED
629	3-Jun-2022	BAGALKOT	220	BIDNAL- NAGJHARI	BIDNAL_220	13:58	18:35	4:37	LINE FAULT
630	3-Jun-2022	BAGALKOT	220	CHIKKODI- KUDACHI2	STATION NOT AFFECTED CHIKKODI_220	11:02	14:25	3:23	LINE CLEAR AVAILED
631	3-Jun-2022	BAGALKOT	110	HAVERI220- TILUVALLI (HANGAL)	HAVERI_220	11:10	11:27	0:17	HAND TRIPPED
632	3-Jun-2022	BAGALKOT	220	KUDACHI- CHIKKODI2	KUDACHI_220	11:02	14:20	3:18	LINE CLEAR AVAILED
633	3-Jun-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	14:32	19:31	4:59	LINE FAULT
634	3-Jun-2022	BAGALKOT	110	MUGALKHOD- LN12 (PG HUNSHYAL)	MUGALKHOD_220	5:40	5:54	0:14	LINE FAULT
635	3-Jun-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	14:32	19:31	4:59	LINE FAULT
636	3-Jun-2022	BAGALKOT	110	110/11KV, HV4	HUBLI_220	10:38	13:32	2:54	LINE CLEAR AVAILED
637	3-Jun-2022	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	STATION NOT AFFECTED MAHALINGAPUR_220	3:21	6:30	3:09	LINE FAULT
638	3-Jun-2022	BAGALKOT	110	110/33KV, HV3	ANKALI_110	12:34	13:33	0:59	LINE CLEAR AVAILED
639	3-Jun-2022	BAGALKOT	110	110/11KV, HV1	GADAG_110	5:30	5:41	0:11	TRANSFORMER FAULT
640	3-Jun-2022	BAGALKOT	110	HALIYAL- GMR (ALNAVAR)	HALIYAL_110	22:51	23:01	0:10	LINE FAULT
641	3-Jun-2022	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	4:34	4:40	0:06	TRANSFORMER FAULT
642	3-Jun-2022	BAGALKOT	110	110/11KV, HV1	ISLAMPUR_110	10:10	14:19	4:09	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
643	3-Jun-2022	BAGALKOT	110	110/11KV, HV2	ITANAL_110	9:37	9:42	0:05	TRANSFORMER FAULT
644	3-Jun-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT
645	3-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
646	3-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
647	3-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
648	3-Jun-2022	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)	21:37 (03.05.2022)	374:17hrs	TRANSFORMER CHARGED
649	3-Jun-2022	BAGALKOT	110	110/11KV, HV1	KATARAKI_110	9:00	12:10	3:10	LINE CLEAR AVOIDED
650	3-Jun-2022	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:40	13:30	0:50	LINE CLEAR AVOIDED
651	3-Jun-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	SHIRAGUPPI_110	5:45	5:50	0:05	LINE FAULT
652	3-Jun-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110 ,GIRISAGAR_110, TOLAMATTI_110 &BISNAL_110	5:45	5:53	0:08	MAIN SUPPLY FAILURE
653	3-Jun-2022	BAGALKOT	110	SIRSI220- SIRSI1	STATION NOT AFFECTED SIRSI_220	10:09	17:36	7:27	LINE CLEAR AVOIDED
654	3-Jun-2022	BAGALKOT	110	SIRSI220- SIRSI2	STATION NOT AFFECTED SIRSI_220	10:09	17:36	7:27	LINE CLEAR AVOIDED
655	3-Jun-2022	BAGALKOT	110	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	10:30	12:20	1:50	LINE CLEAR AVOIDED
656	3-Jun-2022	BAGALKOT	110	MK HUBLI220- BIDI	MK HUBLI_220	4:49	5:35	0:46	LINE FAULT
657	3-Jun-2022	BAGALKOT	110	110/11KV, HV1	LAKAMANHALLI_110	2:30	3:30	1:00	TRANSFORMER FAULT
658	3-Jun-2022	BAGALKOT	110	110/11KV, HV1	UMMACHAGI_110	10:00	17:20	7:20	LINE CLEAR AVOIDED
659	3-Jun-2022	BAGALKOT	220	KARWAR- KADRA2	STATION NOT AFFECTED KARWAR_220	9:40	16:48	7:08	NFBC ISSUED
660	3-Jun-2022	BAGALKOT	110	TARIHAL-NAVANAGR(H)	STATION NOT AFFECTED TARIHAL_110	6:00	10:25	4:25	LINE CLEAR AVOIDED
661	3-Jun-2022	BAGALKOT	110	TARIHAL-NAVANAGR(H)	STATION NOT AFFECTED TARIHAL_110	12:05	12:45	0:40	LINE CLEAR AVOIDED
662	3-Jun-2022	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	4:32	4:34	0:02	TRANSFORMER FAULT
663	3-Jun-2022	BAGALKOT	110	BAGEWADI- UKKALI	BAGEWADI_220	9:25	12:15	2:50	LINE CLEAR AVOIDED
664	3-Jun-2022	BAGALKOT	110	BAGEWADI- NIDAGUNDI	BAGEWADI_220	10:46	12:52	2:06	LINE CLEAR AVOIDED
665	3-Jun-2022	BENGALURU	66	HV1	DEVARABISANAHALLI	20:42	20:50	0:08	TRANSFORMER FAULT
666	3-Jun-2022	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	17:54	18:43	0:49	LINE FAULT
667	3-Jun-2022	BENGALURU	66	LR BANDE - HBR LAYOUT 66	LR BANDE	5:21	5:24	0:03	LOAD CHANGE OVER
668	3-Jun-2022	BENGALURU	66	IISc - HEBBALA 220	IISc	5:16	5:22	0:06	LOAD CHANGE OVER
669	3-Jun-2022	BENGALURU	66	HV1	IISc	11:06	11:10	0:04	LINE CLEAR AVOIDED
670	3-Jun-2022	BENGALURU	66	HV2	IISc	12:30	12:32	0:02	LINE CLEAR AVOIDED
671	3-Jun-2022	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	18:59	19:18	0:19	MAIN SUPPLY FAILURE
672	3-Jun-2022	BENGALURU	66	HV1	JAYADEVA	15:40	15:56	0:16	LINE CLEAR AVOIDED
673	3-Jun-2022	BENGALURU	66	HV2	JAYADEVA	16:18	16:35	0:17	LINE CLEAR AVOIDED
674	3-Jun-2022	BENGALURU	66	HV1	KHODAYS 220	18:52	19:25	0:33	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
675	3-Jun-2022	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	19:49	21:18	1:29	LINE FAULT
676	3-Jun-2022	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	20:03	21:50	1:47	LINE FAULT
677	3-Jun-2022	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	17:01	17:19	0:18	MAIN SUPPLY FAILURE
678	3-Jun-2022	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	17:01	17:28	0:27	MAIN SUPPLY FAILURE
679	3-Jun-2022	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU	21:02	21:15	0:13	LINE CLEAR AVAILED
680	3-Jun-2022	BENGALURU	66	HV1	MATHIKERE	9:32	9:34	0:02	LINE CLEAR AVAILED
681	3-Jun-2022	BENGALURU	66	HV1	MATHIKERE	11:40	11:43	0:03	LOAD CHANGE OVER
682	3-Jun-2022	BENGALURU	66	HV2	MATHIKERE	11:45	11:49	0:04	LINE CLEAR AVAILED
683	3-Jun-2022	BENGALURU	66	HV2	MATHIKERE	14:57	15:00	0:03	LOAD CHANGE OVER
684	3-Jun-2022	BENGALURU	220	NIMHANS 220 - KORAMANGALA 220	NIMHANS 220	17:01	17:23	0:22	MAIN SUPPLY FAILURE
685	3-Jun-2022	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	17:01	17:23	0:22	MAIN SUPPLY FAILURE
686	3-Jun-2022	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	17:01	17:23	0:22	MAIN SUPPLY FAILURE
687	3-Jun-2022	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI	17:01	17:23	0:22	MAIN SUPPLY FAILURE
688	3-Jun-2022	BENGALURU	220	HSR LAYOUT 220 - KORAMANGALA 220	KORAMANGALA 220, NIMHANS 220	17:01	17:18	0:17	LINE FAULT
689	3-Jun-2022	BENGALURU	66	NRS 220 - REMCO MY 1	VIJAYANAGARA	19:15	19:27	0:12	LINE FAULT
690	3-Jun-2022	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	18:59	19:18	0:19	LINE FAULT
691	3-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	18:50	19:18	0:28	LINE FAULT
692	3-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	19:18	20:57	1:39	LINE FAULT
693	3-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	20:57	21:52	0:55	LINE CLEAR AVAILED
694	3-Jun-2022	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	20:49	21:18	0:29	LINE FAULT
695	3-Jun-2022	BENGALURU	66	HV2	VIJAYANAGARA	21:15	21:17	0:02	LOAD CHANGE OVER
696	3-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	NO STATION AFFECTED	13:45	14:02	0:17	LINE FAULT
697	3-Jun-2022	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	5:43	5:58	0:15	LINE FAULT
698	3-Jun-2022	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	19:03	19:25	0:22	LINE FAULT
699	3-Jun-2022	BENGALURU	220	KOLAR 220 - MALUR 3	NO STATION AFFECTED	17:55	18:27	0:32	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
700	3-Jun-2022	BENGALURU	66	HV1	KOLAR 220	17:37	18:09	0:32	MAIN SUPPLY FAILURE
701	3-Jun-2022	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:37	18:01	0:24	MAIN SUPPLY FAILURE
702	3-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	17:37	18:00	0:23	MAIN SUPPLY FAILURE
703	3-Jun-2022	BENGALURU	66	HV2	KOLAR 220	17:37	21:39	4:02	TRANSFORMER FAULT
704	3-Jun-2022	BENGALURU	220	HV2	KOLAR 220	17:37	17:56	0:19	TRANSFORMER FAULT
705	3-Jun-2022	BENGALURU	220	LV2	KOLAR 220	17:37	17:56	0:19	TRANSFORMER FAULT
706	3-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	9:30	9:40	0:10	LINE CLEAR AVOIDED
707	3-Jun-2022	BENGALURU	66	HV2	KOLAR 220	9:30	9:40	0:10	LINE CLEAR AVOIDED
708	3-Jun-2022	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	18:01	18:56	0:55	MAIN SUPPLY FAILURE
709	3-Jun-2022	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	18:01	18:55	0:54	MAIN SUPPLY FAILURE
710	3-Jun-2022	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	18:01	18:55	0:54	MAIN SUPPLY FAILURE
711	3-Jun-2022	BENGALURU	220	HV1	MALUR 220	18:01	18:53	0:52	MAIN SUPPLY FAILURE
712	3-Jun-2022	BENGALURU	220	MALUR 220 - HOODY 220	NO STATION AFFECTED	17:57	18:45	0:48	LINE FAULT
713	3-Jun-2022	BENGALURU	220	MALUR 220 - KOLAR 3	NO STATION AFFECTED	17:56	18:27	0:31	LINE FAULT
714	3-Jun-2022	BENGALURU	66	HV1	SARJAPURA 220	19:28	19:36	0:08	TRANSFORMER FAULT
715	3-Jun-2022	BENGALURU	220	HV1	MAGADI 220	19:28	19:36	0:08	TRANSFORMER FAULT
716	3-Jun-2022	BENGALURU	220	HV1	MAGADI 220	21:21	21:48	0:26	TRANSFORMER FAULT
717	3-Jun-2022	BENGALURU	220	HV2	MAGADI 220	19:28	19:37	0:09	TRANSFORMER FAULT
718	3-Jun-2022	BENGALURU	66	LV1	MAGADI 220	19:28	19:38	0:10	TRANSFORMER FAULT
719	3-Jun-2022	BENGALURU	66	LV1	MAGADI 220	21:21	21:48	0:26	TRANSFORMER FAULT
720	3-Jun-2022	BENGALURU	66	HV2	HUKUNDA	16:08	16:32	0:23	TRANSFORMER FAULT
721	3-Jun-2022	BENGALURU	66	HV1	HAROBEL KANAKPURA	19:25	19:30	0:05	TRANSFORMER FAULT
722	3-Jun-2022	BENGALURU	66	HV2	HAROBEL KANAKPURA	19:25	19:30	0:05	TRANSFORMER FAULT
723	3-Jun-2022	BENGALURU	220	HV1	GOWRIBIDANUR 220	9:27	19:41	10:14	LINE CLEAR AVOIDED
724	3-Jun-2022	BENGALURU	66	LV1	GOWRIBIDANUR 220	9:26	19:42	10:15	LINE CLEAR AVOIDED
725	3-Jun-2022	BENGALURU	66	HV1	SANKALGERE	5:08	5:18	0:10	TRANSFORMER FAULT
726	3-Jun-2022	BENGALURU	66	HV2	ALUR	15:24	17:04	1:39	LINE CLEAR AVOIDED
727	3-Jun-2022	BENGALURU	66	HV2	DIBBURALLI	12:00	12:03	0:03	LINE CLEAR AVOIDED
728	3-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	5:32	5:51	0:19	LINE FAULT
729	3-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	19:27	19:40	0:13	MAIN SUPPLY FAILURE
730	3-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	21:25	21:48	0:22	MAIN SUPPLY FAILURE
731	3-Jun-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	21:25	21:48	0:22	MAIN SUPPLY FAILURE
732	3-Jun-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	22:01	22:24	0:22	LINE FAULT
733	3-Jun-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	19:27	20:21	0:54	LINE FAULT
734	3-Jun-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	20:01	20:16	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
735	3-Jun-2022	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	18:57	21:22	2:25	LINE CLEAR AVAILED
736	3-Jun-2022	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	20:18	21:08	0:49	LINE FAULT
737	3-Jun-2022	BENGALURU	66	GANJIGUNTE - BURUDAGUNTE	BURUDAGUNTE	14:01	14:15	0:14	LINE CLEAR AVAILED
738	3-Jun-2022	BENGALURU	66	IRGAMPALLI - BURUDAGUNTE	BURUDAGUNTE	16:38	16:43	0:05	LOAD CHANGE OVER
739	3-Jun-2022	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	13:28	13:39	0:11	LINE CLEAR AVAILED
740	3-Jun-2022	BENGALURU	220	KOLAR 220 - MALUR 3	NO STATION AFFECTED	18:27(3-6-2022)			LINE OPEN,LINE FAULT
741	3-Jun-2022	BENGALURU	220	MALUR 220 - KOLAR 3	NO STATION AFFECTED	18:27(3-6-2022)			LINE OPEN,LINE FAULT
742	3-Jun-2022	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 2	NO STATION AFFECTED	18:58(03/06/2022)			LINE OPEN,LINE FAULT
743	3-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN,LINE FAULT
744	3-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.5.22)			LINE OPEN, LINE CLEAR AVAILED
745	3-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
746	3-Jun-2022	GULBARGA	220	HV2	ITTAGI_220	1:10	1:17	0:07	TRANSFORMER FAULT
747	3-Jun-2022	GULBARGA	220	ITTAGI-BMM ISPAT_IPP	BMM ISPAT_IPP	10:30	19:05	8:35	LINE CLEAR AVAILED
748	3-Jun-2022	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNGA_220	19:07	20:15	1:08	LINE CLEAR AVAILED
749	3-Jun-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	18:52 (2.05.2022)	13:18 (3.05.2022)	18:26 HRS	LINE CHARGED
750	3-Jun-2022	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	12:19	13:17	0:58	LINE CLEAR AVAILED
751	3-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
752	3-Jun-2022	GULBARGA	110	HV2	DEODURGA_110	12:40	12:50	0:10	TRANSFORMER FAULT
753	3-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	13:57	14:02	0:05	TRANSFORMER FAULT
754	3-Jun-2022	GULBARGA	110	HV1	HUNSIGI_110	9:30	18:15	8:45	LINE CLEAR AVAILED
755	3-Jun-2022	GULBARGA	110	LV1	ITTAGI_220	1:10	1:17	0:07	TRANSFORMER FAULT
756	3-Jun-2022	GULBARGA	110	HV1	CHOWDAPUR_110	7:40	7:45	0:05	TRANSFORMER FAULT
757	3-Jun-2022	GULBARGA	110	HV1	HALAHUNDI_110	7:55	8:30	0:35	LINE CLEAR AVAILED
758	3-Jun-2022	GULBARGA	110	HV1	HALAHUNDI_110	12:05	12:50	0:45	LINE CLEAR AVAILED
759	3-Jun-2022	GULBARGA	110	HV3	MADIYAL_110	14:50	14:55	0:05	LINE CLEAR AVAILED
760	3-Jun-2022	GULBARGA	110	HV1	MANVI_110	1:13	1:18	0:05	TRANSFORMER FAULT
761	3-Jun-2022	GULBARGA	110	HV1	MANVI_110	1:39	1:43	0:04	TRANSFORMER FAULT
762	3-Jun-2022	GULBARGA	110	HV2	MANVI_110	2:01	2:06	0:05	TRANSFORMER FAULT
763	3-Jun-2022	GULBARGA	110	HV2	MANVI_110	11:58	12:05	0:07	TRANSFORMER FAULT
764	3-Jun-2022	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	20:10	20:15	0:05	LINE FAULT
765	3-Jun-2022	GULBARGA	110	YERAGERA-VADAVATI	YERAGERA_110	3:35	3:50	0:15	MAIN SUPPLY FAILURE
766	3-Jun-2022	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	3:39	3:45	0:06	LINE FAULT
767	3-Jun-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	10:55	11:43	0:48	LINE FAULT
768	3-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	0:04	0:20	0:16	LINE FAULT
769	3-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:04	0:20	0:16	LINE FAULT
770	3-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:07	20:11	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
771	3-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	5:41	5:44	0:03	LINE FAULT
772	3-Jun-2022	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110,YAKATPUR_110	19:23	19:29	0:06	LINE FAULT
773	3-Jun-2022	GULBARGA	66	HV1	BENNEHALLI_66	23:40(2.06.2022)	17:35(3.06.2022)	17:55HRS	TRANSFORMER CHARGED
774	3-Jun-2022	GULBARGA	66	HV2	BENNEHALLI_66	6:50	6:55	0:05	TRANSFORMER FAULT
775	3-Jun-2022	GULBARGA	66	HV2	BENNEHALLI_66	16:40	16:45	0:05	TRANSFORMER FAULT
776	3-Jun-2022	GULBARGA	66	HV1	HARVI_66	7:10	7:30	0:20	LINE CLEAR AVAILED
777	3-Jun-2022	GULBARGA	66	HV1	BADELADUKU_220 (KUDLIGI)	9:05	9:15	0:10	TRANSFORMER FAULT
778	3-Jun-2022	GULBARGA	66	BADELADUKU-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	19:00	19:10	0:10	LINE FAULT
779	3-Jun-2022	GULBARGA	66	ITTAGI-SUZLON_1_IPP	ITTAGI_220	1:10	11:40	10:30	LINE FAULT
780	3-Jun-2022	GULBARGA	66	ITTAGI-HAGRIBOMMANHALLI	HAGRIBOMMANHALLI_66,UP ANAYAKANAHALLI_66,BACHI GONDANAHALLI_66	8:30	14:55	6:25	LINE CLEAR AVAILED
781	3-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE CLEAR AVAILED
782	3-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
783	3-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
784	3-Jun-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT
785	3-Jun-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
786	3-Jun-2022	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	11:24	14:19	2:55	LINE CLEAR AVAILED
787	3-Jun-2022	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:44	13:02	2:18	LINE CLEAR AVAILED
788	3-Jun-2022	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	17:17	18:02	0:45	LINE FAULT
789	3-Jun-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:27	11:38	0:11	HAND TRIPPED
790	3-Jun-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	13:16	15:34	2:18	LINE CLEAR AVAILED
791	3-Jun-2022	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	11:24	14:19	2:55	LINE CLEAR AVAILED
792	3-Jun-2022	HASSAN	220	HV1	SHIRALKOPPA_220	15:28	17:24	1:56	LINE CLEAR AVAILED
793	3-Jun-2022	HASSAN	110	LV1	SHIRALKOPPA_220	15:28	17:24	1:56	LINE CLEAR AVAILED
794	3-Jun-2022	HASSAN	110	LV1	SHIRALKOPPA_220	12:10	13:17	1:07	TRANSFORMER FAULT
795	3-Jun-2022	HASSAN	110	LV1	SHIRALKOPPA_220	13:22	14:07	0:45	TRANSFORMER FAULT
796	3-Jun-2022	HASSAN	110	HV2	ESSUR_110	12:45	13:15	0:30	LINE CLEAR AVAILED
797	3-Jun-2022	HASSAN	110	HV2	ESSUR_110	15:15	15:45	0:30	LINE CLEAR AVAILED
798	3-Jun-2022	HASSAN	110	HV1	KULASHEKAR_110	10:09	16:49	6:40	LINE CLEAR AVAILED
799	3-Jun-2022	HASSAN	110	KULASH-KAVOOR 1	KULASHEKAR_110	10:30	17:48	7:18	HAND TRIPPED
800	3-Jun-2022	HASSAN	110	KULASH-KAVOOR 2	KULASHEKAR_110	10:30	17:48	7:18	LINE CLEAR AVAILED
801	3-Jun-2022	HASSAN	110	HV2	KUNDAPURA_110	17:43	18:03	0:20	TRANSFORMER FAULT
802	3-Jun-2022	HASSAN	66	HV2	ARAKALGUD_66	23:00	23:20	0:20	TRANSFORMER FAULT
803	3-Jun-2022	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	18:20	18:40	0:20	LINE FAULT
804	3-Jun-2022	HASSAN	66	HV1	HALEBEEDU_66	10:15	16:10	5:55	LINE CLEAR AVAILED
805	3-Jun-2022	HASSAN	66	HV2	HALEBEEDU_66	10:15	16:10	5:55	LINE CLEAR AVAILED
806	3-Jun-2022	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:33	6:53	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
807	3-Jun-2022	HASSAN	66	HV1	MALLAPURA_66	15:46	17:23	1:37	TRANSFORMER FAULT
808	3-Jun-2022	HASSAN	66	HV1	MALLAPURA_66	17:33	18:15	0:42	LINE CLEAR AVAILED
809	3-Jun-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPUA_66	11:35	15:40	4:05	LINE CLEAR AVAILED
810	3-Jun-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPUA_66	11:35	15:40	4:05	LINE CLEAR AVAILED
811	3-Jun-2022	MYSURU	66	BILIKERE-GVGUDI	GVGUDI_66	14:47	14:58	0:10	LINE FAULT
812	3-Jun-2022	MYSURU	66	HV1	BYLUKUPPE_66	0:05	0:13	0:08	TRANSFORMER FAULT
813	3-Jun-2022	MYSURU	66	HV1	COWDALLI_66	21:25	21:40	0:15	TRANSFORMER FAULT
814	3-Jun-2022	MYSURU	66	HV2	DEVANOORNGUDU_66	16:21	18:04	1:42	LINE CLEAR AVAILED
815	3-Jun-2022	MYSURU	66	DUNDANAHALLI-ANCHEPALYA	NO STATIONS EFFECTED	11:55	18:50	6:55	HAND TRIPPED
816	3-Jun-2022	MYSURU	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	14:48	16:51	2:03	HAND TRIPPED
817	3-Jun-2022	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	14:48	16:51	2:03	HAND TRIPPED
818	3-Jun-2022	MYSURU	66	HV1	HANAGODU_66	6:05	6:20	0:15	TRANSFORMER FAULT
819	3-Jun-2022	MYSURU	66	KHB-HOOTAGLLI	NO STATIONS EFFECTED	14:42	16:55	2:13	HAND TRIPPED
820	3-Jun-2022	MYSURU	66	KHONALAGERE-SOMANHALLI	K_HONNALGERE_66	15:58	21:16	5:17	LINE CLEAR AVAILED
821	3-Jun-2022	MYSURU	66	B G PURA-HEBBANI	BGPURA_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	8:21	8:24	0:03	HAND TRIPPED
822	3-Jun-2022	MYSURU	66	B G PURA-HEBBANI	BGPURA_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	16:27	16:34	0:07	HAND TRIPPED
823	3-Jun-2022	MYSURU	66	HV1	BGPURA_66	8:00	16:34	8:34	LINE CLEAR AVAILED
824	3-Jun-2022	MYSURU	66	HV2	BGPURA_66	8:21	16:34	8:13	LINE CLEAR AVAILED
825	3-Jun-2022	MYSURU	66	HV-1	VAJAMANGALA_220	10:10	17:35	7:25	LINE CLEAR AVAILED
826	3-Jun-2022	MYSURU	66	HV-2	VAJAMANGALA_220	10:10	17:35	7:25	LINE CLEAR AVAILED
827	3-Jun-2022	MYSURU	66	TUBINKERE-PANDAVAPURA	BANANGADI_66 DODDABYADARAHALLI_66 PANDAVAPURA_66	10:10	18:02	7:52	LINE CLEAR AVAILED
828	3-Jun-2022	MYSURU	66	HV-2	HOOTAGALLY_220	17:30	17:51	0:21	TRANSFORMER FAULT
829	3-Jun-2022	MYSURU	66	HV-2	HOOTAGALLY_220	18:52	19:19	0:27	TRANSFORMER FAULT
830	3-Jun-2022	MYSURU	66	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	12:10	18:50	6:40	LINE CLEAR AVAILED
831	3-Jun-2022	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66	9:08	18:00	8:52	LINE CLEAR AVAILED
832	3-Jun-2022	MYSURU	66	MALAVALLI-KK HALLI	MALAVALLI_66	9:08	18:00	8:52	LINE CLEAR AVAILED
833	3-Jun-2022	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	13:56	14:02	0:06	LINE FAULT
834	3-Jun-2022	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	11:39	15:30	3:51	NFBC ISSUED
835	3-Jun-2022	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDRAVADI_66	11:46	11:59	0:13	LINE FAULT
836	3-Jun-2022	MYSURU	66	G UKKADA-S R PATNA	SRIRANGAPATNA_66	10:55	11:00	0:05	LINE FAULT
837	3-Jun-2022	MYSURU	66	G UKKADA-TUBINAKERE	SRIRANGAPATNA_66 GARUDANAUKADDA_66	16:50	17:05	0:15	LINE FAULT
838	3-Jun-2022	MYSURU	66	ADDIHALLY-S B HALLY	ADDIHALLI_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KADABALLY_66 VADERALLI_66	18:53	19:03	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
839	3-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	5:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
840	3-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
841	3-Jun-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN, LINE CLEAR AVAILED
842	3-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	5:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
843	3-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
844	3-Jun-2022	TUMKUR	220	TR1 AND TR2	HONNALI-220	2:00	2:37	0:37	MAIN SUPPLY FAILURE
845	3-Jun-2022	TUMKUR	220	TR1 AND TR2	HOSADURGA_220	2:10	3:30	1:20	MAIN SUPPLY FAILURE
846	3-Jun-2022	TUMKUR	220	MADHUGIRI 220kV-GOWRIBIDANUR220	MADHUGIRI 220kV	23:22	0:00	0:38	LINE FAULT
847	3-Jun-2022	TUMKUR	220	TR1 AND TR2	BENKIKERE_220	2:07	2:39	0:32	MAIN SUPPLY FAILURE
848	3-Jun-2022	TUMKUR	220	TR1	BENKIKERE_220	2:11	3:18	1:07	MAIN SUPPLY FAILURE
849	3-Jun-2022	TUMKUR	220	TR2	BENKIKERE_220	2:11	3:18	1:07	MAIN SUPPLY FAILURE
850	3-Jun-2022	TUMKUR	220	HONNALLI 220kV-DAVANGERE-220	DAVANGERE-220	2:08	2:37	0:29	LINE FAULT
851	3-Jun-2022	TUMKUR	220	TR1	ANTHRASANAHALLI_220	12:28	17:15	4:47	LINE CLEAR AVAILED
852	3-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66, MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	11:13	11:22	0:09	HAND TRIPPED
853	3-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66, MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	17:22	17:26	0:04	HAND TRIPPED
854	3-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66, MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	21:16	21:49	0:33	LINE FAULT
855	3-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLTEGERE	KOLTEGERE, CHIKKATOTLUKER E_66, BELADARA_66	21:57	22:24	0:27	LINE FAULT
856	3-Jun-2022	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	9:48	9:56	0:08	LINE FAULT
857	3-Jun-2022	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	9:56	10:20	0:24	LINE FAULT
858	3-Jun-2022	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	10:20	23:59	13:40	LINE CLEAR AVAILED
859	3-Jun-2022	TUMKUR	66	HIRIYURKV 220KV-SUZLON 1	SUZLON1_IPP_66	12:10	14:53	2:43	LINE CLEAR AVAILED
860	3-Jun-2022	TUMKUR	66	HIRIYUR_220-PARSHAMPURA 66	HIRIYUR_220	1:00	1:20	0:20	LINE FAULT
861	3-Jun-2022	TUMKUR	66	HIRIYUR_220-PARSHAMPURA 66	HIRIYUR_220	2:03	6:30	4:27	LINE FAULT
862	3-Jun-2022	TUMKUR	66	BENKIKERE-CHANNAGIRI(NALLUR)	BENKIKERE_220	2:08	3:13	1:05	MAIN SUPPLY FAILURE
863	3-Jun-2022	TUMKUR	66	BENKIKERE-MALADIHALLI 66	BENKIKERE_220	2:09	3:14	1:05	MAIN SUPPLY FAILURE
864	3-Jun-2022	TUMKUR	66	BENKIKERE-GOPPENAHALLI 66	BENKIKERE_220	2:10	3:15	1:05	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
865	3-Jun-2022	TUMKUR	66	HONNALLI 220kV-KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	17:20	17:42	0:22	MAIN SUPPLY FAILURE
866	3-Jun-2022	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	2:00	2:39	0:39	MAIN SUPPLY FAILURE
867	3-Jun-2022	TUMKUR	66	HONNALI66-HONNALLI220	HONNALI_66	2:00	2:39	0:39	MAIN SUPPLY FAILURE
868	3-Jun-2022	TUMKUR	66	HONNALLI 220KV-NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	2:00	2:39	0:39	MAIN SUPPLY FAILURE
869	3-Jun-2022	TUMKUR	66	HONNALLI 220kV-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	2:00	2:39	0:39	MAIN SUPPLY FAILURE
870	3-Jun-2022	TUMKUR	66	HONNALLI 220kV-KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	2:00	2:39	0:39	MAIN SUPPLY FAILURE
871	3-Jun-2022	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	2:00	2:39	0:39	MAIN SUPPLY FAILURE
872	3-Jun-2022	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	9:13	9:15	0:02	LINE CLEAR AVAILED
873	3-Jun-2022	TUMKUR	66	TR1 AND TR2	KALAMARANAHALLI_66	13:00	13:20	0:20	MAIN SUPPLY FAILURE
874	3-Jun-2022	TUMKUR	66	TR1 AND TR2	KALAMARANAHALLI_66	14:05	14:10	0:05	MAIN SUPPLY FAILURE
875	3-Jun-2022	TUMKUR	66	KALAMARANAHALLI-HIRIYUR220KV	KALAMARANAHALLI_66	18:30	18:50	0:20	LINE CLEAR AVAILED
876	3-Jun-2022	TUMKUR	66	TR1	HIRIYUR-66	8:25	8:55	0:30	LINE CLEAR AVAILED
877	3-Jun-2022	TUMKUR	66	TR1	MATHOD-66	16:15	16:20	0:05	TRANSFORMER FAULT
878	3-Jun-2022	TUMKUR	66	TR1 AND TR2	RANGNATHAPURA-66	1:55	2:10	0:15	HAND TRIPPED
879	3-Jun-2022	TUMKUR	66	TR1	SASUVEHALLI_66	16:45	19:10	2:25	LINE CLEAR AVAILED
880	3-Jun-2022	TUMKUR	66	TR1	SASUVEHALLI_66	23:59	16:30	16:31	LINE CLEAR AVAILED
881	3-Jun-2022	TUMKUR	66	TR1 AND TR2	PD KOTE 66	9:15	9:25	0:10	MAIN SUPPLY FAILURE
882	3-Jun-2022	TUMKUR	66	TR1 AND TR2	PD KOTE 66	13:00	13:30	0:30	MAIN SUPPLY FAILURE
883	3-Jun-2022	TUMKUR	66	CLEAR SOLAR	PD KOTE 66	13:00	13:35	0:35	MAIN SUPPLY FAILURE
884	3-Jun-2022	TUMKUR	66	TR1 AND TR2	PD KOTE 66	14:05	14:10	0:05	MAIN SUPPLY FAILURE
885	3-Jun-2022	TUMKUR	66	CLEAR SOLAR	PD KOTE 66	14:05	14:15	0:10	MAIN SUPPLY FAILURE
886	3-Jun-2022	TUMKUR	66	TR1 AND TR2	DASUDI	9:50(3.6.22)			MAIN SUPPLY FAILURE
887	4-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
888	4-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55(28.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
889	4-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
890	4-Jun-2022	BAGALKOT	220	BELGAUM-AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)			LINE CLEAR AVAILED
891	4-Jun-2022	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110	9:02(01.06.2022)	12:25(04.06.2022)	75:23hrs	LINE CHARGED
892	4-Jun-2022	BAGALKOT	220	AMBEWADI- PONDA-2	STATION NOT AFFECTED AMBEWADI_220	14:30:00(02.06.2022)	18:59 (04.06.2022)	52:29hrs	LINE CHARGED
893	4-Jun-2022	BAGALKOT	110	AEQUS-HUKKERI	STATION NOT AFFECTED AEQUS_220	12:00	12:37	0:37	LINE CLEAR AVAILED
894	4-Jun-2022	BAGALKOT	110	AEQUS-SANKESHWAR	STATION NOT AFFECTED AEQUS_220	15:39	18:49	3:10	LINE CLEAR AVAILED
895	4-Jun-2022	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	5:21	6:03	0:42	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
896	4-Jun-2022	BAGALKOT	110	BELLATTI-AB-SLR	BELLATTI_110	5:21	6:03	0:42	HAND TRIPPED
897	4-Jun-2022	BAGALKOT	110	BELLATTI-LAXMESHWAR	BELLATTI_110	5:17	5:52	0:35	LINE FAULT
898	4-Jun-2022	BAGALKOT	110	110/11KV,HV1	BISNAL_110	8:00	11:33	3:33	LINE CLEAR AVAILED
899	4-Jun-2022	BAGALKOT	110	110/33KV,HV3	KULLOLLI_33,GOKAK MILLS_33 GHATAPRABHA_110	11:22	12:04	0:42	TRANSFORMER FAULT
900	4-Jun-2022	BAGALKOT	110	110/33KV,HV3	KULLOLLI_33,GOKAK MILLS_33 GHATAPRABHA_110	12:04	14:01	1:57	TRANSFORMER FAULT
901	4-Jun-2022	BAGALKOT	110	110/33KV,HV3	KULLOLLI_33,GOKAK MILLS_33 GHATAPRABHA_110	14:03	14:06	0:03	TRANSFORMER FAULT
902	4-Jun-2022	BAGALKOT	110	HALIYAL-GMR(ALNAVAR)	HALIYAL_110	18:58	19:05	0:07	LINE FAULT
903	4-Jun-2022	BAGALKOT	110	HALIYAL-GMR(ALNAVAR)	HALIYAL_110	19:05	19:09	0:04	LINE FAULT
904	4-Jun-2022	BAGALKOT	110	ILKAL-AVADA SOLAR	ILKAL_110	13:33	13:56	0:23	LINE FAULT
905	4-Jun-2022	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110	6:44	10:05	3:21	LINE CLEAR AVAILED
906	4-Jun-2022	BAGALKOT	110	LAXMESHWAR-BELLATTI	LAXMESHWAR_110	5:20	5:51	0:31	LINE FAULT
907	4-Jun-2022	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	15:04	15:42	0:38	TRANSFORMER FAULT
908	4-Jun-2022	BAGALKOT	110	SOUDATTI-RAMDURGA	RAMDURGA_110	20:11	20:42	0:31	HAND TRIPPED
909	4-Jun-2022	BAGALKOT	110	110/11KV,HV1	RATTIHALI_110	11:25	18:57	7:32	LINE CLEAR AVAILED
910	4-Jun-2022	BAGALKOT	110	SHIGGOAN- RAMANAKOPPA(MUNDAGO D)	SHIGGOAN_110	13:45	20:22	6:37	LINE CLEAR AVAILED
911	4-Jun-2022	BAGALKOT	110	SAVALAGI-TODALBAGI	TODALABAGI_110	14:00	14:23	0:23	LINE CLEAR AVAILED
912	4-Jun-2022	BAGALKOT	110	UMMACHAGI-KIRUVATTI	UMMACHAGI_110	15:20	18:30	3:10	HAND TRIPPED
913	4-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YADAWAD_110	11:19	11:24	0:05	TRANSFORMER FAULT
914	4-Jun-2022	BAGALKOT	110	MAHALINGAPUR220- HIDKAL	HIDKAL_110	2:58	3:14	0:16	LINE FAULT
915	4-Jun-2022	BAGALKOT	220	AMBEWADI- PONDA1	STATION NOT AFFECTED AMBEWADI_220	10:05	18:47	8:42	LINE CLEAR AVAILED
916	4-Jun-2022	BAGALKOT	220	BIDNAL- NARENDRA	STATION NOT AFFECTED BIDNAL_220	11:24	17:50	6:26	LINE CLEAR AVAILED
917	4-Jun-2022	BAGALKOT	110	CHIKKODI220- SANKESHWAR	STATION NOT AFFECTED CHIKKODI_220	15:20	19:15	3:55	LINE CLEAR AVAILED
918	4-Jun-2022	BAGALKOT	110	CHIKKODI220- RAIBAG2	STATION NOT AFFECTED CHIKKODI_220	9:27	13:40	4:13	LINE CLEAR AVAILED
919	4-Jun-2022	BAGALKOT	110	220/110KV, LV1	KARWAR_220	03:30	03:48	0:18	HAND TRIPPED
920	4-Jun-2022	BAGALKOT	110	KARWAR220- ARGA (KUMATA)	KARWAR_220	3:30	3:45	0:15	HAND TRIPPED
921	4-Jun-2022	BAGALKOT	110	GHATAPRABHA220- SHIRGAON	GHATAPRABHA_220	14:12	14:28	0:16	LINE FAULT
922	4-Jun-2022	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_220	23:16	23:35	0:19	LINE FAULT
923	4-Jun-2022	BAGALKOT	220	MK HUBLI-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	10:38	14:40	5:02	LINE CLEAR AVAILED
924	4-Jun-2022	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED MUGALKHOD_220	09:36	11:16	1:40	LINE CLEAR AVAILED
925	4-Jun-2022	BAGALKOT	220	NARENDRA- HAVERI1 (BIDNAL)	STATION NOT AFFECTED NARENDRA_220	11:27	17:49	6:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
926	4-Jun-2022	BAGALKOT	110	SOUDATTI220- NARAGUND (RAMDURG2)	SOUDATTI_220	10:41	14:06	3:25	LINE CLEAR AVAILED
927	4-Jun-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	12:50	15:09	2:19	HAND TRIPPED
928	4-Jun-2022	BAGALKOT	110	110/11KV, HV1	UDYAMBAG_110	20:21 (04.06.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
929	4-Jun-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT
930	4-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVAILED
931	4-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVAILED
932	4-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
933	4-Jun-2022	BAGALKOT	110	SOUDATTI220- RAMDURG1	SOUDATTI_220	10:40	14:11	3:31	LINE CLEAR AVAILED
934	4-Jun-2022	BAGALKOT	110	110/11KV, HV1	UDAKERI_110	18:05	18:50	0:45	LINE CLEAR AVAILED
935	4-Jun-2022	BAGALKOT	110	110/11KV, HV2	UDAKERI_110	18:55	19:55	1:00	LINE CLEAR AVAILED
936	4-Jun-2022	BAGALKOT	220	KARWAR- KADRA2	KARWAR_220	3:12 (04.06.2022)			LINE OPEN,LINE FAULT
937	4-Jun-2022	BAGALKOT	110	220/110KV, LV2	KARWAR_220	03:30	03:48	0:18	HAND TRIPPED
938	4-Jun-2022	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	09:18	09:41	0:23	HAND TRIPPED
939	4-Jun-2022	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	16:19	16:31	0:12	HAND TRIPPED
940	4-Jun-2022	BAGALKOT	110	UMMACHAGI - KIRVATTI	STATION NOT AFFECTED UMMACHAGI_110	15:25	18:30	3:05	NFBC ISSUED
941	4-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	11:47	11:57	0:10	LINE FAULT
942	4-Jun-2022	BAGALKOT	110	110/33KV, HV3	BELUR_110	12:00	18:21	6:21	LINE CLEAR AVAILED
943	4-Jun-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	SHIRAGUPPI_110, BILAGI_110, GIRISAGAR_110, TOLAMATTI_110& BISNAL_110	05:45	05:50	0:05	LINE FAULT
944	4-Jun-2022	BAGALKOT	110	110/11KV, HV1	BISANAL_110	8:00	11:35	3:35	LINE CLEAR AVAILED
945	4-Jun-2022	BAGALKOT	110	HALIYAL-ALNAVAR	HALIYAL_110	18:59	19:04	0:05	LINE FAULT
946	4-Jun-2022	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	13:08	15:11	2:03	LINE CLEAR AVAILED
947	4-Jun-2022	BENGALURU	66	BANASAWADI - HEBBALA 220	BANASAWADI	14:16	14:20	0:04	LOAD CHANGE OVER
948	4-Jun-2022	BENGALURU	66	BANASAWADI - ITI 220	BANASAWADI	17:11	17:15	0:04	LOAD CHANGE OVER
949	4-Jun-2022	BENGALURU	66	HV2	BG ROAD	16:26	16:30	0:04	LINE CLEAR AVAILED
950	4-Jun-2022	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	18:48	19:03	0:15	MAIN SUPPLY FAILURE
951	4-Jun-2022	BENGALURU	220	HOODY 400 - SOMANAHALLI 220	NO STATION AFFECTED	17:48	21:57	4:09	LINE FAULT
952	4-Jun-2022	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	10:57	14:00	3:03	LINE CLEAR AVAILED
953	4-Jun-2022	BENGALURU	220	HOODY 220 - HBR LAYOUT 220	HBR LAYOUT 220	18:46	19:21	0:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
954	4-Jun-2022	BENGALURU	66	HBR LAYOUT 220 - KONDASPURA	KONDASPURA	18:46	19:25	0:39	MAIN SUPPLY FAILURE
955	4-Jun-2022	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	12:17	12:29	0:12	LINE CLEAR AVAILED
956	4-Jun-2022	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	13:27	14:12	0:45	LINE FAULT
957	4-Jun-2022	BENGALURU	66	HV3	MANYATHA TECH PARK 220	18:51	19:22	0:31	LOAD CHANGE OVER
958	4-Jun-2022	BENGALURU	66	HV2	ST JOHN WOOD	8:01	8:04	0:03	TRANSFORMER FAULT
959	4-Jun-2022	BENGALURU	66	HV2	ST JOHN WOOD	8:33	8:36	0:03	TRANSFORMER FAULT
960	4-Jun-2022	BENGALURU	66	HV2	ST JOHN WOOD	18:41	18:43	0:02	TRANSFORMER FAULT
961	4-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	18:50	19:16	0:26	LINE FAULT
962	4-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	22:56	23:33	0:37	LINE FAULT
963	4-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	23:08	23:17	0:09	LINE FAULT
964	4-Jun-2022	BENGALURU	66	HV1	VIJAYANAGARA	14:38	15:19	0:41	MAIN SUPPLY FAILURE
965	4-Jun-2022	BENGALURU	66	HV2	VIJAYANAGARA	14:41	15:26	0:45	MAIN SUPPLY FAILURE
966	4-Jun-2022	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	14:20	14:22	0:02	LINE CLEAR AVAILED
967	4-Jun-2022	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	17:20	17:22	0:02	LOAD CHANGE OVER
968	4-Jun-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	14:12	15:09	0:57	LINE CLEAR AVAILED
969	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	9:41	9:46	0:05	LINE CLEAR AVAILED
970	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	9:41	9:47	0:06	LINE CLEAR AVAILED
971	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	9:41	9:47	0:06	LINE CLEAR AVAILED
972	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	9:46	9:56	0:10	LINE FAULT
973	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	9:51	9:55	0:04	LINE CLEAR AVAILED
974	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	9:51	9:55	0:04	LINE CLEAR AVAILED
975	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	17:07	17:12	0:05	LINE CLEAR AVAILED
976	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	17:07	17:12	0:05	LINE CLEAR AVAILED
977	4-Jun-2022	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	17:07	17:12	0:05	LINE CLEAR AVAILED
978	4-Jun-2022	BENGALURU	66	LV2	MITTEMARI 220	9:51	18:47	8:56	LINE CLEAR AVAILED
979	4-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	16:37	16:54	0:17	LINE FAULT
980	4-Jun-2022	BENGALURU	220	KOLAR 220 - MALUR 3	NO STATION AFFECTED	0:16	1:00	0:44	LINE CLEAR AVAILED
981	4-Jun-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	17:28	17:40	0:12	LINE FAULT
982	4-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	20:06	20:17	0:11	LINE FAULT
983	4-Jun-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:31	19:45	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
984	4-Jun-2022	BENGALURU	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	19:00	19:23	0:22	LINE FAULT
985	4-Jun-2022	BENGALURU	66	HV1	YEDUMADU	13:12	13:15	0:02	LINE CLEAR AVAILED
986	4-Jun-2022	BENGALURU	66	HV2	YEDUMADU	11:27	11:35	0:07	LINE CLEAR AVAILED
987	4-Jun-2022	BENGALURU	66	HV2	TYAMAGONDLU	20:03	20:14	0:11	TRANSFORMER FAULT
988	4-Jun-2022	BENGALURU	66	HV1	SIRIGIRIPURA	16:20	16:40	0:20	LINE CLEAR AVAILED
989	4-Jun-2022	BENGALURU	66	HV2	SARJAPURA 220	9:21	9:39	0:17	TRANSFORMER FAULT
990	4-Jun-2022	BENGALURU	66	HV1	KOLAR 220	11:03	11:35	0:32	LINE CLEAR AVAILED
991	4-Jun-2022	BENGALURU	66	HV1	KOLAR 220	13:38	14:33	0:55	LINE CLEAR AVAILED
992	4-Jun-2022	BENGALURU	66	HV2	KOLAR 220	11:00	17:21	6:21	LINE CLEAR AVAILED
993	4-Jun-2022	BENGALURU	66	HV2	JANGAMKOTE	8:06	8:10	0:03	LINE CLEAR AVAILED
994	4-Jun-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	11:25	11:40	0:15	TRANSFORMER FAULT
995	4-Jun-2022	BENGALURU	66	HV1	BAGEPALLI	10:20	10:25	0:05	LINE CLEAR AVAILED
996	4-Jun-2022	BENGALURU	66	HV2	BAGEPALLI	15:55	16:05	0:10	TRANSFORMER FAULT
997	4-Jun-2022	BENGALURU	66	HV1	KEMBODI	11:50	12:15	0:25	LINE CLEAR AVAILED
998	4-Jun-2022	BENGALURU	220	HV1	GOWRIBIDANUR 220	12:15	12:25	0:10	LINE CLEAR AVAILED
999	4-Jun-2022	BENGALURU	66	HV1	LAKSHMIPURA	8:00	8:30	0:30	LINE CLEAR AVAILED
1000	4-Jun-2022	BENGALURU	66	HV2	NANDIGANAHALLI	10:30	10:55	0:25	LINE CLEAR AVAILED
1001	4-Jun-2022	BENGALURU	66	HV1	TAMAKA	7:20	7:30	0:10	TRANSFORMER FAULT
1002	4-Jun-2022	BENGALURU	66	HV1	TAMAKA	13:25	13:35	0:10	TRANSFORMER FAULT
1003	4-Jun-2022	BENGALURU	66	HV1	DALSANUR	1:40	1:50	0:10	TRANSFORMER FAULT
1004	4-Jun-2022	BENGALURU	66	AVANI - T GOLAHALLI 220	AVANI, MULBAGLU	18:50	19:20	0:30	LINE FAULT
1005	4-Jun-2022	BENGALURU	66	HV2	AVANI	12:00	12:10	0:10	TRANSFORMER FAULT
1006	4-Jun-2022	BENGALURU	66	HV2	AVANI	14:50	15:25	0:35	LINE CLEAR AVAILED
1007	4-Jun-2022	BENGALURU	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA, MELUR, JAGAMKOTE	21:31	21:38	0:07	LINE FAULT
1008	4-Jun-2022	BENGALURU	66	ISKCON - SUBRAMANYAPURA 220	ISKCON	8:14	8:17	0:03	LOAD CHANGE OVER
1009	4-Jun-2022	BENGALURU	66	KANAKPURA 220 - CHANNAPATNA	ALLIMARDANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	22:37	22:47	0:10	LINE FAULT
1010	4-Jun-2022	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	21:07(4-6-2022)			LINE OPEN,LINE FAULT
1011	4-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	23:17:00(04/06/2022)			LINE OPEN,LINE FAULT
1012	4-Jun-2022	BENGALURU	220	KOLAR 220 - MALUR 3	NO STATION AFFECTED	18:27(3-6-2022)	1:03(4-6-2022)	6:35hrs	LINE CHARGED
1013	4-Jun-2022	BENGALURU	220	MALUR 220 - KOLAR 3	NO STATION AFFECTED	18:27(3-6-2022)	1:03(4-6-2022)	6:35hrs	LINE CHARGED
1014	4-Jun-2022	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 2	NO STATION AFFECTED	23:59	9:15	9:16	LINE FAULT
1015	4-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN,LINE FAULT
1016	4-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.5.22)			LINE OPEN, LINE CLEAR AVAILED
1017	4-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1018	4-Jun-2022	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	17:18(04.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1019	4-Jun-2022	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	8:39	17:30	8:51	LINE CLEAR AVAILED
1020	4-Jun-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	9:10	17:31	8:21	LINE CLEAR AVAILED
1021	4-Jun-2022	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	4:39	6:17	1:38	LINE FAULT
1022	4-Jun-2022	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNGA_220	10:46	20:02	9:16	LINE CLEAR AVAILED
1023	4-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1024	4-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	6:27	6:35	0:08	TRANSFORMER FAULT
1025	4-Jun-2022	GULBARGA	110	HV1	YELBURGA_110	6:45	6:59	0:14	TRANSFORMER FAULT
1026	4-Jun-2022	GULBARGA	110	HV2	YELBURGA_110	6:45	7:02	0:17	TRANSFORMER FAULT
1027	4-Jun-2022	GULBARGA	110	HV2	HATTI_110	19:34	19:40	0:06	TRANSFORMER FAULT
1028	4-Jun-2022	GULBARGA	110	HV2	HATTI_110	21:49	21:54	0:05	TRANSFORMER FAULT
1029	4-Jun-2022	GULBARGA	110	HV2	HATTI_110	22:12	22:32	0:20	TRANSFORMER FAULT
1030	4-Jun-2022	GULBARGA	110	HV2	HATTI_110	23:06	23:32	0:26	TRANSFORMER FAULT
1031	4-Jun-2022	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	21:10	21:40	0:30	MAIN SUPPLY FAILURE
1032	4-Jun-2022	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	21:00	21:25	0:25	LINE FAULT
1033	4-Jun-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	23:49	23:54	0:05	LINE FAULT
1034	4-Jun-2022	GULBARGA	110	SINDHANOOR220-SINDHANOOR1,2	SINDHANOOR_110,MUDDAPUR_110,MASKI_110,HATTI_110,VALKAMDINNI_110,BYAGWAT_110	8:25	13:45	5:20	LINE CLEAR AVAILED
1035	4-Jun-2022	GULBARGA	110	SINDHANOOR220-VALABALLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADAVI AMARESHWAR_110	8:25	13:05	4:40	LINE CLEAR AVAILED
1036	4-Jun-2022	GULBARGA	110	SINDHANOOR220-SIRUGUPPA	DHADESUGUR_110,SIRUGUPPA_A_110,TEKKALKOTE_110,NSL SUGAR_IPP,SIRIGERECROSS_110	8:25	13:05	4:40	LINE CLEAR AVAILED
1037	4-Jun-2022	GULBARGA	110	SINDHANOOR220-MUNIRABAD1	KARATAGI_110,SRNAGAR_110,GANGAVATHI_110,VENKATGIRI_110	19:45	19:55	0:10	LINE FAULT
1038	4-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	17:10	18:10	1:00	LINE CLEAR AVAILED
1039	4-Jun-2022	GULBARGA	66	HV2	BENNEHALLI_66	10:20	10:40	0:20	TRANSFORMER FAULT
1040	4-Jun-2022	GULBARGA	66	CHORNOOR-ACMESOLAR_IPP	CHORNOOR_66	11:30	12:00	0:30	LINE FAULT
1041	4-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1042	4-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1043	4-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1044	4-Jun-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1045	4-Jun-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1046	4-Jun-2022	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:36	15:55	5:19	LINE FAULT
1047	4-Jun-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	12:58	13:09	0:11	LINE FAULT
1048	4-Jun-2022	HASSAN	220	SHRAVITY-SHIMOGA4	gen_sharavaty	10:36	15:55	5:19	LINE FAULT
1049	4-Jun-2022	HASSAN	110	MRSSHM-SS1	MRSMSG_220	9:55	12:52	2:57	LINE CLEAR AVAILED
1050	4-Jun-2022	HASSAN	110	ALKOLA-MRS	ALKOLA_110	9:55	12:52	2:57	HAND TRIPPED
1051	4-Jun-2022	HASSAN	110	BARANGI-ANVATTI	BARANGI_110	12:30	18:00	5:30	LINE CLEAR AVAILED
1052	4-Jun-2022	HASSAN	110	BARANGI-SHR220	BARANGI_110	12:40	18:20	5:40	LOAD CHANGE OVER
1053	4-Jun-2022	HASSAN	110	HV1	SALATHUR_110	10:21	14:26	4:05	LINE CLEAR AVAILED
1054	4-Jun-2022	HASSAN	66	HV2	ARAKALGUD_66	0:02	0:10	0:08	TRANSFORMER FAULT
1055	4-Jun-2022	HASSAN	66	BASAVAG-DUDDA	BASAVAGATTA_66	11:10	14:00	2:50	MAIN SUPPLY FAILURE
1056	4-Jun-2022	HASSAN	66	HV2	BASAVAGATTA_66	11:35	14:20	2:45	LINE CLEAR AVAILED
1057	4-Jun-2022	HASSAN	66	HV3	BASAVAGATTA_66	12:05	14:20	2:15	LINE CLEAR AVAILED
1058	4-Jun-2022	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA_66	11:29	13:53	2:24	LINE CLEAR AVAILED
1059	4-Jun-2022	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	10:20	13:50	3:30	MAIN SUPPLY FAILURE
1060	4-Jun-2022	HASSAN	66	HV1	DUDDA_66	10:20	14:50	4:30	LINE CLEAR AVAILED
1061	4-Jun-2022	HASSAN	66	HV2	DUDDA_66	13:30	14:55	1:25	LINE CLEAR AVAILED
1062	4-Jun-2022	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:18	13:11	2:53	LINE CLEAR AVAILED
1063	4-Jun-2022	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:18	14:55	4:37	LINE CLEAR AVAILED
1064	4-Jun-2022	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	10:18	10:24	0:06	HAND TRIPPED
1065	4-Jun-2022	HASSAN	66	HV1 CB	HETTUR_66	10:30	16:20	5:50	LINE CLEAR AVAILED
1066	4-Jun-2022	HASSAN	66	HV1	KIADB_66	10:20	15:15	4:55	LINE CLEAR AVAILED
1067	4-Jun-2022	HASSAN	66	HV2	KIADB_66	10:20	15:20	5:00	LINE CLEAR AVAILED
1068	4-Jun-2022	HASSAN	66	KIADBH-RAMESWARNAGAR	KIADB_66	10:20	15:20	5:00	LINE CLEAR AVAILED
1069	4-Jun-2022	HASSAN	66	MALALI-CRPATNA	MALALI_66	15:00	15:10	0:10	LINE FAULT
1070	4-Jun-2022	HASSAN	66	HV2	RAMNATHPURA_66	10:20	16:00	5:40	LINE CLEAR AVAILED
1071	4-Jun-2022	HASSAN	66	HV2	RAMESHWARNAGARA_66	14:45	18:25	3:40	TRANSFORMER FAULT
1072	4-Jun-2022	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	10:15	15:15	5:00	HAND TRIPPED
1073	4-Jun-2022	HASSAN	66	HASSAN2	UDDURKOPPALU_66	10:20	10:25	0:05	HAND TRIPPED
1074	4-Jun-2022	HASSAN	66	HASSAN2	UDDURKOPPALU_66	10:10	13:15	3:05	HAND TRIPPED
1075	4-Jun-2022	MYSURU	66	BG NAGARA-HIRISAVE	KADABALLY_66	19:15	19:24	0:08	LINE FAULT
1076	4-Jun-2022	MYSURU	66	HV1	COWDALLI_66	5:50	5:55	0:05	TRANSFORMER FAULT
1077	4-Jun-2022	MYSURU	66	CR NAGARA- CHANDAKAVADI	CHANDAKAVADI_66	13:26	13:34	0:07	LINE FAULT
1078	4-Jun-2022	MYSURU	66	CR NAGARA-DR PETE 2	NO STATIONS EFFECTED	13:26	13:36	0:10	LINE FAULT
1079	4-Jun-2022	MYSURU	66	CR NAGARA-HONNALLI	ARKALVADI_66 ATTIGULIPURA_66 HONNALLY MYS 66	13:26	13:35	0:09	LINE FAULT
1080	4-Jun-2022	MYSURU	66	DATTAGALLI-HOOTAGALLI	NO STATIONS EFFECTED	9:19	12:05	2:46	NFBC ISSUED
1081	4-Jun-2022	MYSURU	66	HV2	HAMPAPURA_66	8:28	14:09	5:41	LINE CLEAR AVAILED
1082	4-Jun-2022	MYSURU	66	HV1	HANAGODU_66	0:56	1:23	0:27	TRANSFORMER FAULT
1083	4-Jun-2022	MYSURU	66	HV1	HANAGODU_66	8:26	9:41	1:15	TRANSFORMER FAULT
1084	4-Jun-2022	MYSURU	66	HV1	HANAGODU_66	19:30	19:47	0:16	TRANSFORMER FAULT
1085	4-Jun-2022	MYSURU	66	HOOTAGALLI-BARC 1	NO STATIONS EFFECTED	9:41	11:26	1:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1086	4-Jun-2022	MYSURU	66	HOOTAGALLI-BARC 1	NO STATIONS EFFECTED	12:50	14:03	1:13	LINE CLEAR AVAILED
1087	4-Jun-2022	MYSURU	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	12:50	14:03	1:13	LINE CLEAR AVAILED
1088	4-Jun-2022	MYSURU	66	HV1	KADAKOLA_220	13:05	13:54	0:49	LINE CLEAR AVAILED
1089	4-Jun-2022	MYSURU	66	HV1	KOLKARANADODDI_66	12:35	13:20	0:45	LINE CLEAR AVAILED
1090	4-Jun-2022	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU 66	3:26	3:28	0:02	LINE FAULT
1091	4-Jun-2022	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU 66	5:07	5:12	0:05	LINE FAULT
1092	4-Jun-2022	MYSURU	66	KOPPA-NAGAMANGALA 220	NO STATIONS EFFECTED	12:00	17:00	5:00	HAND TRIPPED
1093	4-Jun-2022	MYSURU	66	MADHUVANAHALLI- LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA 66	5:53	5:58	0:05	LINE FAULT
1094	4-Jun-2022	MYSURU	66	HV2	MADIKERI_66	13:17	15:33	2:15	LINE CLEAR AVAILED
1095	4-Jun-2022	MYSURU	66	PERIYAPATNA- KUSHALANAGARA 1	NO STATIONS EFFECTED	10:00	10:30	0:30	LINE CLEAR AVAILED
1096	4-Jun-2022	MYSURU	66	PERIYAPATNA- KUSHALANAGARA 2	NO STATIONS EFFECTED	10:31	11:05	0:34	LINE CLEAR AVAILED
1097	4-Jun-2022	MYSURU	66	PERIYAPATNA- KAMPLAPURA	KAMPALAPURA_66	10:10	14:53	4:43	LINE CLEAR AVAILED
1098	4-Jun-2022	MYSURU	66	HV1	PERIYAPATNA_66	11:10	17:05	5:55	LINE CLEAR AVAILED
1099	4-Jun-2022	MYSURU	66	HV2	PERIYAPATNA_66	10:00	18:03	8:03	LINE CLEAR AVAILED
1100	4-Jun-2022	MYSURU	66	HV2	SHIVALLY_66	8:01	8:38	0:36	LINE CLEAR AVAILED
1101	4-Jun-2022	MYSURU	66	VAJAMANGALA- MEGHALAPURA	MEGHALAPURA_66	10:45	17:46	7:01	NFBC ISSUED
1102	4-Jun-2022	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	5:13	5:22	0:09	LINE FAULT
1103	4-Jun-2022	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	23:08(4.6.22)			LINE OPEN,LINE FAULT
1104	4-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	12:05(4.6.22)			LINE OPEN, LINE CLEAR AVAILED
1105	4-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU- BAS1	NO STATIONS EFFECTED	18:10 (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1106	4-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1107	4-Jun-2022	MYSURU	66	DUNDANAHALLY- HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)	12:00:00	843:23HRs	LINE CHARGED
1108	4-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1109	4-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1110	4-Jun-2022	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2 (NAGAMANGALA 2)(MAGADI)	ANCHEPALYA_220	21:07(4.6.22)			LINE OPEN,LINE FAULT
1111	4-Jun-2022	TUMKUR	220	MADHUGIRI 220kV- GOWRIBIDANUR220	MADHUGIRI_220	23:22(3.6.22)	1:43(4.6.22)	2:16HRS	LINE CHARGED
1112	4-Jun-2022	TUMKUR	220	BENKIKERE 220kV- HOSADURGA LINE 1	HOSADURGA_66	18:32	19:42	1:10	LINE FAULT
1113	4-Jun-2022	TUMKUR	220	HOSADURGA220- BENKIKERE 1 & 2	HOSADURGA_220	18:30	19:45	1:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1114	4-Jun-2022	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	21:36(4.6.22)			LINE OPEN,LINE FAULT
1115	4-Jun-2022	TUMKUR	66	TR-2	BEVINAHALLI	8:59	9:35	0:36	LINE CLEAR AVAILED
1116	4-Jun-2022	TUMKUR	66	TR-1	KDBVNP_220	12:45	14:01	1:16	LINE CLEAR AVAILED
1117	4-Jun-2022	TUMKUR	66	TR-1	RANGANATAPURA_66	1:59	2:12	0:13	MAIN SUPPLY FAILURE
1118	4-Jun-2022	TUMKUR	66	TR-2	RANGANATAPURA_66	1:59	2:10	0:11	MAIN SUPPLY FAILURE
1119	4-Jun-2022	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WLSPNSOLAR1	2:07	2:21	0:13	MAIN SUPPLY FAILURE
1120	4-Jun-2022	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WLSPNSOLAR2	2:07	2:20	0:13	MAIN SUPPLY FAILURE
1121	4-Jun-2022	TUMKUR	66	TR-1	RANGANATAPURA_66	9:32	10:20	0:48	LINE CLEAR AVAILED
1122	4-Jun-2022	TUMKUR	66	TR-2	RANGANATAPURA_66	9:32	10:20	0:48	LINE CLEAR AVAILED
1123	4-Jun-2022	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WLSPNSOLAR1	9:32	10:23	0:50	LINE CLEAR AVAILED
1124	4-Jun-2022	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WLSPNSOLAR2	9:32	10:23	0:50	LINE CLEAR AVAILED
1125	5-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
1126	5-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55(28.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1127	5-Jun-2022	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1128	5-Jun-2022	BAGALKOT	220	BELGAUM- AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)			LINE CLEAR AVAILED
1129	5-Jun-2022	BAGALKOT	110	110/11KV, HV1	UDYAMBAG_110	20:21 (04.06.2022)	19:12 (05.06.2022)	22:51HRS	TRANSFORMER CHARGED
1130	5-Jun-2022	BAGALKOT	110	AIGALI-SAVALAGI	AIGALI_110	3:53	4:03	0:10	LINE FAULT
1131	5-Jun-2022	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	19:08	19:11	0:03	HAND TRIPPED
1132	5-Jun-2022	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	19:08	19:10	0:02	HAND TRIPPED
1133	5-Jun-2022	BAGALKOT	110	110/33KV,HV1	KABBUR_33 CHIKKODI_110	16:22	16:29	0:07	TRANSFORMER FAULT
1134	5-Jun-2022	BAGALKOT	110	110/33KV,HV1	KABBUR_33 CHIKKODI_110	16:54	17:15	0:21	TRANSFORMER FAULT
1135	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	DEVANAGOAN_110	12:02	12:09	0:07	TRANSFORMER FAULT
1136	5-Jun-2022	BAGALKOT	110	HALIYAL-GMR(ALNAVAR)	HALIYAL_110	0:36	0:47	0:11	LINE FAULT
1137	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIRESMASALI_110	17:09	18:06	0:57	TRANSFORMER FAULT
1138	5-Jun-2022	BAGALKOT	110	GHATAPRABHA-ISLAMPUR	ISLAMPUR_110	4:39	5:10	0:31	LINE FAULT
1139	5-Jun-2022	BAGALKOT	110	BORUKA-ITNAL	ITNAL_110	5:53	6:14	0:21	LINE FAULT
1140	5-Jun-2022	BAGALKOT	110	KABBUR-ITNAL3	ITNAL_110	15:03	15:13	0:10	LINE FAULT
1141	5-Jun-2022	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	2:17	2:26	0:09	TRANSFORMER FAULT
1142	5-Jun-2022	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	JAMAKHANDI_110	19:50(05.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1143	5-Jun-2022	BAGALKOT	110	110/33KV,HV3	MACHE_110	10:45	11:24	0:39	LINE CLEAR AVAILED
1144	5-Jun-2022	BAGALKOT	110	110/33KV,HV4	MACHE_110	11:25	12:15	0:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1145	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	MACHE_110	15:45	16:10	0:25	LINE CLEAR AVAILED
1146	5-Jun-2022	BAGALKOT	110	110/11KV,HV2	MACHE_110	15:22	18:24	3:02	LINE CLEAR AVAILED
1147	5-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	19:27	19:29	0:02	TRANSFORMER FAULT
1148	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	20:09	20:14	0:05	TRANSFORMER FAULT
1149	5-Jun-2022	BAGALKOT	110	110/11KV,HV2	NAVALAGI_110	20:09	20:14	0:05	TRANSFORMER FAULT
1150	5-Jun-2022	BAGALKOT	110	NAVALAGI-JAMAKHANDI	NAVALAGI_110	19:39(05.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1151	5-Jun-2022	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	22:59	23:06	0:07	LINE FAULT
1152	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	TODALABAGI_110	20:01	20:05	0:04	TRANSFORMER FAULT
1153	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	TODALABAGI_110	20:34	20:40	0:06	TRANSFORMER FAULT
1154	5-Jun-2022	BAGALKOT	110	110/11KV,HV1	VADAGOAN_110	9:30	17:31	8:01	LINE CLEAR AVAILED
1155	5-Jun-2022	BAGALKOT	110	110/11KV,HV4	VADAGOAN_110	14:54	17:32	2:38	LINE CLEAR AVAILED
1156	5-Jun-2022	BAGALKOT	110	VADAGOAN-MACHE	VADAGOAN_110	15:08	17:29	2:21	LINE CLEAR AVAILED
1157	5-Jun-2022	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	15:18	17:28	2:10	LINE CLEAR AVAILED
1158	5-Jun-2022	BAGALKOT	110	YELLAMMANAVADI-SAVALAGI	YELLAMMANAVWADI_110	4:06	4:14	0:08	LINE FAULT
1159	5-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJJRAMATTI_110	10:16	18:42	8:26	LINE CLEAR AVAILED
1160	5-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJJRAMATTI_110	10:16	18:42	8:26	LINE CLEAR AVAILED
1161	5-Jun-2022	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	19:17	20:07	0:50	LINE FAULT
1162	5-Jun-2022	BAGALKOT	220	MAHALINGAPUR-VAJJRAMATTI1	MAHALINGAPUR_220	19:17	20:28	1:11	LINE FAULT
1163	5-Jun-2022	BAGALKOT	220	220/110KV, HV3	MAHALINGAPUR_220	19:17	20:35	1:18	TRANSFORMER FAULT
1164	5-Jun-2022	BAGALKOT	220	220/110KV, HV2	MAHALINGAPUR_220	19:17	20:35	1:18	TRANSFORMER FAULT
1165	5-Jun-2022	BAGALKOT	110	220/110KV, LV2	MAHALINGAPUR_220	19:17	20:08	0:51	TRANSFORMER FAULT
1166	5-Jun-2022	BAGALKOT	220	BAGEWADI- FORTUNE FIVE2	STATION NOT AFFECTED BAGEWADI_220	12:33	14:39	2:06	LINE CLEAR AVAILED
1167	5-Jun-2022	BAGALKOT	220	BAGEWADI- RBRK	STATION NOT AFFECTED BAGEWADI_220	20:13	20:41	0:28	LINE FAULT
1168	5-Jun-2022	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	18:42	23:29	4:47	LINE FAULT
1169	5-Jun-2022	BAGALKOT	110	CHIKKODI220-SANKESHWAR	STATION NOT AFFECTED CHIKKODI_220	10:38	10:50	0:12	LINE FAULT
1170	5-Jun-2022	BAGALKOT	110	CHIKKODI220-SANKESHWAR	STATION NOT AFFECTED CHIKKODI_220	15:30	15:40	0:10	LINE FAULT
1171	5-Jun-2022	BAGALKOT	220	KARWAR- KADRA1	KARWAR_220	10:30	19:05	8:35	LINE CLEAR AVAILED
1172	5-Jun-2022	BAGALKOT	110	KARWAR220- BINAGA	KARWAR_220	10:17	10:22	0:05	HAND TRIPPED
1173	5-Jun-2022	BAGALKOT	110	220/110KV, LV1	KARWAR_220	10:18	19:10	8:52	HAND TRIPPED
1174	5-Jun-2022	BAGALKOT	110	KARWAR220- BINAGA	KARWAR_220	19:08	19:15	0:07	HAND TRIPPED
1175	5-Jun-2022	BAGALKOT	110	KARWAR220- ARGA (KUMATA)	KARWAR_220	19:10	19:15	0:05	HAND TRIPPED
1176	5-Jun-2022	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_220	4:39	5:04	0:25	LINE FAULT
1177	5-Jun-2022	BAGALKOT	110	GHATAPRABHA220-KABBUR	GHATAPRABHA_220	19:14	19:23	0:09	LINE FAULT
1178	5-Jun-2022	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	MK HUBLI_220	10:16	12:10	1:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1179	5-Jun-2022	BAGALKOT	110	MK HUBLI220- HIREBAGEWADI	MK HUBLI_220	14:34	14:54	0:20	LINE FAULT
1180	5-Jun-2022	BAGALKOT	110	MUGALKHOD- LN5(ITANAL3)	STATION NOT AFFECTED MUGALKHOD_220	15:03	15:12	0:09	LINE FAULT
1181	5-Jun-2022	BAGALKOT	110	RANEBENNUR220- AREMALLAPUR (HONNATTI)	RANEBENNUR_220	2:00	2:10	0:10	LINE FAULT
1182	5-Jun-2022	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	18:42	23:38	4:56	LINE FAULT
1183	5-Jun-2022	BAGALKOT	110	SOUDATTI220 -MUNAVALLI	SOUDATTI_220	19:26	20:21	0:55	HAND TRIPPED
1184	5-Jun-2022	BAGALKOT	110	SOUDATTI220- BENAKATTI	SOUDATTI_220	19:26	20:13	0:47	HAND TRIPPED
1185	5-Jun-2022	BAGALKOT	110	SOUDATTI220- SOUDATTI1	SOUDATTI_220	19:26	20:17	0:51	HAND TRIPPED
1186	5-Jun-2022	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_220	19:26	20:18	0:52	HAND TRIPPED
1187	5-Jun-2022	BAGALKOT	110	SOUDATTI220- RAMDURGA1	SOUDATTI_220	19:26	20:39	1:13	HAND TRIPPED
1188	5-Jun-2022	BAGALKOT	110	SOUDATTI220- RAMDURGA2	SOUDATTI_220	19:26	20:39	1:13	HAND TRIPPED
1189	5-Jun-2022	BAGALKOT	110	SOUDATTI220- MMCL	SOUDATTI_220	19:26	20:35	1:09	HAND TRIPPED
1190	5-Jun-2022	BAGALKOT	110	SOUDATTI220- UDIKERI	SOUDATTI_220	7:21	20:33	13:12	LINE CLEAR AVAILED
1191	5-Jun-2022	BAGALKOT	110	VAJRAMATTI220 - VAJRAMATTI	VAJRAMATTI_220	10:35	18:26	7:51	LINE CLEAR AVAILED
1192	5-Jun-2022	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	19:17	20:09	0:52	LINE FAULT
1193	5-Jun-2022	BAGALKOT	110	BELGAUM220- ANKALAGI (VADAGOAN)	STATION NOT AFFECTED BELGAUM_220	15:24	17:27	2:03	NFBC ISSUED
1194	5-Jun-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT
1195	5-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVAILED
1196	5-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVAILED
1197	5-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1198	5-Jun-2022	BAGALKOT	220	KARWAR- KADRA2	KARWAR_220	3:12 (04.06.2022)	19:05 (05.06.2022)	39:53HRS	LINE CHARGED
1199	5-Jun-2022	BAGALKOT	110	220/110KV, LV2	KARWAR_220	10:18	19:10	8:52	HAND TRIPPED
1200	5-Jun-2022	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	18:42	23:38	4:56	LINE FAULT
1201	5-Jun-2022	BAGALKOT	220	SOUDATTI- MAHALINGPUR	SOUDATTI_220	19:26	20:08	0:42	HAND TRIPPED
1202	5-Jun-2022	BAGALKOT	220	220/110KV, HV1	SOUDATTI_220	19:26	20:08	0:42	HAND TRIPPED
1203	5-Jun-2022	BAGALKOT	220	220/110KV, HV2	SOUDATTI_220	19:26	20:08	0:42	HAND TRIPPED
1204	5-Jun-2022	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	19:26	20:12	0:46	HAND TRIPPED
1205	5-Jun-2022	BENGALURU	66	BANASAWADI - HEBBALA 220	BANASAWADI	17:01	17:08	0:07	LOAD CHANGE OVER
1206	5-Jun-2022	BENGALURU	66	BANASAWADI - ITI 220	BANASAWADI	20:07	20:12	0:05	LOAD CHANGE OVER
1207	5-Jun-2022	BENGALURU	66	EXORA - CESSNA	EXORA	8:10	15:10	7:00	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1208	5-Jun-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	17:35	17:37	0:02	LOAD CHANGE OVER
1209	5-Jun-2022	BENGALURU	66	HV1	KHODAYS 220	22:06	22:14	0:08	TRANSFORMER FAULT
1210	5-Jun-2022	BENGALURU	66	HV2	NRS 220	23:17	23:23	0:06	LOAD CHANGE OVER
1211	5-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	20:24	20:40	0:16	LINE FAULT
1212	5-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	23:59	5:08	5:09	LINE FAULT
1213	5-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	22:40	22:50	0:10	LINE FAULT
1214	5-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	22:50	23:10	0:20	LINE FAULT
1215	5-Jun-2022	BENGALURU	66	HV1	YARANDANAHALLI 220	5:57	6:41	0:44	LINE CLEAR AVAILED
1216	5-Jun-2022	BENGALURU	66	HV3	YARANDANAHALLI 220	5:57	6:41	0:44	LINE CLEAR AVAILED
1217	5-Jun-2022	BENGALURU	66	HV2	YARANDANAHALLI 220	6:00	6:04	0:04	LINE CLEAR AVAILED
1218	5-Jun-2022	BENGALURU	66	HV1	YARANDANAHALLI 220	18:11	18:43	0:32	LINE CLEAR AVAILED
1219	5-Jun-2022	BENGALURU	66	HV3	YARANDANAHALLI 220	18:11	18:43	0:32	LINE CLEAR AVAILED
1220	5-Jun-2022	BENGALURU	66	HV2	YARANDANAHALLI 220	18:52	18:54	0:02	LINE CLEAR AVAILED
1221	5-Jun-2022	BENGALURU	220	HV2	YARANDANAHALLI 220	6:01	6:29	0:28	LINE CLEAR AVAILED
1222	5-Jun-2022	BENGALURU	220	HV3	YARANDANAHALLI 220	6:01	6:29	0:28	LINE CLEAR AVAILED
1223	5-Jun-2022	BENGALURU	220	HV3	YARANDANAHALLI 220	18:18	18:43	0:25	LINE CLEAR AVAILED
1224	5-Jun-2022	BENGALURU	220	HV2	YARANDANAHALLI 220	18:18	18:43	0:25	LINE CLEAR AVAILED
1225	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	5:57	6:31	0:34	LINE CLEAR AVAILED
1226	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	5:57	6:31	0:34	LINE CLEAR AVAILED
1227	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	5:57	6:31	0:34	LINE CLEAR AVAILED
1228	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	5:57	6:31	0:34	LINE CLEAR AVAILED
1229	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	5:57	6:31	0:34	LINE CLEAR AVAILED
1230	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	18:11	18:44	0:33	LINE CLEAR AVAILED
1231	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	18:11	18:44	0:33	LINE CLEAR AVAILED
1232	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	18:11	18:44	0:33	LINE CLEAR AVAILED
1233	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	18:11	18:44	0:33	LINE CLEAR AVAILED
1234	5-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	18:11	18:47	0:36	LINE CLEAR AVAILED
1235	5-Jun-2022	BENGALURU	220	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	10:40	18:47	8:07	LINE CLEAR AVAILED
1236	5-Jun-2022	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	17:00	17:06	0:06	MAIN SUPPLY FAILURE
1237	5-Jun-2022	BENGALURU	66	HV3	KUMBALAGODU	4:20	4:55	0:35	TRANSFORMER FAULT
1238	5-Jun-2022	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU	8:00	8:15	0:15	LINE CLEAR AVAILED
1239	5-Jun-2022	BENGALURU	66	HV2	MELLAHALLI	13:39	13:55	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1240	5-Jun-2022	BENGALURU	66	MELLAHALLI -KOTIPURA 220	MELLAHALLI	2:20	3:35	1:15	LINE FAULT
1241	5-Jun-2022	BENGALURU	66	KUMBARANAHALLI - YERANDANAHALLI 220	KUMBARANAHALLI, BAGANDODDI	18:20	19:17	0:57	LOAD CHANGE OVER
1242	5-Jun-2022	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	5:52	6:40	0:48	LOAD CHANGE OVER
1243	5-Jun-2022	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	5:40	6:40	1:00	LOAD CHANGE OVER
1244	5-Jun-2022	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	5:53	5:58	0:05	LOAD CHANGE OVER
1245	5-Jun-2022	BENGALURU	220	KOLAR 220 - MALUR 1	NO STATION AFFECTED	21:46	22:16	0:30	LINE FAULT
1246	5-Jun-2022	BENGALURU	220	KOLAR 220 - MALUR 1	NO STATION AFFECTED	21:29	21:46	0:17	LINE FAULT
1247	5-Jun-2022	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR	20:37	20:48	0:11	LINE FAULT
1248	5-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	22:49	23:58	1:09	LINE FAULT
1249	5-Jun-2022	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	MAGADI 220	13:36	13:48	0:12	LOAD CHANGE OVER
1250	5-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	13:36	13:48	0:12	LOAD CHANGE OVER
1251	5-Jun-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVAREKERE	13:36	13:48	0:12	LOAD CHANGE OVER
1252	5-Jun-2022	BENGALURU	66	T G HALLI - TAVAREKERE	TAVAREKERE	19:43	19:53	0:10	LOAD CHANGE OVER
1253	5-Jun-2022	BENGALURU	66	T G HALLI - TAVAREKERE	TAVAREKERE	9:55	17:50	7:55	LINE CLEAR AVAILED
1254	5-Jun-2022	BENGALURU	66	TADIGOLU CROSS - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	20:45	20:55	0:10	LINE FAULT
1255	5-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	22:18	23:01	0:43	LINE FAULT
1256	5-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	23:01	23:05	0:03	LINE FAULT
1257	5-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	20:54	21:10	0:15	LINE FAULT
1258	5-Jun-2022	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	18:50	19:10	0:19	LINE FAULT
1259	5-Jun-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	22:03	22:16	0:13	LINE FAULT
1260	5-Jun-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	20:50	21:11	0:21	LINE FAULT
1261	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	19:03	19:16	0:12	LINE FAULT
1262	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	19:16	21:05	1:49	LINE FAULT
1263	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	21:51	22:00	0:09	LINE FAULT
1264	5-Jun-2022	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENHALLI, CHEEMANGALA	14:11	14:21	0:10	LINE FAULT
1265	5-Jun-2022	BENGALURU	66	AVANI - MULBAGLU	MULBAGAL	20:08	20:24	0:16	LINE FAULT
1266	5-Jun-2022	BENGALURU	66	HV2	Y HUNSENHALLI	17:30	17:46	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1267	5-Jun-2022	BENGALURU	66	HV2	Y HUNSENAHALLI	17:30	17:46	0:16	TRANSFORMER FAULT
1268	5-Jun-2022	BENGALURU	66	HV2	THAYALUR	11:18	11:25	0:07	TRANSFORMER FAULT
1269	5-Jun-2022	BENGALURU	66	HV2	TYAMAGONDLU	16:56	17:06	0:10	TRANSFORMER FAULT
1270	5-Jun-2022	BENGALURU	66	HV2	TYAMAGONDLU	17:06	17:10	0:04	TRANSFORMER FAULT
1271	5-Jun-2022	BENGALURU	66	HV2	NANDAGUDI	11:15	11:25	0:09	LINE CLEAR AVAILED
1272	5-Jun-2022	BENGALURU	66	HV1	ATTIBELE	5:15	5:20	0:05	LOAD CHANGE OVER
1273	5-Jun-2022	BENGALURU	66	HV1	ATTIBELE	20:05	20:10	0:05	LOAD CHANGE OVER
1274	5-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	23:03	23:06	0:03	LINE CLEAR AVAILED
1275	5-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	NO STATION AFFECTED	23:16	23:34	0:18	LINE FAULT
1276	5-Jun-2022	BENGALURU	220	HV1	DB PURA 220	23:16	23:49	0:33	TRANSFORMER FAULT
1277	5-Jun-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	23:16	23:49	0:33	MAIN SUPPLY FAILURE
1278	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	23:16	23:49	0:33	MAIN SUPPLY FAILURE
1279	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	23:16	23:49	0:33	MAIN SUPPLY FAILURE
1280	5-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	23:16	23:49	0:33	MAIN SUPPLY FAILURE
1281	5-Jun-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	23:16	23:49	0:33	MAIN SUPPLY FAILURE
1282	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	20:34	21:05	0:31	LINE FAULT
1283	5-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	19:09	19:24	0:15	LINE FAULT
1284	5-Jun-2022	BENGALURU	66	HV2	NARASAPURA	1:20	2:20	1:00	TRANSFORMER FAULT
1285	5-Jun-2022	BENGALURU	66	HV1	T GOLAHALLI	7:45	8:05	0:09	TRANSFORMER FAULT
1286	5-Jun-2022	BENGALURU	66	KANAKPURA 220 - CHANNAPATNA	ALLIMARDANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	22:15	22:32	0:17	LINE FAULT
1287	5-Jun-2022	BENGALURU	220	MALUR 220 - HOODY 220	NO STATION AFFECTED	21:29(5-6-2022)			LINE OPEN,LINE FAULT
1288	5-Jun-2022	BENGALURU	66	HV1	RANGANDODDI	23:03:23(5-6-2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1289	5-Jun-2022	BENGALURU	66	HV1	NELAMANGALA 66	23:59(5-6-2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1290	4-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	23:17(04/06/2022)			LINE OPEN,LINE FAULT
1291	5-Jun-2022	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	21:07(4-6-2022)	19:03(5-6-2022)	21:55HRS	LINE CHARGED
1292	5-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	23:10(05/06/2022)			LINE OPEN,LINE FAULT
1293	5-Jun-2022	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	14:26(05/06/2022)			LINE OPEN,LINE FAULT
1294	5-Jun-2022	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	21:35(05/06/2022)			LINE OPEN,LINE FAULT
1295	5-Jun-2022	BENGALURU	220	HV2	HEBBALA 220	17:00:00(05/06/2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1296	5-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1297	5-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.5.22)			LINE OPEN, LINE CLEAR AVAILED
1298	5-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1299	5-Jun-2022	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	19:39(05.06.2022)			LINE OPEN,LINE FAULT
1300	5-Jun-2022	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	19:39(05.06.2022)			LINE OPEN,LINE FAULT
1301	5-Jun-2022	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	17:18(04.06.2022)	15:53(05.06.2022)	22:35HRS	LINE CHARGED
1302	5-Jun-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	20:01	20:16	0:15	LINE FAULT
1303	5-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNAT HI_IPP,COREGREENSUGARS_I PP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1304	5-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	18:43(5.6.22)			LINE OPEN,LINE FAULT
1305	5-Jun-2022	GULBARGA	110	HV4	DEODURGA_110	20:00(05.06.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1306	5-Jun-2022	GULBARGA	110	SINDHANOOR220-SUZLON	SINDHANOOR_220	23:05(05.06.2022)			LINE OPEN,LINE FAULT
1307	5-Jun-2022	GULBARGA	110	HV3	CHINCHOLI_110	10:59	11:22	0:23	TRANSFORMER FAULT
1308	5-Jun-2022	GULBARGA	110	HV3	CHINCHOLI_110	13:08	13:15	0:07	TRANSFORMER FAULT
1309	5-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	21:58	22:03	0:05	TRANSFORMER FAULT
1310	5-Jun-2022	GULBARGA	110	HV2	SHAHAPUR_220	17:30	17:46	0:16	TRANSFORMER FAULT
1311	5-Jun-2022	GULBARGA	110	HV2	HATTI_110	19:34	19:40	0:06	TRANSFORMER FAULT
1312	5-Jun-2022	GULBARGA	110	HV2	HATTI_110	21:49	21:54	0:05	TRANSFORMER FAULT
1313	5-Jun-2022	GULBARGA	110	HV2	HATTI_110	22:12	22:32	0:20	TRANSFORMER FAULT
1314	5-Jun-2022	GULBARGA	110	HV2	HATTI_110	23:06	23:32	0:26	TRANSFORMER FAULT
1315	5-Jun-2022	GULBARGA	110	HV1	DEODURGA_110	20:00	22:15	2:15	TRANSFORMER FAULT
1316	5-Jun-2022	GULBARGA	110	HV2	DEODURGA_110	20:00	21:45	1:45	TRANSFORMER FAULT
1317	5-Jun-2022	GULBARGA	110	HV3	DEODURGA_110	22:45	23:45	1:00	LINE CLEAR AVAILED
1318	5-Jun-2022	GULBARGA	110	HV1	GOOGLE_110	11:05	11:35	0:30	LINE CLEAR AVAILED
1319	5-Jun-2022	GULBARGA	110	HV1	CHOWDAPUR_110	10:40	10:45	0:05	TRANSFORMER FAULT
1320	5-Jun-2022	GULBARGA	110	HV1	CHOWDAPUR_110	11:20	11:35	0:15	TRANSFORMER FAULT
1321	5-Jun-2022	GULBARGA	110	HV1	CHOWDAPUR_110	12:00	12:05	0:05	TRANSFORMER FAULT
1322	5-Jun-2022	GULBARGA	110	LV1	SINDHANOOR_220	20:01	20:50	0:49	TRANSFORMER FAULT
1323	5-Jun-2022	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	14:30	14:50	0:20	MAIN SUPPLY FAILURE
1324	5-Jun-2022	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	15:05	15:10	0:05	MAIN SUPPLY FAILURE
1325	5-Jun-2022	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	15:20	15:25	0:05	MAIN SUPPLY FAILURE
1326	5-Jun-2022	GULBARGA	110	CHINCHOLI-SEDAM1	CHINCHOLI_110	10:59	11:20	0:21	LINE FAULT
1327	5-Jun-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	21:16	21:24	0:08	LINE FAULT
1328	5-Jun-2022	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	11:54	12:00	0:06	LINE FAULT
1329	5-Jun-2022	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	15:50	16:02	0:12	LINE FAULT
1330	5-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	23:54(5.06.2022)			MAIN SUPPLY FAILURE
1331	5-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	10:57	11:02	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1332	5-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	10:47	11:02	0:15	LOAD CURTAILMENT
1333	5-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:55	11:58	0:03	LINE FAULT
1334	5-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	15:45	15:56	0:11	LINE FAULT
1335	5-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	15:45	15:56	0:11	LINE FAULT
1336	5-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	16:25(05/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1337	5-Jun-2022	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110,VALKAMDINNI_110	22:52	23:00	0:08	LINE FAULT
1338	5-Jun-2022	GULBARGA	110	GANGAVATI-KANAKAGIRI	NAVALI_110,CLEAN SOLAR_IPP	23:40	0:00	0:20	LINE FAULT
1339	5-Jun-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	14:33	14:49	0:16	LINE FAULT
1340	5-Jun-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	15:01	15:09	0:08	LINE FAULT
1341	5-Jun-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	15:19	15:27	0:08	LINE FAULT
1342	5-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:43	18:54	0:11	LINE FAULT
1343	5-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:01	21:20	1:19	LINE FAULT
1344	5-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:24	21:33	0:09	LINE FAULT
1345	5-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:41	21:53	0:12	LINE FAULT
1346	5-Jun-2022	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	VICAT SAGAR_IPP	3:55	4:30	0:35	LINE FAULT
1347	5-Jun-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:00	11:19	0:19	LINE FAULT
1348	5-Jun-2022	GULBARGA	110	STARMETALIC-MUNIRABAD	STARMETALIC_110	17:16	17:28	0:12	LINE FAULT
1349	5-Jun-2022	GULBARGA	110	SINDHANOOR220-LATUR GAMESHA	SINDHANOOR_220	20:01	21:15	1:14	LINE FAULT
1350	5-Jun-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	10:58	11:08	0:10	LINE FAULT
1351	5-Jun-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	15:51	16:03	0:12	LINE FAULT
1352	5-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	17:10	17:55	0:45	LINE CLEAR AVAILED
1353	5-Jun-2022	GULBARGA	66	HV1	BENNEHALLI_66	19:00	19:20	0:20	TRANSFORMER FAULT
1354	5-Jun-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	19:10	19:25	0:15	LINE FAULT
1355	5-Jun-2022	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	19:12	19:20	0:08	LINE FAULT
1356	5-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1357	5-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1358	5-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1359	5-Jun-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT
1360	5-Jun-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1361	5-Jun-2022	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLY_66	19:00(05.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1362	5-Jun-2022	HASSAN	220	HV1	MRSMSG_220	7:53	9:24	1:31	LINE CLEAR AVAILED
1363	5-Jun-2022	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	2:46	13:02	10:16	LINE FAULT
1364	5-Jun-2022	HASSAN	220	VARAH1-SHIMOGA1	gen_varahi	2:46	13:02	10:16	LINE FAULT
1365	5-Jun-2022	HASSAN	110	LV1	MRSMSG_220	7:53	9:24	1:31	LINE CLEAR AVAILED
1366	5-Jun-2022	HASSAN	110	MRSSHM-SS1	MRSMSG_220	7:53	9:24	1:31	HAND TRIPPED
1367	5-Jun-2022	HASSAN	110	MRSSHM-SS2	MRSMSG_220	7:53	9:24	1:31	HAND TRIPPED
1368	5-Jun-2022	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	3:01	3:31	0:30	LINE FAULT
1369	5-Jun-2022	HASSAN	110	HV2	NAVUNDA_110	8:10	8:25	0:15	TRANSFORMER FAULT
1370	5-Jun-2022	HASSAN	110	NERALA-HV2	NERALAKERE_110	18:40	18:50	0:10	LINE FAULT
1371	5-Jun-2022	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	3:01	3:37	0:36	LINE FAULT
1372	5-Jun-2022	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	3:01	3:28	0:27	LINE FAULT
1373	5-Jun-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	16:02	17:15	1:13	LINE FAULT
1374	5-Jun-2022	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	22:05	22:20	0:15	LINE FAULT
1375	5-Jun-2022	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	16:02	17:15	1:13	MAIN SUPPLY FAILURE
1376	5-Jun-2022	HASSAN	66	HV1	BALEHONNUR_66	16:02	17:15	1:13	TRANSFORMER FAULT
1377	5-Jun-2022	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	0:14	0:54	0:40	LINE FAULT
1378	5-Jun-2022	HASSAN	66	HV1	HOLALUR_66	9:30	11:38	2:08	LINE CLEAR AVAILED
1379	5-Jun-2022	HASSAN	66	HV2	HOLALUR_66	9:30	11:38	2:08	LINE CLEAR AVAILED
1380	5-Jun-2022	HASSAN	66	HV1	HOLEHONNUR_66	9:35	11:35	2:00	LINE CLEAR AVAILED
1381	5-Jun-2022	HASSAN	66	HV2	HOLEHONNUR_66	9:35	11:35	2:00	LINE CLEAR AVAILED
1382	5-Jun-2022	HASSAN	66	HV1	MALLAPURA_66	10:00	11:35	1:35	LINE CLEAR AVAILED
1383	5-Jun-2022	HASSAN	66	HV2	MALLAPURA_66	10:00	11:35	1:35	LINE CLEAR AVAILED
1384	5-Jun-2022	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	10:00	11:35	1:35	LINE CLEAR AVAILED
1385	5-Jun-2022	HASSAN	66	HV1 CB	NAGARTHI_66	0:40	4:18	3:38	TRANSFORMER FAULT
1386	5-Jun-2022	HASSAN	66	L1 CB	NAGARTHI_66	0:40	4:15	3:35	TRANSFORMER FAULT
1387	5-Jun-2022	HASSAN	66	L2 CB	NAGARTHI_66	0:40	4:35	3:55	TRANSFORMER FAULT
1388	5-Jun-2022	HASSAN	66	HV2	RAMNATHPURA_66	0:01	0:58	0:57	TRANSFORMER FAULT
1389	5-Jun-2022	HASSAN	66	SAKALE-IPCL1	SAKALESPURA_66	9:51	16:08	6:17	LINE CLEAR AVAILED
1390	5-Jun-2022	HASSAN	66	SAKALE-IPCL2	SAKALESPURA_66	9:51	16:08	6:17	LINE CLEAR AVAILED
1391	5-Jun-2022	HASSAN	66	TAVARE-HONNALLI-	TAVARECHETTANAHALLY_66	9:30	11:30	2:00	LINE CLEAR AVAILED
1392	5-Jun-2022	MYSURU	66	HV1	HANAGODU_66	0:01	0:09	0:07	TRANSFORMER FAULT
1393	5-Jun-2022	MYSURU	66	HV1	HANAGODU_66	1:27	12:30	11:03	TRANSFORMER FAULT
1394	5-Jun-2022	MYSURU	66	HV1	HANAGODU_66	13:51	14:29	0:37	LINE CLEAR AVAILED
1395	5-Jun-2022	MYSURU	66	HV1	KIKKERI_66	1:08	1:30	0:21	TRANSFORMER FAULT
1396	5-Jun-2022	MYSURU	66	HV1	KIKKERI_66	2:15	7:22	5:06	TRANSFORMER FAULT
1397	5-Jun-2022	MYSURU	66	KOLLEGALA-THALAKADU	NO STATIONS EFFECTED	17:48	18:04	0:16	LINE FAULT
1398	5-Jun-2022	MYSURU	66	HV1	MANDGERE_66	1:10	4:35	3:25	MAIN SUPPLY FAILURE
1399	5-Jun-2022	MYSURU	66	HV2	MANDGERE_66	1:10	4:35	3:25	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1400	5-Jun-2022	MYSURU	66	ADDIHALLI-BG NAGARA	BGNAGARA_66 ADICHUNCHANAGIRI_66 KADABALLY_66 VADERALLI 66	18:17	18:32	0:15	LINE FAULT
1401	5-Jun-2022	MYSURU	66	SANTHESARAGURU-KABINI 1	NO STATIONS EFFECTED	5:55	6:05	0:10	LINE FAULT
1402	5-Jun-2022	MYSURU	66	KR PETE 220- MAHADESHWRAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE 66	22:23	22:28	0:05	LINE FAULT
1403	5-Jun-2022	MYSURU	66	HV 1	KADAKOLA_220	10:13	17:35	7:22	LINE CLEAR AVAILED
1404	5-Jun-2022	MYSURU	66	HV 2	KADAKOLA_220	10:13	18:14	8:01	LINE CLEAR AVAILED
1405	5-Jun-2022	MYSURU	66	KUSHALANAGARA- SUNTIKOPPA	NO STATIONS EFFECTED	1:21	1:34	0:13	LINE FAULT
1406	5-Jun-2022	MYSURU	66	VAJAMANGALA-BANNUR	NO STATIONS EFFECTED	5:35	5:40	0:05	LINE FAULT
1407	5-Jun-2022	MYSURU	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	0:14	0:36	0:22	LINE FAULT
1408	5-Jun-2022	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	23:08 (04.06.2022)	5:00 (05.06.2022)	5:51hrs	LINE CHARGED
1409	5-Jun-2022	MYSURU	220	HOOTAGALLI-BASTHIPURA2	NO STATIONS EFFECTED	23:26 (05.06.2022)			LINE OPEN,LINE FAULT
1410	5-Jun-2022	MYSURU	66	HOOTAGALLI-ELAVALA	NO STATIONS EFFECTED	23:26 (05.06.2022)			LINE OPEN,LINE FAULT
1411	5-Jun-2022	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66	23:29 (05.06.2022)			LINE OPEN,LINE FAULT
1412	5-Jun-2022	MYSURU	66	KR PETE 220-K R PETE 1	NO STATIONS EFFECTED	23:57 (05.06.2022)			LINE OPEN,LINE FAULT
1413	5-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	12:05(5.6.22)			LINE OPEN, LINE CLEAR AVAILED
1414	5-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU- BAS1	NO STATIONS EFFECTED	18:10 (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1415	5-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1416	5-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1417	5-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1418	4-Jun-2022	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2 (NAGAMANGALA 2)(MAGADI)	ANCHEPALYA_220	21:07(4.6.22)	19:36(5.6.22)	22:26HRS	LINE CHARGED
1419	3-Jun-2022	TUMKUR	66	TR1 AND TR2	DASUDI	9:50(3.6.22)			MAIN SUPPLY FAILURE
1420	4-Jun-2022	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	21:36(4.6.22)	9:40(5.6.22)	12:04HRS	LINE CHARGED
1421	5-Jun-2022	TUMKUR	220	TR-1 & TR-2	CHITRADURGA_220	19:04	19:48	0:44	LINE CLEAR AVAILED
1422	5-Jun-2022	TUMKUR	110	TR-1	SAMPIGE_110	11:40	12:35	0:55	LINE CLEAR AVAILED
1423	5-Jun-2022	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	12:00	12:10	0:10	LINE FAULT
1424	5-Jun-2022	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	20:54	21:28	0:34	LINE FAULT
1425	5-Jun-2022	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	23:06	23:35	0:29	LINE FAULT
1426	5-Jun-2022	TUMKUR	66	ANCHEPALYA 220- HEBBUR	HEBBUR_66	23:08	23:35	0:27	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1427	5-Jun-2022	TUMKUR	66	ANTHRASANAHALI 220kv-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE 66	23:39	23:49	0:10	LINE FAULT
1428	5-Jun-2022	TUMKUR	66	CHITRADURGA 220kv-SUZLON 1 & 2	SUZLON1_IPP_66	11:18	16:45	5:27	LINE CLEAR AVAILED
1429	5-Jun-2022	TUMKUR	66	TR-2	CHITRADURGA_220	11:18	16:25	5:07	LINE CLEAR AVAILED
1430	5-Jun-2022	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE 66	16:28	16:39	0:11	HAND TRIPPED
1431	5-Jun-2022	TUMKUR	66	CHITRADURGA 220kv-CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE 66	16:30	16:42	0:12	HAND TRIPPED
1432	5-Jun-2022	TUMKUR	66	TR-3(LV-SIDE)	CHITRADURGA_220	11:22	16:32	5:10	LINE CLEAR AVAILED
1433	5-Jun-2022	TUMKUR	66	CHITRADURGA 220kv-SUZLON 1 & 2	SUZLON1_IPP_66	17:55	18:30	0:35	LINE CLEAR AVAILED
1434	5-Jun-2022	TUMKUR	66	CHITRADURGA 220kv-CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE 66	19:06	19:54	0:48	LINE FAULT
1435	5-Jun-2022	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE 66	19:49	20:09	0:20	LINE FAULT
1436	5-Jun-2022	TUMKUR	66	SIRA220-GOWRIBIDANUR220	SIRA_220	20:49	21:11	0:22	LINE FAULT
1437	5-Jun-2022	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 1	PATNAYAKANAHALLI 1	7:50	7:56	0:06	LINE FAULT
1438	5-Jun-2022	TUMKUR	66	THALLAK 220kv- P R PURA	PR PURA_66	11:00	11:04	0:04	LINE FAULT
1439	5-Jun-2022	TUMKUR	66	THALLAK 220kv-CHALLAKERE	CHALLAKERE_66, SANIKERE 66	19:06	20:31	1:25	LINE FAULT
1440	5-Jun-2022	TUMKUR	66	THALLAK 220kv-CHALLAKERE-2	CHALLAKERE_66	19:34	20:31	0:57	LINE FAULT
1441	6-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE CLEAR AVAILED
1442	6-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55(28.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1443	6-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1444	6-Jun-2022	BAGALKOT	220	BELGAUM-AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)			LINE CLEAR AVAILED
1445	6-Jun-2022	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	JAMAKHANDI_110	19:50(05.06.2022)	7:15(06.06.2022)	11:25HRS	LINE CHARGED
1446	6-Jun-2022	BAGALKOT	110	NAVALAGI-JAMAKHANDI	NAVALAGI_110	19:39(05.06.2022)	7:25(06.06.2022)	11:46HRS	LINE CHARGED
1447	6-Jun-2022	BAGALKOT	110	AIGALI-SAVALAGI	AIGALI_110	5:39	5:50	0:11	LINE FAULT
1448	6-Jun-2022	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	17:16	17:34	0:18	LINE CLEAR AVAILED
1449	6-Jun-2022	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	5:22	5:44	0:22	HAND TRIPPED
1450	6-Jun-2022	BAGALKOT	110	BELLATTI-AB_SOLAR	BELLATTI_110	5:22	5:38	0:16	HAND TRIPPED
1451	6-Jun-2022	BAGALKOT	110	BJCTY(THORVI)-BHUTNAL	THORVI_110	6:21	15:15	8:54	NFBC ISSUED
1452	6-Jun-2022	BAGALKOT	110	DAMBAL-SUZLON2	DAMBAL_110	6:00	7:16	1:16	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1453	6-Jun-2022	BAGALKOT	110	110/11KV,HV2	HATTARAGI_110	13:15	13:33	0:18	TRANSFORMER FAULT
1454	6-Jun-2022	BAGALKOT	110	110/11KV,HV1	HUDLI_110	14:36	17:22	2:46	LINE CLEAR AVAILED
1455	6-Jun-2022	BAGALKOT	110	ILKAL-KUSTAGI1&2	ILKAL_110	1:06	2:29	1:23	LINE FAULT
1456	6-Jun-2022	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	7:33	7:43	0:10	LINE CLEAR AVAILED
1457	6-Jun-2022	BAGALKOT	110	110/33KV,HV3(HV1)	KANABARGI LAYOUT_110	8:43	13:06	4:23	LINE CLEAR AVAILED
1458	6-Jun-2022	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	10:18	12:50	2:32	LINE CLEAR AVAILED
1459	6-Jun-2022	BAGALKOT	110	110/33KV,HV3	TIGADI_33,ARALIMATTI_33 KULIGOD_110	0:44	6:16	5:32	TRANSFORMER FAULT
1460	6-Jun-2022	BAGALKOT	110	LAKMESHWAR-BELLATTI	BELLATTI_110	5:10	5:30	0:20	LINE FAULT
1461	6-Jun-2022	BAGALKOT	110	110/11KV,HV1	MALGHAN(S)_110	4:46(06.06.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1462	6-Jun-2022	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	9:37	16:59	7:22	LINE CLEAR AVAILED
1463	6-Jun-2022	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	6:47	18:51	12:04	LINE FAULT
1464	6-Jun-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:42	18:50	8:08	LINE CLEAR AVAILED
1465	6-Jun-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	19:41 (06.06.2022)			LINE OPEN,LINE FAULT
1466	6-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	15:02	18:49	3:47	HAND TRIPPED
1467	6-Jun-2022	BAGALKOT	110	RANEENNUR- BYADAGI (GUTTAL)	RANEENNUR_220	13:40	14:17	0:37	LINE FAULT
1468	6-Jun-2022	BAGALKOT	110	110/33KV, HV3	ANKALI_110, NANDIKURLI_33	12:15	12:30	0:15	LINE CLEAR AVAILED
1469	6-Jun-2022	BAGALKOT	110	KARWAR220- KARWAR	KARWAR_220	17:18	17:30	0:12	LINE FAULT
1470	6-Jun-2022	BAGALKOT	220	BELGAUM- KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	21:38 (06.06.2022)			LINE OPEN,LINE FAULT
1471	6-Jun-2022	BAGALKOT	400	400/220KV, ICT2	STATION NOT AFFECTED DHONI_400	10:30	16:51	6:21	LINE CLEAR AVAILED
1472	6-Jun-2022	BAGALKOT	220	400/220KV, ICT2	STATION NOT AFFECTED DHONI_400	10:31	16:53	6:22	LINE CLEAR AVAILED
1473	6-Jun-2022	BAGALKOT	110	GADAG220- DAMBAL1 (SAMBAPUR ROAD)	STATION NOT AFFECTED GADAG_220	5:55	6:27	0:32	LINE FAULT
1474	6-Jun-2022	BAGALKOT	110	GHATAPRABHA220- MUDALAGI (MANTUR(G))	STATION NOT AFFECTED GHATAPRABHA_220	6:20	6:25	0:05	LINE FAULT
1475	6-Jun-2022	BAGALKOT	220	220/110KV, HV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	0:55	1:22	0:27	TRANSFORMER FAULT
1476	6-Jun-2022	BAGALKOT	220	220/110KV, HV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	12:54	13:23	0:29	LINE CLEAR AVAILED
1477	6-Jun-2022	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	MAHALINGAPUR_220	0:29	13:26	12:57	LINE FAULT
1478	6-Jun-2022	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	STATION NOT AFFECTED MAHALINGAPUR_220	12:54	13:23	0:29	HAND TRIPPED
1479	6-Jun-2022	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MUGALKHOD_220	10:02	11:56	1:54	LINE CLEAR AVAILED
1480	6-Jun-2022	BAGALKOT	110	MK HUBLI220- MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	13:32(06.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1481	6-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	14:59	18:49	3:50	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1482	6-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	21:37 (06.06.2022)			LINE OPEN,LINE FAULT
1483	6-Jun-2022	BAGALKOT	110	VAJRAMATTI220- BILAGI (SHIRAGUPPI)	VAJRAMATTI_220, SHIRAGUPPI_110 ,BILAGI_110, TOLAMATTI_110, BISANAL_110, GIRISAGAR_110	21:30	21:44	0:14	LINE FAULT
1484	6-Jun-2022	BAGALKOT	110	110/11KV, HV2	UTTUR_110	0:01	0:51	0:50	TRANSFORMER FAULT
1485	6-Jun-2022	BAGALKOT	110	KAVALWADA(SIRSI220)- SIRSI2	STATION NOT AFFECTED SIRSI_110	11:26	11:33	0:07	HAND TRIPPED
1486	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	NAVALAGI_110	12:35	12:39	0:04	TRANSFORMER FAULT
1487	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	0:29	0:32	0:03	TRANSFORMER FAULT
1488	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	0:39	7:13	6:34	TRANSFORMER FAULT
1489	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	8:00	8:05	0:05	TRANSFORMER FAULT
1490	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	10:04	10:07	0:03	TRANSFORMER FAULT
1491	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	11:16	11:21	0:05	TRANSFORMER FAULT
1492	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	11:39	11:49	0:10	TRANSFORMER FAULT
1493	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	12:03	12:09	0:06	TRANSFORMER FAULT
1494	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	12:10	12:16	0:06	TRANSFORMER FAULT
1495	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	13:40	13:52	0:12	TRANSFORMER FAULT
1496	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	14:15	14:28	0:13	TRANSFORMER FAULT
1497	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	14:30	14:40	0:10	TRANSFORMER FAULT
1498	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	16:10	17:12	1:02	LINE CLEAR AVOIDED
1499	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	17:29	17:35	0:06	TRANSFORMER FAULT
1500	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	17:52	17:57	0:05	TRANSFORMER FAULT
1501	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	20:12	20:17	0:05	TRANSFORMER FAULT
1502	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	20:30	20:41	0:11	TRANSFORMER FAULT
1503	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	20:52	20:59	0:07	TRANSFORMER FAULT
1504	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	21:06	21:12	0:06	TRANSFORMER FAULT
1505	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	21:27	21:33	0:06	TRANSFORMER FAULT
1506	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	21:47	21:56	0:09	TRANSFORMER FAULT
1507	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	22:01	22:07	0:06	TRANSFORMER FAULT
1508	6-Jun-2022	BAGALKOT	110	110/11KV, HV1	NEERABUDIHAI_110	11:20	15:34	4:14	LINE CLEAR AVOIDED
1509	6-Jun-2022	BAGALKOT	110	RAMANKOPPA- SAVANUR (MUNDAGOD)	STATION NOT AFFECTED RAMANKOPPA_110	19:51 (06.06.2022)			LINE OPEN,LINE FAULT
1510	6-Jun-2022	BAGALKOT	110	MUNDAGOD- HUBLI (RAMANKOPPA)	STATION NOT AFFECTED MUNDAGOD_110	20:28 (06.06.2022)			LINE OPEN, LINE CLEAR AVOIDED
1511	6-Jun-2022	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40(27.04.2022)			LINE OPEN,LINE FAULT
1512	6-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
1513	6-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE CLEAR AVOIDED
1514	6-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1515	6-Jun-2022	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED BELGAUM_220	21:39 (06.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1516	6-Jun-2022	BAGALKOT	110	VAJRAMATTI220- SHIRAGUPPI (BILAGI)	SHIRAGUPPI_110	21:30	21:45	0:15	LINE FAULT
1517	6-Jun-2022	BAGALKOT	110	SHIRAGUPPI- BILAGI	SHIRAGUPPI_110	21:30	21:50	0:20	LINE FAULT
1518	6-Jun-2022	BAGALKOT	110	SIRSI220- SIRSI2	STATION NOT AFFECTED SIRSI_220	11:26	11:31	0:05	HAND TRIPPED
1519	6-Jun-2022	BAGALKOT	110	BAGALKOT220- RAMDURGA	STATION NOT AFFECTED BAGALKOT_220	20:06	20:09	0:03	HAND TRIPPED
1520	6-Jun-2022	BAGALKOT	110	BAGALKOT220- RAMDURGA	STATION NOT AFFECTED BAGALKOT_220	20:31	20:35	0:04	HAND TRIPPED
1521	6-Jun-2022	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI, BOSCH (EHT)	8:44	8:50	0:06	LOAD CHANGE OVER
1522	6-Jun-2022	BENGALURU	66	HV1	CHATRA	14:00	14:05	0:05	LINE CLEAR AVAILED
1523	6-Jun-2022	BENGALURU	66	HV1	CHATRA	17:20	18:00	0:40	LINE CLEAR AVAILED
1524	6-Jun-2022	BENGALURU	66	HV2	CHATRA	10:40	11:00	0:20	LINE CLEAR AVAILED
1525	6-Jun-2022	BENGALURU	66	IISc - NRS 220	IISc	14:27	14:51	0:24	MAIN SUPPLY FAILURE
1526	6-Jun-2022	BENGALURU	66	IISc - HEBBALA 220	IISc	17:39	17:43	0:04	LOAD CHANGE OVER
1527	6-Jun-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 3	HONNIGANAHALLI	15:36	15:51	0:15	LINE FAULT
1528	6-Jun-2022	BENGALURU	66	HV3	NRS 220	14:13	16:27	2:14	MAIN SUPPLY FAILURE
1529	6-Jun-2022	BENGALURU	66	HV1	NRS 220	14:13	16:25	2:12	MAIN SUPPLY FAILURE
1530	6-Jun-2022	BENGALURU	66	HV4	NRS 220	14:22	16:26	2:04	MAIN SUPPLY FAILURE
1531	6-Jun-2022	BENGALURU	66	HV5	NRS 220	14:24	16:26	2:02	MAIN SUPPLY FAILURE
1532	6-Jun-2022	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	14:25	16:22	1:57	MAIN SUPPLY FAILURE
1533	6-Jun-2022	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	14:26	16:29	2:03	MAIN SUPPLY FAILURE
1534	6-Jun-2022	BENGALURU	220	LV1	NRS 220	14:28	16:18	1:50	MAIN SUPPLY FAILURE
1535	6-Jun-2022	BENGALURU	220	LV2	NRS 220	14:28	16:18	1:50	MAIN SUPPLY FAILURE
1536	6-Jun-2022	BENGALURU	66	NRS 220 - SRS 2	NO STATION AFFECTED	16:18	16:59	0:41	LINE FAULT
1537	6-Jun-2022	BENGALURU	66	NRS 220 - A STATION 1	NO STATION AFFECTED	14:06	16:32	2:26	MAIN SUPPLY FAILURE
1538	6-Jun-2022	BENGALURU	66	NRS 220 - SRS 1	NO STATION AFFECTED	14:06	16:36	2:30	MAIN SUPPLY FAILURE
1539	6-Jun-2022	BENGALURU	66	NRS 220 - IISc	NO STATION AFFECTED	14:27	17:06	2:39	MAIN SUPPLY FAILURE
1540	6-Jun-2022	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	14:06	16:29	2:23	MAIN SUPPLY FAILURE
1541	6-Jun-2022	BENGALURU	220	HV2	TK HALLI 220	22:32	22:41	0:09	TRANSFORMER FAULT
1542	6-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	22:32	22:44	0:12	MAIN SUPPLY FAILURE
1543	6-Jun-2022	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	22:32	22:44	0:12	MAIN SUPPLY FAILURE
1544	6-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:32	22:44	0:12	MAIN SUPPLY FAILURE
1545	6-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:32	22:44	0:12	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1546	6-Jun-2022	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	22:32	22:46	0:14	MAIN SUPPLY FAILURE
1547	6-Jun-2022	BENGALURU	66	TK HALLI 220 - LIMBAVALI	NO STATION AFFECTED	22:32	22:46	0:14	MAIN SUPPLY FAILURE
1548	6-Jun-2022	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO STATION AFFECTED	22:32	23:00	0:28	MAIN SUPPLY FAILURE
1549	6-Jun-2022	BENGALURU	66	HV3	YARANDANAHALLI 220	17:39	18:01	0:22	LINE CLEAR AVAILED
1550	6-Jun-2022	BENGALURU	66	HV2	YARANDANAHALLI 220	21:44	21:57	0:13	TRANSFORMER FAULT
1551	6-Jun-2022	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	21:50	22:00	0:10	LOAD CHANGE OVER
1552	6-Jun-2022	BENGALURU	66	HV1	DALASNUR	11:25	12:10	0:45	LINE CLEAR AVAILED
1553	6-Jun-2022	BENGALURU	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	11:25	11:35	0:10	LOAD CHANGE OVER
1554	6-Jun-2022	BENGALURU	66	HONNIGANAHALLI - HALAGUR	ACHALU, HALAGURU	15:36	16:07	0:31	LINE FAULT
1555	6-Jun-2022	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	6:51	7:13	0:22	LINE FAULT
1556	6-Jun-2022	BENGALURU	66	HV2	MASTHI	12:01	13:00	0:59	LINE CLEAR AVAILED
1557	6-Jun-2022	BENGALURU	66	HV2	MALLASANDRA	17:33	18:31	0:58	LINE CLEAR AVAILED
1558	6-Jun-2022	BENGALURU	66	HV1	MELUR	11:06	11:15	0:09	LINE CLEAR AVAILED
1559	6-Jun-2022	BENGALURU	66	HV1	MELUR	12:40	12:45	0:05	LINE CLEAR AVAILED
1560	6-Jun-2022	BENGALURU	66	HV1	MULBAGLU	15:35	15:59	0:24	LINE CLEAR AVAILED
1561	6-Jun-2022	BENGALURU	66	HV3	NELAMANGALA 66	3:08	3:32	0:24	TRANSFORMER FAULT
1562	6-Jun-2022	BENGALURU	220	HV1	DB PURA 220	1:39	2:21	0:42	TRANSFORMER FAULT
1563	6-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	1:39	2:21	0:42	MAIN SUPPLY FAILURE
1564	6-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	1:39	2:21	0:42	MAIN SUPPLY FAILURE
1565	6-Jun-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	1:39	2:21	0:42	MAIN SUPPLY FAILURE
1566	6-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	1:39	2:21	0:42	MAIN SUPPLY FAILURE
1567	6-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	1:39	2:21	0:42	MAIN SUPPLY FAILURE
1568	6-Jun-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	1:39	2:21	0:42	MAIN SUPPLY FAILURE
1569	6-Jun-2022	BENGALURU	220	HV1	DB PURA 220	5:15	17:10	11:55	TRANSFORMER FAULT
1570	6-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1571	6-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1572	6-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1573	6-Jun-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1574	6-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1575	6-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1576	6-Jun-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	5:15	5:39	0:24	MAIN SUPPLY FAILURE
1577	6-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:00	17:11	0:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1578	6-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:00	17:11	0:11	LINE CLEAR AVAILED
1579	6-Jun-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	17:00	17:11	0:11	LINE CLEAR AVAILED
1580	6-Jun-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:00	17:11	0:11	LINE CLEAR AVAILED
1581	6-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	NO STATION AFFECTED	1:39	6:27	4:48	LINE FAULT
1582	6-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	3:20	3:25	0:05	LINE CLEAR AVAILED
1583	6-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	0:41	0:46	0:05	LINE CLEAR AVAILED
1584	6-Jun-2022	BENGALURU	220	LV2	DB PURA 220	3:19	5:37	2:18	LOAD CURTAILMENT
1585	6-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	23:16	23:20	0:04	LINE CLEAR AVAILED
1586	6-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:00	12:01	0:01	LINE CLEAR AVAILED
1587	6-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:03	12:05	0:02	LINE CLEAR AVAILED
1588	6-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:22	12:26	0:04	LINE CLEAR AVAILED
1589	6-Jun-2022	BENGALURU	66	CESSNA - KALYANI TECH PARK	KALYANI TECH PARK, EXORA	8:10	15:08	6:58	LINE CLEAR AVAILED
1590	6-Jun-2022	BENGALURU	66	HV1	SAHAKARI NAGAR	20:46	20:57	0:11	TRANSFORMER FAULT
1591	6-Jun-2022	BENGALURU	66	HV1	CHEEMANGALA	11:15	14:05	2:50	LINE CLEAR AVAILED
1592	6-Jun-2022	BENGALURU	220	HV2	HEBBALA 220	17:00:00(05/06/2022)	17:32(06/06/2022)	24:32HRS	TRANSFORMER CHARGED
1593	6-Jun-2022	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	21:35(05/06/2022)	1:08(06/06/2022)	3:33HRS	LINE CHARGED
1594	6-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	23:59	7:40	7:41	LINE FAULT
1595	6-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	7:40	9:59	2:19	LINE CLEAR AVAILED
1596	6-Jun-2022	BENGALURU	66	HV1	RANGANDODDI	23:03:23(5-6-2022)	0:10(6-6-2022)	1:05HRS	TRANSFORMER CHARGED
1597	6-Jun-2022	BENGALURU	66	HV1	NELAMANGALA 66	23:59(5-6-2022)	0:28(6-6-2022)	0:29HRS	TRANSFORMER CHARGED
1598	6-Jun-2022	BENGALURU	220	MALUR 220 - HOODY 220	NO STATION AFFECTED	21:29(5-6-2022)	1:35(6-6-2022)	4:05HRS	LINE CHARGED
1599	6-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN,LINE FAULT
1600	6-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23 (27.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1601	6-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1602	6-Jun-2022	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	7:29 (6.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1603	6-Jun-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	7:41	19:33	11:52	LINE CLEAR AVAILED
1604	6-Jun-2022	GULBARGA	220	HV1	KUSTAGI_220	1:41	2:09	0:28	TRANSFORMER FAULT
1605	6-Jun-2022	GULBARGA	220	HV1,HV2	SINDHANOOR_220	19:56	20:25	0:29	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1606	6-Jun-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	5:59	6:45	0:46	LINE FAULT
1607	6-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1608	6-Jun-2022	GULBARGA	110	HV4	DEODURGA_110	20:00(05.06.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1609	6-Jun-2022	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	VICAT SAGAR_IPP	23:50 (6.06.2022)			LINE OPEN,LINE FAULT
1610	6-Jun-2022	GULBARGA	110	SINDHANOOR-TURVIHAL	GANDHINAGAR_110,TURVIHAL_110	19:56(06.06.2022)			LINE OPEN,LINE FAULT
1611	6-Jun-2022	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHAL_110	19:54(06.06.2022)			MAIN SUPPLY FAILURE
1612	6-Jun-2022	GULBARGA	110	HV1	ALIPUR_220	3:25	3:40	0:15	TRANSFORMER FAULT
1613	6-Jun-2022	GULBARGA	110	HV2	KUSTAGI_220	21:15 (05.06.2022)	00:15 (06.06.2022)	3:00 HRS	TRANSFORMER CHARGED
1614	6-Jun-2022	GULBARGA	110	HV1	SIRIGERICROSS_110	10:07	10:17	0:10	TRANSFORMER FAULT
1615	6-Jun-2022	GULBARGA	110	HV1	DEODURGA_110	13:25	13:45	0:20	TRANSFORMER FAULT
1616	6-Jun-2022	GULBARGA	110	HV1	DEODURGA_110	14:00	14:15	0:15	TRANSFORMER FAULT
1617	6-Jun-2022	GULBARGA	110	HV1	CHOWDAPUR_110	13:30	13:55	0:25	TRANSFORMER FAULT
1618	6-Jun-2022	GULBARGA	110	HV2	HATTI_110	17:18	18:29	1:11	TRANSFORMER FAULT
1619	6-Jun-2022	GULBARGA	110	HV1	MYLAR_110	14:01	16:01	2:00	LINE CLEAR AVAILED
1620	6-Jun-2022	GULBARGA	110	HV2	MYLAR_110	14:01	16:01	2:00	LINE CLEAR AVAILED
1621	6-Jun-2022	GULBARGA	110	HV4	YELBURGA_110	0:14	0:36	0:22	TRANSFORMER FAULT
1622	6-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	23:54(5.06.2022)	0:05(6.06.2022)	0:11HRS	MAIN SUPPLY FAILURE
1623	6-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	4:53	5:09	0:16	MAIN SUPPLY FAILURE
1624	6-Jun-2022	GULBARGA	110	SINDHANOOR220-SUZLON	SINDHANOOR_220	23:05(05.06.2022)	01:20(06.06.2022)	02:15HRS	LINE CHARGED
1625	6-Jun-2022	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	1:18	1:20	0:02	LINE FAULT
1626	6-Jun-2022	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110,AFZALPUR_110,KPR_IPP	1:15	1:20	0:05	MAIN SUPPLY FAILURE
1627	6-Jun-2022	GULBARGA	110	CHOWDAPUR-KPR_IPP	CHOWDAPUR_110	1:15	1:25	0:10	LINE FAULT
1628	6-Jun-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	9:40	9:55	0:15	LINE FAULT
1629	6-Jun-2022	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	19:55	20:22	0:27	MAIN SUPPLY FAILURE
1630	6-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	19:56	20:34	0:38	MAIN SUPPLY FAILURE
1631	6-Jun-2022	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	19:55	20:38	0:43	MAIN SUPPLY FAILURE
1632	6-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	18:43 (5.06.2022)	20:16 (6.06.2022)	25:33 HRS	LINE CHARGED
1633	6-Jun-2022	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	VICAT SAGAR_IPP	0:58	1:05	0:07	LINE FAULT
1634	6-Jun-2022	GULBARGA	110	GANGAVATI-KANAKAGIRI	NAVALI_110,CLEAN SOLAR_IPP	10:30	10:44	0:14	LINE CLEAR AVAILED
1635	6-Jun-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	5:34	5:42	0:08	LINE FAULT
1636	6-Jun-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	21:02	21:12	0:10	LINE FAULT
1637	6-Jun-2022	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	0:25	0:26	0:01	LINE FAULT
1638	6-Jun-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	7:14	7:31	0:17	LINE FAULT
1639	6-Jun-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	7:45	7:57	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1640	6-Jun-2022	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	12:05	12:23	0:18	LINE FAULT
1641	6-Jun-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	8:30	8:40	0:10	LINE FAULT
1642	6-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	16:25(05/06/2022)	14:58(06.06.2022)	22:33 HRS	LINE CHARGED
1643	6-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	7:53	14:57	7:04	LINE CLEAR AVAILED
1644	6-Jun-2022	GULBARGA	110	KUSTAGI-ILKAL_1	ILKAL_110	1:41	2:28	0:47	LINE FAULT
1645	6-Jun-2022	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANDAL_110,NAVALI_110	1:30	2:11	0:41	LINE CLEAR AVAILED
1646	6-Jun-2022	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANDAL_110,NAVALI_110	6:38	7:04	0:26	LINE CLEAR AVAILED
1647	6-Jun-2022	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANDAL_110,NAVALI_110	14:14	14:20	0:06	LINE CLEAR AVAILED
1648	6-Jun-2022	GULBARGA	110	KUSATGI-VAJRABANDI	VAJRABANDI_110,YELBURGA_110,KUKNOOR_110	21:10	21:22	0:12	LINE CLEAR AVAILED
1649	6-Jun-2022	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110,YAKATPUR_110	11:45	13:02	1:17	LINE CLEAR AVAILED
1650	6-Jun-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	11:50	12:55	1:05	LINE CLEAR AVAILED
1651	6-Jun-2022	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	12:58	13:32	0:34	LINE FAULT
1652	6-Jun-2022	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	13:30	14:00	0:30	LINE FAULT
1653	6-Jun-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	13:54	14:02	0:08	LINE FAULT
1654	6-Jun-2022	GULBARGA	66	HV1	BENNEHALLI_66	8:15	8:20	0:05	TRANSFORMER FAULT
1655	6-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	5:05	5:10	0:05	TRANSFORMER FAULT
1656	6-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	5:15	5:20	0:05	TRANSFORMER FAULT
1657	6-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	6:20	6:25	0:05	TRANSFORMER FAULT
1658	6-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	9:30	9:35	0:05	TRANSFORMER FAULT
1659	6-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	9:55	10:05	0:10	TRANSFORMER FAULT
1660	6-Jun-2022	GULBARGA	66	HV1	PUNABGHATA_66	10:55	11:20	0:25	TRANSFORMER FAULT
1661	6-Jun-2022	GULBARGA	66	HV2	BANAVEKAL_66	5:35	9:15	3:40	TRANSFORMER FAULT
1662	6-Jun-2022	GULBARGA	66	HV2	BANAVEKAL_66	13:35	13:50	0:15	TRANSFORMER FAULT
1663	6-Jun-2022	GULBARGA	66	BANAVEKAL-SOLAR_IPP	BANAVEKAL_66	0:35	5:30	4:55	LINE FAULT
1664	6-Jun-2022	GULBARGA	66	BADELADUKU-BANVIKAL	BANVIKAL_66	0:30	1:35	1:05	LINE FAULT
1665	6-Jun-2022	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLY_66	19:00(05.06.2022)	1:04(06.06.2022)	6:03 hrs	LINE CHARGED
1666	6-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1667	6-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1668	6-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1669	6-Jun-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN,LINE FAULT
1670	6-Jun-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1671	6-Jun-2022	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	19:58(06.06.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1672	6-Jun-2022	HASSAN	220	SHRAVTY-SHIMOGA1	gen_sharavathy	19:58(06.06.2022)			LINE OPEN,LINE FAULT
1673	6-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1674	6-Jun-2022	HASSAN	220	GERSOPA-TALGUPA1	gen_gersoppa	11:31	11:54	0:23	HAND TRIPPED
1675	6-Jun-2022	HASSAN	220	GERSOPA-TALGUPA2	gen_gersoppa	11:32	11:55	0:23	HAND TRIPPED
1676	6-Jun-2022	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:31	11:55	0:24	HAND TRIPPED
1677	6-Jun-2022	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	11:32	11:54	0:22	HAND TRIPPED
1678	6-Jun-2022	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:35	12:07	0:32	LINE FAULT
1679	6-Jun-2022	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavathy	1:35	12:07	10:32	LINE FAULT
1680	6-Jun-2022	HASSAN	110	HV1	ARASIKERE_110	13:40	14:20	0:40	TRANSFORMER FAULT
1681	6-Jun-2022	HASSAN	110	HV1	HIRIYADKA_110	16:52	17:24	0:32	LINE CLEAR AVAILED
1682	6-Jun-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_110	18:59	19:39	0:40	LINE FAULT
1683	6-Jun-2022	HASSAN	66	HV1	HALLYMYSORE_66	7:05	13:45	6:40	MAIN SUPPLY FAILURE
1684	6-Jun-2022	HASSAN	66	HV2	HALLYMYSORE_66	7:05	13:45	6:40	MAIN SUPPLY FAILURE
1685	6-Jun-2022	HASSAN	66	HETUR-HV1 CB	HETTUR_66	10:25	13:00	2:35	MAIN SUPPLY FAILURE
1686	6-Jun-2022	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	1:30	1:40	0:10	LINE FAULT
1687	6-Jun-2022	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	7:10	13:47	6:37	LINE CLEAR AVAILED
1688	6-Jun-2022	HASSAN	66	HV2	MATTANAVILE_66	12:40	13:20	0:40	LINE CLEAR AVAILED
1689	6-Jun-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:25	15:21	4:56	LINE CLEAR AVAILED
1690	6-Jun-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:25	15:21	4:56	LINE CLEAR AVAILED
1691	6-Jun-2022	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	17:05	17:34	0:29	HAND TRIPPED
1692	6-Jun-2022	HASSAN	66	SIGENAG-KDLGRE	SIGEBAGE_66	6:25	6:45	0:20	LINE FAULT
1693	6-Jun-2022	HASSAN	66	HV1	YESLUR_66	10:10	16:50	6:40	LINE CLEAR AVAILED
1694	6-Jun-2022	HASSAN	66	HV1	YESLUR_66	20:00	21:10	1:10	LINE CLEAR AVAILED
1695	6-Jun-2022	HASSAN	66	YESLUR-SNVRST	YESLUR_66	10:10	16:50	6:40	LINE CLEAR AVAILED
1696	6-Jun-2022	HASSAN	66	YESLUR-SNVRST	YESLUR_66	20:00	21:10	1:10	LINE CLEAR AVAILED
1697	6-Jun-2022	MYSURU	66	HV2	KADAKOLA_220	0:09	1:05	0:56	TRANSFORMER FAULT
1698	6-Jun-2022	MYSURU	66	KADAKOLA-DEVANUR NANJANGUDU	DEVANOORNGUDU_66 SUTTUR_66	5:44	5:51	0:07	LINE FAULT
1699	6-Jun-2022	MYSURU	66	KADAKOLA-D K MAIDANA	DKMAIDANA_66	10:05	17:11	7:06	NFBC ISSUED
1700	6-Jun-2022	MYSURU	66	KUSHALANAGARA- RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66 C B HALLI_66 RUDRAPATNA_66	6:23	6:36	0:13	LINE FAULT
1701	6-Jun-2022	MYSURU	66	KUSHALANAGARA- SUNTIKOPPA	NO STATIONS EFFECTED	15:11	15:39	0:28	LINE FAULT
1702	6-Jun-2022	MYSURU	66	HEBBANI-T K HALLI	NO STATIONS EFFECTED	22:32	22:47	0:15	LINE FAULT
1703	6-Jun-2022	MYSURU	66	TUBINAKERE- NAGAMANGALA 2	HARADANAHALLI_66 SHIVALLY_66	11:21	13:41	2:20	LINE CLEAR AVAILED
1704	6-Jun-2022	MYSURU	66	TUBINAKERE- NAGAMANGALA 2	BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66	18:14	18:19	0:05	LINE FAULT
1705	6-Jun-2022	MYSURU	66	HV1	GARGESHWARI_66	11:24	11:25	0:01	MAIN SUPPLY FAILURE
1706	6-Jun-2022	MYSURU	66	HV2	HALAGUR_66	15:35	16:07	0:32	MAIN SUPPLY FAILURE
1707	6-Jun-2022	MYSURU	66	HV2	HALAGUR_66	22:32	22:50	0:18	MAIN SUPPLY FAILURE
1708	6-Jun-2022	MYSURU	66	THUMBLA-MEGHALAPURA	THUMBLA_66	10:26	11:24	0:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1709	6-Jun-2022	MYSURU	66	THUMBLA-VYASARAJAPURA	THUMBLA_66	10:26	11:24	0:58	LINE CLEAR AVAILED
1710	6-Jun-2022	MYSURU	66	HV2	ANEGOLAL_66	17:25	17:30	0:05	TRANSFORMER FAULT
1711	6-Jun-2022	MYSURU	220	HOOTAGALLI-BASTHIPURA2	NO STATIONS EFFECTED	23:26 (05.06.2022)	14:12 (06.06.2022)	2:46HRS	LINE CHARGED
1712	6-Jun-2022	MYSURU	66	HOOTAGALLI-ELAVALA	NO STATIONS EFFECTED	23:26 (05.06.2022)	14:31 (06.06.2022)	3:05HRS	LINE CHARGED
1713	6-Jun-2022	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66	23:29 (05.06.2022)	14:32 (06.06.2022)	3:03HRS	LINE CHARGED
1714	6-Jun-2022	MYSURU	66	KR PETE 220-K R PETE 1	NO STATIONS EFFECTED	23:57(05.06.2022)	14:07(06.06.2022)	0:10HRS	LINE CHARGED
1715	6-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	23:05(4.6.22)			LINE OPEN, LINE CLEAR AVAILED
1716	6-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	18:10 (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1717	6-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1718	6-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1719	6-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16(08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1720	6-Jun-2022	TUMKUR	66	TR1 AND TR2	DASUDI	9:50(3.6.22)	16:10(4.6.22)	30:20HRS	TRANSFORMER CHARGED
1721	6-Jun-2022	TUMKUR	110	TR-1(LV1)	NITTUR_110	10:19	11:13	0:53	TRANSFORMER FAULT
1722	6-Jun-2022	TUMKUR	110	TR-2(LV2)	NITTUR_110	10:19	11:14	0:55	TRANSFORMER FAULT
1723	6-Jun-2022	TUMKUR	110	TR-1	NITTUR_110	14:45	15:09	0:23	HAND TRIPPED
1724	6-Jun-2022	TUMKUR	110	TR-2	NITTUR_110	14:45	15:08	0:23	HAND TRIPPED
1725	6-Jun-2022	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	14:45	15:09	0:24	HAND TRIPPED
1726	6-Jun-2022	TUMKUR	66	TR-1	KEREGODI_66	7:45	8:13	0:28	LINE CLEAR AVAILED
1727	6-Jun-2022	TUMKUR	66	TR-1	KEREGODI_66	16:15	16:52	0:37	LINE CLEAR AVAILED
1728	6-Jun-2022	TUMKUR	66	TR-2	BADAVANAHALLI_66	0:56	1:15	0:18	TRANSFORMER FAULT
1729	6-Jun-2022	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	0:53	6:51	5:58	LINE FAULT
1730	6-Jun-2022	TUMKUR	66	TR-1	BHARAMAGIRI_66	1:32	1:46	0:14	TRANSFORMER FAULT
1731	6-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	7:12	7:26	0:13	TRANSFORMER FAULT
1732	6-Jun-2022	TUMKUR	66	TR-2	CHITRADURGA_66	18:26	18:39	0:12	HAND TRIPPED
1733	6-Jun-2022	TUMKUR	66	TR-2	CHITRADURGA_66	18:41	19:36	0:54	HAND TRIPPED
1734	6-Jun-2022	TUMKUR	66	TR-2	CHITRAHALLI_66	17:03	17:10	0:07	TRANSFORMER FAULT
1735	6-Jun-2022	TUMKUR	66	TR-2	CHITRAHALLI_66	17:14	17:16	0:02	TRANSFORMER FAULT
1736	6-Jun-2022	TUMKUR	66	TR-2	GUTTUR_66	11:03	13:17	2:14	LINE CLEAR AVAILED
1737	6-Jun-2022	TUMKUR	66	H D PURA-CHITRADURGA220	H D PURA_66	12:08	12:14	0:06	LINE FAULT
1738	6-Jun-2022	TUMKUR	66	H D PURA-CHITRADURGA220	H D PURA_66	16:23	16:31	0:08	LINE FAULT
1739	6-Jun-2022	TUMKUR	66	TR-1	HIRIYUR_66	1:37	1:44	0:07	TRANSFORMER FAULT
1740	6-Jun-2022	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:40	6:51	0:10	LINE FAULT
1741	6-Jun-2022	TUMKUR	66	HIRIYUR 220KV- SUZLON 2	SUZLON1_IPP_66	3:45	3:50	0:05	LINE FAULT
1742	6-Jun-2022	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI 66	4:52	5:05	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1743	6-Jun-2022	TUMKUR	66	HOSADURGA66-RAMAGIRI	RAMAGIRI_66	13:16	15:38	2:22	LINE CLEAR AVAILED
1744	6-Jun-2022	TUMKUR	66	TR-1	KUNIGAL_66	12:04	12:33	0:29	LINE CLEAR AVAILED
1745	6-Jun-2022	TUMKUR	66	TR-2	KUNIGAL_66	11:28	12:04	0:36	LINE CLEAR AVAILED
1746	6-Jun-2022	TUMKUR	66	TR-1	MAVINAKATTE_66	15:02	15:11	0:09	TRANSFORMER FAULT
1747	6-Jun-2022	TUMKUR	66	TR-2	SHYLAPURA_66	1:22	10:01	8:39	TRANSFORMER FAULT
1748	6-Jun-2022	TUMKUR	66	TR-2	SIRA_220	14:10	17:42	3:32	LINE CLEAR AVAILED
1749	6-Jun-2022	TUMKUR	66	TR-2	THALLAK_220	14:57	19:26	4:29	LINE CLEAR AVAILED