

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 05.02.2019 to 11.02.2019

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|-----------------------------|--|---------|-----------|----------|--------------------|
| 1 | 5-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-2 | AREMALLAPUR_110 | 12:31 | 14:14 | 1:43 | HAND TRIPPED |
| 2 | 5-Feb-19 | BAGALKOT | 110 | BETAGERI-NAREGAL | BETAGERI_110 | 8:19 | 19:02 | 10:43 | HAND TRIPPED |
| 3 | 5-Feb-19 | BAGALKOT | 110 | GADAG- BETAGERI | BETAGERI_110 | 10:28 | 19:02 | 8:34 | HAND TRIPPED |
| 4 | 5-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-1 | BETAGERI_110 | 10:28 | 19:02 | 8:34 | HAND TRIPPED |
| 5 | 5-Feb-19 | BAGALKOT | 220 | 220/110KV,HV&LV-1 | GADAG_220 | 11:01 | 23:59 | 12:58 | HAND TRIPPED |
| 6 | 5-Feb-19 | BAGALKOT | 110 | GADAG- BETAGERI | BETAGERI_110 | 10:30 | 17:35 | 7:05 | HAND TRIPPED |
| 7 | 5-Feb-19 | BAGALKOT | 110 | KUSHTAGI-GAJENDRAGAD | GAJENDRAGAD_110 | 8:04 | 8:14 | 0:10 | HAND TRIPPED |
| 8 | 5-Feb-19 | BAGALKOT | 110 | KUSHTAGI-GAJENDRAGAD | GAJENDRAGAD_110 | 17:46 | 18:00 | 0:14 | HAND TRIPPED |
| 9 | 5-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-1 | KALADAGI_110 | 17:58 | 18:15 | 0:17 | TRANSFORMER FAULT |
| 10 | 5-Feb-19 | BAGALKOT | 110 | HUBLI-KALAGHATGI | KALAGHATAGI_110 | 16:23 | 19:01 | 2:38 | HAND TRIPPED |
| 11 | 5-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-2 | MUNAVALLI_110 | 20:57 | 21:09 | 0:12 | TRANSFORMER FAULT |
| 12 | 5-Feb-19 | BAGALKOT | 110 | NAREGAL-BETAGERI | NAREGAL_110 | 10:25 | 17:38 | 7:13 | HAND TRIPPED |
| 13 | 5-Feb-19 | BAGALKOT | 110 | NAREGAL-RON | NAREGAL_110 | 12:27 | 12:35 | 0:08 | HAND TRIPPED |
| 14 | 5-Feb-19 | BAGALKOT | 110 | NAREGAL-RON | NAREGAL_110 | 17:25 | 17:42 | 0:17 | HAND TRIPPED |
| 15 | 5-Feb-19 | BAGALKOT | 110 | 110/33KV, HV2 | UTTUR_110, YADWAD_33, VANTAGODI_33 | 11:15 | 11:26 | 0:11 | TRANSFORMER FAULT |
| 16 | 5-Feb-19 | BAGALKOT | 110 | 110/33KV, HV2 | UTTUR_110, YADWAD_33, VANTAGODI_33 | 11:57 | 12:04 | 0:07 | TRANSFORMER FAULT |
| 17 | 5-Feb-19 | BAGALKOT | 110 | HUBLI220-KALGHATAGI | KALGHATAGI_110 | 15:50 | 18:50 | 3:00 | LINE FAULT |
| 18 | 5-Feb-19 | BAGALKOT | 110 | 110/33KV, HV2 | SADALAGA_110, BHOJ_33 | 11:53 | 12:23 | 0:30 | LINE CLEAR AVAILED |
| 19 | 5-Feb-19 | BAGALKOT | 110 | 110/33KV, HV2 | SADALAGA_110, BHOJ_33 | 13:22 | 15:03 | 1:41 | LINE CLEAR AVAILED |
| 20 | 5-Feb-19 | BAGALKOT | 110 | 110/33KV, HV2 | RATTIHALLI_110, MASSUR_33, HALLUR_33 | 10:05 | 17:24 | 7:19 | LINE CLEAR AVAILED |
| 21 | 5-Feb-19 | BAGALKOT | 110 | 110/11KV, HV3 | RATTHALLI_110 | 10:05 | 17:23 | 7:18 | LINE CLEAR AVAILED |
| 22 | 5-Feb-19 | BAGALKOT | 110 | RANNABELAGALI-MUDHOL(UTTUR) | RANNABELAGALI_110 | 18:00 | 23:59 | 5:59 | LINE CLEAR AVAILED |
| 23 | 5-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 13:59 | 14:15 | 0:16 | LINE FAULT |
| 24 | 5-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 14:20 | 16:20 | 1:59 | LINE CLEAR AVAILED |
| 25 | 5-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 16:40 | 16:50 | 0:10 | LINE FAULT |
| 26 | 5-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 16:55 | 18:08 | 1:13 | LINE CLEAR AVAILED |
| 27 | 5-Feb-19 | BANGALORE | 66 | KEMBODI - NANGALI | MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 15:40 | 16:15 | 0:34 | LINE CLEAR AVAILED |
| 28 | 5-Feb-19 | BANGALORE | 66 | KEMBODI - NANGALI | MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 17:29 | 18:00 | 0:30 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|-------------------------------|---|---------|-----------|----------|---------------------|
| 29 | 5-Feb-19 | BANGALORE | 66 | HV2 | CHAKAVELU | 15:55 | 16:20 | 0:25 | TRANSFORMER FAULT |
| 30 | 5-Feb-19 | BANGALORE | 66 | HV2 | CHAKAVELU | 16:20 | 17:15 | 0:55 | TRANSFORMER FAULT |
| 31 | 5-Feb-19 | BANGALORE | 66 | HBR LAYOUT - HOSKOTE 220 | HBR LAYOUT | 17:20 | 17:25 | 0:05 | LOAD CHANGEOVER |
| 32 | 5-Feb-19 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 7:58 | 8:30 | 0:32 | LINE FAULT |
| 33 | 5-Feb-19 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 14:33 | 14:55 | 0:21 | LINE FAULT |
| 34 | 5-Feb-19 | BANGALORE | 66 | HV1 | JIGANI 66 | 12:30 | 13:20 | 0:50 | MAIN SUPPLY FAILURE |
| 35 | 5-Feb-19 | BANGALORE | 66 | YEDUMADU - SOMANAHALLI 220 | YEDUMADU | 11:40 | 11:56 | 0:16 | LOAD CHANGEOVER |
| 36 | 5-Feb-19 | BANGALORE | 66 | YEDUMADU - KANAKAPURA 220 | YEDUMADU | 13:02 | 13:10 | 0:08 | LOAD CHANGEOVER |
| 37 | 5-Feb-19 | BANGALORE | 66 | HV1 | AMARJYOTHI | 5:23 | 5:50 | 0:26 | TRANSFORMER FAULT |
| 38 | 5-Feb-19 | BANGALORE | 66 | HV1 | AMARJYOTHI | 6:25 | 6:28 | 0:02 | LINE CLEAR AVAILED |
| 39 | 5-Feb-19 | BANGALORE | 66 | HV2 | AREHALLI | 11:16 | 11:18 | 0:01 | LOAD CHANGEOVER |
| 40 | 5-Feb-19 | BANGALORE | 66 | HV2 | HANUMANTHANAGARA | 10:15 | 10:26 | 0:10 | LINE CLEAR AVAILED |
| 41 | 5-Feb-19 | BANGALORE | 66 | KADABISANAHALLI - HAL 220 | KADUBISANAHALLI | 13:40 | 15:20 | 1:40 | LINE CLEAR AVAILED |
| 42 | 5-Feb-19 | BANGALORE | 66 | KADABISANAHALLI - CESSNA | KADUBISANAHALLI | 16:55 | 17:00 | 0:05 | LOAD CHANGEOVER |
| 43 | 5-Feb-19 | BANGALORE | 66 | HV1 | SHAMRAJ TECH PARK | 8:35 | 9:13 | 0:37 | LINE CLEAR AVAILED |
| 44 | 5-Feb-19 | BANGALORE | 66 | SOMANAHALLI 220 - JIGANI 2 | BG ROAD, JIGANI LINK ROAD | 12:26 | 13:20 | 0:54 | LINE FAULT |
| 45 | 5-Feb-19 | BANGALORE | 66 | BG ROAD - JIGANI LINK ROAD | JIGANI LINK ROAD | 13:20 | 13:36 | 0:16 | MAIN SUPPLY FAILURE |
| 46 | 5-Feb-19 | BANGALORE | 66 | SOMANAHALLI 220 - KUMBALAGODU | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 10:55 | 11:15 | 0:20 | LINE FAULT |
| 47 | 5-Feb-19 | BANGALORE | 66 | JIGANI LINK ROAD - JIGANI 66 | JIGANI 66 | 12:26 | 13:36 | 1:10 | LINE FAULT |
| 48 | 5-Feb-19 | BANGALORE | 66 | YELAHANKA 220 - LINE 7 | KANASWADI | 10:00 | 17:40 | 7:40 | LINE CLEAR AVAILED |
| 49 | 5-Feb-19 | GULBARGA | 110 | STARMETALLIC-MUNIRABAD | STARMETALLIC_110 | 5:55 | 6:46 | 0:51 | LINE FAULT |
| 50 | 5-Feb-19 | GULBARGA | 110 | HV2 | HATTI_110 | 5:47 | 6:00 | 0:13 | TRANSFORMER FAULT |
| 51 | 5-Feb-19 | GULBARGA | 110 | HV2 | HATTI_110 | 6:10 | 6:19 | 0:09 | TRANSFORMER FAULT |
| 52 | 5-Feb-19 | GULBARGA | 110 | HV1 | SINDHANOOR_110 | 10:20 | 23:59 | 13:39 | LINE CLEAR AVAILED |
| 53 | 5-Feb-19 | GULBARGA | 110 | GURUMITAKAL-SEDAM | GURUMITAKAL_110, KONKAL_110 | 21:04 | 21:25 | 0:21 | LINE FAULT |
| 54 | 5-Feb-19 | GULBARGA | 110 | HV2 | HANUMASAGAR_110 | 17:20 | 17:50 | 0:30 | LINE CLEAR AVAILED |
| 55 | 5-Feb-19 | GULBARGA | 110 | KUSTAGI-KANKAGIRI | KANAKAGIRI_110, GANADAL_110 | 7:00 | 18:05 | 11:05 | LINE CLEAR AVAILED |
| 56 | 5-Feb-19 | GULBARGA | 110 | SHAKTINAGAR-RAICHURBIO | SHAKTINAGAR_110 | 9:50 | 11:16 | 1:26 | MAIN SUPPLY FAILURE |
| 57 | 5-Feb-19 | GULBARGA | 66 | HV2 | UPANAYAKANAHALLI_66 | 11:23 | 11:30 | 0:07 | TRANSFORMER FAULT |
| 58 | 5-Feb-19 | GULBARGA | 66 | ITTAGI-RNWSLR1,2 | ITTAGI_220 | 18:05 | 19:12 | 1:07 | LINE CLEAR AVAILED |
| 59 | 5-Feb-19 | HASSAN | 220 | MRSSHM-HV2 | MRSMSG_220 | 9:37 | 23:59 | 14:22 | LINE CLEAR AVAILED |
| 60 | 5-Feb-19 | HASSAN | 110 | HV1 | HALADY_110 | 12:38 | 14:22 | 1:44 | LINE CLEAR AVAILED |
| 61 | 5-Feb-19 | HASSAN | 110 | HV2 | HALADY_110 | 10:07 | 12:38 | 2:31 | LINE CLEAR AVAILED |
| 62 | 5-Feb-19 | HASSAN | 110 | KADUR-TNGL | KADUR_220 | 13:04 | 14:37 | 1:33 | LINE CLEAR AVAILED |
| 63 | 5-Feb-19 | HASSAN | 110 | HV1 | MRSMSG_220 | 9:26 | 9:34 | 0:08 | HAND TRIPPED |
| 64 | 5-Feb-19 | HASSAN | 110 | HV3 | MRSMSG_220 | 9:26 | 9:29 | 0:03 | HAND TRIPPED |
| 65 | 5-Feb-19 | HASSAN | 110 | HV4 | MRSMSG_220 | 9:26 | 9:29 | 0:03 | HAND TRIPPED |
| 66 | 5-Feb-19 | HASSAN | 110 | LV2 | MRSMSG_220 | 9:27 | 23:39 | 14:12 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|---------|---------|-----------------------------|--|---------|-----------|----------|--------------------|
| 67 | 5-Feb-19 | HASSAN | 110 | SAGARA-SORABA | SAGARA_110 | 8:40 | 9:02 | 0:22 | HAND TRIPPED |
| 68 | 5-Feb-19 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 8:39 | 8:53 | 0:14 | HAND TRIPPED |
| 69 | 5-Feb-19 | HASSAN | 110 | SORABA-SHR220 | SORABA_110 | 8:35 | 8:45 | 0:10 | HAND TRIPPED |
| 70 | 5-Feb-19 | HASSAN | 66 | MRSSHM-BD-2 | MRSMSG_220 | 9:25 | 9:33 | 0:08 | HAND TRIPPED |
| 71 | 5-Feb-19 | HASSAN | 66 | MRSSHM-DVG2 | MRSMSG_220 | 9:21 | 9:35 | 0:14 | HAND TRIPPED |
| 72 | 5-Feb-19 | HASSAN | 66 | MRSSHM-DVG1 | MRSMSG_220 | 9:25 | 9:36 | 0:11 | HAND TRIPPED |
| 73 | 5-Feb-19 | HASSAN | 66 | ARAKAL-MALLIPATNA | ARKD_66 | 11:54 | 14:53 | 2:59 | LINE CLEAR AVAILED |
| 74 | 5-Feb-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 9:24 | 9:32 | 0:08 | HAND TRIPPED |
| 75 | 5-Feb-19 | HASSAN | 66 | BHADRA-SHMG A 1 | bhadra_gen | 9:26 | 9:32 | 0:06 | HAND TRIPPED |
| 76 | 5-Feb-19 | HASSAN | 66 | BHADRA-SHMG A 2 | bhadra_gen | 9:25 | 9:32 | 0:07 | HAND TRIPPED |
| 77 | 5-Feb-19 | HASSAN | 66 | CHANNARA-CRPATNA2 | CHANNARAYAPATNA_66 | 12:10 | 17:30 | 5:20 | LINE CLEAR AVAILED |
| 78 | 5-Feb-19 | HASSAN | 66 | CHANNARA-CRPATNA2 | CHANNARAYAPATNA_66 | 19:50 | 19:55 | 0:05 | HAND TRIPPED |
| 79 | 5-Feb-19 | HASSAN | 66 | CHANNARA-CRPATNA1 | CHANNARAYAPATNA_66 | 12:10 | 19:50 | 7:40 | LINE CLEAR AVAILED |
| 80 | 5-Feb-19 | HASSAN | 66 | CHANNARA-MALLALI | CHANNARAYAPATNA_66 | 12:10 | 18:15 | 6:05 | LINE CLEAR AVAILED |
| 81 | 5-Feb-19 | HASSAN | 66 | CHANNARA-UDAYAPURA | CHANNARAYAPATNA_66 | 12:10 | 17:35 | 5:25 | LINE CLEAR AVAILED |
| 82 | 5-Feb-19 | HASSAN | 66 | HV1 | CHIKKAMAGLORE_66 | 15:58 | 16:20 | 0:22 | LINE CLEAR AVAILED |
| 83 | 5-Feb-19 | HASSAN | 66 | CHIKMA-L1-ALDUR | CHIKKAMAGLORE_66 | 14:57 | 16:14 | 1:17 | LINE CLEAR AVAILED |
| 84 | 5-Feb-19 | HASSAN | 66 | SIGEBAG-KDLGRE | SIGEBAGE_66 | 9:48 | 10:08 | 0:20 | HAND TRIPPED |
| 85 | 5-Feb-19 | MYSORE | 66 | HV1 | BANANGADI_66 | 14:02 | 15:55 | 1:52 | LINE CLEAR AVAILED |
| 86 | 5-Feb-19 | MYSORE | 66 | HV2 | BANANGADI_66 | 10:15 | 14:15 | 4:00 | LINE CLEAR AVAILED |
| 87 | 5-Feb-19 | MYSORE | 66 | HV1 | PANDAVAPURA- | 11:05 | 18:25 | 7:20 | LINE CLEAR AVAILED |
| 88 | 5-Feb-19 | MYSORE | 66 | HV1 | MADIKERI_66 | 10:48 | 12:03 | 1:15 | LINE CLEAR AVAILED |
| 89 | 5-Feb-19 | MYSORE | 66 | HV2 | PONNAMPET_66 | 12:37 | 13:24 | 0:46 | LINE CLEAR AVAILED |
| 90 | 5-Feb-19 | MYSORE | 66 | HV2 | PANDYADAHUNDI_66 | 12:16 | 12:50 | 0:34 | HAND TRIPPED |
| 91 | 5-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 8:15 | 8:35 | 0:19 | LINE CLEAR AVAILED |
| 92 | 5-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 12:08 | 12:28 | 0:20 | LINE CLEAR AVAILED |
| 93 | 5-Feb-19 | MYSORE | 66 | HV1 | SFCSHIVA_66 | 2:31 | 7:21 | 4:50 | TRANSFORMER FAULT |
| 94 | 5-Feb-19 | MYSORE | 66 | HV1 | SFCSHIVA_66 | 9:13 | 23:59 | 14:45 | LINE CLEAR AVAILED |
| 95 | 5-Feb-19 | MYSORE | 66 | TALAKADU-ADANI | THALAKADU_66 | 9:53 | 16:30 | 6:36 | LINE CLEAR AVAILED |
| 96 | 5-Feb-19 | MYSORE | 66 | TALAKADU-BG PURA | THALAKADU_66 | 9:50 | 16:30 | 6:40 | LINE CLEAR AVAILED |
| 97 | 5-Feb-19 | MYSORE | 66 | PARINAMIPURA-TALAKADU | THALAKADU_66 BGPURA_66 | 0:49 | 5:47 | 4:58 | LINE FAULT |
| 98 | 5-Feb-19 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 | 11:03 | 11:08 | 0:05 | LINE FAULT |
| 99 | 5-Feb-19 | MYSORE | 66 | HV2 | HDKOTE_66 | 13:25 | 14:40 | 1:15 | HAND TRIPPED |
| 100 | 5-Feb-19 | TUMKUR | 110 | CHIKKANAYAKANAHALLI-HULIYAR | SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110 | 20:35 | 21:01 | 0:25 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|----------|---------|---|---|---------|-----------|----------|--------------------|
| 101 | 5-Feb-19 | TUMKUR | 110 | CHIKKANAYAKANAHALLI-HULIYAR | SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110 | 21:38 | 22:21 | 0:42 | LINE FAULT |
| 102 | 5-Feb-19 | TUMKUR | 110 | CHIKKANAYAKANAHALLI- K B CROSS | CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110 | 20:35 | 20:51 | 0:16 | LINE FAULT |
| 103 | 5-Feb-19 | TUMKUR | 110 | CHIKKANAYAKANAHALLI- K B CROSS | CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110 | 21:38 | 22:14 | 0:35 | LINE FAULT |
| 104 | 5-Feb-19 | TUMKUR | 110 | KB CROSS 220kV- CHIKKANAYAKANAHALLI | CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110 | 20:36 | 20:49 | 0:13 | LINE FAULT |
| 105 | 5-Feb-19 | TUMKUR | 110 | KB CROSS 220kV- CHIKKANAYAKANAHALLI | CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110 | 21:38 | 22:12 | 0:34 | LINE FAULT |
| 106 | 5-Feb-19 | TUMKUR | 66 | ANCHEPALYA 220- ANCHEPALYA 2 | KUDUR_66, HULLENAHALLI_66 | 16:08 | 16:41 | 0:32 | LINE FAULT |
| 107 | 5-Feb-19 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 8:50 | 8:52 | 0:02 | TRANSFORMER FAULT |
| 108 | 5-Feb-19 | TUMKUR | 66 | CHANNAGIRI- (CHANNAGIRI(LINGDHILI)) | CHANNAGIRI_66 | 8:40 | 8:44 | 0:04 | HAND TRIPPED |
| 109 | 5-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 7:40 | 17:39 | 9:59 | HAND TRIPPED |
| 110 | 5-Feb-19 | TUMKUR | 66 | GUTUR 66-DAVANGERE SRS2 | GUTUR_66 | 13:06 | 13:36 | 0:30 | LINE CLEAR AVAILED |
| 111 | 5-Feb-19 | TUMKUR | 66 | TR-2 | GUTUR_66 | 13:36 | 14:23 | 0:46 | LINE CLEAR AVAILED |
| 112 | 5-Feb-19 | TUMKUR | 66 | TR-2 | IDHALLY_66 | 15:58 | 17:38 | 1:39 | LINE CLEAR AVAILED |
| 113 | 5-Feb-19 | TUMKUR | 66 | TR-1 | RANGENAHALLI_66 | 12:50 | 13:03 | 0:12 | LINE CLEAR AVAILED |
| 114 | 5-Feb-19 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 7:06 | 7:17 | 0:11 | LINE FAULT |
| 115 | 6-Feb-19 | BAGALKOT | 220 | AMBEWADI-NAGJHARI 1 | AMBEWADI_220 | 14:55 | 15:32 | 0:37 | HAND TRIPPED |
| 116 | 6-Feb-19 | BAGALKOT | 220 | AMBEWADI-NAGJHARI 2 | AMBEWADI_220 | 14:22 | 23:59 | 9:37 | LINE FAULT |
| 117 | 6-Feb-19 | BAGALKOT | 220 | AMBEWADI-NARENDRA 1 | AMBEWADI_220 | 12:08 | 15:32 | 3:24 | HAND TRIPPED |
| 118 | 6-Feb-19 | BAGALKOT | 110 | AMBEWADI-SUPA 2 | AMBEWADI_220, | 14:51 | 15:34 | 0:43 | HAND TRIPPED |
| 119 | 6-Feb-19 | BAGALKOT | 110 | AMBEWADI-SUPA 1 | AMBEWADI_220 | 14:54 | 15:22 | 0:28 | HAND TRIPPED |
| 120 | 6-Feb-19 | BAGALKOT | 110 | AMBEWADI-NK2 | KAWALAVAD_110 | 14:51 | 15:16 | 0:25 | HAND TRIPPED |
| 121 | 6-Feb-19 | BAGALKOT | 110 | AMBEWADI-NK1 | HALIYAL_110 | 14:54 | 15:16 | 0:22 | HAND TRIPPED |
| 122 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-2 | AMBEWADI_220 | 14:55 | 15:14 | 0:19 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|---|---|---------|-----------|----------|---------------------|
| 123 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-3 | BAILHONGAL_110 | 6:56 | 15:05 | 8:09 | TRANSFORMER FAULT |
| 124 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-3 | BIJAPUR_110 | 8:31 | 17:47 | 9:16 | HAND TRIPPED |
| 125 | 6-Feb-19 | BAGALKOT | 110 | CHIKKODI-SANKESHWAR | SANKESHWAR_110 | 21:03 | 21:23 | 0:20 | HAND TRIPPED |
| 126 | 6-Feb-19 | BAGALKOT | 220 | 220/110KV, HV1&LV1 | VAJRAMATTI_220 | 16:47 | 17:25 | 0:38 | LINE CLEAR AVAILED |
| 127 | 6-Feb-19 | BAGALKOT | 220 | 220/110KV, HV1&LV1 | HUBLI_220 | 9:50 | 14:02 | 4:12 | LINE CLEAR AVAILED |
| 128 | 6-Feb-19 | BAGALKOT | 110 | SIRSI220-2-SIRSI | SIRSI_110 | 15:12 | 15:39 | 0:27 | HAND TRIPPED |
| 129 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV2 | SANKESHWAR_110 | 21:02 | 21:28 | 0:26 | TRANSFORMER FAULT |
| 130 | 6-Feb-19 | BAGALKOT | 110 | 110/33KV, HV3 | SANKESHWAR_110, HEBBAL_33, KANAGALA_33 | 21:02 | 21:29 | 0:27 | TRANSFORMER FAULT |
| 131 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV2 | NIDAGUNDI_110 | 17:36 | 19:10 | 1:34 | TRANSFORMER FAULT |
| 132 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | MURDESHWAR_110 | 10:30 | 12:15 | 1:45 | LINE CLEAR AVAILED |
| 133 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | MUNDARGI_110 | 18:10 | 18:17 | 0:07 | TRANSFORMER FAULT |
| 134 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV2 | MALGHAN(B)_110 | 9:53 | 9:55 | 0:02 | TRANSFORMER FAULT |
| 135 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV4 | HUKKERI_110 | 20:59 | 21:40 | 0:41 | TRANSFORMER FAULT |
| 136 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | GOPPANAKOPPA_110 | 17:42 | 18:18 | 0:36 | LINE CLEAR AVAILED |
| 137 | 6-Feb-19 | BAGALKOT | 110 | MKHUBLI220-BAILHONGAL | BAILHONGAL_110 | 14:22 | 14:23 | 0:01 | HAND TRIPPED |
| 138 | 6-Feb-19 | BAGALKOT | 110 | SIRSI220-IDLE3(SIRSI1) | SIRSI_110 | 14:51 | 15:31 | 0:40 | LINE FAULT |
| 139 | 6-Feb-19 | BAGALKOT | 110 | 110/11KV, HV2 | DAVALESHWAR_110 | 11:33 | 14:51 | 3:18 | LINE CLEAR AVAILED |
| 140 | 6-Feb-19 | BANGALORE | 66 | ELECTRONIC CITY - YARANDANAHALLI 1 & 2 | ELECTRONIC CITY, INFOSYS (EHT) | 11:10 | 11:19 | 0:09 | LOAD CHANGEOVER |
| 141 | 6-Feb-19 | BANGALORE | 66 | ELECTRONIC CITY - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY, INFOSYS (EHT) | 11:52 | 12:00 | 0:08 | LOAD CHANGEOVER |
| 142 | 6-Feb-19 | BANGALORE | 66 | HV1 | KADUBISANAHALLI | 14:13 | 14:31 | 0:18 | LINE CLEAR AVAILED |
| 143 | 6-Feb-19 | BANGALORE | 66 | HV1 | HANUMANTHNAGARA | 10:00 | 10:10 | 0:10 | LINE CLEAR AVAILED |
| 144 | 6-Feb-19 | BANGALORE | 66 | HV2 | NANDINI LAYOUT | 12:39 | 13:40 | 1:00 | LINE CLEAR AVAILED |
| 145 | 6-Feb-19 | BANGALORE | 66 | HV2 | PADMANABHANAGARA | 11:23 | 11:24 | 0:01 | LINE CLEAR AVAILED |
| 146 | 6-Feb-19 | BANGALORE | 66 | HV1 | TK HALLI 220 | 13:15 | 13:18 | 0:03 | TRANSFORMER FAULT |
| 147 | 6-Feb-19 | BANGALORE | 66 | HV1 | TK HALLI 220 | 19:59 | 20:05 | 0:06 | TRANSFORMER FAULT |
| 148 | 6-Feb-19 | BANGALORE | 220 | SOMANAHALLI 220 - YARANDANAHALLI 220 | JIGANI 220, YARANDANAHALLI 220 | 11:13 | 11:40 | 0:26 | LINE CLEAR AVAILED |
| 149 | 6-Feb-19 | BANGALORE | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 11:12 | 11:45 | 0:33 | MAIN SUPPLY FAILURE |
| 150 | 6-Feb-19 | BANGALORE | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL | 11:12 | 11:47 | 0:35 | MAIN SUPPLY FAILURE |
| 151 | 6-Feb-19 | BANGALORE | 66 | YARANDANAHALLI 220 - TIMES OF INDIA(EHT) | TIMES OF INDIA(EHT) | 11:12 | 11:50 | 0:38 | MAIN SUPPLY FAILURE |
| 152 | 6-Feb-19 | BANGALORE | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | BOMMASANDRA I/A, BIOCON (EHT) | 11:12 | 11:48 | 0:36 | MAIN SUPPLY FAILURE |
| 153 | 6-Feb-19 | BANGALORE | 66 | POTTERY ROAD - HOODY 220 | POTTERY ROAD, ITC(EHT) | 11:20 | 11:25 | 0:05 | LOAD CHANGEOVER |
| 154 | 6-Feb-19 | BANGALORE | 66 | POTTERY ROAD - HEBBAL 220 | POTTERY ROAD, ITC(EHT) | 12:30 | 12:36 | 0:06 | LOAD CHANGEOVER |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|---------------------------------|---|---------|-----------|----------|--------------------|
| 155 | 6-Feb-19 | BANGALORE | 66 | HV2 | CHANDAPURA | 13:28 | 13:30 | 0:02 | LINE CLEAR AVAILED |
| 156 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - CB PURA 2 | CB PURA I/A, CB PURA URBAN, NALLIMARADANAHALLI | 9:51 | 17:50 | 7:59 | LINE CLEAR AVAILED |
| 157 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - CB PURA 1 | TUBUGERE | 9:51 | 19:47 | 9:56 | LINE CLEAR AVAILED |
| 158 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - DEVANAHALLI 1 & 2 | DEVANAHALLI, KUNDANA | 10:23 | 17:32 | 7:08 | LINE CLEAR AVAILED |
| 159 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - DG 2 | AIR (EHT) | 10:08 | 11:00 | 0:51 | LOAD CHANGEOVER |
| 160 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - DG 2 | AIR (EHT) | 16:30 | 16:46 | 0:15 | LOAD CHANGEOVER |
| 161 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - VIJAYAPURA | VIJAYAPURA, JANGAMAKOTE | 10:08 | 10:26 | 0:18 | LOAD CHANGEOVER |
| 162 | 6-Feb-19 | BANGALORE | 66 | DB PURA 220 - VIJAYAPURA | VIJAYAPURA, JANGAMAKOTE | 16:47 | 16:53 | 0:06 | LOAD CHANGEOVER |
| 163 | 6-Feb-19 | BANGALORE | 66 | GOWRIBIDANUR 220 - BAGEPALLI 1 | VATADAHOSAHALLI | 10:12 | 16:30 | 6:17 | LINE CLEAR AVAILED |
| 164 | 6-Feb-19 | BANGALORE | 66 | KOLAR 220 - NARASAPURA | NARASAPURA | 19:50 | 20:02 | 0:12 | LINE FAULT |
| 165 | 6-Feb-19 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT) | 14:02 | 14:36 | 0:33 | LINE FAULT |
| 166 | 6-Feb-19 | BANGALORE | 66 | MALUR 220 - KGF 2 | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 14:02 | 14:10 | 0:07 | LINE FAULT |
| 167 | 6-Feb-19 | BANGALORE | 66 | MALUR 220 - KGF 2 | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 14:10 | 14:36 | 0:26 | LINE FAULT |
| 168 | 6-Feb-19 | BANGALORE | 66 | SURYANAGAR - YARANDANAHALLI 220 | SURYANAGAR | 11:11 | 12:23 | 1:12 | LINE CLEAR AVAILED |
| 169 | 6-Feb-19 | BANGALORE | 66 | YELAHANKA 220 - LINE 7 | KANASWADI | 6:44 | 6:58 | 0:13 | LINE FAULT |
| 170 | 6-Feb-19 | GULBARGA | 110 | ALIPUR-BELLARYSOUTH2 | BELLARYSOUTH_110, HALKUNDI_110 | 19:00 | 19:06 | 0:06 | LINE FAULT |
| 171 | 6-Feb-19 | GULBARGA | 110 | HV2 | KOPPAL_110 | 14:30 | 16:01 | 1:31 | LINE CLEAR AVAILED |
| 172 | 6-Feb-19 | GULBARGA | 110 | HV2 | KOPPAL_110 | 21:55 | 22:28 | 0:33 | LINE CLEAR AVAILED |
| 173 | 6-Feb-19 | GULBARGA | 110 | KAPNOOR220-GULBARGA NORTH2 | GULBARGANORTH_110,GULBARGASOUTH_110,GULUNI_110 | 15:51 | 15:58 | 0:07 | HAND TRIPPED |
| 174 | 6-Feb-19 | GULBARGA | 110 | HUMNABAD220-BIDAR1 | HALIKHED_110 | 7:45 | 8:04 | 0:19 | LINE FAULT |
| 175 | 6-Feb-19 | GULBARGA | 110 | KAPNOOR220-GULBARGANORTH1 | GULBARGANORTH_110,GULBARGASOUTH_110,GULUNI_110 | 15:51 | 15:58 | 0:07 | HAND TRIPPED |
| 176 | 6-Feb-19 | GULBARGA | 110 | KOLHAR-SHAHI_SLR_IPP | KOLHAR_110 | 12:42 | 13:29 | 0:47 | LINE FAULT |
| 177 | 6-Feb-19 | GULBARGA | 66 | HV1 | HAMPASAGAR_66 | 15:25 | 15:31 | 0:06 | TRANSFORMER FAULT |
| 178 | 6-Feb-19 | HASSAN | 220 | MRSSHM-VARAH12 | MRSMSG_220 | 17:21 | 19:02 | 1:41 | LINE FAULT |
| 179 | 6-Feb-19 | HASSAN | 110 | HV1 | MRSMSG_220 | 18:00 | 18:05 | 0:05 | HAND TRIPPED |
| 180 | 6-Feb-19 | HASSAN | 110 | HV2 | MRSMSG_220 | 18:00 | 18:05 | 0:05 | HAND TRIPPED |
| 181 | 6-Feb-19 | HASSAN | 110 | HV3 | MRSMSG_220 | 18:05 | 18:13 | 0:08 | HAND TRIPPED |
| 182 | 6-Feb-19 | HASSAN | 110 | HV4 | MRSMSG_220 | 18:05 | 18:13 | 0:08 | HAND TRIPPED |
| 183 | 6-Feb-19 | HASSAN | 220 | HV1 | SHIRALKOPPA_220 | 12:57 | 23:59 | 11:02 | LINE CLEAR AVAILED |
| 184 | 6-Feb-19 | HASSAN | 110 | LV1 | SHIRALKOPPA_220 | 12:57 | 23:59 | 11:02 | LINE CLEAR AVAILED |
| 185 | 6-Feb-19 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 12:56 | 13:09 | 0:13 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|---------|---------|---------------------------------------|--|---------|-----------|----------|--------------------|
| 186 | 6-Feb-19 | HASSAN | 220 | VARAHI-SHIMOGA2 | VARAHI_GEN | 7:21 | 19:02 | 11:41 | LINE FAULT |
| 187 | 6-Feb-19 | HASSAN | 110 | BANTWA-SALATTUR | BANTWAL_110 | 10:30 | 14:07 | 3:37 | LINE CLEAR AVAILED |
| 188 | 6-Feb-19 | HASSAN | 110 | JOG110-AMBTR2 | JOG_110 | 11:17 | 23:59 | 12:42 | LINE CLEAR AVAILED |
| 189 | 6-Feb-19 | HASSAN | 110 | HV2 | KULASHEKARA_110 | 10:49 | 10:56 | 0:07 | TRANSFORMER FAULT |
| 190 | 6-Feb-19 | HASSAN | 110 | SAGARA-IDLE | SAGARA_110 | 18:24 | 18:41 | 0:17 | HAND TRIPPED |
| 191 | 6-Feb-19 | HASSAN | 110 | SORABA-SHR220 | SORABA_110 | 13:00 | 13:10 | 0:10 | HAND TRIPPED |
| 192 | 6-Feb-19 | HASSAN | 110 | HV2 | VITLA_110 | 11:21 | 19:47 | 8:26 | LINE CLEAR AVAILED |
| 193 | 6-Feb-19 | HASSAN | 110 | HV2 | VITLA_110 | 23:29 | 23:59 | 0:30 | TRANSFORMER FAULT |
| 194 | 6-Feb-19 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 11:05 | 13:54 | 2:49 | LINE CLEAR AVAILED |
| 195 | 6-Feb-19 | HASSAN | 66 | CHIKMA-L1-ALDUR | CHIKMAGALUR_66 | 16:46 | 17:08 | 0:22 | LINE FAULT |
| 196 | 6-Feb-19 | HASSAN | 66 | HV1 | HOLALUR_66 | 13:20 | 13:42 | 0:22 | LINE CLEAR AVAILED |
| 197 | 6-Feb-19 | HASSAN | 66 | RAMNAT-BNDSTHL | RAMNATHPURA_66 | 10:33 | 13:53 | 3:20 | NFBC ISSUED |
| 198 | 6-Feb-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHAPURA_66 | 6:04 | 6:16 | 0:12 | LINE FAULT |
| 199 | 6-Feb-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHAPURA_66 | 11:09 | 16:20 | 5:11 | LINE CLEAR AVAILED |
| 200 | 6-Feb-19 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESHAPURA_66 | 11:09 | 17:38 | 6:29 | LINE CLEAR AVAILED |
| 201 | 6-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 7:52 | 8:07 | 0:15 | LINE CLEAR AVAILED |
| 202 | 6-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 12:02 | 12:22 | 0:19 | LINE CLEAR AVAILED |
| 203 | 6-Feb-19 | MYSORE | 66 | HAMPAPURA-BASARALU | KOPPA_66, BESAGARAHALLI_66, DUNDANAHALLI_66 | 3:59 | 4:06 | 0:07 | LINE FAULT |
| 204 | 6-Feb-19 | MYSORE | 66 | HV1 | HONNALLY_MYS_66 | 12:26 | 12:28 | 0:02 | TRANSFORMER FAULT |
| 205 | 6-Feb-19 | MYSORE | 66 | HV1 | HONNALLY_MYS_66 | 12:35 | 12:44 | 0:09 | TRANSFORMER FAULT |
| 206 | 6-Feb-19 | MYSORE | 66 | HV2 | HONNALLY_MYS_66 | 12:26 | 12:28 | 0:02 | TRANSFORMER FAULT |
| 207 | 6-Feb-19 | MYSORE | 66 | HV2 | HONNALLY_MYS_66 | 12:35 | 12:44 | 0:09 | TRANSFORMER FAULT |
| 208 | 6-Feb-19 | MYSORE | 66 | KR PETE 220-MAHADESHWARAPURA | MADESWARAPURA_66,JAKKANAHALLY_66 GUDDENAHALLI_66, BOGADHI MANDYA_66, G MALLIGERE_66, NAGAMANGALA_66 | 10:27 | 10:30 | 0:02 | LINE FAULT |
| 209 | 6-Feb-19 | MYSORE | 66 | KUSHALANAGRA 220-SUNTIKOPPA | SUNTIKOPPA_66 | 16:48 | 19:57 | 3:09 | LINE FAULT |
| 210 | 6-Feb-19 | MYSORE | 66 | HV1 | PONNAMPET_66 | 13:00 | 13:42 | 0:41 | LINE CLEAR AVAILED |
| 211 | 6-Feb-19 | MYSORE | 66 | HV2 | PONNAMPET_66 | 13:00 | 13:42 | 0:41 | LINE CLEAR AVAILED |
| 212 | 6-Feb-19 | MYSORE | 66 | HV5 | SFCSHIVA_66 | 6:43 | 10:00 | 3:16 | HAND TRIPPED |
| 213 | 6-Feb-19 | MYSORE | 66 | HV1 | SUNTIKOPPA_66 | 16:45 | 0:00 | 7:15 | TRANSFORMER FAULT |
| 214 | 6-Feb-19 | MYSORE | 66 | HV1 | VIRAJPET_66 | 13:01 | 14:41 | 1:39 | LINE CLEAR AVAILED |
| 215 | 6-Feb-19 | MYSORE | 66 | HV2 | VIRAJPET_66 | 14:05 | 15:09 | 1:04 | LINE CLEAR AVAILED |
| 216 | 6-Feb-19 | TUMKUR | 220 | ANTHRASANAHALLI 220kv- NELAMANGALA | ANTHRASANAHALLI_220 | 14:16 | 16:32 | 2:16 | HAND TRIPPED |
| 217 | 6-Feb-19 | TUMKUR | 110 | HONNAVALLI 110-TIPTUR | HALKURKE_110,KEREKODI_110,HUNSEG HATTA_110 | 13:31 | 14:59 | 1:28 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|----------|---------|---|--|---------|-----------|----------|--------------------|
| 218 | 6-Feb-19 | TUMKUR | 66 | TR-1 | AMRUTHUR_66 | 15:44 | 16:30 | 0:45 | HAND TRIPPED |
| 219 | 6-Feb-19 | TUMKUR | 66 | TR-2 | BELADARA_66 | 11:37 | 13:51 | 2:14 | LINE CLEAR AVAILED |
| 220 | 6-Feb-19 | TUMKUR | 66 | TR-2 | BELLAVI_66 | 13:28 | 14:11 | 0:43 | LINE CLEAR AVAILED |
| 221 | 6-Feb-19 | TUMKUR | 66 | TR-2 | DAVANAGERE_66 | 12:39 | 13:11 | 0:32 | LINE CLEAR AVAILED |
| 222 | 6-Feb-19 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66 | 17:27 | 17:45 | 0:18 | LINE FAULT |
| 223 | 6-Feb-19 | TUMKUR | 66 | TR-1(HV SIDE) | DAVANAGERE_66 | 22:26 | 22:34 | 0:08 | HAND TRIPPED |
| 224 | 6-Feb-19 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 18:00 | 18:18 | 0:17 | LINE FAULT |
| 225 | 6-Feb-19 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 10:23 | 10:59 | 0:36 | HAND TRIPPED |
| 226 | 6-Feb-19 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 21:04 | 21:38 | 0:34 | HAND TRIPPED |
| 227 | 6-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:26 | 17:49 | 9:23 | HAND TRIPPED |
| 228 | 6-Feb-19 | TUMKUR | 66 | GUTUR_400-DAVANGERE SRS2 | DAVANGERE_SRS_220 | 17:23 | 17:33 | 0:10 | HAND TRIPPED |
| 229 | 6-Feb-19 | TUMKUR | 66 | TR-2 | GUTUR_400 | 17:23 | 17:33 | 0:10 | HAND TRIPPED |
| 230 | 6-Feb-19 | TUMKUR | 66 | HARAPPANAHALLI-SUZLON 2 | SUZLON_IPP_66 | 13:50 | 18:52 | 5:02 | LINE CLEAR AVAILED |
| 231 | 6-Feb-19 | TUMKUR | 66 | HIRIYUR 220KV- RKP2 | RKP2_IPP_66 | 15:13 | 19:36 | 4:23 | LINE CLEAR AVAILED |
| 232 | 6-Feb-19 | TUMKUR | 66 | HONNALLI 220KV- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 11:00 | 11:16 | 0:16 | LINE FAULT |
| 233 | 6-Feb-19 | TUMKUR | 66 | HONNALLI 220KV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 14:45 | 15:30 | 0:44 | LINE CLEAR AVAILED |
| 234 | 6-Feb-19 | TUMKUR | 66 | HOSAKERE- MIDIGESHI | MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66 | 6:41 | 6:45 | 0:04 | LINE FAULT |
| 235 | 6-Feb-19 | TUMKUR | 66 | TR-1 | KATTIGE_66 | 1:06 | 1:13 | 0:07 | TRANSFORMER FAULT |
| 236 | 6-Feb-19 | TUMKUR | 66 | KEMPANAHALLI - AGALAKOTE | AGALKOTE_66 | 13:50 | 14:18 | 0:28 | LINE CLEAR AVAILED |
| 237 | 6-Feb-19 | TUMKUR | 66 | LINGADAHALLI- SHYLAPURA | SHYLAPURA_66,, MANGALWADA_66, YNHOSKOTE_66 | 18:03 | 18:05 | 0:01 | HAND TRIPPED |
| 238 | 6-Feb-19 | TUMKUR | 66 | MATHOD- PANCHANAHALLI | PANCHANAHALLI_66, GARAGA_66 | 18:54 | 19:10 | 0:15 | LOAD CURTAILMENT |
| 239 | 6-Feb-19 | TUMKUR | 66 | MATHOD- PANCHANAHALLI | PANCHANAHALLI_66, GARAGA_66 | 22:19 | 23:21 | 1:01 | LOAD CURTAILMENT |
| 240 | 6-Feb-19 | TUMKUR | 66 | NEELAGUNDA 220KV- HARAPPANAHALLI | HARAPPANAHALLI_66 | 13:51 | 18:19 | 4:28 | LINE CLEAR AVAILED |
| 241 | 6-Feb-19 | TUMKUR | 66 | TR-1 | TUMKUR_66 | 23:16 | 23:32 | 0:16 | HAND TRIPPED |
| 242 | 6-Feb-19 | TUMKUR | 66 | SIRA- KALLAMBELLA | KALLAMBELLA_66 | 21:35 | 21:48 | 0:13 | LINE FAULT |
| 243 | 6-Feb-19 | TUMKUR | 66 | SIRA- MADHUGIRI 2 | BUKKAPATNA_66, KALLAMBELLA_66 | 21:35 | 21:48 | 0:13 | LINE FAULT |
| 244 | 7-Feb-19 | BAGALKOT | 220 | AMBEWADI-NAGJHARI1 | AMBEWADI_220 | 10:13 | 15:11 | 4:58 | LINE CLEAR AVAILED |
| 245 | 7-Feb-19 | BAGALKOT | 220 | GADAG-LINGAPUR1(DHONI1) | GADAG_220 | 11:30 | 17:41 | 6:11 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|----------------------------------|--|---------|-----------|----------|---------------------|
| 246 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV2 | BAGALKOT_110 | 9:29 | 9:34 | 0:05 | TRANSFORMER FAULT |
| 247 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | ATHANI_220 | 9:52 | 16:12 | 6:20 | LINE CLEAR AVAILED |
| 248 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV3 | BIJAPUR CITY_110 | 10:02 | 10:58 | 0:56 | LINE CLEAR AVAILED |
| 249 | 7-Feb-19 | BAGALKOT | 110 | GADAG220-DAMBAL2 | DAMBAL_110 | 2:37 | 3:18 | 0:41 | LINE FAULT |
| 250 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | GADAG_110 | 6:08 | 6:17 | 0:09 | TRANSFORMER FAULT |
| 251 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | GADAG_110 | 6:20 | 6:30 | 0:10 | TRANSFORMER FAULT |
| 252 | 7-Feb-19 | BAGALKOT | 110 | KUDACHI220-UGARKHUD(KUDACHI110) | KUDACHI_110 | 10:16 | 17:49 | 7:33 | LINE CLEAR AVAILED |
| 253 | 7-Feb-19 | BAGALKOT | 110 | KUDACHI220-TERDAL(MORAB) | MORAB_110 | 12:36 | 17:53 | 5:17 | LINE CLEAR AVAILED |
| 254 | 7-Feb-19 | BAGALKOT | 110 | KUMTA-SIRSI1 | KUMTA_110 | 17:29 | 17:38 | 0:09 | LINE CLEAR AVAILED |
| 255 | 7-Feb-19 | BAGALKOT | 110 | KUMTA-SIRSI1 | KUMTA_110 | 18:27 | 23:59 | 5:32 | LINE CLEAR AVAILED |
| 256 | 7-Feb-19 | BAGALKOT | 110 | 110/33KV, HV4 | LAKMANHALLI_110, ALNAVAR_33 | 10:50 | 11:10 | 0:20 | TRANSFORMER FAULT |
| 257 | 7-Feb-19 | BAGALKOT | 110 | DAMBAL-MUNDARGI | MUNDARGI_110 | 3:10 | 3:20 | 0:10 | HAND TRIPPED |
| 258 | 7-Feb-19 | BAGALKOT | 110 | VIJAYNAGAR SUGARS-MUNDARGI | MUNDARGI_110 | 2:40 | 3:24 | 0:44 | LINE FAULT |
| 259 | 7-Feb-19 | BAGALKOT | 110 | 110/33KV, HV3 | MURDESHWAR_110, KASARKOD_33 | 7:35 | 8:44 | 1:09 | LINE CLEAR AVAILED |
| 260 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | SALAHALLI_110 | 9:29 | 10:10 | 0:41 | LINE CLEAR AVAILED |
| 261 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | SIDDAPUR_110 | 13:23 | 14:08 | 0:45 | LINE CLEAR AVAILED |
| 262 | 7-Feb-19 | BAGALKOT | 110 | 110/11KV,HV-2 | UGAR KHUD_110 | 15:10 | 15:28 | 0:18 | TRANSFORMER FAULT |
| 263 | 7-Feb-19 | BAGALKOT | 220 | NAGJHARI 2-SRS HUBLI | SRS HUBLI_220 | 12:38 | 13:03 | 0:25 | LINE FAULT |
| 264 | 7-Feb-19 | BAGALKOT | 110 | 220KV SIRSI- 110V IDLE3(SIRSI 1) | SIRSI_110 | 16:03 | 16:54 | 0:51 | HAND TRIPPED |
| 265 | 7-Feb-19 | BANGALORE | 66 | CHANDAPURA - YERANDANAHALLI 220 | CHANDAPURA | 17:00 | 17:05 | 0:05 | LOAD CHANGEOVER |
| 266 | 7-Feb-19 | BANGALORE | 66 | HV1 | SURYANAGAR | 11:28 | 11:38 | 0:09 | TRANSFORMER FAULT |
| 267 | 7-Feb-19 | BANGALORE | 220 | MALUR - KOLAR 1 | MALUR 220 | 15:15 | 16:30 | 1:15 | MAIN SUPPLY FAILURE |
| 268 | 7-Feb-19 | BANGALORE | 220 | MALUR - KOLAR 3 | SARJAPURA 220, VIKAS TECH PARK 220 | 15:15 | 16:26 | 1:11 | MAIN SUPPLY FAILURE |
| 269 | 7-Feb-19 | BANGALORE | 66 | MALUR 220 - MAASTHI | MAASTHI, DEVANGONDHI, LAKKUR | 15:15 | 16:26 | 1:11 | MAIN SUPPLY FAILURE |
| 270 | 7-Feb-19 | BANGALORE | 66 | MALUR 220 - KGF 1 | KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 15:15 | 16:31 | 1:16 | MAIN SUPPLY FAILURE |
| 271 | 7-Feb-19 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT) | 15:15 | 16:26 | 1:11 | MAIN SUPPLY FAILURE |
| 272 | 7-Feb-19 | BANGALORE | 66 | MALUR 220 - MALUR 66 | MALUR 66 | 15:15 | 16:26 | 1:11 | MAIN SUPPLY FAILURE |
| 273 | 7-Feb-19 | BANGALORE | 220 | HV1 | KOLAR 220 | 17:10 | 17:16 | 0:06 | LINE CLEAR AVAILED |
| 274 | 7-Feb-19 | BANGALORE | 220 | HV2 | KOLAR 220 | 17:10 | 17:16 | 0:06 | LINE CLEAR AVAILED |
| 275 | 7-Feb-19 | BANGALORE | 220 | HV3 | KOLAR 220 | 17:10 | 17:16 | 0:06 | LINE CLEAR AVAILED |
| 276 | 7-Feb-19 | BANGALORE | 220 | KOLAR 220 - PGCIL 1 & 2 | KOLAR 220 | 15:15 | 15:45 | 0:30 | MAIN SUPPLY FAILURE |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|--|--|---------|-----------|----------|---------------------|
| 277 | 7-Feb-19 | BANGALORE | 66 | KOLAR 220 - NANGALI | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 7:37 | 8:05 | 0:27 | LOAD CURTAILMENT |
| 278 | 7-Feb-19 | BANGALORE | 66 | GANJIGUNTE - DIBBURAHALLI, | DIBBURAHALLI, SOMENAHALLI, SADLI, JULUPALYA | 11:03 | 11:16 | 0:12 | LINE FAULT |
| 279 | 7-Feb-19 | BANGALORE | 66 | DOMMASANDRA - KACHMARANAHALLI | DOMMASANDRA | 16:30 | 16:40 | 0:10 | LOAD CHANGEOVER |
| 280 | 7-Feb-19 | BANGALORE | 66 | HV1 | DABUSPET 220 | 11:45 | 12:44 | 0:58 | LINE CLEAR AVAILED |
| 281 | 7-Feb-19 | BANGALORE | 220 | HV2 | CHINTAMANI 220 | 12:11 | 13:05 | 0:54 | TRANSFORMER FAULT |
| 282 | 7-Feb-19 | BANGALORE | 220 | CHINTAMANI 220 - PGCIL 2 | CHINTAMANI 220 | 16:22 | 18:24 | 2:02 | LINE CLEAR AVAILED |
| 283 | 7-Feb-19 | BANGALORE | 220 | CHINTAMANI 220 - PGCIL 2 | CHINTAMANI 220 | 15:15 | 15:35 | 0:20 | MAIN SUPPLY FAILURE |
| 284 | 7-Feb-19 | BANGALORE | 220 | CHINTAMANI 220 - PGCIL 2 | CHINTAMANI 220 | 12:49 | 12:57 | 0:08 | LOAD CHANGEOVER |
| 285 | 7-Feb-19 | BANGALORE | 66 | CHINTAMANI 220 - GANJIGUNTE 1 | GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA | 11:03 | 11:11 | 0:07 | LINE FAULT |
| 286 | 7-Feb-19 | BANGALORE | 66 | CHINTAMANI 220 - GANJIGUNTE 2 | GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA | 11:03 | 11:11 | 0:07 | LINE FAULT |
| 287 | 7-Feb-19 | BANGALORE | 66 | SARJAPURA 220 - DOMMASANDRA | DOMMASANDRA | 15:05 | 16:00 | 0:55 | MAIN SUPPLY FAILURE |
| 288 | 7-Feb-19 | BANGALORE | 66 | SARJAPURA 220 - ATTIBELE | ATTIBELE | 15:05 | 16:29 | 1:24 | MAIN SUPPLY FAILURE |
| 289 | 7-Feb-19 | BANGALORE | 66 | SARJAPURA 220 - CHANDAPURA | CHANDAPURA | 15:05 | 16:05 | 1:00 | MAIN SUPPLY FAILURE |
| 290 | 7-Feb-19 | BANGALORE | 66 | HV2 | NANGALI | 13:40 | 14:17 | 0:36 | LINE CLEAR AVAILED |
| 291 | 7-Feb-19 | BANGALORE | 66 | HV2 | HOSUR RAMAPURA | 12:59 | 13:05 | 0:06 | LINE CLEAR AVAILED |
| 292 | 7-Feb-19 | BANGALORE | 66 | VIKAS TECH PARK 220 - RMZ | RMZ | 15:15 | 16:25 | 1:10 | MAIN SUPPLY FAILURE |
| 293 | 7-Feb-19 | BANGALORE | 66 | VIKAS TECH PARK 220 - PRIMAL PROJECTS | PRIMAL PROJECTS | 15:15 | 16:25 | 1:10 | MAIN SUPPLY FAILURE |
| 294 | 7-Feb-19 | BANGALORE | 66 | VIKAS TECH PARK 220 - GLOBAL TECH PARK | GLOBAL TECH PARK, GLOBAL TECH PARK (EHT) | 15:15 | 16:25 | 1:10 | MAIN SUPPLY FAILURE |
| 295 | 7-Feb-19 | BANGALORE | 66 | TK HALLI 220 - BWSSB 1 (EHT) | BWSSB (EHT) | 14:59 | 15:10 | 0:10 | MAIN SUPPLY FAILURE |
| 296 | 7-Feb-19 | BANGALORE | 66 | TK HALLI 220 - BWSSB 2 (EHT) | BWSSB (EHT) | 14:59 | 15:10 | 0:10 | MAIN SUPPLY FAILURE |
| 297 | 7-Feb-19 | BANGALORE | 66 | TK HALLI 220 - BWSSB 4 (EHT) | BWSSB (EHT) | 14:59 | 15:10 | 0:10 | MAIN SUPPLY FAILURE |
| 298 | 7-Feb-19 | BANGALORE | 220 | HV1 | TK HALLI 220 | 14:59 | 15:08 | 0:09 | TRANSFORMER FAULT |
| 299 | 7-Feb-19 | BANGALORE | 66 | HV1 | TK HALLI 220 | 14:59 | 15:10 | 0:10 | MAIN SUPPLY FAILURE |
| 300 | 7-Feb-19 | BANGALORE | 66 | KANAKAPURA 220 - TK HALLI 1 | HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI | 10:36 | 12:56 | 2:19 | LINE CLEAR AVAILED |
| 301 | 7-Feb-19 | BANGALORE | 66 | SOMANAHALLI 220 - KUMBALAGODU | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 11:28 | 11:47 | 0:19 | LINE FAULT |
| 302 | 7-Feb-19 | BANGALORE | 66 | HV1 | AMARJYOTHI | 22:34 | 22:59 | 0:24 | TRANSFORMER FAULT |
| 303 | 7-Feb-19 | BANGALORE | 66 | ELECTRONIC CITY - YARANDANAHALLI 1 & 2 | ELECTRONIC CITY, INFOSYS (EHT) | 16:00 | 16:05 | 0:05 | LOAD CHANGEOVER |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|---|--|---------|-----------|----------|---------------------|
| 304 | 7-Feb-19 | BANGALORE | 66 | ELECTRONIC CITY - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY, INFOSYS (EHT) | 17:00 | 17:06 | 0:06 | LOAD CHANGEOVER |
| 305 | 7-Feb-19 | BANGALORE | 66 | ELITE PROMENEDE - KHODAYS 220 | ELITE PROMENEDE | 12:03 | 20:26 | 8:22 | LINE CLEAR AVAILED |
| 306 | 7-Feb-19 | BANGALORE | 66 | HV1 | GOKULA | 11:37 | 12:02 | 0:25 | LINE CLEAR AVAILED |
| 307 | 7-Feb-19 | BANGALORE | 66 | HV2 | HANUMANTHANAGARA | 14:41 | 16:19 | 1:38 | LINE CLEAR AVAILED |
| 308 | 7-Feb-19 | BANGALORE | 66 | HV2 | HEJJALA | 12:06 | 13:39 | 1:33 | LINE CLEAR AVAILED |
| 309 | 7-Feb-19 | BANGALORE | 66 | HOODY 220 - ITI | ITI | 15:12 | 15:27 | 0:15 | LINE FAULT |
| 310 | 7-Feb-19 | BANGALORE | 66 | HOODY 220 - POTTERY ROAD | POTTERY ROAD, ITC (EHT) | 15:12 | 15:28 | 0:16 | LINE FAULT |
| 311 | 7-Feb-19 | BANGALORE | 66 | ADUGODI - HAL 2 | K&C VALLEY, NAL(EHT) | 14:22 | 16:33 | 2:10 | LINE FAULT |
| 312 | 7-Feb-19 | BANGALORE | 66 | NIMHANS 220 - ADUGODI | ADUGODI, BOSCH (EHT) | 14:22 | 14:47 | 0:24 | LINE FAULT |
| 313 | 7-Feb-19 | BANGALORE | 66 | NIMHANS 220 - JAYADEVA | JAYADEVA | 14:22 | 14:38 | 0:15 | MAIN SUPPLY FAILURE |
| 314 | 7-Feb-19 | BANGALORE | 66 | NIMHANS 220 - JAYANAGARA | JAYANAGARA, PADMANABHANAGARA | 14:22 | 14:39 | 0:16 | MAIN SUPPLY FAILURE |
| 315 | 7-Feb-19 | BANGALORE | 66 | HSR LAYOUT 220 - NIMHANS 220 | NIMHANS 220 | 14:22 | 14:36 | 0:13 | LINE FAULT |
| 316 | 7-Feb-19 | BANGALORE | 66 | HV1 | NIMHANS 220 | 14:22 | 14:39 | 0:16 | MAIN SUPPLY FAILURE |
| 317 | 7-Feb-19 | BANGALORE | 66 | HV2 | NIMHANS 220 | 14:22 | 14:39 | 0:16 | MAIN SUPPLY FAILURE |
| 318 | 7-Feb-19 | GULBARGA | 220 | SEDAM-TANDUR | TANDUR_220 | 14:08 | 18:28 | 4:20 | LINE CLEAR AVAILED |
| 319 | 7-Feb-19 | GULBARGA | 220 | LINGAPUR-GUDAHALLI1 | LINGAPUR_220 | 9:53 | 13:24 | 3:31 | LINE CLEAR AVAILED |
| 320 | 7-Feb-19 | GULBARGA | 110 | SINDHANOOR220-MUNIRABAD1 | KARTAGI_110,SRERAMANAGAR_110,VE NKATAGIRI_110,GANGAVATHI_110 | 18:03 | 19:28 | 1:25 | LINE FAULT |
| 321 | 7-Feb-19 | GULBARGA | 110 | HV1 | RAICHUR_220 | 1:13 | 1:31 | 0:18 | TRANSFORMER FAULT |
| 322 | 7-Feb-19 | HASSAN | 220 | HASSAN4-C R PATNA | HASSAN_400 | 12:11 | 16:39 | 4:28 | LINE CLEAR AVAILED |
| 323 | 7-Feb-19 | HASSAN | 220 | ARSK2-NITTUR | ARASIKERE_220 | 10:19 | 15:59 | 5:40 | NFBC ISSUED |
| 324 | 7-Feb-19 | HASSAN | 220 | KADUR-DABUSET | KADUR_220 | 10:06 | 15:41 | 5:35 | NFBC ISSUED |
| 325 | 7-Feb-19 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 9:50 | 17:20 | 7:30 | LINE CLEAR AVAILED |
| 326 | 7-Feb-19 | HASSAN | 220 | VARAHI-KEMAR2 | VARAHI_GEN | 9:50 | 17:20 | 7:30 | NFBC ISSUED |
| 327 | 7-Feb-19 | HASSAN | 220 | HV2 | GOPALPURA_220 | 10:14 | 15:34 | 5:20 | LINE CLEAR AVAILED |
| 328 | 7-Feb-19 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 7:28 | 8:25 | 0:57 | MAIN SUPPLY FAILURE |
| 329 | 7-Feb-19 | HASSAN | 110 | HV3 | PUTTUR_110 | 10:28 | 13:28 | 3:00 | LINE CLEAR AVAILED |
| 330 | 7-Feb-19 | HASSAN | 110 | HV1 | JOG_110 | 18:01 | 19:46 | 1:45 | LINE CLEAR AVAILED |
| 331 | 7-Feb-19 | HASSAN | 110 | KAVOOR-BAIKAMPADY | KAVOOR | 17:33 | 17:44 | 0:11 | LINE FAULT |
| 332 | 7-Feb-19 | HASSAN | 110 | HV1 | SAGARA_110 | 10:02 | 10:24 | 0:22 | TRANSFORMER FAULT |
| 333 | 7-Feb-19 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 0:16 | 0:50 | 0:34 | LINE FAULT |
| 334 | 7-Feb-19 | HASSAN | 110 | SHRLKP-SHIKARIPURA | SHIRALKOPPA_220 | 0:18 | 0:36 | 0:18 | LINE FAULT |
| 335 | 7-Feb-19 | HASSAN | 110 | HV2 | VITLA_110 | 10:49 | 11:16 | 0:27 | LINE CLEAR AVAILED |
| 336 | 7-Feb-19 | HASSAN | 66 | HASSN22-HN PURA | HASSAN_220 | 10:38 | 16:18 | 5:40 | LINE CLEAR AVAILED |
| 337 | 7-Feb-19 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 7:22 | 18:12 | 10:50 | MAIN SUPPLY FAILURE |
| 338 | 7-Feb-19 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 7:22 | 18:03 | 10:41 | MAIN SUPPLY FAILURE |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|---------|---------|---------------------------------------|---|---------|-----------|----------|--------------------|
| 339 | 7-Feb-19 | HASSAN | 66 | HV1 | CHIKMAGALUR_66 | 18:48 | 19:35 | 0:47 | LINE CLEAR AVAILED |
| 340 | 7-Feb-19 | HASSAN | 66 | CHIKMA-L1-ALDUR | CHIKMAGALUR_66 | 7:22 | 18:07 | 10:45 | LINE CLEAR AVAILED |
| 341 | 7-Feb-19 | HASSAN | 66 | GENDEHA-MUDIGERE | GENDEHALLI_66 | 18:42 | 18:55 | 0:13 | LINE FAULT |
| 342 | 7-Feb-19 | HASSAN | 66 | HV1 | KALASAPURA_66 | 14:41 | 14:43 | 0:02 | HAND TRIPPED |
| 343 | 7-Feb-19 | HASSAN | 66 | UDDURKO-CKNDGL | UDDURKOPLU_66 | 18:25 | 18:46 | 0:21 | LINE FAULT |
| 344 | 7-Feb-19 | HASSAN | 66 | UDDURKO-CKNDGL | UDDURKOPLU_66 | 18:50 | 19:33 | 0:43 | LINE FAULT |
| 345 | 7-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 7:58 | 8:11 | 0:12 | LINE CLEAR AVAILED |
| 346 | 7-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 12:00 | 23:59 | 11:58 | LINE CLEAR AVAILED |
| 347 | 7-Feb-19 | MYSORE | 66 | HV1 | DUNDANAHALLI_66 | 14:30 | 15:10 | 0:40 | LINE CLEAR AVAILED |
| 348 | 7-Feb-19 | MYSORE | 66 | HV2 | DUNDANAHALLI_66 | 14:30 | 15:28 | 0:58 | LINE CLEAR AVAILED |
| 349 | 7-Feb-19 | MYSORE | 66 | KADAKOLA-SARGUR 1 | JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66 | 18:39 | 18:44 | 0:05 | LINE FAULT |
| 350 | 7-Feb-19 | MYSORE | 66 | KIADB MANDYA-MADDUR | MADDUR_66 K K_HONNALGERE_66 | 9:15 | 9:29 | 0:14 | LINE FAULT |
| 351 | 7-Feb-19 | MYSORE | 66 | HV1 | KMDODDI_66 | 14:25 | 14:35 | 0:10 | TRANSFORMER FAULT |
| 352 | 7-Feb-19 | MYSORE | 66 | HV2 | KMDODDI_66 | 14:25 | 15:05 | 0:40 | TRANSFORMER FAULT |
| 353 | 7-Feb-19 | MYSORE | 66 | HV2 | KMDODDI_66 | 4:25 | 7:12 | 2:46 | TRANSFORMER FAULT |
| 354 | 7-Feb-19 | MYSORE | 66 | KR PETE 220-MAHADESHWARAPURA | MADESWARAPURA_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 G MALLIGERE_66 JAKKANAHALLY_66 NAGAMANGALA_66 | 7:41 | 7:52 | 0:10 | LINE FAULT |
| 355 | 7-Feb-19 | MYSORE | 66 | HV1 | MADIKERI_66 | 9:32 | 18:50 | 9:17 | LINE CLEAR AVAILED |
| 356 | 7-Feb-19 | MYSORE | 66 | HV1 | RAMAPURA_MYS_66 | 17:26 | 18:00 | 0:34 | LINE CLEAR AVAILED |
| 357 | 7-Feb-19 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 12:04 | 13:19 | 1:15 | LINE CLEAR AVAILED |
| 358 | 7-Feb-19 | MYSORE | 66 | HV2 | SANTHESARAGUR_66 | 7:00 | 7:42 | 0:42 | LINE CLEAR AVAILED |
| 359 | 7-Feb-19 | MYSORE | 66 | HV1 | SRIRANGAPATNA_66 | 12:31 | 12:40 | 0:08 | TRANSFORMER FAULT |
| 360 | 7-Feb-19 | MYSORE | 66 | SUNTIKOPPA-KUSHALANAGAR | SUNTIKOPPA_66 | 8:19 | 16:02 | 7:43 | LINE CLEAR AVAILED |
| 361 | 7-Feb-19 | MYSORE | 66 | SUNTIKOPPA-MADIKERI | SUNTIKOPPA_66 | 8:19 | 16:20 | 8:01 | LINE CLEAR AVAILED |
| 362 | 7-Feb-19 | TUMKUR | 220 | NITTUR 220kV-HASSAN | NITTUR_220 | 10:19 | 15:57 | 5:38 | LINE CLEAR AVAILED |
| 363 | 7-Feb-19 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- TUMKUR | TUMKUR_66 | 8:33 | 10:13 | 1:39 | LINE CLEAR AVAILED |
| 364 | 7-Feb-19 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 13:28 | 17:27 | 3:59 | LINE FAULT |
| 365 | 7-Feb-19 | TUMKUR | 66 | TR-2 | BRAHMASANDRA_66 | 22:03 | 22:32 | 0:29 | TRANSFORMER FAULT |
| 366 | 7-Feb-19 | TUMKUR | 66 | TR-1 | CHANNAGIRI_66 | 12:09 | 12:17 | 0:07 | TRANSFORMER FAULT |
| 367 | 7-Feb-19 | TUMKUR | 66 | TR-1 & TR-2 | CHANNAGIRI_66 | 16:20 | 17:03 | 0:43 | HAND TRIPPED |
| 368 | 7-Feb-19 | TUMKUR | 66 | CHANNAGIRI- (CHANNAGIRI(LINGDHLI)) | CHANNAGIRI_66 | 16:36 | 17:03 | 0:27 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|----------|---------|--|--|---------|-----------|----------|--------------------|
| 369 | 7-Feb-19 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 17:25 | 17:42 | 0:16 | LINE FAULT |
| 370 | 7-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:40 | 17:41 | 9:01 | HAND TRIPPED |
| 371 | 7-Feb-19 | TUMKUR | 66 | TR-1 | HANGLA_66 | 10:36 | 10:46 | 0:10 | LINE CLEAR AVAILED |
| 372 | 7-Feb-19 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 10:06 | 10:13 | 0:06 | LINE FAULT |
| 373 | 7-Feb-19 | TUMKUR | 66 | KALAMARANAHALLI- PR PURA | KALAMARANAHALLI_66 | 8:43 | 17:30 | 8:47 | HAND TRIPPED |
| 374 | 7-Feb-19 | TUMKUR | 66 | TR-2 | SHYLAPURA_66 | 18:07 | 18:21 | 0:14 | HAND TRIPPED |
| 375 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | AREMALLAPUR_110 | 10:06 | 10:40 | 0:34 | LINE CLEAR AVAILED |
| 376 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | ATHANI_220 | 12:58 | 13:33 | 0:35 | LINE CLEAR AVAILED |
| 377 | 8-Feb-19 | BAGALKOT | 110 | BAGALKOT220-GULEDAGUDDA | GULEDAGUDDA_110 | 17:10 | 18:33 | 1:23 | LINE CLEAR AVAILED |
| 378 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | BAGALKOT_110 | 9:23 | 9:34 | 0:11 | TRANSFORMER FAULT |
| 379 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | BAGALKOT_110 | 11:26 | 12:08 | 0:42 | LINE CLEAR AVAILED |
| 380 | 8-Feb-19 | BAGALKOT | 110 | BELGAUM220-ANKALAGI | ANKALAGI_110 | 12:00 | 13:43 | 1:43 | HAND TRIPPED |
| 381 | 8-Feb-19 | BAGALKOT | 110 | BELGAUM220-ANKALAGI | ANKALAGI_110 | 14:27 | 14:43 | 0:16 | HAND TRIPPED |
| 382 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | DAMBAL_110 | 10:47 | 17:26 | 6:39 | LINE CLEAR AVAILED |
| 383 | 8-Feb-19 | BAGALKOT | 110 | MRITYUNJAYNAGAR1- GOPANAKOPPA | GOPANAKOPPA_110 | 13:37 | 13:40 | 0:03 | HAND TRIPPED |
| 384 | 8-Feb-19 | BAGALKOT | 110 | MRITYUNJAYNAGAR2- GOPANAKOPPA | GOPANAKOPPA_110 | 13:37 | 14:41 | 1:04 | HAND TRIPPED |
| 385 | 8-Feb-19 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 14:30 | 14:41 | 0:11 | HAND TRIPPED |
| 386 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | HIDIKAL_110 | 15:07 | 15:11 | 0:04 | LINE CLEAR AVAILED |
| 387 | 8-Feb-19 | BAGALKOT | 110 | 110/33KV, HV4 | LAKMANHALLI_110, ALANAVAR_33 | 9:53 | 10:00 | 0:07 | TRANSFORMER FAULT |
| 388 | 8-Feb-19 | BAGALKOT | 110 | 220/110KV, LV3 | MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110 | 11:11 | 11:19 | 0:08 | TRANSFORMER FAULT |
| 389 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | MAREGUDDI_110 | 11:05 | 11:51 | 0:46 | LINE CLEAR AVAILED |
| 390 | 8-Feb-19 | BAGALKOT | 220 | 220/110KV,HV1&LV1 | BIDNAL_220 | 13:18 | 14:01 | 0:43 | TRANSFORMER FAULT |
| 391 | 8-Feb-19 | BAGALKOT | 110 | BIDNAL220-ANNIGERI | ANNIGERI_110 | 13:34 | 14:45 | 1:11 | HAND TRIPPED |
| 392 | 8-Feb-19 | BAGALKOT | 110 | BIDNAL220-GADAG ROAD | GADAG ROAD_110 | 13:25 | 14:26 | 1:01 | HAND TRIPPED |
| 393 | 8-Feb-19 | BAGALKOT | 110 | BIDNAL220-NAVALGUND | NAVALGUND_110 | 13:24 | 14:28 | 1:04 | HAND TRIPPED |
| 394 | 8-Feb-19 | BAGALKOT | 110 | BIDNAL220-PH COMPOUND | PH COMPOUND_110 | 13:25 | 14:19 | 0:54 | HAND TRIPPED |
| 395 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1&HV2 | BIDNAL_220 | 13:25 | 13:34 | 0:09 | HAND TRIPPED |
| 396 | 8-Feb-19 | BAGALKOT | 220 | GADAG-LINGAPUR1(DHONI1) | GADAG_220 | 10:06 | 17:52 | 7:46 | LINE CLEAR AVAILED |
| 397 | 8-Feb-19 | BAGALKOT | 110 | BIDNAL220-NAVALGUND | NAVALGUND_110 | 14:01 | 23:59 | 9:58 | HAND TRIPPED |
| 398 | 8-Feb-19 | BAGALKOT | 110 | KONNUR-NAVALGUND | NAVALGUND_110 | 15:40 | 16:03 | 0:23 | HAND TRIPPED |
| 399 | 8-Feb-19 | BAGALKOT | 110 | 110/33KV.HV5 | INDI_110 | 8:09 | 10:45 | 2:36 | HAND TRIPPED |
| 400 | 8-Feb-19 | BAGALKOT | 110 | INDI220-INDI | INDI_110 | 10:33 | 23:59 | 13:26 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|--------------------------------|---|---------|-----------|----------|--------------------|
| 401 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | YELPHARHATTI_110 | 11:53 | 12:02 | 0:09 | HAND TRIPPED |
| 402 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | YELPHARHATTI_110 | 12:42 | 12:46 | 0:04 | HAND TRIPPED |
| 403 | 8-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | RANNABELAGALI_110 | 10:12 | 11:40 | 1:28 | LINE CLEAR AVAILED |
| 404 | 8-Feb-19 | BANGALORE | 66 | KYALANUR - VEMGAL | KYALANUR | 6:46 | 6:51 | 0:04 | LINE FAULT |
| 405 | 8-Feb-19 | BANGALORE | 66 | DB PURA 220 - DG 1 | AIR (EHT) | 16:15 | 16:37 | 0:22 | LINE FAULT |
| 406 | 8-Feb-19 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 6:22 | 6:27 | 0:04 | LINE FAULT |
| 407 | 8-Feb-19 | BANGALORE | 66 | CHINTAMANI 220 - LAKSHMIPURA | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI | 2:35 | 2:45 | 0:09 | LINE FAULT |
| 408 | 8-Feb-19 | BANGALORE | 66 | CHINTAMANI 220 - LAKSHMIPURA | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI | 3:57 | 4:10 | 0:12 | LINE FAULT |
| 409 | 8-Feb-19 | BANGALORE | 66 | HV1 | ISRO LAYOUT | 20:40 | 20:45 | 0:04 | TRANSFORMER FAULT |
| 410 | 8-Feb-19 | BANGALORE | 66 | HV2 | ISRO LAYOUT | 20:21 | 20:30 | 0:08 | TRANSFORMER FAULT |
| 411 | 8-Feb-19 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA | 9:23 | 9:32 | 0:08 | LINE FAULT |
| 412 | 8-Feb-19 | BANGALORE | 66 | HV1 | TK HALLI 220 | 7:00 | 7:07 | 0:06 | TRANSFORMER FAULT |
| 413 | 8-Feb-19 | BANGALORE | 220 | TK HALLI 220 - VAJAMANGALA 220 | TK HALLI 220 | 13:18 | 14:13 | 0:55 | LINE FAULT |
| 414 | 8-Feb-19 | BANGALORE | 66 | RMV - TATA INSTITUTE (EHT) | TATA INSTITUTE (EHT) | 17:44 | 18:19 | 0:34 | LINE FAULT |
| 415 | 8-Feb-19 | BANGALORE | 66 | SOMANAHALLI 220 - KUMBALAGODU | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 11:15 | 11:29 | 0:14 | LINE FAULT |
| 416 | 8-Feb-19 | BANGALORE | 66 | SOMANAHALLI 220 - KUMBALAGODU | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 16:09 | 16:21 | 0:12 | LINE FAULT |
| 417 | 8-Feb-19 | GULBARGA | 220 | ITTAGI-LINGAPUR | ITTAGI_220 | 11:44 | 13:46 | 2:02 | LINE CLEAR AVAILED |
| 418 | 8-Feb-19 | GULBARGA | 220 | ITTAGI-GUTTUR | GUTTUR_220 | 14:30 | 15:40 | 1:10 | LINE CLEAR AVAILED |
| 419 | 8-Feb-19 | GULBARGA | 220 | SEDAM-RTPS2 | SEDAM_220 | 9:13 | 23:59 | 14:46 | NFBC ISSUED |
| 420 | 8-Feb-19 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 11:34 | 11:48 | 0:14 | LINE FAULT |
| 421 | 8-Feb-19 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 12:05 | 12:15 | 0:10 | LINE FAULT |
| 422 | 8-Feb-19 | GULBARGA | 110 | HV2 | KOLHAR_110 | 11:55 | 12:15 | 0:20 | LINE CLEAR AVAILED |
| 423 | 8-Feb-19 | GULBARGA | 110 | STAR METALLIC-MUNIRABAD | STAR METALLIC_IPP | 13:59 | 14:44 | 0:45 | LINE FAULT |
| 424 | 8-Feb-19 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 3:10 | 3:24 | 0:14 | TRANSFORMER FAULT |
| 425 | 8-Feb-19 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 14:02 | 14:04 | 0:02 | TRANSFORMER FAULT |
| 426 | 8-Feb-19 | GULBARGA | 66 | ITTAGI-HBHALLI | UPANAYAKANAHALLI_66 | 9:45 | 9:55 | 0:10 | LINE CLEAR AVAILED |
| 427 | 8-Feb-19 | GULBARGA | 66 | ITTAGI-KUDILGII,2 | KUDILIGI_66,KOGALI_66,HANASI_66,CJH ALLI_66,GUDEKOTE_66,HOSAHALLI_66,B ANVEKAL_66,CHORNOOR_66 | 9:40 | 10:08 | 0:28 | LOAD CHANGEOVER |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|----------|---------|------------------------|---|---------|-----------|----------|--------------------|
| 428 | 8-Feb-19 | GULBARGA | 66 | ITTAGI-HUVINAHADAGALLI | HUVINA_HADAGALLI_66,HOLAGUNDI_66 | 10:10 | 10:20 | 0:10 | LINE FAULT |
| 429 | 8-Feb-19 | GULBARGA | 66 | LV2 | ITTAGI_220 | 11:04 | 11:27 | 0:23 | LOAD CHANGEOVER |
| 430 | 8-Feb-19 | GULBARGA | 66 | ITTAGI-KUDILGII1,2 | KUDILIGI_66,KOGALI_66,HANASI_66,CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANVEKAL_66,CHORNOOR_66 | 11:25 | 11:30 | 0:05 | LOAD CHANGEOVER |
| 431 | 8-Feb-19 | GULBARGA | 66 | LV2 | ITTAGI_220 | 11:20 | 11:28 | 0:08 | TRANSFORMER FAULT |
| 432 | 8-Feb-19 | HASSAN | 220 | TALAGU-STRP2 | TALAGUPPA_400 | 10:38 | 15:08 | 4:30 | LINE CLEAR AVAILED |
| 433 | 8-Feb-19 | HASSAN | 220 | ARSK2-NITTUR | ARASIKERE_220 | 14:25 | 19:22 | 4:57 | NFBC ISSUED |
| 434 | 8-Feb-19 | HASSAN | 220 | ARSK2-NITTUR | ARASIKERE_220 | 13:03 | 17:12 | 4:09 | LINE FAULT |
| 435 | 8-Feb-19 | HASSAN | 220 | HV1 | ARASIKERE_220 | 13:32 | 13:48 | 0:16 | TRANSFORMER FAULT |
| 436 | 8-Feb-19 | HASSAN | 220 | GERSOPA-STRP1 | gerusoppa_gen | 9:05 | 12:23 | 3:18 | LINE CLEAR AVAILED |
| 437 | 8-Feb-19 | HASSAN | 220 | GERSOPA-D9STRP2 | gerusoppa_gen | 10:39 | 15:08 | 4:29 | LINE CLEAR AVAILED |
| 438 | 8-Feb-19 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 9:53 | 14:19 | 4:26 | LINE CLEAR AVAILED |
| 439 | 8-Feb-19 | HASSAN | 220 | HV1 | PUTTUR_220 | 9:27 | 13:58 | 4:31 | LINE CLEAR AVAILED |
| 440 | 8-Feb-19 | HASSAN | 220 | HV2 | PUTTUR_220 | 13:59 | 17:14 | 3:15 | LINE CLEAR AVAILED |
| 441 | 8-Feb-19 | HASSAN | 220 | HV1 | SHIRALKOPPA_220 | 10:07 | 16:55 | 6:48 | LINE CLEAR AVAILED |
| 442 | 8-Feb-19 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 9:51 | 14:19 | 4:28 | LINE CLEAR AVAILED |
| 443 | 8-Feb-19 | HASSAN | 110 | ARSK2-GANDASI | ARASIKERE_220 | 7:56 | 17:38 | 9:42 | LINE CLEAR AVAILED |
| 444 | 8-Feb-19 | HASSAN | 110 | ARSK2-GERUMARA | ARASIKERE_220 | 13:39 | 14:01 | 0:22 | HAND TRIPPED |
| 445 | 8-Feb-19 | HASSAN | 110 | HV1 | ARASIKERE_220 | 13:42 | 13:50 | 0:08 | HAND TRIPPED |
| 446 | 8-Feb-19 | HASSAN | 110 | LV1 | ARASIKERE_220 | 13:32 | 13:49 | 0:17 | HAND TRIPPED |
| 447 | 8-Feb-19 | HASSAN | 110 | LV1 | PUTTUR_220 | 9:27 | 13:58 | 4:31 | LINE CLEAR AVAILED |
| 448 | 8-Feb-19 | HASSAN | 110 | LV2 | PUTTUR_220 | 13:59 | 17:14 | 3:15 | LINE CLEAR AVAILED |
| 449 | 8-Feb-19 | HASSAN | 110 | PUTTUR-SLTR | PUTTUR_220 | 12:25 | 17:26 | 5:01 | LINE CLEAR AVAILED |
| 450 | 8-Feb-19 | HASSAN | 110 | LV1 | SHIRALKOPPA_220 | 10:07 | 16:58 | 6:51 | LINE CLEAR AVAILED |
| 451 | 8-Feb-19 | HASSAN | 110 | BANTWA-SALATTUR | BANTWAL_110 | 8:13 | 11:10 | 2:57 | LINE FAULT |
| 452 | 8-Feb-19 | HASSAN | 110 | KADUR-YGTI | KADUR_220 | 6:25 | 6:35 | 0:10 | LINE FAULT |
| 453 | 8-Feb-19 | HASSAN | 110 | HV2 | KARAYA_110 | 10:08 | 14:05 | 3:57 | LINE CLEAR AVAILED |
| 454 | 8-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 12:02 | 12:07 | 0:05 | HAND TRIPPED |
| 455 | 8-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 17:27 | 17:30 | 0:03 | HAND TRIPPED |
| 456 | 8-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 12:02 | 12:07 | 0:05 | HAND TRIPPED |
| 457 | 8-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 17:27 | 17:32 | 0:05 | HAND TRIPPED |
| 458 | 8-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 12:03 | 12:06 | 0:03 | HAND TRIPPED |
| 459 | 8-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 17:27 | 17:31 | 0:04 | HAND TRIPPED |
| 460 | 8-Feb-19 | HASSAN | 110 | HV1 | KONDENALU_110 | 9:12 | 17:43 | 8:31 | LINE CLEAR AVAILED |
| 461 | 8-Feb-19 | HASSAN | 110 | HV2 | KONDENALU_110 | 9:12 | 17:43 | 8:31 | LINE CLEAR AVAILED |
| 462 | 8-Feb-19 | HASSAN | 110 | HV2 | KULASHEKARA_110 | 0:30 | 16:38 | 16:08 | LINE CLEAR AVAILED |
| 463 | 8-Feb-19 | HASSAN | 66 | HV1 | CHIKMAGALUR_66 | 15:24 | 15:34 | 0:10 | HAND TRIPPED |
| 464 | 8-Feb-19 | HASSAN | 66 | HV2 | HOLALUR_66 | 9:16 | 10:18 | 1:02 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|---------|---------|-----------------|-----------------|---------|-----------|----------|--------------------|
| 465 | 8-Feb-19 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 11:55 | 12:44 | 0:49 | LINE CLEAR AVAILED |
| 466 | 8-Feb-19 | HASSAN | 220 | TALAGU-STRP2 | TALAGUPPA_400 | 10:38 | 15:08 | 4:30 | LINE CLEAR AVAILED |
| 467 | 8-Feb-19 | HASSAN | 220 | ARSK2-NITTUR | ARASIKERE_220 | 14:25 | 19:22 | 4:57 | NFBC ISSUED |
| 468 | 8-Feb-19 | HASSAN | 220 | ARSK2-NITTUR | ARASIKERE_220 | 13:03 | 17:12 | 4:09 | LINE FAULT |
| 469 | 8-Feb-19 | HASSAN | 220 | HV1 | ARASIKERE_220 | 13:32 | 13:48 | 0:16 | TRANSFORMER FAULT |
| 470 | 8-Feb-19 | HASSAN | 220 | GERSOPA-STRP1 | gerusoppa_gen | 9:05 | 12:23 | 3:18 | LINE CLEAR AVAILED |
| 471 | 8-Feb-19 | HASSAN | 220 | GERSOPA-D9STRP2 | gerusoppa_gen | 10:39 | 15:08 | 4:29 | LINE CLEAR AVAILED |
| 472 | 8-Feb-19 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 9:53 | 14:19 | 4:26 | LINE CLEAR AVAILED |
| 473 | 8-Feb-19 | HASSAN | 220 | HV1 | PUTTUR_220 | 9:27 | 13:58 | 4:31 | LINE CLEAR AVAILED |
| 474 | 8-Feb-19 | HASSAN | 220 | HV2 | PUTTUR_220 | 13:59 | 17:14 | 3:15 | LINE CLEAR AVAILED |
| 475 | 8-Feb-19 | HASSAN | 220 | HV1 | SHIRALKOPPA_220 | 10:07 | 16:55 | 6:48 | LINE CLEAR AVAILED |
| 476 | 8-Feb-19 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 9:51 | 14:19 | 4:28 | LINE CLEAR AVAILED |
| 477 | 8-Feb-19 | HASSAN | 110 | ARSK2-GANDASI | ARASIKERE_220 | 7:56 | 17:38 | 9:42 | LINE CLEAR AVAILED |
| 478 | 8-Feb-19 | HASSAN | 110 | ARSK2-GERUMARA | ARASIKERE_220 | 13:39 | 14:01 | 0:22 | HAND TRIPPED |
| 479 | 8-Feb-19 | HASSAN | 110 | HV1 | ARASIKERE_220 | 13:42 | 13:50 | 0:08 | HAND TRIPPED |
| 480 | 8-Feb-19 | HASSAN | 110 | LV1 | ARASIKERE_220 | 13:32 | 13:49 | 0:17 | HAND TRIPPED |
| 481 | 8-Feb-19 | HASSAN | 110 | LV1 | PUTTUR_220 | 9:27 | 13:58 | 4:31 | LINE CLEAR AVAILED |
| 482 | 8-Feb-19 | HASSAN | 110 | LV2 | PUTTUR_220 | 13:59 | 17:14 | 3:15 | LINE CLEAR AVAILED |
| 483 | 8-Feb-19 | HASSAN | 110 | PUTTUR-SLTR | PUTTUR_220 | 12:25 | 17:26 | 5:01 | LINE CLEAR AVAILED |
| 484 | 8-Feb-19 | HASSAN | 110 | LV1 | SHIRALKOPPA_220 | 10:07 | 16:58 | 6:51 | LINE CLEAR AVAILED |
| 485 | 8-Feb-19 | HASSAN | 110 | BANTWA-SALATTUR | BANTWAL_110 | 8:13 | 11:10 | 2:57 | LINE FAULT |
| 486 | 8-Feb-19 | HASSAN | 110 | KADUR-YGTI | KADUR_220 | 6:25 | 6:35 | 0:10 | LINE FAULT |
| 487 | 8-Feb-19 | HASSAN | 110 | HV2 | KARAYA_110 | 10:08 | 14:05 | 3:57 | LINE CLEAR AVAILED |
| 488 | 8-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 12:02 | 12:07 | 0:05 | HAND TRIPPED |
| 489 | 8-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 17:27 | 17:30 | 0:03 | HAND TRIPPED |
| 490 | 8-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 12:02 | 12:07 | 0:05 | HAND TRIPPED |
| 491 | 8-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 17:27 | 17:32 | 0:05 | HAND TRIPPED |
| 492 | 8-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 12:03 | 12:06 | 0:03 | HAND TRIPPED |
| 493 | 8-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 17:27 | 17:31 | 0:04 | HAND TRIPPED |
| 494 | 8-Feb-19 | HASSAN | 110 | HV1 | KONDENALU_110 | 9:12 | 17:43 | 8:31 | LINE CLEAR AVAILED |
| 495 | 8-Feb-19 | HASSAN | 110 | HV2 | KONDENALU_110 | 9:12 | 17:43 | 8:31 | LINE CLEAR AVAILED |
| 496 | 8-Feb-19 | HASSAN | 110 | HV2 | KULASHEKARA_110 | 0:30 | 16:38 | 16:08 | LINE CLEAR AVAILED |
| 497 | 8-Feb-19 | HASSAN | 66 | HV1 | CHIKMAGALUR_66 | 15:24 | 15:34 | 0:10 | HAND TRIPPED |
| 498 | 8-Feb-19 | HASSAN | 66 | HV2 | HOLALUR_66 | 9:16 | 10:18 | 1:02 | LINE CLEAR AVAILED |
| 499 | 8-Feb-19 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 11:55 | 12:44 | 0:49 | LINE CLEAR AVAILED |
| 500 | 8-Feb-19 | MYSORE | 66 | HV1 | MUGUR_66 | 17:05 | 23:06 | 6:01 | TRANSFORMER FAULT |
| 501 | 8-Feb-19 | MYSORE | 66 | HV1 | BGPURA_66 | 14:59 | 15:08 | 0:09 | LINE CLEAR AVAILED |
| 502 | 8-Feb-19 | MYSORE | 66 | HV2 | BGPURA_66 | 12:05 | 14:59 | 2:53 | LINE CLEAR AVAILED |
| 503 | 8-Feb-19 | MYSORE | 66 | HV2 | BGPURA_66 | 15:35 | 16:55 | 1:20 | LINE CLEAR AVAILED |
| 504 | 8-Feb-19 | MYSORE | 66 | HV2 | BGPURA_66 | 17:05 | 17:35 | 0:30 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|----------|---------|---|---|---------|-----------|----------|--------------------|
| 505 | 8-Feb-19 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 8:30 | 8:43 | 0:12 | LINE CLEAR AVAILED |
| 506 | 8-Feb-19 | MYSORE | 66 | DR PETE-HV1 | DODDARAYAPET_66 | 12:00 | 12:22 | 0:21 | LINE CLEAR AVAILED |
| 507 | 8-Feb-19 | MYSORE | 66 | DR PETE-MADHUVANAHALLI | SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 | 17:07 | 17:55 | 0:47 | LINE FAULT |
| 508 | 8-Feb-19 | MYSORE | 66 | DR PETE-MADHUVANAHALLI | SANTHEMARAHALLI_66 MUGUR_66 | 21:52 | 22:58 | 1:05 | LINE FAULT |
| 509 | 8-Feb-19 | MYSORE | 66 | DR PETE-MADHUVANAHALLI | SANTHEMARAHALLI_66 MUGUR_66 | 23:00 | 23:06 | 0:05 | HAND TRIPPED |
| 510 | 8-Feb-19 | MYSORE | 66 | HV2 | PERIYAPATNA_66 | 15:49 | 22:26 | 6:37 | TRANSFORMER FAULT |
| 511 | 8-Feb-19 | MYSORE | 66 | HV2 | SALIGRAMA_66 | 14:58 | 0:00 | 9:01 | TRANSFORMER FAULT |
| 512 | 8-Feb-19 | MYSORE | 66 | HV2 | SALIGRAMA_66 | 15:06 | 15:19 | 0:12 | TRANSFORMER FAULT |
| 513 | 8-Feb-19 | MYSORE | 66 | HV2 | SALIGRAMA_66 | 23:07 | 23:09 | 0:02 | TRANSFORMER FAULT |
| 514 | 8-Feb-19 | MYSORE | 66 | HV5 | SFCSHIVA_66 | 19:20 | 23:59 | 4:38 | HAND TRIPPED |
| 515 | 8-Feb-19 | MYSORE | 66 | VAJAMANGALA-BANNUR | BANNUR_66 KIRUGAVALU_66 MALIYURU_66 | 17:52 | 17:53 | 0:01 | HAND TRIPPED |
| 516 | 8-Feb-19 | TUMKUR | 400 | TR-1(HV SIDE) | GUTUR_400 | 17:32 | 21:07 | 3:34 | LINE CLEAR AVAILED |
| 517 | 8-Feb-19 | TUMKUR | 220 | NEELAGUNDA- ITTAGI | NEELAGUNDA_220 | 14:34 | 15:40 | 1:06 | LINE CLEAR AVAILED |
| 518 | 8-Feb-19 | TUMKUR | 220 | NITTUR 220kV-ARASIKERE | NITTUR_220 | 12:32 | 19:16 | 6:44 | LINE CLEAR AVAILED |
| 519 | 8-Feb-19 | TUMKUR | 110 | HONNAVALLI 110- KADUR220(ARASIKERE) | HONNAVALLI_110 | 8:35 | 19:17 | 10:42 | LINE CLEAR AVAILED |
| 520 | 8-Feb-19 | TUMKUR | 110 | TR-2 | CHIKKANAYAKANAHALLI_110 | 8:30 | 9:59 | 1:29 | LINE CLEAR AVAILED |
| 521 | 8-Feb-19 | TUMKUR | 110 | TR-2 | CHIKKANAYAKANAHALLI_110 | 11:26 | 18:44 | 7:18 | LINE CLEAR AVAILED |
| 522 | 8-Feb-19 | TUMKUR | 110 | TR-1 | GUBBI_110 | 7:06 | 7:11 | 0:05 | TRANSFORMER FAULT |
| 523 | 8-Feb-19 | TUMKUR | 66 | ANCHEPALYA 220kV- YEDIYUR(BG NAGAR) | YEDIYUR_66 | 10:34 | 10:56 | 0:22 | LINE FAULT |
| 524 | 8-Feb-19 | TUMKUR | 66 | TR-2 | BAGUR_66 | 18:43 | 19:17 | 0:33 | LINE CLEAR AVAILED |
| 525 | 8-Feb-19 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66 | 10:21 | 10:38 | 0:17 | LINE FAULT |
| 526 | 8-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:26 | 18:01 | 9:34 | HAND TRIPPED |
| 527 | 8-Feb-19 | TUMKUR | 66 | HONNALLI 220kV- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 16:24 | 16:33 | 0:08 | LINE FAULT |
| 528 | 8-Feb-19 | TUMKUR | 66 | HOSAKERE- MIDIGESHI | MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66 | 7:05 | 7:15 | 0:10 | LINE FAULT |
| 529 | 8-Feb-19 | TUMKUR | 66 | TR-2 | HULIYURDURGA_66 | 7:04 | 9:31 | 2:26 | TRANSFORMER FAULT |
| 530 | 8-Feb-19 | TUMKUR | 66 | TR-2 | SHYLAPURA_66 | 9:37 | 16:10 | 6:32 | LINE CLEAR AVAILED |
| 531 | 8-Feb-19 | TUMKUR | 66 | SHYLAPURA- MADHUGIRI | SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66 | 21:58 | 22:03 | 0:04 | HAND TRIPPED |
| 532 | 8-Feb-19 | TUMKUR | 66 | TR-1 | SIRA_66 | 15:06 | 15:10 | 0:04 | TRANSFORMER FAULT |
| 533 | 8-Feb-19 | TUMKUR | 66 | TR-1 | TUMKUR_66 | 9:19 | 10:47 | 1:27 | LINE CLEAR AVAILED |
| 534 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | AREMALLAPUR_110 | 10:22 | 14:06 | 3:44 | LINE CLEAR AVAILED |
| 535 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | BAGALKOT_110 | 6:07 | 6:11 | 0:04 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|---------------------------------|--|---------|-----------|----------|--------------------|
| 536 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | BAGALKOT_110 | 8:53 | 9:59 | 1:06 | LINE CLEAR AVAILED |
| 537 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | BAGALKOT_110 | 12:55 | 13:07 | 0:12 | TRANSFORMER FAULT |
| 538 | 9-Feb-19 | BAGALKOT | 110 | CHIKKODI220-CHIKKODI110 | CHIKKODI_110 | 11:46 | 18:08 | 6:22 | LINE CLEAR AVAILED |
| 539 | 9-Feb-19 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 13:53 | 14:02 | 0:09 | HAND TRIPPED |
| 540 | 9-Feb-19 | BAGALKOT | 110 | MRITYUNJAYNAGAR2-GOPANAKOPPA | GOPANAKOPPA_110 | 13:46 | 13:50 | 0:04 | HAND TRIPPED |
| 541 | 9-Feb-19 | BAGALKOT | 110 | 110/33KV, HV4 | HIDIKAL_110, ALAGAWADI_33 | 14:32 | 14:40 | 0:08 | TRANSFORMER FAULT |
| 542 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | MUNAVALLI_110 | 8:56 | 9:01 | 0:05 | TRANSFORMER FAULT |
| 543 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV, HV1 | NIPPANI_110 | 12:07 | 18:23 | 6:16 | LINE CLEAR AVAILED |
| 544 | 9-Feb-19 | BAGALKOT | 220 | GADAG-LINGAPUR1(DHONI1) | GADAG_220 | 11:05 | 17:57 | 6:52 | LINE CLEAR AVAILED |
| 545 | 9-Feb-19 | BAGALKOT | 110 | ZALKI-CHADCHAN | CHADCHAN_110 | 15:22 | 16:48 | 1:26 | LINE CLEAR AVAILED |
| 546 | 9-Feb-19 | BAGALKOT | 110 | HUBLI220-BIDNAL2 | BIDNAL_220 | 16:23 | 23:59 | 7:36 | LINE CLEAR AVAILED |
| 547 | 9-Feb-19 | BAGALKOT | 110 | HUBLI220-P H COMPOUND | P H COMPOUND_110 | 16:25 | 23:59 | 7:34 | LINE CLEAR AVAILED |
| 548 | 9-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | SALAHALLI_110 | 9:28 | 10:02 | 0:34 | HAND TRIPPED |
| 549 | 9-Feb-19 | BAGALKOT | 400 | DHONI-GUTTUR | DHONI_400 | 7:19 | 8:16 | 0:57 | LINE FAULT |
| 550 | 9-Feb-19 | BANGALORE | 66 | CHANDAPURA - YERANDANAHALLI 220 | CHANDAPURA | 16:45 | 16:50 | 0:04 | LOAD CHANGEOVER |
| 551 | 9-Feb-19 | BANGALORE | 66 | DABUSPET 220 - NELAMANGALA 66 | NELAMANGALA 66 | 17:36 | 22:24 | 4:48 | LINE CLEAR AVAILED |
| 552 | 9-Feb-19 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 6:34 | 6:42 | 0:08 | LINE FAULT |
| 553 | 9-Feb-19 | BANGALORE | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSEHANAHALLI, CHEEMANGALA | 17:53 | 18:01 | 0:07 | LINE FAULT |
| 554 | 9-Feb-19 | BANGALORE | 66 | GUNDAMGERE - DB PURA 220 | GUNDAMGERE | 11:40 | 11:45 | 0:05 | LOAD CHANGEOVER |
| 555 | 9-Feb-19 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 17:47 | 17:59 | 0:11 | LINE FAULT |
| 556 | 9-Feb-19 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 17:59 | 18:28 | 0:29 | LINE FAULT |
| 557 | 9-Feb-19 | BANGALORE | 66 | HV2 | HOSUR RAMAPURA | 15:30 | 16:11 | 0:40 | TRANSFORMER FAULT |
| 558 | 9-Feb-19 | BANGALORE | 66 | KOLAR 220 - NANGALI | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI | 14:16 | 15:46 | 1:30 | LINE CLEAR AVAILED |
| 559 | 9-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYALUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 12:34 | 12:45 | 0:11 | LINE FAULT |
| 560 | 9-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYALUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 12:50 | 15:46 | 2:56 | LINE CLEAR AVAILED |
| 561 | 9-Feb-19 | BANGALORE | 220 | KOLAR 220 - MALUR 3 | SARJAPURA 220, VIKAS TECH PARK 220 | 15:43 | 16:23 | 0:40 | LINE FAULT |
| 562 | 9-Feb-19 | BANGALORE | 66 | YELAHANKA 220 - LINE 6 | SOLDEVANAHALLI | 17:02 | 17:10 | 0:07 | LINE CLEAR AVAILED |
| 563 | 9-Feb-19 | BANGALORE | 66 | SOLDEVANAHALLI - SRS PEENYA 220 | SOLDEVANAHALLI | 19:16 | 19:20 | 0:04 | LOAD CHANGEOVER |
| 564 | 9-Feb-19 | BANGALORE | 66 | MALUR 220 - HOSKOTE 1 | JADIGENAHALLI, MALUR I/A | 15:40 | 16:48 | 1:08 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|-----------|---------|--------------------------------------|--|---------|-----------|----------|---------------------|
| 565 | 9-Feb-19 | BANGALORE | 220 | MALUR 220 - KOLAR 1 | SARJAPURA 220, VIKAS TECH PARK 220 | 15:47 | 16:20 | 0:33 | LINE FAULT |
| 566 | 9-Feb-19 | BANGALORE | 66 | MALUR 220 - KGF 1 | KGF, TEKAL, BUDIKOTE, KAMASAMUDRA | 15:40 | 16:45 | 1:05 | LINE FAULT |
| 567 | 9-Feb-19 | BANGALORE | 66 | MALUR 220 - KGF 2 | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 15:40 | 16:45 | 1:05 | LINE FAULT |
| 568 | 9-Feb-19 | BANGALORE | 66 | AREHALLI - SUBRAMANYAPURA 220 | AREHALLI | 9:43 | 9:46 | 0:02 | LOAD CHANGEOVER |
| 569 | 9-Feb-19 | BANGALORE | 66 | AREHALLI - BANASHANKARI | AREHALLI | 16:28 | 16:30 | 0:02 | LOAD CHANGEOVER |
| 570 | 9-Feb-19 | BANGALORE | 66 | SUBRAMANYAPURA 220 - REMCO 1 | AREHALLI | 17:14 | 17:41 | 0:26 | LINE FAULT |
| 571 | 9-Feb-19 | BANGALORE | 66 | HV1 | CHANDRAPPA CIRCLE | 18:46 | 19:05 | 0:18 | TRANSFORMER FAULT |
| 572 | 9-Feb-19 | BANGALORE | 66 | GOLF LINKS - ADUGODI 1 | GOLF LINKS | 11:15 | 11:20 | 0:05 | LOAD CHANGEOVER |
| 573 | 9-Feb-19 | BANGALORE | 66 | GOLF LINKS - ADUGODI 2 | GOLF LINKS | 13:13 | 13:15 | 0:02 | LOAD CHANGEOVER |
| 574 | 9-Feb-19 | BANGALORE | 66 | HAL 220 - ADUGODI 1 | LEELA VENTURE | 11:15 | 12:32 | 1:16 | LINE CLEAR AVAILED |
| 575 | 9-Feb-19 | BANGALORE | 66 | HAL 220 - ADUGODI 2 | LEELA VENTURE | 11:15 | 12:32 | 1:17 | LINE CLEAR AVAILED |
| 576 | 9-Feb-19 | BANGALORE | 66 | HEBBAL 220 - BANASWADI | BANASWADI | 10:59 | 11:28 | 0:29 | LINE FAULT |
| 577 | 9-Feb-19 | BANGALORE | 66 | HV2 | KADUGODI | 12:24 | 12:53 | 0:28 | LINE CLEAR AVAILED |
| 578 | 9-Feb-19 | BANGALORE | 66 | KADUGODI - ARMY WELFARE ORGANIZATION | ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA | 14:22 | 17:10 | 2:47 | LINE CLEAR AVAILED |
| 579 | 9-Feb-19 | BANGALORE | 66 | KANAKAPURA 220 - SOMANAHALLI 1 | MARALWADI, GODUR, CHATRA | 6:22 | 6:35 | 0:12 | LINE FAULT |
| 580 | 9-Feb-19 | BANGALORE | 66 | KANAKAPURA 220 - SOMANAHALLI 1 | MARALWADI, GODUR, CHATRA | 6:37 | 10:57 | 4:20 | LINE CLEAR AVAILED |
| 581 | 9-Feb-19 | BANGALORE | 66 | KANAKAPURA 220 - TK HALLI 1 | HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI | 13:03 | 13:10 | 0:07 | LINE FAULT |
| 582 | 9-Feb-19 | BANGALORE | 66 | HANUMANTHNAGARA - KANAKAPURA 220 | HANUMANTHNAGARA | 6:22 | 7:05 | 0:42 | MAIN SUPPLY FAILURE |
| 583 | 9-Feb-19 | BANGALORE | 66 | SHOBHA APARTMENT - HSR LAYOUT 220 | SHOBHA APARTMENT, CESSNO, CESSNO(EHT) | 11:35 | 11:40 | 0:05 | LOAD CHANGEOVER |
| 584 | 9-Feb-19 | BANGALORE | 66 | CESSNO - DEVARABISANAHALLI | SHOBHA APARTMENT, CESSNO, CESSNO(EHT) | 14:10 | 14:20 | 0:10 | LOAD CHANGEOVER |
| 585 | 9-Feb-19 | BANGALORE | 66 | RMV - TATA INSTITUTE (EHT) | TATA INSTITUTE (EHT) | 15:44 | 15:53 | 0:08 | LINE CLEAR AVAILED |
| 586 | 9-Feb-19 | GULBARGA | 220 | HV1 | KUSTAGI_220 | 12:25 | 20:40 | 8:15 | TRANSFORMER FAULT |
| 587 | 9-Feb-19 | GULBARGA | 110 | RAJESHWAR-HUMNABAD | RAJESHWAR_110 | 8:34 | 14:20 | 5:46 | LINE CLEAR AVAILED |
| 588 | 9-Feb-19 | GULBARGA | 110 | HV1 | RAICHUR_220 | 10:02 | 18:17 | 8:15 | LINE CLEAR AVAILED |
| 589 | 9-Feb-19 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | BTPS WATER WORKS,KEREHALLI_110,MALLAPUR_110 | 10:02 | 20:05 | 10:03 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|----------|---------|-----------------------|--|---------|-----------|----------|--------------------|
| 590 | 9-Feb-19 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD1 | GANGAVATHI_110,SRERAMANAGAR_110, VENKATGIRI_110,KARATAGI_110 | 16:14 | 19:30 | 3:16 | LINE CLEAR AVAILED |
| 591 | 9-Feb-19 | GULBARGA | 110 | KUSTAGI-ILKAL1 | ILKAL_110 | 6:42 | 7:05 | 0:23 | LINE FAULT |
| 592 | 9-Feb-19 | GULBARGA | 110 | KUSTAGI-ILKAL2 | ILKAL_110 | 6:42 | 14:20 | 7:38 | LINE FAULT |
| 593 | 9-Feb-19 | GULBARGA | 110 | LV1 | KUSTAGI_220 | 7:03 | 7:08 | 0:05 | TRANSFORMER FAULT |
| 594 | 9-Feb-19 | GULBARGA | 66 | HV2 | TAMBRAHALLI_66 | 12:05 | 12:46 | 0:41 | LINE CLEAR AVAILED |
| 595 | 9-Feb-19 | GULBARGA | 66 | ITTAGI-CLNMAX1 | ITTAGI_220 | 12:57 | 13:01 | 0:04 | LINE FAULT |
| 596 | 9-Feb-19 | HASSAN | 220 | VARAHI-SHIMOGA2 | varahi_gen | 17:34 | 23:22 | 5:48 | LINE FAULT |
| 597 | 9-Feb-19 | HASSAN | 220 | HV1 | KAVOOR_220 | 5:31 | 9:34 | 4:03 | LINE CLEAR AVAILED |
| 598 | 9-Feb-19 | HASSAN | 220 | MRSSHM-ANTRSNH | MRSMSG_220 | 9:49 | 12:56 | 3:07 | LINE CLEAR AVAILED |
| 599 | 9-Feb-19 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 9:05 | 12:24 | 3:19 | LINE CLEAR AVAILED |
| 600 | 9-Feb-19 | HASSAN | 220 | MRSSHM-VARAH12 | MRSMSG_220 | 17:35 | 22:41 | 5:06 | LINE CLEAR AVAILED |
| 601 | 9-Feb-19 | HASSAN | 220 | HV1 | SHIRALKOPPA_220 | 11:12 | 14:32 | 3:20 | LINE CLEAR AVAILED |
| 602 | 9-Feb-19 | HASSAN | 110 | MSEZ-BAIKAMPADY | MSEZ_220 | 9:57 | 16:15 | 6:18 | LINE CLEAR AVAILED |
| 603 | 9-Feb-19 | HASSAN | 110 | LV1 | SHIRALKOPPA_220 | 11:12 | 14:32 | 3:20 | LINE CLEAR AVAILED |
| 604 | 9-Feb-19 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHIRALKOPPA_220 | 14:24 | 14:35 | 0:11 | HAND TRIPPED |
| 605 | 9-Feb-19 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 14:59 | 15:14 | 0:15 | HAND TRIPPED |
| 606 | 9-Feb-19 | HASSAN | 110 | LV1 | KAVOOR_220 | 5:31 | 9:34 | 4:03 | LINE CLEAR AVAILED |
| 607 | 9-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 5:20 | 5:24 | 0:04 | HAND TRIPPED |
| 608 | 9-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 9:42 | 9:45 | 0:03 | HAND TRIPPED |
| 609 | 9-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 5:20 | 5:24 | 0:04 | HAND TRIPPED |
| 610 | 9-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 9:42 | 9:50 | 0:08 | HAND TRIPPED |
| 611 | 9-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 5:20 | 5:24 | 0:04 | HAND TRIPPED |
| 612 | 9-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 9:42 | 9:49 | 0:07 | HAND TRIPPED |
| 613 | 9-Feb-19 | HASSAN | 110 | SAGARA-IDLE | SAGARA_110 | 15:19 | 16:27 | 1:08 | LINE CLEAR AVAILED |
| 614 | 9-Feb-19 | HASSAN | 66 | BELUR66-MUDIGERE | BELUR_66 | 11:22 | 11:41 | 0:19 | LINE CLEAR AVAILED |
| 615 | 9-Feb-19 | HASSAN | 66 | GENDEHA-HASSAN | GENDEHALLI_66 | 11:26 | 11:41 | 0:15 | LOAD CURTAILMENT |
| 616 | 9-Feb-19 | HASSAN | 66 | UDDURKO-SUZLON2 | UDDURKOPLU_66 | 6:51 | 8:27 | 1:36 | LINE FAULT |
| 617 | 9-Feb-19 | HASSAN | 66 | HNPR2-MYSOR1 | HOLENARASIPURA_220 | 14:12 | 14:17 | 0:05 | LINE FAULT |
| 618 | 9-Feb-19 | HASSAN | 220 | VARAHI-SHIMOGA2 | varahi_gen | 17:34 | 23:22 | 5:48 | LINE FAULT |
| 619 | 9-Feb-19 | HASSAN | 220 | HV1 | KAVOOR_220 | 5:31 | 9:34 | 4:03 | LINE CLEAR AVAILED |
| 620 | 9-Feb-19 | HASSAN | 220 | MRSSHM-ANTRSNH | MRSMSG_220 | 9:49 | 12:56 | 3:07 | LINE CLEAR AVAILED |
| 621 | 9-Feb-19 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 9:05 | 12:24 | 3:19 | LINE CLEAR AVAILED |
| 622 | 9-Feb-19 | HASSAN | 220 | MRSSHM-VARAH12 | MRSMSG_220 | 17:35 | 22:41 | 5:06 | LINE CLEAR AVAILED |
| 623 | 9-Feb-19 | HASSAN | 220 | HV1 | SHIRALKOPPA_220 | 11:12 | 14:32 | 3:20 | LINE CLEAR AVAILED |
| 624 | 9-Feb-19 | HASSAN | 110 | MSEZ-BAIKAMPADY | MSEZ_220 | 9:57 | 16:15 | 6:18 | LINE CLEAR AVAILED |
| 625 | 9-Feb-19 | HASSAN | 110 | LV1 | SHIRALKOPPA_220 | 11:12 | 14:32 | 3:20 | LINE CLEAR AVAILED |
| 626 | 9-Feb-19 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHIRALKOPPA_220 | 14:24 | 14:35 | 0:11 | HAND TRIPPED |
| 627 | 9-Feb-19 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 14:59 | 15:14 | 0:15 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|----------|---------|---------|---|--|---------|-----------|----------|--------------------|
| 628 | 9-Feb-19 | HASSAN | 110 | LV1 | KAVOOR_220 | 5:31 | 9:34 | 4:03 | LINE CLEAR AVAILED |
| 629 | 9-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 5:20 | 5:24 | 0:04 | HAND TRIPPED |
| 630 | 9-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 9:42 | 9:45 | 0:03 | HAND TRIPPED |
| 631 | 9-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 5:20 | 5:24 | 0:04 | HAND TRIPPED |
| 632 | 9-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 9:42 | 9:50 | 0:08 | HAND TRIPPED |
| 633 | 9-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 5:20 | 5:24 | 0:04 | HAND TRIPPED |
| 634 | 9-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 9:42 | 9:49 | 0:07 | HAND TRIPPED |
| 635 | 9-Feb-19 | HASSAN | 110 | SAGARA-IDLE | SAGARA_110 | 15:19 | 16:27 | 1:08 | LINE CLEAR AVAILED |
| 636 | 9-Feb-19 | HASSAN | 66 | BELUR66-MUDIGERE | BELUR_66 | 11:22 | 11:41 | 0:19 | LINE CLEAR AVAILED |
| 637 | 9-Feb-19 | HASSAN | 66 | GENDEHA-HASSAN | GENDEHALLI_66 | 11:26 | 11:41 | 0:15 | LOAD CURTAILMENT |
| 638 | 9-Feb-19 | HASSAN | 66 | UDDURKO-SUZLON2 | UDDURKOPLU_66 | 6:51 | 8:27 | 1:36 | LINE FAULT |
| 639 | 9-Feb-19 | HASSAN | 66 | HNPR2-MYSOR1 | HOLENARASIPURA_220 | 14:12 | 14:17 | 0:05 | LINE FAULT |
| 640 | 9-Feb-19 | MYSORE | 66 | KR PETE 220-BOOKANKERE | SHEELUNERE, GANJIGERE, BOOKANAKERE, CHINAKURULI & BANNANGADI STATIONS INTERRUPTED. | 9:22 | 9:29 | 0:07 | LINE FAULT |
| 641 | 9-Feb-19 | MYSORE | 66 | KR PETE 220-BOOKANKERE | MAHADESHWRAPURA, JAKKANAHALLI, G MALLIGERE, GUDDENAHALLI, BOGADHI & NAGAMANGALA STATIONS INTERRUPTED. | 11:56 | 12:08 | 0:12 | LINE FAULT |
| 642 | 9-Feb-19 | MYSORE | 66 | KR PETE 220-MAHADESHWARAPURA | MAHADESHWRAPURA, JAKKANAHALLI, G MALLIGERE, GUDDENAHALLI, BOGADHI & NAGAMANGALA STATIONS INTERRUPTED. | 6:39 | 6:46 | 0:07 | LINE FAULT |
| 643 | 9-Feb-19 | MYSORE | 66 | VAJAMANGALA-BANNUR | BANNUR, KIRUGAVALU & MALIYUR STATIONS INTERRUPTED. | 9:54 | 9:57 | 0:02 | HAND TRIPPED |
| 644 | 9-Feb-19 | TUMKUR | 220 | NITTUR 220kV-ARASIKERE | NITTUR_220 | 13:03 | 17:22 | 4:18 | LINE FAULT |
| 645 | 9-Feb-19 | TUMKUR | 110 | TR-1 | TURUVEKERE_110 | 1:58 | 2:07 | 0:08 | TRANSFORMER FAULT |
| 646 | 9-Feb-19 | TUMKUR | 66 | ANCHEPALYA 220kV- KUNIGAL | KUNIGAL_66 | 10:56 | 11:32 | 0:35 | LINE CLEAR AVAILED |
| 647 | 9-Feb-19 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 13:11 | 13:26 | 0:14 | LINE FAULT |
| 648 | 9-Feb-19 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- KOLALA (dabaspete) | KOLALA_66, URDIGERE_66 | 10:17 | 11:07 | 0:49 | LINE FAULT |
| 649 | 9-Feb-19 | TUMKUR | 66 | ANTHRASANAHALLI 220kV- KORATAGERE | CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66 | 10:26 | 13:16 | 2:50 | LINE FAULT |
| 650 | 9-Feb-19 | TUMKUR | 66 | TR-1& TR-2 | BELADARA_66 | 10:53 | 10:57 | 0:03 | HAND TRIPPED |
| 651 | 9-Feb-19 | TUMKUR | 66 | TR-1& TR-2 | BELADARA_66 | 13:02 | 13:18 | 0:16 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|-----------|-----------|---------|---|---------------------------------|---------|-----------|----------|--------------------|
| 652 | 9-Feb-19 | TUMKUR | 66 | BELADADARA-KORATAGERE(ANTHRASANAHALLI) | BELADARA_66 | 10:57 | 13:02 | 2:05 | HAND TRIPPED |
| 653 | 9-Feb-19 | TUMKUR | 66 | TR-1 | CHANNAGIRI_66 | 12:22 | 13:23 | 1:00 | TRANSFORMER FAULT |
| 654 | 9-Feb-19 | TUMKUR | 66 | TR-2 | DAVANAGERE_66 | 3:23 | 4:38 | 1:15 | TRANSFORMER FAULT |
| 655 | 9-Feb-19 | TUMKUR | 66 | TR-2 | DAVANAGERE_66 | 5:06 | 7:03 | 1:56 | TRANSFORMER FAULT |
| 656 | 9-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:26 | 18:11 | 9:44 | HAND TRIPPED |
| 657 | 9-Feb-19 | TUMKUR | 66 | JAVAGONDANAHALLI- BEVINAHALLI | JAVAGONDANAHALLI_66 | 1:13 | 2:16 | 1:03 | LOAD CURTAILMENT |
| 658 | 9-Feb-19 | TUMKUR | 66 | TR-1 | KATTIGE_66 | 8:53 | 9:04 | 0:10 | TRANSFORMER FAULT |
| 659 | 10-Feb-19 | BAGALKOT | 110 | MACHE-ASHOK IRON PLANT | MACHE_110 | 16:48 | 20:20 | 3:32 | LINE CLEAR AVAILED |
| 660 | 10-Feb-19 | BAGALKOT | 220 | KAVATAGI LIS-VAJRAMATTI | VAJRAMATTI_220 | 17:27 | 18:06 | 0:39 | HAND TRIPPED |
| 661 | 10-Feb-19 | BAGALKOT | 220 | HUBLI-BIDNAL1 | HUBLI_220 | 16:52 | 21:13 | 4:21 | LINE CLEAR AVAILED |
| 662 | 10-Feb-19 | BAGALKOT | 220 | HUBLI-BIDNAL2 | HUBLI_220 | 16:52 | 21:14 | 4:22 | LINE CLEAR AVAILED |
| 663 | 10-Feb-19 | BANGALORE | 66 | HBR LAYOUT - LR BANDE | HBR LAYOUT | 9:25 | 9:35 | 0:10 | LOAD CHANGEOVER |
| 664 | 10-Feb-19 | BANGALORE | 66 | SOUTH CITY - SOMANAHALLI 220 | SOUTH CITY | 10:20 | 10:35 | 0:15 | LOAD CHANGEOVER |
| 665 | 10-Feb-19 | BANGALORE | 66 | SOUTH CITY - KHODAYS 220 | SOUTH CITY | 15:20 | 15:26 | 0:06 | LOAD CHANGEOVER |
| 666 | 10-Feb-19 | BANGALORE | 66 | RR NAGAR - VRISHABHAVATHI 220 | RR NAGAR | 15:53 | 15:58 | 0:05 | LOAD CHANGEOVER |
| 667 | 10-Feb-19 | BANGALORE | 66 | RR NAGAR - SUBRAMANYAPURA 220 | RR NAGAR | 11:15 | 11:20 | 0:05 | LOAD CHANGEOVER |
| 668 | 10-Feb-19 | BANGALORE | 66 | RMV - TATA INSTITUTE (EHT) | TATA INSTITUTE (EHT) | 21:03 | 21:14 | 0:11 | LINE CLEAR AVAILED |
| 669 | 10-Feb-19 | GULBARGA | 110 | SEDAM-GURUMITKAL | GURUMITKAL_110 | 6:50 | 7:05 | 0:15 | LINE FAULT |
| 670 | 10-Feb-19 | GULBARGA | 66 | LV1 ,LV2 | ITTAGI_220 | 18:27 | 18:50 | 0:23 | TRANSFORMER FAULT |
| 671 | 10-Feb-19 | HASSAN | 220 | HV2 | KAVOOR_220 | 5:36 | 9:03 | 3:27 | LINE CLEAR AVAILED |
| 672 | 10-Feb-19 | HASSAN | 220 | HV3 | KAVOOR_220 | 9:06 | 12:21 | 3:15 | LINE CLEAR AVAILED |
| 673 | 10-Feb-19 | HASSAN | 110 | LV2 | KAVOOR_220 | 5:36 | 9:03 | 3:27 | LINE CLEAR AVAILED |
| 674 | 10-Feb-19 | HASSAN | 110 | LV3 | KAVOOR_220 | 9:06 | 12:21 | 3:15 | LINE CLEAR AVAILED |
| 675 | 10-Feb-19 | HASSAN | 110 | MSEZ-KAVOOR | MSEZ_220 | 9:57 | 16:15 | 6:18 | LINE CLEAR AVAILED |
| 676 | 10-Feb-19 | HASSAN | 110 | PUTTUR-PUTTUR11 | PUTTUR_220 | 8:08 | 12:22 | 4:14 | LINE FAULT |
| 677 | 10-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 12:36 | 12:40 | 0:04 | HAND TRIPPED |
| 678 | 10-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 12:36 | 12:40 | 0:04 | HAND TRIPPED |
| 679 | 10-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 12:36 | 12:40 | 0:04 | HAND TRIPPED |
| 680 | 10-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 5:05 | 5:08 | 0:03 | HAND TRIPPED |
| 681 | 10-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 5:05 | 5:08 | 0:03 | HAND TRIPPED |
| 682 | 10-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 5:05 | 5:08 | 0:03 | HAND TRIPPED |
| 683 | 10-Feb-19 | HASSAN | 66 | HV1 | DODDAKADANUR_66 | 18:44 | 18:49 | 0:05 | TRANSFORMER FAULT |
| 684 | 10-Feb-19 | HASSAN | 66 | HV1 | DODDAKADANUR_66 | 20:38 | 20:40 | 0:02 | TRANSFORMER FAULT |
| 685 | 10-Feb-19 | HASSAN | 66 | MRSSHM-BD-1 | MRSMSG_220 | 16:33 | 16:47 | 0:14 | LINE FAULT |
| 686 | 10-Feb-19 | HASSAN | 220 | HV2 | KAVOOR_220 | 5:36 | 9:03 | 3:27 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|-----------|----------|---------|--|---|---------|-----------|----------|---------------------|
| 687 | 10-Feb-19 | HASSAN | 220 | HV3 | KAVOOR_220 | 9:06 | 12:21 | 3:15 | LINE CLEAR AVAILED |
| 688 | 10-Feb-19 | HASSAN | 110 | LV2 | KAVOOR_220 | 5:36 | 9:03 | 3:27 | LINE CLEAR AVAILED |
| 689 | 10-Feb-19 | HASSAN | 110 | LV3 | KAVOOR_220 | 9:06 | 12:21 | 3:15 | LINE CLEAR AVAILED |
| 690 | 10-Feb-19 | HASSAN | 110 | MSEZ-KAVOOR | MSEZ_220 | 9:57 | 16:15 | 6:18 | LINE CLEAR AVAILED |
| 691 | 10-Feb-19 | HASSAN | 110 | PUTTUR-PUTTUR11 | PUTTUR_220 | 8:08 | 12:22 | 4:14 | LINE FAULT |
| 692 | 10-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 12:36 | 12:40 | 0:04 | HAND TRIPPED |
| 693 | 10-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 12:36 | 12:40 | 0:04 | HAND TRIPPED |
| 694 | 10-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 12:36 | 12:40 | 0:04 | HAND TRIPPED |
| 695 | 10-Feb-19 | HASSAN | 110 | HV1 | KONAJE_110 | 5:05 | 5:08 | 0:03 | HAND TRIPPED |
| 696 | 10-Feb-19 | HASSAN | 110 | HV2 | KONAJE_110 | 5:05 | 5:08 | 0:03 | HAND TRIPPED |
| 697 | 10-Feb-19 | HASSAN | 110 | HV3 | KONAJE_110 | 5:05 | 5:08 | 0:03 | HAND TRIPPED |
| 698 | 10-Feb-19 | HASSAN | 66 | HV1 | DODDAKADANUR_66 | 18:44 | 18:49 | 0:05 | TRANSFORMER FAULT |
| 699 | 10-Feb-19 | HASSAN | 66 | HV1 | DODDAKADANUR_66 | 20:38 | 20:40 | 0:02 | TRANSFORMER FAULT |
| 700 | 10-Feb-19 | HASSAN | 66 | MRSSHM-BD-1 | MRSMSG_220 | 16:33 | 16:47 | 0:14 | LINE FAULT |
| 701 | 10-Feb-19 | MYSORE | 66 | KUSHALANAGARA 220-MERCERA-1 | MADIKERI & SUNTIKOPPA STATIONS INTERRUPTED. | 16:04 | 16:18 | 0:14 | LINE FAULT |
| 702 | 10-Feb-19 | TUMKUR | 110 | TR-1 | KALLUR_110 | 21:20 | 22:35 | 1:14 | TRANSFORMER FAULT |
| 703 | 10-Feb-19 | TUMKUR | 110 | TR-3 | AMMASANDRA_110 | 19:55 | 22:34 | 2:38 | HAND TRIPPED |
| 704 | 10-Feb-19 | TUMKUR | 66 | DASUDI-M/S CLEAN SOLAR | M/S CLEAN SOLAR _66 | 21:50 | 22:34 | 0:43 | MAIN SUPPLY FAILURE |
| 705 | 10-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 16:48 | 17:46 | 0:58 | HAND TRIPPED |
| 706 | 10-Feb-19 | TUMKUR | 66 | TR-1 | HIRIYUR_66 | 20:39 | 21:03 | 0:24 | TRANSFORMER FAULT |
| 707 | 10-Feb-19 | TUMKUR | 66 | JAVAGONDANAHALLI- SIRA | JAVAGONDANAHALLI_66 | 21:51 | 22:16 | 0:25 | LINE CLEAR AVAILED |
| 708 | 10-Feb-19 | TUMKUR | 66 | KUNDUR- SUZLON | SUZLON_IPP_66 | 18:06 | 19:23 | 1:17 | LINE FAULT |
| 709 | 10-Feb-19 | TUMKUR | 66 | KUNDUR- SUZLON | SUZLON_IPP_66 | 21:22 | 21:37 | 0:15 | LINE FAULT |
| 710 | 10-Feb-19 | TUMKUR | 66 | TR-2 | THIMMASANDRA_66 | 22:35 | 22:44 | 0:08 | TRANSFORMER FAULT |
| 711 | 11-Feb-19 | BAGALKOT | 110 | KUDUCHI220-AINAPUR | AINAPUR_110 | 5:39 | 8:47 | 3:08 | LINE CLEAR AVAILED |
| 712 | 11-Feb-19 | BAGALKOT | 110 | GADAG-ANNIGERI | ANNIGERI_110 | 12:52 | 13:06 | 0:14 | HAND TRIPPED |
| 713 | 11-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | AREMALLAPUR_110 | 10:22 | 13:15 | 2:53 | LINE CLEAR AVAILED |
| 714 | 11-Feb-19 | BAGALKOT | 110 | 220/110KV, LV2 | BELGAUM_220 | 0:22 | 6:24 | 6:02 | HAND TRIPPED |
| 715 | 11-Feb-19 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 11:59 | 12:07 | 0:08 | HAND TRIPPED |
| 716 | 11-Feb-19 | BAGALKOT | 110 | 110/33KV,HV2 | GANESHGUDI_110,JOIDA_33 | 15:43 | 17:47 | 2:04 | LINE CLEAR AVAILED |
| 717 | 11-Feb-19 | BAGALKOT | 110 | GHATAPRABHA220-SHIRAGAON | SHIRAGAON_110 | 10:13 | 16:51 | 6:38 | LINE CLEAR AVAILED |
| 718 | 11-Feb-19 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 12:07 | 12:14 | 0:07 | HAND TRIPPED |
| 719 | 11-Feb-19 | BAGALKOT | 110 | MRUTYUNJAYNAGAR2-GOPANAKOPPA | GOPANAKOPPA_110 | 12:14 | 12:24 | 0:10 | HAND TRIPPED |
| 720 | 11-Feb-19 | BAGALKOT | 220 | DHONI1-GADAG | GADAG_220 | 11:11 | 19:08 | 7:57 | LINE CLEAR AVAILED |
| 721 | 11-Feb-19 | BAGALKOT | 220 | DHONI2-GADAG | GADAG_220 | 16:23 | 23:59 | 7:36 | LINE FAULT |
| 722 | 11-Feb-19 | BAGALKOT | 220 | GADAG-BAGALKOT1 | GADAG_220 | 16:46 | 18:42 | 1:56 | LINE CLEAR AVAILED |
| 723 | 11-Feb-19 | BAGALKOT | 220 | BIDNAL-HAVERI | HAVERI_220 | 17:14 | 19:07 | 1:53 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|-----------|-----------|---------|---------------------------------|--|---------|-----------|----------|--------------------|
| 724 | 11-Feb-19 | BAGALKOT | 110 | HIDIKAL-ITANAL | ITANAL_110 | 15:27 | 18:35 | 3:08 | LINE CLEAR AVAILED |
| 725 | 11-Feb-19 | BAGALKOT | 110 | ITANAL-RAIBAG2 | RAIBAG_110 | 15:27 | 18:35 | 3:08 | LINE CLEAR AVAILED |
| 726 | 11-Feb-19 | BAGALKOT | 110 | UGAR SUG-UGAR KHUD | UGAR KHUD_110 | 6:26 | 6:45 | 0:19 | LINE FAULT |
| 727 | 11-Feb-19 | BAGALKOT | 110 | BIDNAL220-P H COMPOUND | P H COMPOUND_110 | 12:22 | 23:59 | 11:37 | HAND TRIPPED |
| 728 | 11-Feb-19 | BAGALKOT | 110 | 110/11KV,HV2 | MUNAVALLI_110 | 13:54 | 13:59 | 0:05 | TRANSFORMER FAULT |
| 729 | 11-Feb-19 | BAGALKOT | 110 | MRUTHYUNJAY NAGAR-GOPPANKOPPA 1 | GOPPANKOPPA_110 | 12:18 | 23:59 | 11:41 | HAND TRIPPED |
| 730 | 11-Feb-19 | BAGALKOT | 110 | 110/11KV,HV4 | LAKAMANAHALLI_110,ALNAVAR 33KV | 11:15 | 11:21 | 0:06 | TRANSFORMER FAULT |
| 731 | 11-Feb-19 | BAGALKOT | 110 | 110/11KV,HV4 | LAKAMANAHALLI_110,ALNAVAR 33KV | 11:34 | 11:43 | 0:09 | TRANSFORMER FAULT |
| 732 | 11-Feb-19 | BAGALKOT | 110 | 110/11KV,HV4 | LAKAMANAHALLI_110,ALNAVAR 33KV | 11:53 | 12:11 | 0:18 | TRANSFORMER FAULT |
| 733 | 11-Feb-19 | BAGALKOT | 110 | KUMTA-SIRSI1 | KUMTA_110 | 18:33 | 23:59 | 5:26 | LINE CLEAR AVAILED |
| 734 | 11-Feb-19 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | KUDUCHI_220,UGAR KHUD_110,MORAB_110,AINAPUR_110, KUDUCHI_110,YELPARATTI_110,TERDAL_110 | 5:39 | 6:07 | 0:28 | TRANSFORMER FAULT |
| 735 | 11-Feb-19 | BAGALKOT | 220 | 220/110KV,HV2,LV2 | KUDUCHI_220,UGAR KHUD_110,MORAB_110,AINAPUR_110, KUDUCHI_110,YELPARATTI_110,TERDAL_110 | 5:39 | 6:50 | 1:11 | TRANSFORMER FAULT |
| 736 | 11-Feb-19 | BAGALKOT | 110 | 220/110KV,LV1 | KUDUCHI_220 | 6:08 | 6:17 | 0:09 | TRANSFORMER FAULT |
| 737 | 11-Feb-19 | BAGALKOT | 110 | KUDUCHI220-AINAPUR(KUDCHI) | AINAPUR_110 | 7:42 | 8:41 | 0:59 | LINE CLEAR AVAILED |
| 738 | 11-Feb-19 | BAGALKOT | 110 | KUDUCHI220-TERDAL | TERDAL_110 | 11:50 | 13:03 | 1:13 | LINE CLEAR AVAILED |
| 739 | 11-Feb-19 | BAGALKOT | 110 | KUDUCHI220-AINAPUR(KUDCHI) | AINAPUR_110 | 6:07 | 6:37 | 0:30 | LINE FAULT |
| 740 | 11-Feb-19 | BAGALKOT | 110 | 110/11KV,HV1 | JAMBAGI_110 | 18:21 | 18:26 | 0:05 | TRANSFORMER FAULT |
| 741 | 11-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 13:43 | 13:57 | 0:14 | LINE FAULT |
| 742 | 11-Feb-19 | BANGALORE | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 15:14 | 16:47 | 1:32 | LINE CLEAR AVAILED |
| 743 | 11-Feb-19 | BANGALORE | 66 | KOLAR 220 - PGCIL | PGCIL, SUGUTUR, SM MANGALA | 13:40 | 14:00 | 0:20 | LINE FAULT |
| 744 | 11-Feb-19 | BANGALORE | 66 | SURYANAGAR - YERANDANAHALLI 220 | SURYANAGAR | 13:02 | 16:09 | 3:06 | LINE CLEAR AVAILED |
| 745 | 11-Feb-19 | BANGALORE | 66 | KOLAR 220 - NANGALI | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 15:23 | 16:35 | 1:11 | LINE CLEAR AVAILED |
| 746 | 11-Feb-19 | BANGALORE | 66 | HV1 | ABBIGERE | 11:59 | 12:49 | 0:49 | LINE CLEAR AVAILED |
| 747 | 11-Feb-19 | BANGALORE | 66 | HV2 | ABBIGERE | 14:45 | 15:53 | 1:07 | LINE CLEAR AVAILED |
| 748 | 11-Feb-19 | BANGALORE | 220 | HV1 | HAL 220 | 2:41 | 3:12 | 0:30 | TRANSFORMER FAULT |
| 749 | 11-Feb-19 | BANGALORE | 220 | HSR LAYOUT 220 - NIMHANS 220 | NIMHANS 220 | 2:18 | 2:49 | 0:31 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|-----------|-----------|---------|-----------------------------------|--|---------|-----------|----------|---------------------|
| 750 | 11-Feb-19 | BANGALORE | 220 | HV1 | NIMHANS 220 | 2:18 | 2:50 | 0:32 | MAIN SUPPLY FAILURE |
| 751 | 11-Feb-19 | BANGALORE | 220 | HV2 | NIMHANS 220 | 2:18 | 2:51 | 0:32 | MAIN SUPPLY FAILURE |
| 752 | 11-Feb-19 | BANGALORE | 66 | NIMHANS 220 - ADUGODI | ADUGODI, BOSCH (EHT), K&C VALLEY, NAL(EHT) | 2:18 | 2:57 | 0:38 | MAIN SUPPLY FAILURE |
| 753 | 11-Feb-19 | BANGALORE | 66 | NIMHANS 220 - JAYADEVA | JAYADEVA | 2:18 | 2:57 | 0:38 | MAIN SUPPLY FAILURE |
| 754 | 11-Feb-19 | BANGALORE | 66 | NIMHANS 220 - JAYANAGARA | JAYANAGARA, PADMANABHANAGARA | 2:18 | 2:56 | 0:37 | MAIN SUPPLY FAILURE |
| 755 | 11-Feb-19 | BANGALORE | 220 | HAL 220 - EDC 220 | EDC 220 | 2:18 | 3:02 | 0:43 | LINE FAULT |
| 756 | 11-Feb-19 | BANGALORE | 220 | EDC 220 - HAL 220 | EDC 220 | 2:18 | 3:02 | 0:43 | LINE FAULT |
| 757 | 11-Feb-19 | BANGALORE | 220 | EDC 220 - A STATION 220 | A STATION 220 | 2:18 | 2:28 | 0:09 | MAIN SUPPLY FAILURE |
| 758 | 11-Feb-19 | BANGALORE | 66 | EDC 220 - AUSTIN TOWN | AUSTIN TOWN, AMARJYOTHI, KORAMANGALA | 2:18 | 3:09 | 0:51 | MAIN SUPPLY FAILURE |
| 759 | 11-Feb-19 | BANGALORE | 66 | EDC 220 - B STATION | B STATION | 2:18 | 3:25 | 1:06 | MAIN SUPPLY FAILURE |
| 760 | 11-Feb-19 | BANGALORE | 66 | EDC 220 - BMTC | BMTC, NATIONAL COLLEGE | 2:18 | 3:06 | 0:47 | MAIN SUPPLY FAILURE |
| 761 | 11-Feb-19 | BANGALORE | 66 | A STATION 220 - A STATION 2 | A STATION 66 | 2:18 | 2:28 | 0:09 | MAIN SUPPLY FAILURE |
| 762 | 11-Feb-19 | BANGALORE | 66 | A STATION 220 - VICTORIA HOSPITAL | VICTORIA HOSPITAL | 2:18 | 2:28 | 0:09 | MAIN SUPPLY FAILURE |
| 763 | 11-Feb-19 | BANGALORE | 220 | HV1 | EDC 220 | 2:18 | 3:02 | 0:44 | MAIN SUPPLY FAILURE |
| 764 | 11-Feb-19 | BANGALORE | 220 | HV2 | EDC 220 | 2:18 | 3:02 | 0:44 | MAIN SUPPLY FAILURE |
| 765 | 11-Feb-19 | BANGALORE | 66 | HV1 | EDC 220 | 2:18 | 3:07 | 0:49 | MAIN SUPPLY FAILURE |
| 766 | 11-Feb-19 | BANGALORE | 66 | HV2 | EDC 220 | 2:18 | 3:08 | 0:50 | MAIN SUPPLY FAILURE |
| 767 | 11-Feb-19 | GULBARGA | 220 | LINGAPUR-GADAG2 | LINGAPUR_220 | 12:26 | 17:44 | 5:18 | LINE FAULT |
| 768 | 11-Feb-19 | GULBARGA | 110 | DHADESUGUR-VEPLSLR | DHADESUGUR_110 | 17:40 | 18:43 | 1:03 | LINE CLEAR AVAILED |
| 769 | 11-Feb-19 | GULBARGA | 110 | HALBARG-SANTHAPUR | SNATHAPUR_110,DONGRAGOAN_110,D IGGI_110,JANAWADA_110 | 17:50 | 18:04 | 0:14 | LINE FAULT |
| 770 | 11-Feb-19 | GULBARGA | 110 | SINDHANOOR-SUZLON1 | SIDHANOOR_220 | 6:37 | 7:20 | 0:43 | LINE FAULT |
| 771 | 11-Feb-19 | GULBARGA | 66 | HV1 | CHORNOOR_66 | 10:22 | 11:06 | 0:44 | LINE CLEAR AVAILED |
| 772 | 11-Feb-19 | GULBARGA | 66 | ITTAGI-KUDILGI1,2 | KUDILGI_66,KOGALI_66,HANASI_66,CJH ALLI_66,GUDEKOTE_66,HOSAHALLI_66,B ANVEKAL_66,CHORNOOR_66 | 17:06 | 17:10 | 0:04 | LOAD CHANGEOVER |
| 773 | 11-Feb-19 | GULBARGA | 66 | LV2 | ITTAGI_220 | 17:06 | 17:10 | 0:04 | LOAD CHANGEOVER |
| 774 | 11-Feb-19 | GULBARGA | 66 | ITTAGI-HBHALLI | UPANAYAKANAHALLI_66,HAGARIBOMM ANAHALLI_66 | 17:33 | 17:40 | 0:07 | HAND TRIPPED |
| 775 | 11-Feb-19 | HASSAN | 220 | HV1 | MRSMG_220 | 11:28 | 14:20 | 2:52 | LINE CLEAR AVAILED |
| 776 | 11-Feb-19 | HASSAN | 110 | MRSSHM-GAJNUR | MRSMG_220 | 10:36 | 10:42 | 0:06 | HAND TRIPPED |
| 777 | 11-Feb-19 | HASSAN | 110 | LV1 | MRSMG_220 | 11:28 | 14:20 | 2:52 | LINE CLEAR AVAILED |
| 778 | 11-Feb-19 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 14:05 | 14:10 | 0:05 | LINE FAULT |
| 779 | 11-Feb-19 | HASSAN | 110 | ANAVATI-JADE | ANAVATTI_110 | 14:05 | 14:16 | 0:11 | LINE FAULT |
| 780 | 11-Feb-19 | HASSAN | 110 | GAJNUR-IPP IC LINE | GAJNUR_110 | 10:36 | 10:42 | 0:06 | LOAD CURTAILMENT |
| 781 | 11-Feb-19 | HASSAN | 110 | GURUVA-KEMAR1 | GURUVAYANAKERE_110 | 12:03 | 14:15 | 2:12 | NFBC ISSUED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|-----------|---------|---------|--|--|---------|-----------|----------|--------------------|
| 782 | 11-Feb-19 | HASSAN | 110 | GURUVA-KEMAR2 | GURUVAYANAKERE_110 | 10:47 | 11:57 | 1:10 | NFBC ISSUED |
| 783 | 11-Feb-19 | HASSAN | 110 | HV3 | HIRIYA | 9:34 | 12:14 | 2:40 | LINE CLEAR AVAILED |
| 784 | 11-Feb-19 | HASSAN | 110 | KEMAR-Guruvykere1 | KEMAR_220 | 12:02 | 14:14 | 2:12 | LINE CLEAR AVAILED |
| 785 | 11-Feb-19 | HASSAN | 110 | KEMAR-Guruvykere2 | KEMAR_220 | 10:47 | 11:57 | 1:10 | LINE CLEAR AVAILED |
| 786 | 11-Feb-19 | HASSAN | 110 | KEMAR-NANDHIKUR1 | KEMAR_220 | 12:14 | 13:05 | 0:51 | LINE CLEAR AVAILED |
| 787 | 11-Feb-19 | HASSAN | 110 | KEMAR-NANDHIKUR2 | KEMAR_220 | 13:12 | 14:03 | 0:51 | LINE CLEAR AVAILED |
| 788 | 11-Feb-19 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 7:17 | 19:21 | 12:04 | LINE CLEAR AVAILED |
| 789 | 11-Feb-19 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 7:26 | 19:20 | 11:54 | LOAD CURTAILMENT |
| 790 | 11-Feb-19 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 13:08 | 13:23 | 0:15 | TRANSFORMER FAULT |
| 791 | 11-Feb-19 | HASSAN | 66 | CHIKMA-L1-ALDUR | CHIKMAGALUR_66 | 7:26 | 19:18 | 11:52 | LINE CLEAR AVAILED |
| 792 | 11-Feb-19 | HASSAN | 66 | HV2 | HOLEHONNUR_66 | 12:58 | 13:19 | 0:21 | LINE CLEAR AVAILED |
| 793 | 11-Feb-19 | MYSORE | 66 | HV2 | HARVEY_66 | 13:38 | 13:45 | 0:06 | TRANSFORMER FAULT |
| 794 | 11-Feb-19 | MYSORE | 66 | HV1 | HOOTAGALLY_220 | 10:12 | 11:58 | 1:46 | LINE CLEAR AVAILED |
| 795 | 11-Feb-19 | MYSORE | 66 | HV2 | HOOTAGALLY_220 | 12:03 | 12:58 | 0:55 | LINE CLEAR AVAILED |
| 796 | 11-Feb-19 | MYSORE | 66 | HV1 | KADAKOLA_220 | 11:32 | 11:38 | 0:06 | TRANSFORMER FAULT |
| 797 | 11-Feb-19 | MYSORE | 66 | HV1 | KADAKOLA_220 | 11:34 | 11:41 | 0:07 | TRANSFORMER FAULT |
| 798 | 11-Feb-19 | MYSORE | 66 | HV1 | KADAKOLA_220 | 12:17 | 12:23 | 0:06 | TRANSFORMER FAULT |
| 799 | 11-Feb-19 | MYSORE | 220 | HV2 | KADAKOLA_220 | 11:10 | 13:10 | 1:59 | LINE CLEAR AVAILED |
| 800 | 11-Feb-19 | MYSORE | 66 | KADAKOLA-SARGUR 2 | HURA_66, HULLAHALLI_66, DOORA_66 B MATKERE_66, SANTHESARAGUR_66 | 6:55 | 7:08 | 0:13 | LINE FAULT |
| 801 | 11-Feb-19 | MYSORE | 66 | KADAKOLA-SARGUR 1 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66 | 6:55 | 7:08 | 0:13 | LINE FAULT |
| 802 | 11-Feb-19 | MYSORE | 66 | HV1 | KIRUGAVALU_66 | 12:50 | 19:03 | 6:12 | LINE CLEAR AVAILED |
| 803 | 11-Feb-19 | MYSORE | 66 | KR PET 220-BOOKANKERE | SHEELUNERE_66, GANJIGERE_66, BOOKANAKERE_66, BANANGADI_66 CHINAKURALI_66 | 14:45 | 15:00 | 0:14 | LINE FAULT |
| 804 | 11-Feb-19 | MYSORE | 66 | HV1 | MADHUVANAHALLI_220 | 16:28 | 17:55 | 1:26 | HAND TRIPPED |
| 805 | 11-Feb-19 | MYSORE | 66 | MANDYA-CHIKKAMANDYA | CHIKKA_MANDYA_66 HAMPAPURA(K)_66, KOPPA_66 BESAGARAHALLI_66 & DUNDANAHALLI_66 | 15:16 | 15:22 | 0:06 | LINE FAULT |
| 806 | 11-Feb-19 | MYSORE | 66 | HV1 | VIRAJPET_66 | 11:11 | 12:02 | 0:50 | LINE CLEAR AVAILED |
| 807 | 11-Feb-19 | TUMKUR | 110 | TR-1 | TURUVEKERE_110 | 14:27 | 14:37 | 0:09 | TRANSFORMER FAULT |
| 808 | 11-Feb-19 | TUMKUR | 110 | TR-1 & TR-2 | TURUVEKERE_110 | 12:08 | 12:12 | 0:04 | TRANSFORMER FAULT |
| 809 | 11-Feb-19 | TUMKUR | 110 | TURUVEKERE110-KBCROSS | TURUVEKERE_110 | 12:08 | 12:12 | 0:04 | LINE FAULT |
| 810 | 11-Feb-19 | TUMKUR | 110 | TR-2 | TURUVEKERE_110 | 15:15 | 15:20 | 0:04 | TRANSFORMER FAULT |
| 811 | 11-Feb-19 | TUMKUR | 66 | ANCHEPALYA 220KV- YEDIYUR(BG NAGAR) | YEDIYUR_66 | 8:34 | 8:48 | 0:14 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASONS |
|--------|-----------|---------|---------|--|---------------------------------|---------|-----------|----------|---------------------|
| 812 | 11-Feb-19 | TUMKUR | 66 | BELADADARA-ANTHRASANAHALLI) | BELADARA_66 | 11:42 | 12:26 | 0:43 | LINE CLEAR AVAILED |
| 813 | 11-Feb-19 | TUMKUR | 66 | BELADADARA-CTKERE | BELADARA_66 | 11:42 | 12:28 | 0:46 | LINE CLEAR AVAILED |
| 814 | 11-Feb-19 | TUMKUR | 66 | TR-1 & TR-2 | BELADARA_66 | 11:42 | 12:29 | 0:46 | LINE CLEAR AVAILED |
| 815 | 11-Feb-19 | TUMKUR | 66 | BUKKAPATNA-GOLDEN HATCHERIES_IPP_66 | GOLDEN HATCHERIES_IPP_66 | 12:35 | 13:26 | 0:51 | LINE CLEAR AVAILED |
| 816 | 11-Feb-19 | TUMKUR | 66 | TR-1 | CHIKKABANAGERE_66 | 11:14 | 13:38 | 2:24 | LINE CLEAR AVAILED |
| 817 | 11-Feb-19 | TUMKUR | 66 | CHITRADURGA 66kV- MEGMICON 1 | MEGMICON 1_IPP_66 | 12:48 | 13:14 | 0:25 | LINE FAULT |
| 818 | 11-Feb-19 | TUMKUR | 66 | CHITRADURGA 66kV- MEGMICON2 | MEGMICON 1_IPP_66 | 12:48 | 13:14 | 0:25 | LINE FAULT |
| 819 | 11-Feb-19 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:02 | 9:05 | 1:03 | HAND TRIPPED |
| 820 | 11-Feb-19 | TUMKUR | 66 | HARIYABBE-CHIKKABANAGERE | CHIKKABANAGERE_66 | 16:43 | 16:44 | 0:01 | HAND TRIPPED |
| 821 | 11-Feb-19 | TUMKUR | 66 | KALAMARANAHALLI- TATA SOLAR_IPP_66 | TATA SOLAR_IPP_66 | 11:57 | 13:32 | 1:34 | LOAD CURTAILMENT |
| 822 | 11-Feb-19 | TUMKUR | 66 | TR-1 | NEELAGUNDA_220 | 22:56 | 23:42 | 0:46 | TRANSFORMER FAULT |
| 823 | 11-Feb-19 | TUMKUR | 66 | TR-1 | PAVAGADA_66 | 11:59 | 12:37 | 0:37 | LINE CLEAR AVAILED |
| 824 | 11-Feb-19 | TUMKUR | 66 | TAVAREKERE (H)-HIRIYUR | TAVAREKERE(H)_66 | 15:08 | 17:13 | 2:05 | MAIN SUPPLY FAILURE |
| 825 | 11-Feb-19 | TUMKUR | 66 | RANGENAHALLI -AZURESOLAR | AZURESOLAR_IPP_66 | 10:52 | 16:03 | 5:10 | MAIN SUPPLY FAILURE |
| 826 | 11-Feb-19 | TUMKUR | 66 | RANGENAHALLI- BORUKHASOLAR | BORUKHASOLAR_IPP_66 | 10:52 | 11:30 | 0:38 | MAIN SUPPLY FAILURE |
| 827 | 11-Feb-19 | TUMKUR | 66 | RANGANATHAPURA-DYVARANAHALLI | RANGENAHALLI_66 | 10:52 | 18:17 | 7:25 | MAIN SUPPLY FAILURE |
| 828 | 11-Feb-19 | TUMKUR | 66 | RANGANATHAPURA-HIRIYUR | RANGENAHALLI_66 | 10:52 | 18:17 | 7:25 | MAIN SUPPLY FAILURE |