

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 15.09.2020 TO 21.9.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	15-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
2	15-Sep-2020	BAGALKOT	110	110/11KV,HV1	DAVALESHWAR_110	11:01	16:01	5:00	LINE CLEAR AVOIDED
3	15-Sep-2020	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	8:47	8:50	0:03	TRANSFORMER FAULT
4	15-Sep-2020	BAGALKOT	110	110/11KV,HV1(HV2)	MUDDEBHAL_110	7:00	9:46	2:46	LINE CLEAR AVOIDED
5	15-Sep-2020	BAGALKOT	110	110/11KV,HV1(HV4)	GAJENDRAGAD_110	17:15	17:25	0:10	LINE CLEAR AVOIDED
6	15-Sep-2020	BAGALKOT	110	110/11KV,HV2	GAJENDRAGAD_110	16:49	17:10	0:21	LINE CLEAR AVOIDED
7	15-Sep-2020	BAGALKOT	110	110/11KV,HV2	RANEENNUR_220	10:40	16:33	5:53	LINE CLEAR AVOIDED
8	15-Sep-2020	BAGALKOT	110	110/11KV,HV3	LOKAPUR_110	12:25	13:35	1:10	LINE CLEAR AVOIDED
9	15-Sep-2020	BAGALKOT	110	110/33KV,HV3,HV4	GAJENDRAGAD_110,WIND 1&2,WIND3&4	17:30	18:05	0:35	LINE CLEAR AVOIDED
10	15-Sep-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	21:57(14.09.2020)	9:00(15.09.2020)	11:03hrs	TRANSFORMER CHARGED
11	15-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
12	15-Sep-2020	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	21:55	22:32	0:37	LINE FAULT
13	15-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
14	15-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVOIDED
15	15-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
16	15-Sep-2020	BAGALKOT	110	HIREKERUR-RATTIHALI	STATION NOT AFFECTED RATTIHALI_110	13:48(13.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
17	15-Sep-2020	BAGALKOT	110	JK CEMENT-VAJRAMATTI	VAJRAMATTI_220	1:30	2:30	1:00	LINE FAULT
18	15-Sep-2020	BAGALKOT	110	KAVLWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
19	15-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51(01.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
20	15-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
21	15-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVOIDED
22	15-Sep-2020	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	11:22	11:59	0:37	LINE FAULT
23	15-Sep-2020	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	23:07(13.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
24	15-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
25	15-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19(02.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
26	15-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	21:58(14.09.2020)	8:04(15.09.2020)	10:06hrs	LINE CHARGED
27	15-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	10:28	13:38	3:10	LINE FAULT
28	15-Sep-2020	BAGALKOT	220	GADAG- BAGALKOT1	GADAG_220	23:07(13.09.2020)			LINE OPEN, LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
29	15-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
30	15-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	6:28 (15.09.2020)			LOAD CURTAILMENT
31	15-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
32	15-Sep-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:28	13:42	0:14	LINE CLEAR AVOIDED
33	15-Sep-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	11:32	13:46	2:14	LINE CLEAR AVOIDED
34	15-Sep-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	13:28	13:46	0:18	LINE FAULT
35	15-Sep-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	13:28	13:41	0:13	LINE CLEAR AVOIDED
36	15-Sep-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	13:28	13:41	0:13	LINE CLEAR AVOIDED
37	15-Sep-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	21:04	21:12	0:08	LINE FAULT
38	15-Sep-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	21:14	23:11	1:56	LINE FAULT
39	15-Sep-2020	BENGALURU	66	HV2	KUMBALAGODU	12:36	15:05	2:29	LINE CLEAR AVOIDED
40	15-Sep-2020	BENGALURU	66	HV3	HEBBALA 220	13:00	13:05	0:05	LINE CLEAR AVOIDED
41	15-Sep-2020	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	9:10	9:55	0:45	LINE FAULT
42	15-Sep-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:27	14:00	0:33	LINE CLEAR AVOIDED
43	15-Sep-2020	BENGALURU	66	SADALI - GANJIGUNTE	SADALI	9:25	9:30	0:05	LOAD CHANGE OVER
44	15-Sep-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 1	SUBRAMANYAPURA 66, ISKON	10:25	10:35	0:10	LINE CLEAR AVOIDED
45	15-Sep-2020	BENGALURU	220	LV2	CHINTAMANI 220	13:28	13:40	0:12	TRANSFORMER FAULT
46	15-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
47	15-Sep-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	18:25	18:55	0:30	LINE FAULT
48	15-Sep-2020	GULBARGA	110	GABUR-RAICHUR	GABUR_110	18:25	18:30	0:05	MAIN SUPPLY FAILURE
49	15-Sep-2020	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK IPP,BSSK IPP	0:47	0:55	0:08	LINE FAULT
50	15-Sep-2020	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK IPP,BSSK IPP	4:20	4:30	0:10	LINE FAULT
51	15-Sep-2020	GULBARGA	110	HALBARGA-SANTHAPUR	DONGARGOAN_110,KAM ALANAGAR_110,SANTHAP UR_110	2:43	3:01	0:18	LINE FAULT
52	15-Sep-2020	GULBARGA	110	HV2	HATTI_110	16:12	16:18	0:06	TRANSFORMER FAULT
53	15-Sep-2020	GULBARGA	110	HV2	HATTI_110	10:01	10:03	0:02	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
54	15-Sep-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:55	6:02	0:07	LINE FAULT
55	15-Sep-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAM DINNI_110	23:04	23:14	0:10	LINE FAULT
56	15-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
57	15-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	23:55(14.9.2020)	00:05(15.9.2020)	0:10 HRS	LINE CHARGED
58	15-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	12:40	12:50	0:10	LINE FAULT
59	15-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	13:40	13:50	0:10	LINE FAULT
60	15-Sep-2020	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	23:01(15.09.2020)			LINE OPEN, LINE CLEAR AVAILED
61	15-Sep-2020	GULBARGA	220	HV1	HALBARGA_220	0:47	0:53	0:06	TRANSFORMER FAULT
62	15-Sep-2020	GULBARGA	220	HV2	KUSHTAGI_220	17:42	23:20	5:38	LINE CLEAR AVAILED
63	15-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	3:31	7:38	4:07	LINE CLEAR AVAILED
64	15-Sep-2020	GULBARGA	220	KUSHTAGI-ASTRO_WIND_IPP	KUSHTAGI_220	15:40	23:14	7:34	LINE CLEAR AVAILED
65	15-Sep-2020	GULBARGA	220	KUSHTAGI-SUZLON WIND1_IPP	KUSHTAGI_220	10:15	12:05	1:50	LINE CLEAR AVAILED
66	15-Sep-2020	GULBARGA	220	KUSHTAGI-SUZLON WIND2_IPP	KUSHTAGI_220	12:50	15:35	2:45	LINE CLEAR AVAILED
67	15-Sep-2020	GULBARGA	220	LINGAPUR-GUDAHALLI1	GUDAHALLI_220	11:33	13:04	1:31	LINE FAULT
68	15-Sep-2020	GULBARGA	220	LINGAPUR-JINDAL2	JINDAL_220	10:16	14:10	3:54	LINE CLEAR AVAILED
69	15-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT
70	15-Sep-2020	GULBARGA	220	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,C OREGREEN SUGAR_IPP	5:39	5:54	0:15	LINE FAULT
71	15-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)			LINE OPEN, LINE CLEAR AVAILED
72	15-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
73	15-Sep-2020	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	5:53	5:58	0:05	LINE FAULT
74	15-Sep-2020	HASSAN	66	HV1	HARIHARAPURA_66	9:15	12:35	3:20	LINE CLEAR AVAILED
75	15-Sep-2020	HASSAN	66	HV1	SOMANAHALLI_66	13:00	15:33	2:33	LINE CLEAR AVAILED
76	15-Sep-2020	HASSAN	66	HV2	TAVARECHANAHALLI_66	17:24	18:40	1:16	TRANSFORMER FAULT
77	15-Sep-2020	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:07	15:37	5:30	LINE CLEAR AVAILED
78	15-Sep-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:07	13:24	3:17	LINE CLEAR AVAILED
79	15-Sep-2020	HASSAN	110	HV1	ARASIKERE_220	11:04	15:17	4:13	LINE CLEAR AVAILED
80	15-Sep-2020	HASSAN	110	HV1	GANDASI_110	1:35	14:58	13:23	LINE CLEAR AVAILED
81	15-Sep-2020	HASSAN	110	HV1	KARAYA_110	11:15	14:34	3:19	MAIN SUPPLY FAILURE
82	15-Sep-2020	HASSAN	110	HV2	BAIKAMPADI_110	13:57	15:13	1:16	LINE CLEAR AVAILED
83	15-Sep-2020	HASSAN	110	HV2	HALADY_110	2:07	2:25	0:18	TRANSFORMER FAULT
84	15-Sep-2020	HASSAN	110	HV2	KARAYA_110	11:15	14:34	3:19	MAIN SUPPLY FAILURE
85	15-Sep-2020	HASSAN	110	HV4	MANIPAL_110	9:33	15:26	5:53	LINE CLEAR AVAILED
86	15-Sep-2020	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	11:15	14:34	3:19	MAIN SUPPLY FAILURE
87	15-Sep-2020	HASSAN	110	LV1	SHIRALKOPPA_220	15:38	17:44	2:06	LINE CLEAR AVAILED
88	15-Sep-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	11:02	14:33	3:31	LINE CLEAR AVAILED
89	15-Sep-2020	HASSAN	220	HV1	SHIRALKOPPA_220	15:38	17:44	2:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
90	15-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:17	11:21	1:04	LINE CLEAR AVAILED
91	15-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	9:30	12:56	3:26	LINE CLEAR AVAILED
92	15-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	18:43(14.09.2020)	18:26 (15.09.2020)	23:42 hrs	LINE CHARGED
93	15-Sep-2020	HASSAN	220	SHRVATY-SHIMOGA1	sharavathy_gen	9:30	12:56	3:26	LINE CLEAR AVAILED
94	15-Sep-2020	HASSAN	220	VARAH1-KEMAR3	varahi_gen	10:18	11:22	1:04	NFBC ISSUED
95	15-Sep-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	12:32 (14.09.2020)	18:40 (15.09.2020)	30:07 hrs	LINE CHARGED
96	15-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
97	15-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:47 (12.09.2020)	16:50(15.09.2020)	67:2 hrs	LINE CHARGED
98	15-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:04(15.09.2020)			LINE OPEN, LINE CLEAR AVAILED
99	15-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
100	15-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:08 (14.08.2020)	6:43 (15.08.2020)	7:34 hrs	LINE CHARGED
101	15-Sep-2020	MYSURU	66	BOGADHI-GIS	KALAMANDIRA_66	10:00	16:38	6:38	NFBC ISSUED
102	15-Sep-2020	MYSURU	66	ELWALA-HUNSUR	GAVADAGERE_66 HUNSUR_66	10:20	18:03	7:43	NFBC ISSUED
103	15-Sep-2020	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	13:49	13:56	0:07	HAND TRIPPED
104	15-Sep-2020	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66	10:01	14:39	4:38	NFBC ISSUED
105	15-Sep-2020	MYSURU	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66	10:28	15:15	4:47	LINE CLEAR AVAILED
106	15-Sep-2020	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66 HUNSUR_66	10:20	18:57	8:37	NFBC ISSUED
107	15-Sep-2020	MYSURU	66	HV1	KIRUGAVALU_66	12:31	16:17	3:46	LINE CLEAR AVAILED
108	15-Sep-2020	MYSURU	66	HV2	KIRUGAVALU_66	10:49	12:46	1:56	LINE CLEAR AVAILED
109	15-Sep-2020	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	12:55	15:05	2:10	LINE CLEAR AVAILED
110	15-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	17:03	17:08	0:05	LINE FAULT
111	15-Sep-2020	MYSURU	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	9:25	9:30	0:05	LINE FAULT
112	15-Sep-2020	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	9:27	12:27	2:59	NFBC ISSUED
113	15-Sep-2020	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	12:32	13:59	1:27	NFBC ISSUED
114	15-Sep-2020	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	11:35	12:44	1:08	LINE CLEAR AVAILED
115	15-Sep-2020	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	11:13	11:20	0:06	LINE FAULT
116	15-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	11:42	11:53	0:10	LINE FAULT
117	15-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	12:35	13:00	0:25	LINE FAULT
118	15-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	10:18	10:35	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
119	15-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:38	11:42	0:04	LINE FAULT
120	15-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAG IRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:10	15:20	0:09	LINE FAULT
121	15-Sep-2020	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	11:33	12:38	1:04	LINE CLEAR AVAILED
122	15-Sep-2020	TUMKUR	66	TAVAREKERE (H)- PATTNAYAKANAHALLI	TAVAREKERE(H)_66	10:10	10:32	0:22	MAIN SUPPLY FAILURE
123	15-Sep-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	CHALLAKERE_66, SANIKERE_66	12:51	13:02	0:11	HAND TRIPPED
124	15-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
125	15-Sep-2020	TUMKUR	66	TR-2	KUNIGAL_66	10:05	15:56	5:51	LINE CLEAR AVAILED
126	15-Sep-2020	TUMKUR	66	TR-2	MELKOTE_66	11:34	12:39	1:04	LINE CLEAR AVAILED
127	15-Sep-2020	TUMKUR	66	TR-2	SANIKERE_66	15:48	16:02	0:14	TRANSFORMER FAULT
128	15-Sep-2020	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	12:45	13:30	0:44	LINE CLEAR AVAILED
129	15-Sep-2020	TUMKUR	66	UCHCHANGIDURGA- I/C220SRSDAVANGERE	UCHCHANGIDURGA_66	16:31	16:44	0:13	LINE FAULT
130	15-Sep-2020	TUMKUR	110	TR-1	MAYASANDRA_110	0:59	1:36	0:36	TRANSFORMER FAULT
131	15-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT
132	15-Sep-2020	TUMKUR	110	TR-3	AMMASANDRA_110	9:48(15.09.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
133	15-Sep-2020	TUMKUR	110	TR-3	GUBBI_110	12:53	13:48	0:54	LINE CLEAR AVAILED
1	16-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
2	16-Sep-2020	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ANKOLA_110	22:54(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
3	16-Sep-2020	BAGALKOT	110	110/11KV, HV1	GANESHGUDI_110	1:46	18:12	16:26	TRANSFORMER FAULT
4	16-Sep-2020	BAGALKOT	110	110/11KV, HV2	YARAGATTI_110	10:09	16:51	6:42	LINE CLEAR AVAILED
5	16-Sep-2020	BAGALKOT	110	110/11KV, HV2	MUNVALLI_110	18:03	18:47	0:44	LINE CLEAR AVAILED
6	16-Sep-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	15:59	18:04	2:05	LINE CLEAR AVAILED
7	16-Sep-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL DAM_110	15:16	18:43	3:27	TRANSFORMER FAULT
8	16-Sep-2020	BAGALKOT	110	110/11KV, HV 1	AIGALI_110	12:41	13:35	0:54	LINE CLEAR AVAILED
9	16-Sep-2020	BAGALKOT	110	110/11KV, HV 1	STATION NOT AFFECTED DAMBAL_110	14:14(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
10	16-Sep-2020	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED BAGALKOT_110	19:20(17.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
11	16-Sep-2020	BAGALKOT	110	110/33KV, HV2	GANESHGUDI_110,JOIDEA 33	18:27	19:14	0:47	LINE CLEAR AVAILED
12	16-Sep-2020	BAGALKOT	110	110/33KV, HV3	GADAG_110, NAGAVI_33, MALLASAMUDRA_IPP, KAPPADGUDDA_IPP, PIONEER_IPP	10:08	17:48	7:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
13	16-Sep-2020	BAGALKOT	110	110/33KV, HV3	YARAGATTI_110, SHIVAPUR_33, CHINCHNUR LIS 33	10:09	16:47	6:38	LINE CLEAR AVAILED
14	16-Sep-2020	BAGALKOT	110	110/33KV, HV4	GADAG_110, HULKOTI_33, LAKKUNDI_33, TDPL1&2 IPP	10:09	17:49	7:40	LINE CLEAR AVAILED
15	16-Sep-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	21:58 (16.09.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
16	16-Sep-2020	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	9:25	17:45	8:20	NFBC ISSUED
17	16-Sep-2020	BAGALKOT	110	ANKOLA-ARAGA(L1)	ANKOLA_110	9:25	14:12	4:47	LINE CLEAR AVAILED
18	16-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
19	16-Sep-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:02	15:27	5:25	NFBC ISSUED
20	16-Sep-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	9:56	15:53	5:57	NFBC ISSUED
21	16-Sep-2020	BAGALKOT	110	GHATAPRABHA- HIDIKAL DAM	HIDIKAL DAM_110	16:04	18:44	2:40	LINE CLEAR AVAILED
22	16-Sep-2020	BAGALKOT	110	GMR SUGARS-HALIYAL	HALIYAL_110	17:24	18:00	0:36	HAND TRIPPED
23	16-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
24	16-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
25	16-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
26	16-Sep-2020	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	7:13	7:27	0:14	LINE FAULT
27	16-Sep-2020	BAGALKOT	110	HIREKERUR-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	13:48(13.09.2020)	14:21 (16.09.2020)	72:33 hrs	LINE CHARGED
28	16-Sep-2020	BAGALKOT	110	KARWAR220- ARGA	ARGA_110	9:33	13:50	4:17	LINE CLEAR AVAILED
29	16-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
30	16-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
31	16-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
32	16-Sep-2020	BAGALKOT	110	SOUDATTI220- YARGATTI	YARAGATTI_110	14:05	16:08	2:03	LINE CLEAR AVAILED
33	16-Sep-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
34	16-Sep-2020	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220	11:00	14:32	3:32	LINE CLEAR AVAILED
35	16-Sep-2020	BAGALKOT	220	220/110KV, HV2&LV2	VAJRAMATTI_220	14:36	16:47	2:11	LINE CLEAR AVAILED
36	16-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:05	6:38	6:33	LOAD CURTAILMENT
37	16-Sep-2020	BAGALKOT	220	BAGALKOT-GADAG1	STATION NOT AFFECTED BAGALKOT_220	23:07(13.09.2020)	8:36 (17.09.2020)	81:29 hrs	LINE CHARGED
38	16-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
39	16-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19(02.09.2020)	16:11(16.09.2020)	339:52 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
40	16-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28(16.09.2020)			LINE OPEN, LINE CLEAR AVALIED
41	16-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:21	6:46	6:25	LOAD CURTAILMENT
42	16-Sep-2020	BAGALKOT	220	GADAG- BAGALKOT1	STATION NOT AFFECTED GADAG_220	23:07(13.09.2020)	8:37(17.09.2020)	81:30 hrs	LINE CHARGED
43	16-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	6:28(15.09.2020)			LOAD CURTAILMENT
44	16-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)	0:12(16.09.2020)	365:24 hrs	LINE CHARGED
45	16-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	6:33(16.09.2020)			LOAD CURTAILMENT
46	16-Sep-2020	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	0:10	6:38	6:28	LOAD CURTAILMENT
47	16-Sep-2020	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	0:14	6:40	6:26	LOAD CURTAILMENT
48	16-Sep-2020	BAGALKOT	400	400/220,ICT1	DHONI_400	16:09	18:28	2:19	TRANSFORMER FAULT
49	16-Sep-2020	BANGALORE	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
50	16-Sep-2020	BANGALORE	66	HV1	D CROSS	8:30	8:38	0:07	TRANSFORMER FAULT
51	16-Sep-2020	BANGALORE	66	HV1	VOLVO	12:35	13:37	1:02	LINE CLEAR AVALIED
52	16-Sep-2020	BANGALORE	66	HV2	VOLVO	13:29	13:39	0:10	LINE CLEAR AVALIED
53	16-Sep-2020	BANGALORE	66	HV2	HAROBELE	3:35	4:10	0:35	TRANSFORMER FAULT
54	16-Sep-2020	BANGALORE	66	KUMBALAGODU - Kengeri SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	18:10	18:12	0:02	LOAD CHANGEOVER
55	16-Sep-2020	BANGALORE	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	15:30	16:30	1:00	LINE CLEAR AVALIED
56	16-Sep-2020	BANGALORE	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
57	16-Sep-2020	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BSSK_IPP	5:58	6:05	0:07	LINE FAULT
58	16-Sep-2020	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKO TE_110	18:39	19:20	0:41	LINE FAULT
59	16-Sep-2020	GULBARGA	110	HALBARGA-SANTHAPUR	DONGARGOAN_110,KAM ALANAGAR_110,SANTHAP UR_110	6:15	6:30	0:15	LINE FAULT
60	16-Sep-2020	GULBARGA	110	HALBARGA-SANTHAPUR	DONGARGOAN_110,KAM ALANAGAR_110,SANTHAP UR_110	22:22	22:29	0:07	LINE FAULT
61	16-Sep-2020	GULBARGA	110	HALBARGA-SANTHAPUR	DONGARGOAN_110,KAM ALANAGAR_110,SANTHAP UR_110	22:58	23:03	0:05	LINE FAULT
62	16-Sep-2020	GULBARGA	110	HV1	KOLHAR_110	21:20	22:10	0:50	LINE CLEAR AVALIED
63	16-Sep-2020	GULBARGA	110	HV2	HATTI_110	14:01	14:06	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
64	16-Sep-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R_110	21:20	21:30	0:10	LINE FAULT
65	16-Sep-2020	GULBARGA	110	KOLHAR- NSSKSUGARS_IPP	JANAWADA_110,NSSK SUGAR FACTORY_IPP	22:45(16.9.2020)			LINE OPEN, LINE FAULT
66	16-Sep-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	22:10	23:59	1:49	LINE FAULT
67	16-Sep-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:45	4:55	0:10	LINE FAULT
68	16-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
69	16-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	1:43	2:03	0:20	LINE CLEAR AVAILED
70	16-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	21:18	21:28	0:10	LINE FAULT
71	16-Sep-2020	GULBARGA	110	SHAHAPUR-WARDHA SOLAR_IPP	SHAHAPUR_220	1:43	2:26	0:43	LINE FAULT
72	16-Sep-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:06	19:11	0:05	LINE FAULT
73	16-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	1:43	2:03	0:20	LINE CLEAR AVAILED
74	16-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:54	20:01	0:07	LINE FAULT
75	16-Sep-2020	GULBARGA	110	SINDHANOOR- MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,BTPSWATERWORKS	2:15	2:25	0:10	LINE FAULT
76	16-Sep-2020	GULBARGA	110	SINDHANOOR- NIRLOOTI_IPP	SINDHANOOR_220	20:40	20:50	0:10	LINE FAULT
77	16-Sep-2020	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	23:01(15.09.2020)			LINE OPEN, LINE CLEAR AVAILED
78	16-Sep-2020	GULBARGA	220	HV1	HALBARGA_220	5:58	6:03	0:05	TRANSFORMER FAULT
79	16-Sep-2020	GULBARGA	220	HV1	SHAHAPUR_220	1:43	1:56	0:13	TRANSFORMER FAULT
80	16-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	22:03(16.9.2020)			LINE OPEN, LINE CLEAR AVAILED
81	16-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	0:32	10:33	10:01	LINE CLEAR AVAILED
82	16-Sep-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	6:00	6:15	0:15	LINE FAULT
83	16-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT
84	16-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)			LINE OPEN, LINE CLEAR AVAILED
85	16-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
86	16-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	22:16 (16.09.2020)			LINE OPEN, LINE FAULT
87	16-Sep-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	22:16	22:40	0:24	LINE FAULT
88	16-Sep-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	22:16 (16.09.2020)			LINE OPEN, LINE FAULT
89	16-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
90	16-Sep-2020	HASSAN	400	TALAGU- NELAMANGALA#2	TALAGUPPA_400	23:04(15.09.2020)	8:45 (16.09.2020)	8:12 hrs	LINE CHARGED
91	16-Sep-2020	HASSAN	400	TALAGU- NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
92	16-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
93	16-Sep-2020	MYSURU	66	HV1	HUNSUR_66	8:30	11:00	2:29	LINE CLEAR AVAILED
94	16-Sep-2020	MYSURU	66	HV1	KIADBMANDYA_66	6:14	7:05	0:50	TRANSFORMER FAULT
95	16-Sep-2020	MYSURU	66	HV1	MADHUVANAHALLI_220	12:52	13:40	0:48	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
96	16-Sep-2020	MYSURU	66	HV1	MANDGERE_66	14:05	14:15	0:10	TRANSFORMER FAULT
97	16-Sep-2020	MYSURU	66	HV2	KIADBMANDYA_66	6:14	7:30	1:16	TRANSFORMER FAULT
98	16-Sep-2020	MYSURU	66	HV2	MADHUVANAHALLI_220	12:13	12:49	0:36	HAND TRIPPED
99	16-Sep-2020	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 TUMBEKERE_66 MADDUR_66 SOMANAHALLI_66	6:55	7:04	0:09	LINE FAULT
100	16-Sep-2020	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	13:30	13:39	0:08	HAND TRIPPED
101	16-Sep-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:54	14:17	0:23	HAND TRIPPED
102	16-Sep-2020	MYSURU	66	TALKADU-ADANI	NO STATIONS EFFECTED	6:11	6:26	0:15	LINE FAULT
103	16-Sep-2020	MYSURU	220	KUSHALNAGARA 220-BASTIPURA 2	NO STATIONS EFFECTED	12:10	22:23	10:13	LINE CLEAR AVAILED
104	16-Sep-2020	MYSURU	220	KUSHALNAGARA 220-HV1	NO STATIONS EFFECTED	16:56	17:41	0:44	LINE FAULT
105	16-Sep-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:41	18:10	7:28	LINE CLEAR AVAILED
106	16-Sep-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	17:10	17:19	0:09	LINE FAULT
107	16-Sep-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	10:54	18:00	7:06	LINE CLEAR AVAILED
108	16-Sep-2020	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	10:06	10:29	0:23	HAND TRIPPED
109	16-Sep-2020	TUMKUR	66	MATHOD-AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	10:46	10:52	0:05	HAND TRIPPED
110	16-Sep-2020	TUMKUR	66	TR-1	HIREGUNTANUR_66	13:16	13:53	0:36	LINE CLEAR AVAILED
111	16-Sep-2020	TUMKUR	66	TR-1	NAGALMADIKE_66	7:00	7:08	0:08	TRANSFORMER FAULT
112	16-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
113	16-Sep-2020	TUMKUR	66	TR-2	BADDIHALLI_66	10:15	16:10	5:55	LINE CLEAR AVAILED
114	16-Sep-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	14:10	14:31	0:20	LINE CLEAR AVAILED
115	16-Sep-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	7:51	7:57	0:05	LINE CLEAR AVAILED
116	16-Sep-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	18:00	19:01	1:00	LINE CLEAR AVAILED
117	16-Sep-2020	TUMKUR	66	TR-3	CHITRADURGA_220	10:52	12:27	1:34	LINE CLEAR AVAILED
118	16-Sep-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	12:13	12:38	0:24	LINE FAULT
119	16-Sep-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:19	16:23	0:04	TRANSFORMER FAULT
120	16-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT
121	16-Sep-2020	TUMKUR	110	TR-3	AMMASANDRA_110	9:48:04 AM(15.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
122	16-Sep-2020	TUMKUR	220	DAVANGERE SRS-GUTTUR-1	DAVANGERE_SRS_220	10:48	17:45	6:57	LINE CLEAR AVAILED
123	16-Sep-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	10:48	17:41	6:53	LINE CLEAR AVAILED
124	17-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
125	17-Sep-2020	BAGALKOT	110	110/11KV ,HV1	STATION NOT AFFECTED ANKOLA 110	22:54(16.09.2020)	1:59(17.09.2020)	2:05	TRANSFORMER CHARGED
126	17-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
127	17-Sep-2020	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BAGALKOT 110	19:20(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
128	17-Sep-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	21:58 (16.09.2020)	9:47 (17.09.2020)	11:49	TRANSFORMER CHARGED
129	17-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
130	17-Sep-2020	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED RON 110	20:00(06.09.2020)	17:25(17.09.2020)	261:25 hrs	LINE CHARGED
131	17-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA 110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
132	17-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
133	17-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
134	17-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
135	17-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR 110	12:51(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
136	17-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
137	17-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
138	17-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
139	17-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28(16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
140	17-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	0:03	7:45	7:42	LOAD CURTAILMENT
141	17-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI 220	6:28(15.09.2020)			LOAD CURTAILMENT
142	17-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI 220	6:33(16.09.2020)			LOAD CURTAILMENT
143	17-Sep-2020	GULBARGA	110	ALIPUR-BELLARY NORTH1	SOMASAMUNDRA_110,BELLARY NORTH_110,MOKA_110,P D_HALLI_110,BISIHALLI_110	4:48	5:01	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
144	17-Sep-2020	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BSSK_IPP	5:58	6:10	0:12	LINE FAULT
145	17-Sep-2020	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BSSK_IPP	6:26	6:46	0:20	LINE FAULT
146	17-Sep-2020	GULBARGA	110	HALBARGA-SANTHAPUR	DONGARGOAN_110,KAM ALANAGAR_110,SANTHAP UR_110	15:34	15:54	0:20	LINE FAULT
147	17-Sep-2020	GULBARGA	110	HATTI- SOMANAMARDI_IPP	HATTI_110	1:14	1:18	0:04	LINE FAULT
148	17-Sep-2020	GULBARGA	110	HV1	RAJESHWAR_110	17:54	18:10	0:16	TRANSFORMER FAULT
149	17-Sep-2020	GULBARGA	110	HV1	KOLHAR_110	9:30	11:05	1:35	LINE CLEAR AVAILED
150	17-Sep-2020	GULBARGA	110	KOLHAR- NSSKSUGARS_IPP	JANAWADA_110,NSSK SUGAR FACTORY_IPP	22:45(16.9.2020)	7:10(17.09.2020)	8:25hrs	LINE CHARGED
151	17-Sep-2020	GULBARGA	110	KOLHAR- NSSKSUGARS_IPP	JANAWADA_110,NSSK SUGAR FACTORY_IPP	15:35	15:50	0:15	LINE FAULT
152	17-Sep-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:10	11:15	0:05	LINE FAULT
153	17-Sep-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	15:35	15:50	0:15	LINE FAULT
154	17-Sep-2020	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	17:40	17:45	0:05	LINE FAULT
155	17-Sep-2020	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	17:55	18:05	0:10	LINE FAULT
156	17-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
157	17-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	5:26	5:31	0:05	LINE FAULT
158	17-Sep-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:15	4:20	0:05	LINE FAULT
159	17-Sep-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	6:04	6:11	0:07	LINE FAULT
160	17-Sep-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	6:11	6:15	0:04	LINE FAULT
161	17-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:01	21:10	0:09	LINE FAULT
162	17-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	21:35	21:58	0:23	LINE FAULT
163	17-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	21:59	22:44	0:45	LINE FAULT
164	17-Sep-2020	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	23:01(15.09.2020)			LINE OPEN, LINE CLEAR AVAILED
165	17-Sep-2020	GULBARGA	220	HV1	HALBARGA_220	15:34	15:54	0:20	TRANSFORMER FAULT
166	17-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	1:13	1:25	0:12	TRANSFORMER FAULT
167	17-Sep-2020	GULBARGA	220	HV1, HV2	KUSTAGI_220	12:48	12:57	0:09	TRANSFORMER FAULT
168	17-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	22:03(16.9.2020)	7:50(17.09.2020)	9:07hrs	LINE CHARGED
169	17-Sep-2020	GULBARGA	220	KAPNOOR-SHAHABAD1	SHAHABAD_220	12:20	19:01	6:41	LINE CLEAR AVAILED
170	17-Sep-2020	GULBARGA	220	KUSTAGI-LINGAPUR	KUSTAGI_220	21:56	22:52	0:56	MAIN SUPPLY FAILURE
171	17-Sep-2020	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	1:14	1:26	0:12	LINE FAULT
172	17-Sep-2020	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	21:56	22:49	0:53	LINE FAULT
173	17-Sep-2020	GULBARGA	220	LINGASUGUR- BBAGEWADI2	B.BAGEWADI_220	1:13	1:32	0:19	LINE FAULT
174	17-Sep-2020	GULBARGA	220	LINGASUGUR- BBAGEWADI2	B.BAGEWADI_220	9:10	15:58	6:48	LINE CLEAR AVAILED
175	17-Sep-2020	GULBARGA	220	LINGASUGUR-KUSHTAGI	LINGASUGUR_220	21:55(17.9.2020)			LINE OPEN, LINE CLEAR AVAILED
176	17-Sep-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	1:13	1:31	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
177	17-Sep-2020	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:42	10:46	10:04	LINE CLEAR AVAILED
178	17-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT
179	17-Sep-2020	GULBARGA	220	SEDAM-SHREE CEMENTS IPP	SEDAM_220	5:58	6:33	0:35	LINE FAULT
180	17-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)			LINE OPEN, LINE CLEAR AVAILED
181	17-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
182	17-Sep-2020	HASSAN	66	HV1	DIDIGA_66	13:00	13:59	0:59	LINE CLEAR AVAILED
183	17-Sep-2020	HASSAN	110	BAIKAMPADY	MSEZ_220	12:17	14:10	1:53	LINE FAULT
184	17-Sep-2020	HASSAN	110	HV1	KALLUSADARAHALLY_110	14:44	16:23	1:39	LINE CLEAR AVAILED
185	17-Sep-2020	HASSAN	110	KAVOOR	MSEZ_220	12:17	14:10	1:53	LINE FAULT
186	17-Sep-2020	HASSAN	220	HV1	MSEZ_220	12:17	14:10	1:53	TRANSFORMER FAULT
187	17-Sep-2020	HASSAN	220	HV2	MSEZ_220	12:17	14:10	1:53	TRANSFORMER FAULT
188	17-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	22:16 (16.09.2020)			LINE OPEN, LINE FAULT
189	17-Sep-2020	HASSAN	220	SHIMOGA2	varahi_gen	18:24	20:20	1:56	LINE CLEAR AVAILED
190	17-Sep-2020	HASSAN	220	STRP2	TALAGUPPA_400	10:38	14:21	3:43	LINE CLEAR AVAILED
191	17-Sep-2020	HASSAN	220	TALGUPA2	gerusoppa_gen	10:38	14:21	3:43	NFBC ISSUED
192	17-Sep-2020	HASSAN	220	VARAH12	MRSMSG_220	18:24	20:18	1:54	LINE CLEAR AVAILED
193	17-Sep-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	22:16 (16.09.2020)			LINE OPEN, LINE FAULT
194	17-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
195	17-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
196	17-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
197	17-Sep-2020	MYSURU	66	HV1	HANGLA_66	17:01	18:05	1:04	TRANSFORMER FAULT
198	17-Sep-2020	MYSURU	66	HV1	KOLKARANADODDI_66	8:30	9:30	1:00	LINE CLEAR AVAILED
199	17-Sep-2020	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 TUMBEKERE_66 MADDUR_66 SOMANAHALLI_66	11:58	12:10	0:12	LINE FAULT
200	17-Sep-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	18:17	18:28	0:10	LINE FAULT
201	17-Sep-2020	MYSURU	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	5:45	5:57	0:12	LINE FAULT
202	17-Sep-2020	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	3:48	3:58	0:10	LINE FAULT
203	17-Sep-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	7:11	7:22	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
204	17-Sep-2020	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	9:13	9:23	0:10	HAND TRIPPED
205	17-Sep-2020	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	9:55	10:11	0:15	HAND TRIPPED
206	17-Sep-2020	TUMKUR	66	HONNALLI 220kv-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:51	19:01	0:09	LINE FAULT
207	17-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	12:19	12:20	0:01	LINE FAULT
208	17-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	13:24	13:30	0:05	LINE FAULT
209	17-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
210	17-Sep-2020	TUMKUR	66	TR-2	BENNEHALLI_66	11:09	11:22	0:13	LINE CLEAR AVAILED
211	17-Sep-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	21:20	21:28	0:07	LINE CLEAR AVAILED
212	17-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT
213	17-Sep-2020	TUMKUR	110	TR-3	AMMASANDRA_110	9:48:04 AM(15.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1	18-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	18-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
3	18-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	18-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
5	18-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
6	18-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
7	18-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
8	18-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
9	18-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
10	18-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
11	18-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	6:28(15.09.2020)			LOAD CURTAILMENT
12	18-Sep-2020	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BAGALKOT_110	19:20(16.09.2020)	16:38 (18.09.2020)	45:18hrs	TRANSFORMER CHARGED
13	18-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
14	18-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28(16.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
15	18-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	6:33(16.09.2020)			LOAD CURTAILMENT
16	18-Sep-2020	BAGALKOT	110	AB_ SOLAR-BELLATTI	BELLATTI_110	22:52	22:56	0:04	HAND TRIPPED
17	18-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	15:09	15:19	0:10	HAND TRIPPED
18	18-Sep-2020	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	23:16	23:33	0:17	LINE FAULT
19	18-Sep-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	11:50	19:32	7:42	LINE CLEAR AVOIDED
20	18-Sep-2020	BAGALKOT	110	BELGAUM-HUDLI	HUDLI_110	8:52	9:11	0:19	LINE FAULT
21	18-Sep-2020	BAGALKOT	110	BSPL-HUDLI	HUDLI_110	9:05	9:20	0:15	HAND TRIPPED
22	18-Sep-2020	BAGALKOT	110	JAMBAGI-HALAKI (MUDHOL)	HALAKI_110	13:27	13:38	0:11	HAND TRIPPED
23	18-Sep-2020	BAGALKOT	110	JAMBAGI-HALAKI (MUDHOL)	HALAKI_110	15:58	16:07	0:09	HAND TRIPPED
24	18-Sep-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	0:09	0:21	0:12	TRANSFORMER FAULT
25	18-Sep-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	1:30	4:14	2:44	TRANSFORMER FAULT
26	18-Sep-2020	BAGALKOT	110	VAJRAMATTI220- MANTUR2	STATION NOT AFFECTED MANTUR_110	11:40	13:35	1:55	LINE CLEAR AVOIDED
27	18-Sep-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	14:23	14:30	0:07	TRANSFORMER FAULT
28	18-Sep-2020	BAGALKOT	110	NOUKAR SOLAR- NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	17:37	21:30	3:53	LINE CLEAR AVOIDED
29	18-Sep-2020	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	21:01	21:30	0:29	TRANSFORMER FAULT
30	18-Sep-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:22	8:35	8:13	LOAD CURTAILMENT
31	18-Sep-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	22:58(18.09.2020)			LOAD CURTAILMENT
32	18-Sep-2020	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	15:53	18:26	2:33	LINE CLEAR AVOIDED
33	18-Sep-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:20	16:50	7:30	LINE CLEAR AVOIDED
34	18-Sep-2020	BAGALKOT	220	HUBLI -SIRSI2	STATION NOT AFFECTED HUBLI_220	18:58	22:33	3:35	LINE FAULT
35	18-Sep-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	11:58	12:12	0:14	LINE FAULT
36	18-Sep-2020	BENGALURU	66	KODIGENAHALLI - T G HALLI	TAVAREKERE	19:09	20:07	0:58	LINE FAULT
37	18-Sep-2020	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	KOTIPURA 220	15:31	15:40	0:09	LOAD CHANGEVER
38	18-Sep-2020	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:31	15:41	0:10	LOAD CHANGEVER
39	18-Sep-2020	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	MELLAHALLI	15:31	15:41	0:10	LOAD CHANGEVER
40	18-Sep-2020	BENGALURU	66	KOTIPURA 220 - KUTAGALLU	KUTAGALLU	15:31	15:41	0:10	LOAD CHANGEVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
41	18-Sep-2020	BENGALURU	66	HV1	SHAMARAJU TECH PARK	14:54	15:02	0:08	TRANSFORMER FAULT
42	18-Sep-2020	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	5:20	5:31	0:11	LINE FAULT
43	18-Sep-2020	BENGALURU	66	HV1	MANDIKAL	12:01	17:01	5:00	LINE CLEAR AVAILED
44	18-Sep-2020	BENGALURU	66	HV1	SADALI	17:05	17:41	0:35	LINE CLEAR AVAILED
45	18-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
46	18-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
47	18-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)			LINE OPEN, LINE CLEAR AVAILED
48	18-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
49	18-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT
50	18-Sep-2020	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	12:33(18.9.2020)			LINE OPEN, LINE CLEAR AVAILED
51	18-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	22:30(18.9.2020)			LINE OPEN, LINE CLEAR AVAILED
52	18-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	0:15	6:35	6:20	LINE CLEAR AVAILED
53	18-Sep-2020	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	23:01(15.09.2020)	10:06(18.9.2020)	59:05hrs	LINE CHARGED
54	18-Sep-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	0:23	6:47	6:24	LINE CLEAR AVAILED
55	18-Sep-2020	GULBARGA	220	LINGASUGUR-KUSHTAGI	LINGASUGUR_220	21:55(17.9.2020)	17:28(18.9.2020)	19:34 HRS	LINE CHARGED
56	18-Sep-2020	GULBARGA	220	SEDAM-SHREECEMENTS	SHREE CEMENTS	5:58	6:33	0:35	LINE FAULT
57	18-Sep-2020	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	12:33	20:11	7:38	LINE CLEAR AVAILED
58	18-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	6:00	6:05	0:05	TRANSFORMER FAULT
59	18-Sep-2020	GULBARGA	220	HV2	LINGASUGUR_220	6:00	6:40	0:40	TRANSFORMER FAULT
60	18-Sep-2020	GULBARGA	220	HV2	KUSHTAGI_220	11:35	18:38	7:03	LINE CLEAR AVAILED
61	18-Sep-2020	GULBARGA	110	HUMNABAD220- CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	5:40	5:48	0:08	LINE FAULT
62	18-Sep-2020	GULBARGA	110	LINGASUGUR-MUDAGAL	MUDGAL_110	6:00	6:12	0:12	LINE FAULT
63	18-Sep-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:25	11:35	0:10	LINE FAULT
64	18-Sep-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANV I_110	4:49	4:59	0:10	LINE FAULT
65	18-Sep-2020	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONK AL_110	23:09	23:27	0:18	LINE FAULT
66	18-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
67	18-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
68	18-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
69	18-Sep-2020	HASSAN	400	TALAGU- NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
70	18-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	22:16 (16.09.2020)	13:42(18.09.2020)	39:25 hrs	LINE CHARGED
71	18-Sep-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	22:16 (16.09.2020)	13:42(18.09.2020)	39:25 hrs	LINE CHARGED
72	18-Sep-2020	HASSAN	110	HV2	BARANGI_110	15:29	15:47	0:18	LINE CLEAR AVAILED
73	18-Sep-2020	HASSAN	110	HV1	BARANGI_110	12:05	13:10	1:05	LINE CLEAR AVAILED
74	18-Sep-2020	HASSAN	110	HV1	BELAGUMBA_110	10:02	13:49	3:47	LINE CLEAR AVAILED
75	18-Sep-2020	HASSAN	110	HV2	BELAGUMBA_110	10:03	14:56	4:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	18-Sep-2020	HASSAN	110	HV1	HIRENALLUR_110	15:39	16:43	1:04	LINE CLEAR AVAILED
77	18-Sep-2020	HASSAN	110	HV1	HOSANGADI_110	10:01	11:04	1:03	LINE CLEAR AVAILED
78	18-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:28	14:28	3:00	TRANSFORMER FAULT
79	18-Sep-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	5:37	5:43	0:06	LINE FAULT
80	18-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	9:33	11:49	2:16	LINE CLEAR AVAILED
81	18-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	17:21	17:26	0:05	HAND TRIPPED
82	18-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	19:15	19:16	0:01	HAND TRIPPED
83	18-Sep-2020	MYSURU	66	HV1	BANNUR_66	17:25	17:35	0:10	HAND TRIPPED
84	18-Sep-2020	MYSURU	66	HV2	BANNUR_66	17:35	18:05	0:30	HAND TRIPPED
85	18-Sep-2020	MYSURU	66	HV2	CHANDAKAVADI_66	14:07	14:34	0:26	LINE CLEAR AVAILED
86	18-Sep-2020	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	15:03	15:05	0:01	LINE FAULT
87	18-Sep-2020	MYSURU	66	HV1	HANGLA_66	9:20	12:08	2:48	LINE CLEAR AVAILED
88	18-Sep-2020	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	10:51	15:36	4:44	LINE CLEAR AVAILED
89	18-Sep-2020	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	11:34	15:38	4:04	LINE CLEAR AVAILED
90	18-Sep-2020	MYSURU	66	KADAKOLA-MYS SOUTH	NO STATIONS EFFECTED	11:14	15:34	4:20	LINE CLEAR AVAILED
91	18-Sep-2020	MYSURU	66	KADAKOLA-TVS	NO STATIONS EFFECTED	13:00	14:01	1:01	LINE CLEAR AVAILED
92	18-Sep-2020	MYSURU	220	HV1	KADAKOLA_220	13:04	14:03	0:59	LINE CLEAR AVAILED
93	18-Sep-2020	MYSURU	66	HV1	KADAKOLA_220	13:21	13:42	0:20	HAND TRIPPED
94	18-Sep-2020	MYSURU	220	HV1	KADAKOLA_220	14:01	14:04	0:02	HAND TRIPPED
95	18-Sep-2020	MYSURU	66	HV2	KADAKOLA_220	13:21	13:42	0:20	HAND TRIPPED
96	18-Sep-2020	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	11:23	15:39	4:16	LINE CLEAR AVAILED
97	18-Sep-2020	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	11:23	15:40	4:17	LINE CLEAR AVAILED
98	18-Sep-2020	MYSURU	66	KADAKOLA-RK NAGARA	NO STATIONS EFFECTED	11:13	15:34	4:21	LINE CLEAR AVAILED
99	18-Sep-2020	MYSURU	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	11:32	15:40	4:08	LINE CLEAR AVAILED
100	18-Sep-2020	MYSURU	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	11:32	15:40	4:08	LINE CLEAR AVAILED
101	18-Sep-2020	MYSURU	66	K HONNALGERE-IGLOOR	NO STATIONS EFFECTED	12:26	15:20	2:53	LINE CLEAR AVAILED
102	18-Sep-2020	MYSURU	66	HV1	KRPET_220	14:12	15:41	1:29	LINE CLEAR AVAILED
103	18-Sep-2020	MYSURU	66	HV2	KRPET_220	14:12	15:42	1:30	LINE CLEAR AVAILED
104	18-Sep-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	8:30	8:35	0:04	LINE FAULT
105	18-Sep-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	8:36	8:52	0:16	LINE FAULT
106	18-Sep-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	8:54	12:57	4:03	LINE FAULT
107	18-Sep-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	14:47	14:54	0:06	LINE FAULT
108	18-Sep-2020	MYSURU	220	MADHUVANAHALLI-HEBBANI-2	NO STATIONS EFFECTED	10:00	16:52	6:52	LINE CLEAR AVAILED
109	18-Sep-2020	MYSURU	66	HV1	MANDGERE_66	5:41	5:43	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
110	18-Sep-2020	MYSURU	66	MEGHALAPURA-SFC	THUMBLA_66 VYASRAJPURA_66 GARGESHWARI_66 CHIDRAVALLI_66 BGPURA_66	2:20	2:35	0:14	LINE FAULT
111	18-Sep-2020	MYSURU	66	HV2	TERAKANAMBE_66	11:01	13:11	2:09	LINE CLEAR AVAILED
112	18-Sep-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	MARADIHUNDI_66 AYRALLI_66	18:18	18:25	0:07	LINE FAULT
113	18-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT
114	18-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
115	18-Sep-2020	TUMKUR	110	TR-3	AMMASANDRA_110	9:48(15.09.2020)	16:47(19.09.2020)	103.38hrs	TRANSFORMER CHARGED
116	18-Sep-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	18:51(18.09.2020)			LINE OPEN, LINE CLEAR AVAILED
117	18-Sep-2020	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	11:26	11:55	0:29	LINE CLEAR AVAILED
118	18-Sep-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	2:54	2:59	0:05	LINE FAULT
119	18-Sep-2020	TUMKUR	66	TR-3	CHITRADURGA_220	10:09	17:49	7:40	LINE CLEAR AVAILED
120	18-Sep-2020	TUMKUR	66	TR-2	CHITRADURGA_220	10:10	17:49	7:39	LINE CLEAR AVAILED
121	18-Sep-2020	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	10:10	17:49	7:39	LINE CLEAR AVAILED
122	18-Sep-2020	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	14:22	15:39	1:17	LINE CLEAR AVAILED
123	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:15	10:25	0:09	HAND TRIPPED
124	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	14:10	14:58	0:47	HAND TRIPPED
125	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:22	12:32	0:09	HAND TRIPPED
126	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:22	12:32	0:10	HAND TRIPPED
127	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHPURA_66	10:12	10:16	0:03	HAND TRIPPED
128	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHPURA_66	11:24	11:41	0:17	HAND TRIPPED
129	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHPURA_66	13:42	14:00	0:18	HAND TRIPPED
130	18-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHPURA_66	14:58	15:11	0:13	HAND TRIPPED
131	18-Sep-2020	TUMKUR	66	HOLALKERE- PANDRAHALLI2	HOLALKERE_66	13:37	13:43	0:05	LINE FAULT
132	18-Sep-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:43	13:50	0:06	HAND TRIPPED
133	18-Sep-2020	TUMKUR	66	TR-2	HOSADURGA_66	14:01	14:15	0:14	MAIN SUPPLY FAILURE
134	18-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:27	10:31	0:03	HAND TRIPPED
135	18-Sep-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	19:43	21:11	1:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
136	18-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:39	11:47	0:07	LINE FAULT
137	18-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAG IRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:04	10:12	0:08	LINE FAULT
138	18-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAG IRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:19	13:32	0:12	LINE FAULT
139	18-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAG IRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:02	14:10	0:08	LINE FAULT
140	18-Sep-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:19	13:28	0:08	LINE FAULT
141	18-Sep-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:02	14:10	0:08	LINE FAULT
142	18-Sep-2020	TUMKUR	66	TR-1	LINGDHALLI_66(SHYLAPU RA)	14:35	14:43	0:08	TRANSFORMER FAULT
143	18-Sep-2020	TUMKUR	66	TR-1	LINGDHALLI_66(SHYLAPU RA)	20:57	21:00	0:02	TRANSFORMER FAULT
144	18-Sep-2020	TUMKUR	66	MATHOD- AVNTI SLR IPP 66	AVNTI_SLR_IPP_66	13:30	13:34	0:03	HAND TRIPPED
145	18-Sep-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	4:00	4:09	0:08	LINE FAULT
146	18-Sep-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	10:17	10:27	0:09	TRANSFORMER FAULT
147	18-Sep-2020	TUMKUR	66	TR-1	NAGASAMUDRA_66	5:48	5:55	0:06	TRANSFORMER FAULT
148	18-Sep-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKO TE_66,LINGDHALLI_66,MA NGALWADA_66	14:55	14:56	0:01	LINE FAULT
1	19-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
2	19-Sep-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	15:37	16:06	0:29	LINE CLEAR AVAILED
3	19-Sep-2020	BAGALKOT	110	110/11KV, HV1&HV2	RON_110	10:40	17:00	6:20	LINE CLEAR AVAILED
4	19-Sep-2020	BAGALKOT	110	110/11KV, HV2	YELPARAHATTI_110	11:12	11:49	0:37	LINE CLEAR AVAILED
5	19-Sep-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	15:07	18:08	3:01	LINE CLEAR AVAILED
6	19-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
7	19-Sep-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	15:07	17:46	2:39	TRANSFORMER FAULT
8	19-Sep-2020	BAGALKOT	110	110/11KV,HV1	GOKAK_110	10:19	20:28	10:09	LINE CLEAR AVAILED
9	19-Sep-2020	BAGALKOT	110	110/11KV,HV1&2	ANAND NAGAR_110	10:02	16:26	6:24	LINE CLEAR AVAILED
10	19-Sep-2020	BAGALKOT	110	110/33KV, HV1	HUBLI_220, TAUSHI_33	14:37	21:09	6:32	TRANSFORMER FAULT
11	19-Sep-2020	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEVARGENNUR_33, LINGADALLI LIS_33	12:01	18:26	6:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
12	19-Sep-2020	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110, ALNAVAR_33	17:46	18:03	0:17	TRANSFORMER FAULT
13	19-Sep-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & KARADI&AMINAGAD_33	13:31	13:37	0:06	TRANSFORMER FAULT
14	19-Sep-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & KARADI&AMINAGAD_33	14:12	14:20	0:08	TRANSFORMER FAULT
15	19-Sep-2020	BAGALKOT	110	110/33KV,HV3	RON_110, MUSHIGERI_33	10:20	15:10	4:50	LINE CLEAR AVAILED
16	19-Sep-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	22:58(18.09.2020)	8:20 (19.09.2020)	9:22hrs	TRANSFORMER CHARGED
17	19-Sep-2020	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	5:20	5:33	0:13	LINE FAULT
18	19-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
19	19-Sep-2020	BAGALKOT	110	GAJENDRAGAD-RON 1&2	RON_110	11:18	15:21	4:03	LINE CLEAR AVAILED
20	19-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
21	19-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
22	19-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
23	19-Sep-2020	BAGALKOT	110	HUBLI- ANAND NAGAR	ANAND NAGAR_110	10:24	16:19	5:55	LINE CLEAR AVAILED
24	19-Sep-2020	BAGALKOT	110	KAGAWAD- SHIRGUPPI SUGARS	KAGAWAD_110	5:20	5:31	0:11	LINE FAULT
25	19-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
26	19-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51(10.09.2020)	11:53 (19.09.2020)	23:02hrs	LINE CHARGED
27	19-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
28	19-Sep-2020	BAGALKOT	110	NAREGAL- RON	RON_110	12:48	14:28	1:40	LINE CLEAR AVAILED
29	19-Sep-2020	BAGALKOT	110	PG HUNSHYAL- SATTI SUGARS	PG HUNSHYAL_110	9:54	12:12	2:18	LINE CLEAR AVAILED
30	19-Sep-2020	BAGALKOT	110	SIGIKERI-ACHANUR	ACHANUR_110	11:45	11:50	0:05	HAND TRIPPED
31	19-Sep-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
32	19-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
33	19-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28(16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
34	19-Sep-2020	BAGALKOT	220	BELGAUM-KANABARGI 2 (NARENDRA2)	BELGAUM_220	23:38 (19.09.2020)			LOAD CURTAILMENT
35	19-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	6:28(15.09.2020)			LOAD CURTAILMENT
36	19-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	6:33(16.09.2020)			LOAD CURTAILMENT
37	19-Sep-2020	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	4:23	7:09	2:46	LOAD CURTAILMENT
38	19-Sep-2020	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	4:16	7:00	2:44	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
39	19-Sep-2020	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	11:16	15:08	3:52	LINE CLEAR AVAILED
40	19-Sep-2020	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	12:10	12:15	0:04	LOAD CHANGE OVER
41	19-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
42	19-Sep-2020	BENGALURU	66	CB PURA I/A - DB PURA 1	CB PURA I/A, CB PURA URBAN	15:50	16:00	0:10	LINE CLEAR AVAILED
43	19-Sep-2020	BENGALURU	66	CB PURA I/A - DB PURA 2	CB PURA I/A	15:50	16:01	0:10	LINE CLEAR AVAILED
44	19-Sep-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	12:15	12:25	0:10	LOAD CHANGE OVER
45	19-Sep-2020	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	6:46	6:50	0:04	LOAD CHANGE OVER
46	19-Sep-2020	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	13:03	13:07	0:04	LOAD CHANGE OVER
47	19-Sep-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:04	13:04	0:59	LINE CLEAR AVAILED
48	19-Sep-2020	BENGALURU	66	ELECTRONIC CITY PH2 SEC 1 - ELECTRONIC CITY	ELECTRONIC CITY PH2 SEC-1	15:23	15:38	0:15	LOAD CHANGE OVER
49	19-Sep-2020	BENGALURU	66	ELECTRONIC CITY PH2 SEC 1 - NAGANATHPURA 220	ELECTRONIC CITY PH2 SEC-1	10:11	10:15	0:04	LOAD CHANGE OVER
50	19-Sep-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	7:02	8:51	1:49	LINE FAULT
51	19-Sep-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:17	17:51	0:34	LINE CLEAR AVAILED
52	19-Sep-2020	BENGALURU	66	HV1	A STATION 66	11:16	16:40	5:24	LINE CLEAR AVAILED
53	19-Sep-2020	BENGALURU	66	HV1	MATHIKERE	8:52	8:55	0:03	LINE CLEAR AVAILED
54	19-Sep-2020	BENGALURU	66	HV1	MITTEMARI 220	11:14	11:17	0:03	LOAD CHANGE OVER
55	19-Sep-2020	BENGALURU	66	HV1	ANDERSONPET	11:58	13:52	1:54	LINE CLEAR AVAILED
56	19-Sep-2020	BENGALURU	66	HV2	MATHIKERE	11:08	11:12	0:04	LINE CLEAR AVAILED
57	19-Sep-2020	BENGALURU	66	HV2	ANDERSONPET	14:04	15:18	1:14	LINE CLEAR AVAILED
58	19-Sep-2020	BENGALURU	66	HV2	CHANDAPURA	2:22	2:42	0:20	TRANSFORMER FAULT
59	19-Sep-2020	BENGALURU	66	HV2	NARASAPURA	12:43	13:05	0:21	LINE CLEAR AVAILED
60	19-Sep-2020	BENGALURU	66	HV2	SARJAPURA 220	5:01	6:42	1:41	MAIN SUPPLY FAILURE
61	19-Sep-2020	BENGALURU	66	HV3	A STATION 66	11:16	15:32	4:16	LINE CLEAR AVAILED
62	19-Sep-2020	BENGALURU	66	HV4	A STATION 66	11:16	15:32	4:16	LINE CLEAR AVAILED
63	19-Sep-2020	BENGALURU	66	IISc - NRS 220	IISc	5:45	5:50	0:05	LOAD CHANGE OVER
64	19-Sep-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTH NAGAR, YEDUMADU	8:49	9:07	0:18	LINE FAULT
65	19-Sep-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	8:49	9:13	0:24	LINE FAULT
66	19-Sep-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	5:01	6:41	1:40	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
67	19-Sep-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	19:13	19:29	0:15	LOAD CURTAILMENT
68	19-Sep-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	5:01	6:40	1:39	MAIN SUPPLY FAILURE
69	19-Sep-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	5:01	19:35	14:34	LOAD CURTAILMENT
70	19-Sep-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	5:01	6:22	1:21	MAIN SUPPLY FAILURE
71	19-Sep-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:44	19:13	0:28	LOAD CURTAILMENT
72	19-Sep-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	5:01	6:42	1:41	MAIN SUPPLY FAILURE
73	19-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	5:01	6:41	1:40	MAIN SUPPLY FAILURE
74	19-Sep-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	5:01	6:21	1:20	MAIN SUPPLY FAILURE
75	19-Sep-2020	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	14:13	14:22	0:09	LINE FAULT
76	19-Sep-2020	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	16:42	16:50	0:08	LINE FAULT
77	19-Sep-2020	BENGALURU	66	KUMBALAGODU - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	9:00	15:30	6:30	LINE CLEAR AVAILED
78	19-Sep-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	5:01	6:41	1:40	MAIN SUPPLY FAILURE
79	19-Sep-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	5:01	6:40	1:39	MAIN SUPPLY FAILURE
80	19-Sep-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:01	6:41	1:40	MAIN SUPPLY FAILURE
81	19-Sep-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	5:01	6:41	1:40	MAIN SUPPLY FAILURE
82	19-Sep-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:01	6:41	1:40	MAIN SUPPLY FAILURE
83	19-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	11:21	11:25	0:04	LOAD CHANGEOVER
84	19-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	11:26	11:30	0:04	LOAD CHANGEOVER
85	19-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	11:21	11:25	0:04	LOAD CHANGEOVER
86	19-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	11:21	11:25	0:04	LOAD CHANGEOVER
87	19-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	11:21	11:25	0:04	LOAD CHANGEOVER
88	19-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	18:26	18:33	0:07	LINE FAULT
89	19-Sep-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	5:01	6:43	1:42	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
90	19-Sep-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	5:01	5:40	0:39	MAIN SUPPLY FAILURE
91	19-Sep-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	5:01	6:46	1:45	MAIN SUPPLY FAILURE
92	19-Sep-2020	BENGALURU	66	SOLADEVANAHALLI - SRS PEENYA 220	SOLADEVANAHALLI	7:59	8:06	0:07	LOAD CHANGEVER
93	19-Sep-2020	BENGALURU	66	SOLADEVANAHALLI - YELAHANKA 220	SOLADEVANAHALLI	6:16	6:30	0:14	MAIN SUPPLY FAILURE
94	19-Sep-2020	BENGALURU	66	YELAHANKA 220 - LINE1	NO STATION AFFECTED	18:13	21:09	2:55	LINE FAULT
95	19-Sep-2020	BENGALURU	220	HV2	KOLAR 220	5:01	6:38	1:37	MAIN SUPPLY FAILURE
96	19-Sep-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	5:01	6:38	1:37	MAIN SUPPLY FAILURE
97	19-Sep-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	5:01	6:05	1:04	MAIN SUPPLY FAILURE
98	19-Sep-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	6:06	6:20	0:14	MAIN SUPPLY FAILURE
99	19-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
100	19-Sep-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	5:01	6:39	1:38	MAIN SUPPLY FAILURE
101	19-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66	6:02	6:15	0:13	LINE FAULT
102	19-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,GIRIY APURA_66,SOVENAHALLI_66,MAGALA_66	6:37	6:42	0:05	LINE FAULT
103	19-Sep-2020	GULBARGA	110	GABUR-DEODURGA	GABUR_110	18:55	19:05	0:10	LINE FAULT
104	19-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
105	19-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	14:44	16:49	2:05	LINE FAULT
106	19-Sep-2020	GULBARGA	110	HV1	SINDHANOOR_110	10:15	10:35	0:20	LINE CLEAR AVAILED
107	19-Sep-2020	GULBARGA	110	HV1	SINDHANOOR_110	10:35	17:15	6:40	LINE CLEAR AVAILED
108	19-Sep-2020	GULBARGA	110	HV1	BEVOOR_110	10:15	10:35	0:20	LINE CLEAR AVAILED
109	19-Sep-2020	GULBARGA	110	HV1	GABUR_110	18:36	18:50	0:14	LOAD CURTAILMENT
110	19-Sep-2020	GULBARGA	110	HV1	JEEWARGI_110	18:35	18:40	0:05	LOAD CURTAILMENT
111	19-Sep-2020	GULBARGA	110	HV1	KURKUNTA_110	18:55	19:25	0:30	LOAD CURTAILMENT
112	19-Sep-2020	GULBARGA	110	HV1	MAHAGAOM_110	18:20	19:45	1:25	TRANSFORMER FAULT
113	19-Sep-2020	GULBARGA	110	HV1	PD_HALLI_110	18:33	18:40	0:07	LOAD CURTAILMENT
114	19-Sep-2020	GULBARGA	110	HV2	HANUMANAL_110	7:55	8:20	0:25	TRANSFORMER FAULT
115	19-Sep-2020	GULBARGA	110	HV2	VENKATAPUR_110	12:43	12:48	0:05	TRANSFORMER FAULT
116	19-Sep-2020	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	4:49	4:59	0:10	LINE FAULT
117	19-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
118	19-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNSAGI_110	5:11	5:21	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
119	19-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	19:27	19:37	0:10	LINE FAULT
120	19-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWATERWORKS	4:17	4:27	0:10	LINE FAULT
121	19-Sep-2020	GULBARGA	110	TEKKELKOTE-SINDHANOOR	TEKKELKOTE_110	10:14	10:17	0:03	LINE FAULT
122	19-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	23:29(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
123	19-Sep-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	22:30(18.9.2020)	7:14(19.9.2020)	8:44 HRS	LINE CHARGED
124	19-Sep-2020	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	12:33(18.9.2020)	17:47(19.09.2020)	29:20 HRS	LINE CHARGED
125	19-Sep-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	2:36	3:00	0:24	LINE FAULT
126	19-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT
127	19-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)			LINE OPEN, LINE CLEAR AVAILED
128	19-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
129	19-Sep-2020	HASSAN	66	HV1	BASAVAGHATTA_66	10:38	13:50	3:12	LINE CLEAR AVAILED
130	19-Sep-2020	HASSAN	66	HV1	HALLIMYSORE_66	18:31	18:39	0:08	LOAD CURTAILMENT
131	19-Sep-2020	HASSAN	66	HV1	HANGARANAHALLY_66	18:31	18:46	0:15	LOAD CURTAILMENT
132	19-Sep-2020	HASSAN	66	HV1	SAKLESHPURA_66	3:10	3:20	0:10	TRANSFORMER FAULT
133	19-Sep-2020	HASSAN	66	HV2	BASAVAGHATTA_66	10:38	13:51	3:13	LINE CLEAR AVAILED
134	19-Sep-2020	HASSAN	66	HV2	BASAVAGHATTA_66	18:31	18:43	0:12	LOAD CURTAILMENT
135	19-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:30	18:38	0:08	LOAD CURTAILMENT
136	19-Sep-2020	HASSAN	66	HV2	HOLALUR_66	11:39	13:21	1:42	LINE CLEAR AVAILED
137	19-Sep-2020	HASSAN	66	HV2	HOLALUR_66	14:02	14:42	0:40	LINE CLEAR AVAILED
138	19-Sep-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	16:30	16:45	0:15	LINE FAULT
139	19-Sep-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	6:43	6:50	0:07	LINE FAULT
140	19-Sep-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	14:27	14:54	0:27	LINE FAULT
141	19-Sep-2020	HASSAN	110	HV1	JAVAGAA_110	18:31	18:40	0:09	LOAD CURTAILMENT
142	19-Sep-2020	HASSAN	110	HV1	KONDENALU_110	18:31	18:47	0:16	LOAD CURTAILMENT
143	19-Sep-2020	HASSAN	110	HV1	NANDIKUR_110	4:43	4:50	0:07	TRANSFORMER FAULT
144	19-Sep-2020	HASSAN	110	HV2	GANDASI_110	18:32	18:44	0:12	LOAD CURTAILMENT
145	19-Sep-2020	HASSAN	110	HV2	GERUMARA_110	18:31	18:44	0:13	LOAD CURTAILMENT
146	19-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	23:42 (19.09.2020)			LINE OPEN, LINE FAULT
147	19-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	5:18	7:30	2:12	LINE FAULT
148	19-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	9:50	10:40	0:50	LINE FAULT
149	19-Sep-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	13:41	15:25	1:44	LINE FAULT
150	19-Sep-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	12:54	13:47	0:53	HAND TRIPPED
151	19-Sep-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	7:28	7:46	0:18	HAND TRIPPED
152	19-Sep-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	10:31	10:41	0:10	HAND TRIPPED
153	19-Sep-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	0:23	23:54	23:31	LINE CLEAR AVAILED
154	19-Sep-2020	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	14:41	16:38	1:57	NFBC ISSUED
155	19-Sep-2020	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	13:10	16:39	3:29	LINE CLEAR AVAILED
156	19-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
157	19-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
158	19-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
159	19-Sep-2020	MYSURU	66	BASARALU-KASALGERE	BASARALU_66	9:20	16:15	6:55	LINE CLEAR AVAILED
160	19-Sep-2020	MYSURU	66	COWDALLY-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	16:16	16:35	0:19	LINE CLEAR AVAILED
161	19-Sep-2020	MYSURU	66	HV1	BGPURA_66	18:30	18:44	0:13	LOAD CURTAILMENT
162	19-Sep-2020	MYSURU	66	HV1	BILIKERE_66	18:31	18:50	0:19	LOAD CURTAILMENT
163	19-Sep-2020	MYSURU	66	HV1	DODDINADUVADI_66	18:31	18:34	0:03	LOAD CURTAILMENT
164	19-Sep-2020	MYSURU	66	HV1	HANGLA_66	11:20	15:29	4:08	LINE CLEAR AVAILED
165	19-Sep-2020	MYSURU	66	HV1	PANDAVAPURA_66	18:31	18:41	0:09	LOAD CURTAILMENT
166	19-Sep-2020	MYSURU	66	HV1	SATHEGALA_66	18:32	18:37	0:04	LOAD CURTAILMENT
167	19-Sep-2020	MYSURU	66	HV2	ADDIHALLI_66	18:30	18:35	0:05	LOAD CURTAILMENT
168	19-Sep-2020	MYSURU	66	HV2	AKKIHEBBAL_66	18:30	18:37	0:06	LOAD CURTAILMENT
169	19-Sep-2020	MYSURU	66	HV2	BOOKANAKERE_66	18:30	18:40	0:09	LOAD CURTAILMENT
170	19-Sep-2020	MYSURU	66	HV2	CHINAKURALI_66	18:30	18:49	0:18	LOAD CURTAILMENT
171	19-Sep-2020	MYSURU	66	HV2	ELAVALA_66	18:31	18:42	0:10	LOAD CURTAILMENT
172	19-Sep-2020	MYSURU	66	HV2	HANNUR_66	18:31	18:36	0:05	LOAD CURTAILMENT
173	19-Sep-2020	MYSURU	66	HV2	HDKOTE_66	18:31	18:44	0:13	LOAD CURTAILMENT
174	19-Sep-2020	MYSURU	66	HV2	JAIPUR_66	18:32	18:43	0:10	LOAD CURTAILMENT
175	19-Sep-2020	MYSURU	66	HV2	KIRUGAVALU_66	18:32	18:41	0:09	LOAD CURTAILMENT
176	19-Sep-2020	MYSURU	66	HV2	KMDODDI_66	18:31	18:49	0:17	LOAD CURTAILMENT
177	19-Sep-2020	MYSURU	66	HV2	KOLLEGALA_66	18:31	18:38	0:06	LOAD CURTAILMENT
178	19-Sep-2020	MYSURU	66	HV2	PONNAMPET_66	18:31	18:41	0:09	LOAD CURTAILMENT
179	19-Sep-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	18:32	18:49	0:17	LOAD CURTAILMENT
180	19-Sep-2020	MYSURU	66	HV2	DODDARAYAPET_66	18:30	18:35	0:05	LOAD CURTAILMENT
181	19-Sep-2020	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	18:33	18:48	0:14	LINE FAULT
182	19-Sep-2020	MYSURU	66	MADHUVANAHALLY-PGPALYA	PGPALYA_66	15:42	15:50	0:08	LINE FAULT
183	19-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	18:02	18:06	0:03	LINE FAULT
184	19-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10			LINE OPEN, LINE CLEAR AVAILED
185	19-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10			LINE OPEN, LINE CLEAR AVAILED
186	19-Sep-2020	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	16:14	16:17	0:02	LINE CLEAR AVAILED
187	19-Sep-2020	TUMKUR	66	DAVANGERE SRS-GUTTUR66	GUTTUR_66	12:09	14:16	2:06	LINE CLEAR AVAILED
188	19-Sep-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:48	15:56	0:08	LINE FAULT
189	19-Sep-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:16	16:30	0:14	LINE FAULT
190	19-Sep-2020	TUMKUR	66	GUTUR 66-DAVANGERE	GUTUR_66	12:19	14:17	1:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
191	19-Sep-2020	TUMKUR	66	HONNALLI 220KV-KUNDUR	KUNDUR_66,MALEBENNU R_66	12:46	12:55	0:08	LINE FAULT
192	19-Sep-2020	TUMKUR	66	HONNALLI 220kv-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	3:41	3:44	0:03	LINE FAULT
193	19-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	10:30	10:33	0:03	LINE FAULT
194	19-Sep-2020	TUMKUR	66	MADHUGIRI 66kv-BADAVANAHALLI	MADHUGIRI_66	10:04	11:18	1:14	LINE CLEAR AVAILED
195	19-Sep-2020	TUMKUR	66	MADHUGIRI 66kv-MADHUGIRI	MADHUGIRI_66	10:04	11:16	1:12	LINE CLEAR AVAILED
196	19-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv-HULUVAGALU	HALUVAGALU_66	14:04	14:06	0:01	HAND TRIPPED
197	19-Sep-2020	TUMKUR	66	NEELAGUNDA220kv-HARPANAHALLI-1	HARAPPANAHALLI_66	14:04	14:06	0:01	HAND TRIPPED
198	19-Sep-2020	TUMKUR	66	TR-1	BALENAHALLI_66	16:18	18:06	1:47	LINE CLEAR AVAILED
199	19-Sep-2020	TUMKUR	66	TR-1	KUKKAWADA_66	10:05	13:48	3:43	LINE CLEAR AVAILED
200	19-Sep-2020	TUMKUR	66	TR-1	MADHUGIRI_66	10:04	11:17	1:13	LINE CLEAR AVAILED
201	19-Sep-2020	TUMKUR	66	TR-1	MATHOD_66	7:45	7:51	0:06	TRANSFORMER FAULT
202	19-Sep-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	4:26	4:32	0:05	HAND TRIPPED
203	19-Sep-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	12:35	13:54	1:18	LINE CLEAR AVAILED
204	19-Sep-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	14:00	14:06	0:06	HAND TRIPPED
205	19-Sep-2020	TUMKUR	66	TR-1	VENKATAPURA_66	22:43	22:52	0:08	TRANSFORMER FAULT
206	19-Sep-2020	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	13:59	14:04	0:05	HAND TRIPPED
207	19-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020	4:26:51(19.09.2020	23:49 hrs	TRANSFORMER CHARGED
208	19-Sep-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	15:41	17:57	2:15	TRANSFORMER FAULT
209	19-Sep-2020	TUMKUR	66	TR-2	BAGUR_TMK_66	23:36	0:00	0:23	TRANSFORMER FAULT
210	19-Sep-2020	TUMKUR	66	TR-2	BALENAHALLI_66	11:19	16:25	5:06	LINE CLEAR AVAILED
211	19-Sep-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	7:27	8:25	0:57	LINE CLEAR AVAILED
212	19-Sep-2020	TUMKUR	66	TR-2	KUKKAWADA_66	10:05	13:48	3:43	LINE CLEAR AVAILED
213	19-Sep-2020	TUMKUR	66	TR-2	MADHUGIRI_66	10:04	11:17	1:13	LINE CLEAR AVAILED
214	19-Sep-2020	TUMKUR	66	TR-2	TELAGI_66	13:59	14:09	0:10	MAIN SUPPLY FAILURE
215	19-Sep-2020	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	11:28	12:29	1:00	LINE CLEAR AVAILED
216	19-Sep-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	18:51:31(18.09.2020	5:30:58 (19.09.2020	11:21hrs	LINE CHARGED
217	19-Sep-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	13:14	14:38	1:24	LINE CLEAR AVAILED
218	19-Sep-2020	TUMKUR	110	TR-1	KALLUR_110	14:05	14:39	0:33	LINE CLEAR AVAILED
219	19-Sep-2020	TUMKUR	110	TR-1	KBCROSS_220	10:03	13:05	3:02	LINE CLEAR AVAILED
220	19-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
221	20-Sep-2020	BAGALKOT	66	HONNALL(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVALIED
222	20-Sep-2020	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	18:29	18:33	0:04	TRANSFORMER FAULT
223	20-Sep-2020	BAGALKOT	110	110/11KV, HV2	KUDACHI_110	7:05	7:31	0:26	TRANSFORMER FAULT
224	20-Sep-2020	BAGALKOT	110	110/11KV, HV2A&HV3	JAMKHANDI_110	10:26	11:05	0:39	LINE CLEAR AVALIED
225	20-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
226	20-Sep-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	0:42	0:55	0:13	TRANSFORMER FAULT
227	20-Sep-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	16:30	18:16	1:46	TRANSFORMER FAULT
228	20-Sep-2020	BAGALKOT	110	110/33KV, HV3	KULIGOD_110, ARALIMATTI_33, TIGADI_33	17:03	17:19	0:16	TRANSFORMER FAULT
229	20-Sep-2020	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	4:36	6:16	1:40	LINE FAULT
230	20-Sep-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	20:28	20:47	0:19	LINE FAULT
231	20-Sep-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	20:50	21:00	0:10	LINE FAULT
232	20-Sep-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	22:32	22:40	0:08	LINE FAULT
233	20-Sep-2020	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110	9:03	13:54	4:51	LINE CLEAR AVALIED
234	20-Sep-2020	BAGALKOT	110	BELGAUM220-HUDLI	HUDLI_110	10:58	14:08	3:10	LINE CLEAR AVALIED
235	20-Sep-2020	BAGALKOT	110	BELGAUM-HUKKERI	HUKKERI_110	9:03	13:39	4:36	LINE CLEAR AVALIED
236	20-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVALIED
237	20-Sep-2020	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	18:18	18:23	0:05	LINE FAULT
238	20-Sep-2020	BAGALKOT	110	GHATAPRABHA220-PG HUNASYAL	PG HUNASYAL_110	14:18	15:01	0:43	LINE FAULT
239	20-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVALIED
240	20-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVALIED
241	20-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVALIED
242	20-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVALIED
243	20-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
244	20-Sep-2020	BAGALKOT	110	KUDACHI220- KUDACHI (AINAPUR)	AINAPUR_110	9:59	22:25	12:26	LINE FAULT
245	20-Sep-2020	BAGALKOT	110	MATRIX WIND-MUKARTIHAL	MUKARTIHAL_110	22:43 (20.09.2020)			LINE OPEN, LINE CLEAR AVALIED
246	20-Sep-2020	BAGALKOT	110	MMCL- SOUDATTI	SOUDATTI_220	16:49	17:35	0:46	LINE FAULT
247	20-Sep-2020	BAGALKOT	110	NARAGUND-GOPANAKOPPA	GOPANAKOPPA_110	8:40	13:26	4:46	LINE FAULT
248	20-Sep-2020	BAGALKOT	110	NARENDRA 2-BELUR	BELUR_110	20:38	20:42	0:04	HAND TRIPPED
249	20-Sep-2020	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	10:50	18:38	7:48	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
250	20-Sep-2020	BAGALKOT	110	PG HUNSHYAL- NAGANUR	NAGANUR_110	14:17	15:06	0:49	HAND TRIPPED
251	20-Sep-2020	BAGALKOT	110	PG HUNSHYAL- SATTI SUGARS	PG HUNSHYAL_110	15:06	15:08	0:02	HAND TRIPPED
252	20-Sep-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	10:10	17:30	7:20	LINE CLEAR AVAILED
253	20-Sep-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	10:11	17:14	7:03	LINE CLEAR AVAILED
254	20-Sep-2020	BAGALKOT	110	UCHAGOAN-UDYAMBAG	UDYAMBAG_110	9:41	13:54	4:13	LINE CLEAR AVAILED
255	20-Sep-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
256	20-Sep-2020	BAGALKOT	220	220/110KV,HV1&LV1	BELGAUM_220	12:21	13:33	1:12	LINE CLEAR AVAILED
257	20-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	21:21 (20.09.2020)			LOAD CURTAILMENT
258	20-Sep-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	11:16	11:42	0:26	LINE FAULT
259	20-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
260	20-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
261	20-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	0:31	6:43	6:12	LOAD CURTAILMENT
262	20-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	14:04 (20.09.2020)			LOAD CURTAILMENT
263	20-Sep-2020	BAGALKOT	220	BELGAUM-KANABARGI 2 (NARENDRA2)	BELGAUM_220	23:38 (19.09.2020)	8:00 AM (20.09.2020)	7:00hrs	LINE CHARGED
264	20-Sep-2020	BAGALKOT	220	BELGAUM-KANABARGI 2 (NARENDRA2)	BELGAUM_220	12:53	13:54	1:01	LINE FAULT
265	20-Sep-2020	BAGALKOT	220	BELGAUM-KANABARGI 2 (NARENDRA2)	BELGAUM_220	15:23 (20.09.2020)			LOAD CURTAILMENT
266	20-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	6:28 (15.09.2020)	18:01 (20.09.2020)	11:33hrs	LINE CHARGED
267	20-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	6:33 (16.09.2020)	22:19 (20.09.2020)	15:46hrs	LINE CHARGED
268	20-Sep-2020	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	21:24 (20.09.2020)			LOAD CURTAILMENT
269	20-Sep-2020	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	16:02	17:56	1:54	LOAD CURTAILMENT
270	20-Sep-2020	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	16:02	17:52	1:50	LOAD CURTAILMENT
271	20-Sep-2020	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	12:53	13:56	1:03	LINE FAULT
272	20-Sep-2020	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	21:26 (20.09.2020)			LOAD CURTAILMENT
273	20-Sep-2020	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	18:03	18:20	0:17	HAND TRIPPED
274	20-Sep-2020	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	17:08 (20.09.2020)			LINE OPEN, LINE FAULT
275	20-Sep-2020	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	13:30	13:40	0:10	LOAD CHANGEOVER
276	20-Sep-2020	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	9:50	10:20	0:30	LINE FAULT
277	20-Sep-2020	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	12:30	12:39	0:09	MAIN SUPPLY FAILURE
278	20-Sep-2020	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	11:33	11:45	0:12	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
279	20-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
280	20-Sep-2020	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	THIMAMPALLI, SOMANATHPURA	13:20	14:20	1:00	MAIN SUPPLY FAILURE
281	20-Sep-2020	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	13:20	14:20	1:00	MAIN SUPPLY FAILURE
282	20-Sep-2020	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	13:20	14:20	1:00	MAIN SUPPLY FAILURE
283	20-Sep-2020	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	13:20	14:20	1:00	MAIN SUPPLY FAILURE
284	20-Sep-2020	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	13:20	14:20	1:00	MAIN SUPPLY FAILURE
285	20-Sep-2020	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE	13:20	14:20	1:00	MAIN SUPPLY FAILURE
286	20-Sep-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH2 SE2	23:42:00(20/09/2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
287	20-Sep-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH2 SE2	23:42	23:59	0:17	TRANSFORMER FAULT
288	20-Sep-2020	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	12:56	13:04	0:08	TRANSFORMER FAULT
289	20-Sep-2020	BENGALURU	66	HV1	MITTEMARI 220	13:20	14:40	1:20	MAIN SUPPLY FAILURE
290	20-Sep-2020	BENGALURU	66	HV1	DEVANAHALLI	2:00	2:07	0:06	TRANSFORMER FAULT
291	20-Sep-2020	BENGALURU	66	HV1	DEVANAHALLI	11:01	11:06	0:05	TRANSFORMER FAULT
292	20-Sep-2020	BENGALURU	66	HV2	ELECTRONIC CITY PH2 SE2	11:20	11:35	0:15	TRANSFORMER FAULT
293	20-Sep-2020	BENGALURU	66	HV2	NANDINI LAYOUT	12:57	12:59	0:02	LINE CLEAR AVAILED
294	20-Sep-2020	BENGALURU	66	HV2	KGF	12:53	13:42	0:49	LINE CLEAR AVAILED
295	20-Sep-2020	BENGALURU	66	KUMBALAGODU - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	8:55	15:15	6:20	LINE CLEAR AVAILED
296	20-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	13:20	14:42	1:22	MAIN SUPPLY FAILURE
297	20-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	13:20	14:42	1:22	MAIN SUPPLY FAILURE
298	20-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	13:20	14:42	1:22	MAIN SUPPLY FAILURE
299	20-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	13:20	14:42	1:22	MAIN SUPPLY FAILURE
300	20-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	13:20	14:42	1:22	MAIN SUPPLY FAILURE
301	20-Sep-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:26	18:40	0:14	LINE FAULT
302	20-Sep-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:26	18:38	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
303	20-Sep-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	17:48	17:55	0:06	LOAD CHANGEOVER
304	20-Sep-2020	BENGALURU	66	YELAHANKA 220 - LINE3	ESCORTS (EHT), MANYATHA TECH PARK, ABBIGERE, ATTUR YELAHANKA	12:31	12:40	0:09	LINE FAULT
305	20-Sep-2020	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	13:20	14:20	1:00	LINE FAULT
306	20-Sep-2020	BENGALURU	220	HV1	GOWRIBIDANUR 220	13:20	14:20	1:00	MAIN SUPPLY FAILURE
307	20-Sep-2020	BENGALURU	220	HV1	MITTEMARI 220	13:20	14:40	1:20	MAIN SUPPLY FAILURE
308	20-Sep-2020	BENGALURU	220	HV2	GOWRIBIDANUR 220	13:20	14:20	1:00	MAIN SUPPLY FAILURE
309	20-Sep-2020	BENGALURU	220	HV2	MITTEMARI 220	13:20	14:40	1:20	MAIN SUPPLY FAILURE
310	20-Sep-2020	BENGALURU	220	HV3	GOWRIBIDANUR 220	13:20	14:20	1:00	MAIN SUPPLY FAILURE
311	20-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
312	20-Sep-2020	GULBARGA	66	ITTAGGI-KUDLIGI2	JKUDLIGI_66,KOGALI_66,C JHALLI_66,HOSAHALLI_66, BANVEKAL_66,CHORNOO R_66,GUDEKOTE_66	17:58	18:15	0:17	LINE FAULT
313	20-Sep-2020	GULBARGA	110	HALBURGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	22:16	22:21	0:05	LINE FAULT
314	20-Sep-2020	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGARGAON_110, KAMALNAGAR_110	3:45	3:56	0:11	LINE FAULT
315	20-Sep-2020	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGARGAON_110, KAMALNAGAR_110	5:39	5:45	0:06	LINE FAULT
316	20-Sep-2020	GULBARGA	110	HATTI-SOMANMARADI	HATTI_110	4:55	5:03	0:08	LINE FAULT
317	20-Sep-2020	GULBARGA	110	HUMNABAD- MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
318	20-Sep-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:50	6:00	0:10	LINE FAULT
319	20-Sep-2020	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	17:07	17:15	0:08	LINE FAULT
320	20-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
321	20-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	18:53	19:03	0:10	LINE FAULT
322	20-Sep-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	18:30	22:20	3:50	LINE FAULT
323	20-Sep-2020	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONK AL_110	6:10	6:38	0:28	LINE FAULT
324	20-Sep-2020	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110,UGARSUG AR_IPP	5:01	5:10	0:09	LINE FAULT
325	20-Sep-2020	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110,UGARSUG AR_IPP	18:42	18:51	0:09	LINE FAULT
326	20-Sep-2020	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110,UGARSUG AR_IPP	20:25	20:32	0:07	LINE FAULT
327	20-Sep-2020	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	4:35	4:44	0:09	LINE FAULT
328	20-Sep-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	5:25	5:40	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
329	20-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	21:40(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
330	20-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:29(19.09.2020)	8:23(20.09.2020)	8:55 HRS	LINE CHARGED
331	20-Sep-2020	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	3:37	3:56	0:19	LINE FAULT
332	20-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT
333	20-Sep-2020	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	6:20	6:50	0:30	LINE CLEAR AVAILED
334	20-Sep-2020	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	6:50	17:07	10:17	LINE CLEAR AVAILED
335	20-Sep-2020	GULBARGA	220	SINDHANOOR-LINGSUGUR	SINDHANOOR_220	5:05	6:10	1:05	LINE FAULT
336	20-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)			LINE OPEN, LINE CLEAR AVAILED
337	20-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
338	20-Sep-2020	HASSAN	66	CHANNARA-SHETTIHALLY	CHANNARAYAPATNA_66	6:00	6:10	0:10	LINE FAULT
339	20-Sep-2020	HASSAN	66	HV1	DUDDA_66	12:48	13:32	0:44	TRANSFORMER FAULT
340	20-Sep-2020	HASSAN	66	HV1	DUDDA_66	13:58	14:22	0:24	TRANSFORMER FAULT
341	20-Sep-2020	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	15:02	15:13	0:11	LINE FAULT
342	20-Sep-2020	HASSAN	110	HV1	BRAHMAVARA_110	13:14	21:53	8:39	LINE CLEAR AVAILED
343	20-Sep-2020	HASSAN	110	HV1	KONDENALU_110	9:00	11:10	2:10	LINE CLEAR AVAILED
344	20-Sep-2020	HASSAN	110	HV2	KONDENALU_110	9:00	11:10	2:10	LINE CLEAR AVAILED
345	20-Sep-2020	HASSAN	110	HV2	MANIPAL_110	9:59	11:03	1:04	LINE CLEAR AVAILED
346	20-Sep-2020	HASSAN	110	HV2	SHIKARIPURA_110	10:14	17:40	7:26	LINE CLEAR AVAILED
347	20-Sep-2020	HASSAN	110	HV3	PUTTUR_110	19:25	19:36	0:11	TRANSFORMER FAULT
348	20-Sep-2020	HASSAN	110	HV3	PUTTUR_110	21:47	21:52	0:05	TRANSFORMER FAULT
349	20-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	23:42 (19.09.2020)	0:22 (20.09.2020)	0:39 hrs	LINE CHARGED
350	20-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE FAULT
351	20-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE FAULT
352	20-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	17:08(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
353	20-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
354	20-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
355	20-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
356	20-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:15 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
357	20-Sep-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	15:05	15:33	0:28	LINE FAULT
358	20-Sep-2020	MYSURU	66	HANNUR-MADHUVANAHALLY 2	HANNUR_66	15:05	15:33	0:28	LINE FAULT
359	20-Sep-2020	MYSURU	66	HV1	HALAGUR_66	8:13	11:50	3:37	LINE CLEAR AVAILED
360	20-Sep-2020	MYSURU	66	HV1	KHBCOLONY_66	17:44	17:52	0:07	LINE CLEAR AVAILED
361	20-Sep-2020	MYSURU	66	HV2	HAMPAPURA_66	20:00	20:09	0:08	TRANSFORMER FAULT
362	20-Sep-2020	MYSURU	66	HV2	MALAVALLI_66	14:02	14:15	0:13	TRANSFORMER FAULT
363	20-Sep-2020	MYSURU	66	HV2	MALAVALLI_66	15:38	15:47	0:08	TRANSFORMER FAULT
364	20-Sep-2020	MYSURU	66	HV2	VAJAMANGALA_220	11:40	11:56	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
365	20-Sep-2020	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	18:25	18:40	0:15	HAND TRIPPED
366	20-Sep-2020	MYSURU	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	15:05	15:36	0:30	LINE FAULT
367	20-Sep-2020	MYSURU	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	14:12	14:26	0:13	LINE FAULT
368	20-Sep-2020	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66 HANAGODU_66	14:12	14:26	0:13	LINE FAULT
369	20-Sep-2020	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	5:44	5:50	0:06	LINE FAULT
370	20-Sep-2020	MYSURU	220	HV1	MADHUVANAHALLI_220	15:05	15:29	0:24	TRANSFORMER FAULT
371	20-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10			LINE OPEN, LINE CLEAR AVAILED
372	20-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10			LINE OPEN, LINE CLEAR AVAILED
373	20-Sep-2020	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:19	10:32	0:12	LINE FAULT
374	20-Sep-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:13	10:30	0:16	MAIN SUPPLY FAILURE
375	20-Sep-2020	TUMKUR	66	HONNALLI 220kV-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:10	9:18	0:08	LINE FAULT
376	20-Sep-2020	TUMKUR	66	KALAMARANAHALLI-HIRIYUR	KALAMARANAHALLI_66	10:22	10:36	0:14	MAIN SUPPLY FAILURE
377	20-Sep-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:47	17:00	0:12	LINE FAULT
378	20-Sep-2020	TUMKUR	66	KUKKAWADA-SRS DAVANGERE	KUKKAWADA_66	16:47	16:58	0:11	LINE FAULT
379	20-Sep-2020	TUMKUR	66	PAVAGADA 220kV-PAVAGADA 1	PAVAGADA_220	17:38	17:42	0:04	LINE FAULT
380	20-Sep-2020	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	17:38	17:44	0:06	LINE FAULT
381	20-Sep-2020	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	17:38	17:57	0:19	LINE FAULT
382	20-Sep-2020	TUMKUR	66	TR-1	LINGDHALLI_66(SHYLAPURA)	14:49	16:21	1:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
383	20-Sep-2020	TUMKUR	66	TR-1	PAVAGADA_220	10:18	10:30	0:11	TRANSFORMER FAULT
384	20-Sep-2020	TUMKUR	66	TR-1	PAVAGADA_220	11:28	11:40	0:12	TRANSFORMER FAULT
385	20-Sep-2020	TUMKUR	66	TR-1	PAVAGADA_220	21:20	21:26	0:05	TRANSFORMER FAULT
386	20-Sep-2020	TUMKUR	66	TR-1	VENKATAPURA_66	0:12	0:20	0:07	LINE CLEAR AVAILED
387	20-Sep-2020	TUMKUR	66	TR-1	SASALUHALLA_66	8:55	13:23	4:28	LINE CLEAR AVAILED
388	20-Sep-2020	TUMKUR	66	TR-2	BAGUR_TMK_66	1:09	1:37	0:27	TRANSFORMER FAULT
389	20-Sep-2020	TUMKUR	66	TR-2	BAGUR_TMK_66	6:38	6:56	0:18	TRANSFORMER FAULT
390	20-Sep-2020	TUMKUR	66	TR-2	BAGUR_TMK_66	7:11	8:45	1:33	TRANSFORMER FAULT
391	20-Sep-2020	TUMKUR	66	TR-2	BAGUR_TMK_66	10:37	11:19	0:42	TRANSFORMER FAULT
392	20-Sep-2020	TUMKUR	66	TR-2	HARIYABBE_66	10:13	10:30	0:16	TRANSFORMER FAULT
393	20-Sep-2020	TUMKUR	66	TR-2	SASALUHALLA_66	13:18	14:42	1:23	LINE CLEAR AVAILED
394	20-Sep-2020	TUMKUR	66	TR-3	HARIYABBE_66	14:57	15:01	0:04	TRANSFORMER FAULT
395	20-Sep-2020	TUMKUR	110	SHETTIKERE-TIMMANAHALLI	SHETYKERE_110	10:58	12:27	1:28	LINE CLEAR AVAILED
396	20-Sep-2020	TUMKUR	110	TR-1	SHETYKERE_110	10:58	12:31	1:32	LINE CLEAR AVAILED
397	20-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT
398	20-Sep-2020	TUMKUR	110	TR-2	SHETYKERE_110	11:00	12:27	1:27	LINE CLEAR AVAILED
1	21-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	21-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
3	21-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	21-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
5	21-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
6	21-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
7	21-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
8	21-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
9	21-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34(13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
10	21-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14(16.09.2020)			TRANSFORMER OPEN ,TRANSFORMER FAULT
11	21-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28(16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
12	21-Sep-2020	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	21:24 (20.09.2020)	6:50 (21.09.2020)	9:26hrs	LINE CHARGED
13	21-Sep-2020	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	17:08 (20.09.2020)	14:09(21.09.2020)	21:01hrs	LINE CHARGED
14	21-Sep-2020	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	21:26 (20.09.2020)	8:05 (21.09.2020)	10:39hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
15	21-Sep-2020	BAGALKOT	110	MATRIX WIND-MUKARTIHAL	STATION NOT AFFECTED MUKARTIHAL_110	22:43 (20.09.2020)	7:28 (21.09.2020)	8:45hrs	LINE CHARGED
16	21-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	STATION NOT AFFECTED AMBEWADI_220	21:21 (20.09.2020)	15:10 (21.09.2020)	17:49hrs	LINE CHARGED
17	21-Sep-2020	BAGALKOT	220	BELGAUM-KANABARGI 2 (NARENDRA2)	STATION NOT AFFECTED BELGAUM_220	15:23 (20.09.2020)	8:05 (21.09.2020)	16:42hrs	LINE CHARGED
18	21-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	14:04 (20.09.2020)	8:03 (21.09.2020)	17:59hrs	LINE CHARGED
19	21-Sep-2020	BAGALKOT	110	110/33KV,HV2	ATHANI_110, JAMBAGI_33, MURGUNDI_33	10:15	11:50	1:35	LINE CLEAR AVOIDED
20	21-Sep-2020	BAGALKOT	110	110/11KV,HV1	ATHANI_220	16:28	17:01	0:33	TRANSFORMER FAULT
21	21-Sep-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI(RAMPUR)	NIDAGUNDI_110	7:41	7:50	0:09	LINE FAULT
22	21-Sep-2020	BAGALKOT	110	110/11KV,HV1	BABLESHWAR_110	6:10	6:25	0:15	TRANSFORMER FAULT
23	21-Sep-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI(RAMPUR)	NIDAGUNDI_110	21:15	21:52	0:37	LINE FAULT
24	21-Sep-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	11:18	14:10	2:52	LINE CLEAR AVOIDED
25	21-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	11:17	12:38	1:21	NFBC ISSUED
26	21-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	23:20 (21.09.2020)			LOAD CURTAILMENT
27	21-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
28	21-Sep-2020	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	3:56	9:21	5:25	LINE FAULT
29	21-Sep-2020	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	4:05	9:21	5:16	LINE CLEAR AVOIDED
30	21-Sep-2020	BAGALKOT	110	SOUDATTI220-MMCL	SOUDATTI_220	5:41	9:23	3:42	LINE FAULT
31	21-Sep-2020	BAGALKOT	220	SHARAVATY1-SIRSI220	SIRSI_220	7:35	14:05	6:30	LINE CLEAR AVOIDED
32	21-Sep-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	18:57	19:16	0:19	HAND TRIPPED
33	21-Sep-2020	BAGALKOT	220	SIRSI-HUBLI 1&2	SIRSI_220	14:08 (21.09.2020)			LOAD CURTAILMENT
34	21-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	15:16 (20.09.2020)	18:57 (21.09.2020)	459:41hrs	LINE CHARGED
35	21-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	19:17	20:50	1:33	LINE CLEAR AVOIDED
36	21-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	21:24 (21.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
37	21-Sep-2020	BAGALKOT	110	ESALE1&2(SIRSI220)-SIRSI	SIRSI_110	12:15	20:57	8:42	LINE CLEAR AVOIDED
38	21-Sep-2020	BAGALKOT	110	SIRSI- KUMATA2	SIRSI_110	11:10	16:45	5:35	LINE CLEAR AVOIDED
39	21-Sep-2020	BAGALKOT	110	VISHWANATH SUGARS-HUKKERI	HUKKERI_110	15:00	18:26	3:26	LINE CLEAR AVOIDED
40	21-Sep-2020	BAGALKOT	110	GMR SUGARS- HALIYAL	HALIYAL_110	10:00	18:52	8:52	LINE CLEAR AVOIDED
41	21-Sep-2020	BAGALKOT	110	BIDNAL- NAVALGUND	NAVALGUND_110	10:25 (21.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
42	21-Sep-2020	BENGALURU	66	ADUGODI - KORAMANGALA 220	ADUGODI, BOSCH (EHT)	22:34	23:20	0:46	MAIN SUPPLY FAILURE
43	21-Sep-2020	BENGALURU	66	HV2	APPAREL PARK	13:05	13:10	0:05	TRANSFORMER FAULT
44	21-Sep-2020	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	23:04	23:08	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
45	21-Sep-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	10:10	12:11	2:01	LINE CLEAR AVAILED
46	21-Sep-2020	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	9:27	9:35	0:08	LINE FAULT
47	21-Sep-2020	BENGALURU	220	HV2	KORAMANGALA 220	22:34	22:53	0:19	TRANSFORMER FAULT
48	21-Sep-2020	BENGALURU	66	HV2	R R NAGAR	12:45	13:04	0:19	TRANSFORMER FAULT
49	21-Sep-2020	BENGALURU	66	HV2	SOMANAHALLI 220	4:42	4:48	0:06	TRANSFORMER FAULT
50	21-Sep-2020	BENGALURU	66	HV2	SOMANAHALLI 220	6:15	6:20	0:05	TRANSFORMER FAULT
51	21-Sep-2020	BENGALURU	220	BIDADI 220 - SOMANAHALLI 220 1	SOMANAHALLI 220	12:42	16:51	4:09	LINE FAULT
52	21-Sep-2020	BENGALURU	220	BIDADI 220 - SOMANAHALLI 220 2	SOMANAHALLI 220	12:42	16:49	4:07	LINE FAULT
53	21-Sep-2020	BENGALURU	220	SOMANAHALLI 220 - BIDADI 220	SOMANAHALLI 220	12:42	13:18	0:36	MAIN SUPPLY FAILURE
54	21-Sep-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	12:42	13:20	0:38	LINE CLEAR AVAILED
55	21-Sep-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	12:42	13:20	0:38	LINE CLEAR AVAILED
56	21-Sep-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	12:42	13:20	0:38	LINE CLEAR AVAILED
57	21-Sep-2020	BENGALURU	220	HV1	VIKAS TECH PARK	13:50	18:05	4:15	TRANSFORMER FAULT
58	21-Sep-2020	BENGALURU	66	HV2	CB PURA I/A	10:25	10:55	0:29	LINE CLEAR AVAILED
59	21-Sep-2020	BENGALURU	66	HV1	D CROSS	1:39	1:45	0:05	TRANSFORMER FAULT
60	21-Sep-2020	BENGALURU	66	HV1	KGF	10:50	12:47	1:57	LINE CLEAR AVAILED
61	21-Sep-2020	BENGALURU	66	HV3	KGF	11:45	11:50	0:05	TRANSFORMER FAULT
62	21-Sep-2020	BENGALURU	66	HV3	KGF	14:05	15:20	1:15	TRANSFORMER FAULT
63	21-Sep-2020	BENGALURU	66	HV1	MELUR	13:15	13:52	0:37	TRANSFORMER FAULT
64	21-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	16:02	16:09	0:07	LINE FAULT
65	21-Sep-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH2 SE2	23:42:00(20/09/2020)	1:39(21/09/2020)	1:57HRS	TRANSFORMER CHARGED
66	21-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
67	21-Sep-2020	BENGALURU	66	KORAMANGALA 220 - ADUGODI	NO STATION AFFECTED	22:34(21/09/2020)			LINE OPEN, LINE FAULT
68	21-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
69	21-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
70	21-Sep-2020	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50(14.09.2020)	9:58(21.09.2020)	155:08 HRS	LINE CHARGED
71	21-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
72	21-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
73	21-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
74	21-Sep-2020	GULBARGA	220	ITTAGGI-BMM ISPAT	ITTAGGI_220	10:10	16:25	6:15	LINE FAULT
75	21-Sep-2020	GULBARGA	220	ITTAGGI-NEELAGUNDA	ITTAGGI_220	10:45	16:25	5:40	LINE CHARGED
76	21-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	21:40(20.09.2020)	7:57(21.09.2020)	9:17 HRS	LINE CHARGED
77	21-Sep-2020	GULBARGA	220	ITTAGGI-BMM ISPAT	ITTAGGI_220	10:10	16:25	6:15	LINE CHARGED
78	21-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	21:40(20.09.2020)	7:52(21.9.2020)	10:32hrs	LINE CHARGED
79	21-Sep-2020	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGGI_220	10:10	13:05	2:55	LINE FAULT
80	21-Sep-2020	GULBARGA	220	HV2	ITTAGGI_220	10:10	10:25	0:15	TRANSFORMER FAULT
81	21-Sep-2020	GULBARGA	220	ITTAGI-BMM	ITTAGGI_220	13:05	16:25	3:20	LINE CLEAR AVAILED
82	21-Sep-2020	GULBARGA	220	HV1 & HV2	ITTAGGI_220	13:00	16:40	3:40	LINE CLEAR AVAILED
83	21-Sep-2020	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGGI_220	13:05	16:25	3:20	LINE CLEAR AVAILED
84	21-Sep-2020	GULBARGA	110	HV1	HALBURGA_220	6:10	6:21	0:11	TRANSFORMER FAULT
85	21-Sep-2020	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY IPP	11:50	11:55	0:05	LINE FAULT
86	21-Sep-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	13:05	13:15	0:10	LINE CLEAR AVAILED
87	21-Sep-2020	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:00	5:05	0:05	LINE FAULT
88	21-Sep-2020	GULBARGA	110	HV1	MADIYAL_110	11:15	11:20	0:05	TRANSFORMER FAULT
89	21-Sep-2020	GULBARGA	110	HV1	MADIYAL_110	11:35	14:10	2:35	LINE CLEAR AVAILED
90	21-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,BTPSWATERWORKS	2:10	2:25	0:15	LINE FAULT
91	21-Sep-2020	GULBARGA	110	HV2	SANKLAPUR_110	10:55	10:58	0:03	TRANSFORMER FAULT
92	21-Sep-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRIYA PUR_66,MAGALA_66,SOV ENHALLI_66,TUNGABHAD RA IPP	6:20	6:27	0:07	LINE FAULT
93	21-Sep-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRIYA PUR_66,MAGALA_66,SOV ENHALLI_66,TUNGABHAD RA IPP	18:39	18:48	0:09	LINE FAULT
94	21-Sep-2020	GULBARGA	66	KOTTUR-ITTAGGI	KOTTUR,UJJAINI	10:40	12:45	2:05	MAIN SUPPLY FAILURE
95	21-Sep-2020	GULBARGA	66	KOTTUR-ITTAGGI	KOTTUR,UJJAINI	16:30	16:45	0:15	MAIN SUPPLY FAILURE
96	21-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	17:08(20.09.2020)	14:10 (21.09.2020)	21:01 hrs	LINE CHARGED
97	21-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
98	21-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
99	21-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
100	21-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
101	21-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:15 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
102	21-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
103	21-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
104	21-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
105	21-Sep-2020	HASSAN	220	HV1	HASSAN_220	14:18	16:26	2:08	TRANSFORMER FAULT
106	21-Sep-2020	HASSAN	220	HASSN220-NITTUR	HASSAN_220	8:36	9:31	0:55	LINE FAULT
107	21-Sep-2020	HASSAN	220	HASSN220-SKPURA	HASSAN_220	8:36	9:14	0:38	LINE FAULT
108	21-Sep-2020	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	14:25	16:25	2:00	LINE CLEAR AVAILED
109	21-Sep-2020	HASSAN	66	LV1	HASSAN_220	14:25	16:25	2:00	LINE CLEAR AVAILED
110	21-Sep-2020	HASSAN	66	HASSN220-CRP1	HASSAN_220	14:25	16:25	2:00	LINE CLEAR AVAILED
111	21-Sep-2020	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	14:25	15:25	1:00	HAND TRIPPED
112	21-Sep-2020	HASSAN	66	HASSN220-HASSAN	HASSAN_220	14:25	15:25	1:00	HAND TRIPPED
113	21-Sep-2020	HASSAN	66	HASSN220-HASSAN	HASSAN_220	17:30	17:44	0:14	HAND TRIPPED
114	21-Sep-2020	HASSAN	66	HASSN220-SKPURA	HASSAN_220	14:25	16:25	2:00	LINE CLEAR AVAILED
115	21-Sep-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	2:18	9:43	7:25	LINE FAULT
116	21-Sep-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	2:18	2:33	0:15	LINE FAULT
117	21-Sep-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	0:02	11:59	11:57	LINE FAULT
118	21-Sep-2020	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	9:44	14:06	4:22	LINE CLEAR AVAILED
119	21-Sep-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	0:04	11:47	11:43	MAIN SUPPLY FAILURE
120	21-Sep-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:04	0:30	0:26	MAIN SUPPLY FAILURE
121	21-Sep-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	0:04	0:32	0:28	MAIN SUPPLY FAILURE
122	21-Sep-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	0:04	0:31	0:27	MAIN SUPPLY FAILURE
123	21-Sep-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	0:04	0:30	0:26	MAIN SUPPLY FAILURE
124	21-Sep-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	2:18	9:43	7:25	LINE FAULT
125	21-Sep-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	2:17	2:25	0:08	LINE FAULT
126	21-Sep-2020	HASSAN	110	HV1	GURUPURA_110	13:48	14:00	0:12	LINE CLEAR AVAILED
127	21-Sep-2020	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:30	10:40	0:10	HAND TRIPPED
128	21-Sep-2020	HASSAN	110	HV1	PUTTUR_110	9:57	15:49	5:52	LINE CLEAR AVAILED
129	21-Sep-2020	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:37	10:42	0:05	HAND TRIPPED
130	21-Sep-2020	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:48	11:51	0:03	HAND TRIPPED
131	21-Sep-2020	HASSAN	110	HV2	SORABA_110	11:29	12:09	0:40	LINE CLEAR AVAILED
132	21-Sep-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:32	13:15	0:43	LINE CLEAR AVAILED
133	21-Sep-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	19:50	20:13	0:23	LINE FAULT
134	21-Sep-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:00	13:04	0:04	TRANSFORMER FAULT
135	21-Sep-2020	HASSAN	66	HV2	BAGUR_66	11:37	11:59	0:22	TRANSFORMER FAULT
136	21-Sep-2020	HASSAN	66	BALLUPE-SAKLESHPUR	BALLUPETE_66	12:15	16:28	4:13	LINE CLEAR AVAILED
137	21-Sep-2020	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	19:52	20:24	0:32	HAND TRIPPED
138	21-Sep-2020	HASSAN	66	CRPATNA2-HNPURA	CRPATNA_220	12:18	12:29	0:11	LINE FAULT
139	21-Sep-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	8:36	16:28	7:52	LINE FAULT
140	21-Sep-2020	HASSAN	66	HV1	MAGGE_66	8:39	16:31	7:52	MAIN SUPPLY FAILURE
141	21-Sep-2020	HASSAN	66	HV2	MAGGE_66	8:39	16:31	7:52	MAIN SUPPLY FAILURE
142	21-Sep-2020	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	8:36	16:30	7:54	LINE FAULT
143	21-Sep-2020	HASSAN	66	HV1	SINGAPURA_66	12:20	12:36	0:16	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
144	21-Sep-2020	HASSAN	66	HV2	SINGAPURA_66	12:20	12:36	0:16	MAIN SUPPLY FAILURE
145	21-Sep-2020	MYSURU	66	HV2	BOGADHI_66	14:15	17:30	3:15	TRANSFORMER FAULT
146	21-Sep-2020	MYSURU	66	BYLUKUPPE-KUSHALNAGARA 220	BYLUKUPPE_66	10:00	17:40	7:40	LINE CLEAR AVAILED
147	21-Sep-2020	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	13:47	13:57	0:09	LINE FAULT
148	21-Sep-2020	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	SUTTUR_66 DEVANOORNGUDU_66	7:34	7:45	0:10	LINE FAULT
149	21-Sep-2020	MYSURU	66	HV1	HALAGUR_66	10:24	12:14	1:50	LINE CLEAR AVAILED
150	21-Sep-2020	MYSURU	66	HV1	HOOTAGALLY_220	11:23	13:28	2:04	LINE CLEAR AVAILED
151	21-Sep-2020	MYSURU	66	HV1	KADAKOLA_220	10:16	13:05	2:49	LINE CLEAR AVAILED
152	21-Sep-2020	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	1:19	1:33	0:13	LINE FAULT
153	21-Sep-2020	MYSURU	66	KOPPA 66-HAMPAPURA	KOPPA_66 BESAGARAHALLI_66	12:10	17:00	4:49	HAND TRIPPED AS PER THE INSTRUCTION OF AE(M) KOPPA DUE TO CONDUCTOR SNAP NEAR HAMPAPURA & NFBC ISSUED TO HAMPAPURA JE @ 13:20:00 IN ORDER TO ISSUE LC TO TLI STAFF FOR ATTENDING THE FAULT. KOPPA & BESAGRALLI STATIONS INTERRUPTED UPTO 12:25:00, LOAD RESUMED FROM DUNDANAHALLI UPTO 16:24:00(AS PER STATION RECORD).
154	21-Sep-2020	MYSURU	66	HV1	KOPPA_66	16:24	17:03	0:38	HAND TRIPPED
155	21-Sep-2020	MYSURU	66	HV2	KOPPA_66	16:24	17:02	0:38	HAND TRIPPED
156	21-Sep-2020	MYSURU	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66	17:22	18:53	1:30	LINE CLEAR AVAILED
157	21-Sep-2020	MYSURU	66	KUSHALNAGARA 220KV-BYLUKUPPE	BYLUKUPPE_66	9:19	9:23	0:03	HAND TRIPPED
158	21-Sep-2020	MYSURU	66	KUSHALNAGARA 220KV-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	6:46	6:52	0:05	LINE FAULT
159	21-Sep-2020	MYSURU	66	KUSHALNAGARA 220KV-PERIYAPATNA-1	PERIYAPATNA_66 HANAGODU_66 VIRAJPET_66 PONNAMPET_66	9:23	12:17	2:53	LINE CLEAR AVAILED
160	21-Sep-2020	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 VIRAJPET_66 PONNAMPET_66	4:25	4:35	0:10	LINE FAULT
161	21-Sep-2020	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 VIRAJPET_66 PONNAMPET_66	8:15	8:25	0:10	LINE FAULT
162	21-Sep-2020	MYSURU	66	HV2	MALLAVALLI	4:23	4:33	0:10	TRANSFORMER FAULT
163	21-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:35	11:40	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
164	21-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	12:43	12:48	0:05	LINE FAULT
165	21-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	13:15	13:25	0:10	LINE FAULT
166	21-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10(19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
167	21-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10(19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
168	21-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN ,TRANSFORMER FAULT
169	21-Sep-2020	TUMKUR	220	NEELAGUNDA220kv- GUTTUR 220kv	NEELAGUNDA_220	10:41(21.09.2020)			LINE OPEN, LINE FAULT
170	21-Sep-2020	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	16:26	19:33	3:06	LINE CLEAR AVAILED
171	21-Sep-2020	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	16:25	19:17	2:52	LINE CLEAR AVAILED
172	21-Sep-2020	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	10:27	19:18	8:50	LINE CLEAR AVAILED
173	21-Sep-2020	TUMKUR	220	HIRIYUR 220kv- PGCIL	HIRIYUR_220	16:25	19:23	2:57	LINE CLEAR AVAILED
174	21-Sep-2020	TUMKUR	220	NEELAGUNDA220kv- ITTAGI 220kv	NEELAGUNDA_220	15:44	16:43	0:59	LINE FAULT
175	21-Sep-2020	TUMKUR	110	HONNAVALI 110-ADAN SOLAR	ADAN SOLAR_IPP_66	17:26	20:04	2:38	LINE CLEAR AVAILED
176	21-Sep-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	21:09	22:03	0:54	LINE FAULT
177	21-Sep-2020	TUMKUR	110	TR-1	MAYASANDRA_110	15:34	16:55	1:20	TRANSFORMER FAULT
178	21-Sep-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	10:45	17:11	6:26	TRANSFORMER FAULT
179	21-Sep-2020	TUMKUR	66	TR-1	BENNEHALLI_66	10:40	12:53	2:13	LINE CLEAR AVAILED
180	21-Sep-2020	TUMKUR	66	BENNEHALLI-SUZLON	SUZLON1_IPP_66	12:53	14:37	1:43	MAIN SUPPLY FAILURE
181	21-Sep-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	8:25	8:56	0:30	LINE FAULT
182	21-Sep-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:01	13:12	0:10	LINE FAULT
183	21-Sep-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:01	13:12	0:11	LINE FAULT
184	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	10:45	17:04	6:18	LINE CLEAR AVAILED
185	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:47	19:21	8:34	LINE CLEAR AVAILED
186	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	16:29	17:32	1:02	LINE CLEAR AVAILED
187	21-Sep-2020	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	16:30	19:17	2:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
188	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:46	19:19	8:33	LINE CLEAR AVAILED
189	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:47	19:38	8:51	LINE CLEAR AVAILED
190	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:47	19:38	8:51	LINE CLEAR AVAILED
191	21-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHPURA_66	10:27	19:19	8:52	LINE CLEAR AVAILED
192	21-Sep-2020	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	16:30	17:34	1:04	LINE CLEAR AVAILED
193	21-Sep-2020	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT 66	13:22	13:33	0:10	LINE FAULT
194	21-Sep-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	13:28	13:37	0:08	LINE FAULT
195	21-Sep-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:14	18:23	0:09	LINE FAULT
196	21-Sep-2020	TUMKUR	66	TR-2	HONNUDIKE_66	14:52	15:34	0:42	LINE CLEAR AVAILED
197	21-Sep-2020	TUMKUR	66	TR-2	HOSADURGA_66	12:40	12:56	0:15	TRANSFORMER FAULT
198	21-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:15	11:16	0:01	LINE FAULT
199	21-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:21	12:26	0:04	LINE FAULT
200	21-Sep-2020	TUMKUR	66	TR-2	LINGDHALLI_66(SHYLAPU RA)	13:09	14:48	1:38	LINE CLEAR AVAILED
201	21-Sep-2020	TUMKUR	66	MATHOD- AVNTI SLR IPP 66	AVNTI_SLR_IPP_66	8:42	8:52	0:09	HAND TRIPPED
202	21-Sep-2020	TUMKUR	66	MATHOD- ENERCON1 IPP 66	ENERCON1_IPP_66	8:41	9:00	0:19	HAND TRIPPED
203	21-Sep-2020	TUMKUR	66	NEELAGUNDA220kv- HARPANAHALLI-1	HARAPPANAHALLI_66	11:02	12:56	1:54	LINE CLEAR AVAILED
204	21-Sep-2020	TUMKUR	66	NEELAGUNDA220kv- HARPANAHALLI-1	HARAPPANAHALLI_66	16:28	16:46	0:17	HAND TRIPPED
205	21-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	10:41	14:22	3:40	LINE CLEAR AVAILED
206	21-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	16:28	16:46	0:18	HAND TRIPPED
207	21-Sep-2020	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	12:27	16:44	4:16	LINE CLEAR AVAILED
208	21-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UC HCHANGIDURGA_66,PALL AGATTE_66,SOKKE_66	11:01	14:29	3:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
209	21-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UC HCHANGIDURGA_66,PALL AGATTE_66, SOKKE_66	16:28	17:12	0:44	HAND TRIPPED
210	21-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv- TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	11:01	12:38	1:36	LINE CLEAR AVAILED
211	21-Sep-2020	TUMKUR	66	NEELAGUNDA 220kv- TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	16:28	17:02	0:34	HAND TRIPPED
212	21-Sep-2020	TUMKUR	66	UCHANGIDURGA- NEELAGUNDA	UCHCHANGIDURGA_66	14:33	17:43	3:10	MAIN SUPPLY FAILURE
213	21-Sep-2020	TUMKUR	66	URDIGERE- ANTHRASANAHALI	URDIGERE_66	15:07	18:18	3:10	LINE CLEAR AVAILED
214	21-Sep-2020	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	16:18	16:47	0:29	LINE CLEAR AVAILED
215	21-Sep-2020	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	18:01	18:22	0:21	LINE CLEAR AVAILED