

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 14.07.2020 TO 20.07.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	14-Jul-20	BAGALKOT	110	110/11KV, HV1	NANADI_110	16:26	17:17	0:51	LINE CLEAR AVAILED
2	14-Jul-20	BAGALKOT	110	110/11KV, HV2	ITANAL_110	8:37	9:45	1:08	TRANSFORMER FAULT
3	14-Jul-20	BAGALKOT	110	110/11KV, HV3	MUDHOL_110	11:43	13:29	1:46	LINE CLEAR AVAILED
4	14-Jul-20	BAGALKOT	110	110/33KV,HV 2	GULEDGUDD_110&SIRUR_3 3, KAMATAGI 33	23:19	23:28	0:09	TRANSFORMER FAULT
5	14-Jul-20	BAGALKOT	110	110/33KV,HV 3	GUTTAL_110	16:01	16:33	0:32	HAND TRIPPED
6	14-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM 110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
7	14-Jul-20	BAGALKOT	110	ATHANI-RENUKA SUGARS	ATHANI_110	6:15	6:51	0:36	LINE FAULT
8	14-Jul-20	BAGALKOT	110	ATHANI-RENUKA SUGARS	ATHANI_110	22:44	22:58	0:14	LINE FAULT
9	14-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
10	14-Jul-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	12:05	12:36	0:31	LINE CLEAR AVAILED
11	14-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
12	14-Jul-20	BAGALKOT	110	HALYAL-GMR SUGARS	HALYAL_110	10:46	12:39	1:53	LINE CLEAR AVAILED
13	14-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
14	14-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR-110	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
15	14-Jul-20	BAGALKOT	110	HUKKERI- KOTAWAGI_LIS	HUKKERI_110	1:22	2:46	1:24	LINE FAULT
16	14-Jul-20	BAGALKOT	110	HUKKERI- KOTAWAGI_LIS	HUKKERI_110	2:48	3:04	0:16	LINE CLEAR AVAILED
17	14-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
18	14-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
19	14-Jul-20	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	16:18	18:25	2:07	LINE CLEAR AVAILED
20	14-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
21	14-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
22	14-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
23	14-Jul-20	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	14:55	18:35	3:40	LINE CLEAR AVAILED
24	14-Jul-20	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	NARENDRA_220,UAS_110,M RUTHYUNJAYANAGAR_110,K UD DHARWAD_110,SHEDBAL_1 10,BELUR1&2_110,TADASIN AKOPPA_110	10:10	10:19	0:09	TRANSFORMER FAULT

25	14-Jul-20	BAGALKOT	220	ADPH 2-BAGEWADI	BAGEWADI_220	10:59 (12.07.2020)			LOAD CURTAILMENT
26	14-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
27	14-Jul-20	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT AFFECTED RANEENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
28	14-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN: LINE CLEAR AVALIED
29	14-Jul-20	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	10:10	10:19	0:09	LINE FAULT
30	14-Jul-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	14:33 (13.07.2020)			LINE OPEN: LINE CLEAR AVALIED
31	14-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	18:51 (12.07.2020)			LOAD CURTAILMENT
32	14-Jul-20	BAGALKOT	400	400/220KV,ICT 1(HV&LV)	DHONI_400	11:28	18:17	6:49	LINE CLEAR AVALIED
33	14-Jul-20	BAGALKOT	400	DHONI-GUTTUR	DHONI_400	10:46	18:20	7:34	LINE CLEAR AVALIED
34	14-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
35	14-Jul-20	BENGALURU	66	HV1	MELUR	21:54 (13-7-2020)	9:00	11:05	TRANSFORMER FAULT
36	14-Jul-20	BENGALURU	66	HV1	MALLASANDRA	11:32	11:47	0:14	LINE CLEAR AVALIED
37	14-Jul-20	BENGALURU	66	HV1	SM MANGALA	8:02	8:13	0:11	LINE CLEAR AVALIED
38	14-Jul-20	BENGALURU	66	HV1	VIJAYAPURA	15:03	16:22	1:18	LINE CLEAR AVALIED
39	14-Jul-20	BENGALURU	66	HV1	NIMHANS 220	11:53	11:56	0:02	LINE CLEAR AVALIED
40	14-Jul-20	BENGALURU	66	HV1	LR BANDE	14:29	14:32	0:03	TRANSFORMER FAULT
41	14-Jul-20	BENGALURU	66	HV2	MALLASANDRA	14:26	14:36	0:09	LINE CLEAR AVALIED
42	14-Jul-20	BENGALURU	66	HV2	BOODIGERE	14:21	15:45	1:24	LINE CLEAR AVALIED
43	14-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
44	14-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT
45	14-Jul-20	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
46	14-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
47	14-Jul-20	GULBARGA	66	HV1	KOTTUR_66	10:16	12:46	2:30	LINE CLEAR AVALIED
48	14-Jul-20	GULBARGA	66	HV2	KOTTUR_66	11:25	12:45	1:20	LINE CLEAR AVALIED
49	14-Jul-20	GULBARGA	110	GABBU-DEODURGA	DEODURGA_110	19:10	19:15	0:05	LINE FAULT
50	14-Jul-20	GULBARGA	110	HV2	MANVI_110	12:04	16:08	4:04	LINE CLEAR AVALIED
51	14-Jul-20	GULBARGA	110	KAPANOOR-HUMNABAD2	ALAND_110,KADAGANCHI_1 10	1:51	2:07	0:16	LINE FAULT
52	14-Jul-20	GULBARGA	110	KAPANOOR-HUMNABAD2	ALAND_110,KADAGANCHI_1 10	5:44	5:55	0:11	LINE FAULT
53	14-Jul-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFA CTORY,CHOWDAPUR_110	23:10	23:20	0:10	LINE FAULT
54	14-Jul-20	GULBARGA	110	LADHA-RENEW WIND SOLAR	LADHA_110	10:33	10:43	0:10	LINE FAULT
55	14-Jul-20	GULBARGA	110	LADHA-RENEW WIND SOLAR	LADHA_110	10:46	11:01	0:15	LINE FAULT

56	14-Jul-20	GULBARGA	110	LV1	SHAHPUR_220	11:06	18:04	6:58	LINE CLEAR AVAILED
57	14-Jul-20	GULBARGA	110	LV2	SHAHPUR_220	16:31	16:53	0:22	TRANSFORMER FAULT
58	14-Jul-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:40	2:56	0:16	LINE FAULT
59	14-Jul-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:40	1:50	0:10	LINE FAULT
60	14-Jul-20	GULBARGA	110	MALLAT-BYAGAWAT	BYAGWAT_110	5:38	5:49	0:11	LINE FAULT
61	14-Jul-20	GULBARGA	110	MALLAT-BYAGAWAT	BYAGWAT_110	6:36	6:46	0:10	LINE FAULT
62	14-Jul-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	9:46	9:56	0:10	LINE FAULT
63	14-Jul-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:45	3:55	0:10	LINE FAULT
64	14-Jul-20	GULBARGA	110	RAICHUR-MANVI	MANVI_110	1:10	1:16	0:06	MAIN SUPPLY FAILURE
65	14-Jul-20	GULBARGA	110	RAICHUR-MANVI	MANVI_110	5:12	5:35	0:23	MAIN SUPPLY FAILURE
66	14-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_110	22:24	22:34	0:10	LINE FAULT
67	14-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_110	23:24	23:28	0:04	LINE FAULT
68	14-Jul-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:23	20:33	0:10	LINE FAULT
69	14-Jul-20	GULBARGA	110	SHAHPUR220-KEMBHAVI2	KBJNL_IPP	16:31	16:48	0:17	LINE FAULT
70	14-Jul-20	GULBARGA	110	SHAHPUR220-SHAHBAD1	SHAHPUR_110	16:31	16:45	0:14	LINE FAULT
71	14-Jul-20	GULBARGA	110	SHAHPUR220-SHORAPUR	SHORAPUR_110	16:31	16:48	0:17	LINE FAULT
72	14-Jul-20	GULBARGA	110	SHAHPUR220-YADGIR	YADGIR_110	16:31	16:53	0:22	LINE FAULT
73	14-Jul-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	0:04	10:17	10:13	LINE FAULT
74	14-Jul-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110	5:35	5:44	0:09	LINE FAULT
75	14-Jul-20	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_11 O,BTPSWATERWORKS	3:15	3:34	0:19	LINE FAULT
76	14-Jul-20	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_11 O,BTPSWATERWORKS	3:57	4:13	0:16	LINE FAULT
77	14-Jul-20	GULBARGA	110	SINDHANOOR220- SINDHANOOR1	SINDHANOOR_110	6:21	6:37	0:16	LINE FAULT
78	14-Jul-20	GULBARGA	110	SINDHANOOR220- SIRIGUPPA	DHADESUGUR_110,SIRIGUP PA_110,TEKKALKOTE_110	9:20	10:05	0:45	LINE FAULT
79	14-Jul-20	GULBARGA	220	BTPSG-RTPS	BTPSG_400	2:27	7:27	5:00	LINE FAULT
80	14-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
81	14-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
82	14-Jul-20	GULBARGA	220	LINGAPUR-GUDEHALLI1	LINGAPUR_220	9:32	15:19	5:47	LINE CLEAR AVAILED
83	14-Jul-20	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	1:38	1:55	0:17	LINE FAULT
84	14-Jul-20	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	1:38	1:54	0:16	LINE FAULT
85	14-Jul-20	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	13:23	13:35	0:12	LINE CLEAR AVAILED
86	14-Jul-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	19:03	19:12	0:09	LINE CLEAR AVAILED
87	14-Jul-20	HASSAN	66	HV2	HOLEHONNUR_66	12:43	15:42	2:59	TRANSFORMER FAULT
88	14-Jul-20	HASSAN	110	HV2	MOODABIDRE_110	11:56	13:23	1:27	TRANSFORMER FAULT

89	14-Jul-20	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
90	14-Jul-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	9:51	13:31	3:40	LINE CLEAR AVAILED
91	14-Jul-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	16:03	19:15	3:12	LINE CLEAR AVAILED
92	14-Jul-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:49	10:51	0:02	HAND TRIPPED
93	14-Jul-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	11:19	11:22	0:03	HAND TRIPPED
94	14-Jul-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	9:52	13:31	3:39	NFBC ISSUED
95	14-Jul-20	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	0:44	14:32	13:48	LINE CLEAR AVAILED
96	14-Jul-20	HASSAN	220	KEMAR-UPCL2	KEMAR_220	9:05	21:25	12:20	NFBC ISSUED
97	14-Jul-20	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	14:25	14:55	0:30	LINE CLEAR AVAILED
98	14-Jul-20	HASSAN	220	UPCL-KEMAR2	upcl_gen	9:05	21:24	12:19	LINE CLEAR AVAILED
99	14-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHANTHIGRAMA_400	21:49 (6.07.2020)	8:49 (14.07.2020)	178:59 hrs	LINE CHARGED
100	14-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHANTHIGRAMA_400	22:56 (14.07.2020)			LINE OPEN: LINE FAULT
101	14-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:50 (6.07.2020)	8:49 (14.07.2020)	178:58 hrs	LINE CHARGED
102	14-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:56 (14.07.2020)			LINE OPEN: LINE FAULT
103	14-Jul-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	18:01 (11.07.2020)			LINE OPEN: LINE CLEAR AVAILED
104	14-Jul-20	MYSURU	66	HV1	BYLUKUPPE_66	12:43	13:59	1:16	LINE CLEAR AVAILED
105	14-Jul-20	MYSURU	66	HV1	DODDABYADARAHALLI_66	11:35	13:06	1:31	LINE CLEAR AVAILED
106	14-Jul-20	MYSURU	66	HV1	HAMPAPURA_66	10:48	11:47	0:59	LINE CLEAR AVAILED
107	14-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
108	14-Jul-20	MYSURU	66	HV2	KIRUGAVALU_66	11:33	11:42	0:08	LINE CLEAR AVAILED
109	14-Jul-20	MYSURU	66	JAKKANAHALLI-NAGMANGLA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	15:53	15:59	0:06	LINE FAULT
110	14-Jul-20	MYSURU	66	KABHALLY-GUNDLUPETE	NO STATIONS EFFECTED	18:55	19:02	0:06	LINE FAULT
111	14-Jul-20	MYSURU	66	KADABALLI-TUBINKERE	KADABALLY_66	10:37	15:38	5:00	LINE CLEAR AVAILED
112	14-Jul-20	MYSURU	66	KUNTHUR-DODDRAIPETE	MUGUR_66 JANNUR_66 THAYURU_66 SANTHEMARAHALLI_66	7:59	8:06	0:06	LINE FAULT
113	14-Jul-20	MYSURU	66	KUNTHUR-DODDRAIPETE	MUGUR_66 JANNUR_66 THAYURU_66 SANTHEMARAHALLI_66	8:33	13:57	5:23	NFBC ISSUED
114	14-Jul-20	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	13:31	13:36	0:04	HAND TRIPPED
115	14-Jul-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	13:41	13:43	0:02	HAND TRIPPED
116	14-Jul-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	15:26	15:33	0:07	LINE FAULT
117	14-Jul-20	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	14:08	14:11	0:02	HAND TRIPPED
118	14-Jul-20	MYSURU	66	MUGUR-KUNTHUR	NO STATIONS EFFECTED	9:01	14:01	5:00	NFBC ISSUED
119	14-Jul-20	MYSURU	66	SANIVARSANTHE-YESSLUR	NO STATIONS EFFECTED	13:35	13:56	0:21	LINE FAULT

120	14-Jul-20	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	15:26	15:30	0:04	LINE FAULT
121	14-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN: LINE FAULT
122	14-Jul-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:44	8:46	0:01	HAND TRIPPED
123	14-Jul-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:07	6:17	0:09	LINE FAULT
124	14-Jul-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	17:37	18:00	0:22	LINE CLEAR AVAILED
125	14-Jul-20	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	6:07	6:19	0:11	LINE FAULT
126	14-Jul-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHC HANGIDURGA_66,PALLAGAT TE_66, SOKKE_66	15:04	15:45	0:41	LINE FAULT
127	14-Jul-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66, RAMAGIRI_66	8:16	8:34	0:17	LINE FAULT
128	14-Jul-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66, RAMAGIRI_66	8:35	8:42	0:07	LINE FAULT
129	14-Jul-20	TUMKUR	66	PAVAGADA220-MADHUGIRI	PAVAGADA_66	17:11	17:36	0:25	LINE FAULT
130	14-Jul-20	TUMKUR	66	PAVAGADA220-PAVAGADA1	PAVAGADA_66	17:10	17:21	0:11	LINE FAULT
131	14-Jul-20	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	17:11	18:59	1:48	LINE FAULT
132	14-Jul-20	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	17:11	17:36	0:25	MAIN SUPPLY FAILURE
133	14-Jul-20	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
134	14-Jul-20	TUMKUR	66	TR-1	PANDARAHALLI_66	6:23	6:24	0:01	TRANSFORMER FAULT
135	14-Jul-20	TUMKUR	66	TR-1	SHYLAPURA_66	5:05	5:15	0:09	MAIN SUPPLY FAILURE
136	14-Jul-20	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	17:10	17:21	0:11	TRANSFORMER FAULT
137	14-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
138	14-Jul-20	TUMKUR	66	TR-2	GUTTUR_66	11:03	12:28	1:24	LINE CLEAR AVAILED
139	14-Jul-20	TUMKUR	66	TR-2	LINGADAHALLI_TM2_66	17:41	18:33	0:52	MAIN SUPPLY FAILURE
140	14-Jul-20	TUMKUR	66	TR-2	TELAGI_66	8:22	9:30	1:08	LINE CLEAR AVAILED
141	14-Jul-20	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	17:10	17:20	0:09	TRANSFORMER FAULT
142	14-Jul-20	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANGERE	UCHCHANGIDURGA_66	11:37	13:10	1:32	LINE CLEAR AVAILED
143	14-Jul-20	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	PALLAGATTE_66,SOKKE_66,	17:11	19:05	1:53	MAIN SUPPLY FAILURE
144	14-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
145	14-Jul-20	TUMKUR	220	TR-1	PAVAGADA_220	17:10	17:22	0:11	TRANSFORMER FAULT
146	14-Jul-20	TUMKUR	220	TR-2	PAVAGADA_220	17:10	17:22	0:11	TRANSFORMER FAULT
147	14-Jul-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	6:32	16:48	10:15	LINE CLEAR AVAILED

148	15-Jul-20	BAGALKOT	110	110/11KV, HV1	SIRSI_110	12:40	13:04	0:24	LINE CLEAR AVAILED
149	15-Jul-20	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	15:17	15:31	0:14	TRANSFORMER FAULT
150	15-Jul-20	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:24	10:26	0:02	LINE CLEAR AVAILED
151	15-Jul-20	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	11:24	16:30	5:06	LINE CLEAR AVAILED
152	15-Jul-20	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	15:53	17:36	1:43	LINE CLEAR AVAILED
153	15-Jul-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	8:38	8:46	0:08	TRANSFORMER FAULT
154	15-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
155	15-Jul-20	BAGALKOT	110	ATHANI-RENUKA SUGARS	ATHANI_110	6:47	6:58	0:11	LINE FAULT
156	15-Jul-20	BAGALKOT	110	ATHANI-RENUKA SUGARS	ATHANI_110	10:38	15:31	4:53	LINE FAULT
157	15-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
158	15-Jul-20	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	15:11	16:30	1:19	LINE CLEAR AVAILED
159	15-Jul-20	BAGALKOT	110	ESALE(SIRSI220)1&2- SIRSI	SIRSI_110	12:23	13:43	1:20	LINE CLEAR AVAILED
160	15-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
161	15-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
162	15-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED SAVANUR-110	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
163	15-Jul-20	BAGALKOT	110	HUNGUND- KUDAL SANGAM	KUDAL SANGAM_110	20:00	20:14	0:14	LINE FAULT
164	15-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
165	15-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
166	15-Jul-20	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	RABAKAVI_110	2:29	5:47	3:18	LINE FAULT
167	15-Jul-20	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	RABAKAVI_110	10:23	10:41	0:18	HAND TRIPPED
168	15-Jul-20	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	RABAKAVI_110	14:20	14:55	0:35	HAND TRIPPED
169	15-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
170	15-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
171	15-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
172	15-Jul-20	BAGALKOT	220	ADPH 2-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	10:59 (12.07.2020)			LOAD CURTAILMENT
173	15-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
174	15-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
175	15-Jul-20	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59			LOAD CURTAILMENT
176	15-Jul-20	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	13:22	18:21	4:59	LINE CLEAR AVAILED

177	15-Jul-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
178	15-Jul-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
179	15-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	8:57 (08.07.2020)			LINE OPEN: LINE CLEAR AVAILED
180	15-Jul-20	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	13:16	13:17	0:01	HAND TRIPPED
181	15-Jul-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	14:33 (13.07.2020)	17:40 (15.07.2020)	51:07 hrs	LINE CHARGED
182	15-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	18:51 (12.07.2020)	17:40 (15.07.2020)	70:49 hrs	LINE CHARGED
183	15-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN: LINE FAULT
184	15-Jul-20	BAGALKOT	400	440/220KV, ICT1(HV1&LV1)	DHONI_400	15:39	18:00	2:21	LINE CLEAR AVOIDED
185	15-Jul-20	BAGALKOT	400	440/220KV, ICT2(HV2&LV2)	DHONI_400	11:06	18:42	7:36	LINE CLEAR AVOIDED
186	15-Jul-20	BAGALKOT	400	DHONI- GUDADALLI	DHONI_400	11:05	18:41	7:36	LINE CLEAR AVOIDED
187	15-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
188	15-Jul-20	BENGALURU	66	F1	DODALAHALLI	21:53	22:22	0:28	TRANSFORMER FAULT
189	15-Jul-20	BENGALURU	66	HV1	EDC 220	11:56	12:02	0:05	LINE CLEAR AVOIDED
190	15-Jul-20	BENGALURU	66	HV1	MELUR	13:13	15:42	2:28	TRANSFORMER FAULT
191	15-Jul-20	BENGALURU	66	HV1	MUDIYANUR	16:51	17:07	0:16	TRANSFORMER FAULT
192	15-Jul-20	BENGALURU	66	HV1	SOMAYAJJANAHALLI	14:13	16:32	2:19	LINE CLEAR AVOIDED
193	15-Jul-20	BENGALURU	66	HV1	SRIGANDAKAVAL	7:14	7:32	0:18	TRANSFORMER FAULT
194	15-Jul-20	BENGALURU	66	HV2	PRIMAL PROJECT	16:15	16:20	0:05	LINE CLEAR AVOIDED
195	15-Jul-20	BENGALURU	66	HV2	PRIMAL PROJECT	12:15	12:20	0:04	LINE CLEAR AVOIDED
196	15-Jul-20	BENGALURU	66	HV2	SOMAYAJJANAHALLI	15:19	17:21	2:01	LINE CLEAR AVOIDED
197	15-Jul-20	BENGALURU	66	HV2	SRIGANDAKAVAL	11:45	11:50	0:05	LINE CLEAR AVOIDED
198	15-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
199	15-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT
200	15-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
201	15-Jul-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR	13:18	14:06	0:48	LINE FAULT
202	15-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
203	15-Jul-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	3:27	3:42	0:15	LINE FAULT
204	15-Jul-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	4:11	4:21	0:10	LINE FAULT
205	15-Jul-20	GULBARGA	110	HUMNABAD-MADIYAL	MADIYAL_110	5:15	5:20	0:05	LINE FAULT
206	15-Jul-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	5:19	5:28	0:09	LINE FAULT
207	15-Jul-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	12:50	12:53	0:03	LINE CLEAR AVOIDED
208	15-Jul-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	15:40	15:45	0:05	LINE FAULT
209	15-Jul-20	GULBARGA	110	HV1	MANVI_110	18:42	18:54	0:12	TRANSFORMER FAULT

210	15-Jul-20	GULBARGA	110	HV1	MANVI_110	19:14	19:24	0:10	TRANSFORMER FAULT
211	15-Jul-20	GULBARGA	110	HV1 & HV2	SHAHAPUR_220	23:04	23:37	0:33	TRANSFORMER FAULT
212	15-Jul-20	GULBARGA	110	HV3	SHAHAPUR_220	9:01	9:19	0:18	TRANSFORMER FAULT
213	15-Jul-20	GULBARGA	110	HV3	SHAHAPUR_220	9:25	10:00	0:35	TRANSFORMER FAULT
214	15-Jul-20	GULBARGA	110	HV3	SHAHAPUR_220	10:29	10:53	0:24	TRANSFORMER FAULT
215	15-Jul-20	GULBARGA	110	HV3	SHAHAPUR_220	13:00	19:17	6:17	TRANSFORMER FAULT
216	15-Jul-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:40	5:46	0:06	LINE FAULT
217	15-Jul-20	GULBARGA	110	KAPNOOR-HUMNABAD1	KAPNOOR_220	18:42			LINE OPEN: LINE CLEAR AVAILED
218	15-Jul-20	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_ 110	21:54	23:59	2:05	LINE FAULT
219	15-Jul-20	GULBARGA	110	KEMBHAVI-UGAR SUGAR_IPP	UGAR SUGAR_IPP	6:30	6:35	0:05	LINE FAULT
220	15-Jul-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:40	2:56	0:16	LINE FAULT
221	15-Jul-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	5:38	5:49	0:11	LINE FAULT
222	15-Jul-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	19:50	20:05	0:15	LINE FAULT
223	15-Jul-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	6:36	6:46	0:10	LINE FAULT
224	15-Jul-20	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,SASTHAPU R_110,MANTHAL_110	19:55	20:20	0:25	LINE FAULT
225	15-Jul-20	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	19:55	23:59	4:05	LINE FAULT
226	15-Jul-20	GULBARGA	110	SHAHAPUR220-SHAHAPUR	SHAHAPUR_110	5:31	8:26	2:55	LINE FAULT
227	15-Jul-20	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	0:07	12:46	12:39	LINE FAULT
228	15-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_ 110	0:56	1:03	0:07	LINE FAULT
229	15-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_ 110	3:45	3:53	0:08	LINE FAULT
230	15-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	19:59	20:05	0:06	LINE FAULT
231	15-Jul-20	GULBARGA	110	SHAHAPUR-WARDASOLAR	WARDASOLAR_110	0:16	0:24	0:08	LINE FAULT
232	15-Jul-20	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	21:09	21:25	0:16	LINE FAULT
233	15-Jul-20	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	23:07	23:28	0:21	LINE FAULT
234	15-Jul-20	GULBARGA	110	SIDHANOOR-TURVIHAL	TURVIHAL_110	3:55	4:05	0:10	LINE FAULT
235	15-Jul-20	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	5:38	5:48	0:10	LINE FAULT
236	15-Jul-20	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	2:35	2:55	0:20	MAIN SUPPLY FAILURE
237	15-Jul-20	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	5:45	6:00	0:15	MAIN SUPPLY FAILURE
238	15-Jul-20	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	6:35	6:45	0:10	MAIN SUPPLY FAILURE
239	15-Jul-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	1:12	6:05	4:53	LINE CLEAR AVAILED
240	15-Jul-20	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	23:04			LINE OPEN: LINE CLEAR AVAILED
241	15-Jul-20	GULBARGA	220	HV2	SHAHAPUR_220	0:07	0:17	0:10	TRANSFORMER FAULT

242	15-Jul-20	GULBARGA	220	HV2	SHAHAPUR_220	23:04			TRANSFORMER OPEN:TRANSFORMER FAULT
243	15-Jul-20	GULBARGA	220	KAPANOOR-HUMNABAD1	HUMNABAD_220	1:05	6:05	5:00	HAND TRIPPED
244	15-Jul-20	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
245	15-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
246	15-Jul-20	GULBARGA	220	LINGAPUR-GADAG1	GADAG_220	9:38	15:38	6:00	LINE CLEAR AVOIDED
247	15-Jul-20	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	2:27	3:51	1:24	LINE FAULT
248	15-Jul-20	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	22:35	22:55	0:20	LINE FAULT
249	15-Jul-20	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	1:34	12:26	10:52	LINE CLEAR AVOIDED
250	15-Jul-20	GULBARGA	220	SHAHAPUR-RTPS2	RTPS_220	23:20			LINE OPEN: LINE CLEAR AVAILED
251	15-Jul-20	HASSAN	66	HV1	CHANNARA	12:25	13:44	1:19	LINE CLEAR AVOIDED
252	15-Jul-20	HASSAN	66	HV2	UDAYAPURA_66	11:01	14:46	3:45	TRANSFORMER FAULT
253	15-Jul-20	HASSAN	66	KIADB HA-RAMESWARNAGAR	KIADB_66	13:05	13:17	0:12	LINE FAULT
254	15-Jul-20	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	13:05	13:20	0:15	LOAD CURTAILMENT
255	15-Jul-20	HASSAN	110	HV1	NANDIKUR_110	12:21	12:35	0:14	HAND TRIPPED
256	15-Jul-20	HASSAN	110	HV2	BARANGI_110	11:25	11:50	0:25	LINE CLEAR AVOIDED
257	15-Jul-20	HASSAN	110	HV2	NANDIKUR_110	12:22	12:36	0:14	HAND TRIPPED
258	15-Jul-20	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
259	15-Jul-20	HASSAN	110	NANDIKU-ISTRL	NANDIKUR_110	12:22	12:30	0:08	HAND TRIPPED
260	15-Jul-20	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	12:22	12:30	0:08	HAND TRIPPED
261	15-Jul-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	12:22	12:29	0:07	HAND TRIPPED
262	15-Jul-20	HASSAN	110	NDKR-SUZLON	NANDIKUR_110	12:20	16:59	4:39	LINE CLEAR AVOIDED
263	15-Jul-20	HASSAN	220	KEMAR-UPCL2	KEMAR_220	8:22	20:48	12:26	NFBC ISSUED
264	15-Jul-20	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	8:25	9:19	0:54	LINE FAULT
265	15-Jul-20	HASSAN	220	UPCL-KEMAR2	upcl_gen	8:22	20:48	12:26	LINE CLEAR AVOIDED
266	15-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHANTHIGRAMA_400	22:56 (14.07.2020)			LINE OPEN: LINE FAULT
267	15-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:37 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
268	15-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:56 (14.07.2020)			LINE OPEN: LINE FAULT
269	15-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:01 (12.07.2020)	7:52 (15.07.2020)	61:51hrs	LINE CHARGED
270	15-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:55 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
271	15-Jul-20	MYSURU	66	ADDIHALLI-NAGAMANGALA	ADDIHALLI_66	10:04	15:13	5:09	LINE CLEAR AVOIDED
272	15-Jul-20	MYSURU	66	CR NAGARA-CHANDAKVADI	CHANDAKAVADI_66	14:56	15:09	0:13	LINE FAULT
273	15-Jul-20	MYSURU	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY MYS 66	14:56	15:14	0:18	LINE FAULT
274	15-Jul-20	MYSURU	66	HV1	BGPURA_66	12:23	13:51	1:28	LINE CLEAR AVOIDED
275	15-Jul-20	MYSURU	66	HV1	PANDAVAPURA_66	13:02	13:28	0:25	HAND TRIPPED

276	15-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
277	15-Jul-20	MYSURU	66	HV2	BGPURA_66	10:24	12:23	1:58	LINE CLEAR AVAILED
278	15-Jul-20	MYSURU	66	HV2	DEVANOORMYS_66	13:54	14:11	0:16	HAND TRIPPED
279	15-Jul-20	MYSURU	66	HV2	PANDAVAPURA_66	12:00	13:00	0:59	LINE CLEAR AVAILED
280	15-Jul-20	MYSURU	66	HV2	VIJAYANAGRAMYS_66	20:26	20:57	0:30	HAND TRIPPED
281	15-Jul-20	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	DODDASARANGI_66,MELKO TE_66, BADDIHALI_66, HONNUDIKE_66, HIREHALLY_66	7:08	7:47	0:39	LINE FAULT
282	15-Jul-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:51	9:56	0:05	HAND TRIPPED
283	15-Jul-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:19	14:35	0:15	LINE FAULT
284	15-Jul-20	TUMKUR	66	HIREHALLI - BADDIHALI	HIREHALLY_66	17:47	18:14	0:26	LINE FAULT
285	15-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN: LINE FAULT
286	15-Jul-20	TUMKUR	66	NEELAGUNDA 220KV-TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALI_66	0:36	0:51	0:15	LINE FAULT
287	15-Jul-20	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
288	15-Jul-20	TUMKUR	66	TR-1	BADAVANAHALLI_66	12:29	14:27	1:58	LINE CLEAR AVAILED
289	15-Jul-20	TUMKUR	66	TR-1	HULIYURDURGA_66	11:52	14:01	2:08	LINE CLEAR AVAILED
290	15-Jul-20	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	8:16	8:34	0:17	TRANSFORMER FAULT
291	15-Jul-20	TUMKUR	66	TR-1	PANDARAHALLI_66	15:08	18:09	3:00	LINE CLEAR AVAILED
292	15-Jul-20	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)	13:16:16 (15.07.2020)	410 hrs	TRANSFORMER CHARGED
293	15-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
294	15-Jul-20	TUMKUR	66	TR-2	CHITRADURGA_220	6:43	7:10	0:26	TRANSFORMER FAULT
295	15-Jul-20	TUMKUR	66	TR-2	KOLALA_66	15:59	17:06	1:07	LINE CLEAR AVAILED
296	15-Jul-20	TUMKUR	66	TR-2	MANGALWADA_66	11:54	11:59	0:05	TRANSFORMER FAULT
297	15-Jul-20	TUMKUR	110	TR-1	TURUVEKERE_110	12:09	12:25	0:16	LINE CLEAR AVAILED
298	15-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
299	15-Jul-20	TUMKUR	110	TR-2	TURUVEKERE_110	12:29	12:49	0:19	LINE CLEAR AVAILED

300	15-Jul-20	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	0:29	14:36	14:06	LINE FAULT
301	15-Jul-20	TUMKUR	220	NEELAGUNDA220kV- GUTTUR 220kV	NEELAGUNDA_220	0:29	14:37	14:08	LINE FAULT
302	16-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
303	16-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
304	16-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
305	16-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
306	16-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
307	16-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
308	16-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
309	16-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
310	16-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
311	16-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
312	16-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
313	16-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	8:57 (08.07.2020)			LINE OPEN: LINE CLEAR AVAILED
314	16-Jul-20	BAGALKOT	220	ADPH 1&2-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	10:59 (12.07.2020)	12:32:00(16.07.2020)	96:33hrs	LINE CHARGED
315	16-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED SAVANUR-110	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
316	16-Jul-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
317	16-Jul-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
318	16-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN: LINE FAULT
319	16-Jul-20	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59			LOAD CURTAILMENT
320	16-Jul-20	BAGALKOT	110	ATHANI SHUGARS-AINAPUR	AINAPUR_110	2:03	2:56	0:53	LINE FAULT
321	16-Jul-20	BAGALKOT	110	ATHANI SHUGARS-AINAPUR	AINAPUR_110	4:36	6:28	1:52	LINE FAULT
322	16-Jul-20	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	6:09	6:21	0:12	LINE FAULT
323	16-Jul-20	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	9:34	9:36	0:02	LOAD CHANGEOVER
324	16-Jul-20	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	10:50	10:59	0:09	LOAD CHANGEOVER
325	16-Jul-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT

326	16-Jul-20	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	6:09	6:42	0:33	LINE FAULT
327	16-Jul-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	0:37	7:43	7:06	LOAD CURTAILMENT
328	16-Jul-20	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	0:39	7:44	7:05	LOAD CURTAILMENT
329	16-Jul-20	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	11:00	15:31	4:31	LINE CLEAR AVAILED
330	16-Jul-20	BAGALKOT	400	400/220KV, ICT2 (HV 2 & LV2)	DHONI_400	10:52	15:24	4:32	LINE CLEAR AVAILED
331	16-Jul-20	BAGALKOT	400	DHONI-GUDADALLI	DHONI_400	10:51	18:51	8:00	LINE CLEAR AVAILED
332	16-Jul-20	BAGALKOT	220	SHARAVTHI2-SIRSI	SIRSI_220	16:09 (16.07.2020)			LINE OPEN: LINE FAULT
333	16-Jul-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	0:54	5:50	4:56	TRANSFORMER FAULT
334	16-Jul-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	11:32	11:41	0:09	HAND TRIPPED
335	16-Jul-20	BAGALKOT	110	VAJRAMATTI-MANTUR1	MANTUR_110	8:29	8:39	0:10	LINE FAULT
336	16-Jul-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	7:25	7:36	0:11	TRANSFORMER FAULT
337	16-Jul-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	9:41	9:46	0:05	TRANSFORMER FAULT
338	16-Jul-20	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	11:54	14:30	2:36	TRANSFORMER FAULT
339	16-Jul-20	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	6:09	7:01	0:52	LINE FAULT
340	16-Jul-20	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	6:09	6:42	0:33	LINE FAULT
341	16-Jul-20	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	5:48	7:43	1:55	LINE FAULT
342	16-Jul-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:20	8:56	8:36	HAND TRIPPED
343	16-Jul-20	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:30	7:23	6:53	HAND TRIPPED
344	16-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, SHIRGUPPI_110, UGARKHUD_110	2:03	2:12	0:09	TRANSFORMER FAULT
345	16-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, AINAPUR_110, UGARKHUD_110	4:15	4:23	0:08	TRANSFORMER FAULT
346	16-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, AINAPUR_110, UGARKHUD_110	5:58	6:06	0:08	TRANSFORMER FAULT
347	16-Jul-20	BAGALKOT	110	KUDACHI220- AINAPUR	AINAPUR_110	4:15	4:35	0:20	LINE FAULT
348	16-Jul-20	BAGALKOT	110	KUDACHI220- AINAPUR	AINAPUR_110	5:58	6:14	0:16	LINE FAULT
349	16-Jul-20	BAGALKOT	110	220/110KV, LV1	INDI_110	1:35	2:35	1:00	TRANSFORMER FAULT
350	16-Jul-20	BAGALKOT	110	110/11KV, HV1&HV2	GUTTAL_110	10:06	18:55	8:49	LINE CLEAR AVAILED
351	16-Jul-20	BAGALKOT	110	110/33KV, HV3	GUTTAL_110, HOSARATTI_33	10:07	18:55	8:48	LINE CLEAR AVAILED
352	16-Jul-20	BAGALKOT	110	SUZLON1&2- GUTTAL	GUTTAL_110	10:07	18:25	8:18	LINE CLEAR AVAILED
353	16-Jul-20	BAGALKOT	110	GADAG- ANNIGERI	ANNIGERI_110	9:35	10:58	1:23	HAND TRIPPED
354	16-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	GADAG_220	10:56	13:19	2:23	LINE CLEAR AVAILED
355	16-Jul-20	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	1:57	2:40	0:43	MAIN SUPPLY FAILURE
356	16-Jul-20	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI	1:57	2:50	0:53	MAIN SUPPLY FAILURE
357	16-Jul-20	BENGALURU	66	AMAR JYOTHI - ADUGODI 2	GOLF LINK	1:57	3:08	1:11	MAIN SUPPLY FAILURE
358	16-Jul-20	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI, GOLF LIK	3:29	3:40	0:11	MAIN SUPPLY FAILURE
359	16-Jul-20	BENGALURU	66	A STATION 220 - EDC 220	A STATION 220	1:59	2:08	0:09	MAIN SUPPLY FAILURE

360	16-Jul-20	BENGALURU	66	A STATION 66 - A STATION 1	A STATION 66	1:59	2:08	0:09	MAIN SUPPLY FAILURE
361	16-Jul-20	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	1:59	2:08	0:09	MAIN SUPPLY FAILURE
362	16-Jul-20	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	1:59	2:08	0:09	MAIN SUPPLY FAILURE
363	16-Jul-20	BENGALURU	66	HV1	BTM 4TH PHASE	14:43	14:50	0:07	LINE CLEAR AVAILED
364	16-Jul-20	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	8:42	8:44	0:02	LOAD CHANGEOVER
365	16-Jul-20	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	16:55	16:58	0:03	LOAD CHANGEOVER
366	16-Jul-20	BENGALURU	220	EDC 220 - HAL 220	EDC 220	1:58	2:32	0:34	MAIN SUPPLY FAILURE
367	16-Jul-20	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	1:58	2:45	0:47	MAIN SUPPLY FAILURE
368	16-Jul-20	BENGALURU	66	EDC 220 - BMTC	BMTC	1:58	2:44	0:46	MAIN SUPPLY FAILURE
369	16-Jul-20	BENGALURU	66	EDC 220 - B STATION	B STATION	1:58	2:31	0:33	MAIN SUPPLY FAILURE
370	16-Jul-20	BENGALURU	220	EPIP 220 - ITPL(EHT) 220	EPIP 220	1:58	4:10	2:12	MAIN SUPPLY FAILURE
371	16-Jul-20	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	1:58	3:15	1:17	MAIN SUPPLY FAILURE
372	16-Jul-20	BENGALURU	66	HENNUR CROSS - BIAL 220	HENNUR CROSS	1:58	2:09	0:11	MAIN SUPPLY FAILURE
373	16-Jul-20	BENGALURU	400	HOODY 400 - KOLAR-PGCIL 1	HOODY 400	1:58	3:15	1:17	MAIN SUPPLY FAILURE
374	16-Jul-20	BENGALURU	400	HOODY 400 - KOLAR-PGCIL 2	HOODY 400	1:58	4:01	2:03	MAIN SUPPLY FAILURE
375	16-Jul-20	BENGALURU	220	HOODY 220 - HOODY 400	HOODY 220	1:58	3:37	1:39	MAIN SUPPLY FAILURE
376	16-Jul-20	BENGALURU	220	HOODY 220 - BEGUR 220	BEGUR 220	1:58	2:07	0:09	MAIN SUPPLY FAILURE
377	16-Jul-20	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	1:58	4:36	2:38	MAIN SUPPLY FAILURE
378	16-Jul-20	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	1:58	4:13	2:15	MAIN SUPPLY FAILURE
379	16-Jul-20	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	1:58	4:10	2:12	MAIN SUPPLY FAILURE
380	16-Jul-20	BENGALURU	220	HOODY 220 - ITI 220	ITI 220	1:58	2:40	0:42	MAIN SUPPLY FAILURE
381	16-Jul-20	BENGALURU	220	HOODY 220 - RAILWAY 1	NO STATION AFFECTED	1:58	14:30	12:32	LINE FAULT
382	16-Jul-20	BENGALURU	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK	1:58	4:34	2:36	MAIN SUPPLY FAILURE
383	16-Jul-20	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	1:58	2:38	0:40	MAIN SUPPLY FAILURE
384	16-Jul-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	1:58	2:38	0:40	MAIN SUPPLY FAILURE
385	16-Jul-20	BENGALURU	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220	1:58	2:50	0:52	MAIN SUPPLY FAILURE
386	16-Jul-20	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	1:58	2:45	0:47	MAIN SUPPLY FAILURE
387	16-Jul-20	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	1:58	2:40	0:42	MAIN SUPPLY FAILURE
388	16-Jul-20	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	1:58	3:06	1:08	MAIN SUPPLY FAILURE
389	16-Jul-20	BENGALURU	66	HV1	KADUGODI	4:05	4:50	0:45	LINE CLEAR AVAILED
390	16-Jul-20	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	1:58	2:50	0:52	MAIN SUPPLY FAILURE

391	16-Jul-20	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	1:58	2:50	0:52	MAIN SUPPLY FAILURE
392	16-Jul-20	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	1:58	2:48	0:50	MAIN SUPPLY FAILURE
393	16-Jul-20	BENGALURU	66	KORAMANGALA 220 - KORAMANGALA 66	KORAMANGALA 66	1:58	2:52	0:54	MAIN SUPPLY FAILURE
394	16-Jul-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	6:05	6:16	0:11	LOAD CHANGEOVER
395	16-Jul-20	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	17:13	17:20	0:07	LOAD CHANGEOVER
396	16-Jul-20	BENGALURU	66	HV1	RR NAGAR	12:27	13:04	0:37	LINE CLEAR AVAILED
397	16-Jul-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	5:21	5:23	0:02	LOAD CHANGEOVER
398	16-Jul-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	17:05	17:09	0:04	LOAD CHANGEOVER
399	16-Jul-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	2:00	3:23	1:23	MAIN SUPPLY FAILURE
400	16-Jul-20	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	2:00	3:23	1:23	MAIN SUPPLY FAILURE
401	16-Jul-20	BENGALURU	66	BEGUR 220 - VIDYANAGAR	GRINDWELL (EHT), VIDYANAGARA	1:58	2:04	0:06	MAIN SUPPLY FAILURE
402	16-Jul-20	BENGALURU	66	BEGUR 220 - BIAL 2	BIAL	1:58	2:04	0:06	MAIN SUPPLY FAILURE
403	16-Jul-20	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	1:58	2:04	0:06	MAIN SUPPLY FAILURE
404	16-Jul-20	BENGALURU	220	HV1	BIAL BEGUR 220	1:58	2:04	0:06	MAIN SUPPLY FAILURE
405	16-Jul-20	BENGALURU	220	HV2	BIAL BEGUR 220	1:58	2:04	0:06	MAIN SUPPLY FAILURE
406	16-Jul-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220, DEVANAHALLI KIADB PARK 220	1:58	2:09	0:11	MAIN SUPPLY FAILURE
407	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	1:58	3:13	1:15	MAIN SUPPLY FAILURE
408	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	1:58	3:13	1:15	MAIN SUPPLY FAILURE
409	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	1:58	3:13	1:15	MAIN SUPPLY FAILURE
410	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	1:58	3:13	1:15	MAIN SUPPLY FAILURE
411	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	1:58	3:13	1:15	MAIN SUPPLY FAILURE
412	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	1:58	3:13	1:15	MAIN SUPPLY FAILURE
413	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	1:58	3:13	1:15	MAIN SUPPLY FAILURE
414	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	1:58	3:13	1:15	MAIN SUPPLY FAILURE
415	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	1:58	3:13	1:15	MAIN SUPPLY FAILURE

416	16-Jul-20	BENGALURU	220	HV2	CHINTAMANI 220	3:13	9:00	5:47	TRANSFORMER FAULT
417	16-Jul-20	BENGALURU	220	HV3	CHINTAMANI 220	1:58	3:20	1:22	MAIN SUPPLY FAILURE
418	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	9:02	9:10	0:08	LOAD CHANGEOVER
419	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:02	9:10	0:08	LOAD CHANGEOVER
420	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	9:02	9:10	0:08	LOAD CHANGEOVER
421	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	9:02	9:10	0:08	LOAD CHANGEOVER
422	16-Jul-20	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	9:02	9:11	0:09	LINE FAULT
423	16-Jul-20	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	3:33	3:38	0:05	LOAD CHANGEOVER
424	16-Jul-20	BENGALURU	220	KIADB DEVANAHALLI PARK 220 - BIAL BEGUR 220	KIADB DEVANAHALLI PARK 220, HOSKOTE 220	1:58	2:18	0:20	LINE FAULT
425	16-Jul-20	BENGALURU	220	KIADB DEVANAHALLI PARK 220 - BIAL BEGUR 220	KIADB DEVANAHALLI PARK 220, HOSKOTE 220	7:15	7:42	0:27	LINE FAULT
426	16-Jul-20	BENGALURU	220	KIADB DEVANAHALLI PARK 220 - BIAL BEGUR 220	KIADB DEVANAHALLI PARK 220, HOSKOTE 220	12:05	13:05	1:00	LINE FAULT
427	16-Jul-20	BENGALURU	66	HV1	KIADB DEVANAHALLI PARK 220	1:58	2:18	0:20	MAIN SUPPLY FAILURE
428	16-Jul-20	BENGALURU	66	HV1	KIADB DEVANAHALLI PARK 220	7:15	7:42	0:27	MAIN SUPPLY FAILURE
429	16-Jul-20	BENGALURU	66	HV1	KIADB DEVANAHALLI PARK 220	12:05	13:05	1:00	MAIN SUPPLY FAILURE
430	16-Jul-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	1:58	2:32	0:34	MAIN SUPPLY FAILURE
431	16-Jul-20	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	1:58	2:32	0:34	MAIN SUPPLY FAILURE
432	16-Jul-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	1:58	2:35	0:37	MAIN SUPPLY FAILURE
433	16-Jul-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	1:58	2:15	0:17	MAIN SUPPLY FAILURE
434	16-Jul-20	BENGALURU	220	HV1	HOSKOTE 220	1:58	2:14	0:16	MAIN SUPPLY FAILURE
435	16-Jul-20	BENGALURU	220	HV2	HOSKOTE 220	1:58	2:40	0:42	MAIN SUPPLY FAILURE
436	16-Jul-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	7:15	7:52	0:37	MAIN SUPPLY FAILURE
437	16-Jul-20	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	7:15	7:52	0:37	MAIN SUPPLY FAILURE
438	16-Jul-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	7:15	7:53	0:38	MAIN SUPPLY FAILURE
439	16-Jul-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	7:15	7:54	0:39	MAIN SUPPLY FAILURE
440	16-Jul-20	BENGALURU	220	HV1	HOSKOTE 220	7:15	7:50	0:35	MAIN SUPPLY FAILURE
441	16-Jul-20	BENGALURU	220	HV2	HOSKOTE 220	7:15	7:52	0:37	MAIN SUPPLY FAILURE
442	16-Jul-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:05	13:20	1:15	MAIN SUPPLY FAILURE
443	16-Jul-20	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	12:05	13:18	1:13	MAIN SUPPLY FAILURE
444	16-Jul-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	12:05	13:16	1:11	MAIN SUPPLY FAILURE

445	16-Jul-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:05	13:20	1:15	MAIN SUPPLY FAILURE
446	16-Jul-20	BENGALURU	220	HV1	HOSKOTE 220	12:05	13:11	1:06	MAIN SUPPLY FAILURE
447	16-Jul-20	BENGALURU	220	HV2	HOSKOTE 220	12:05	13:13	1:08	MAIN SUPPLY FAILURE
448	16-Jul-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	2:00	2:58	0:58	MAIN SUPPLY FAILURE
449	16-Jul-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	2:00	2:58	0:58	MAIN SUPPLY FAILURE
450	16-Jul-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	2:00	3:10	1:10	MAIN SUPPLY FAILURE
451	16-Jul-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	2:00	2:58	0:58	MAIN SUPPLY FAILURE
452	16-Jul-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	2:00	2:58	0:58	MAIN SUPPLY FAILURE
453	16-Jul-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	2:00	2:58	0:58	MAIN SUPPLY FAILURE
454	16-Jul-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	2:00	2:58	0:58	MAIN SUPPLY FAILURE
455	16-Jul-20	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	2:00	2:58	0:58	MAIN SUPPLY FAILURE
456	16-Jul-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	2:00	2:58	0:58	MAIN SUPPLY FAILURE
457	16-Jul-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	2:00	2:58	0:58	MAIN SUPPLY FAILURE
458	16-Jul-20	BENGALURU	66	HV1	KOLAR 220	2:00	2:58	0:58	MAIN SUPPLY FAILURE
459	16-Jul-20	BENGALURU	66	HV2	KOLAR 220	2:00	2:58	0:58	MAIN SUPPLY FAILURE
460	16-Jul-20	BENGALURU	220	HV1	KOLAR 220	2:00	2:58	0:58	MAIN SUPPLY FAILURE
461	16-Jul-20	BENGALURU	220	HV2	KOLAR 220	2:00	2:58	0:58	MAIN SUPPLY FAILURE
462	16-Jul-20	BENGALURU	220	HV3	KOLAR 220	2:00	2:58	0:58	MAIN SUPPLY FAILURE
463	16-Jul-20	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	2:00	2:57	0:57	MAIN SUPPLY FAILURE
464	16-Jul-20	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	2:00	2:57	0:57	MAIN SUPPLY FAILURE
465	16-Jul-20	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	2:00	2:55	0:55	MAIN SUPPLY FAILURE
466	16-Jul-20	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	2:00	3:15	1:15	MAIN SUPPLY FAILURE
467	16-Jul-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	2:00	3:02	1:02	MAIN SUPPLY FAILURE
468	16-Jul-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	2:00	3:02	1:02	MAIN SUPPLY FAILURE
469	16-Jul-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	2:00	3:02	1:02	MAIN SUPPLY FAILURE
470	16-Jul-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	2:00	3:02	1:02	MAIN SUPPLY FAILURE
471	16-Jul-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	2:00	3:02	1:02	MAIN SUPPLY FAILURE
472	16-Jul-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	2:00	3:02	1:02	MAIN SUPPLY FAILURE

473	16-Jul-20	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	2:00	3:02	1:02	MAIN SUPPLY FAILURE
474	16-Jul-20	BENGALURU	220	HV1	MALUR 220	2:00	3:02	1:02	MAIN SUPPLY FAILURE
475	16-Jul-20	BENGALURU	220	HV2	MALUR 220	2:00	3:02	1:02	MAIN SUPPLY FAILURE
476	16-Jul-20	BENGALURU	220	HV1	SARJAPURA 220	2:00	3:24	1:24	MAIN SUPPLY FAILURE
477	16-Jul-20	BENGALURU	220	HV2	SARJAPURA 220	2:00	3:23	1:23	MAIN SUPPLY FAILURE
478	16-Jul-20	BENGALURU	66	HV1	DOMMASANDRA	3:40	3:50	0:10	LINE CLEAR AVAILED
479	16-Jul-20	BENGALURU	66	HV1	DALASNUR	9:25	9:55	0:30	LINE CLEAR AVAILED
480	16-Jul-20	BENGALURU	66	HV2	DALASNUR	15:25	15:40	0:15	LINE CLEAR AVAILED
481	16-Jul-20	BENGALURU	220	HV1	BEGUR 220	4:50	4:53	0:02	MAIN SUPPLY FAILURE
482	16-Jul-20	BENGALURU	220	HV2	BEGUR 220	4:51	4:53	0:01	MAIN SUPPLY FAILURE
483	16-Jul-20	BENGALURU	220	HV1	VIKAS TECH PARK 220	2:00	3:19	1:19	MAIN SUPPLY FAILURE
484	16-Jul-20	BENGALURU	220	HV2	VIKAS TECH PARK 220	2:00	3:19	1:19	MAIN SUPPLY FAILURE
485	16-Jul-20	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	2:00	3:25	1:25	MAIN SUPPLY FAILURE
486	16-Jul-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	2:00	3:25	1:25	MAIN SUPPLY FAILURE
487	16-Jul-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	2:00	3:26	1:26	MAIN SUPPLY FAILURE
488	16-Jul-20	BENGALURU	66	SADLI - JULLUPALYA	SADLI	21:52	21:54	0:02	LINE FAULT
489	16-Jul-20	BENGALURU	66	SADLI - JULLUPALYA	SADLI	19:40	19:50	0:10	LINE FAULT
490	16-Jul-20	BENGALURU	66	SADLI - JULLUPALYA	SADLI	21:15	21:30	0:15	LINE FAULT
491	16-Jul-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:06	14:20	0:13	LINE FAULT
492	16-Jul-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:26	21:38	0:12	LINE FAULT
493	16-Jul-20	BENGALURU	220	BEGUR 220 - HOODY 220	BEGUR 220, KIADB DEVANAHALLI PARK 220, HOSKOTE 220	2:00	2:11	0:11	LINE FAULT
494	16-Jul-20	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	6:12	6:18	0:06	LOAD CHANGEOVER
495	16-Jul-20	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	17:11	17:19	0:08	LOAD CHANGEOVER
496	16-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
497	16-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
498	16-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
499	16-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
500	16-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT

501	16-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
502	16-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
503	16-Jul-20	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	23:04(15.07.2020)	7:06(16.07.2020)	8:02HRS	LINE CHARGED
504	16-Jul-20	GULBARGA	220	SHAHAPUR-RTPS2	RTPS_220	23:20(15.07.2020)	5:12(16.07.2020)	5:52HRS	LINE CHARGED
505	16-Jul-20	GULBARGA	220	HV2	SHAHAPUR_220	23:04(15.07.2020)	6:37(16.7.2020)	10:33HRS	TRANSFORMER CHARGED
506	16-Jul-20	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHPUR_220	1:12	15:58	14:46	LINE FAULT
507	16-Jul-20	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	1:12	1:32	0:20	LINE FAULT
508	16-Jul-20	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	1:15	7:35	6:20	LINE CLEAR AVAILED
509	16-Jul-20	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	18:42	18:59	0:17	LINE FAULT
510	16-Jul-20	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	0:00	4:22	4:22	LINE FAULT
511	16-Jul-20	GULBARGA	220	HV1	KUSTAGI_220	0:00	10:45	10:45	TRANSFORMER FAULT
512	16-Jul-20	GULBARGA	220	HV2	KUSTAGI_220	0:00	1:31	1:31	TRANSFORMER FAULT
513	16-Jul-20	GULBARGA	220	HV2	KUSTAGI_220	10:45	10:59	0:14	TRANSFORMER FAULT
514	16-Jul-20	GULBARGA	110	KAPNOOR-HUMNABAD1	KAPNOOR_220	18:42(15.7.2020)	7:03(16.7.2020)	12:21HRS	LINE CHARGED
515	16-Jul-20	GULBARGA	110	HUMNABAD-SASTHAPUR	SASATHAPUR_110,RAJESHW AR_110,MANTHAL_110	8:20	12:25	4:05	LINE CLEAR AVAILED
516	16-Jul-20	GULBARGA	110	KUSHTAGI-HANUMANAL	HANUMANAL_110	10:50	11:10	0:20	MAIN SUPPLY FAILURE
517	16-Jul-20	GULBARGA	110	KUSHTAGI-HANUMANAL	HANUMANAL_110	21:05	21:45	0:40	MAIN SUPPLY FAILURE
518	16-Jul-20	GULBARGA	110	KUSHTAGI-HANUMANAL	HANUMANAL_110	0:00	2:30	2:30	MAIN SUPPLY FAILURE
519	16-Jul-20	GULBARGA	110	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66,HAMPAS AGAR_66,MORAGERE_66	16:20	16:30	0:10	MAIN SUPPLY FAILURE
520	16-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	1:43	2:42	0:59	MAIN SUPPLY FAILURE
521	16-Jul-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	9:21	9:30	0:09	MAIN SUPPLY FAILURE
522	16-Jul-20	GULBARGA	110	HV1	SHAHAPUR_220	13:52	21:50	7:58	LINE CLEAR AVAILED
523	16-Jul-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:32	21:42	0:10	MAIN SUPPLY FAILURE
524	16-Jul-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:10	23:17	0:07	MAIN SUPPLY FAILURE
525	16-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	22:50	23:01	0:11	MAIN SUPPLY FAILURE
526	16-Jul-20	HASSAN	110	HV3	HIRIYADKA_110	10:29(03.07.2020)	23:15 (16.07.2020)	324:45 hrs	LINE CHARGED
527	16-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:37 (15.07.2020)	7:37 (16.07.2020)	7:59 hrs	LINE CHARGED
528	16-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHANTHIGRAMA_400	22:56 (14.07.2020)	16:59 (16.07.2020)	42:02 hrs	LINE CHARGED
529	16-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:56 (14.07.2020)	16:59 (16.07.2020)	42:02 hrs	LINE CHARGED
530	16-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:55 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
531	16-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:30 (16.07.2020)			LINE OPEN: LINE CLEAR AVAILED
532	16-Jul-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	16:05 (16.07.2020)			LINE OPEN: LINE CLEAR AVAILED
533	16-Jul-20	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:32 (16.07.2020)			LINE OPEN: LINE FAULT
534	16-Jul-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:17	19:04	1:47	MAIN SUPPLY FAILURE
535	16-Jul-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:17	20:13	2:56	MAIN SUPPLY FAILURE
536	16-Jul-20	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:17	19:05	1:48	MAIN SUPPLY FAILURE

537	16-Jul-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:16	19:02	1:46	LINE FAULT
538	16-Jul-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:16	20:13	2:57	LINE FAULT
539	16-Jul-20	HASSAN	110	HV1	KULASHEKARA_110	13:28	14:43	1:15	LINE CLEAR AVAILED
540	16-Jul-20	HASSAN	110	HV1	KULASHEKARA_110	15:12	18:22	3:10	TRANSFORMER FAULT
541	16-Jul-20	HASSAN	110	HV2	MOODABIDRE_110	17:32	18:29	0:57	MAIN SUPPLY FAILURE
542	16-Jul-20	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	17:32	18:27	0:55	MAIN SUPPLY FAILURE
543	16-Jul-20	HASSAN	110	HV1	SINGATGERE_66	10:58	16:03	5:05	LINE CLEAR AVAILED
544	16-Jul-20	HASSAN	110	SINGATG-YAGATI	SINGATGERE_66	10:58	16:03	5:05	LINE CLEAR AVAILED
545	16-Jul-20	HASSAN	110	HV2	HIRIYADKA_110	17:28	17:35	0:07	TRANSFORMER FAULT
546	16-Jul-20	MYSURU	66	HV2	BOMMALAPURA_66	11:15	13:15	1:59	LINE CLEAR AVAILED
547	16-Jul-20	MYSURU	66	HV2	FTS_66	11:12	17:38	6:25	LINE CLEAR AVAILED
548	16-Jul-20	MYSURU	66	HV1	HALAGUR_66	11:33	12:29	0:55	LINE CLEAR AVAILED
549	16-Jul-20	MYSURU	66	HV1	KIADBMANDYA_66	10:04	10:17	0:12	TRANSFORMER FAULT
550	16-Jul-20	MYSURU	66	HV2	MADHUVANAHALLI_220	13:14	13:53	0:39	HAND TRIPPED
551	16-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
552	16-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN: LINE FAULT
553	16-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
554	16-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
555	16-Jul-20	TUMKUR	110	TR-1	TURUVEKERE_110	2:09	2:19	0:10	TRANSFORMER FAULT
556	16-Jul-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	17:35	17:53	0:17	LINE CLEAR AVAILED
557	16-Jul-20	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	14:34	16:12	1:38	LINE FAULT
558	16-Jul-20	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	6:08	6:34	0:26	LINE FAULT
559	16-Jul-20	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	12:18	15:05	2:47	LINE CLEAR AVAILED
560	16-Jul-20	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	13:05	13:45	0:39	LINE CLEAR AVAILED
561	16-Jul-20	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	14:47	14:51	0:04	LINE CLEAR AVAILED
562	16-Jul-20	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	13:05	13:48	0:43	LINE CLEAR AVAILED
563	16-Jul-20	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	14:47	14:56	0:08	LINE CLEAR AVAILED
564	16-Jul-20	TUMKUR	66	TR-2	HOLALKERE_66	15:45	15:51	0:05	TRANSFORMER FAULT
565	16-Jul-20	TUMKUR	66	HULIYURDURGA-DUNDANAHALLI	DUNDANAHALLI_66	16:28	17:32	1:04	LINE FAULT
566	16-Jul-20	TUMKUR	66	TR-2	LINGDHALLI_66	16:09	16:17	0:07	LINE CLEAR AVAILED

567	16-Jul-20	TUMKUR	66	TR-2	MATHOD_66	11:05	11:15	0:09	TRANSFORMER FAULT
568	16-Jul-20	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_66	2:43	2:52	0:08	LINE FAULT
569	16-Jul-20	TUMKUR	66	NEELAGUNDA 220KV-PUNABHAGHATTA	PUNABHAGHATTA_66,UCHC HANGIDURGA_66,PALLAGATTE_66, SOKKE_66	12:48	14:29	1:41	LINE CLEAR AVAILED
570	16-Jul-20	TUMKUR	66	NEELAGUNDA220KV-HARPANAHALLI-1	HARAPPANAHALLI_66	18:38	18:47	0:08	LINE FAULT
571	16-Jul-20	TUMKUR	66	TR-1	PANDARAHALLI_66	12:59	13:02	0:02	TRANSFORMER FAULT
572	16-Jul-20	TUMKUR	66	TR-1	PANDARAHALLI_66	16:32	17:33	1:01	LINE CLEAR AVAILED
573	16-Jul-20	TUMKUR	66	TR-1	PUNABHAGHATTA_66	14:44	15:51	1:06	LINE CLEAR AVAILED
574	16-Jul-20	TUMKUR	66	PULAMGHATTA66- MADHUGIRI 220KV	PULAMG_66	15:44	15:51	0:06	LINE CLEAR AVAILED
575	16-Jul-20	TUMKUR	66	RANGENAHALLI-DYVARANAHALLI	RANGENAHALLI_66	8:46	17:52	9:06	HAND TRIPPED
576	16-Jul-20	TUMKUR	66	TR-2	RANGANATHAPURA_66	17:16	18:37	1:20	LINE CLEAR AVAILED
577	16-Jul-20	TUMKUR	66	TR-1	SASALUHALLA_66	16:56	17:19	0:22	LINE CLEAR AVAILED
578	16-Jul-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	17:27	18:20	0:52	HAND TRIPPED
579	16-Jul-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	6:34	6:49	0:15	HAND TRIPPED
580	16-Jul-20	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	6:34	6:49	0:15	HAND TRIPPED
581	17-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
582	17-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
583	17-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
584	17-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
585	17-Jul-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
586	17-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
587	17-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
588	17-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
589	17-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
590	17-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
591	17-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT

592	17-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	8:57 (08.07.2020)			LINE OPEN: LINE CLEAR AVAILED
593	17-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED SAVANUR-110	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
594	17-Jul-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
595	17-Jul-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
596	17-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN: LINE FAULT
597	17-Jul-20	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59 (15.07.2020)			LOAD CURTAILMENT
598	17-Jul-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT
599	17-Jul-20	BAGALKOT	220	SHARAVTHI2-SIRSI	SIRSI_220	16:09 (16.07.2020)	16:54 (17.07.2020)	24:45hrs	LINE CHARGED
600	17-Jul-20	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	10:55	17:45	6:50hrs	LINE CLEAR AVAILED
601	17-Jul-20	BAGALKOT	110	110/11KV,HV2	BIDNAL_220	11:34	16:00	4:26	LINE CLEAR AVAILED
602	17-Jul-20	BAGALKOT	220	KAVATAGI LIS-VAJRAMATTI	VAJRAMATTI_220	6:11	6:41	0:30	LINE FAULT
603	17-Jul-20	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	0:34	0:54	0:20	TRANSFORMER FAULT
604	17-Jul-20	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	2:04	7:42	5:38	TRANSFORMER FAULT
605	17-Jul-20	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	7:46	12:25	4:39	LINE CLEAR AVAILED
606	17-Jul-20	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED GUTTAL_110	15:44 (17.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
607	17-Jul-20	BAGALKOT	110	BORUKA(BPCL)-ITNAL	ITNAL_110	6:14	6:29	0:15	LINE FAULT
608	17-Jul-20	BAGALKOT	110	JUMBAGI-MUDHOL	STATION NOT AFFECTED MUDHOL_110	12:08 (17.07.2020)			LINE OPEN: LINE FAULT
609	17-Jul-20	BAGALKOT	110	110/11KV,HV1	MALLIGERI_110	11:01	15:00	3:59	LINE CLEAR AVAILED
610	17-Jul-20	BAGALKOT	110	110/11KV,HV1	MALLIGERI_110	15:10	15:20	0:10	TRANSFORMER FAULT
611	17-Jul-20	BAGALKOT	110	110/11KV,HV1	MALLIGERI_110	15:45	16:20	0:35	TRANSFORMER FAULT
612	17-Jul-20	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	2:08	2:21	0:13	LINE FAULT
613	17-Jul-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:40	13:43	1:03	LINE CLEAR AVAILED
614	17-Jul-20	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	11:21	12:44	1:23	LINE CLEAR AVAILED
615	17-Jul-20	BAGALKOT	110	NAREGAL- RON	NAREGAL_110	16:35	16:46	0:11	HAND TRIPPED
616	17-Jul-20	BAGALKOT	110	110/11KV, HV1	MUNDARGI_110	11:10	12:21	1:11	LINE CLEAR AVAILED
617	17-Jul-20	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	5:49	6:30	0:41	LINE FAULT
618	17-Jul-20	BAGALKOT	110	MAHALINGAPUR(HALKI)- MUDHOL	MUDHOL_110	15:55	18:19	2:24	LINE CLEAR AVAILED
619	17-Jul-20	BENGALURU	66	HV2	AUSTIN TOWN	13:14	13:30	0:16	TRANSFORMER FAULT
620	17-Jul-20	BENGALURU	66	HV2	BIEC	12:01	13:20	1:19	LINE CLEAR AVAILED
621	17-Jul-20	BENGALURU	66	HV2	HANUMANTHNAGARA	8:01	8:28	0:27	TRANSFORMER FAULT
622	17-Jul-20	BENGALURU	66	HV1	HANUMANTHNAGARA	8:01	8:23	0:22	TRANSFORMER FAULT

623	17-Jul-20	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	13:35	13:40	0:05	LOAD CHANGEOVER
624	17-Jul-20	BENGALURU	220	NRS 220 - VRISHABHAVATHI 220	NO STATION AFFECTED	16:40	19:45	3:05	LINE FAULT
625	17-Jul-20	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL	12:45	13:05	0:20	LOAD CHANGEOVER
626	17-Jul-20	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	10:23	11:37	1:13	LINE CLEAR AVOID
627	17-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
628	17-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
629	17-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
630	17-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
631	17-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT
632	17-Jul-20	GULBARGA	400	BTPSG-RTPS	BTPSG_400	5:07	13:18	8:11	LINE FAULT
633	17-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
634	17-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVALIED
635	17-Jul-20	GULBARGA	220	ITTAGI-NEELGUND	NEELGUNDA_220	14:12	17:10	2:58	HAND TRIPPED
636	17-Jul-20	GULBARGA	220	HV2	KUSTAGI_220	0:00	8:05	8:05	TRANSFORMER FAULT
637	17-Jul-20	GULBARGA	220	HV2	KUSTAGI_220	11:25	11:38	0:13	TRANSFORMER FAULT
638	17-Jul-20	GULBARGA	220	BMMISPAT-ITTAGI	ITTAGI_220	8:40	13:40	5:00	LINE CLEAR AVOID
639	17-Jul-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.07.2020)			LINE OPEN: LINE FAULT
640	17-Jul-20	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	11:29	12:10	0:41	LINE FAULT
641	17-Jul-20	GULBARGA	110	HANUMANAL-KUSHTAGI	HANUMANAL_110	11:30	12:10	0:40	MAIN SUPPLY FAILURE
642	17-Jul-20	GULBARGA	110	HV1	SHAHAPUR_220	19:04	19:51	0:47	TRANSFORMER FAULT
643	17-Jul-20	GULBARGA	110	SIDHANOOR-NIRLOOTI	NIRLOOTI_110	3:45	4:05	0:20	LINE CLEAR AVOID
644	17-Jul-20	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_11 0,BTPSWATERWORKS	19:26	22:40	3:14	LINE CLEAR AVOID
645	17-Jul-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:25	19:35	0:10	LINE FAULT
646	17-Jul-20	GULBARGA	110	GURUMITKAL-SEDAM	GURUMITAKAL_110,KONKAL _110	5:45	5:50	0:05	LINE FAULT
647	17-Jul-20	GULBARGA	110	GURUMITKAL-SEDAM	GURUMITAKAL_110,KONKAL _110	20:35	20:40	0:05	LINE FAULT
648	17-Jul-20	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66,UJJAINI_66	19:13	19:15	0:02	MAIN SUPPLY FAILURE
649	17-Jul-20	GULBARGA	66	ITTAGI-RENEWSOLAR1,2	ITTAGI_220	11:25	11:35	0:10	LINE FAULT
650	17-Jul-20	GULBARGA	66	ITTAGI-RENEWSOLAR1,2	ITTAGI_220	11:42	11:52	0:10	LINE FAULT
651	17-Jul-20	GULBARGA	66	TAMBRAHALLI-ITTAGGI	TAMBRAHALLI_66	10:40	11:10	0:30	MAIN SUPPLY FAILURE
652	17-Jul-20	GULBARGA	66	HV3	ITTAGI_220	14:10	14:20	0:10	TRANSFORMER FAULT
653	17-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:30 (16.07.2020)	6:39 (17.07.2020)	8:08 hrs	LINE CHARGED
654	17-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:55 (15.07.2020)	6:41 (17.07.2020)	32:45 hrs	LINE CHARGED
655	17-Jul-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	16:05 (16.07.2020)	16:54 (17.07.2020)	24:48 hrs	LINE CHARGED
656	17-Jul-20	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:32 (16.07.2020)			LINE OPEN: LINE FAULT

657	17-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:07 (17.07.2020)			LINE OPEN: LINE CLEAR AVAILED
658	17-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:53 (17.07.2020)			LINE OPEN: LINE CLEAR AVAILED
659	17-Jul-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	4:32	17:15	12:43	LINE FAULT
660	17-Jul-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	4:32	17:18	12:46	LINE FAULT
661	17-Jul-20	HASSAN	110	HV1	KEMAR_220	16:21	17:05	0:44	LINE CLEAR AVAILED
662	17-Jul-20	HASSAN	110	HV2	KEMAR_220	16:14	16:45	0:31	LINE CLEAR AVAILED
663	17-Jul-20	HASSAN	110	HV2	NANDIKUR_110	12:43	12:48	0:05	LINE CLEAR AVAILED
664	17-Jul-20	HASSAN	66	HV1	BALEHONNUR_66	19:56	20:15	0:19	TRANSFORMER FAULT
665	17-Jul-20	HASSAN	66	HV2	BALEHONNUR_66	19:56	20:11	0:15	TRANSFORMER FAULT
666	17-Jul-20	HASSAN	66	HV2	BALEHONNUR_66	21:05	21:12	0:07	TRANSFORMER FAULT
667	17-Jul-20	HASSAN	66	HV3	BALEHONNUR_66	19:56	20:33	0:37	TRANSFORMER FAULT
668	17-Jul-20	HASSAN	66	HV2	MALLAPURA_66	13:01	16:32	3:31	LINE CLEAR AVAILED
669	17-Jul-20	MYSURU	66	HV2	BOMMALAPURA_66	13:21	14:59	1:38	LINE CLEAR AVAILED
670	17-Jul-20	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	18:32	18:47	0:15	LINE FAULT
671	17-Jul-20	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	18:32	18:46	0:13	LINE FAULT
672	17-Jul-20	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	5:02	6:39	1:37	LINE FAULT
673	17-Jul-20	MYSURU	220	KADAKOLA-CR NAGARA 2	NO STATIONS EFFECTED	5:02	6:41	1:39	LINE FAULT
674	17-Jul-20	MYSURU	220	HV2	KADAKOLA_220	5:02	6:41	1:39	TRANSFORMER FAULT
675	17-Jul-20	MYSURU	66	HV1	KOLLEGALA_66	11:21	12:12	0:50	LINE CLEAR AVAILED
676	17-Jul-20	MYSURU	66	HV2	KOLLEGALA_66	12:15	13:18	1:03	LINE CLEAR AVAILED
677	17-Jul-20	MYSURU	66	HV2	PANDAVAPURA_66	11:28	16:40	5:11	LINE CLEAR AVAILED
678	17-Jul-20	MYSURU	66	HV2	VIJAYANAGRAMYS_66	11:22	13:26	2:04	LINE CLEAR AVAILED
679	17-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
680	17-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN: LINE FAULT
681	17-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
682	17-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
683	17-Jul-20	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	10:41	11:03	0:22	LINE FAULT
684	17-Jul-20	TUMKUR	220	NEELAGUNDA220kv- GINFRA_WIND	GINFRA_WIND_IPP_66	12:02	12:32	0:29	LINE CLEAR AVAILED
685	17-Jul-20	TUMKUR	220	NEELAGUNDA220kv- ITTAGI 220kv	NEELAGUNDA_220	10:56	11:06	0:10	LINE CLEAR AVAILED

686	17-Jul-20	TUMKUR	220	NEELAGUNDA220kv- ITTAGI 220kv	NEELAGUNDA_220	14:14	17:10	2:56	LINE CLEAR AVAILED
687	17-Jul-20	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	14:53	15:04	0:11	LINE FAULT
688	17-Jul-20	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	8:15	8:17	0:02	TRANSFORMER FAULT
689	17-Jul-20	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	9:40	9:43	0:02	TRANSFORMER FAULT
690	17-Jul-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	16:03	16:35	0:31	LINE CLEAR AVAILED
691	17-Jul-20	TUMKUR	66	TR-2	KUNIGAL_66	17:05	19:02	1:56	LINE CLEAR AVAILED
692	17-Jul-20	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	15:16	16:03	0:47	LINE CLEAR AVAILED
693	17-Jul-20	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	10:54	11:05	0:10	LINE CLEAR AVAILED
694	17-Jul-20	TUMKUR	66	NEELAGUNDA220kv- HARAPANAHALLI-1	HARAPPANAHALLI_66	10:57	11:09	0:12	HAND TRIPPED
695	17-Jul-20	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	10:41	11:10	0:29	HAND TRIPPED
696	17-Jul-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHC HANGIDURGA_66,PALLAGAT TE_66, SOKKE_66	10:57	11:09	0:12	HAND TRIPPED
697	17-Jul-20	TUMKUR	66	NEELAGUNDA 220kv-TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	10:57	11:09	0:12	HAND TRIPPED
698	17-Jul-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:51	17:27	9:36	HAND TRIPPED
699	17-Jul-20	TUMKUR	66	RANGANATHAPURA- WLSPTSOLAR1	RANGANATHAPURA_66	17:07	19:06	1:59	LINE CLEAR AVAILED
700	17-Jul-20	TUMKUR	66	RANGANATHAPURA- WLSPTSOLAR2	RANGANATHAPURA_66	17:07	19:06	1:59	LINE CLEAR AVAILED
701	17-Jul-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	6:23	9:18	2:54	LINE CLEAR AVAILED
702	17-Jul-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	17:08	18:56	1:48	LINE CLEAR AVAILED
703	17-Jul-20	TUMKUR	66	TR-2	RANGANATHAPURA_66	10:40	10:43	0:02	LINE CLEAR AVAILED
704	17-Jul-20	TUMKUR	66	TR-2	RANGANATHAPURA_66	17:07	18:57	1:49	LINE CLEAR AVAILED
705	17-Jul-20	TUMKUR	66	TR-1	SHYLAPURA_66	8:59	9:04	0:05	TRANSFORMER FAULT
706	17-Jul-20	TUMKUR	66	TR-1	YEDIYUR_66	13:17	14:01	0:43	LINE CLEAR AVAILED
707	17-Jul-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	13:31	18:48	5:16	LINE CLEAR AVAILED
708	18-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
709	18-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
710	18-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
711	18-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED

712	18-Jul-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
713	18-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
714	18-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
715	18-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
716	18-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
717	18-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
718	18-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
719	18-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	8:57 (08.07.2020)			LINE OPEN: LINE CLEAR AVAILED
720	18-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
721	18-Jul-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
722	18-Jul-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
723	18-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN: LINE FAULT
724	18-Jul-20	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59 (15.07.2020)			LOAD CURTAILMENT
725	18-Jul-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT
726	18-Jul-20	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED GUTTAL_110	15:44 (17.07.2020)	18:13 (18.07.2020)	26:29hrs	LINE CHARGED
727	18-Jul-20	BAGALKOT	110	JUMBAGI-MUDHOL	STATION NOT AFFECTED MUDHOL_110	12:08 (17.07.2020)			LINE OPEN: LINE FAULT
728	18-Jul-20	BAGALKOT	110	110/11KV,HV1	ATHANI_220	15:51	18:34	2:43	TRANSFORMER FAULT
729	18-Jul-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	3:27	3:45	0:18	LINE FAULT
730	18-Jul-20	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	16:30	19:47	3:17	LINE CLEAR AVAILED
731	18-Jul-20	BAGALKOT	110	110/11KV,HV3	GOKAK_110,KOLAVI SUGAR_33,RIDDISIDDI_33	13:11	14:21	1:10	LINE CLEAR AVAILED
732	18-Jul-20	BAGALKOT	110	HAVERI 1-GUTTAL	GUTTAL_110	17:17 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
733	18-Jul-20	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	15:12	16:00	0:48	LINE CLEAR AVAILED
734	18-Jul-20	BAGALKOT	110	110/11KV,HV1	MALLIGERI_110	12:53	17:38	4:45	LINE CLEAR AVAILED
735	18-Jul-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:01	7:59	7:58	HAND TRIPPED
736	18-Jul-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	15:21	15:49	0:28	LINE CLEAR AVAILED
737	18-Jul-20	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	10:47	11:48	1:01	LINE FAULT

738	18-Jul-20	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	8:51	17:00	8:09	LINE CLEAR AVAILED
739	18-Jul-20	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	18:55	20:30	1:35	LINE FAULT
740	18-Jul-20	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	7:45	8:28	0:43	LINE FAULT
741	18-Jul-20	BENGALURU	66	JAYADEVA - ADUGODI	NO STATION AFFECTED	18:39	21:11	2:32	LINE FAULT
742	18-Jul-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	11:30	11:33	0:03	LOAD CHANGEOVER
743	18-Jul-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	12:10	12:13	0:03	LOAD CHANGEOVER
744	18-Jul-20	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	11:15	12:32	1:17	LINE CLEAR AVAILED
745	18-Jul-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:40	19:52	4:12	LINE CLEAR AVAILED
746	18-Jul-20	BENGALURU	66	DEVANAHALLI - DB PURA 2	DEVANAHALLI	6:17	6:38	0:20	LINE FAULT
747	18-Jul-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	6:17	6:36	0:18	LINE FAULT
748	18-Jul-20	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	17:00	17:06	0:06	LOAD CHANGEOVER
749	18-Jul-20	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	18:12	18:23	0:11	LINE FAULT
750	18-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
751	18-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
752	18-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
753	18-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
754	18-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT
755	18-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
756	18-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
757	18-Jul-20	GULBARGA	220	HV1	KUSTAGI_220	16:26	19:30	3:04	LINE CLEAR AVAILED
758	18-Jul-20	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	18:27	18:40	0:13	LINE FAULT
759	18-Jul-20	GULBARGA	220	MALLAT-RTPS	MALLAT_220	18:23	18:40	0:17	LINE FAULT
760	18-Jul-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.7.2020)			LINE OPEN: LINE FAULT
761	18-Jul-20	GULBARGA	110	KUSTAGI-HANUMSAGAR	HANUMSAGAR_110	13:30	19:30	6:00	LINE CLEAR AVAILED
762	18-Jul-20	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	2:18	2:30	0:12	LINE FAULT
763	18-Jul-20	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	2:30	8:40	6:10	LINE CLEAR AVAILED
764	18-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP,HUNASAGI_110,ASKI_110	5:20	5:27	0:07	LINE FAULT
765	18-Jul-20	GULBARGA	110	HV2	SHAHAPUR_220	15:00	15:30	0:30	TRANSFORMER FAULT
766	18-Jul-20	GULBARGA	110	KEMBHAVI-UGAR SUGAR_IPP	UGAR SUGAR_IPP	20:11	22:42	2:31	LINE FAULT
767	18-Jul-20	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110	4:35	6:20	1:45	LINE FAULT

768	18-Jul-20	GULBARGA	110	HV2	KEMBHAVI_110	16:18	16:42	0:24	TRANSFORMER FAULT
769	18-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_ 110	20:12	20:22	0:10	LINE FAULT
770	18-Jul-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDIN NI_110	4:40	4:50	0:10	LINE FAULT
771	18-Jul-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDIN NI_110	5:24	5:33	0:09	LINE FAULT
772	18-Jul-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	21:15	21:25	0:10	LINE FAULT
773	18-Jul-20	GULBARGA	110	SIDHANOOR-NIRLOOTI	NIRLOOTI_110	0:40	0:50	0:10	LINE FAULT
774	18-Jul-20	GULBARGA	110	HV2	BISIHALLI_110	22:12	22:26	0:14	TRANSFORMER FAULT
775	18-Jul-20	GULBARGA	66	CJHALLI-KUDLIGI	CJHALLI_66,HOSAHALLI_66	11:55	12:30	0:35	MAIN SUPPLY FAILURE
776	18-Jul-20	HASSAN	110	MOODAB-SOHAM2	NO STN AFFECTED	17:32 (16.07.2020)			LINE OPEN: LINE CLEAR AVAILED
777	18-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:07 (17.07.2020)	8:40 (18.07.2020)	9:32 hrs	LINE CHARGED
778	18-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:14 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
779	18-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:53 (17.07.2020)	7:18 (18.07.2020)	10:24 hrs	LINE CHARGED
780	18-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:06 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
781	18-Jul-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:09	12:41	2:32	LINE CLEAR AVOIDED
782	18-Jul-20	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	11:12	12:14	1:02	LINE CLEAR AVOIDED
783	18-Jul-20	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	11:22	11:35	0:13	HAND TRIPPED
784	18-Jul-20	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	12:08	12:14	0:06	HAND TRIPPED
785	18-Jul-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	21:50	22:06	0:16	LINE FAULT
786	18-Jul-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:09	12:41	2:32	NFBC ISSUED
787	18-Jul-20	HASSAN	110	HV1	KULASHEKARA_110	1:53	7:01	5:08	LINE CLEAR AVOIDED
788	18-Jul-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	1:54	2:01	0:07	LOAD CHANGE OVER
789	18-Jul-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	12:55	13:00	0:05	LOAD CHANGE OVER
790	18-Jul-20	HASSAN	110	HV2	SORABA_110	11:10	12:07	0:57	LINE CLEAR AVOIDED
791	18-Jul-20	MYSURU	66	HV2	COWDALLI_66	16:14	16:51	0:37	TRANSFORMER FAULT
792	18-Jul-20	MYSURU	66	HOOTAGALLI-BARC 1	NO STATIONS EFFECTED	1:21	1:26	0:05	LINE FAULT
793	18-Jul-20	MYSURU	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66,JAIPUR_66	6:11	6:16	0:05	LINE FAULT
794	18-Jul-20	MYSURU	220	KADAKOLA-CR NAGAR 1	NO STATIONS EFFECTED	12:11	13:37	1:25	NFBC ISSUED
795	18-Jul-20	MYSURU	220	KADAKOLA-CR NAGAR 2	NO STATIONS EFFECTED	10:33	12:10	1:36	NFBC ISSUED
796	18-Jul-20	MYSURU	66	HV4	KUSHALNAGARA_220	12:02	12:27	0:24	LINE CLEAR AVOIDED
797	18-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
798	18-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN: LINE FAULT

799	18-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
800	18-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
801	18-Jul-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	16:16(18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
802	18-Jul-20	TUMKUR	110	HONNAVALI 110- KADUR	HONNAVALI_110	16:26	16:34	0:07	LOAD CHANGEOVER
803	18-Jul-20	TUMKUR	110	TR-1	SAMPIGE_110	16:08	16:29	0:21	LINE CLEAR AVAILED
804	18-Jul-20	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	7:39	7:50	0:10	LINE FAULT
805	18-Jul-20	TUMKUR	66	TR-2	BAGUR_TM_66	16:14	16:16	0:02	TRANSFORMER FAULT
806	18-Jul-20	TUMKUR	66	TR-1	KORA_66	0:51	0:55	0:03	TRANSFORMER FAULT
807	18-Jul-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGI RI_66, BASAVAPATNA_66	6:36	6:45	0:09	LINE FAULT
808	18-Jul-20	TUMKUR	66	TR-1	NEELAGUNDA_220	17:48	17:53	0:05	TRANSFORMER FAULT
809	18-Jul-20	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	19:00	19:25	0:24	LINE FAULT
810	18-Jul-20	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	19:00	19:08	0:07	LINE FAULT
811	18-Jul-20	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	PALLAGATTE_66,SOKKE_66,	18:59	19:28	0:28	MAIN SUPPLY FAILURE
812	19-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
813	19-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
814	19-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
815	19-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
816	19-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
817	19-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
818	19-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
819	19-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
820	19-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
821	19-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
822	19-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT

823	19-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	8:57 (08.07.2020)			LINE OPEN: LINE CLEAR AVAILED
824	19-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
825	19-Jul-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
826	19-Jul-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
827	19-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN: LINE FAULT
828	19-Jul-20	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59 (15.07.2020)			LOAD CURTAILMENT
829	19-Jul-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT
830	19-Jul-20	BAGALKOT	110	JUMBAGI-MUDHOL	STATION NOT AFFECTED MUDHOL_110	12:08 (17.07.2020)			LINE OPEN: LINE FAULT
831	19-Jul-20	BAGALKOT	110	HAVERI 1-GUTTAL	STATION NOT AFFECTED GUTTAL_110	17:17 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
832	19-Jul-20	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	20:30	20:42	0:12	LINE FAULT
833	19-Jul-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN: LINE CLEAR AVAILED
834	19-Jul-20	BAGALKOT	110	110/33KV,HV1	GOKAK_110	11:03	11:59	0:56	LINE CLEAR AVAILED
835	19-Jul-20	BAGALKOT	220	HAVERI-NARENDRA1	HAVERI_220	10:17	15:53	5:36	LINE FAULT
836	19-Jul-20	BAGALKOT	110	110/11KV,HV4	KERUR_110	8:08	8:46	0:38	HAND TRIPPED
837	19-Jul-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:03	8:20	7:17	HAND TRIPPED
838	19-Jul-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	18:02 (19.07.2020)			LINE OPEN: LINE CLEAR AVAILED
839	19-Jul-20	BAGALKOT	220	MK HULI-NARENDRA1	MK HUBLI_220	12:14	13:36	1:22	LINE FAULT
840	19-Jul-20	BAGALKOT	110	110/11KV,HV1(HV2)	MUDDEBIHAL_110	0:11	0:23	0:12	TRANSFORMER FAULT
841	19-Jul-20	BAGALKOT	110	110/11KV,HV1(HV2)	MUDDEBIHAL_110	0:25	1:17	0:52	TRANSFORMER FAULT
842	19-Jul-20	BAGALKOT	66	HONNALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN: LINE CLEAR AVAILED
843	19-Jul-20	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	14:18	15:11	0:53	LINE FAULT
844	19-Jul-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	6:58	7:09	0:10	LINE FAULT
845	19-Jul-20	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	8:16	8:38	0:21	LINE FAULT
846	19-Jul-20	BENGALURU	66	HV1	SIDDALAGATTA	11:55	12:06	0:11	TRANSFORMER FAULT
847	19-Jul-20	BENGALURU	66	HV3	HOSKOTE 66	19:13	19:26	0:13	TRANSFORMER FAULT
848	19-Jul-20	BENGALURU	66	HV1	KOLAR 220	8:12	13:26	5:13	LINE CLEAR AVAILED
849	19-Jul-20	BENGALURU	66	HV2	KOLAR 220	8:12	13:08	4:56	LINE CLEAR AVAILED
850	19-Jul-20	BENGALURU	66	HEBBAL 220 - IISC	IISC	16:09	16:44	0:35	LINE FAULT
851	19-Jul-20	BENGALURU	66	HV1	IISc	16:44	16:49	0:05	LINE CLEAR AVAILED
852	19-Jul-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:15	11:20	0:05	LOAD CHANGEOVER

853	19-Jul-20	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	14:23	14:28	0:05	LOAD CHANGEOVER
854	19-Jul-20	BENGALURU	66	SRIGANDADA KAVALU - BYDRAHALLI	SRIGANDADA KAVALU	11:20	11:23	0:03	MAIN SUPPLY FAILURE
855	19-Jul-20	BENGALURU	66	SRIGANDADA KAVALU - BYDRAHALLI	SRIGANDADA KAVALU	13:47	13:48	0:01	MAIN SUPPLY FAILURE
856	19-Jul-20	BENGALURU	66	HEBBAL 220 - IISC	NO STATION AFFECTED	16:09(19-07-2020)			LINE OPEN: LINE FAULT
857	19-Jul-20	BENGALURU	66	HV1	IISc	16:44(19-07-2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
858	19-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
859	19-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
860	19-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
861	19-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
862	19-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT
863	19-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
864	19-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
865	19-Jul-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	18:09(19.7.2020)			LINE OPEN: LINE CLEAR AVAILED
866	19-Jul-20	GULBARGA	220	HV1	KUSTAGI_220	11:30	11:50	0:20	TRANSFORMER FAULT
867	19-Jul-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	16:36	18:09	1:33	LINE FAULT
868	19-Jul-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.7.2020)			LINE OPEN: LINE FAULT
869	19-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	0:05	0:15	0:10	LINE FAULT
870	19-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	1:28	1:36	0:08	LINE FAULT
871	19-Jul-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,KAMAL APUR_110,SHATAVAHANA_I PP,AGRAWAL IPP	4:30	4:44	0:14	LINE FAULT
872	19-Jul-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:46	4:59	0:13	LINE FAULT
873	19-Jul-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	8:00	8:24	0:24	LINE FAULT
874	19-Jul-20	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWATERWORKS	23:40	23:50	0:10	LINE FAULT
875	19-Jul-20	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110	8:35	9:00	0:25	MAIN SUPPLY FAILURE
876	19-Jul-20	GULBARGA	110	HV2	DEODURGA_110	15:34	15:44	0:10	TRANSFORMER FAULT
877	19-Jul-20	GULBARGA	110	HV2	BELLARYSOUTH_110	11:38	12:42	1:04	LINE CLEAR AVAILED
878	19-Jul-20	HASSAN	110	MOODAB-SOHAM2	NO STN AFFECTED	17:32 (16.07.2020)			LINE OPEN: LINE CLEAR AVAILED
879	19-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	NO STN AFFECTED	23:14 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED

880	19-Jul-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:06 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
881	19-Jul-20	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	11:02	15:07	4:05	LINE FAULT
882	19-Jul-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:11	19:07	5:56	LINE FAULT
883	19-Jul-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:48	12:06	1:18	LINE FAULT
884	19-Jul-20	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:18	11:55	0:37	LINE FAULT
885	19-Jul-20	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	10:48	12:06	1:18	LINE FAULT
886	19-Jul-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	13:11	19:08	5:57	LINE FAULT
887	19-Jul-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:48	11:01	0:13	LINE FAULT
888	19-Jul-20	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	16:52	17:41	0:49	LINE CLEAR AVAILED
889	19-Jul-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	15:51	16:09	0:18	LINE FAULT
890	19-Jul-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	15:56	16:23	0:27	MAIN SUPPLY FAILURE
891	19-Jul-20	HASSAN	66	MALALI-HASSAN	MALALI_66	16:08	16:12	0:04	MAIN SUPPLY FAILURE
892	19-Jul-20	HASSAN	66	HV1	MALALI_66	15:52	16:19	0:27	MAIN SUPPLY FAILURE
893	19-Jul-20	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	10:16	10:29	0:13	LINE FAULT
894	19-Jul-20	MYSURU	66	BOGADHI-HOOTAGALLI	NO STATIONS EFFECTED	17:45	21:17	3:31	HAND TRIPPED
895	19-Jul-20	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	6:07	6:21	0:14	LINE FAULT
896	19-Jul-20	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	6:07	6:20	0:13	LINE FAULT
897	19-Jul-20	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	14:14	14:41	0:27	LINE FAULT
898	19-Jul-20	MYSURU	66	CR NAGARA-PANYADHUNDI	PANDYADAHUNDI_66 HEMMARGALA_66	13:34	14:46	1:12	HAND TRIPPED
899	19-Jul-20	MYSURU	66	HEBBAL-HOOTAGALLI	HEBBAL-INDUSTRIAL_66 METAGALLY_66	17:16	18:12	0:56	MAIN SUPPLY FAILURE
900	19-Jul-20	MYSURU	220	HV 1	HOOTAGALLY_220	17:19	19:31	2:12	TRANSFORMER FAULT
901	19-Jul-20	MYSURU	220	HV 2	HOOTAGALLY_220	17:19	19:26	2:07	TRANSFORMER FAULT
902	19-Jul-20	MYSURU	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	19:29	19:41	0:11	HAND TRIPPED
903	19-Jul-20	MYSURU	66	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	19:29	19:41	0:11	HAND TRIPPED
904	19-Jul-20	MYSURU	66	HOOTAGALLI-BEML	NO STATIONS EFFECTED	19:29	20:01	0:31	HAND TRIPPED
905	19-Jul-20	MYSURU	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	17:19	21:23	4:04	HAND TRIPPED
906	19-Jul-20	MYSURU	66	HOOTAGALLI-ELWALA	GAVADAGERE_66	17:16	20:42	3:26	LINE FAULT
907	19-Jul-20	MYSURU	66	HOOTAGALLI-HUNSUR	HUNSUR_66 HOSURGATE_66 BANNIKUPPE_66	17:16	18:24	1:07	LINE FAULT
908	19-Jul-20	MYSURU	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	15:32 (19/07/2020)			LINE OPEN: LINE FAULT
909	19-Jul-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 KARYA_66 PANDYADAHUNDI_66 HEMMARGALA_66 SUTTUR_66	16:36	18:26	1:50	LINE FAULT

910	19-Jul-20	MYSURU	220	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	14:14	14:39	0:25	LINE FAULT
911	19-Jul-20	MYSURU	66	HV2	PANDAVAPURA_66	10:01	10:25	0:23	LINE CLEAR AVAILED
912	19-Jul-20	MYSURU	66	VIJAYANAGARA-HOOTAGALLI	VIJAYANAGRAMYS_66 BANNIMANTAP_66	17:53	21:31	3:38	HAND TRIPPED
913	19-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
914	19-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26(26.05.20)			LINE OPEN: LINE FAULT
915	19-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
916	19-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
917	19-Jul-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	16:16 (18.07.2020)	13:25 (19.07.2020)	20:68hrs	LINE CHARGED
918	19-Jul-20	TUMKUR	66	NEELAGUNDA 220kv-TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	9:56(19.07.2020)			LINE OPEN: LINE FAULT
919	19-Jul-20	TUMKUR	220	TR-3	HIRIYUR_220	4:34	4:43	0:09	TRANSFORMER FAULT
920	19-Jul-20	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	11:01	11:10	0:09	LINE FAULT
921	19-Jul-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	14:20	15:16	0:55	HAND TRIPPED
922	19-Jul-20	TUMKUR	66	TR-1	MYLANAHALLI_66	15:03	15:21	0:18	TRANSFORMER FAULT
923	19-Jul-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:47	17:39	9:51	HAND TRIPPED
924	19-Jul-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	12:28	13:11	0:43	LINE CLEAR AVAILED
925	19-Jul-20	TUMKUR	66	TR2	HARIYABBE_66	17:28	18:24	0:55	LINE CLEAR AVAILED
926	19-Jul-20	TUMKUR	66	TR-2	HINDASGHATTA_66	14:30	14:46	0:16	LINE CLEAR AVAILED
927	19-Jul-20	TUMKUR	66	TR-1	HIRIYUR_66	19:40	19:51	0:11	TRANSFORMER FAULT
928	19-Jul-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	14:23	15:06	0:43	LINE CLEAR AVAILED
929	19-Jul-20	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	20:03	20:36	0:32	LINE FAULT
930	19-Jul-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHC HANGIDURGA_66,PALLAGAT TE_66, SOKKE_66	12:04	12:17	0:12	LINE FAULT
931	19-Jul-20	TUMKUR	66	NEELAGUNDA 220kv-TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	20:03	20:35	0:31	LINE FAULT

932	20-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
933	20-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
934	20-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
935	20-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
936	20-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
937	20-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
938	20-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
939	20-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
940	20-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
941	20-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)	16:24 (20.07.2020)	430:10hrs	LINE CHARGED
942	20-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
943	20-Jul-20	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	8:57 (08.07.2020)	10:13 (20.07.2020)	289:16hrs	LINE CHARGED
944	20-Jul-20	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN: LINE CLEAR AVAILED
945	20-Jul-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
946	20-Jul-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)			LINE OPEN: LINE CLEAR AVAILED
947	20-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN: LINE FAULT
948	20-Jul-20	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59 (15.07.2020)			LOAD CURTAILMENT
949	20-Jul-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT
950	20-Jul-20	BAGALKOT	110	JAMBAGI-MUDHOL	STATION NOT AFFECTED MUDHOL_110	12:08 (17.07.2020)			LINE OPEN: LINE FAULT
951	20-Jul-20	BAGALKOT	110	HAVERI 1-GUTTAL	STATION NOT AFFECTED GUTTAL_110	17:17 (18.07.2020)	14:55 (20.07.2020)	45:38hrs	LINE CHARGED
952	20-Jul-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN: LINE CLEAR AVAILED
953	20-Jul-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	18:02 (19.07.2020)	14:34 (20.07.2020)	20:32hrs	LINE CHARGED
954	20-Jul-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN: LINE CLEAR AVAILED

955	20-Jul-20	BAGALKOT	220	RBRK-BAGEWADI220	BAGEWADI_220	11:50	12:15	0:25	LINE FAULT
956	20-Jul-20	BAGALKOT	220	NAGJHARI-BIDNAL220	BIDNAL_220	11:20	12:14	0:54	LINE FAULT
957	20-Jul-20	BAGALKOT	220	NAGJHARI-BIDNAL220	BIDNAL_220	12:40	15:24	2:44	LINE FAULT
958	20-Jul-20	BAGALKOT	220	BELGUAM220-CHIKKODI2	BELGAUM_220	(20.07.2020 15:54)			LINE OPEN: LINE FAULT
959	20-Jul-20	BAGALKOT	220	BELGUAM220-NARENDRA1&2	BELGUAM_220	9:40	18:19	8:39	HAND TRIPPED
960	20-Jul-20	BAGALKOT	110	BELGUAM220-ANKALAGI110	ANKALAGI_110	16:37	18:55	2:18	HAND TRIPPED
961	20-Jul-20	BAGALKOT	110	110/33KV HV2	DAMBAL_110	12:00	15:00	3:00	LINE CLEAR AVAILED
962	20-Jul-20	BAGALKOT	110	110/33KV HV2	DAMBAL_110	15:01	17:41	2:40	TRANSFORMER FAULT
963	20-Jul-20	BAGALKOT	110	110/11KV HV2	GOKAK_110	12:41	13:13	0:32	LINE CLEAR AVAILED
964	20-Jul-20	BAGALKOT	110	HAVERI 1-GUTTAL	STATION NOT AFFECTED GUTTAL_110	16:40 (20.07.2020)			LINE OPEN: LINE CLEAR AVAILED
965	20-Jul-20	BAGALKOT	110	RAIBAG-HIDAKAL	HIDAKAL_110	11:24	16:34	5:10	HAND TRIPPED
966	20-Jul-20	BAGALKOT	110	RAIBAG-HIDAKAL	HIDAKAL_110	18:05 (20.07.2020)			LINE OPEN: LINE CLEAR AVAILED
967	20-Jul-20	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	10:37	10:42	0:05	TRANSFORMER FAULT
968	20-Jul-20	BAGALKOT	220	SIRSI220-UMMACHAGI	UMMACHAGI_110	11:29 (20.07.2020)			LINE OPEN: LINE CLEAR AVAILED
969	20-Jul-20	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	7:37	8:40	1:03	LINE CLEAR AVAILED
970	20-Jul-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:13	19:17	7:04	LINE FAULT
971	20-Jul-20	BAGALKOT	110	SIRSI1&2-SIRSI	SIRSI_110	12:11	12:20	0:09	LINE CLEAR AVAILED
972	20-Jul-20	BAGALKOT	110	RANEBEMNNUR-HIREKERUR	HIREKERUR_110	6:28	6:41	0:13	LINE FAULT
973	20-Jul-20	BAGALKOT	220	220/110KV,HV2,LV2	MK HUBLI_220	14:34	16:05	1:31	TRANSFORMER FAULT
974	20-Jul-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	21:38 (20.07.2020)			LINE OPEN: LINE CLEAR AVAILED
975	20-Jul-20	BAGALKOT	110	110/11KV,HV4	MK HUBLI_110	14:47	15:18	0:31	LINE CLEAR AVAILED
976	20-Jul-20	BAGALKOT	110	110/11KV,HV1	MELLIGERI	13:11	14:32	1:21	LINE CLEAR AVAILED
977	20-Jul-20	BAGALKOT	110	110/11KV,HV2	LAXMESHWAR_110	21:35	22:47	1:12	HAND TRIPPED
978	20-Jul-20	BAGALKOT	110	GADAG1-LAXMESHWAR	LAXMESHWAR_110	6:01	12:13	6:12	LINE FAULT
979	20-Jul-20	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	11:26	11:46	0:20	LINE CLEAR AVAILED
980	20-Jul-20	BAGALKOT	110	SHIRAGUPPI SUGAR-KAGAWAD	KAGAWAD_110	23:46	23:54	0:08	LINE FAULT
981	20-Jul-20	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMINAGA D_33,KARADI,MYTRA SOLAR_33	7:51	7:56	0:05	TRANSFORMER FAULT
982	20-Jul-20	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMINAGA D_33,KARADI,MYTRA SOLAR_33	15:55	15:58	0:03	TRANSFORMER FAULT
983	20-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:56 (20.02.2020)			LINE OPEN: LINE CLEAR AVAILED
984	20-Jul-20	BAGALKOT	220	NAREENDRA-BELGAUM1	NARENDRA_220	15:17	15:51	0:34	LINE FAULT
985	20-Jul-20	BAGALKOT	220	NAREENDRA-BELGAUM1&2	NARENDRA_220	17:29	18:18	0:49	HAND TRIPPED
986	20-Jul-20	BAGALKOT	220	KAVATAGI LIS-VAJRAMATTI	VAJRAMATTI_220	4:18	5:19	1:01	LINE FAULT
987	20-Jul-20	BENGALURU	66	SIDLAGATTA - VIJAYAPURA	MELUR, VIJAYAPURA	10:55	11:03	0:08	LOAD CHANGEOVER

988	20-Jul-20	BENGALURU	66	MELUR - CHINTAMANI 220	MELUR, VIJAYAPURA	9:30	10:30	1:00	LOAD CHANGEOVER
989	20-Jul-20	BENGALURU	66	PATHPALYA - SOMANATHPURA	SOMANATHPURA, THIMMAMPALLI	15:21	15:28	0:07	LINE FAULT
990	20-Jul-20	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	14:56	17:39	2:42	LINE FAULT
991	20-Jul-20	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	21:21	21:29	0:08	LINE FAULT
992	20-Jul-20	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	7:37	7:56	0:18	LINE FAULT
993	20-Jul-20	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	9:47	10:43	0:56	LINE OPEN: LINE CLEAR AVAILED
994	20-Jul-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	9:47	10:59	1:12	LINE OPEN: LINE CLEAR AVAILED
995	20-Jul-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	7:37	7:47	0:10	LINE FAULT
996	20-Jul-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:18	18:22	0:04	LOAD CHANGEOVER
997	20-Jul-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:19	17:21	0:01	LINE CLEAR AVAILED
998	20-Jul-20	BENGALURU	66	HV1	AVANI	13:17	13:20	0:02	LINE CLEAR AVAILED
999	20-Jul-20	BENGALURU	66	HV1	AVANI	21:40	22:10	0:30	LINE CLEAR AVAILED
1000	20-Jul-20	BENGALURU	66	HV1	AVANI	15:00	15:05	0:05	LINE CLEAR AVAILED
1001	20-Jul-20	BENGALURU	66	HV2	BANGARPET	10:57	11:26	0:28	LINE CLEAR AVAILED
1002	20-Jul-20	BENGALURU	66	HV2	CB PURA I/A	11:02	12:39	1:37	LINE CLEAR AVAILED
1003	20-Jul-20	BENGALURU	66	HV1	DEVANAHALLI	15:12	15:18	0:05	TRANSFORMER FAULT
1004	20-Jul-20	BENGALURU	66	HV1	MUDIYANUR	14:50	15:42	0:51	LINE CLEAR AVAILED
1005	20-Jul-20	BENGALURU	66	HV1	MUDIYANUR	14:40	16:20	1:40	LINE CLEAR AVAILED
1006	20-Jul-20	BENGALURU	66	HV1	YELAHANKA 220	21:54	22:04	0:09	TRANSFORMER FAULT
1007	20-Jul-20	BENGALURU	66	HAL 220 - HOODY 1	KADUBISANAHALLI, EXORA	8:18	8:58	0:40	LINE FAULT
1008	20-Jul-20	BENGALURU	66	HENNUR SROSS - VIDYANAGARA	HENNUR CROSS	14:57	15:27	0:30	MAIN SUPPLY FAILURE
1009	20-Jul-20	BENGALURU	66	HENNUR SROSS - SHOBHA CITY	HENNUR CROSS	17:51	17:55	0:04	LOAD CHANGEOVER
1010	20-Jul-20	BENGALURU	66	VIDYANAGRA - HENNUR CROSS	NO STATION AFFECTED	14:55	15:27	0:32	LINE FAULT
1011	20-Jul-20	BENGALURU	66	KADUBISANAHALLI - HSR LAYOUT 220	KADUBISANAHALLI, EXORA	10:17	10:32	0:15	LOAD CHANGEOVER
1012	20-Jul-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:36	11:52	0:16	LINE FAULT
1013	20-Jul-20	BENGALURU	66	HV1	VIJAYANAGARA	22:34	23:20	0:46	TRANSFORMER FAULT
1014	20-Jul-20	BENGALURU	66	HEBBAL 220 - IISC	NO STATION AFFECTED	16:09(19-07-2020)	12:54(20-07-2020)	20:44hrs	LINE CHARGED
1015	20-Jul-20	BENGALURU	66	HV1	IISc	16:44(19-07-2020)	10:55(20-07-2020)	18:11hrs	TRANSFORMER CHARGED
1016	20-Jul-20	BENGALURU	66	HV1	VIJAYANAGARA	22:34(20/07/2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
1017	20-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED

1018	20-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN: LINE FAULT
1019	20-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
1020	20-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
1021	20-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN: LINE FAULT
1022	20-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
1023	20-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
1024	20-Jul-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.7.2020)			LINE OPEN: LINE FAULT
1025	20-Jul-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:30(20.07.2020)			LINE OPEN: LINE FAULT
1026	20-Jul-20	GULBARGA	220	RTPS-LINGASUGUR2	RTPS_220	2:30	2:43	0:13	LINE FAULT
1027	20-Jul-20	GULBARGA	220	RTPS-LINGASUGUR1	RTPS_220	5:53	7:00	1:07	LINE FAULT
1028	20-Jul-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	18:09(19.7.2020)	13:39(20.07.2020)	19:30hrs	LINE CHARGED
1029	20-Jul-20	GULBARGA	220	SINDHANOOR-VALKAMDINNI	VALKAMDINNI_110	9:50	15:10	5:20	NFBC ISSUED
1030	20-Jul-20	GULBARGA	220	KUSTAGI-SUZLON1_IPP	KUSTAGI_220	16:07	16:18	0:11	LINE OPEN: LINE CLEAR AVAILED
1031	20-Jul-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	16:15	17:40	1:25	NFBC ISSUED
1032	20-Jul-20	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	6:40	18:55	12:15	LINE FAULT
1033	20-Jul-20	GULBARGA	110	HV2	CHICKSUGUR_110	13:52	14:05	0:13	TRANSFORMER FAULT
1034	20-Jul-20	GULBARGA	110	PDHALLI-CLNSLR_IPP	PDHALLI_110	3:00	3:45	0:45	LINE CLEAR AVAILED
1035	20-Jul-20	GULBARGA	110	HV3	SHORAPUR_110	1:07	1:20	0:13	TRANSFORMER FAULT
1036	20-Jul-20	GULBARGA	110	SHORAPUR-SHAHAPUR	SHORAPUR_110	1:02	1:07	0:05	MAIN SUPPLY FAILURE
1037	20-Jul-20	GULBARGA	110	HV2	BISIHALLI_110	8:25	8:47	0:22	TRANSFORMER FAULT
1038	20-Jul-20	GULBARGA	110	HV2	BISIHALLI_110	10:16	10:25	0:09	TRANSFORMER FAULT
1039	20-Jul-20	GULBARGA	110	HV2	BISIHALLI_110	10:43	10:50	0:07	TRANSFORMER FAULT
1040	20-Jul-20	GULBARGA	110	SINDHANOOR-VALKAMDINNI	VALKAMDINNI_110	9:40	14:55	5:15	NFBC ISSUED
1041	20-Jul-20	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	0:15	0:40	0:25	LINE FAULT
1042	20-Jul-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	0:50	1:08	0:18	LINE FAULT
1043	20-Jul-20	GULBARGA	110	SINDHANOOR-VALKAMDINNI	VALKAMDINNI_110	14:50	15:20	0:30	LINE CLEAR AVAILED
1044	20-Jul-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	1:49	2:09	0:20	LINE FAULT
1045	20-Jul-20	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	2:37	2:57	0:20	LINE FAULT
1046	20-Jul-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	3:19	3:40	0:21	LINE FAULT
1047	20-Jul-20	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	3:51	6:40	2:49	LINE FAULT
1048	20-Jul-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	0:12	0:22	0:10	LINE FAULT
1049	20-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	3:30	3:38	0:08	LINE FAULT
1050	20-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	3:55	4:04	0:09	LINE FAULT
1051	20-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	6:05	6:30	0:25	LINE FAULT
1052	20-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGA R_IPP,HUNASAGI_110,ASKI_ 110	12:19	12:31	0:12	LINE FAULT

1053	20-Jul-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,KAMALAPUR_110,SHATAVAHANA_IPP,AGRAWAL_IPP	20:16	20:28	0:12	LINE FAULT
1054	20-Jul-20	GULBARGA	110	KAPANOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	20:46	20:55	0:09	LINE FAULT
1055	20-Jul-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	19:30	19:53	0:23	LINE FAULT
1056	20-Jul-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP,HUNASAGI_110,ASKI_110	23:05	23:11	0:06	LINE FAULT
1057	20-Jul-20	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWATERWORKS	20:10	20:20	0:10	LINE FAULT
1058	20-Jul-20	GULBARGA	110	SIDHANOOR-NIRLOOTI	NIRLOOTI_110	20:55	21:15	0:20	LINE FAULT
1059	20-Jul-20	GULBARGA	66	CJHALLI-KUDLIGI	CJHALLI_66,HOSAHALLI_66	21:35	21:55	0:20	MAIN SUPPLY FAILURE
1060	20-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:14 (18.07.2020)	6:35 (20.07.2020)	30.39hrs	LINE CHARGED
1061	20-Jul-20	HASSAN	110	MOODAB-SOHAM2	NO STN AFFECTED	17:32 (16.07.2020)			LINE OPEN: LINE CLEAR AVAILED
1062	20-Jul-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:06 (18.07.2020)			LINE OPEN: LINE CLEAR AVAILED
1063	20-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:19 (20.07.2020)			LINE OPEN: LINE CLEAR AVAILED
1064	20-Jul-20	HASSAN	66	UDDURKO-SUZLON	UDDURKOPLU_66	11:30(20.07.2020)			LINE OPEN: LINE FAULT
1065	20-Jul-20	HASSAN	220	HV1	KADUR_220	13:05	14:35	1:30	LINE CLEAR AVAILED
1066	20-Jul-20	HASSAN	110	LV1	KADUR_220	13:05	14:35	1:30	LINE CLEAR AVAILED
1067	20-Jul-20	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:41	7:37	6:56	HAND TRIPPED
1068	20-Jul-20	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	11:38	13:18	1:40	LINE CLEAR AVAILED
1069	20-Jul-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:48	14:43	3:55	LINE CLEAR AVAILED
1070	20-Jul-20	HASSAN	110	HV2	ESSUR_110	16:03	16:33	0:30	LINE CLEAR AVAILED
1071	20-Jul-20	HASSAN	110	HV3	HIRIYADKA_110	10:18	18:23	8:05	HAND TRIPPED
1072	20-Jul-20	HASSAN	110	HV1	NANDIKUR_110	11:58	12:05	0:07	HAND TRIPPED
1073	20-Jul-20	HASSAN	110	HV1	NANDIKUR_110	21:07	21:13	0:06	TRANSFORMER FAULT
1074	20-Jul-20	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	14:32	14:41	0:09	LINE FAULT
1075	20-Jul-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:38	18:01	0:23	LINE CLEAR AVAILED
1076	20-Jul-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	17:37	17:56	0:19	LINE CLEAR AVAILED
1077	20-Jul-20	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	13:41	15:00	1:19	MAIN SUPPLY FAILURE
1078	20-Jul-20	HASSAN	66	HASSN220-BELUR	HASSAN_220	12:41	14:35	1:54	LINE CLEAR AVAILED
1079	20-Jul-20	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	11:30	14:36	3:06	LINE FAULT
1080	20-Jul-20	HASSAN	66	HV1	JUTTANAHALLI_66	10:47	11:19	0:32	LINE CLEAR AVAILED
1081	20-Jul-20	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	15:56	16:08	0:12	LINE FAULT
1082	20-Jul-20	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	13:53	14:37	0:44	MAIN SUPPLY FAILURE
1083	20-Jul-20	MYSURU	66	HV1	BANNUR_66	13:19	13:47	0:27	LINE CLEAR AVAILED
1084	20-Jul-20	MYSURU	66	CR NAGARA-YELANDUR	YELANDUR_66	6:34	6:40	0:05	LINE FAULT

1085	20-Jul-20	MYSURU	66	HV2	ELAVALA_66	13:32	16:55	3:23	LINE CLEAR AVAILED
1086	20-Jul-20	MYSURU	66	GUDDENAHALLY-JAKKANAHALLY	GUDDENAHALLI_66	1:50	2:00	0:10	LINE FAULT
1087	20-Jul-20	MYSURU	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALLI_66	14:58	15:08	0:10	LINE FAULT
1088	20-Jul-20	MYSURU	66	GUNDLUPETE-HANGALA	HANGLA_66 BHARGI_66	14:58	15:09	0:11	LINE FAULT
1089	20-Jul-20	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	14:58	15:17	0:18	LINE FAULT
1090	20-Jul-20	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	19:20	19:29	0:08	LINE FAULT
1091	20-Jul-20	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	19:20	19:28	0:08	LINE FAULT
1092	20-Jul-20	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	20:52	20:59	0:06	LINE FAULT
1093	20-Jul-20	MYSURU	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	13:12	14:57	1:45	HAND TRIPPED
1094	20-Jul-20	MYSURU	66	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	13:12	14:57	1:45	HAND TRIPPED
1095	20-Jul-20	MYSURU	66	HOOTAGALLI-BEML	NO STATIONS EFFECTED	13:24	14:50	1:26	HAND TRIPPED
1096	20-Jul-20	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	12:10	15:14	3:03	HAND TRIPPED
1097	20-Jul-20	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	12:13	15:26	3:13	HAND TRIPPED
1098	20-Jul-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	12:05	15:30	3:24	HAND TRIPPED
1099	20-Jul-20	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATIONS EFFECTED	12:05	15:30	3:24	HAND TRIPPED
1100	20-Jul-20	MYSURU	66	HV2	HOOTAGALLY_220	13:46	14:44	0:58	HAND TRIPPED
1101	20-Jul-20	MYSURU	220	HV3	HOOTAGALLY_220	12:50	15:27	2:37	HAND TRIPPED
1102	20-Jul-20	MYSURU	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	6:27	6:32	0:05	LINE FAULT
1103	20-Jul-20	MYSURU	66	KHB -HOOTAGALLI	NO STATIONS EFFECTED	11:55	15:33	3:38	HAND TRIPPED
1104	20-Jul-20	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	11:36	11:48	0:11	LINE FAULT
1105	20-Jul-20	MYSURU	66	HV2	MALAVALLI_66	3:02	3:08	0:06	TRANSFORMER FAULT
1106	20-Jul-20	MYSURU	66	HV2	MALAVALLI_66	4:13	5:37	1:24	LINE CLEAR AVAILED
1107	20-Jul-20	MYSURU	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 TNARASIPURA_66 VYASRAIPURA_66	18:21	18:30	0:08	LINE FAULT
1108	20-Jul-20	MYSURU	66	PONNAMPETE-HANAGUDU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	11:27	11:41	0:13	LINE FAULT
1109	20-Jul-20	MYSURU	66	PONNAMPETE-HANAGUDU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	19:21	19:34	0:13	LINE FAULT
1110	20-Jul-20	MYSURU	66	SFCSIVA-HEBBANI 6	NO STATIONS EFFECTED	3:39	4:49	1:10	LINE FAULT
1111	20-Jul-20	MYSURU	66	SFCSIVA-HEBBANI 8	NO STATIONS EFFECTED	4:00	4:49	0:48	LINE FAULT
1112	20-Jul-20	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	3:39	3:45	0:05	LINE FAULT
1113	20-Jul-20	MYSURU	66	SFCSIVA-HEBBANI 1	NO STATIONS EFFECTED	3:39	4:59	1:20	LINE FAULT
1114	20-Jul-20	MYSURU	66	SFCSIVA-HEBBANI 9	NO STATIONS EFFECTED	4:00	4:49	0:48	LINE FAULT

1115	20-Jul-20	MYSURU	66	SFCSIVA-HEBBANI 2	NO STATIONS EFFECTED	3:39	4:58	1:19	LINE FAULT
1116	20-Jul-20	MYSURU	66	SFCSIVA-HEBBANI 7	NO STATIONS EFFECTED	4:00	4:49	0:49	LINE FAULT
1117	20-Jul-20	MYSURU	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 HEBBAL_66 METAGALLY_66 SRIRANGAPATNA_66	6:15	6:26	0:10	LINE FAULT
1118	20-Jul-20	MYSURU	66	VAJAMANGALA-JYOTHINAGARA	DKMAIDANA_66 FTS_66 JYOTHINAGARA_66	7:03	7:21	0:17	LINE FAULT
1119	20-Jul-20	MYSURU	66	VIJAYANAGARA-HOOTAGALLY	NO STATIONS EFFECTED	12:50	15:07	2:17	HAND TRIPPED
1120	20-Jul-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
1121	20-Jul-20	MYSURU	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	15:32 (19.07.2020)	16:35 (20.07.2020)	25:03hrs	LINE CHARGED
1122	20-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
1123	20-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
1124	20-Jul-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	16:16:54(18.07.2020)	13:25:05 (19.07.2020)	21:9hrs	LINE CHARGED
1125	20-Jul-20	TUMKUR	66	NEELAGUNDA 220KV-TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJIHALLI_66	21:56:43(19.07.2020)	12:43:34(20.07.2020)	14:47hrs	LINE CHARGED
1126	20-Jul-20	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	18:40	19:29	0:48	TRANSFORMER FAULT
1127	20-Jul-20	TUMKUR	110	TR-1	HALKURKE_110	12:35	13:31	0:55	LINE CLEAR AVAILED
1128	20-Jul-20	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:19	12:34	2:14	LINE CLEAR AVAILED
1129	20-Jul-20	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	15:38	17:17	1:38	LINE CLEAR AVAILED
1130	20-Jul-20	TUMKUR	66	TR-2	BENNEHALLI_66	13:34	13:38	0:04	TRANSFORMER FAULT
1131	20-Jul-20	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	19:11	19:31	0:19	HAND TRIPPED
1132	20-Jul-20	TUMKUR	66	TR-2	GULIGENAHALLI_66	11:55	12:52	0:57	LINE CLEAR AVAILED
1133	20-Jul-20	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	6:51	7:19	0:27	LINE FAULT
1134	20-Jul-20	TUMKUR	66	TR-1	HANAGAL_66	11:10	12:48	1:38	LINE CLEAR AVAILED
1135	20-Jul-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	13:32	13:34	0:02	MAIN SUPPLY FAILURE
1136	20-Jul-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	19:24	19:57	0:33	HAND TRIPPED
1137	20-Jul-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:19	19:42	7:22	HAND TRIPPED
1138	20-Jul-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	19:18	19:35	0:16	HAND TRIPPED
1139	20-Jul-20	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	19:18	19:35	0:16	HAND TRIPPED
1140	20-Jul-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	19:19	19:39	0:19	HAND TRIPPED