

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 02.04.2019 to 08.04.2019

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|------------------------------------|--|---------|-----------|----------|--------------------|
| 1 | 2-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | ANAND NAGAR_110 | 10:30 | 16:38 | 6:08 | LINE CLEAR AVAILED |
| 2 | 2-Apr-19 | BAGALKOT | 110 | HUNAGUND -B.BAGEWADI(KUDALASANGAM) | KUDALASANGAM_110 | 10:33 | 10:38 | 0:05 | LOAD CHANGEOVER |
| 3 | 2-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KAVALAWAD_110 | 6:46 | 7:29 | 0:43 | LINE FAULT |
| 4 | 2-Apr-19 | BAGALKOT | 220 | BIDNAL-NARENDRA | BIDNAL_220 | 11:14 | 14:46 | 3:32 | NFBC ISSUED |
| 5 | 2-Apr-19 | BAGALKOT | 220 | BIDNAL-HARTI 2 | BIDNAL_220 | 7:42 | 13:39 | 5:57 | LINE CLEAR AVAILED |
| 6 | 2-Apr-19 | BAGALKOT | 110 | KUADALASANGAM-HUNAGUND | KUDASANGAM_110 | 10:33 | 11:02 | 0:29 | LOAD CHANGEOVER |
| 7 | 2-Apr-19 | BAGALKOT | 110 | JOG2-SIRSI | SIRSI_110 | 11:49 | 12:59 | 1:10 | LINE CLEAR AVAILED |
| 8 | 2-Apr-19 | BAGALKOT | 110 | SIRSI220-SIRSI | SIRSI_110 | 10:39 | 11:45 | 1:06 | LINE CLEAR AVAILED |
| 9 | 2-Apr-19 | BAGALKOT | 110 | JOG1(SIDDAPUR)-SIRSI | SIRSI_110 | 6:45 | 7:18 | 0:33 | LINE FAULT |
| 10 | 2-Apr-19 | BAGALKOT | 220 | HUBLI-NARENDRA1 | HUBLI_220 | 14:02 | 18:08 | 4:06 | LINE FAULT |
| 11 | 2-Apr-19 | BAGALKOT | 220 | HAVERI-NARENDRA | HAVERI_220 | 7:06 | 14:44 | 7:38 | LINE FAULT |
| 12 | 2-Apr-19 | BAGALKOT | 220 | BELGAUM-CHIKKODI2 | BELGAUM_220 | 0:00 | 7:44 | 7:44 | LINE CLEAR AVAILED |
| 13 | 2-Apr-19 | BAGALKOT | 66 | 66/33KV, HV4 | HARIHAR HOSPET_66 | 16:50 | 19:30 | 2:40 | LOAD CURTAILMENT |
| 14 | 2-Apr-19 | BANGALORE | 66 | HV2 | HSR LAYOUT 220 | 3:21 | 3:23 | 0:01 | TRANSFORMER FAULT |
| 15 | 2-Apr-19 | BANGALORE | 66 | MAHALAKSHMILAYOUT - SRS PEENYA 220 | MAHALAKSHMILAYOUT | 16:40 | 16:43 | 0:03 | LINE CLEAR AVAILED |
| 16 | 2-Apr-19 | BANGALORE | 66 | HV1 | LR BANDE | 6:40 | 7:44 | 1:03 | LINE CLEAR AVAILED |
| 17 | 2-Apr-19 | BANGALORE | 66 | KUMBALAGODU - CHANDRAPPA CIRCLE | HANDRAPPA CIRCLE | 17:19 | 18:35 | 1:15 | LINE CLEAR AVAILED |
| 18 | 2-Apr-19 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, SHIVANAHALLI, CHIKKENAHALLI, CHANNAPATNA, DASHAVARA, SANKALGERE, BEVOOR | 7:16 | 7:23 | 0:06 | LINE FAULT |
| 19 | 2-Apr-19 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, SHIVANAHALLI, CHIKKENAHALLI, CHANNAPATNA, DASHAVARA, SANKALGERE, BEVOOR | 7:46 | 7:50 | 0:04 | LINE CLEAR AVAILED |
| 20 | 2-Apr-19 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, SHIVANAHALLI, CHIKKENAHALLI, CHANNAPATNA, DASHAVARA, SANKALGERE, BEVOOR | 9:06 | 10:36 | 1:30 | LINE CLEAR AVAILED |
| 21 | 2-Apr-19 | BANGALORE | 66 | ATTIBELE - SARAJAPURA 220 | ATTIBELE | 12:35 | 12:50 | 0:15 | LOAD CHANGEOVER |
| 22 | 2-Apr-19 | BANGALORE | 66 | ATTIBELE - ANEKAL | ATTIBELE | 14:00 | 14:10 | 0:10 | LOAD CHANGEOVER |
| 23 | 2-Apr-19 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAVARA, SANKALGERE, BEVOOR | 6:08 | 6:14 | 0:06 | LINE FAULT |
| 24 | 2-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 8:02 | 8:10 | 0:07 | TRANSFORMER FAULT |
| 25 | 2-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 12:43 | 12:53 | 0:10 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|-----------------------------------|----------------------|---------|-----------|----------|---------------------|
| 26 | 2-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 16:44 | 17:40 | 0:55 | LINE CLEAR AVAILED |
| 27 | 2-Apr-19 | BANGALORE | 66 | HV2 | HAROBEL | 16:35 | 16:36 | 0:01 | LINE CLEAR AVAILED |
| 28 | 2-Apr-19 | BANGALORE | 66 | HOSUR RAMAPURA - GOWRIBIDANUR 220 | HOSUR RAMAPURA | 0:40 | 0:45 | 0:05 | NFBC ISSUED |
| 29 | 2-Apr-19 | BANGALORE | 66 | HV1 | JIGANI 66 | 13:30 | 14:00 | 0:30 | LINE CLEAR AVAILED |
| 30 | 2-Apr-19 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 10:25 | 10:39 | 0:14 | LINE CLEAR AVAILED |
| 31 | 2-Apr-19 | BANGALORE | 66 | HV1 | YEDMADU | 22:10 | 22:15 | 0:05 | LINE CLEAR AVAILED |
| 32 | 2-Apr-19 | BANGALORE | 66 | HV2 | YEDMADU | 21:45 | 22:08 | 0:23 | LINE CLEAR AVAILED |
| 33 | 2-Apr-19 | BANGALORE | 66 | HV2 | YELAHANKA 220 | 19:01 | 22:42 | 3:40 | TRANSFORMER FAULT |
| 34 | 2-Apr-19 | GULBARGA | 220 | HV2 | HALBARGA_220 | 1:33 | 1:45 | 0:12 | TRANSFORMER FAULT |
| 35 | 2-Apr-19 | GULBARGA | 220 | SEDAM-RTPS1 | SEDAM_220 | 12:35 | 15:50 | 3:15 | LINE FAULT |
| 36 | 2-Apr-19 | GULBARGA | 220 | SEDAM-SHAHPUR | SEDAM_220 | 0:00 | 18:43 | 18:43 | LINE FAULT |
| 37 | 2-Apr-19 | GULBARGA | 220 | SEDAM-SHAHPUR | SEDAM_220 | 19:29 | 23:59 | 4:30 | LINE FAULT |
| 38 | 2-Apr-19 | GULBARGA | 110 | LV2 | HALBARGA_220 | 1:33 | 1:45 | 0:12 | TRANSFORMER FAULT |
| 39 | 2-Apr-19 | GULBARGA | 110 | HV1 | UPANAYAKANAHALLI_110 | 8:40 | 9:33 | 0:53 | LINE CLEAR AVAILED |
| 40 | 2-Apr-19 | GULBARGA | 110 | HV3, HV4 | YELBURGA_110 | 16:50 | 17:05 | 0:15 | TRANSFORMER FAULT |
| 41 | 2-Apr-19 | GULBARGA | 110 | HV1 | CHITGUPPA_110 | 16:30 | 17:40 | 1:10 | TRANSFORMER FAULT |
| 42 | 2-Apr-19 | GULBARGA | 110 | SHAHPUR-KEMBHAVI2 | KEMBHAVI_110,KBJNL | 0:00 | 12:50 | 12:50 | LINE FAULT |
| 43 | 2-Apr-19 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 0:00 | 16:28 | 16:28 | LINE FAULT |
| 44 | 2-Apr-19 | HASSAN | 220 | KEMAR-BAJPE2 | KEMAR_220 | 10:09 | 14:25 | 4:16 | NFBC ISSUED |
| 45 | 2-Apr-19 | HASSAN | 220 | KEMAR-Varahi3 | KEMAR_220 | 16:52 | 23:59 | 7:07 | LINE CLEAR AVAILED |
| 46 | 2-Apr-19 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 10:09 | 14:25 | 4:16 | LINE CLEAR AVAILED |
| 47 | 2-Apr-19 | HASSAN | 220 | VARAHI-KEMAR3 | varahi_gen | 16:52 | 23:59 | 7:07 | NFBC ISSUED |
| 48 | 2-Apr-19 | HASSAN | 110 | HV3 | BANTWAL_110 | 17:25 | 17:32 | 0:07 | TRANSFORMER FAULT |
| 49 | 2-Apr-19 | HASSAN | 110 | HV1 | GURUVAYANAKERE_110 | 20:53 | 22:06 | 1:13 | TRANSFORMER FAULT |
| 50 | 2-Apr-19 | HASSAN | 110 | HV3 | GURUVAYANAKERE_110 | 17:05 | 18:00 | 0:55 | TRANSFORMER FAULT |
| 51 | 2-Apr-19 | HASSAN | 110 | HV3 | GURUVAYANAKERE_110 | 18:20 | 18:25 | 0:05 | TRANSFORMER FAULT |
| 52 | 2-Apr-19 | HASSAN | 110 | HV3 | GURUVAYANAKERE_110 | 21:00 | 22:05 | 1:05 | LINE CLEAR AVAILED |
| 53 | 2-Apr-19 | HASSAN | 110 | HV1 | KITTADAHALLY_110 | 13:05 | 13:45 | 0:40 | LINE CLEAR AVAILED |
| 54 | 2-Apr-19 | HASSAN | 110 | KONAJE-MANJESWARG | KONAJE_110 | 17:29 | 20:07 | 2:38 | LINE FAULT |
| 55 | 2-Apr-19 | HASSAN | 110 | HV4 | PUTTUR_110 | 17:16 | 17:42 | 0:26 | TRANSFORMER FAULT |
| 56 | 2-Apr-19 | HASSAN | 110 | SALATHU-BNTWAL | SALATHUR_110 | 17:29 | 17:58 | 0:29 | LINE FAULT |
| 57 | 2-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 7:09 | 7:14 | 0:05 | LINE FAULT |
| 58 | 2-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 13:14 | 13:23 | 0:09 | LINE FAULT |
| 59 | 2-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 13:37 | 13:55 | 0:18 | LINE FAULT |
| 60 | 2-Apr-19 | HASSAN | 66 | HV1 | BYCHANAHALLY_66 | 16:03 | 16:15 | 0:12 | HAND TRIPPED |
| 61 | 2-Apr-19 | HASSAN | 66 | GENDEHA-HASSAN | GENDEHALLY_66 | 14:18 | 15:05 | 0:47 | MAIN SUPPLY FAILURE |
| 62 | 2-Apr-19 | HASSAN | 66 | HV1 | GENDEHALLY_66 | 14:19 | 15:49 | 1:30 | MAIN SUPPLY FAILURE |
| 63 | 2-Apr-19 | HASSAN | 66 | GENDEHA-MUDIGERE | GENDEHALLY_66 | 14:18 | 15:07 | 0:49 | MAIN SUPPLY FAILURE |
| 64 | 2-Apr-19 | HASSAN | 66 | GENDEHA-MUDIGERE | GENDEHALLY_66 | 16:25 | 16:45 | 0:20 | MAIN SUPPLY FAILURE |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|---------|---------|---------------------------|--|---------|-----------|----------|---------------------|
| 65 | 2-Apr-19 | HASSAN | 66 | GENDEHA-HASSAN | GENDEHALLY_66 | 16:25 | 16:45 | 0:20 | MAIN SUPPLY FAILURE |
| 66 | 2-Apr-19 | HASSAN | 66 | GORUR-ARAKALGUD | GORUR_66 | 14:37 | 14:41 | 0:04 | HAND TRIPPED |
| 67 | 2-Apr-19 | HASSAN | 66 | GORUR-HASSAN | GORUR_66 | 14:06 | 14:40 | 0:34 | LINE FAULT |
| 68 | 2-Apr-19 | HASSAN | 66 | HASSN220-ARAKALGUD | HASSAN_220 | 14:07 | 14:37 | 0:30 | LINE FAULT |
| 69 | 2-Apr-19 | HASSAN | 66 | HASSN220-CHIKAMAGLUR2 | HASSAN_220 | 14:07 | 14:38 | 0:31 | LINE FAULT |
| 70 | 2-Apr-19 | HASSAN | 66 | HASSN220-MALLALI | HASSAN_220 | 13:26 | 13:39 | 0:13 | LINE FAULT |
| 71 | 2-Apr-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHPUA_66 | 7:56 | 17:05 | 9:09 | LINE CLEAR AVAILED |
| 72 | 2-Apr-19 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESHPUA_66 | 7:56 | 17:25 | 9:29 | LINE CLEAR AVAILED |
| 73 | 2-Apr-19 | HASSAN | 66 | HV1 | SIGEBAGE_66 | 17:30 | 18:52 | 1:22 | LINE CLEAR AVAILED |
| 74 | 2-Apr-19 | MYSORE | 66 | HV1 | HONNALLY_MYS_66 | 13:20 | 13:22 | 0:02 | TRANSFORMER FAULT |
| 75 | 2-Apr-19 | MYSORE | 66 | HV2 | HONNALLY_MYS_66 | 13:20 | 23:59 | 10:38 | TRANSFORMER FAULT |
| 76 | 2-Apr-19 | MYSORE | 66 | KADAKOLA-SARAGUR 2 | HURA_66, HULLAHALLI_66, DOORA_66 | 14:05 | 14:25 | 0:20 | LINE FAULT |
| 77 | 2-Apr-19 | MYSORE | 66 | KADAKOLA-SARAGUR 1 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 | 14:05 | 14:26 | 0:20 | LINE FAULT |
| 78 | 2-Apr-19 | MYSORE | 66 | KADAKOLA-SARAGUR 1 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 | 13:29 | 13:35 | 0:05 | LINE FAULT |
| 79 | 2-Apr-19 | MYSORE | 66 | HV1 | MADIKERI_66 | 10:33 | 12:33 | 1:59 | LINE CLEAR AVAILED |
| 80 | 2-Apr-19 | MYSORE | 66 | HV1 | MADIKERI_66 | 13:20 | 13:22 | 0:02 | HAND TRIPPED |
| 81 | 2-Apr-19 | MYSORE | 66 | SANTHE SARAGUR-KADAKOLA 2 | B MATKERE_66, SANTHESARAGUR_66 | 10:47 | 12:08 | 1:21 | LINE CLEAR AVAILED |
| 82 | 2-Apr-19 | MYSORE | 66 | SANTHE SARAGUR-KADAKOLA 1 | B MATKERE_66, SANTHESARAGUR_66 | 10:47 | 17:33 | 6:45 | LINE CLEAR AVAILED |
| 83 | 2-Apr-19 | MYSORE | 66 | SANTHE SARAGUR-KALSON | B MATKERE_66, SANTHESARAGUR_66 | 10:35 | 12:09 | 1:34 | LINE CLEAR AVAILED |
| 84 | 2-Apr-19 | MYSORE | 66 | SANTHE SARAGUR-B MATTGERE | B MATKERE_66, SANTHESARAGUR_66 | 10:44 | 12:16 | 1:32 | LINE CLEAR AVAILED |
| 85 | 2-Apr-19 | MYSORE | 66 | HV5 | SFCSHIVA_66 | 0:10 | 7:57 | 7:47 | LINE CLEAR AVAILED |
| 86 | 2-Apr-19 | MYSORE | 66 | VAJAMANGALA-BANNUR | BANNUR_66 | 6:35 | 6:52 | 0:16 | LINE FAULT |
| 87 | 2-Apr-19 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 13:55 | 14:01 | 0:05 | TRANSFORMER FAULT |
| 88 | 2-Apr-19 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 18:55 | 19:01 | 0:05 | TRANSFORMER FAULT |
| 89 | 2-Apr-19 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 3:05 | 3:15 | 0:10 | LINE FAULT |
| 90 | 2-Apr-19 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 10:31 | 10:38 | 0:07 | LINE FAULT |
| 91 | 2-Apr-19 | TUMKUR | 66 | TR-1 | HALURAMESHWARA_66 | 16:07 | 16:38 | 0:30 | LINE CLEAR AVAILED |
| 92 | 2-Apr-19 | TUMKUR | 66 | HIREHALLI - MELKOTE_66 | MELKOTE_66 | 16:05 | 16:28 | 0:22 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|-------------------------------------|--|---------|-----------|----------|--------------------|
| 93 | 2-Apr-19 | TUMKUR | 66 | HONNALLI 220kV- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 11:35 | 11:42 | 0:07 | LINE FAULT |
| 94 | 2-Apr-19 | TUMKUR | 66 | KALAMARANAHALLI- TATA SOLAR_IPP_66 | TATA SOLAR_IPP_66 | 13:17 | 13:26 | 0:09 | LINE FAULT |
| 95 | 2-Apr-19 | TUMKUR | 66 | KUKKAWADA- LINGADAHALLI(CHANNAGIRI) | TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 8:52 | 10:34 | 1:42 | LINE CLEAR AVAILED |
| 96 | 2-Apr-19 | TUMKUR | 66 | TR-1 | LINGADAHALLY_66 | 18:45 | 18:51 | 0:06 | TRANSFORMER FAULT |
| 97 | 2-Apr-19 | TUMKUR | 66 | TR-1 | NAGALMADIKE_66 | 12:14 | 13:03 | 0:48 | LINE CLEAR AVAILED |
| 98 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-2 | ANANAD NAGAR_110 | 11:08 | 16:17 | 5:09 | LINE CLEAR AVAILED |
| 99 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-2 | BANAHATTI_110 | 7:37 | 9:36 | 1:59 | LINE CLEAR AVAILED |
| 100 | 3-Apr-19 | BAGALKOT | 220 | BIDNAL-HUBLI 1 | BIDNAL_220 | 10:06 | 13:00 | 2:54 | LINE CLEAR AVAILED |
| 101 | 3-Apr-19 | BAGALKOT | 220 | BIDNAL-SOUDATTI(HUBLI 2) | BIDNAL_220 | 12:55 | 13:05 | 0:10 | LINE FAULT |
| 102 | 3-Apr-19 | BAGALKOT | 220 | BIDNAL-SOUDATTI | BIDNAL_220 | 12:55 | 13:00 | 0:05 | LINE FAULT |
| 103 | 3-Apr-19 | BAGALKOT | 220 | 220/110KV,HV-1 | BIDNAL_220 | 12:55 | 13:00 | 0:05 | TRANSFORMER FAULT |
| 104 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-2 | BIDNAL_220 | 12:55 | 13:07 | 0:12 | TRANSFORMER FAULT |
| 105 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | BIDNAL_220 | 12:55 | 13:03 | 0:08 | TRANSFORMER FAULT |
| 106 | 3-Apr-19 | BAGALKOT | 110 | BIDNAL-ANNIGERI | ANNIGERI_110 | 12:56 | 13:12 | 0:16 | LINE FAULT |
| 107 | 3-Apr-19 | BAGALKOT | 110 | BIDNAL-NAVALGUND | NAVALAGUND_110 | 12:56 | 13:23 | 0:27 | LINE FAULT |
| 108 | 3-Apr-19 | BAGALKOT | 110 | BIDNAL-GADAG ROAD | GADAG ROAD_110 | 12:56 | 13:19 | 0:23 | LINE FAULT |
| 109 | 3-Apr-19 | BAGALKOT | 110 | BIDNAL-PH COMPOUND | PH COMPOUND_110 | 12:56 | 13:13 | 0:17 | LINE FAULT |
| 110 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-4 | GHTAPRABHA_110 | 7:48 | 7:57 | 0:09 | TRANSFORMER FAULT |
| 111 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | GUTTAL_110 | 16:29 | 17:30 | 1:01 | LINE CLEAR AVAILED |
| 112 | 3-Apr-19 | BAGALKOT | 110 | HAVERI-TILUVALLI(HANAGALL) | HANAGAL_110 | 12:08 | 12:11 | 0:03 | LINE CLEAR AVAILED |
| 113 | 3-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KAVALAWAD_110 | 8:22 | 12:58 | 4:36 | LINE CLEAR AVAILED |
| 114 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | HIDIKAL_110 | 3:25 | 3:30 | 0:05 | TRANSFORMER FAULT |
| 115 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | HIDIKAL_110 | 17:50 | 20:12 | 2:22 | LINE CLEAR AVAILED |
| 116 | 3-Apr-19 | BAGALKOT | 110 | SIRSI(AMBEWADI)-KIRUVATTI | KIRUVATTI_110 | 8:34 | 13:05 | 4:31 | LOAD CHANGE OVER |
| 117 | 3-Apr-19 | BAGALKOT | 110 | MAHALINGAPUR-HIDIKAL | HIDIKAL_110 | 3:30 | 3:50 | 0:20 | HAND TRIPPED |
| 118 | 3-Apr-19 | BAGALKOT | 110 | MAHALINGAPUR-TERADAL | TERADAL_110 | 11:50 | 12:03 | 0:13 | HAND TRIPPED |
| 119 | 3-Apr-19 | BAGALKOT | 110 | 110/33KV, HV4 | ZALKI_110, NEVARGI_33, DHULKED_33 | 11:21 | 11:26 | 0:05 | TRANSFORMER FAULT |
| 120 | 3-Apr-19 | BAGALKOT | 110 | HUBLI220-KALGHATAGI | KALGHATAGI_110 | 10:08 | 12:54 | 2:46 | LINE FAULT |
| 121 | 3-Apr-19 | BAGALKOT | 110 | HUBLI220-KADANKOPPA | KADANKOPPA_110 | 10:14 | 12:55 | 2:41 | LINE CLEAR AVAILED |
| 122 | 3-Apr-19 | BAGALKOT | 110 | 220/110KV, LV3 | HUBLI_220 | 17:13 | 23:59 | 6:46 | LINE CLEAR AVAILED |
| 123 | 3-Apr-19 | BAGALKOT | 110 | SIRSI220-KAVALWADA | KAVALWADA_110 | 8:23 | 10:55 | 2:32 | LINE CLEAR AVAILED |
| 124 | 3-Apr-19 | BAGALKOT | 110 | SIRSI-KUMTA2 | SIRSI_110 | 10:30 | 13:10 | 2:40 | LINE CLEAR AVAILED |
| 125 | 3-Apr-19 | BAGALKOT | 110 | PG HUNSYAL-NAGNUR | NAGNUR_110 | 5:50 | 6:02 | 0:12 | LINE FAULT |
| 126 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV, HV2 | MAMDAPUR(B)_110 | 1:09 | 1:15 | 0:06 | TRANSFORMER FAULT |
| 127 | 3-Apr-19 | BAGALKOT | 110 | 110/11KV, HV2 | MAMDAPUR(B)_110 | 12:30 | 14:10 | 1:40 | LINE CLEAR AVAILED |
| 128 | 3-Apr-19 | BAGALKOT | 400 | GUTTUR-DHONI | DHONI_400 | 10:50 | 17:30 | 6:40 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|-----------------------------------|--|---------|-----------|----------|---------------------|
| 129 | 3-Apr-19 | BANGALORE | 66 | RMV - HEBBAL 220 | RMV, TATA INSTITUTE (EHT) | 13:30 | 16:33 | 3:03 | LOAD CHANGEOVER |
| 130 | 3-Apr-19 | BANGALORE | 220 | HV2 | TK HALLI 220 | 18:48 | 18:57 | 0:08 | TRANSFORMER FAULT |
| 131 | 3-Apr-19 | BANGALORE | 66 | TK HALLI 220 - AKKURMOLE | AKKURMOLE, IGGALUR, K HONALGERE | 18:48 | 18:57 | 0:08 | MAIN SUPPLY FAILURE |
| 132 | 3-Apr-19 | BANGALORE | 66 | TK HALLI 220 - MANDYA 1 | KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA | 18:48 | 19:00 | 0:11 | MAIN SUPPLY FAILURE |
| 133 | 3-Apr-19 | BANGALORE | 66 | HV2 | ATTUR YELAHANKA | 8:39 | 11:55 | 3:16 | TRANSFORMER FAULT |
| 134 | 3-Apr-19 | BANGALORE | 66 | SOLDEVANAHALLI - SRS PEENYA 220 | SOLDEVANAHALLI | 18:40 | 18:41 | 0:01 | LOAD CHANGEOVER |
| 135 | 3-Apr-19 | BANGALORE | 66 | GOKULA - HEBBAL 2 | RMV, TATA INSTITUTE (EHT) | 13:34 | 13:36 | 0:01 | LINE CLEAR AVAILED |
| 136 | 3-Apr-19 | BANGALORE | 66 | HANUMANTHANAGAR - KANAKAPURA 220 | HANUMANTHANAGAR | 14:00 | 14:10 | 0:10 | LOAD CHANGEOVER |
| 137 | 3-Apr-19 | BANGALORE | 66 | HANUMANTHANAGAR - YEDUMADU | HANUMANTHANAGAR | 16:10 | 16:20 | 0:10 | LOAD CHANGEOVER |
| 138 | 3-Apr-19 | BANGALORE | 66 | HV2 | LEELAVENTURE | 14:15 | 14:29 | 0:14 | TRANSFORMER FAULT |
| 139 | 3-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - NELEKADRINAHALLI | NELEKADRINAHALLI | 11:46 | 12:20 | 0:33 | LINE FAULT |
| 140 | 3-Apr-19 | BANGALORE | 66 | KOLAR 220 - SRINIVASPURA | DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR | 5:50 | 5:57 | 0:07 | LINE FAULT |
| 141 | 3-Apr-19 | BANGALORE | 66 | KOLAR 220 - VEMGAL | VEMGAL, KYALANUR | 22:44 | 22:58 | 0:14 | LOAD CURTAILMENT |
| 142 | 3-Apr-19 | BANGALORE | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 22:15 | 22:45 | 0:30 | LOAD CURTAILMENT |
| 143 | 3-Apr-19 | BANGALORE | 66 | KEMBODI - NANGLI | MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI | 2:10 | 2:19 | 0:09 | LINE FAULT |
| 144 | 3-Apr-19 | BANGALORE | 220 | LV1 | MALUR 220 | 6:03 | 6:29 | 0:26 | TRANSFORMER FAULT |
| 145 | 3-Apr-19 | BANGALORE | 66 | MALUR 220 - KGF 1 | KGF, TEKAL, BUDIKOTE, KAMASAMUDRA | 6:03 | 6:31 | 0:27 | MAIN SUPPLY FAILURE |
| 146 | 3-Apr-19 | BANGALORE | 66 | MALUR 220 - KGF 2 | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 6:03 | 6:34 | 0:31 | MAIN SUPPLY FAILURE |
| 147 | 3-Apr-19 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 6:03 | 6:31 | 0:27 | MAIN SUPPLY FAILURE |
| 148 | 3-Apr-19 | BANGALORE | 66 | HV2 | NANGLI | 10:45 | 11:37 | 0:52 | LINE CLEAR AVAILED |
| 149 | 3-Apr-19 | BANGALORE | 66 | YEDUMADU - SOMANAHALLI 220 | YEDUMADU | 14:00 | 14:15 | 0:15 | LOAD CHANGEOVER |
| 150 | 3-Apr-19 | BANGALORE | 66 | YEDUMADU - HANUMANTHNAGARA | YEDUMADU | 16:15 | 16:20 | 0:05 | LOAD CHANGEOVER |
| 151 | 3-Apr-19 | BANGALORE | 66 | YELAHANKA 220 - LINE 6 | SOLADEVANAHALLI | 16:30 | 17:20 | 0:49 | LINE FAULT |
| 152 | 3-Apr-19 | GULBARGA | 400 | BTPSG-RTPS | BTPSG_400 | 12:36 | 19:02 | 6:26 | LINE FAULT |
| 153 | 3-Apr-19 | GULBARGA | 220 | HV1 | RAICHUR_220 | 19:38 | 23:59 | 4:21 | TRANSFORMER FAULT |
| 154 | 3-Apr-19 | GULBARGA | 220 | HV2 | ALIPUR_220 | 14:50 | 17:29 | 2:39 | TRANSFORMER FAULT |
| 155 | 3-Apr-19 | GULBARGA | 220 | SHAHPUR-SEDAM | SEDAM_220 | 0:00 | 13:09 | 13:09 | LINE FAULT |
| 156 | 3-Apr-19 | GULBARGA | 110 | HV3 | KOLHAR_110 | 10:21 | 12:02 | 1:41 | LINE CLEAR AVAILED |
| 157 | 3-Apr-19 | GULBARGA | 110 | GURUGUNTA-LJVL_IPP | LJVL_IPP | 2:40 | 3:05 | 0:25 | LINE FAULT |
| 158 | 3-Apr-19 | GULBARGA | 110 | LINGASUGUR-GURUGUNTA | GURUGUNTA_110 | 10:50 | 13:30 | 2:40 | LINE CLEAR AVAILED |
| 159 | 3-Apr-19 | GULBARGA | 110 | HV1 | KAVITAL_110 | 7:40 | 7:56 | 0:16 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|----------------------------------|--|---------|-----------|----------|---------------------|
| 160 | 3-Apr-19 | GULBARGA | 110 | ALIPUR-MUNIRABAD | TORANGALLU_110,KUDITINI_110, KURUGOD_110, SHATAVANA_IPP, AGARWAL_IPP, SUZLON_IPP, KAMALAPUT_110 | 5:13 | 5:20 | 0:07 | LINE FAULT |
| 161 | 3-Apr-19 | GULBARGA | 110 | RAICHUR-SHAHPUR1 | GABUR_110, DEODURGA_110 | 19:50 | 21:39 | 1:49 | LINE FAULT |
| 162 | 3-Apr-19 | GULBARGA | 66 | HV1 | HAMPASAGAR_66 | 10:05 | 10:10 | 0:05 | TRANSFORMER FAULT |
| 163 | 3-Apr-19 | HASSAN | 220 | KEMAR-BAJPE2 | KEMAR_220 | 9:50 | 13:41 | 3:51 | NFBC ISSUED |
| 164 | 3-Apr-19 | HASSAN | 220 | KEMAR-PUTUR1 | KEMAR_220 | 10:30 | 14:30 | 4:00 | NFBC ISSUED |
| 165 | 3-Apr-19 | HASSAN | 220 | KEMAR-Varahi3 | KEMAR_220 | 0:00 | 15:12 | 15:12 | LINE CLEAR AVAILED |
| 166 | 3-Apr-19 | HASSAN | 110 | HV1 | KEMAR_220 | 1:26 | 1:59 | 0:33 | LINE CLEAR AVAILED |
| 167 | 3-Apr-19 | HASSAN | 66 | MRSSHM-DVG2 | MRSMSG_220 | 5:51 | 8:01 | 2:10 | LINE FAULT |
| 168 | 3-Apr-19 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 9:49 | 13:41 | 3:52 | LINE CLEAR AVAILED |
| 169 | 3-Apr-19 | HASSAN | 220 | PUTTUR-KEMAR1 | PUTTUR_220 | 10:31 | 14:30 | 3:59 | LINE CLEAR AVAILED |
| 170 | 3-Apr-19 | HASSAN | 220 | VARAHI-KEMAR3 | varahi_gen | 0:00 | 15:14 | 15:14 | NFBC ISSUED |
| 171 | 3-Apr-19 | HASSAN | 110 | HV1 | ARASIKERE_220 | 11:31 | 12:40 | 1:09 | LINE CLEAR AVAILED |
| 172 | 3-Apr-19 | HASSAN | 110 | HV3 | GURUVAYANAKERE_110 | 12:32 | 19:39 | 7:07 | LINE CLEAR AVAILED |
| 173 | 3-Apr-19 | HASSAN | 110 | MANIPAL-BRAMVR | MANIPAL_110 | 10:51 | 11:09 | 0:18 | HAND TRIPPED |
| 174 | 3-Apr-19 | HASSAN | 66 | BHADRALINGADAHALLI | bhadra_gen | 12:16 | 14:00 | 1:44 | LINE CLEAR AVAILED |
| 175 | 3-Apr-19 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 10:26 | 10:30 | 0:04 | HAND TRIPPED |
| 176 | 3-Apr-19 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 13:36 | 13:49 | 0:13 | HAND TRIPPED |
| 177 | 3-Apr-19 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 19:32 | 20:15 | 0:43 | HAND TRIPPED |
| 178 | 3-Apr-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHPUA_66 | 7:29 | 14:45 | 7:16 | LINE CLEAR AVAILED |
| 179 | 3-Apr-19 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESHPUA_66 | 7:29 | 14:45 | 7:16 | LINE CLEAR AVAILED |
| 180 | 3-Apr-19 | MYSORE | 66 | KR PETE 220-BOOKANKERE | BANANGADI_66 BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 | 2:14 | 2:24 | 0:10 | LINE FAULT |
| 181 | 3-Apr-19 | MYSORE | 66 | MIRLE-KR NAGARA | MIRLE_66 | 14:45 | 17:39 | 2:54 | LINE CLEAR AVAILED |
| 182 | 3-Apr-19 | MYSORE | 66 | HV1 | PANDAVAPURA_66 | 10:32 | 11:42 | 1:10 | LINE CLEAR AVAILED |
| 183 | 3-Apr-19 | TUMKUR | 110 | TR-1 | BANDIHALLI_110 | 11:35 | 11:54 | 0:18 | LINE CLEAR AVAILED |
| 184 | 3-Apr-19 | TUMKUR | 66 | BELLAVI-ANTHRASANAHALI | BELLAVI_66 | 2:26 | 2:32 | 0:05 | MAIN SUPPLY FAILURE |
| 185 | 3-Apr-19 | TUMKUR | 66 | TR-1 | CHANNAGIRI_66 | 11:48 | 17:23 | 5:35 | LINE CLEAR AVAILED |
| 186 | 3-Apr-19 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 11:48 | 15:49 | 4:00 | LINE CLEAR AVAILED |
| 187 | 3-Apr-19 | TUMKUR | 66 | CHANNAGIRI-(CHANNAGIRI(LINGDHLI) | CHANNAGIRI_66 | 8:06 | 8:08 | 0:02 | LINE FAULT |
| 188 | 3-Apr-19 | TUMKUR | 66 | CHANNAGIRI-(CHANNAGIRI(LINGDHLI) | CHANNAGIRI_66 | 10:32 | 16:37 | 6:04 | MAIN SUPPLY FAILURE |
| 189 | 3-Apr-19 | TUMKUR | 66 | CHIKKABANAGERE- GLOBAL TECKPARK | GLOBAL TECKPARK_IPP_66 | 8:42 | 9:10 | 0:28 | HAND TRIPPED |
| 190 | 3-Apr-19 | TUMKUR | 66 | CHIKKABANAGERE- HARIYABBE | CHIKKABANAGERE_66 | 8:42 | 9:02 | 0:20 | HAND TRIPPED |
| 191 | 3-Apr-19 | TUMKUR | 66 | TR-1 | CHIKKABANAGERE_66 | 8:42 | 9:04 | 0:21 | HAND TRIPPED |
| 192 | 3-Apr-19 | TUMKUR | 66 | DEVARAHALLI- CHANNAGIRI | DEVARAHALLI_66 | 10:35 | 15:44 | 5:08 | MAIN SUPPLY FAILURE |
| 193 | 3-Apr-19 | TUMKUR | 66 | TR-1 | DEVARAHALLI_66 | 10:35 | 15:44 | 5:08 | MAIN SUPPLY FAILURE |
| 194 | 3-Apr-19 | TUMKUR | 66 | DODDASARANGI- ANTHRASANAHALI | DODDASARANGI_66 | 11:59 | 12:04 | 0:05 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|-------------------------------|--|---------|-----------|----------|---------------------|
| 195 | 3-Apr-19 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 6:39 | 6:49 | 0:09 | LINE FAULT |
| 196 | 3-Apr-19 | TUMKUR | 66 | HONNALLI 220kV- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 9:24 | 9:32 | 0:08 | LINE FAULT |
| 197 | 3-Apr-19 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 0:42 | 0:56 | 0:13 | LINE FAULT |
| 198 | 3-Apr-19 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 10:03 | 15:39 | 5:35 | LINE CLEAR AVAILED |
| 199 | 3-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 12:18 | 15:39 | 3:21 | LINE CLEAR AVAILED |
| 200 | 3-Apr-19 | TUMKUR | 66 | TR-1 | KOLALA_66 | 16:46 | 17:38 | 0:52 | LINE CLEAR AVAILED |
| 201 | 3-Apr-19 | TUMKUR | 66 | LINGADAHALLI- SHIMOGA | LINGDHALLI_66 | 10:17 | 13:51 | 3:34 | LINE CLEAR AVAILED |
| 202 | 3-Apr-19 | TUMKUR | 66 | TR-1 | LINGDHALLI_66 | 20:19 | 20:21 | 0:02 | TRANSFORMER FAULT |
| 203 | 3-Apr-19 | TUMKUR | 66 | TR-2 | MALEBENNUR_66 | 18:53 | 19:12 | 0:18 | LINE CLEAR AVAILED |
| 204 | 3-Apr-19 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 12:01 | 15:04 | 3:03 | LINE CLEAR AVAILED |
| 205 | 4-Apr-19 | BAGALKOT | 110 | BAGALKOT220-NEERBUDHIHAL | NEERBUDHIHAL_110 | 17:51 | 18:33 | 0:42 | LINE FAULT |
| 206 | 4-Apr-19 | BAGALKOT | 110 | BAGALKOT220-NEERBUDHIHAL | NEERBUDHIHAL_110 | 23:05 | 23:53 | 0:48 | LINE FAULT |
| 207 | 4-Apr-19 | BAGALKOT | 110 | BAGEWADI220-MUDDEBIHAL | MUDDEBIHAL_110 | 21:29 | 23:00 | 1:31 | LINE CLEAR AVAILED |
| 208 | 4-Apr-19 | BAGALKOT | 220 | AMBEWADI-NARENDRA2 | AMBEWADI_220 | 11:05 | 23:59 | 12:54 | LINE CLEAR AVAILED |
| 209 | 4-Apr-19 | BAGALKOT | 110 | BELGAUM220-ANKALAGI | ANKALAGI_110 | 15:58 | 16:39 | 0:41 | LINE FAULT |
| 210 | 4-Apr-19 | BAGALKOT | 110 | GAJENDRAGAD-RON1 | GAJENDRAGAD_110 | 12:40 | 12:42 | 0:02 | HAND TRIPPED |
| 211 | 4-Apr-19 | BAGALKOT | 110 | GOPPANAKOPPA-NARGUND | GOPPANAKOPPA_110 | 12:09 | 12:12 | 0:03 | HAND TRIPPED |
| 212 | 4-Apr-19 | BAGALKOT | 110 | ITANAL-RAIBAG | ITANAL_110 | 22:58 | 23:15 | 0:17 | LINE FAULT |
| 213 | 4-Apr-19 | BAGALKOT | 110 | 110/33KV,HV2 | JAMKHANDI_110, HIPARGI_33 | 10:32 | 10:49 | 0:17 | TRANSFORMER FAULT |
| 214 | 4-Apr-19 | BAGALKOT | 110 | 110/33KV,HV3 | LOKAPUR_110, RSK_33, BATARKURKI_33 | 18:40 | 18:53 | 0:13 | TRANSFORMER FAULT |
| 215 | 4-Apr-19 | BAGALKOT | 110 | 110/33KV, HV4 | ZALKI_110, DHULKED_33, NEVARGI_33 | 10:05 | 10:15 | 0:10 | TRANSFORMER FAULT |
| 216 | 4-Apr-19 | BAGALKOT | 110 | 110/33KV, HV4 | ZALKI_110, DHULKED_33, NEVARGI_33 | 11:23 | 11:26 | 0:03 | TRANSFORMER FAULT |
| 217 | 4-Apr-19 | BAGALKOT | 110 | VAJRAMATTI220-MALLIGERI | MALLIGERI_110 | 10:08 | 10:14 | 0:06 | HAND TRIPPED |
| 218 | 4-Apr-19 | BAGALKOT | 110 | 110/33KV,HV2 | UTTUR_110,YADWAD_33KV,VANTAGODI_33KV | 23:54 | 23:59 | 0:05 | TRANSFORMER FAULT |
| 219 | 4-Apr-19 | BAGALKOT | 220 | 220/110KV,HV3,LV3 | HUBLI_220 | 10:14 | 12:28 | 2:14 | LINE CLEAR AVAILED |
| 220 | 4-Apr-19 | BAGALKOT | 220 | HUBLI-BIDNAL | HUBLI_220 | 10:19 | 13:07 | 2:48 | NFBC ISSUED |
| 221 | 4-Apr-19 | BAGALKOT | 220 | HUBLI-NAGJHARI2 | HUBLI_220 | 10:25 | 13:09 | 2:44 | LINE CLEAR AVAILED |
| 222 | 4-Apr-19 | BAGALKOT | 110 | SIRSI-JOG2 | SIRSI_110 | 14:14 | 14:29 | 0:15 | LINE CLEAR AVAILED |
| 223 | 4-Apr-19 | BAGALKOT | 110 | RON-GAJENDRAGAD2 | GAJENDRAGAD_110 | 11:51 | 23:59 | 12:08 | LINE CLEAR AVAILED |
| 224 | 4-Apr-19 | BAGALKOT | 110 | MAHALINGAPUR220-RANNABELAGALI | RANNABEGALI_110 | 8:55 | 13:07 | 4:12 | MAIN SUPPLY FAILURE |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|-----------------------------|--|---------|-----------|----------|--------------------|
| 225 | 4-Apr-19 | BAGALKOT | 110 | BALAGI SUGARS-MUDDEBIHAL | MUDDEBIHAL_110 | 23:04 | 23:15 | 0:11 | LINE FAULT |
| 226 | 4-Apr-19 | BAGALKOT | 110 | 110/11KV,HV3 | MUDALGI_110 | 16:32 | 16:42 | 0:10 | LINE CLEAR AVAILED |
| 227 | 4-Apr-19 | BAGALKOT | 110 | 110/11KV,HV1 | MAREGUDDI_110 | 20:04 | 20:06 | 0:02 | TRANSFORMER FAULT |
| 228 | 4-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | MAMADAPUR(B)_110 | 10:16 | 13:09 | 2:53 | LINE CLEAR AVAILED |
| 229 | 4-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | MAMADAPUR(B)_110 | 13:27 | 13:30 | 0:03 | TRANSFORMER FAULT |
| 230 | 4-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | MAMADAPUR(B)_110 | 14:09 | 14:10 | 0:01 | TRANSFORMER FAULT |
| 231 | 4-Apr-19 | BAGALKOT | 220 | MAHALINGAPUR-SOUDATTI | MAHALINGAPUR_220 | 17:08 | 18:05 | 0:57 | LINE FAULT |
| 232 | 4-Apr-19 | BAGALKOT | 220 | 220/110KV,LV3 | MAHALINGAPUR_220,HIDIKAL_110,ITNAL_110 | 17:08 | 20:36 | 3:28 | TRANSFORMER FAULT |
| 233 | 4-Apr-19 | BAGALKOT | 110 | MAHALINGAPUR-HIDIKAL | HIDIKAL_110 | 17:39 | 20:43 | 3:04 | LINE FAULT |
| 234 | 4-Apr-19 | BANGALORE | 66 | HV1 | ANDERSONPET | 6:03 | 6:07 | 0:04 | TRANSFORMER FAULT |
| 235 | 4-Apr-19 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 17:28 | 17:32 | 0:04 | LINE FAULT |
| 236 | 4-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 10:58 | 12:01 | 1:02 | LINE CLEAR AVAILED |
| 237 | 4-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 13:28 | 15:21 | 1:52 | LINE CLEAR AVAILED |
| 238 | 4-Apr-19 | BANGALORE | 66 | HV2 | HAROBEL | 10:58 | 12:01 | 1:02 | LINE CLEAR AVAILED |
| 239 | 4-Apr-19 | BANGALORE | 66 | HV2 | HAROBEL | 13:28 | 15:21 | 1:52 | LINE CLEAR AVAILED |
| 240 | 4-Apr-19 | BANGALORE | 66 | MALUR 220 - KGF 2 | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 6:03 | 6:08 | 0:05 | LINE FAULT |
| 241 | 4-Apr-19 | BANGALORE | 66 | HV2 | MANCHENAHALLI | 14:09 | 14:14 | 0:05 | TRANSFORMER FAULT |
| 242 | 4-Apr-19 | BANGALORE | 66 | HV1 | TK HALLI 220 | 14:29 | 14:35 | 0:06 | TRANSFORMER FAULT |
| 243 | 4-Apr-19 | BANGALORE | 66 | HV1 | BOODIGERE | 15:08 | 15:20 | 0:12 | TRANSFORMER FAULT |
| 244 | 4-Apr-19 | GULBARGA | 220 | HV2 | ALIPUR_220 | 12:50 | 12:54 | 0:04 | LINE CLEAR AVAILED |
| 245 | 4-Apr-19 | GULBARGA | 220 | HV1 | RAICHUR_220 | 8:20 | 10:16 | 1:56 | LINE CLEAR AVAILED |
| 246 | 4-Apr-19 | GULBARGA | 220 | HV2 | HALBURGA_220 | 16:57 | 17:00 | 0:03 | LINE CLEAR AVAILED |
| 247 | 4-Apr-19 | GULBARGA | 220 | HV2 | HALBURGA_220 | 20:16 | 20:22 | 0:06 | LINE CLEAR AVAILED |
| 248 | 4-Apr-19 | GULBARGA | 220 | HV2 | HALBURGA_220 | 23:24 | 23:30 | 0:06 | LINE CLEAR AVAILED |
| 249 | 4-Apr-19 | GULBARGA | 220 | LINGASUGUR-KUSHTAGI | KUSHTAGI_220 | 15:25 | 17:38 | 2:13 | LINE CLEAR AVAILED |
| 250 | 4-Apr-19 | GULBARGA | 220 | LINGASUGUR-KUSHTAGI | KUSTAGI_220 | 12:50 | 13:30 | 0:40 | LINE FAULT |
| 251 | 4-Apr-19 | GULBARGA | 220 | HUMNABAD-HALBARGA1 | HALBURGA_220 | 21:55 | 23:18 | 1:23 | LINE CLEAR AVAILED |
| 252 | 4-Apr-19 | GULBARGA | 220 | KAPNOOR-HUMNABAD1 | KAPNOOR_220 | 20:25 | 23:08 | 2:43 | LINE CLEAR AVAILED |
| 253 | 4-Apr-19 | GULBARGA | 220 | KAPNOOR-HUMNABAD2 | KAPNOOR_220 | 20:36 | 23:59 | 3:23 | LINE CLEAR AVAILED |
| 254 | 4-Apr-19 | GULBARGA | 220 | LINGASUGUR-RTPS1,2,3, | LINGASUGUR_220 | 12:48 | 13:10 | 0:22 | LINE CLEAR AVAILED |
| 255 | 4-Apr-19 | GULBARGA | 220 | KUSTAGI-SUZLON1,SUZLON2 | KUSTAGI_220 | 19:40 | 20:10 | 0:30 | LINE FAULT |
| 256 | 4-Apr-19 | GULBARGA | 110 | GULBARGA SOUTH-FARTHABAD | GULBARGASOUTH_110 | 15:12 | 15:40 | 0:28 | LINE FAULT |
| 257 | 4-Apr-19 | GULBARGA | 110 | KAPANOOR-HUMNABAD1 | MAHAGOAN_110,MARAGUTTI_110 | 11:08 | 11:14 | 0:06 | LINE FAULT |
| 258 | 4-Apr-19 | GULBARGA | 110 | HV1 | RAICHUR_220 | 11:30 | 11:40 | 0:10 | LINE CLEAR AVAILED |
| 259 | 4-Apr-19 | GULBARGA | 110 | HV1 | RAICHUR_220 | 12:20 | 12:50 | 0:30 | LINE CLEAR AVAILED |
| 260 | 4-Apr-19 | GULBARGA | 110 | HV1 | RAICHUR_220 | 0:01 | 0:07 | 0:06 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|---------------------------|--|---------|-----------|----------|---------------------|
| 261 | 4-Apr-19 | GULBARGA | 110 | RAICHUR-MATMARI | MATMARI_110 | 6:01 | 7:30 | 1:29 | LINE CLEAR AVAILED |
| 262 | 4-Apr-19 | GULBARGA | 110 | HALBURGA-SANTHAPUR | DONGRAGOA_110,SANTHAPUR_110,KAMALANAGAR_110 | 20:58 | 21:08 | 0:10 | LINE FAULT |
| 263 | 4-Apr-19 | GULBARGA | 110 | HALBURGA-SANTHAPUR | DONGRAGOA_110,SANTHAPUR_110,KAMALANAGAR_110 | 21:56 | 22:05 | 0:09 | LINE FAULT |
| 264 | 4-Apr-19 | GULBARGA | 110 | CHITAGUPPA-HUMNABAD | CHITGUPPA_110 | 18:15 | 18:30 | 0:15 | LINE FAULT |
| 265 | 4-Apr-19 | GULBARGA | 110 | HUMNABAD-CHITAGUPPA | CHITGUPPA_110 | 20:19 | 21:04 | 0:45 | LINE FAULT |
| 266 | 4-Apr-19 | GULBARGA | 110 | GURGUNTA-LINGASUGUR | GURGUNTA_110 | 21:40 | 21:55 | 0:15 | LINE FAULT |
| 267 | 4-Apr-19 | GULBARGA | 110 | GURGUNTA-LJVL_IPP | GURGUNTA_110 | 21:40 | 22:10 | 0:30 | LINE FAULT |
| 268 | 4-Apr-19 | GULBARGA | 110 | GURGUNTA-KHEL_IPP | GURGUNTA_110 | 21:40 | 23:59 | 2:19 | LINE FAULT |
| 269 | 4-Apr-19 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 16:55 | 19:12 | 2:17 | LINE FAULT |
| 270 | 4-Apr-19 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 20:16 | 21:26 | 1:10 | LINE FAULT |
| 271 | 4-Apr-19 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 23:32 | 23:59 | 0:27 | LINE FAULT |
| 272 | 4-Apr-19 | GULBARGA | 110 | MARAGUTTI-KAPNOOR | MARGUTTI_110 | 11:10 | 11:15 | 0:05 | MAIN SUPPLY FAILURE |
| 273 | 4-Apr-19 | GULBARGA | 110 | HV1 | HANUMASAGAR_110 | 9:45 | 10:00 | 0:15 | LINE CLEAR AVAILED |
| 274 | 4-Apr-19 | GULBARGA | 110 | KAPNOOR-GULBARGA NORTH1,2 | GULBARGANORTH_110,GULBARGAUNIVERSITY_110 | 18:13 | 18:29 | 0:16 | LINE FAULT |
| 275 | 4-Apr-19 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 4:26 | 4:31 | 0:05 | LINE FAULT |
| 276 | 4-Apr-19 | GULBARGA | 110 | MALLAT-ALKOD | ALOKD_110 | 5:50 | 5:55 | 0:05 | LINE FAULT |
| 277 | 4-Apr-19 | GULBARGA | 110 | SINDHANOOR-SIRIGUPPA | SIRIGUPPA_110,DHADESUGUR_110,TEKKALAKOTE_110 | 23:37 | 23:51 | 0:14 | LINE FAULT |
| 278 | 4-Apr-19 | GULBARGA | 110 | KUSTAGI-ILKAL1,2 | ILKAL_110 | 12:50 | 13:45 | 0:55 | LINE FAULT |
| 279 | 4-Apr-19 | GULBARGA | 110 | KUSTAGI-KANKAGIRI | GANADAL_110, KANAKAGIRI_110 | 12:50 | 14:00 | 1:10 | LINE FAULT |
| 280 | 4-Apr-19 | GULBARGA | 110 | KUSTAGI-YELBURGA | YELBURGA_110 | 12:50 | 14:00 | 1:10 | LINE FAULT |
| 281 | 4-Apr-19 | GULBARGA | 110 | KUSTAGI-ILKAL1,2 | ILKAL_110 | 17:45 | 19:45 | 2:00 | LINE FAULT |
| 282 | 4-Apr-19 | GULBARGA | 110 | KUSTAGI-KANKAGIRI | GANADAL_110, KANAKAGIRI_110 | 17:45 | 19:25 | 1:40 | LINE FAULT |
| 283 | 4-Apr-19 | GULBARGA | 110 | KUSTAGI-YELBURGA | YELBURGA_110 | 17:45 | 19:15 | 1:30 | LINE FAULT |
| 284 | 4-Apr-19 | HASSAN | 220 | GOPALPURA-BASTIPURA | GOPALAPURA_220 | 6:05 | 6:40 | 0:35 | LINE FAULT |
| 285 | 4-Apr-19 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 9:57 | 14:16 | 4:19 | LINE CLEAR AVAILED |
| 286 | 4-Apr-19 | HASSAN | 220 | KEMAR-BAJPE1 | KEMAR_220 | 9:43 | 14:18 | 4:35 | NFBC ISSUED |
| 287 | 4-Apr-19 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 15:27 | 16:41 | 1:14 | LINE FAULT |
| 288 | 4-Apr-19 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 15:27 | 16:48 | 1:21 | LINE FAULT |
| 289 | 4-Apr-19 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 15:24 | 16:41 | 1:17 | LINE FAULT |
| 290 | 4-Apr-19 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 15:24 | 16:41 | 1:17 | LINE FAULT |
| 291 | 4-Apr-19 | HASSAN | 110 | HV1 | BAIKAMPADI_110 | 11:10 | 13:33 | 2:23 | LINE CLEAR AVAILED |
| 292 | 4-Apr-19 | HASSAN | 110 | HV1 | ARASIKERE_220 | 15:57 | 17:50 | 1:53 | LINE CLEAR AVAILED |
| 293 | 4-Apr-19 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 18:48 | 18:58 | 0:10 | LINE FAULT |
| 294 | 4-Apr-19 | HASSAN | 110 | SORABA-SHR220 | SORABA_110 | 15:15 | 15:55 | 0:40 | LINE CLEAR AVAILED |
| 295 | 4-Apr-19 | HASSAN | 110 | SORABA-SHR220 | SORABA_110 | 23:20 | 23:27 | 0:07 | HAND TRIPPED |
| 296 | 4-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 11:15 | 12:05 | 0:50 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|---|--------------------------------|---------|-----------|----------|---------------------|
| 297 | 4-Apr-19 | HASSAN | 66 | HV1 | HANGARANAHALLY_66 | 6:05 | 11:20 | 5:15 | TRANSFORMER FAULT |
| 298 | 4-Apr-19 | HASSAN | 66 | HV1 | HANGARANAHALLY_66 | 17:23 | 23:59 | 6:36 | TRANSFORMER FAULT |
| 299 | 4-Apr-19 | HASSAN | 66 | HV2 | SINGAPURA_66 | 11:21 | 11:35 | 0:14 | TRANSFORMER FAULT |
| 300 | 4-Apr-19 | HASSAN | 66 | SIGEBAG-KDLGRE | SIGEBAGI_66 | 11:38 | 13:46 | 2:08 | LINE FAULT |
| 301 | 4-Apr-19 | HASSAN | 66 | HNPR2-HNPR1 | HOLENARASIPURA_220 | 13:03 | 13:15 | 0:12 | LINE FAULT |
| 302 | 4-Apr-19 | HASSAN | 66 | HNPR2-HNPR1 | HOLENARASIPURA_220 | 13:27 | 16:05 | 2:38 | LINE FAULT |
| 303 | 4-Apr-19 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 16:45 | 16:54 | 0:09 | LINE CLEAR AVAILED |
| 304 | 4-Apr-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHPUA_66 | 7:35 | 18:30 | 10:55 | LINE CLEAR AVAILED |
| 305 | 4-Apr-19 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESHPUA_66 | 7:35 | 18:30 | 10:55 | LINE CLEAR AVAILED |
| 306 | 4-Apr-19 | MYSORE | 66 | BOGADHI | BOGADHI_66 KALAMANDIRA_66 | 11:14 | 11:15 | 0:01 | HAND TRIPPED |
| 307 | 4-Apr-19 | MYSORE | 66 | BOGADHI | BOGADHI_66 KALAMANDIRA_66 | 13:07 | 13:09 | 0:01 | HAND TRIPPED |
| 308 | 4-Apr-19 | MYSORE | 66 | VIJAYANAGARA | BANNIMANTAP_66 VIJAYANAGARA_66 | 11:05 | 11:10 | 0:05 | HAND TRIPPED |
| 309 | 4-Apr-19 | MYSORE | 66 | VIJAYANAGARA | BANNIMANTAP_66 VIJAYANAGARA_66 | 13:12 | 13:14 | 0:02 | HAND TRIPPED |
| 310 | 4-Apr-19 | MYSORE | 66 | HV1 | HOOTAGALLY_220 | 11:20 | 11:28 | 0:07 | HAND TRIPPED |
| 311 | 4-Apr-19 | MYSORE | 66 | HV2 | HOOTAGALLY_220 | 11:19 | 11:28 | 0:09 | HAND TRIPPED |
| 312 | 4-Apr-19 | MYSORE | 66 | HV1 | HOOTAGALLY_220 | 13:19 | 13:21 | 0:01 | HAND TRIPPED |
| 313 | 4-Apr-19 | MYSORE | 66 | HV2 | HOOTAGALLY_220 | 13:19 | 13:21 | 0:01 | HAND TRIPPED |
| 314 | 4-Apr-19 | MYSORE | 66 | HV1 | PANDAVAPURA_66 | 7:12 | 7:20 | 0:07 | TRANSFORMER FAULT |
| 315 | 4-Apr-19 | MYSORE | 66 | HV3 | SFCSHIVA_66 | 17:22 | 23:59 | 6:36 | LINE CLEAR AVAILED |
| 316 | 4-Apr-19 | TUMKUR | 220 | THALLAK 220-HIRIYUR | HIRIYUR_220 | 5:31 | 11:21 | 5:49 | LINE CLEAR AVAILED |
| 317 | 4-Apr-19 | TUMKUR | 220 | THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66 | SEL DIAMOND SOLAR_IPP_66 | 9:18 | 13:45 | 4:27 | LINE CLEAR AVAILED |
| 318 | 4-Apr-19 | TUMKUR | 110 | SHETTIKERE- HANDANKERE | SHETYKERE_110 | 10:24 | 10:30 | 0:05 | LINE CLEAR AVAILED |
| 319 | 4-Apr-19 | TUMKUR | 66 | TR-1 | AMRUTHUR_66 | 13:33 | 15:24 | 1:50 | LINE CLEAR AVAILED |
| 320 | 4-Apr-19 | TUMKUR | 66 | TR-1 | CHANNAGIRI_66 | 18:29 | 18:32 | 0:02 | TRANSFORMER FAULT |
| 321 | 4-Apr-19 | TUMKUR | 66 | CHITRADURGA 66kV- CHITRADURGA 1 | CHITRADURGA_66 | 12:22 | 12:48 | 0:25 | LINE CLEAR AVAILED |
| 322 | 4-Apr-19 | TUMKUR | 66 | TR-2 | HINDASGHATTA_66 | 10:41 | 11:37 | 0:55 | HAND TRIPPED |
| 323 | 4-Apr-19 | TUMKUR | 66 | TR-1 | HIREGUNTANUR_66 | 18:10 | 18:23 | 0:13 | TRANSFORMER FAULT |
| 324 | 4-Apr-19 | TUMKUR | 66 | TR-1 | MALLASANDRA_66 | 21:03 | 21:05 | 0:02 | TRANSFORMER FAULT |
| 325 | 4-Apr-19 | TUMKUR | 66 | TR-1 | SAVALANGA_66 | 13:08 | 13:36 | 0:28 | MAIN SUPPLY FAILURE |
| 326 | 4-Apr-19 | TUMKUR | 66 | THALLAK 220kV- CHALLAKERE 1 | CHALLAKERE_66, SANIKERE_66 | 18:48 | 18:59 | 0:10 | HAND TRIPPED |
| 327 | 4-Apr-19 | TUMKUR | 66 | TR-1 | THALLAKK_220 | 18:37 | 18:45 | 0:07 | TRANSFORMER FAULT |
| 328 | 4-Apr-19 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 12:46 | 12:54 | 0:08 | LINE FAULT |
| 329 | 5-Apr-19 | BAGALKOT | 220 | PONDA2-AMBEWADI | AMBEWADI_220 | 1:12 | 23:59 | 22:47 | LINE FAULT |
| 330 | 5-Apr-19 | BAGALKOT | 220 | AMBEWADI-NARENDRA 2 | AMBEWADI_220 | 0:00 | 15:19 | 15:19 | LINE CLEAR AVAILED |
| 331 | 5-Apr-19 | BAGALKOT | 220 | AMBEWADI-NARENDRA 2 | AMBEWADI_220 | 17:32 | 23:59 | 6:27 | LINE CLEAR AVAILED |
| 332 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV1 | BAGALKOT_110 | 13:19 | 13:24 | 0:05 | HAND TRIPPED |
| 333 | 5-Apr-19 | BAGALKOT | 220 | BIDNAL-HIREBENDIGERI 1&2 | BIDNAL_220 | 10:30 | 15:45 | 5:15 | NFBC ISSUED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|----------------------|---------------------------------------|---------|-----------|----------|--------------------|
| 334 | 5-Apr-19 | BAGALKOT | 220 | BIDNAL-HARTI 1 | BIDNAL_220 | 16:28 | 17:32 | 1:04 | LINE FAULT |
| 335 | 5-Apr-19 | BAGALKOT | 220 | BIDNAL-HAVERI | BIDNAL_220 | 17:13 | 18:21 | 1:08 | LINE FAULT |
| 336 | 5-Apr-19 | BAGALKOT | 220 | BELGAUM-NARENDRA 2 | BELGAUM_220 | 14:34 | 15:04 | 0:30 | LINE FAULT |
| 337 | 5-Apr-19 | BAGALKOT | 220 | BELGAUM-NARENDRA 1 | BELGAUM_220 | 14:35 | 14:57 | 0:22 | LINE FAULT |
| 338 | 5-Apr-19 | BAGALKOT | 220 | BELGAUM-CHIKKODI 2 | BELGAUM_220 | 14:34 | 16:38 | 2:04 | LINE CLEAR AVAILED |
| 339 | 5-Apr-19 | BAGALKOT | 220 | BELGAUM-CHIKKODI 1 | BELGAUM_220 | 15:06 | 16:38 | 1:32 | LINE CLEAR AVAILED |
| 340 | 5-Apr-19 | BAGALKOT | 110 | BELGAUM220-KANABARGI | KANABARGI_110 | 14:34 | 14:35 | 0:01 | HAND TRIPPED |
| 341 | 5-Apr-19 | BAGALKOT | 110 | ESALE1-SIRSI | SIRSI_110 | 3:06 | 4:43 | 1:37 | LINE FAULT |
| 342 | 5-Apr-19 | BAGALKOT | 110 | ESALE1-SIRSI | SIRSI_110 | 21:29 | 21:39 | 0:10 | HAND TRIPPED |
| 343 | 5-Apr-19 | BAGALKOT | 110 | ESALE2-SIRIS | SIRSI_110 | 3:06 | 4:43 | 1:37 | LINE FAULT |
| 344 | 5-Apr-19 | BAGALKOT | 110 | ESALE2-SIRIS | SIRSI_110 | 21:29 | 21:39 | 0:10 | HAND TRIPPED |
| 345 | 5-Apr-19 | BAGALKOT | 110 | SIRSI-KUMTA1 | SIRSI_110 | 4:43 | 11:54 | 7:11 | LINE FAULT |
| 346 | 5-Apr-19 | BAGALKOT | 110 | SIRSI-KUMTA2 | SIRSI_110 | 4:43 | 4:59 | 0:16 | HAND TRIPPED |
| 347 | 5-Apr-19 | BAGALKOT | 110 | SIRSI-KUMTA2 | SIRSI_110 | 8:50 | 11:54 | 3:04 | LINE CLEAR AVAILED |
| 348 | 5-Apr-19 | BAGALKOT | 110 | RON-GAJEDRAGADA2 | GAJENDRAGAD_110 | 0:00 | 14:44 | 14:44 | LINE CLEAR AVAILED |
| 349 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | RANNABELAGALI_110 | 11:18 | 12:11 | 0:53 | TRANSFORMER FAULT |
| 350 | 5-Apr-19 | BAGALKOT | 110 | 110/33KV,HV2 | MURDESHWAR_110 | 12:55 | 14:39 | 1:44 | TRANSFORMER FAULT |
| 351 | 5-Apr-19 | BAGALKOT | 220 | HUBLI-NARENDRA1 | HUBLI_220 | 17:24 | 22:15 | 4:51 | LINE FAULT |
| 352 | 5-Apr-19 | BAGALKOT | 220 | NAGJHARI3-HUBLI | HUBLI_220 | 17:39 | 22:11 | 4:32 | LINE FAULT |
| 353 | 5-Apr-19 | BAGALKOT | 110 | HUBLI-KALGHATAGI | KALGHATAGI_110 | 3:08 | 4:02 | 0:54 | LINE FAULT |
| 354 | 5-Apr-19 | BAGALKOT | 110 | HUBLI-BIDNAL2 | HUBLI_220 | 14:24 | 23:59 | 9:35 | LINE CLEAR AVAILED |
| 355 | 5-Apr-19 | BAGALKOT | 110 | HUBLI-KALGHATAGI | KALGHATAGI_110 | 17:26 | 20:03 | 2:37 | LINE FAULT |
| 356 | 5-Apr-19 | BAGALKOT | 110 | HUBLI-KALGHATAGI | KALGHATAGI_110 | 21:14 | 23:59 | 2:45 | LINE CLEAR AVAILED |
| 357 | 5-Apr-19 | BAGALKOT | 110 | HUBLI-KADANKOPPA | KADANKOPPA_110 | 21:11 | 23:59 | 2:48 | LINE CLEAR AVAILED |
| 358 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV, HV1 | MAREGUDDI_110 | 9:24 | 13:55 | 4:31 | LINE CLEAR AVAILED |
| 359 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | YARAGATTI_110 | 12:22 | 12:28 | 0:06 | TRANSFORMER FAULT |
| 360 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | YARAGATTI_110 | 18:16 | 18:46 | 0:30 | TRANSFORMER FAULT |
| 361 | 5-Apr-19 | BAGALKOT | 110 | 110/33KV,HV2 | UTTUR_110,YADWAD_33KV,VANTAGODI_33KV | 0:00 | 0:36 | 0:36 | LINE CLEAR AVAILED |
| 362 | 5-Apr-19 | BAGALKOT | 220 | 220/110,KV,HV1,LV1 | SOUDATTI_220 | 17:52 | 18:41 | 0:49 | LINE CLEAR AVAILED |
| 363 | 5-Apr-19 | BAGALKOT | 220 | SOUDATTI-BIDNAL | SOUDATTI_220 | 15:03 | 16:28 | 1:25 | LINE FAULT |
| 364 | 5-Apr-19 | BAGALKOT | 110 | SIRSI220-SIRSI1 | SIRSI_110 | 3:58 | 4:12 | 0:14 | HAND TRIPPED |
| 365 | 5-Apr-19 | BAGALKOT | 110 | SIRSI220-SIRSI1 | SIRSI_110 | 14:37 | 14:42 | 0:05 | HAND TRIPPED |
| 366 | 5-Apr-19 | BAGALKOT | 110 | SIRSI220-SIRSI1 | SIRSI_110 | 14:48 | 15:37 | 0:49 | LINE CLEAR AVAILED |
| 367 | 5-Apr-19 | BAGALKOT | 110 | SIRSI220-KAVALWADA | KAVALWADA_110 | 20:34 | 21:05 | 0:31 | LINE CLEAR AVAILED |
| 368 | 5-Apr-19 | BAGALKOT | 110 | SIRSI220-KAVALWADA | KAVALWADA_110 | 21:25 | 21:49 | 0:24 | LINE CLEAR AVAILED |
| 369 | 5-Apr-19 | BAGALKOT | 110 | GAJENDRAGAD-RON 2 | GAJENDRAGAD_110 AND 33KV WIND 1,2,3&4 | 14:14 | 14:45 | 0:31 | HAND TRIPPED |
| 370 | 5-Apr-19 | BAGALKOT | 110 | GAJENDRAGAD-RON 1 | GAJENDRAGAD_110 | 14:18 | 14:36 | 0:18 | HAND TRIPPED |
| 371 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | GHATAPRABHA_110 | 6:27 | 6:30 | 0:03 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|---------------------------------|--|---------|-----------|----------|---------------------|
| 372 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | GOKAK_110 | 15:11 | 16:38 | 1:27 | TRANSFORMER FAULT |
| 373 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | GOKAK_110 | 18:48 | 19:02 | 0:14 | HAND TRIPPED |
| 374 | 5-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | HALIYAL_110 | 3:07 | 3:43 | 0:36 | TRANSFORMER FAULT |
| 375 | 5-Apr-19 | BAGALKOT | 110 | HALIYAL-GMR | HALIYAL_110 | 3:07 | 3:54 | 0:47 | MAIN SUPPLY FAILURE |
| 376 | 5-Apr-19 | BAGALKOT | 110 | ITANAL-HIDIKAL 2 | ITANAL_110 | 1:52 | 2:14 | 0:22 | LINE FAULT |
| 377 | 5-Apr-19 | BAGALKOT | 110 | ITANAL-RAIBAG 2 | ITANAL_110 | 1:58 | 2:14 | 0:16 | LINE FAULT |
| 378 | 5-Apr-19 | BAGALKOT | 110 | ITANAL-HIDIKAL 2 | ITANAL_110 | 17:45 | 17:56 | 0:11 | LINE FAULT |
| 379 | 5-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KADANAKOPPA_110 | 3:18 | 3:40 | 0:22 | LINE FAULT |
| 380 | 5-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KADANAKOPPA_110 | 4:15 | 4:30 | 0:15 | LINE FAULT |
| 381 | 5-Apr-19 | BAGALKOT | 110 | BAGALKOT-KALADAGI | KALADAGI_110 | 10:35 | 11:30 | 0:55 | LINE CLEAR AVAILED |
| 382 | 5-Apr-19 | BAGALKOT | 110 | KAVALAWAD-HUBLI-KALAGHATGI | KALAGHATGI_110 | 21:13 | 23:59 | 2:46 | LINE FAULT |
| 383 | 5-Apr-19 | BAGALKOT | 110 | KIRUVATTI-UMACHAGI(SIRSI) | KIRUVATTI_110 | 4:27 | 9:25 | 4:58 | LOAD CHANGEVER |
| 384 | 5-Apr-19 | BAGALKOT | 110 | KIRUVATTI-SIRSI(AMBEWADI) | KIRUVATTI_110 | 18:00 | 19:06 | 1:06 | LINE FAULT |
| 385 | 5-Apr-19 | BAGALKOT | 110 | KIRUVATTI-SIRSI(AMBEWADI) | KIRUVATTI_110 | 21:40 | 21:45 | 0:05 | LOAD CHANGEVER |
| 386 | 5-Apr-19 | BANGALORE | 66 | ADUGODI - HSR LAYOUT 2 | ADUGODI, BOSCH (EHT) | 14:30 | 14:35 | 0:05 | LINE CLEAR AVAILED |
| 387 | 5-Apr-19 | BANGALORE | 66 | ADUGODI - BOSCH (EHT) | BOSCH (EHT) | 13:08 | 13:55 | 0:47 | LINE CLEAR AVAILED |
| 388 | 5-Apr-19 | BANGALORE | 66 | HV2 | VICTORIA | 16:18 | 16:28 | 0:10 | LINE CLEAR AVAILED |
| 389 | 5-Apr-19 | BANGALORE | 66 | HOODY 220 - GRAPHITE INDIA(EHT) | GRAPHITE INDIA(EHT) | 10:22 | 17:24 | 7:01 | LINE CLEAR AVAILED |
| 390 | 5-Apr-19 | BANGALORE | 66 | SOMANAHALLI 220 - S B PURA 1 | SUBRAMANYAPURA 66, ISKON | 7:34 | 7:57 | 0:22 | LINE FAULT |
| 391 | 5-Apr-19 | BANGALORE | 66 | HAL 220 - ADUGODI 2 | AMARAJYOTHI, GOLFLINKS | 12:02 | 12:19 | 0:17 | LINE FAULT |
| 392 | 5-Apr-19 | BANGALORE | 66 | HV2 | AMARAJYOTHI | 12:28 | 12:30 | 0:01 | LOAD CHANGEVER |
| 393 | 5-Apr-19 | BANGALORE | 66 | HV1 | BANGARPET | 13:00 | 14:51 | 1:50 | LINE CLEAR AVAILED |
| 394 | 5-Apr-19 | BANGALORE | 66 | HV2 | BANGARPET | 13:00 | 14:51 | 1:50 | LINE CLEAR AVAILED |
| 395 | 5-Apr-19 | BANGALORE | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA | 14:09 | 14:13 | 0:03 | LINE FAULT |
| 396 | 5-Apr-19 | BANGALORE | 66 | HV2 | DEVANAGUNDI | 13:02 | 13:25 | 0:23 | LINE CLEAR AVAILED |
| 397 | 5-Apr-19 | BANGALORE | 66 | HV1 | HULLENHALLI | 7:30 | 8:06 | 0:35 | LINE CLEAR AVAILED |
| 398 | 5-Apr-19 | BANGALORE | 66 | KOLAR 220 - NANGLI | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI | 15:15 | 15:21 | 0:05 | LINE FAULT |
| 399 | 5-Apr-19 | BANGALORE | 66 | HV1 | KEMBODI | 15:52 | 15:53 | 0:01 | LINE CLEAR AVAILED |
| 400 | 5-Apr-19 | BANGALORE | 66 | HV2 | KEMBODI | 15:50 | 16:45 | 0:55 | TRANSFORMER FAULT |
| 401 | 5-Apr-19 | BANGALORE | 66 | MALUR 220 - MAASTHI | LAKKUR, DEVANAGONDHI, MAASTHI | 5:47 | 5:53 | 0:06 | LINE FAULT |
| 402 | 5-Apr-19 | BANGALORE | 66 | KANASAWADI - YELAHANKA 220 | KANASAWADI | 10:15 | 10:20 | 0:05 | LOAD CHANGEVER |
| 403 | 5-Apr-19 | BANGALORE | 66 | KANASAWADI - DB PURA 220 | KANASAWADI | 15:50 | 15:55 | 0:05 | LOAD CHANGEVER |
| 404 | 5-Apr-19 | GULBARGA | 220 | KAPNOOR-HUMNABAD2 | KAPNOOR_220 | 0:00 | 9:02 | 9:02 | LINE CLEAR AVAILED |
| 405 | 5-Apr-19 | GULBARGA | 110 | KAPNOOR-GULBARGA WEST | GULBARGA_WEST_110 | 1:46 | 1:55 | 0:09 | LINE FAULT |
| 406 | 5-Apr-19 | GULBARGA | 110 | HV2 | YELBURGA_110 | 9:13 | 9:23 | 0:10 | TRANSFORMER FAULT |
| 407 | 5-Apr-19 | GULBARGA | 110 | MALLAT-MADLAPUR | MADLAPUR_110 | 5:55 | 6:00 | 0:05 | LINE FAULT |
| 408 | 5-Apr-19 | GULBARGA | 110 | SHAHPUR-KEMBHAVI | KEMBHAVI_110 | 6:30 | 6:40 | 0:10 | LINE FAULT |
| 409 | 5-Apr-19 | GULBARGA | 110 | SHAHPUR-KEMBHAVI | KEMBHAVI_110 | 12:30 | 12:35 | 0:05 | LINE FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|-----------------------|---|---------|-----------|----------|--------------------|
| 410 | 5-Apr-19 | GULBARGA | 110 | HV2 | KEMBHAVI_110 | 14:00 | 14:30 | 0:30 | LINE CLEAR AVAILED |
| 411 | 5-Apr-19 | GULBARGA | 110 | HV2 | KEMBHAVI_110 | 14:40 | 15:20 | 0:40 | LINE CLEAR AVAILED |
| 412 | 5-Apr-19 | GULBARGA | 110 | GURGUNTA-KHEL_IPP | GURGUNTA_110 | 0:00 | 10:04 | 10:04 | LINE FAULT |
| 413 | 5-Apr-19 | GULBARGA | 110 | HV2 | HATTI_110 | 16:44 | 16:52 | 0:08 | TRANSFORMER FAULT |
| 414 | 5-Apr-19 | GULBARGA | 66 | HV1 | KOTTUR_66 | 11:55 | 12:03 | 0:08 | TRANSFORMER FAULT |
| 415 | 5-Apr-19 | GULBARGA | 66 | HV3 | HAGRIBOMMANAHALLI_66 | 16:00 | 16:10 | 0:10 | TRANSFORMER FAULT |
| 416 | 5-Apr-19 | GULBARGA | 220 | HV2,LV2 | HALBARGA_220 | 18:57 | 19:05 | 0:08 | TRANSFORMER FAULT |
| 417 | 5-Apr-19 | GULBARGA | 110 | HV2 | HATTI_110 | 17:40 | 17:45 | 0:05 | TRANSFORMER FAULT |
| 418 | 5-Apr-19 | GULBARGA | 110 | MASKI-HATTI | HATTI_110 | 21:49 | 21:57 | 0:08 | LINE FAULT |
| 419 | 5-Apr-19 | GULBARGA | 220 | HUMNABAD-SEDAM1 | SEDAM_220 | 19:01 | 20:41 | 1:40 | LINE FAULT |
| 420 | 5-Apr-19 | GULBARGA | 220 | HUMNABAD-SEDAM2 | SEDAM_220 | 19:01 | 20:50 | 1:49 | LINE FAULT |
| 421 | 5-Apr-19 | GULBARGA | 220 | HV1 | SEDAM_220 | 19:01 | 19:45 | 0:44 | TRANSFORMER FAULT |
| 422 | 5-Apr-19 | HASSAN | 110 | HV1 | BAIKAMPADY_110 | 10:05 | 13:38 | 3:33 | LINE CLEAR AVAILED |
| 423 | 5-Apr-19 | HASSAN | 110 | BANTWA-KAVOOR | BANTWAL_110 | 10:49 | 10:55 | 0:06 | HAND TRIPPED |
| 424 | 5-Apr-19 | HASSAN | 110 | BANTWA-KAVOOR | BANTWAL_110 | 17:08 | 17:12 | 0:04 | HAND TRIPPED |
| 425 | 5-Apr-19 | HASSAN | 66 | HV2 | CHIKMAGALUR_66 | 11:00 | 11:21 | 0:21 | HAND TRIPPED |
| 426 | 5-Apr-19 | HASSAN | 110 | HV1 | GURUVAYANAKERE_110 | 16:21 | 16:42 | 0:21 | TRANSFORMER FAULT |
| 427 | 5-Apr-19 | HASSAN | 110 | HV2 | GURUVAYANAKERE_110 | 13:12 | 14:38 | 1:26 | LINE CLEAR AVAILED |
| 428 | 5-Apr-19 | HASSAN | 66 | HV1 | HANGRANAHALLY_66 | 0:00 | 12:05 | 12:05 | TRANSFORMER FAULT |
| 429 | 5-Apr-19 | HASSAN | 66 | HV1 | HOLALUR_66 | 13:31 | 14:27 | 0:56 | LINE CLEAR AVAILED |
| 430 | 5-Apr-19 | HASSAN | 66 | HV2 | KANDLI_66 | 10:02 | 12:13 | 2:11 | LINE CLEAR AVAILED |
| 431 | 5-Apr-19 | HASSAN | 110 | KAVOOR-GURUPURA | KAVOOR_220 | 10:51 | 10:54 | 0:03 | HAND TRIPPED |
| 432 | 5-Apr-19 | HASSAN | 110 | KAVOOR-GURUPURA | KAVOOR_220 | 17:09 | 17:10 | 0:01 | HAND TRIPPED |
| 433 | 5-Apr-19 | HASSAN | 220 | KEMAR-Kavoor1 | KEMAR_220 | 9:35 | 13:35 | 4:00 | NFBC ISSUED |
| 434 | 5-Apr-19 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 13:39 | 14:37 | 0:58 | LINE CLEAR AVAILED |
| 435 | 5-Apr-19 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 9:35 | 13:36 | 4:01 | LINE CLEAR AVAILED |
| 436 | 5-Apr-19 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 13:39 | 14:37 | 0:58 | LINE CLEAR AVAILED |
| 437 | 5-Apr-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESH PURA_66 | 8:02 | 19:44 | 11:42 | LINE CLEAR AVAILED |
| 438 | 5-Apr-19 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESH PURA_66 | 8:02 | 19:44 | 11:42 | LINE CLEAR AVAILED |
| 439 | 5-Apr-19 | HASSAN | 66 | HV1 | SIGEBAGE_66 | 9:29 | 10:03 | 0:34 | LINE CLEAR AVAILED |
| 440 | 5-Apr-19 | MYSORE | 66 | BG NAGARA-NAGAMANGALA | ADICHUNCHANAGIRI_66 BGNAGARA_66 VADERALLI_66 | 12:39 | 12:53 | 0:13 | HAND TRIPPED |
| 441 | 5-Apr-19 | MYSORE | 66 | HOOTAGALLI-ELAWALA | ELAVALA_66 GAVADAGERE_66 | 6:48 | 23:59 | 17:10 | LINE FAULT |
| 442 | 5-Apr-19 | MYSORE | 66 | HOOTAGALLI-HUNSUR | BANNIKUPPE_66 HOSURGATE_66 HANAGODU_66 HUNSUR_66 | 6:48 | 7:10 | 0:21 | LINE FAULT |
| 443 | 5-Apr-19 | MYSORE | 66 | HV2 | HUNSUR_66 | 11:34 | 11:44 | 0:10 | TRANSFORMER FAULT |
| 444 | 5-Apr-19 | MYSORE | 66 | HV2 | HUNSUR_66 | 11:44 | 16:31 | 4:46 | TRANSFORMER FAULT |
| 445 | 5-Apr-19 | MYSORE | 66 | HV1 | K_HONNALGERE_66 | 6:44 | 6:56 | 0:11 | HAND TRIPPED |
| 446 | 5-Apr-19 | MYSORE | 66 | HV2 | K_HONNALGERE_66 | 6:44 | 6:50 | 0:05 | HAND TRIPPED |
| 447 | 5-Apr-19 | MYSORE | 66 | HV1 | MADDUR_66 | 6:45 | 6:55 | 0:10 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|--|---|---------|-----------|----------|-------------------|
| 448 | 5-Apr-19 | MYSORE | 66 | HV2 | MADDUR_66 | 6:45 | 6:57 | 0:12 | HAND TRIPPED |
| 449 | 5-Apr-19 | MYSORE | 66 | HV2 | TERAKANAMBE_66 | 2:33 | 2:54 | 0:20 | TRANSFORMER FAULT |
| 450 | 5-Apr-19 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66 | 17:12 | 17:18 | 0:06 | LINE FAULT |
| 451 | 5-Apr-19 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 1 | ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66 | 18:32 | 19:40 | 1:08 | LINE CLEAR AVAIED |
| 452 | 5-Apr-19 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66 | 17:48 | 19:34 | 1:45 | LINE CLEAR AVAIED |
| 453 | 5-Apr-19 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | MRSMG_220 | 11:25 | 15:57 | 4:31 | LINE FAULT |
| 454 | 5-Apr-19 | TUMKUR | 220 | THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66 | SEL DIAMOND SOLAR_IPP_66 | 12:06 | 12:40 | 0:34 | HAND TRIPPED |
| 455 | 5-Apr-19 | TUMKUR | 220 | THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66 | SEL DIAMOND SOLAR_IPP_66 | 4:12 | 12:05 | 7:52 | LINE CLEAR AVAIED |
| 456 | 5-Apr-19 | TUMKUR | 66 | TR-1 | CHITRADURGA_66 | 14:22 | 14:48 | 0:25 | LINE CLEAR AVAIED |
| 457 | 5-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 10:08 | 10:13 | 0:04 | LINE FAULT |
| 458 | 5-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 15:30 | 15:41 | 0:10 | LINE FAULT |
| 459 | 5-Apr-19 | TUMKUR | 66 | YEDIYUR- BG NAGARA | BGNAGARA_66 | 18:03 | 19:39 | 1:35 | LINE CLEAR AVAIED |
| 460 | 6-Apr-19 | BAGALKOT | 220 | BAGEWADI-BIJAPUR2 | BAGEWADI_220 | 2:21 | 2:55 | 0:34 | LINE FAULT |
| 461 | 6-Apr-19 | BAGALKOT | 110 | BAGEWADI220-MUDEBIHAL | MUDEBIHAL_110 | 2:47 | 2:54 | 0:07 | LINE FAULT |
| 462 | 6-Apr-19 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 20:01 | 23:59 | 3:58 | LINE FAULT |
| 463 | 6-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | SHIRGOAN_110 | 16:58 | 17:00 | 0:02 | TRANSFORMER FAULT |
| 464 | 6-Apr-19 | BAGALKOT | 110 | BPCL-NARGUND | NARGUND_110 | 20:37 | 20:40 | 0:03 | LINE FAULT |
| 465 | 6-Apr-19 | BAGALKOT | 110 | HUBLI-KALGHATAGI | KALGHATAGI_110 | 0:00 | 1:17 | 1:17 | LINE CLEAR AVAIED |
| 466 | 6-Apr-19 | BAGALKOT | 110 | HUBLI-KADANKOPPA | KADANKOPPA_110 | 0:00 | 1:18 | 1:18 | LINE CLEAR AVAIED |
| 467 | 6-Apr-19 | BAGALKOT | 110 | HUBLI-BIDNAL2 | HUBLI_220 | 0:00 | 13:53 | 13:53 | LINE CLEAR AVAIED |
| 468 | 6-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | MUNDAGOD_110 | 6:10 | 7:33 | 1:23 | LINE CLEAR AVAIED |
| 469 | 6-Apr-19 | BAGALKOT | 110 | 110/33KV,HV2 | MUNAVALLI_110, MALLUR_33, MUNAVALLY_33 | 20:13 | 20:42 | 0:29 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|---------------------------------|--|---------|-----------|----------|--------------------|
| 470 | 6-Apr-19 | BAGALKOT | 110 | MKHUBLI220-HIREBAGEWADI | HIREBAGEWADI_110 | 20:38 | 23:59 | 3:21 | LINE CLEAR AVAILED |
| 471 | 6-Apr-19 | BAGALKOT | 110 | 220/110KV, LV2 | MKHUBLI_220 | 20:40 | 20:47 | 0:07 | HAND TRIPPED |
| 472 | 6-Apr-19 | BAGALKOT | 110 | 110/11KV, HV4 | LAKMANHALLI_110,ALNAVAR_33,UBG_33 | 20:15 | 20:35 | 0:20 | TRANSFORMER FAULT |
| 473 | 6-Apr-19 | BAGALKOT | 110 | KUDACHI220-MORAB | MORAB_110 | 9:54 | 17:19 | 7:25 | LINE CLEAR AVAILED |
| 474 | 6-Apr-19 | BAGALKOT | 220 | HAVERI220-NARENDRA2 | HAVERI_220 | 20:40 | 23:59 | 3:19 | LINE FAULT |
| 475 | 6-Apr-19 | BAGALKOT | 220 | NARENDRA-AMBEWADI1 | NARENDRA_220 | 20:51 | 23:59 | 3:08 | LINE FAULT |
| 476 | 6-Apr-19 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,NEVARGI_33KV,DHULKED_33KV | 0:05 | 0:14 | 0:09 | TRANSFORMER FAULT |
| 477 | 6-Apr-19 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,NEVARGI_33KV,DHULKED_33KV | 1:14 | 1:22 | 0:08 | TRANSFORMER FAULT |
| 478 | 6-Apr-19 | BAGALKOT | 110 | VAJRAMATTI220-KATARKI | KATARKI_110 | 15:28 | 15:40 | 0:12 | LINE CLEAR AVAILED |
| 479 | 6-Apr-19 | BAGALKOT | 220 | SOUDATTI-BIDNAL | SOUDATTI_220 | 20:10 | 23:59 | 3:49 | LINE FAULT |
| 480 | 6-Apr-19 | BAGALKOT | 110 | SIRSI220-KAVALWADA | KAVALWADA_110 | 6:36 | 7:25 | 0:49 | LINE CLEAR AVAILED |
| 481 | 6-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | GOKAK_110 | 15:15 | 16:20 | 1:05 | TRANSFORMER FAULT |
| 482 | 6-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KADANAKOPPA_110 | 1:24 | 6:01 | 4:37 | LINE CLEAR AVAILED |
| 483 | 6-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KADANAKOPPA_110 | 6:29 | 7:13 | 0:44 | HAND TRIPPED |
| 484 | 6-Apr-19 | BAGALKOT | 110 | KAVALAWAD-HUBLI-KALAGHATGI | KALAGHATGI_110 | 0:00 | 1:25 | 1:25 | LINE CLEAR AVAILED |
| 485 | 6-Apr-19 | BAGALKOT | 110 | KIRUVATTI-SIRSI(AMBEWADI) | KIRUVATTI_110 | 6:37 | 7:17 | 0:40 | LOAD CHANGEOVER |
| 486 | 6-Apr-19 | BAGALKOT | 110 | KIRUVATTI-SIRSI(AMBEWADI) | KIRUVATTI_110 | 20:57 | 23:59 | 3:02 | LINE FAULT |
| 487 | 6-Apr-19 | BANGALORE | 66 | HAL 220 - HOODY 2 | BAGHMANE TECH PAR, GTRE (EHT) | 17:36 | 18:33 | 0:56 | LINE FAULT |
| 488 | 6-Apr-19 | BANGALORE | 66 | HOODY 220 - POTTERY ROAD | POTTERY ROAD, ITC (EHT) | 12:41 | 13:39 | 0:58 | LINE FAULT |
| 489 | 6-Apr-19 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, SHIVANAHALLI, CHIKKENAHALLI, CHANNAPATNA, DASHAVARA, SANKALGERE, BEVOOR | 9:01 | 9:12 | 0:10 | LINE FAULT |
| 490 | 6-Apr-19 | BANGALORE | 66 | HV1 | TK HALLI 220 | 16:16 | 16:29 | 0:12 | TRANSFORMER FAULT |
| 491 | 6-Apr-19 | BANGALORE | 66 | TK HALLI 220 - IGGALURU | AKKURMOLE, IGGALUR | 8:26 | 8:31 | 0:05 | LINE FAULT |
| 492 | 6-Apr-19 | BANGALORE | 66 | HV2 | AMARAJYOTHI | 6:42 | 6:52 | 0:10 | LOAD CHANGEOVER |
| 493 | 6-Apr-19 | BANGALORE | 66 | HV1 | BOODIGERE | 2:05 | 2:19 | 0:14 | TRANSFORMER FAULT |
| 494 | 6-Apr-19 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 1:18 | 1:25 | 0:07 | LINE FAULT |
| 495 | 6-Apr-19 | BANGALORE | 66 | CHINTAMANI 220 - NANDIGANAHALLI | NANDIGANAHALLI | 7:47 | 7:56 | 0:08 | LINE FAULT |
| 496 | 6-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 15:55 | 16:45 | 0:50 | LINE CLEAR AVAILED |
| 497 | 6-Apr-19 | BANGALORE | 66 | HV2 | HAROBEL | 15:55 | 16:45 | 0:50 | LINE CLEAR AVAILED |
| 498 | 6-Apr-19 | BANGALORE | 66 | HV1 | HAROBEL | 12:45 | 13:20 | 0:35 | LINE CLEAR AVAILED |
| 499 | 6-Apr-19 | BANGALORE | 66 | HV2 | HAROBEL | 12:45 | 13:20 | 0:35 | LINE CLEAR AVAILED |
| 500 | 6-Apr-19 | BANGALORE | 66 | HV1 | HOSKOTE 220 | 6:11 | 6:16 | 0:05 | TRANSFORMER FAULT |
| 501 | 6-Apr-19 | BANGALORE | 220 | HV3 | KOLAR 220 | 6:10 | 6:21 | 0:10 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|--------------------------|--|---------|-----------|----------|---------------------|
| 502 | 6-Apr-19 | BANGALORE | 66 | KOLAR 220 - VEMGAL | VEMGAL, KYALANUR | 6:10 | 6:33 | 0:22 | LINE FAULT |
| 503 | 6-Apr-19 | BANGALORE | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 6:10 | 6:23 | 0:13 | MAIN SUPPLY FAILURE |
| 504 | 6-Apr-19 | BANGALORE | 66 | KOLAR 220 - NARASAPURA 2 | MALUR I/A, JADIGENAHALLI | 6:10 | 6:23 | 0:13 | MAIN SUPPLY FAILURE |
| 505 | 6-Apr-19 | GULBARGA | 110 | HV2 | KAMPLI_110 | 19:10 | 19:20 | 0:10 | TRANSFORMER FAULT |
| 506 | 6-Apr-19 | GULBARGA | 110 | HV2 | KAMPLI_110 | 20:00 | 20:11 | 0:11 | TRANSFORMER FAULT |
| 507 | 6-Apr-19 | GULBARGA | 220 | RTPS-LINGASUGUR3 | LINGASUGUR_220 | 17:08 | 21:27 | 4:19 | LINE FAULT |
| 508 | 6-Apr-19 | GULBARGA | 220 | RTPS-LINGASUGUR1,2 | LINGASUGUR_220 | 17:35 | 17:39 | 0:04 | LINE CLEAR AVAILED |
| 509 | 6-Apr-19 | GULBARGA | 220 | SEDAM-SHAHPUR | SHAHPUR_220 | 19:50 | 20:10 | 0:20 | LINE FAULT |
| 510 | 6-Apr-19 | GULBARGA | 110 | SEDAM-VASAVADATTA | VASAVADATTA_IPP | 19:50 | 20:05 | 0:15 | LINE FAULT |
| 511 | 6-Apr-19 | GULBARGA | 110 | GABBUR-DEODURGA | DEODURGA_110 | 19:33 | 19:50 | 0:17 | LINE FAULT |
| 512 | 6-Apr-19 | GULBARGA | 66 | HV1 | HAMPASAGAR_66 | 6:16 | 6:19 | 0:03 | TRANSFORMER FAULT |
| 513 | 6-Apr-19 | GULBARGA | 110 | HV1 | SIRWAR_110 | 13:51 | 14:04 | 0:13 | TRANSFORMER FAULT |
| 514 | 6-Apr-19 | GULBARGA | 110 | SINDHANOOR-RAICHUR1 | VALAKAMDINNI_110,SIRWAR_110,ALKO D_110,BYAGWAT_110 | 20:01 | 20:21 | 0:20 | LINE FAULT |
| 515 | 6-Apr-19 | GULBARGA | 110 | MALLAT-BYAGAWAT | BYAGAWAT_110 | 23:27 | 23:36 | 0:09 | LINE FAULT |
| 516 | 6-Apr-19 | GULBARGA | 110 | HV2 | SHORAPUR_110 | 17:20 | 17:25 | 0:05 | TRANSFORMER FAULT |
| 517 | 6-Apr-19 | GULBARGA | 110 | HV2 | SHORAPUR_110 | 19:57 | 20:03 | 0:06 | TRANSFORMER FAULT |
| 518 | 6-Apr-19 | HASSAN | 220 | MRSSHM-HASSAN | MRSMG_220 | 16:38 | 16:58 | 0:20 | LINE FAULT |
| 519 | 6-Apr-19 | HASSAN | 110 | HV2 | KEMAR_220 | 10:31 | 11:06 | 0:35 | LINE CLEAR AVAILED |
| 520 | 6-Apr-19 | HASSAN | 110 | HV2 | KEMAR_220 | 5:50 | 6:47 | 0:57 | TRANSFORMER FAULT |
| 521 | 6-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 12:00 | 12:05 | 0:05 | LINE FAULT |
| 522 | 6-Apr-19 | HASSAN | 66 | BHADRA-SHMGA 1 | bhadra_gen | 10:54 | 11:01 | 0:07 | HAND TRIPPED |
| 523 | 6-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 16:22 | 16:25 | 0:03 | LINE FAULT |
| 524 | 6-Apr-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESH PURA_66 | 8:05 | 18:08 | 10:03 | LINE CLEAR AVAILED |
| 525 | 6-Apr-19 | HASSAN | 66 | SAKALE-IIPCL2 | SAKLESH PURA_66 | 8:05 | 18:08 | 10:03 | LINE CLEAR AVAILED |
| 526 | 6-Apr-19 | HASSAN | 66 | MRSSHM-BD-1 | MRSMG_220 | 10:05 | 11:02 | 0:57 | HAND TRIPPED |
| 527 | 6-Apr-19 | HASSAN | 66 | MRSSHM-DVG2 | MRSMG_220 | 8:19 | 8:30 | 0:11 | LINE FAULT |
| 528 | 6-Apr-19 | MYSORE | 66 | HV2 | HAMPAPURA_66 | 18:15 | 18:22 | 0:06 | TRANSFORMER FAULT |
| 529 | 6-Apr-19 | MYSORE | 66 | KADAKOLA-SARAGUR 2 | HURA_66, HULLAHALLI_66, DOORA_66 | 10:56 | 11:06 | 0:10 | LINE FAULT |
| 530 | 6-Apr-19 | MYSORE | 66 | KADAKOLA-SARAGUR 1 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 | 10:56 | 11:06 | 0:10 | LINE FAULT |
| 531 | 6-Apr-19 | MYSORE | 66 | HV2 | K_HONNALGERE_66 | 8:27 | 8:36 | 0:09 | HAND TRIPPED |
| 532 | 6-Apr-19 | MYSORE | 66 | MADIKERI-SUNTIKOPPA | MADIKERI_66 | 12:10 | 12:33 | 0:23 | HAND TRIPPED |
| 533 | 6-Apr-19 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 13:20 | 13:30 | 0:10 | TRANSFORMER FAULT |
| 534 | 6-Apr-19 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 15:13 | 15:24 | 0:10 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|------------------------------|---|---------|-----------|----------|--------------------|
| 535 | 6-Apr-19 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66 | 6:44 | 6:49 | 0:05 | LINE FAULT |
| 536 | 6-Apr-19 | TUMKUR | 66 | TR-1 | CHITRADURGA_66 | 10:24 | 10:56 | 0:31 | LINE CLEAR AVAILED |
| 537 | 6-Apr-19 | TUMKUR | 66 | HONNALLI 220kv- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 13:07 | 13:14 | 0:06 | LINE FAULT |
| 538 | 7-Apr-19 | BAGALKOT | 220 | POND 2-AMBEWADI | AMBEWADI_220 | 0:00 | 14:11 | 14:11 | LINE CLEAR AVAILED |
| 539 | 7-Apr-19 | BAGALKOT | 110 | BAGALKOT220-LOKAPUR | LOKAPUR_110 | 14:45 | 16:57 | 2:12 | LINE FAULT |
| 540 | 7-Apr-19 | BAGALKOT | 110 | 110/33KV,HV2 | BELGAUM_110 | 6:07 | 6:18 | 0:11 | LINE CLEAR AVAILED |
| 541 | 7-Apr-19 | BAGALKOT | 110 | SUZLON-BYADAGI | BYADAGI_110 | 3:29 | 3:35 | 0:06 | LINE FAULT |
| 542 | 7-Apr-19 | BAGALKOT | 110 | 110/11KV, HV3 | MUDALGI_110 | 7:30 | 10:04 | 2:34 | TRANSFORMER FAULT |
| 543 | 7-Apr-19 | BAGALKOT | 110 | 110/11KV, HV1 | MORATAGI_110 | 12:45 | 12:48 | 0:03 | TRANSFORMER FAULT |
| 544 | 7-Apr-19 | BAGALKOT | 110 | KUDACHI220-MORAB | MORAB_110 | 17:28 | 18:39 | 1:11 | LINE CLEAR AVAILED |
| 545 | 7-Apr-19 | BAGALKOT | 220 | HAVERI220-NARENDRA2 | HAVERI_220 | 0:00 | 15:02 | 15:02 | LINE CLEAR AVAILED |
| 546 | 7-Apr-19 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,NEVARGI_33KV,DHULKED_33KV | 10:31 | 10:34 | 0:03 | TRANSFORMER FAULT |
| 547 | 7-Apr-19 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,NEVARGI_33KV,DHULKED_33KV | 10:52 | 10:59 | 0:07 | TRANSFORMER FAULT |
| 548 | 7-Apr-19 | BAGALKOT | 110 | VAJRAMATTI220-KATARKI | KATARKI_110 | 9:59 | 10:17 | 0:18 | LINE CLEAR AVAILED |
| 549 | 7-Apr-19 | BAGALKOT | 110 | VAJRAMATTI220-LOKAPUR | LOKAPUR_110 | 14:45 | 17:00 | 2:15 | LINE FAULT |
| 550 | 7-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | UDAYAMBAG_110 | 9:30 | 9:57 | 0:27 | LINE CLEAR AVAILED |
| 551 | 7-Apr-19 | BAGALKOT | 220 | SOUDATTI-BIDNAL | SOUDATTI_220 | 0:00 | 13:17 | 13:17 | LINE CLEAR AVAILED |
| 552 | 7-Apr-19 | BAGALKOT | 110 | SIRSI220-KAVALWADA | KAVALWADA_110 | 12:29 | 14:38 | 2:09 | LINE CLEAR AVAILED |
| 553 | 7-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | GOKAK_110 | 16:49 | 17:52 | 1:03 | LINE CLEAR AVAILED |
| 554 | 7-Apr-19 | BAGALKOT | 110 | 110/11KV,HV-1 | HALIYAL_110 | 9:32 | 10:28 | 0:56 | LINE CLEAR AVAILED |
| 555 | 7-Apr-19 | BAGALKOT | 110 | KADANAKOPPA-KAVALAWAD | KADANAKOPPA_110 | 14:03 | 14:12 | 0:09 | HAND TRIPPED |
| 556 | 7-Apr-19 | BAGALKOT | 110 | KIRUVATTI-SIRSI(AMBEWADI) | KIRUVATTI_110 | 0:00 | 14:28 | 14:28 | LINE CLEAR AVAILED |
| 557 | 7-Apr-19 | BANGALORE | 66 | HV1 | GOLF LINKS | 23:56 | 23:59 | 0:03 | LINE CLEAR AVAILED |
| 558 | 7-Apr-19 | BANGALORE | 66 | PLATINUM CITY - DG4 | PLATIMUM CITY | 21:15 | 21:20 | 0:05 | LOAD CHANGEOVER |
| 559 | 7-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - BYADRAHALLI | BYADRAHALLI, TAVAREKERE, KODIHALLI | 10:45 | 11:52 | 1:07 | LINE FAULT |
| 560 | 7-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - BYADRAHALLI | BYADRAHALLI, TAVAREKERE, KODIHALLI | 5:08 | 5:09 | 0:01 | LOAD CHANGEOVER |
| 561 | 7-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - BYADRAHALLI | BYADRAHALLI, TAVAREKERE, KODIHALLI | 8:00 | 8:03 | 0:03 | LOAD CHANGEOVER |
| 562 | 7-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - WEL CAST | WEL CAST | 5:20 | 5:25 | 0:05 | LOAD CHANGEOVER |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|------------------------------|--|---------|-----------|----------|---------------------|
| 563 | 7-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - WEL CAST | WEL CAST | 8:05 | 8:10 | 0:05 | LOAD CHANGEOVER |
| 564 | 7-Apr-19 | BANGALORE | 66 | SRS PEENYA 220 - MEI LAYOUT | MEI LAYOUT, WIDIA, WIDIA (EHT) | 5:00 | 5:07 | 0:06 | LOAD CHANGEOVER |
| 565 | 7-Apr-19 | BANGALORE | 66 | TK HALLI 220 - AKKURMOLE | AKKURMOLE, IGGALUR, K HONALGERE | 18:57 | 19:09 | 0:12 | MAIN SUPPLY FAILURE |
| 566 | 7-Apr-19 | BANGALORE | 66 | TK HALLI 220 - MANDYA 1 & 2 | KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA | 18:57 | 19:10 | 0:13 | MAIN SUPPLY FAILURE |
| 567 | 7-Apr-19 | BANGALORE | 66 | TK HALLI 220 - SOMANAHALLI 2 | HALAGUR, HONNIGANAHALLI, DODDALAHALLI | 18:57 | 19:09 | 0:12 | MAIN SUPPLY FAILURE |
| 568 | 7-Apr-19 | BANGALORE | 66 | TK HALLI 220 - SHIMSHA 2 | TK HALLI 220 | 18:57 | 19:43 | 0:46 | LINE FAULT |
| 569 | 7-Apr-19 | BANGALORE | 220 | HV2 | TK HALLI 220 | 18:57 | 19:09 | 0:12 | TRANSFORMER FAULT |
| 570 | 7-Apr-19 | BANGALORE | 220 | HV2 | SRS PEENYA 220 | 5:03 | 5:05 | 0:02 | LOAD CHANGEOVER |
| 571 | 7-Apr-19 | BANGALORE | 220 | HV2 | SRS PEENYA 220 | 7:47 | 7:52 | 0:05 | LOAD CHANGEOVER |
| 572 | 7-Apr-19 | BANGALORE | 220 | HV3 | SRS PEENYA 220 | 5:08 | 5:09 | 0:01 | LOAD CHANGEOVER |
| 573 | 7-Apr-19 | BANGALORE | 220 | HV3 | SRS PEENYA 220 | 8:00 | 8:03 | 0:02 | LOAD CHANGEOVER |
| 574 | 7-Apr-19 | BANGALORE | 220 | HV4 | SRS PEENYA 220 | 7:53 | 7:56 | 0:03 | LOAD CHANGEOVER |
| 575 | 7-Apr-19 | BANGALORE | 66 | GOWRIBIDANUR 220 - ACC (EHT) | ACC (EHT) | 11:05 | 11:19 | 0:14 | LINE FAULT |
| 576 | 7-Apr-19 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 9:27 | 9:43 | 0:15 | LINE FAULT |
| 577 | 7-Apr-19 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 17:06 | 17:13 | 0:07 | LINE FAULT |
| 578 | 7-Apr-19 | BANGALORE | 220 | DABUSPET 220 - KADUR 220 | KADUR 220 | 12:44 | 15:20 | 2:36 | LINE FAULT |
| 579 | 7-Apr-19 | GULBARGA | 110 | LINGASUGUR-GURUGUNTA | GURUGUNTA_110 | 19:40 | 19:50 | 0:10 | LINE FAULT |
| 580 | 7-Apr-19 | GULBARGA | 110 | HV2 | YELBURGA_110 | 4:05 | 4:14 | 0:09 | TRANSFORMER FAULT |
| 581 | 7-Apr-19 | GULBARGA | 110 | HV2 | YELBURGA_110 | 4:14 | 4:17 | 0:03 | TRANSFORMER FAULT |
| 582 | 7-Apr-19 | GULBARGA | 110 | HV2 | YELBURGA_110 | 9:34 | 9:38 | 0:04 | TRANSFORMER FAULT |
| 583 | 7-Apr-19 | GULBARGA | 110 | HV2 | YELBURGA_110 | 10:09 | 10:14 | 0:05 | TRANSFORMER FAULT |
| 584 | 7-Apr-19 | GULBARGA | 110 | HV4 | YELBURGA_110 | 17:50 | 18:05 | 0:15 | TRANSFORMER FAULT |
| 585 | 7-Apr-19 | GULBARGA | 66 | ITTAGI-KUDILIGI1,2 | KOGALI-66,CHORNOOR_66,CJHALLI_66,BANVEKA L_66,HOSAHALLI_66,GUDEKOTE_66,KUDILIGI_66 | 13:10 | 13:18 | 0:08 | LINE FAULT |
| 586 | 7-Apr-19 | HASSAN | 220 | KADUR-DABUSET | KADUR_220 | 12:44 | 15:06 | 2:22 | LINE FAULT |
| 587 | 7-Apr-19 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 18:40 | 18:49 | 0:09 | LINE FAULT |
| 588 | 7-Apr-19 | HASSAN | 110 | HV2 | NAVUNDA_1110 | 4:03 | 4:33 | 0:30 | TRANSFORMER FAULT |
| 589 | 7-Apr-19 | HASSAN | 110 | HV1 | SAGARA_110 | 16:18 | 17:16 | 0:58 | TRANSFORMER FAULT |
| 590 | 7-Apr-19 | HASSAN | 66 | MRSSHM-HOLUR | MRSMSG_220 | 10:24 | 14:30 | 4:06 | LINE FAULT |
| 591 | 7-Apr-19 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 13:52 | 14:02 | 0:10 | LINE FAULT |
| 592 | 7-Apr-19 | HASSAN | 66 | HV1 | BELUR_66 | 10:55 | 11:05 | 0:10 | TRANSFORMER FAULT |
| 593 | 7-Apr-19 | HASSAN | 66 | HV1 | BELUR_66 | 13:35 | 13:40 | 0:05 | TRANSFORMER FAULT |
| 594 | 7-Apr-19 | HASSAN | 66 | HV2 | BELUR_66 | 14:45 | 15:25 | 0:40 | TRANSFORMER FAULT |
| 595 | 7-Apr-19 | HASSAN | 66 | HV2 | BELUR_66 | 18:40 | 18:50 | 0:10 | TRANSFORMER FAULT |
| 596 | 7-Apr-19 | HASSAN | 66 | HV2 | BELUR_66 | 20:45 | 20:55 | 0:10 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|----------|---------|--------------------------------------|---|---------|-----------|----------|--------------------|
| 597 | 7-Apr-19 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 12:13 | 12:18 | 0:05 | LINE FAULT |
| 598 | 7-Apr-19 | HASSAN | 66 | SAKALE-IIPCL1 | SAKLESH PURA_66 | 7:21 | 23:53 | 16:32 | LINE CLEAR AVAILED |
| 599 | 7-Apr-19 | HASSAN | 66 | SAKALE-IIPCL2 | SAKLESH PURA_66 | 7:21 | 23:53 | 16:32 | LINE CLEAR AVAILED |
| 600 | 7-Apr-19 | MYSORE | 66 | JAKKANAHALLI-NAGAMANGLA | BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66 | 11:01 | 11:09 | 0:08 | LINE FAULT |
| 601 | 7-Apr-19 | MYSORE | 66 | KR PETE 220-MAHADESHWARAPURA | BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66 | 3:27 | 3:34 | 0:06 | LINE FAULT |
| 602 | 7-Apr-19 | MYSORE | 66 | MADHUVANAHALLI-YELANDUR | MAMBALLI_66 YELANDUR_66 | 11:55 | 12:01 | 0:06 | LINE FAULT |
| 603 | 7-Apr-19 | TUMKUR | 66 | ANCHEPALYA 220- ANCHEPALYA 2 | KUDUR_66, HULLENAHALLI_66 | 14:42 | 14:54 | 0:11 | LINE FAULT |
| 604 | 7-Apr-19 | TUMKUR | 66 | TR-2 | BADDIHALLI_66 | 18:58 | 20:37 | 1:38 | LINE CLEAR AVAILED |
| 605 | 7-Apr-19 | TUMKUR | 66 | BADDIHALLI- MELEKOTE | BADDIHALLI_66 | 11:00 | 11:12 | 0:12 | LINE FAULT |
| 606 | 7-Apr-19 | TUMKUR | 66 | BADDIHALLI- MELEKOTE | BADDIHALLI_66 | 22:50 | 22:53 | 0:02 | HAND TRIPPED |
| 607 | 7-Apr-19 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66 | 11:48 | 12:05 | 0:16 | LINE FAULT |
| 608 | 7-Apr-19 | TUMKUR | 66 | HIREHALLI - BADDIHALLI | BADDIHALLI_66 | 22:06 | 22:47 | 0:41 | LINE FAULT |
| 609 | 7-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- KUNDUR | KUNDUR_66,MALEBENNUR_66 | 2:04 | 2:18 | 0:14 | LINE FAULT |
| 610 | 7-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- KUNDUR | KUNDUR_66,MALEBENNUR_66 | 4:26 | 4:37 | 0:11 | LINE FAULT |
| 611 | 7-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- KUNDUR | KUNDUR_66,MALEBENNUR_66 | 5:31 | 6:03 | 0:32 | LINE FAULT |
| 612 | 7-Apr-19 | TUMKUR | 66 | KALAMARANAHALLI- BPCLSOLAR_IPP_66 | BPCLSOLAR_IPP_66 | 13:39 | 15:28 | 1:49 | LINE CLEAR AVAILED |
| 613 | 7-Apr-19 | TUMKUR | 66 | KALAMARANAHALLI- TATA SOLAR_IPP_66 | TATA SOLAR_IPP_66 | 13:39 | 15:29 | 1:49 | LINE CLEAR AVAILED |
| 614 | 7-Apr-19 | TUMKUR | 66 | MATHOD- AVNTI_SLR_IPP_66 | AVNTI_SLR_IPP_66 | 14:35 | 15:31 | 0:56 | HAND TRIPPED |
| 615 | 7-Apr-19 | TUMKUR | 66 | NAGALAMADIKE-MADHUGIRI | NAGALMADIKE_66 | 10:58 | 11:33 | 0:34 | LINE FAULT |
| 616 | 7-Apr-19 | TUMKUR | 66 | NAGALAMADIKE- SUNDARRAJ SOLAR_IPP_66 | SUNDARRAJ SOLAR_IPP_66 | 12:03 | 12:20 | 0:16 | HAND TRIPPED |
| 617 | 7-Apr-19 | TUMKUR | 220 | THALLAK 220-HIRIYUR | HIRIYUR_220 | 5:19 | 10:14 | 4:54 | LINE CLEAR AVAILED |
| 618 | 8-Apr-19 | BAGALKOT | 220 | AMBEWADI-NARENDRA 2 | AMBEWADI_220 | 9:56 | 22:26 | 12:30 | LINE CLEAR AVAILED |
| 619 | 8-Apr-19 | BAGALKOT | 110 | SUPA 2-AMBEWADI | AMBEWADI_220 | 10:02 | 16:07 | 6:05 | LINE CLEAR AVAILED |
| 620 | 8-Apr-19 | BAGALKOT | 110 | DAMBAL-MUNDARGI | MUNDARGI_110 | 5:52 | 10:53 | 5:01 | LINE FAULT |
| 621 | 8-Apr-19 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 0:00 | 11:07 | 11:07 | LINE CLEAR AVAILED |
| 622 | 8-Apr-19 | BAGALKOT | 220 | 220/110KV,HV2,LV2 | HUBLI_220 | 12:25 | 15:05 | 2:40 | LINE CLEAR AVAILED |
| 623 | 8-Apr-19 | BAGALKOT | 110 | KUMTA-SIRSI1 | KUMTA_110 | 12:26 | 23:59 | 11:33 | LINE CLEAR AVAILED |
| 624 | 8-Apr-19 | BAGALKOT | 110 | MRUTHYUNJAY NAGAR-GOPPANKOPPA1 | GOPPANKOPPA_110 | 11:11 | 11:15 | 0:04 | HAND TRIPPED |
| 625 | 8-Apr-19 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,NEVARGI_33KV,DHULKED_33 KV | 10:27 | 10:31 | 0:04 | TRANSFORMER FAULT |
| 626 | 8-Apr-19 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,NEVARGI_33KV,DHULKED_33 KV | 10:50 | 10:55 | 0:05 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|-----------|---------|----------------------------|--|---------|-----------|----------|---------------------|
| 627 | 8-Apr-19 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | KARWAR_220 | 12:12 | 12:24 | 0:12 | HAND TRIPPED |
| 628 | 8-Apr-19 | BAGALKOT | 110 | MAHALINGAPUR220-JAMKHANDI | JAMKHANDI_110 | 14:03 | 14:43 | 0:40 | MAIN SUPPLY FAILURE |
| 629 | 8-Apr-19 | BAGALKOT | 110 | MAHALINGAPUR220-JAMKHANDI | JAMKHANDI_110 | 17:33 | 23:59 | 6:26 | LINE CLEAR AVAILED |
| 630 | 8-Apr-19 | BAGALKOT | 110 | HAVERI220-TILUVALI | TILUVALI_110 | 1:32 | 6:41 | 5:09 | LINE FAULT |
| 631 | 8-Apr-19 | BAGALKOT | 110 | HAVERI220-SAVANUR | SAVANUR-110 | 15:20 | 16:32 | 1:12 | LINE FAULT |
| 632 | 8-Apr-19 | BAGALKOT | 110 | 110/11KV,HV1 | HATTARGI_110 | 4:59 | 11:15 | 6:16 | LINE CLEAR AVAILED |
| 633 | 8-Apr-19 | BAGALKOT | 110 | GOPPANKOPPA-GADAG ROAD | GOPPANKOPPA_110 | 11:02 | 11:09 | 0:07 | HAND TRIPPED |
| 634 | 8-Apr-19 | BAGALKOT | 110 | 110/11KV,HV2 | GUTTAL_110 | 16:21 | 17:10 | 0:49 | TRANSFORMER FAULT |
| 635 | 8-Apr-19 | BAGALKOT | 220 | VAJRAMATTI-KAVATAGI LIS | VAJRAMATTI_220 | 16:07 | 18:06 | 1:59 | LINE CLEAR AVAILED |
| 636 | 8-Apr-19 | BANGALORE | 66 | WELCAST STEEL - ABBIGERE | WELCAST STEEL | 20:50 | 20:55 | 0:05 | LOAD CHANGEOVER |
| 637 | 8-Apr-19 | BANGALORE | 66 | HV2 | CHAKAVELU | 9:00 | 9:34 | 0:33 | LINE CLEAR AVAILED |
| 638 | 8-Apr-19 | BANGALORE | 66 | HV2 | CHAKAVELU | 15:50 | 17:00 | 1:10 | LINE CLEAR AVAILED |
| 639 | 8-Apr-19 | BANGALORE | 66 | GANJIGUNTE - DIBBURAHALLI | DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 21:50 | 21:54 | 0:03 | LINE FAULT |
| 640 | 8-Apr-19 | BANGALORE | 66 | DABUSPET 220 - TYAMAGONDLU | TYAMAGONDLU, T BEGUR | 8:16 | 8:43 | 0:27 | LINE FAULT |
| 641 | 8-Apr-19 | BANGALORE | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA | 13:36 | 15:28 | 1:52 | LINE CLEAR AVAILED |
| 642 | 8-Apr-19 | BANGALORE | 66 | DB PURA 220 - VIJAYAPURA | VIJAYAPURA, JANGAMAKOTE | 14:26 | 14:36 | 0:10 | LINE FAULT |
| 643 | 8-Apr-19 | GULBARGA | 220 | HV2 | HALBURGA_220 | 4:12 | 4:44 | 0:32 | TRANSFORMER FAULT |
| 644 | 8-Apr-19 | GULBARGA | 220 | HV1 | SEDAM_220 | 11:32 | 12:44 | 1:12 | LINE CLEAR AVAILED |
| 645 | 8-Apr-19 | GULBARGA | 110 | HV1 | SIRWAR_110 | 10:12 | 10:41 | 0:29 | LINE CLEAR AVAILED |
| 646 | 8-Apr-19 | GULBARGA | 110 | BETAGERA-KESHAVCEMENTS_IPP | BETAGERA_110 | 5:52 | 6:30 | 0:38 | LINE FAULT |
| 647 | 8-Apr-19 | GULBARGA | 110 | GURUMITAKAL-SEDAM | GURUMITAKAL_110 | 11:47 | 13:16 | 1:29 | MAIN SUPPLY FAILURE |
| 648 | 8-Apr-19 | GULBARGA | 110 | GURGUNTA-LINGASUGUR | GURGUNTA_110 | 0:40 | 0:45 | 0:05 | LINE FAULT |
| 649 | 8-Apr-19 | GULBARGA | 110 | GURGUNTA-KHEL_IPP | KHEL_IPP | 0:40 | 1:30 | 0:50 | LINE FAULT |
| 650 | 8-Apr-19 | GULBARGA | 110 | GURGUNTA- LJVL_IPP | LJVL_IPP | 0:40 | 23:59 | 23:19 | LINE FAULT |
| 651 | 8-Apr-19 | GULBARGA | 110 | GURGUNTA-LINGASUGUR | GURGUNTA_110 | 2:00 | 2:10 | 0:10 | LINE FAULT |
| 652 | 8-Apr-19 | GULBARGA | 110 | GURGUNTA-KHEL_IPP | KHEL_IPP | 2:00 | 2:25 | 0:25 | LINE FAULT |
| 653 | 8-Apr-19 | GULBARGA | 110 | MALLAT-KAVITHAL | KAVITAL_110 | 11:29 | 15:25 | 3:56 | LINE CLEAR AVAILED |
| 654 | 8-Apr-19 | GULBARGA | 110 | HV1 | YELBURGA_110 | 12:37 | 12:40 | 0:03 | LINE CLEAR AVAILED |
| 655 | 8-Apr-19 | GULBARGA | 110 | HV1 | YELBURGA_110 | 13:27 | 13:34 | 0:07 | LINE CLEAR AVAILED |
| 656 | 8-Apr-19 | GULBARGA | 110 | HV1 | YELBURGA_110 | 13:43 | 13:45 | 0:02 | LINE CLEAR AVAILED |
| 657 | 8-Apr-19 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 17:02 | 17:10 | 0:08 | LINE FAULT |
| 658 | 8-Apr-19 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 18:00 | 18:10 | 0:10 | LINE FAULT |
| 659 | 8-Apr-19 | GULBARGA | 110 | SEDAM-VASAVADATTA | VASAVADATTA_IPP | 18:46 | 18:59 | 0:13 | LINE FAULT |
| 660 | 8-Apr-19 | GULBARGA | 110 | HV1 | WADAGERA_110 | 15:40 | 18:40 | 3:00 | LINE CLEAR AVAILED |
| 661 | 8-Apr-19 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:13 | 15:05 | 2:52 | LINE CLEAR AVAILED |
| 662 | 8-Apr-19 | HASSAN | 220 | GOPALAP-BASTIPURA | GOPALAPURA_220 | 22:26 | 23:59 | 1:33 | LINE FAULT |
| 663 | 8-Apr-19 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 10:39 | 10:44 | 0:05 | HAND TRIPPED |
| 664 | 8-Apr-19 | HASSAN | 220 | HV1 | MSEZ_220 | 9:59 | 14:27 | 4:28 | LINE CLEAR AVAILED |
| 665 | 8-Apr-19 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 10:39 | 10:44 | 0:05 | HAND TRIPPED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|---------|---------|------------------------|--|---------|-----------|----------|---------------------|
| 666 | 8-Apr-19 | HASSAN | 110 | LV1 | MSEZ_220 | 9:58 | 14:27 | 4:29 | LINE CLEAR AVAILED |
| 667 | 8-Apr-19 | HASSAN | 110 | ANANDA-SHIMOGA | ANANDAPURA_110 | 18:24 | 18:43 | 0:19 | LINE FAULT |
| 668 | 8-Apr-19 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 10:04 | 10:09 | 0:05 | LINE FAULT |
| 669 | 8-Apr-19 | HASSAN | 110 | GURUPUR-KAVOOR | GURUPURA_110 | 3:07 | 3:19 | 0:12 | LINE FAULT |
| 670 | 8-Apr-19 | HASSAN | 110 | MRSSM-SS2 | MRSMG_220 | 12:24 | 12:42 | 0:18 | LINE FAULT |
| 671 | 8-Apr-19 | HASSAN | 110 | SAGARA-ALKLA | SAGARA_110 | 18:24 | 18:40 | 0:16 | LINE FAULT |
| 672 | 8-Apr-19 | HASSAN | 110 | HV1 | SALATHUR_110 | 7:41 | 7:48 | 0:07 | TRANSFORMER FAULT |
| 673 | 8-Apr-19 | HASSAN | 110 | SHRLKP-SHIKARIPURA | SHIRALKOPPA_220 | 17:34 | 18:00 | 0:26 | LINE FAULT |
| 674 | 8-Apr-19 | HASSAN | 66 | HASSN22-MALLALI | HASSAN_220 | 19:23 | 20:14 | 0:51 | LINE FAULT |
| 675 | 8-Apr-19 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 7:25 | 18:45 | 11:20 | MAIN SUPPLY FAILURE |
| 676 | 8-Apr-19 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 7:25 | 18:45 | 11:20 | MAIN SUPPLY FAILURE |
| 677 | 8-Apr-19 | HASSAN | 66 | HV1 | ALDUR_66 | 7:25 | 18:45 | 11:20 | MAIN SUPPLY FAILURE |
| 678 | 8-Apr-19 | HASSAN | 66 | ARAKAL-MALLIPATNA | ARKD_66 | 17:36 | 18:00 | 0:24 | LINE FAULT |
| 679 | 8-Apr-19 | HASSAN | 66 | BYACHAN-HNPURA | BYACHANAHALLI_66 | 14:43 | 15:11 | 0:28 | HAND TRIPPED |
| 680 | 8-Apr-19 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 14:43 | 15:11 | 0:28 | HAND TRIPPED |
| 681 | 8-Apr-19 | HASSAN | 66 | BYARAPU-BAGUR | K_BYRAPURA_66 | 18:40 | 18:50 | 0:10 | MAIN SUPPLY FAILURE |
| 682 | 8-Apr-19 | HASSAN | 66 | CHIKMA-L1-ALDUR | CHIKMAGALUR_66 | 7:20 | 18:48 | 11:28 | LINE CLEAR AVAILED |
| 683 | 8-Apr-19 | HASSAN | 66 | GENDEHA-MUDIGERE | GENDEHALLI_66 | 15:34 | 15:45 | 0:11 | LINE FAULT |
| 684 | 8-Apr-19 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESH PURA_66 | 11:03 | 16:45 | 5:42 | LINE CLEAR AVAILED |
| 685 | 8-Apr-19 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESH PURA_66 | 11:03 | 16:45 | 5:42 | LINE CLEAR AVAILED |
| 686 | 8-Apr-19 | MYSORE | 66 | COWDALLI-MARTHALLI | RAMAPURA_MYS_66 MARTAHALLI_66 | 6:03 | 6:09 | 0:05 | LINE FAULT |
| 687 | 8-Apr-19 | MYSORE | 66 | HV1 | DEVANOORMYS_66 | 20:55 | 23:59 | 3:03 | LINE CLEAR AVAILED |
| 688 | 8-Apr-19 | MYSORE | 66 | HV2 | DEVANOORMYS_66 | 20:55 | 21:48 | 0:53 | HAND TRIPPED |
| 689 | 8-Apr-19 | MYSORE | 220 | HOOTAGALLI-VAJAMANGALA | VAJAMANGALA_220 DEVANOORMYS_66 FTS_66 MEGALAPURA_66 BANNUR_66 KIRUGAVALU_66 BGPURA_66 THALAKADU_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 BANNIMANTAP_66 THAYURU_66 THUMLA_66 THALAKADU_66 RAJEEVNAGARA_66 | 22:48 | 23:00 | 0:12 | LINE FAULT |
| 690 | 8-Apr-19 | MYSORE | 66 | HV1 | JAKKANAHALLY_66 | 14:30 | 14:43 | 0:13 | TRANSFORMER FAULT |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|---------|---------|-----------------------|--|---------|-----------|----------|--------------------|
| 691 | 8-Apr-19 | MYSORE | 220 | KADAKOLA-CRNAGR1 | CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66 , CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALLI_66 | 22:47 | 23:59 | 1:12 | LINE CLEAR AVAILED |
| 692 | 8-Apr-19 | MYSORE | 220 | KADAKO-BASTHIPURA 1 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66 DKMAIDANA_66 MYSORESOUTH_66 | 22:47 | 23:41 | 0:54 | LINE FAULT |
| 693 | 8-Apr-19 | MYSORE | 220 | KADAKOLA-BASTHIPURA 2 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66 DKMAIDANA_66 MYSORESOUTH_66 | 22:47 | 23:59 | 1:12 | LINE FAULT |
| 694 | 8-Apr-19 | MYSORE | 66 | HV2 | K_HONNALGERE_66 | 23:18 | 23:23 | 0:05 | HAND TRIPPED |
| 695 | 8-Apr-19 | MYSORE | 220 | HV1 | MADHUVANAHALLI_220 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 MADHUVANAHALLI_220 | 22:48 | 23:58 | 1:10 | LINE CLEAR AVAILED |

| Sl.No. | DATE | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|----------|---------|---------|-------------------------------|--|---------|-----------|----------|--------------------|
| 696 | 8-Apr-19 | MYSORE | 220 | HV2 | MADHUVANAHALLI_220 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 | 22:48 | 23:58 | 1:10 | LINE CLEAR AVAILED |
| 697 | 8-Apr-19 | MYSORE | 66 | MADHUVANAHALLY-KUNTHUR | KUNTHUR_66 | 6:02 | 6:10 | 0:08 | LINE FAULT |
| 698 | 8-Apr-19 | MYSORE | 66 | HV2 | PANDYADAHUNDI_66 | 11:59 | 13:08 | 1:08 | LINE CLEAR AVAILED |
| 699 | 8-Apr-19 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 8:43 | 8:52 | 0:09 | LINE CLEAR AVAILED |
| 700 | 8-Apr-19 | MYSORE | 66 | HV5 | SFCSHIVA_66 | 14:28 | 23:59 | 9:30 | LINE CLEAR AVAILED |
| 701 | 8-Apr-19 | MYSORE | 66 | VAJMANGALA-DEVNUR(MYS) | DEVANOORMYS_66 RAJEEVNAGARA_66 | 20:35 | 21:15 | 0:40 | LINE FAULT |
| 702 | 8-Apr-19 | TUMKUR | 220 | HONNALLI 220kV-DAVANAGERE SRS | HONNALLI_220 | 11:21 | 13:08 | 1:47 | LINE CLEAR AVAILED |
| 703 | 8-Apr-19 | TUMKUR | 220 | TR-1 | HONNALLI_220 | 12:58 | 13:09 | 0:11 | TRANSFORMER FAULT |
| 704 | 8-Apr-19 | TUMKUR | 220 | THALLAK 220-HIRIYUR | HIRIYUR_220 | 5:56 | 10:34 | 4:37 | LINE CLEAR AVAILED |
| 705 | 8-Apr-19 | TUMKUR | 110 | TR-1 | CHIKKANAYAKANAHALLI_110 | 16:27 | 16:35 | 0:07 | TRANSFORMER FAULT |
| 706 | 8-Apr-19 | TUMKUR | 66 | TR-1 | AMRUTHUR_66 | 11:15 | 11:35 | 0:19 | TRANSFORMER FAULT |
| 707 | 8-Apr-19 | TUMKUR | 66 | TR-2 | ANTHRASANAHALLI_220 | 15:34 | 16:28 | 0:54 | TRANSFORMER FAULT |
| 708 | 8-Apr-19 | TUMKUR | 66 | BADDIHALLI- MELEKOTE | BADDIHALLI_66 | 12:52 | 15:19 | 2:26 | LINE CLEAR AVAILED |
| 709 | 8-Apr-19 | TUMKUR | 66 | HIREHALLI - MELEKOTE | HIREHALLY_66 | 15:07 | 15:14 | 0:07 | LINE FAULT |
| 710 | 8-Apr-19 | TUMKUR | 66 | TR-1(LV1) | HONNALLI_220 | 13:00 | 13:12 | 0:12 | HAND TRIPPED |
| 711 | 8-Apr-19 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 12:57 | 13:11 | 0:13 | HAND TRIPPED |
| 712 | 8-Apr-19 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 12:57 | 13:12 | 0:15 | HAND TRIPPED |