

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 26.03.2019 to 01.04.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	26-Mar-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	13:22	23:59	10:37	LINE FAULT
2	26-Mar-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	0:00	13:25	13:25	LINE CLEAR AVAILED
3	26-Mar-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	11:24	11:48	0:24	HAND TRIPPED
4	26-Mar-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	13:29	16:49	3:20	LINE CLEAR AVAILED
5	26-Mar-19	BAGALKOT	220	HIREBENDIGERI 2-BIDNAL	BIDNAL_220	0:00	16:20	16:20	LINE CLEAR AVAILED
6	26-Mar-19	BAGALKOT	220	HIREBENDIGERI 1-BIDNAL	BIDNAL_220	16:31	17:04	0:33	LINE CLEAR AVAILED
7	26-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	8:06	8:06	LINE CLEAR AVAILED
8	26-Mar-19	BAGALKOT	110	RON 1&2-GAJENDRAGAD	GAJENDRAGAD_110	8:43	17:50	9:07	LINE CLEAR AVAILED
9	26-Mar-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	17:50	23:59	6:09	LINE CLEAR AVAILED
10	26-Mar-19	BAGALKOT	110	HIREHAL-BADAMI	HIREHAL_110	10:02	18:03	8:01	LINE CLEAR AVAILED
11	26-Mar-19	BAGALKOT	110	MAY FAIR-HIREHAL	HIREHAL_110	10:02	17:45	7:43	LINE CLEAR AVAILED
12	26-Mar-19	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	13:26	14:31	1:05	LINE CLEAR AVAILED
13	26-Mar-19	BAGALKOT	110	SHIROL-JAMAKHANDI	JAMAKHANDI_110	21:28	23:59	2:31	LINE CLEAR AVAILED
14	26-Mar-19	BAGALKOT	220	KADRA 2-KARWAR	KARWAR_220	10:05	18:08	8:03	NFBC ISSUED
15	26-Mar-19	BAGALKOT	220	220/110KV,HV2	VAJRAMATTI_220	18:02	19:45	1:43	LINE CLEAR AVAILED
16	26-Mar-19	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	15:54	16:35	0:41	LINE CLEAR AVAILED
17	26-Mar-19	BAGALKOT	110	110/11KV,HV3	TILUVALI_110,KALKERE_33KV,KNML_33 KV	17:22	17:59	0:37	LINE CLEAR AVAILED
18	26-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	8:39	8:56	0:17	LINE CLEAR AVAILED
19	26-Mar-19	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	11:53	14:12	2:19	LINE CLEAR AVAILED
20	26-Mar-19	BAGALKOT	220	SIRSI220-HUBLI 1 & 2	SIRSI_220	11:57	13:54	1:57	LINE CLEAR AVAILED
21	26-Mar-19	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	0:00	13:56	13:56	LINE CLEAR AVAILED
22	26-Mar-19	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	0:00	13:24	13:24	LINE CLEAR AVAILED
23	26-Mar-19	BAGALKOT	110	SIRSI110-KUMTA1	KUMTA_110	12:00	13:41	1:41	LINE CLEAR AVAILED
24	26-Mar-19	BAGALKOT	110	SIRSI110-KUMTA2	KUMTA_110	13:31	16:14	2:43	LINE CLEAR AVAILED
25	26-Mar-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	11:41	12:01	0:20	LINE CLEAR AVAILED
26	26-Mar-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR	14:44	14:50	0:06	TRANSFORMER FAULT
27	26-Mar-19	BAGALKOT	110	GAMESHA-RON	RON_110	10:01	17:54	7:53	LINE CLEAR AVAILED
28	26-Mar-19	BAGALKOT	110	NARAGAL-RON	RON_110	10:04	17:40	7:36	LINE CLEAR AVAILED
29	26-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	5:13	5:18	0:05	TRANSFORMER FAULT
30	26-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	5:20	5:22	0:02	TRANSFORMER FAULT
31	26-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	5:25	5:27	0:02	TRANSFORMER FAULT
32	26-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	6:58	12:38	5:40	LINE CLEAR AVAILED
33	26-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	13:26	13:34	0:08	LINE CLEAR AVAILED
34	26-Mar-19	BENGALURU	66	HV2	AKKURMOLE	8:49	11:10	2:20	LINE CLEAR AVAILED
35	26-Mar-19	BENGALURU	66	CHIKKABALLAPURA I/A - CHIKKABALLAPURA URBAN	CHIKKABALLAPURA URBAN	13:00	13:21	0:21	LINE CLEAR AVAILED
36	26-Mar-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	5:45	5:52	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
37	26-Mar-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	10:08	10:19	0:11	LINE FAULT
38	26-Mar-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:08	10:29	0:21	MAIN SUPPLY FAILURE
39	26-Mar-19	BENGALURU	66	HV2	YELAHANKA 220	11:33	12:48	1:14	LINE CLEAR AVAILED
40	26-Mar-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:50	9:52	0:02	LINE FAULT
41	26-Mar-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:09	21:15	0:06	LINE FAULT
42	26-Mar-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220	11:33	13:52	2:18	LINE CLEAR AVAILED
43	26-Mar-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:33	13:10	1:36	MAIN SUPPLY FAILURE
44	26-Mar-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	15:42	15:43	0:01	LOAD CHANGEOVER
45	26-Mar-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:33	13:50	2:16	MAIN SUPPLY FAILURE
46	26-Mar-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:33	15:50	4:16	MAIN SUPPLY FAILURE
47	26-Mar-19	BENGALURU	66	DOMMASANDRA - KACHAMARANAHALLI	DOMMASANDRA	15:50	16:00	0:10	LOAD CHANGEOVER
48	26-Mar-19	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	16:20	16:26	0:06	LOAD CHANGEOVER
49	26-Mar-19	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	VIKAS TECH PARK 220	15:40	15:55	0:15	LOAD CHANGEOVER
50	26-Mar-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	11:33	13:05	1:31	MAIN SUPPLY FAILURE
51	26-Mar-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	15:40	15:55	0:15	LOAD CHANGEOVER
52	26-Mar-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:33	13:05	1:31	MAIN SUPPLY FAILURE
53	26-Mar-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:40	15:55	0:15	LOAD CHANGEOVER
54	26-Mar-19	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	11:33	13:05	1:31	MAIN SUPPLY FAILURE
55	26-Mar-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	13:42	14:07	0:25	LINE FAULT
56	26-Mar-19	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, SHIVANAHALLI, CHIKKENAHALLI, CHANNAPATNA, DASHAVARA, SANKALGERE, BEVOOR	10:35	10:41	0:05	LINE FAULT
57	26-Mar-19	BENGALURU	66	HV2	KHB	14:35	15:10	0:35	LINE CLEAR AVAILED
58	26-Mar-19	BENGALURU	66	HV2	KHB	17:05	17:10	0:05	LINE CLEAR AVAILED
59	26-Mar-19	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	16:32	16:40	0:08	LOAD CHANGEOVER
60	26-Mar-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	16:32	16:40	0:08	LOAD CHANGEOVER
61	26-Mar-19	BENGALURU	66	KHODAYS 220 - BMRCL (EHT)	BMRCL (EHT)	16:32	16:40	0:08	LOAD CHANGEOVER
62	26-Mar-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	6:07	6:20	0:13	LINE FAULT
63	26-Mar-19	BENGALURU	66	HV1	SOMANAHALLI 220	16:11	17:09	0:57	LINE CLEAR AVAILED
64	26-Mar-19	BENGALURU	66	HV2	SOMANAHALLI 220	16:11	17:09	0:57	LINE CLEAR AVAILED
65	26-Mar-19	BENGALURU	66	HV2	TAVAREKERE	6:56	7:01	0:05	TRANSFORMER FAULT
66	26-Mar-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	7:04	7:09	0:05	LOAD CHANGEOVER
67	26-Mar-19	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	13:50	13:58	0:08	LOAD CHANGEOVER
68	26-Mar-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	16:25	16:28	0:03	LOAD CHANGEOVER
69	26-Mar-19	BENGALURU	66	ELECTRONIC CITY PH 2 SEC 2 - BIOCON (EHT)	BIOCON (EHT)	12:21	13:50	1:28	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
70	26-Mar-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT, NRS 220	5:09	5:14	0:05	LINE CLEAR AVAILED
71	26-Mar-19	BENGALURU	66	HV2	NRS 220	5:09	5:14	0:05	MAIN SUPPLY FAILURE
72	26-Mar-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI, SRIGANDAKAVAL	5:09	5:13	0:04	LINE CLEAR AVAILED
73	26-Mar-19	BENGALURU	66	SRS PEENYA 220 - DG 2	ALUR	4:39	5:02	0:23	LOAD CURTAILMENT
74	26-Mar-19	BENGALURU	66	SRS PEENYA 220 - WELCAST STEEL	WELCAST STEEL	5:23	5:25	0:02	LINE CLEAR AVAILED
75	26-Mar-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, KODIGEHALI, SRIGANDAKAVAL	14:07	15:41	1:33	LINE FAULT
76	26-Mar-19	BENGALURU	66	BYADRAHALLI - TAVAREKERE	TAVAREKERE	14:07	14:53	0:45	MAIN SUPPLY FAILURE
77	26-Mar-19	BENGALURU	66	TG HALLI - TAVAREKERE	TAVAREKERE	15:52	15:59	0:07	LOAD CHANGEOVER
78	26-Mar-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	4:39	5:14	0:35	MAIN SUPPLY FAILURE
79	26-Mar-19	BENGALURU	66	NELAMANGALA 66 - DOBESPET 220	NELAMANGALA 66	5:00	5:05	0:05	LOAD CHANGEOVER
80	26-Mar-19	BENGALURU	66	HV3	YARANDANAHALLI 220	6:28	6:36	0:08	LOAD CHANGEOVER
81	26-Mar-19	BENGALURU	66	ADUGODI - HAL 2	K & C VALLEY, NAL(EHT)	17:48	17:54	0:06	LOAD CHANGEOVER
82	26-Mar-19	GULBARGA	220	ITTAGI-ESPSLR_IPP	ITTAGI_220	14:32	14:50	0:18	LINE FAULT
83	26-Mar-19	GULBARGA	110	LV1, LV2	HALBURGA_220	12:13	12:21	0:08	TRANSFORMER FAULT
84	26-Mar-19	GULBARGA	110	HALBURGA-KOLHAR1	KOLHAR_110, JANAWADA_110	12:13	12:24	0:11	LINE FAULT
85	26-Mar-19	GULBARGA	110	HALBURGA-ACMESOLAR_IPP	HALBURGA_220	4:33	4:43	0:10	LINE FAULT
86	26-Mar-19	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	6:00	6:16	0:16	MAIN SUPPLY FAILURE
87	26-Mar-19	GULBARGA	110	SEDAM-VASAVADATTA	SEDAM_220	6:19	16:43	10:24	LINE CLEAR AVAILED
88	26-Mar-19	GULBARGA	110	HV1	RAICHUR_220	19:28	21:30	2:02	LINE CLEAR AVAILED
89	26-Mar-19	GULBARGA	110	RAJESHWAR-WARADHA SLR	WARADHA_IPP	19:00	19:30	0:30	LINE CLEAR AVAILED
90	26-Mar-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINA_HADAGALLI_66, HOLAGUNDI_66	8:43	8:51	0:08	LINE FAULT
91	26-Mar-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINA_HADAGALLI_66, HOLAGUNDI_66	13:07	13:15	0:08	LINE FAULT
92	26-Mar-19	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66, GIRIYAPURA_110, SOVENAHALLI_66, TUNGABHADRA_IPP, MYLAR_66, MAGLA_66	14:32	14:48	0:16	LINE FAULT
93	26-Mar-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:00	18:30	18:30	LINE FAULT
94	26-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	9:29	14:47	5:18	LINE CLEAR AVAILED
95	26-Mar-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	9:29	14:47	5:18	NFBC ISSUED
96	26-Mar-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:53	14:11	2:18	LINE CLEAR AVAILED
97	26-Mar-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	0:00	13:57	13:57	LINE FAULT
98	26-Mar-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:00	18:31	18:31	LINE FAULT
99	26-Mar-19	HASSAN	110	HV2	PUTTUR_110	12:54	13:20	0:26	LOAD CURTAILMENT
100	26-Mar-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	8:08	14:00	5:52	LINE FAULT
101	26-Mar-19	HASSAN	110	HV1	ARASIKERE_110	13:21	14:38	1:17	TRANSFORMER FAULT
102	26-Mar-19	HASSAN	110	HV1	ARASIKERE_110	15:23	17:27	2:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
103	26-Mar-19	HASSAN	110	HV1	KONAJE_110	16:01	16:03	0:02	HAND TRIPPED
104	26-Mar-19	HASSAN	110	HV2	KONAJE_110	16:01	16:04	0:03	HAND TRIPPED
105	26-Mar-19	HASSAN	110	HV3	KONAJE_110	16:01	16:04	0:03	HAND TRIPPED
106	26-Mar-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	8:09	8:30	0:21	LOAD CURTAILMENT
107	26-Mar-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:40	15:50	5:10	LOAD CURTAILMENT
108	26-Mar-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	8:49	14:01	5:12	LOAD CURTAILMENT
109	26-Mar-19	HASSAN	110	HV1	SHIVAPURA_110	7:25	9:21	1:56	LINE CLEAR AVAILED
110	26-Mar-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	7:30	7:42	0:12	HAND TRIPPED
111	26-Mar-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	9:55	11:33	1:38	LINE CLEAR AVAILED
112	26-Mar-19	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	7:41	8:25	0:44	LINE FAULT
113	26-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	7:35	18:31	10:56	LINE CLEAR AVAILED
114	26-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	7:35	18:31	10:56	LINE CLEAR AVAILED
115	26-Mar-19	HASSAN	66	HV1	SIGEBAGE_66	0:00	1:36	1:36	TRANSFORMER FAULT
116	26-Mar-19	HASSAN	66	HV2	KIADB_66	12:42	13:00	0:18	LINE CLEAR AVAILED
117	26-Mar-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	9:25	9:29	0:04	LINE FAULT
118	26-Mar-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	9:44	23:59	14:14	LINE FAULT
119	26-Mar-19	MYSORE	66	ELAVALA-HUNSUR	ELAVALA_66 GAVADAGERE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	13:15	13:42	0:27	HAND TRIPPED
120	26-Mar-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	12:36	12:43	0:07	LINE FAULT
121	26-Mar-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	12:55	13:24	0:29	LINE FAULT
122	26-Mar-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66	11:06	15:21	4:15	LINE CLEAR AVAILED
123	26-Mar-19	MYSORE	66	HUNSUR-HANAGODU	HANAGODU_66	13:45	15:36	1:50	LINE CLEAR AVAILED
124	26-Mar-19	MYSORE	66	HV1	MADHUVANAHALLI_220	7:19	7:22	0:03	TRANSFORMER FAULT
125	26-Mar-19	MYSORE	66	HV2	MADHUVANAHALLI_220	8:07	8:24	0:16	LINE CLEAR AVAILED
126	26-Mar-19	MYSORE	66	HV2	MANDYA_66	7:11	9:17	2:06	LINE CLEAR AVAILED
127	26-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:51	10:54	0:03	TRANSFORMER FAULT
128	26-Mar-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	9:25	9:29	0:04	LINE FAULT
129	26-Mar-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	9:44	23:59	14:14	LINE FAULT
130	26-Mar-19	MYSORE	66	ELAVALA-HUNSUR	ELAVALA_66 GAVADAGERE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	13:15	13:42	0:27	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
131	26-Mar-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	12:36	12:43	0:07	LINE FAULT
132	26-Mar-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	12:55	13:24	0:29	LINE FAULT
133	26-Mar-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66	11:06	15:21	4:15	LINE CLEAR AVAILED
134	26-Mar-19	MYSORE	66	HUNSUR-HANAGODU	HANAGODU_66	13:45	15:36	1:50	LINE CLEAR AVAILED
135	26-Mar-19	MYSORE	66	HV1	MADHUVANAHALLI_220	7:19	7:22	0:03	TRANSFORMER FAULT
136	26-Mar-19	MYSORE	66	HV2	MADHUVANAHALLI_220	8:07	8:24	0:16	LINE CLEAR AVAILED
137	26-Mar-19	MYSORE	66	HV2	MANDYA_66	7:11	9:17	2:06	LINE CLEAR AVAILED
138	26-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:51	10:54	0:03	TRANSFORMER FAULT
139	26-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	22:11	22:20	0:08	TRANSFORMER FAULT
140	26-Mar-19	TUMKUR	110	TR-1	KADABA_110	12:13	12:51	0:38	LINE CLEAR AVAILED
141	26-Mar-19	TUMKUR	110	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	18:50	21:39	2:49	LINE CLEAR AVAILED
142	26-Mar-19	TUMKUR	110	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:50	21:39	2:49	LINE CLEAR AVAILED
143	26-Mar-19	TUMKUR	66	TR-2	BUKKAPATNA_66	8:26	9:30	1:04	LINE CLEAR AVAILED
144	26-Mar-19	TUMKUR	66	TR-1	CHANNAGIRI_66	10:09	16:51	6:41	LINE CLEAR AVAILED
145	26-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	10:09	18:03	7:53	LINE CLEAR AVAILED
146	26-Mar-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHLI)	CHANNAGIRI_66	10:07	16:34	6:26	LINE CLEAR AVAILED
147	26-Mar-19	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:45	16:46	6:00	MAIN SUPPLY FAILURE
148	26-Mar-19	TUMKUR	66	TR-1 & TR-2	DEVARAHALLI_66	10:45	16:46	6:00	MAIN SUPPLY FAILURE
149	26-Mar-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:18	11:41	0:23	HAND TRIPPED
150	26-Mar-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:44	12:37	0:52	LINE CLEAR AVAILED
151	26-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:11	8:20	0:08	LINE FAULT
152	26-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:01	16:40	6:39	LINE CLEAR AVAILED
153	26-Mar-19	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	14:40	15:43	1:03	LINE CLEAR AVAILED
154	26-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:23	12:51	0:28	LINE FAULT
155	26-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:04	14:37	0:33	LINE FAULT
156	26-Mar-19	TUMKUR	66	TR-2	RAMPURA_66	7:03	7:06	0:02	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
157	26-Mar-19	TUMKUR	66	TR-2	RAMPURA_66	13:44	14:01	0:17	TRANSFORMER FAULT
158	26-Mar-19	TUMKUR	66	TR-2	RAMPURA_66	23:31	23:34	0:03	TRANSFORMER FAULT
159	27-Mar-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	22:26	22:32	0:06	LOAD CURTAILMENT
160	27-Mar-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	22:38	22:45	0:07	LOAD CURTAILMENT
161	27-Mar-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	23:37	23:44	0:07	LOAD CURTAILMENT
162	27-Mar-19	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	22:25	22:35	0:10	LOAD CURTAILMENT
163	27-Mar-19	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	18:05	18:32	0:27	TRANSFORMER FAULT
164	27-Mar-19	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	19:43	19:52	0:09	TRANSFORMER FAULT
165	27-Mar-19	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	19:59	20:02	0:03	TRANSFORMER FAULT
166	27-Mar-19	BAGALKOT	110	BELGAUM220-UCHAGAON	UCHAGAON_110	11:12	13:00	1:48	LINE FAULT
167	27-Mar-19	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	9:51	11:03	1:12	LINE CLEAR AVAILED
168	27-Mar-19	BAGALKOT	110	GADAG220-LAXMESHWARA 2	LAXMESHWARA_110	11:05	13:47	2:42	LINE CLEAR AVAILED
169	27-Mar-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	22:26	22:41	0:15	LOAD CURTAILMENT
170	27-Mar-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	23:37	23:43	0:06	LOAD CURTAILMENT
171	27-Mar-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	9:59	23:59	14:00	LINE CLEAR AVAILED
172	27-Mar-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	17:35	23:15	5:40	LINE FAULT
173	27-Mar-19	BAGALKOT	220	DHONI-GADAG 1	DHONI_400	13:14	13:23	0:09	LINE CLEAR AVAILED
174	27-Mar-19	BAGALKOT	220	DHONI-ARESS STEEL	DHONI_400	13:37	14:28	0:51	LINE CLEAR AVAILED
175	27-Mar-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	22:26	22:32	0:06	LOAD CURTAILMENT
176	27-Mar-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	22:39	22:58	0:19	LOAD CURTAILMENT
177	27-Mar-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	23:38	23:46	0:08	LOAD CURTAILMENT
178	27-Mar-19	BAGALKOT	110	AMBEWADI220-KAVALWADA	KAVALWADA_110	10:03	15:08	5:05	LINE CLEAR AVAILED
179	27-Mar-19	BAGALKOT	220	220/110KV,HV1&2,LV1&2	KUDUCHI_220,TERDAL_110,YELLAPARA TTI_110,UGARKHUD_110,MORAB_110, KUDUCHI_110,AINAPUR_110	5:30	5:48	0:18	TRANSFORMER FAULT
180	27-Mar-19	BAGALKOT	110	BEGEWADI220-MUDEDEBIHAL	MUDEDEBIHAL_110	17:45	18:18	0:33	MAIN SUPPLY FAILURE
181	27-Mar-19	BAGALKOT	110	BEGEWADI220-MUDEDEBIHAL	MUDEDEBIHAL_110	12:42	13:09	0:27	LINE CLEAR AVAILED
182	27-Mar-19	BAGALKOT	110	220/110KV,HV2,LV2	KUDUCHI_220	11:45	13:32	1:47	LINE CLEAR AVAILED
183	27-Mar-19	BAGALKOT	220	220/110KV,HV2	VAJRAMATTI_220	11:29	14:10	2:41	LINE CLEAR AVAILED
184	27-Mar-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINKOPPA_110	11:00	11:10	0:10	LINE CLEAR AVAILED
185	27-Mar-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINKOPPA_110	11:40	11:43	0:03	LINE CLEAR AVAILED
186	27-Mar-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINKOPPA_110	17:01	17:04	0:03	LINE CLEAR AVAILED
187	27-Mar-19	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	20:59	22:06	1:07	LINE FAULT
188	27-Mar-19	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	9:52	11:03	1:11	NFBC ISSUED
189	27-Mar-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	22:25	22:32	0:07	LOAD CURTAILMENT
190	27-Mar-19	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_220	11:09	17:01	5:52	NFBC ISSUED
191	27-Mar-19	BAGALKOT	220	HUBLI-NAJGHARI3	HUBLI_220	18:05	20:44	2:39	LINE FAULT
192	27-Mar-19	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_220	11:15	16:48	5:33	LINE CLEAR AVAILED
193	27-Mar-19	BAGALKOT	110	110/11KV,HV3	RAIBAG_220	22:05	22:07	0:02	TRANSFORMER FAULT
194	27-Mar-19	BAGALKOT	110	110/11KV,HV2	RAIBAG_220	22:25	22:26	0:01	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
195	27-Mar-19	BAGALKOT	110	110/11KV,HV2	RAIBAG_220	22:38	22:45	0:07	LOAD CURTAILMENT
196	27-Mar-19	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD_110	11:12	16:53	5:41	LINE CLEAR AVAILED
197	27-Mar-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	20:02	20:37	0:35	LINE FAULT
198	27-Mar-19	BAGALKOT	110	110/11KV,HV1	LAXMESWAR_110	22:25	22:35	0:10	LOAD CURTAILMENT
199	27-Mar-19	BAGALKOT	110	110/11KV,HV1	LAXMESWAR_110	22:38	22:51	0:13	LOAD CURTAILMENT
200	27-Mar-19	BAGALKOT	110	110/11KV,HV1	LAXMESWAR_110	23:36	23:45	0:09	LOAD CURTAILMENT
201	27-Mar-19	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66,AREMALLAPUR_33KV	22:24	22:25	0:01	LOAD CURTAILMENT
202	27-Mar-19	BENGALURU	220	HAL 220 - EDC 220	EDC 220, A STATION 220	10:50	11:11	0:20	LINE FAULT
203	27-Mar-19	BENGALURU	220	HV1	EDC 220	10:50	11:12	0:21	MAIN SUPPLY FAILURE
204	27-Mar-19	BENGALURU	220	HV2	EDC 220	10:50	11:12	0:21	MAIN SUPPLY FAILURE
205	27-Mar-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	17:28	17:37	0:08	LINE CLEAR AVAILED
206	27-Mar-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	22:10	22:25	0:15	LOAD CHANGEOVER
207	27-Mar-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	10:50	11:15	0:24	MAIN SUPPLY FAILURE
208	27-Mar-19	BENGALURU	66	EDC 220 - B STATION	B STATION	10:50	11:13	0:22	MAIN SUPPLY FAILURE
209	27-Mar-19	BENGALURU	66	EDC 220 - BMTC	BMTC, NATIONAL COLLEGE	10:50	11:14	0:23	MAIN SUPPLY FAILURE
210	27-Mar-19	BENGALURU	66	HV1	EDC 220	10:50	11:17	0:26	MAIN SUPPLY FAILURE
211	27-Mar-19	BENGALURU	66	HV2	EDC 220	10:50	11:13	0:23	MAIN SUPPLY FAILURE
212	27-Mar-19	BENGALURU	66	HV2	TAVAREKERE	4:17	4:26	0:09	TRANSFORMER FAULT
213	27-Mar-19	BENGALURU	66	HV1	R R NAGAR	23:07	23:50	0:42	TRANSFORMER FAULT
214	27-Mar-19	BENGALURU	220	A STATION 220 - EDC 220	A STATION 220	10:50	10:59	0:08	MAIN SUPPLY FAILURE
215	27-Mar-19	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	13:42	13:46	0:03	LINE FAULT
216	27-Mar-19	BENGALURU	66	HV2	DALASNUR	13:04	13:50	0:45	TRANSFORMER FAULT
217	27-Mar-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	9:30	14:11	4:41	LINE FAULT
218	27-Mar-19	BENGALURU	66	HV2	DEVANAGUNDI	13:16	14:56	1:39	LINE CLEAR AVAILED
219	27-Mar-19	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	14:08	16:21	2:13	LINE CLEAR AVAILED
220	27-Mar-19	BENGALURU	66	HV1	HOSKOTE 220	22:45	22:50	0:05	TRANSFORMER FAULT
221	27-Mar-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	13:48	14:26	0:38	LINE CLEAR AVAILED
222	27-Mar-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	7:05	7:15	0:10	LINE FAULT
223	27-Mar-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	13:25	14:35	1:10	LINE CLEAR AVAILED
224	27-Mar-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:10	9:15	0:05	LINE FAULT
225	27-Mar-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:15	10:20	0:05	LINE FAULT
226	27-Mar-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	13:07	13:38	0:30	LINE CLEAR AVAILED
227	27-Mar-19	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	21:10	22:10	1:00	LINE CLEAR AVAILED
228	27-Mar-19	BENGALURU	66	ATTUR YELAHANKA - DG4	SAHAKARINAGARA	19:40	22:10	2:29	LINE CLEAR AVAILED
229	27-Mar-19	BENGALURU	66	MANYATA TECH PARK - ATTUR YELAHANAKA	MANYATA TECH PARK	20:40	22:15	1:35	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
230	27-Mar-19	BENGALURU	66	YELAHANKA 220 - LINE 4	RAILWAYS (EHT), SAHAKARINAGARA	19:21	19:40	0:18	LINE FAULT
231	27-Mar-19	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	20:25	20:35	0:10	LOAD CHANGEOVER
232	27-Mar-19	BENGALURU	66	HV2	AKKURMOLE	8:50	9:26	0:36	LINE CLEAR AVAILED
233	27-Mar-19	BENGALURU	66	ABBIGERE - WELCAST STEEL	ABBIGERE	22:18	22:23	0:05	LOAD CHANGEOVER
234	27-Mar-19	GULBARGA	220	ALIPUR_BTPS	ALIPUR_220	8:13	8:35	0:22	LINE FAULT
235	27-Mar-19	GULBARGA	220	KUSTAGI-LINGAPUR	KUSTAGI_220	11:30	13:49	2:19	NFBC ISSUED
236	27-Mar-19	GULBARGA	220	HV1	KUSHTAGI_220	20:20	20:40	0:20	TRANSFORMER FAULT
237	27-Mar-19	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110, TORANGALLU_110	8:50	9:50	1:00	LINE CLEAR AVAILED
238	27-Mar-19	GULBARGA	110	ALIPUR-MUNIRABAD	KUDITINI_110 ,TORANGALLU_110,KURUGOD_110,KAMALAPUR_110,MATRI_110	8:13	8:56	0:43	LINE FAULT
239	27-Mar-19	GULBARGA	110	HV1	ALIPUR_220	11:35	12:54	1:19	LINE CLEAR AVAILED
240	27-Mar-19	GULBARGA	110	ALIPUR-MUNIRABAD	KUDITINI_110 , TORANGALLU_110 ,KURUGOD_110, KAMALAPUR_110,MATRI_110	11:48	12:15	0:27	LINE CLEAR AVAILED
241	27-Mar-19	GULBARGA	110	KAPANOOR_HUMNABAD1	MAHAGAON_110,MARGUTTI_110	14:35	14:43	0:08	LINE FAULT
242	27-Mar-19	GULBARGA	110	HV1	SRERAMANAGAR_110	0:14	0:30	0:16	LINE CLEAR AVAILED
243	27-Mar-19	GULBARGA	110	HV1	DHADESUGUR_110	22:24	22:31	0:07	TRANSFORMER FAULT
244	27-Mar-19	GULBARGA	110	HV1	HANUMASAGAR_110	22:24	22:30	0:06	LOAD CURTAILMENT
245	27-Mar-19	GULBARGA	110	HV1	KEMBHAVI_110	7:45	7:50	0:05	TRANSFORMER FAULT
246	27-Mar-19	GULBARGA	110	HV1	KEMBHAVI_110	22:25	22:30	0:05	TRANSFORMER FAULT
247	27-Mar-19	GULBARGA	110	HV1	KOLHAR	9:35	9:40	0:05	TRANSFORMER FAULT
248	27-Mar-19	GULBARGA	110	HV1	KOLHAR	12:35	12:45	0:10	TRANSFORMER FAULT
249	27-Mar-19	GULBARGA	110	HV1	KOLHAR	16:20	16:25	0:05	TRANSFORMER FAULT
250	27-Mar-19	GULBARGA	110	HV1	KOLHAR	17:00	17:10	0:10	LINE CLEAR AVAILED
251	27-Mar-19	GULBARGA	110	HV2	KOLHAR	22:03	22:40	0:37	TRANSFORMER FAULT
252	27-Mar-19	GULBARGA	110	SANKLAPUR-TORANGALLU	TORANAGALLU_110	18:30	20:25	1:55	LINE CLEAR AVAILED
253	27-Mar-19	GULBARGA	110	HV1	SHAKTINAGAR_110	17:22	18:30	1:08	LINE CLEAR AVAILED
254	27-Mar-19	GULBARGA	110	HV1	SRERAMANAGAR_110	0:00	0:25	0:25	LINE CLEAR AVAILED
255	27-Mar-19	GULBARGA	110	HV1	WADAGERA_110	22:30	22:35	0:05	LOAD CURTAILMENT
256	27-Mar-19	GULBARGA	110	HV1	WADAGERA_110	22:40	22:45	0:05	LOAD CURTAILMENT
257	27-Mar-19	GULBARGA	110	HV2	YELBURGA_110	22:25	22:38	0:13	LOAD CURTAILMENT
258	27-Mar-19	GULBARGA	110	HV2	YELBURGA_110	22:38	23:20	0:42	LOAD CURTAILMENT
259	27-Mar-19	GULBARGA	110	HV1	RAJESHWAR_110	22:25	22:35	0:10	LOAD CURTAILMENT
260	27-Mar-19	GULBARGA	110	HV2	RAJESHWAR_110	22:25	22:35	0:10	LOAD CURTAILMENT
261	27-Mar-19	GULBARGA	66	HV1	CJHALLI_66	22:00	22:35	0:35	TRANSFORMER FAULT
262	27-Mar-19	GULBARGA	66	HV1	HAMPASAGARA_66	22:00	22:35	0:35	TRANSFORMER FAULT
263	27-Mar-19	GULBARGA	66	HV1	HAMPASAGARA_66	23:25	23:30	0:05	TRANSFORMER FAULT
264	27-Mar-19	GULBARGA	66	HV3	HAGRIBOMMANAHALLI_66	17:25	17:30	0:05	TRANSFORMER FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
265	27-Mar-19	GULBARGA	66	KOGALI-ATRSOLR	ASTROSOLAR_IPP	18:45	23:59	5:14	LINE CLEAR AVAILED
266	27-Mar-19	GULBARGA	66	HV1	SOVENHALLI_66	22:02	22:25	0:23	TRANSFORMER FAULT
267	27-Mar-19	HASSAN	110	HV2	KAVOOR_220	10:19	23:59	13:40	LINE CLEAR AVAILED
268	27-Mar-19	HASSAN	110	HV2	NERALAKERE_110	0:51	1:57	1:06	TRANSFORMER FAULT
269	27-Mar-19	HASSAN	66	HV2	BELUR_66	14:23	14:33	0:10	TRANSFORMER FAULT
270	27-Mar-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	11:06	13:44	2:38	LINE CLEAR AVAILED
271	27-Mar-19	HASSAN	66	HV1	HARIHARPURA_66	6:16	6:31	0:15	LOAD CURTAILMENT
272	27-Mar-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	6:15	6:27	0:12	LINE FAULT
273	27-Mar-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	12:10	17:05	4:55	LINE CLEAR AVAILED
274	27-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	7:42	19:36	11:54	LINE CLEAR AVAILED
275	27-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	7:42	19:36	11:54	LINE CLEAR AVAILED
276	27-Mar-19	HASSAN	66	HV1	SINGAPURA_66	6:16	6:30	0:14	LOAD CURTAILMENT
277	27-Mar-19	HASSAN	66	HV2	SINGAPURA_66	6:16	6:30	0:14	LOAD CURTAILMENT
278	27-Mar-19	MYSORE	66	BOOKANAKERE-CHINAKURALLI	CHINAKURALI_66 BANANGADI_66	10:36	10:44	0:08	LINE FAULT
279	27-Mar-19	MYSORE	66	HV2	DUNDANAHALLI_66	15:00	15:50	0:49	LINE CLEAR AVAILED
280	27-Mar-19	MYSORE	66	HONNALLI-CR NAGARA	HONNALLY_MYS_66 ATTIGULIPURA_66	12:40	13:00	0:20	HAND TRIPPED
281	27-Mar-19	MYSORE	66	HONNALLI-ATTIGULIPURA	HONNALLY_MYS_66 ATTIGULIPURA_66	12:40	13:00	0:20	HAND TRIPPED
282	27-Mar-19	MYSORE	66	HV3	KIKKERI_66	16:59	17:40	0:41	LINE CLEAR AVAILED
283	27-Mar-19	MYSORE	66	HV2	KMDODDI_66	15:18	15:28	0:09	TRANSFORMER FAULT
284	27-Mar-19	MYSORE	66	HV1	MADHUVANAHALLI_220	6:20	6:25	0:05	TRANSFORMER FAULT
285	27-Mar-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:02	11:09	0:07	LINE FAULT
286	27-Mar-19	MYSORE	66	HV2	NAGAMANGALA_66	11:10	11:45	0:34	LINE CLEAR AVAILED
287	27-Mar-19	MYSORE	66	HV2	PANDYADAHUNDI_66	18:14	18:58	0:44	LINE CLEAR AVAILED
288	27-Mar-19	MYSORE	66	HV2	RKNAGARA_66	13:05	13:44	0:39	LINE CLEAR AVAILED
289	27-Mar-19	MYSORE	66	HV2	THANDYA_66	19:00	19:08	0:08	TRANSFORMER FAULT
290	27-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	7:05	7:12	0:07	LINE FAULT
291	27-Mar-19	MYSORE	66	HV2	TUBINAKERE_220	15:06	15:29	0:23	HAND TRIPPED
292	27-Mar-19	MYSORE	66	BOOKANAKERE-CHINAKURALLI	CHINAKURALI_66 BANANGADI_66	10:36	10:44	0:08	LINE FAULT
293	27-Mar-19	MYSORE	66	HV2	DUNDANAHALLI_66	15:00	15:50	0:49	LINE CLEAR AVAILED
294	27-Mar-19	MYSORE	66	HONNALLI-CR NAGARA	HONNALLY_MYS_66 ATTIGULIPURA_66	12:40	13:00	0:20	HAND TRIPPED
295	27-Mar-19	MYSORE	66	HONNALLI-ATTIGULIPURA	HONNALLY_MYS_66 ATTIGULIPURA_66	12:40	13:00	0:20	HAND TRIPPED
296	27-Mar-19	MYSORE	66	HV3	KIKKERI_66	16:59	17:40	0:41	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
297	27-Mar-19	MYSORE	66	HV2	KMDODDI_66	15:18	15:28	0:09	TRANSFORMER FAULT
298	27-Mar-19	MYSORE	66	HV1	MADHUVANAHALLI_220	6:20	6:25	0:05	TRANSFORMER FAULT
299	27-Mar-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:02	11:09	0:07	LINE FAULT
300	27-Mar-19	MYSORE	66	HV2	NAGAMANGALA_66	11:10	11:45	0:34	LINE CLEAR AVAILED
301	27-Mar-19	MYSORE	66	HV2	PANDYADAHUNDI_66	18:14	18:58	0:44	LINE CLEAR AVAILED
302	27-Mar-19	MYSORE	66	HV2	RKNAGARA_66	13:05	13:44	0:39	LINE CLEAR AVAILED
303	27-Mar-19	MYSORE	66	HV2	THANDYA_66	19:00	19:08	0:08	TRANSFORMER FAULT
304	27-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	7:05	7:12	0:07	LINE FAULT
305	27-Mar-19	MYSORE	66	HV2	TUBINAKERE_220	15:06	15:29	0:23	HAND TRIPPED
306	27-Mar-19	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	15:25	19:12	3:47	LINE CLEAR AVAILED
307	27-Mar-19	TUMKUR	220	CHITRADURGA 220KV- THALLAK	CHITRADURGA_220	5:28	16:57	11:28	LINE CLEAR AVAILED
308	27-Mar-19	TUMKUR	220	NITTUR 220KV- HASSAN(ARASIKERE)	NITTUR_220	9:27	13:52	4:24	LOAD CURTAILMENT
309	27-Mar-19	TUMKUR	220	THALLAK 220kv- CHITRADURGA	CHITRADURGA_220	5:31	16:57	11:26	LINE CLEAR AVAILED
310	27-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	23:06	23:11	0:05	TRANSFORMER FAULT
311	27-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	6:17	6:30	0:13	LINE FAULT
312	27-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	15:04	15:16	0:12	LINE CLEAR AVAILED
313	27-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:21	13:35	0:14	LINE FAULT
314	27-Mar-19	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	11:02	19:08	8:05	LINE CLEAR AVAILED
315	27-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:19	13:51	1:32	LINE FAULT
316	27-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:32	15:49	0:16	LINE FAULT
317	27-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	21:08	21:29	0:21	LINE FAULT
318	27-Mar-19	TUMKUR	66	TR-1	RAMPURA_66	5:25	5:31	0:06	TRANSFORMER FAULT
319	27-Mar-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	0:20	0:22	0:01	TRANSFORMER FAULT
320	28-Mar-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	22:23	22:29	0:06	LOAD CURTAILMENT
321	28-Mar-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	22:08	22:13	0:05	LOAD CURTAILMENT
322	28-Mar-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	22:23	22:26	0:03	LOAD CURTAILMENT
323	28-Mar-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	22:23	22:28	0:05	LOAD CURTAILMENT
324	28-Mar-19	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220	5:42	6:10	0:28	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
325	28-Mar-19	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220	22:23	23:22	0:59	LOAD CURTAILMENT
326	28-Mar-19	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	13:27	13:37	0:10	LINE CLEAR AVAILED
327	28-Mar-19	BAGALKOT	110	RON1-GAJENDRAGAD	GAJENDRAGAD_110	10:15	17:24	7:09	LINE CLEAR AVAILED
328	28-Mar-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	10:10	23:59	13:49	LINE CLEAR AVAILED
329	28-Mar-19	BAGALKOT	110	RON1-GAJENDRAGAD	GAJENDRAGAD_110	10:15	17:30	7:15	LINE CLEAR AVAILED
330	28-Mar-19	BAGALKOT	110	110/33KV,HV2&3	GAJENDRAGAD_110	10:15	19:16	9:01	LINE CLEAR AVAILED
331	28-Mar-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	10:15	17:27	7:12	LINE CLEAR AVAILED
332	28-Mar-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	22:23	22:37	0:14	LOAD CURTAILMENT
333	28-Mar-19	BAGALKOT	110	110/33KV,HV2	DAMBAL_110	10:50	21:06	10:16	LINE CLEAR AVAILED
334	28-Mar-19	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	5:41	5:42	0:01	LOAD CURTAILMENT
335	28-Mar-19	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	22:13	22:23	0:10	LOAD CURTAILMENT
336	28-Mar-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KULIGOD_33,SULTANPUR_33	22:23	22:39	0:16	LOAD CURTAILMENT
337	28-Mar-19	BAGALKOT	110	110/11KV, HV2	TILUVALI_110	5:41	6:15	0:34	LOAD CURTAILMENT
338	28-Mar-19	BAGALKOT	110	SUVARNASOUDA-MACHE	MACHE_110	19:50	20:15	0:25	LINE FAULT
339	28-Mar-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	8:25	13:52	5:27	LINE CLEAR AVAILED
340	28-Mar-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	17:11	17:42	0:31	LINE CLEAR AVAILED
341	28-Mar-19	BAGALKOT	110	JOG1&2-SIRSI	SIRSI_110	17:25	18:01	0:36	LINE CLEAR AVAILED
342	28-Mar-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	17:25	18:01	0:36	LINE CLEAR AVAILED
343	28-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	13:42	14:49	1:07	LINE CLEAR AVAILED
344	28-Mar-19	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	12:00	17:59	5:59	LINE CLEAR AVAILED
345	28-Mar-19	BAGALKOT	110	110/33KV, HV3	RANEENNUR_110, GUDURMAIDUR_33, HALGERI_33	5:41	6:12	0:31	LOAD CURTAILMENT
346	28-Mar-19	BAGALKOT	110	110/33KV, HV3	RANEENNUR_110, GUDURMAIDUR_33, HALGERI_33	22:24	22:52	0:28	LOAD CURTAILMENT
347	28-Mar-19	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	5:41	5:51	0:10	LOAD CURTAILMENT
348	28-Mar-19	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	22:23	22:44	0:21	LOAD CURTAILMENT
349	28-Mar-19	BAGALKOT	110	SHIROL-JAMKHANDI	SHIROL_110	15:40	16:50	1:10	LINE CLEAR AVAILED
350	28-Mar-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	9:40	18:12	8:32	LINE CLEAR AVAILED
351	28-Mar-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	0:00	17:51	17:51	LINE CLEAR AVAILED
352	28-Mar-19	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66, AREMALLAPUR_33	22:12	23:59	1:47	LOAD CURTAILMENT
353	28-Mar-19	BENGALURU	66	HV2	TAVAREKERE	1:59	2:05	0:05	TRANSFORMER FAULT
354	28-Mar-19	BENGALURU	66	HV2	ATTUR YELAHANKA	11:38	11:43	0:05	LINE CLEAR AVAILED
355	28-Mar-19	BENGALURU	66	HV2	VIJAYANAGARA	23:40	23:59	0:18	MAIN SUPPLY FAILURE
356	28-Mar-19	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	8:24	9:30	1:06	LINE FAULT
357	28-Mar-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	1:56	2:18	0:21	LOAD CHANGEOVER
358	28-Mar-19	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	5:32	5:40	0:08	LOAD CHANGEOVER
359	28-Mar-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	16:58	17:07	0:09	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
360	28-Mar-19	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), K & C VALLEY, NAL (EHT)	1:56	2:26	0:29	MAIN SUPPLY FAILURE
361	28-Mar-19	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	18:03	18:07	0:04	LOAD CHANGEOR
362	28-Mar-19	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	18:07	18:11	0:03	LOAD CHANGEOR
363	28-Mar-19	BENGALURU	66	HV3	ELECTRONIC CITY	10:57	11:14	0:17	TRANSFORMER FAULT
364	28-Mar-19	BENGALURU	66	HV3	ELECTRONIC CITY	11:50	12:10	0:20	TRANSFORMER FAULT
365	28-Mar-19	BENGALURU	66	HV1	GOLF LINKS	12:19	12:36	0:16	LINE CLEAR AVAILED
366	28-Mar-19	BENGALURU	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA	2:00	2:45	0:44	MAIN SUPPLY FAILURE
367	28-Mar-19	BENGALURU	66	HV1	NIMHANS 220	1:56	3:41	1:44	MAIN SUPPLY FAILURE
368	28-Mar-19	BENGALURU	66	HV2	NIMHANS 220	1:56	3:42	1:46	MAIN SUPPLY FAILURE
369	28-Mar-19	BENGALURU	66	HV1	NIMHANS 220	17:03	17:15	0:11	MAIN SUPPLY FAILURE
370	28-Mar-19	BENGALURU	66	HV2	NIMHANS 220	17:05	17:15	0:09	MAIN SUPPLY FAILURE
371	28-Mar-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	1:56	4:02	2:05	MAIN SUPPLY FAILURE
372	28-Mar-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGARA, NATIONAL COLLEGE	1:56	3:47	1:51	MAIN SUPPLY FAILURE
373	28-Mar-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	17:07	17:14	0:06	MAIN SUPPLY FAILURE
374	28-Mar-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGARA, NATIONAL COLLEGE	17:07	17:14	0:06	MAIN SUPPLY FAILURE
375	28-Mar-19	BENGALURU	220	LV2	NIMHANS 220	1:56	3:36	1:39	TRANSFORMER FAULT
376	28-Mar-19	BENGALURU	220	LV1	NIMHANS 220	1:56	3:36	1:39	TRANSFORMER FAULT
377	28-Mar-19	BENGALURU	220	NIMHSNS 220 - HSR LAYOUT 220	NIMHANS 220	17:07	17:14	0:06	LINE CLEAR AVAILED
378	28-Mar-19	BENGALURU	220	HV1	NIMHANS 220	1:56	3:35	1:38	TRANSFORMER FAULT
379	28-Mar-19	BENGALURU	220	HV2	NIMHANS 220	1:56	3:35	1:38	TRANSFORMER FAULT
380	28-Mar-19	BENGALURU	66	HV1	NRS 220	23:40	23:57	0:17	MAIN SUPPLY FAILURE
381	28-Mar-19	BENGALURU	66	HV2	NRS 220	23:40	23:58	0:17	MAIN SUPPLY FAILURE
382	28-Mar-19	BENGALURU	66	HV3	NRS 220	23:40	23:59	0:19	MAIN SUPPLY FAILURE
383	28-Mar-19	BENGALURU	66	HV4	NRS 220	23:40	23:59	0:19	MAIN SUPPLY FAILURE
384	28-Mar-19	BENGALURU	66	HV5	NRS 220	23:40	23:59	0:19	MAIN SUPPLY FAILURE
385	28-Mar-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT	TELECOM LAYOUT	23:40	23:52	0:11	MAIN SUPPLY FAILURE
386	28-Mar-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	18:00	18:05	0:05	LOAD CHANGEOR
387	28-Mar-19	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	23:39	23:49	0:10	MAIN SUPPLY FAILURE
388	28-Mar-19	BENGALURU	66	A STATION 220 - KANTEERAVA	KANTEERAVA	23:39	23:49	0:10	MAIN SUPPLY FAILURE
389	28-Mar-19	BENGALURU	66	HV1	BIDADI 220	15:30	15:42	0:12	TRANSFORMER FAULT
390	28-Mar-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	22:42	23:01	0:18	LOAD CURTAILMENT
391	28-Mar-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	15:10	17:02	1:52	TRANSFORMER FAULT
392	28-Mar-19	BENGALURU	66	HV2	GUNDAMGERE	12:21	13:09	0:48	LINE CLEAR AVAILED
393	28-Mar-19	BENGALURU	66	TG HALLI - ANCHEPALYA 220	TG HALLI	1:20	2:00	0:40	MAIN SUPPLY FAILURE
394	28-Mar-19	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	1:20	2:00	0:40	MAIN SUPPLY FAILURE
395	28-Mar-19	BENGALURU	66	GUDEMARANAHALLI - ANCHEPALYA 220	GUDEMARANAHALLI	1:20	2:00	0:40	MAIN SUPPLY FAILURE
396	28-Mar-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	18:48	19:17	0:29	TRANSFORMER FAULT
397	28-Mar-19	BENGALURU	66	HULLENAHALLI - KUDUR	KUDUR	12:58	14:10	1:11	LINE CLEAR AVAILED
398	28-Mar-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	12:45	13:12	0:27	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
399	28-Mar-19	BENGALURU	66	HV2	KOLAR 220	13:10	13:48	0:38	LINE CLEAR AVAILED
400	28-Mar-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	22:42	23:13	0:30	LOAD CURTAILMENT
401	28-Mar-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	22:42	23:11	0:28	LOAD CURTAILMENT
402	28-Mar-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	8:12	8:50	0:37	LINE FAULT
403	28-Mar-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	8:22	8:48	0:26	MAIN SUPPLY FAILURE
404	28-Mar-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA, DEVANAHALLI	9:11	9:16	0:05	LINE FAULT
405	28-Mar-19	BENGALURU	220	HV1	DB PURA 220	8:22	8:48	0:26	TRANSFORMER FAULT
406	28-Mar-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	8:22	8:48	0:26	MAIN SUPPLY FAILURE
407	28-Mar-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	8:22	9:10	0:48	MAIN SUPPLY FAILURE
408	28-Mar-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	9:10	13:49	4:39	LINE CLEAR AVAILED
409	28-Mar-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	8:22	8:48	0:26	MAIN SUPPLY FAILURE
410	28-Mar-19	BENGALURU	220	HV1	DB PURA 220	14:42	15:09	0:27	TRANSFORMER FAULT
411	28-Mar-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	14:42	15:11	0:29	MAIN SUPPLY FAILURE
412	28-Mar-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	14:42	15:11	0:29	MAIN SUPPLY FAILURE
413	28-Mar-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:42	15:11	0:29	MAIN SUPPLY FAILURE
414	28-Mar-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:42	15:11	0:29	MAIN SUPPLY FAILURE
415	28-Mar-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:42	15:30	0:48	MAIN SUPPLY FAILURE
416	28-Mar-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:30	18:14	2:44	LINE CLEAR AVAILED
417	28-Mar-19	BENGALURU	66	DEVANAHALLI - DB PURA 2	DEVANAHALLI	8:12	8:48	0:35	LINE FAULT
418	28-Mar-19	BENGALURU	66	HV1	DODDABELAVANGALA	23:10	23:30	0:20	LINE CLEAR AVAILED
419	28-Mar-19	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 4	NRS 220	23:40	23:56	0:15	LINE FAULT
420	28-Mar-19	BENGALURU	66	HV1	HAROBEL	17:26	17:32	0:05	TRANSFORMER FAULT
421	28-Mar-19	GULBARGA	220	HV1	LINGASUGUR_220	5:40	5:45	0:05	TRANSFORMER FAULT
422	28-Mar-19	GULBARGA	220	LINGASUGUR-SHAHPUR	LINGASUGUR_220	9:20	9:30	0:10	LINE FAULT
423	28-Mar-19	GULBARGA	220	KAPNOOR-SHAHBAD	KAPNOOR_220	9:20	9:55	0:35	LINE FAULT
424	28-Mar-19	GULBARGA	220	KAPNOOR-SHAHPUR	KAPNOOR_220	9:40	10:18	0:38	LINE CLEAR AVAILED
425	28-Mar-19	GULBARGA	220	SHAHPUR-RTPS1	SHAHPUR_220	9:20	10:00	0:40	LINE FAULT
426	28-Mar-19	GULBARGA	220	SHAHBAD-SHAHPUR	SHAHBAD_220	9:23	11:26	2:03	LINE FAULT
427	28-Mar-19	GULBARGA	220	HV2,LV2	KUSTAGI_220	8:10	8:53	0:43	HAND TRIPPED
428	28-Mar-19	GULBARGA	220	LINGASUGUR-SHAHPUR	LINGASUGUR_220	12:24	23:59	11:35	LINE FAULT
429	28-Mar-19	GULBARGA	220	SEDAM-SHAHPUR	SEDAM_220	9:18	23:59	14:41	LINE FAULT
430	28-Mar-19	GULBARGA	220	HUMNABAD-SEDAM1,2	HUMNABAD_220	9:16	9:45	0:29	LINE FAULT
431	28-Mar-19	GULBARGA	110	HV1	DHADESUGUR_110	5:41	5:50	0:09	LOAD CURTAILMENT
432	28-Mar-19	GULBARGA	110	HV1	GABUR_110	5:40	5:50	0:10	LOAD CURTAILMENT
433	28-Mar-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110	5:30	5:45	0:15	LINE FAULT
434	28-Mar-19	GULBARGA	110	GURGUNTA-LJVL_IPP	GURGUNTA_110	5:30	6:00	0:30	LINE FAULT
435	28-Mar-19	GULBARGA	110	HV1	KUSTAGI_220	5:41	5:52	0:11	LOAD CURTAILMENT
436	28-Mar-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	5:53	6:03	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
437	28-Mar-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110, SAIDAPUR_GLB_110,WADAGERA_110, NALWAR_110	5:10	5:26	0:16	LINE FAULT
438	28-Mar-19	GULBARGA	110	HV1	KEMBHAVI_110	5:40	5:45	0:05	LOAD CURTAILMENT
439	28-Mar-19	GULBARGA	110	LV1	SHAHPUR_220	9:20	10:31	1:11	TRANSFORMER FAULT
440	28-Mar-19	GULBARGA	110	LV2	SHAHPUR_220	10:50	11:00	0:10	LINE CLEAR AVAILED
441	28-Mar-19	GULBARGA	110	HV1	SOVENAHALLI_66	5:40	5:45	0:05	LOAD CURTAILMENT
442	28-Mar-19	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110	5:55	6:05	0:10	MAIN SUPPLY FAILURE
443	28-Mar-19	GULBARGA	110	HV1	RAJESHWAR_110	5:40	6:00	0:20	LOAD CURTAILMENT
444	28-Mar-19	GULBARGA	110	HV2	KOLHAR_110	5:40	5:45	0:05	TRANSFORMER FAULT
445	28-Mar-19	GULBARGA	110	HV2	KOLHAR_110	10:50	13:10	2:20	LINE CLEAR AVAILED
446	28-Mar-19	GULBARGA	110	HV2	KOLHAR_110	16:25	16:55	0:30	TRANSFORMER FAULT
447	28-Mar-19	GULBARGA	110	HV1	KOLHAR_110	11:05	11:50	0:45	LINE CLEAR AVAILED
448	28-Mar-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	9:10	12:35	3:25	LINE CLEAR AVAILED
449	28-Mar-19	GULBARGA	110	LV1	KUSTAGI_220	8:10	8:51	0:41	TRANSFORMER FAULT
450	28-Mar-19	GULBARGA	110	KUSTAGI-SUZLONWIND1,2	KUSTAGI_220	8:10	9:15	1:05	LINE FAULT
451	28-Mar-19	GULBARGA	110	HV1	KUSTAGI_220	22:10	22:20	0:10	LOAD CURTAILMENT
452	28-Mar-19	GULBARGA	110	HV1	DHADESUGUR_110	22:00	22:10	0:10	TRANSFORMER FAULT
453	28-Mar-19	GULBARGA	110	HV1	KEMBHAVI_110	22:05	22:10	0:05	TRANSFORMER FAULT
454	28-Mar-19	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	20:37	20:54	0:17	LINE FAULT
455	28-Mar-19	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	21:35	21:45	0:10	LINE FAULT
456	28-Mar-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110, BYAGWAT_110,VALKAMDINI_110	23:40	23:59	0:19	LINE FAULT
457	28-Mar-19	GULBARGA	110	HV1	SHORAPUR_110	15:29	15:41	0:12	LINE CLEAR AVAILED
458	28-Mar-19	GULBARGA	110	HV2	SHORAPUR_110	15:46	16:03	0:17	LINE CLEAR AVAILED
459	28-Mar-19	GULBARGA	110	HV3	SHORAPUR_110	16:11	16:40	0:29	LINE CLEAR AVAILED
460	28-Mar-19	GULBARGA	110	HV4	SHORAPUR_110	16:23	16:41	0:18	LINE CLEAR AVAILED
461	28-Mar-19	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110	18:43	19:05	0:22	LINE FAULT
462	28-Mar-19	GULBARGA	110	HV2	YELBURGA_110	18:50	18:57	0:07	TRANSFORMER FAULT
463	28-Mar-19	GULBARGA	110	HV2	YELBURGA_110	22:06	22:19	0:13	LOAD CURTAILMENT
464	28-Mar-19	GULBARGA	110	HV2	YELBURGA_110	22:23	22:42	0:19	LOAD CURTAILMENT
465	28-Mar-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	18:05	23:59	5:54	LINE CLEAR AVAILED
466	28-Mar-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MARGUTTI_110,MAHAGOAN_110	18:05	19:26	1:21	LINE CLEAR AVAILED
467	28-Mar-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURGUNTA_110	5:30	23:59	18:29	LINE FAULT
468	28-Mar-19	GULBARGA	66	HV1	CJHALLI_66	22:10	22:20	0:10	TRANSFORMER FAULT
469	28-Mar-19	GULBARGA	66	HV1	HAGRIBOMMANAHALLI_66	11:10	11:55	0:45	LINE CLEAR AVAILED
470	28-Mar-19	GULBARGA	66	KOGALI-ATRSOLR	ASTROSOLAR_IPP	0:00	2:05	2:05	LINE CLEAR AVAILED
471	28-Mar-19	GULBARGA	66	HV1	CJHALLI_66	5:40	6:05	0:25	LOAD CURTAILMENT
472	28-Mar-19	GULBARGA	66	HV1	HAMPASAGAR_66	3:05	3:09	0:04	TRANSFORMER FAULT
473	28-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:38	23:59	6:21	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
474	28-Mar-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG	17:32	23:59	6:27	LINE FAULT
475	28-Mar-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG	11:23	11:59	0:36	LINE FAULT
476	28-Mar-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG	12:26	12:39	0:13	LINE FAULT
477	28-Mar-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG	20:33	23:59	3:26	NFBC ISSUED
478	28-Mar-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	11:23	12:09	0:46	LOAD CURTAILMENT
479	28-Mar-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	12:26	12:44	0:18	LOAD CURTAILMENT
480	28-Mar-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	11:42	12:08	0:26	HAND TRIPPED
481	28-Mar-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	11:23	12:09	0:46	LOAD CURTAILMENT
482	28-Mar-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	12:26	12:45	0:19	LOAD CURTAILMENT
483	28-Mar-19	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	11:43	12:08	0:25	LOAD CURTAILMENT
484	28-Mar-19	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	12:31	12:44	0:13	LOAD CURTAILMENT
485	28-Mar-19	HASSAN	110	HV1	BIRUR_110	22:15	22:18	0:03	MAIN SUPPLY FAILURE
486	28-Mar-19	HASSAN	110	HV1	BIRUR_110	5:43	6:10	0:27	MAIN SUPPLY FAILURE
487	28-Mar-19	HASSAN	110	HV2	GANDASI_110	5:42	5:47	0:05	MAIN SUPPLY FAILURE
488	28-Mar-19	HASSAN	110	HV2	GANDASI_110	22:11	22:24	0:13	MAIN SUPPLY FAILURE
489	28-Mar-19	HASSAN	110	HV1	HALADY_110	5:43	5:55	0:12	MAIN SUPPLY FAILURE
490	28-Mar-19	HASSAN	110	HV1	HALADY_110	22:13	22:34	0:21	MAIN SUPPLY FAILURE
491	28-Mar-19	HASSAN	110	HV2	HOSANGADI_110	11:48	14:45	2:57	LINE CLEAR AVAILED
492	28-Mar-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:44	13:47	3:03	LINE CLEAR AVAILED
493	28-Mar-19	HASSAN	110	HV4	PUTTUR_110	1:08	1:35	0:27	TRANSFORMER FAULT
494	28-Mar-19	HASSAN	66	HV2	BASAVAGHATTA_66	5:42	5:44	0:02	MAIN SUPPLY FAILURE
495	28-Mar-19	HASSAN	66	HV2	BASAVAGHATTA_66	22:11	22:14	0:03	MAIN SUPPLY FAILURE
496	28-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:02	13:07	0:05	LINE FAULT
497	28-Mar-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	5:41	5:48	0:07	MAIN SUPPLY FAILURE
498	28-Mar-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	22:11	22:16	0:05	MAIN SUPPLY FAILURE
499	28-Mar-19	HASSAN	66	HV1	HARIHARPURA_66	6:35	6:40	0:05	LOAD CURTAILMENT
500	28-Mar-19	HASSAN	66	HV1	HARIHARPURA_66	6:50	7:00	0:10	LOAD CURTAILMENT
501	28-Mar-19	HASSAN	66	HV1	HARIHARPURA_66	7:35	7:50	0:15	LOAD CURTAILMENT
502	28-Mar-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	6:35	6:41	0:06	LINE FAULT
503	28-Mar-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	6:51	6:59	0:08	LINE FAULT
504	28-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	2:03	2:16	0:13	LINE FAULT
505	28-Mar-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	19:03	20:25	1:22	LINE CLEAR AVAILED
506	28-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	9:10	19:00	9:50	NFBC ISSUED
507	28-Mar-19	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	5:45	19:00	13:15	NFBC ISSUED
508	28-Mar-19	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	5:45	19:00	13:15	NFBC ISSUED
509	28-Mar-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	22:09	22:27	0:18	TRANSFORMER FAULT
510	28-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:40	18:44	11:04	LINE CLEAR AVAILED
511	28-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:40	18:44	11:04	LINE CLEAR AVAILED
512	28-Mar-19	HASSAN	66	HV1	SATHENAHALLY_66	22:08	22:13	0:05	TRANSFORMER FAULT
513	28-Mar-19	HASSAN	66	HV1	SINGAPURA_66	6:37	6:43	0:06	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
514	28-Mar-19	HASSAN	66	HV1	SINGAPURA_66	6:51	8:01	1:10	LOAD CURTAILMENT
515	28-Mar-19	HASSAN	66	HV2	SINGAPURA_66	6:37	6:43	0:06	LOAD CURTAILMENT
516	28-Mar-19	HASSAN	66	HV2	SINGAPURA_66	6:51	8:01	1:10	LOAD CURTAILMENT
517	28-Mar-19	HASSAN	66	HV2	SINGAPURA_66	22:08	22:23	0:15	TRANSFORMER FAULT
518	28-Mar-19	MYSORE	66	HV2	ADDIHALLI_66	22:12	22:18	0:05	LOAD CURTAILMENT
519	28-Mar-19	MYSORE	66	HV2	ADDIHALLI_66	22:22	23:59	1:36	LOAD CURTAILMENT
520	28-Mar-19	MYSORE	66	HV1	BESAGARAHALLI_66	22:11	22:15	0:03	LOAD CURTAILMENT
521	28-Mar-19	MYSORE	66	HV2	BETTADHAPURA_66	18:16	19:05	0:49	LINE CLEAR AVAILED
522	28-Mar-19	MYSORE	66	HV1	BILIKERE_66	5:42	5:52	0:10	LOAD CURTAILMENT
523	28-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	5:41	5:53	0:11	LOAD CURTAILMENT
524	28-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	22:11	22:22	0:11	LOAD CURTAILMENT
525	28-Mar-19	MYSORE	66	HV1	BGNAGARA_66	5:41	5:45	0:03	LOAD CURTAILMENT
526	28-Mar-19	MYSORE	66	HV1	BGNAGARA_66	22:11	22:15	0:03	LOAD CURTAILMENT
527	28-Mar-19	MYSORE	66	HV1	BGNAGARA_66	22:22	22:30	0:07	LOAD CURTAILMENT
528	28-Mar-19	MYSORE	66	HV2	CHINAKURALI_66	5:41	6:15	0:33	LOAD CURTAILMENT
529	28-Mar-19	MYSORE	66	HV2	CHINAKURALI_66	22:11	22:35	0:24	LOAD CURTAILMENT
530	28-Mar-19	MYSORE	66	HV2	DODDARAYAPET_66	5:42	6:00	0:17	LOAD CURTAILMENT
531	28-Mar-19	MYSORE	66	HV2	ELAVALA_66	5:41	5:51	0:09	LOAD CURTAILMENT
532	28-Mar-19	MYSORE	66	HV2	ELAVALA_66	22:11	22:17	0:05	LOAD CURTAILMENT
533	28-Mar-19	MYSORE	66	HV2	ELAVALA_66	22:22	22:32	0:10	LOAD CURTAILMENT
534	28-Mar-19	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66 KOPPA_66	7:01	7:18	0:17	LINE FAULT
535	28-Mar-19	MYSORE	66	HV1	HANAGODU_66	5:42	6:21	0:39	LOAD CURTAILMENT
536	28-Mar-19	MYSORE	66	HV1	HANAGODU_66	22:11	22:17	0:05	LOAD CURTAILMENT
537	28-Mar-19	MYSORE	66	HV1	HANAGODU_66	22:22	22:30	0:08	LOAD CURTAILMENT
538	28-Mar-19	MYSORE	66	HV2	HANAGODU_66	22:17	22:21	0:03	LOAD CURTAILMENT
539	28-Mar-19	MYSORE	66	HV2	JAIPUR_66	5:48	6:01	0:13	LOAD CURTAILMENT
540	28-Mar-19	MYSORE	66	HV1	KADAKOLA_220	12:52	15:21	2:28	LINE CLEAR AVAILED
541	28-Mar-19	MYSORE	66	HV3	KIKKERI_66	17:00	18:06	1:06	LINE CLEAR AVAILED
542	28-Mar-19	MYSORE	66	HV2	KIRUGAVALU_66	22:09	22:41	0:32	LOAD CURTAILMENT
543	28-Mar-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66, MADDUR_66 TUMBEKERE_66	16:30	16:43	0:13	LINE FAULT
544	28-Mar-19	MYSORE	66	HV2	KMDODDI_66	5:47	5:59	0:12	TRANSFORMER FAULT
545	28-Mar-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	5:44	18:45	13:01	LINE CLEAR AVAILED
546	28-Mar-19	MYSORE	66	HV1	KUSHALANAGARA_66	22:11	22:22	0:11	LOAD CURTAILMENT
547	28-Mar-19	MYSORE	66	HV1	MADIKERI_66	9:46	16:39	6:53	LINE CLEAR AVAILED
548	28-Mar-19	MYSORE	66	HV2	MYSORESOUTH_66	8:08	8:17	0:09	TRANSFORMER FAULT
549	28-Mar-19	MYSORE	66	HV1	NAGAMANGALA_66	5:47	5:55	0:07	LOAD CURTAILMENT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
550	28-Mar-19	MYSORE	66	HV1	PANDAVAPURA_66	22:08	22:25	0:16	LOAD CURTAILMENT
551	28-Mar-19	MYSORE	66	HV1	RKNAGARA_66	11:44	11:55	0:10	LINE CLEAR AVAILED
552	28-Mar-19	MYSORE	66	HV1	SALIGRAMA_66	7:40	7:55	0:15	MAIN SUPPLY FAILURE
553	28-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	7:40	7:55	0:15	MAIN SUPPLY FAILURE
554	28-Mar-19	MYSORE	66	HV1	SALIGRAMA_66	9:05	9:10	0:05	MAIN SUPPLY FAILURE
555	28-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	9:05	23:59	14:54	MAIN SUPPLY FAILURE
556	28-Mar-19	MYSORE	66	HV2	SANTHESARAGUR_66	22:07	22:14	0:06	LOAD CURTAILMENT
557	28-Mar-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	22:08	22:21	0:13	LOAD CURTAILMENT
558	28-Mar-19	MYSORE	66	HV1	SATHEGALA_66	22:08	22:20	0:11	LOAD CURTAILMENT
559	28-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	13:21	23:59	10:37	LINE CLEAR AVAILED
560	28-Mar-19	MYSORE	66	HV2	THANDYA_66	11:58	12:08	0:10	TRANSFORMER FAULT
561	28-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 SHIVALLY_66	3:55	23:59	20:03	LINE FAULT
562	28-Mar-19	MYSORE	66	HV2	ADDIHALLI_66	22:12	22:18	0:05	LOAD CURTAILMENT
563	28-Mar-19	MYSORE	66	HV2	ADDIHALLI_66	22:22	23:59	1:36	LOAD CURTAILMENT
564	28-Mar-19	MYSORE	66	HV1	BESAGARAHALLI_66	22:11	22:15	0:03	LOAD CURTAILMENT
565	28-Mar-19	MYSORE	66	HV2	BETTADHAPURA_66	18:16	19:05	0:49	LINE CLEAR AVAILED
566	28-Mar-19	MYSORE	66	HV1	BILIKERE_66	5:42	5:52	0:10	LOAD CURTAILMENT
567	28-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	5:41	5:53	0:11	LOAD CURTAILMENT
568	28-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	22:11	22:22	0:11	LOAD CURTAILMENT
569	28-Mar-19	MYSORE	66	HV1	BGNAGARA_66	5:41	5:45	0:03	LOAD CURTAILMENT
570	28-Mar-19	MYSORE	66	HV1	BGNAGARA_66	22:11	22:15	0:03	LOAD CURTAILMENT
571	28-Mar-19	MYSORE	66	HV1	BGNAGARA_66	22:22	22:30	0:07	LOAD CURTAILMENT
572	28-Mar-19	MYSORE	66	HV2	CHINAKURALI_66	5:41	6:15	0:33	LOAD CURTAILMENT
573	28-Mar-19	MYSORE	66	HV2	CHINAKURALI_66	22:11	22:35	0:24	LOAD CURTAILMENT
574	28-Mar-19	MYSORE	66	HV2	DODDARAYAPET_66	5:42	6:00	0:17	LOAD CURTAILMENT
575	28-Mar-19	MYSORE	66	HV2	ELAVALA_66	5:41	5:51	0:09	LOAD CURTAILMENT
576	28-Mar-19	MYSORE	66	HV2	ELAVALA_66	22:11	22:17	0:05	LOAD CURTAILMENT
577	28-Mar-19	MYSORE	66	HV2	ELAVALA_66	22:22	22:32	0:10	LOAD CURTAILMENT
578	28-Mar-19	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66 KOPPA_66	7:01	7:18	0:17	LINE FAULT
579	28-Mar-19	MYSORE	66	HV1	HANAGODU_66	5:42	6:21	0:39	LOAD CURTAILMENT
580	28-Mar-19	MYSORE	66	HV1	HANAGODU_66	22:11	22:17	0:05	LOAD CURTAILMENT
581	28-Mar-19	MYSORE	66	HV1	HANAGODU_66	22:22	22:30	0:08	LOAD CURTAILMENT
582	28-Mar-19	MYSORE	66	HV2	HANAGODU_66	22:17	22:21	0:03	LOAD CURTAILMENT
583	28-Mar-19	MYSORE	66	HV2	JAIPUR_66	5:48	6:01	0:13	LOAD CURTAILMENT
584	28-Mar-19	MYSORE	66	HV1	KADAKOLA_220	12:52	15:21	2:28	LINE CLEAR AVAILED
585	28-Mar-19	MYSORE	66	HV3	KIKKERI_66	17:00	18:06	1:06	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
586	28-Mar-19	MYSORE	66	HV2	KIRUGAVALU_66	22:09	22:41	0:32	LOAD CURTAILMENT
587	28-Mar-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66, MADDUR_66 TUMBEKERE_66	16:30	16:43	0:13	LINE FAULT
588	28-Mar-19	MYSORE	66	HV2	KMDODDI_66	5:47	5:59	0:12	TRANSFORMER FAULT
589	28-Mar-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	5:44	18:45	13:01	LINE CLEAR AVAILED
590	28-Mar-19	MYSORE	66	HV1	KUSHALANAGARA_66	22:11	22:22	0:11	LOAD CURTAILMENT
591	28-Mar-19	MYSORE	66	HV1	MADIKERI_66	9:46	16:39	6:53	LINE CLEAR AVAILED
592	28-Mar-19	MYSORE	66	HV2	MYSORESOUTH_66	8:08	8:17	0:09	TRANSFORMER FAULT
593	28-Mar-19	MYSORE	66	HV1	NAGAMANGALA_66	5:47	5:55	0:07	LOAD CURTAILMENT
594	28-Mar-19	MYSORE	66	HV1	PANDAVAPURA_66	22:08	22:25	0:16	LOAD CURTAILMENT
595	28-Mar-19	MYSORE	66	HV1	RKNAGARA_66	11:44	11:55	0:10	LINE CLEAR AVAILED
596	28-Mar-19	MYSORE	66	HV1	SALIGRAMA_66	7:40	7:55	0:15	MAIN SUPPLY FAILURE
597	28-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	7:40	7:55	0:15	MAIN SUPPLY FAILURE
598	28-Mar-19	MYSORE	66	HV1	SALIGRAMA_66	9:05	9:10	0:05	MAIN SUPPLY FAILURE
599	28-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	9:05	23:59	14:54	MAIN SUPPLY FAILURE
600	28-Mar-19	MYSORE	66	HV2	SANTHESARAGUR_66	22:07	22:14	0:06	LOAD CURTAILMENT
601	28-Mar-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	22:08	22:21	0:13	LOAD CURTAILMENT
602	28-Mar-19	MYSORE	66	HV1	SATHEGALA_66	22:08	22:20	0:11	LOAD CURTAILMENT
603	28-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	13:21	23:59	10:37	LINE CLEAR AVAILED
604	28-Mar-19	MYSORE	66	HV2	THANDYA_66	11:58	12:08	0:10	TRANSFORMER FAULT
605	28-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 SHIVALLY_66	3:55	23:59	20:03	LINE FAULT
606	28-Mar-19	TUMKUR	220	TR-1	ANCHEPALYA_220	2:10	8:22	6:11	TRANSFORMER FAULT
607	28-Mar-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	11:38	12:13	0:34	MAIN SUPPLY FAILURE
608	28-Mar-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	12:05	12:14	0:08	HAND TRIPPED
609	28-Mar-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	12:05	12:14	0:08	HAND TRIPPED
610	28-Mar-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	11:17	11:41	0:24	HAND TRIPPED
611	28-Mar-19	TUMKUR	110	TR-1	TIPTUR_110	12:08	12:17	0:09	TRANSFORMER FAULT
612	28-Mar-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	2:10	2:19	0:08	HAND TRIPPED
613	28-Mar-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	2:10	2:12	0:02	HAND TRIPPED
614	28-Mar-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	2:10	2:35	0:24	HAND TRIPPED
615	28-Mar-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	2:10	3:20	1:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
616	28-Mar-19	TUMKUR	66	ANCHEPALYA 220KV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	2:36	3:20	0:43	HAND TRIPPED
617	28-Mar-19	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR(BG NAGAR)	YEDIYUR_66	2:10	2:13	0:03	HAND TRIPPED
618	28-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:06	11:19	0:12	HAND TRIPPED
619	28-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:06	11:21	0:14	HAND TRIPPED
620	28-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:06	11:21	0:14	HAND TRIPPED
621	28-Mar-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:29	10:35	0:06	HAND TRIPPED
622	28-Mar-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	23:14	23:43	0:29	MAIN SUPPLY FAILURE
623	28-Mar-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	22:44	23:14	0:29	MAIN SUPPLY FAILURE
624	29-Mar-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	19:19	20:13	0:54	LINE FAULT
625	29-Mar-19	BAGALKOT	220	RAVI URJA 1-ATHANI	ATHANI_220	11:56	14:15	2:19	LINE CLEAR AVAILED
626	29-Mar-19	BAGALKOT	220	RAVI URJA 2-ATHANI	ATHANI_220	14:16	14:46	0:30	LINE CLEAR AVAILED
627	29-Mar-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	12:33	14:17	1:44	LINE CLEAR AVAILED
628	29-Mar-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	16:04	17:01	0:57	LINE FAULT
629	29-Mar-19	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	10:20	20:26	10:06	LINE CLEAR AVAILED
630	29-Mar-19	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	17:46	23:59	6:13	LINE FAULT
631	29-Mar-19	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	18:29	18:42	0:13	TRANSFORMER FAULT
632	29-Mar-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110	16:16	16:25	0:09	TRANSFORMER FAULT
633	29-Mar-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	6:55	7:08	0:13	TRANSFORMER FAULT
634	29-Mar-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	18:36	18:48	0:12	HAND TRIPPED
635	29-Mar-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	18:43	18:54	0:11	TRANSFORMER FAULT
636	29-Mar-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	20:54	21:07	0:13	TRANSFORMER FAULT
637	29-Mar-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	21:17	21:28	0:11	TRANSFORMER FAULT
638	29-Mar-19	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	17:51	18:00	0:09	TRANSFORMER FAULT
639	29-Mar-19	BAGALKOT	220	DHONI-LINGAPUR 1	DHONI_400	7:15	15:31	8:16	LINE CLEAR AVAILED
640	29-Mar-19	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	9:50	17:37	7:47	LINE CLEAR AVAILED
641	29-Mar-19	BAGALKOT	110	KERUR-KONNUR	KERUR_110	14:39	15:23	0:44	HAND TRIPPED
642	29-Mar-19	BAGALKOT	110	KERUR-KONNUR	KERUR_110	18:50	18:56	0:06	HAND TRIPPED
643	29-Mar-19	BAGALKOT	110	110/11KV,HV3	TARIHAL_110,DUMMAWAD_33KV,INDUSTRIAL ESTET_33KV	11:13	13:26	2:13	LINE CLEAR AVAILED
644	29-Mar-19	BAGALKOT	220	220/110KV,HV2	HUBLI_220	11:23	13:44	2:21	LINE CLEAR AVAILED
645	29-Mar-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	14:45	15:51	1:06	LINE FAULT
646	29-Mar-19	BAGALKOT	220	220/110KV,HV2	HUBLI_220	16:04	17:20	1:16	LINE CLEAR AVAILED
647	29-Mar-19	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	19:22	20:05	0:43	LINE FAULT
648	29-Mar-19	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	14:04	23:59	9:55	LINE FAULT
649	29-Mar-19	BAGALKOT	110	HUBLI-KALGATAGI	KALGATAGI_110	16:19	17:48	1:29	LINE CLEAR AVAILED
650	29-Mar-19	BAGALKOT	110	HUBLI-KALGATAGI	KALGATAGI_110	18:08	19:27	1:19	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
651	29-Mar-19	BAGALKOT	110	HUBLI-KALGATAGI	KALGATAGI_110	23:46	23:59	0:13	LINE CLEAR AVAILED
652	29-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	15:30	15:31	0:01	HAND TRIPPED
653	29-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	15:50	18:06	2:16	LINE CLEAR AVAILED
654	29-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	18:12	19:38	1:26	LINE CLEAR AVAILED
655	29-Mar-19	BAGALKOT	110	SIRSI110-JOG2	SIRSI_110	11:05	12:03	0:58	LINE CLEAR AVAILED
656	29-Mar-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	20:49	20:56	0:07	TRANSFORMER FAULT
657	29-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	13:00	13:58	0:58	LINE CLEAR AVAILED
658	29-Mar-19	BAGALKOT	110	110/11KV,HV1	LAKMANAHALLI_110	11:26	12:12	0:46	LINE CLEAR AVAILED
659	29-Mar-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	19:38	23:51	4:13	LINE CLEAR AVAILED
660	29-Mar-19	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	0:41	13:09	12:28	LINE FAULT
661	29-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	18:33	19:40	1:07	LINE CLEAR AVAILED
662	29-Mar-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	8:07	8:36	0:28	LINE FAULT
663	29-Mar-19	BENGALURU	66	HV2	TAVAREKERE	2:24	2:32	0:08	TRANSFORMER FAULT
664	29-Mar-19	BENGALURU	66	NRS 220 - SRS 2	NRS 220	0:00	0:12	0:12	LINE FAULT
665	29-Mar-19	BENGALURU	66	NRS 220 - SRS 2	NRS 220	0:12	0:52	0:40	LINE FAULT
666	29-Mar-19	BENGALURU	66	HV2	RAJANKUNTE	12:50	13:15	0:25	TRANSFORMER FAULT
667	29-Mar-19	BENGALURU	220	LV1	NIMHANS 220	2:06	2:25	0:18	TRANSFORMER FAULT
668	29-Mar-19	BENGALURU	66	HV1	C STATION	1:21	1:32	0:10	TRANSFORMER FAULT
669	29-Mar-19	BENGALURU	66	HV2	BRIGADE METROPOLIS	3:23	3:38	0:14	TRANSFORMER FAULT
670	29-Mar-19	BENGALURU	220	DB PURA 220 - BEGUR 220	BEGUR 220, HOSKOTE 220	13:52	13:58	0:06	LINE FAULT
671	29-Mar-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:30	21:34	0:04	LINE FAULT
672	29-Mar-19	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	11:58	12:45	0:46	LINE FAULT
673	29-Mar-19	BENGALURU	66	HV2	CHANNAPATNA	18:50	18:53	0:03	TRANSFORMER FAULT
674	29-Mar-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:39	17:48	0:08	LINE FAULT
675	29-Mar-19	BENGALURU	66	VIDHURASHWATHA - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	23:50	23:59	0:09	LINE FAULT
676	29-Mar-19	BENGALURU	66	BAGEPALLI - SOMANATHAPURA	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	23:50	23:59	0:09	LINE FAULT
677	29-Mar-19	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	11:36	12:57	1:21	LINE CLEAR AVAILED
678	29-Mar-19	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	13:14	14:09	0:55	LINE CLEAR AVAILED
679	29-Mar-19	GULBARGA	220	LINGAPUR-GADAG1	LINGAPUR_220	7:21	15:32	8:11	NFBC ISSUED
680	29-Mar-19	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	15:43	16:23	0:40	LINE CLEAR AVAILED
681	29-Mar-19	GULBARGA	220	LINGAPUR-GUDDAHALLI1	LINGAPUR_220	10:42	11:18	0:36	LINE CLEAR AVAILED
682	29-Mar-19	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	16:31	17:24	0:53	LINE CLEAR AVAILED
683	29-Mar-19	GULBARGA	220	HV1	KAPNOOR_220	11:23	16:45	5:22	LINE CLEAR AVAILED
684	29-Mar-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	4:17	4:25	0:08	LINE FAULT
685	29-Mar-19	GULBARGA	110	HV1	BISIHALLI_110	16:58	18:31	1:33	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
686	29-Mar-19	GULBARGA	110	HV1	CHICKSUGUR_110	19:47	19:55	0:08	LINE CLEAR AVAILED
687	29-Mar-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110, BYAGWAT_110,VALKAMDINI_110	0:00	0:08	0:08	LINE FAULT
688	29-Mar-19	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE LINE)	MAVI_110,MADALAPUR_110, KURDICROSS_110	20:19	23:59	3:40	LINE FAULT
689	29-Mar-19	GULBARGA	110	HV1	YELBURGA_110	17:25	17:45	0:20	TRANSFORMER FAULT
690	29-Mar-19	GULBARGA	110	HV1	YELBURGA_110	18:05	18:31	0:26	TRANSFORMER FAULT
691	29-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	16:22	16:22	LINE FAULT
692	29-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:03	23:59	4:56	LINE FAULT
693	29-Mar-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	8:00	13:14	5:14	LINE CLEAR AVAILED
694	29-Mar-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	0:00	0:56	0:56	LINE FAULT
695	29-Mar-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	0:00	0:53	0:53	NFBC ISSUED
696	29-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:42	15:51	0:09	LINE FAULT
697	29-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	20:04	20:30	0:26	LINE FAULT
698	29-Mar-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:01	13:14	5:13	NFBC ISSUED
699	29-Mar-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	20:04	20:31	0:27	LINE FAULT
700	29-Mar-19	HASSAN	110	HV2	KEMAR_220	13:11	15:32	2:21	LINE CLEAR AVAILED
701	29-Mar-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:56	19:04	0:08	LINE FAULT
702	29-Mar-19	HASSAN	110	HV2	SORABA_110	15:02	15:39	0:37	LINE CLEAR AVAILED
703	29-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:23	15:28	0:05	LINE FAULT
704	29-Mar-19	HASSAN	66	HV1	DIDIGA_66	12:57	14:21	1:24	LINE CLEAR AVAILED
705	29-Mar-19	HASSAN	66	HNPR2-HASS3	HOLENARSIPURA_220	12:00	12:23	0:23	LINE CLEAR AVAILED
706	29-Mar-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	12:17	12:21	0:04	LINE FAULT
707	29-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:51	7:13	0:22	LOAD CURTAILMENT
708	29-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	19:46	19:57	0:11	LINE FAULT
709	29-Mar-19	HASSAN	66	HV1	MAGGE_66	10:40	12:11	1:31	LINE CLEAR AVAILED
710	29-Mar-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	13:03	13:35	0:32	TRANSFORMER FAULT
711	29-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:02	19:11	11:09	LOAD CURTAILMENT
712	29-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:02	19:11	11:09	LOAD CURTAILMENT
713	29-Mar-19	HASSAN	66	HV1	SIGEBAGE_66	13:09	13:36	0:27	LOAD CURTAILMENT
714	29-Mar-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	1:18	7:05	5:47	LINE FAULT
715	29-Mar-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	13:09	13:36	0:27	LINE CLEAR AVAILED
716	29-Mar-19	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	13:10	13:36	0:26	LINE CLEAR AVAILED
717	29-Mar-19	HASSAN	66	HV2	SINGAPURA_66	12:40	13:59	1:19	LINE CLEAR AVAILED
718	29-Mar-19	MYSORE	66	HV2	BGNAGARA_66	11:05	12:08	1:03	LINE CLEAR AVAILED
719	29-Mar-19	MYSORE	66	HANNUR-DODDINDUVADI	KOTTANUR_66	17:45	23:59	6:13	NFBC ISSUED
720	29-Mar-19	MYSORE	66	KM DODDI-TK HALLI	KOLKARANADODDI_66 KIADBMANDYA_66 K K_HONNALGERE_66 MADDUR_66 TUMBEKERE_66	8:08	8:35	0:27	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
721	29-Mar-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 K K_HONNALGERE_66 MADDUR_66 TUMBEKERE_66	8:21	11:43	3:22	NFBC ISSUED
722	29-Mar-19	MYSORE	66	MEGHALAPURA-SFC	CHIDRAVALLI_66 THUMLA_66	10:20	12:50	2:30	NFBC ISSUED
723	29-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	19:21	23:59	4:37	LINE CLEAR AVAILED
724	29-Mar-19	MYSORE	66	HV1	VIRAJPET_66	9:55	14:17	4:22	LINE CLEAR AVAILED
725	29-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:23	19:45	14:22	LINE CLEAR AVAILED
726	29-Mar-19	TUMKUR	220	TR-2	DAVANGERE_SRS_220	11:23	11:29	0:06	TRANSFORMER FAULT
727	29-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:24	19:47	14:22	LINE CLEAR AVAILED
728	29-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	23:28	23:37	0:09	TRANSFORMER FAULT
729	29-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:43	15:51	0:07	LINE FAULT
730	29-Mar-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHILI)	CHANNAGIRI_66	17:58	18:31	0:33	MAIN SUPPLY FAILURE
731	29-Mar-19	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	15:51	15:53	0:01	MAIN SUPPLY FAILURE
732	29-Mar-19	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	17:24	18:36	1:12	LINE CLEAR AVAILED
733	29-Mar-19	TUMKUR	66	TR-1	DEVARAHALLI_66	17:24	18:36	1:12	LINE CLEAR AVAILED
734	29-Mar-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:26	11:35	0:09	HAND TRIPPED
735	29-Mar-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	11:26	11:35	0:09	HAND TRIPPED
736	29-Mar-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:26	11:38	0:12	HAND TRIPPED
737	29-Mar-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:26	11:35	0:09	HAND TRIPPED
738	29-Mar-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	16:09	16:28	0:19	LINE CLEAR AVAILED
739	29-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:01	18:55	9:54	LINE CLEAR AVAILED
740	29-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	20:11	20:18	0:07	LINE FAULT
741	29-Mar-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	22:23	22:35	0:12	HAND TRIPPED
742	29-Mar-19	TUMKUR	66	MALLASANDRA- ANCHEPALYA	MALLASANDRA_66	14:22	14:29	0:07	LINE FAULT
743	29-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	12:58	13:04	0:06	LINE FAULT
744	29-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	15:02	15:13	0:10	LINE FAULT
745	29-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:47	15:02	5:15	LINE FAULT
746	29-Mar-19	TUMKUR	66	TR-1 & TR-2	TAVAREKERE(C)_66	12:20	13:33	1:12	LINE CLEAR AVAILED
747	29-Mar-19	TUMKUR	66	TR-1 & TR-2	TAVAREKERE(C)_66	20:17	20:23	0:05	TRANSFORMER FAULT
748	29-Mar-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	21:59	22:04	0:04	TRANSFORMER FAULT
749	30-Mar-19	BAGALKOT	110	110/11KV,HV-2	AINAPUR_110	4:55	4:59	0:04	LOAD CURTAILMENT
750	30-Mar-19	BAGALKOT	110	110/11KV,HV-2	AINAPUR_110	5:51	5:55	0:04	LOAD CURTAILMENT
751	30-Mar-19	BAGALKOT	110	ATHANI-ATHANI SUGARS	ATHANI_110	14:18	15:15	0:57	LINE CLEAR AVAILED
752	30-Mar-19	BAGALKOT	110	110/11KV,HV-2	ANAND NAGAR_110	11:15	17:52	6:37	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
753	30-Mar-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	4:57	5:07	0:10	LOAD CURTAILMENT
754	30-Mar-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	5:51	6:04	0:13	LOAD CURTAILMENT
755	30-Mar-19	BAGALKOT	110	110/33KV,HV-3	BAGALKOT_220&KATAGERI_33	4:57	5:50	0:53	LOAD CURTAILMENT
756	30-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	11:05	13:36	2:31	LINE CLEAR AVAILED
757	30-Mar-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	9:43	14:18	4:35	LINE CLEAR AVAILED
758	30-Mar-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	21:18	22:19	1:01	LINE FAULT
759	30-Mar-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	13:06	15:51	2:45	LINE CLEAR AVAILED
760	30-Mar-19	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	12:26	16:37	4:11	LINE CLEAR AVAILED
761	30-Mar-19	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	14:11	14:37	0:26	LINE FAULT
762	30-Mar-19	BAGALKOT	220	BAGEWADI-ATRIA-1	BAGEWADI_220	9:50	17:57	8:07	LINE CLEAR AVAILED
763	30-Mar-19	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	21:17	21:20	0:03	TRANSFORMER FAULT
764	30-Mar-19	BAGALKOT	110	BIDNAL220-GADAG ROAD	GADAG ROAD_110	12:15	16:13	3:58	NFBC ISSUED
765	30-Mar-19	BAGALKOT	110	GADAG ROAD-GOPPANKOPPA	GOPPANKOPPA_110	16:17	16:45	0:28	LINE CLEAR AVAILED
766	30-Mar-19	BAGALKOT	110	ANNIGERI-GADAG	GADAG_110	11:17	23:59	12:42	LINE CLEAR AVAILED
767	30-Mar-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	4:56	5:05	0:09	LOAD CURTAILMENT
768	30-Mar-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	5:51	6:02	0:11	LOAD CURTAILMENT
769	30-Mar-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	6:45	7:02	0:17	TRANSFORMER FAULT
770	30-Mar-19	BAGALKOT	110	GADAG ROAD-GOPPANKOPPA	GOPPANKOPPA_110	16:45	16:49	0:04	LINE CLEAR AVAILED
771	30-Mar-19	BAGALKOT	110	GOPPANKOPPA-MRUTHYUNJAY NAGAR 1 & 2	GOPANKOPPA_110	16:54	17:03	0:09	LINE CLEAR AVAILED
772	30-Mar-19	BAGALKOT	110	NARGUND-GOPPANKOPPA	GOPANKOPPA_110	17:54	19:39	1:45	LINE CLEAR AVAILED
773	30-Mar-19	BAGALKOT	110	GMR-HALIYAL	GALIYA_110	13:13	13:30	0:17	LINE CLEAR AVAILED
774	30-Mar-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110	5:14	5:26	0:12	LOAD CURTAILMENT
775	30-Mar-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33KV	5:51	6:11	0:20	LOAD CURTAILMENT
776	30-Mar-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	15:43	19:41	3:58	LINE FAULT
777	30-Mar-19	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	4:56	5:10	0:14	LOAD CURTAILMENT
778	30-Mar-19	BAGALKOT	110	110/11KV,HV3	HIDIKAL_110,KOLIGUDDA_33KV	5:51	6:10	0:19	LOAD CURTAILMENT
779	30-Mar-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	17:02	18:30	1:28	LINE CLEAR AVAILED
780	30-Mar-19	BAGALKOT	110	VAJRAMATTI220-MALLIGERI	MALLIGERI_110	10:08	10:25	0:17	HAND TRIPPED
781	30-Mar-19	BAGALKOT	110	VAJRAMATTI220-MANTUR	MANTUR_110	16:40	17:45	1:05	LINE CLEAR AVAILED
782	30-Mar-19	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	22:30	23:50	1:20	LINE CLEAR AVAILED
783	30-Mar-19	BAGALKOT	110	110/11KV, HV2	TILUVALI_110	4:57	6:21	1:24	LOAD CURTAILMENT
784	30-Mar-19	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	0:00	3:37	3:37	LINE CLEAR AVAILED
785	30-Mar-19	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	0:00	3:28	3:28	LINE CLEAR AVAILED
786	30-Mar-19	BAGALKOT	110	MMCL-SOUDATTI220	SOUDATTI_220	15:24	16:34	1:10	LINE CLEAR AVAILED
787	30-Mar-19	BAGALKOT	110	MMCL-SOUDATTI220	SOUDATTI_220	15:55	16:34	0:39	LINE FAULT
788	30-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:09	13:48	1:39	LINE CLEAR AVAILED
789	30-Mar-19	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	4:56	5:11	0:15	LOAD CURTAILMENT
790	30-Mar-19	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	7:36	14:14	6:38	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
791	30-Mar-19	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66, AREMALLAPUR_33	5:15	10:48	5:33	LOAD CURTAILMENT
792	30-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	13:09	13:35	0:26	LINE CLEAR AVAILED
793	30-Mar-19	BAGALKOT	220	SHIROLKOPPA-RANEENNUR	RANEENNUR_220	13:09	14:49	1:40	LINE CLEAR AVAILED
794	30-Mar-19	BAGALKOT	110	110/33KV, HV3	RANEENNUR_220, GUDURMAIDUR_33,HALAGERI_33	4:56	4:59	0:03	LOAD CURTAILMENT
795	30-Mar-19	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	4:56	5:01	0:05	LOAD CURTAILMENT
796	30-Mar-19	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	5:51	5:56	0:05	LOAD CURTAILMENT
797	30-Mar-19	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	0:00	18:20	18:20	LINE CLEAR AVAILED
798	30-Mar-19	BAGALKOT	110	110/11KV, HV1	MURDESHWAR_110	19:37	20:11	0:34	HAND TRIPPED
799	30-Mar-19	BAGALKOT	110	110/11KV, HV2	MUKARTHAL_110	13:47	18:19	4:32	LINE CLEAR AVAILED
800	30-Mar-19	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANAKOPPA 1	GOPANAKOPPA_110	16:50	23:59	7:09	LINE CLEAR AVAILED
801	30-Mar-19	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANAKOPPA 2	GOPANAKOPPA_110	16:51	23:59	7:08	LINE CLEAR AVAILED
802	30-Mar-19	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	5:25	5:38	0:13	LOAD CURTAILMENT
803	30-Mar-19	BAGALKOT	220	220/110KV, HV2	M K HUBLI_220	15:08	18:33	3:25	LINE CLEAR AVAILED
804	30-Mar-19	BAGALKOT	110	MK HUBLI220-MKHUBLI 1&2	M K HUBLI_110	14:47	19:04	4:17	LINE CLEAR AVAILED
805	30-Mar-19	BAGALKOT	110	110/11KV,HV1	M K HUBLI_110	18:08	18:41	0:33	TRANSFORMER FAULT
806	30-Mar-19	BAGALKOT	110	110/11KV, HV1	LAKAMANAHALLI_110	4:56	5:26	0:30	LOAD CURTAILMENT
807	30-Mar-19	BAGALKOT	110	KUMTA-SIRSI 1	SIRSI_110	6:51	23:59	17:08	LINE CLEAR AVAILED
808	30-Mar-19	BAGALKOT	220	MAHALINGAPUR-KUDUCHI	KUDUCHI_220	13:35	13:51	0:16	LINE FAULT
809	30-Mar-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	KUDUCHI_220	13:35	13:51	0:16	LINE FAULT
810	30-Mar-19	BAGALKOT	220	CHIKKODI-KUDUCHI	KUDUCHI_220	13:51	14:20	0:29	LINE FAULT
811	30-Mar-19	BAGALKOT	220	ATHANI-KUDUCHI	KUDUCHI_220	13:51	14:16	0:25	LINE FAULT
812	30-Mar-19	BAGALKOT	220	220/110KV,HV1&2,LV1&2	KUDUCHI_220,UGARKHUD_110,MURAB_110,TERDAL_110,AINAPUR_110,KUDUCHI_110,YELPARATTI_110	13:51	14:09	0:18	TRANSFORMER FAULT
813	30-Mar-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	0:01	6:51	6:50	LINE CLEAR AVAILED
814	30-Mar-19	BAGALKOT	220	KADRA 2-KARWAR	KARWAR_220	9:52	18:05	8:13	LINE CLEAR AVAILED
815	30-Mar-19	BENGALURU	66	HV1	TK HALLI 220	12:38	12:48	0:10	TRANSFORMER FAULT
816	30-Mar-19	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	BRINDAVANA	17:45	18:15	0:30	LINE FAULT
817	30-Mar-19	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	16:45	17:05	0:20	LINE FAULT
818	30-Mar-19	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA 220	16:45	17:06	0:21	LINE FAULT
819	30-Mar-19	BENGALURU	220	HV2	SRS PEENYA 220	16:45	17:16	0:31	TRANSFORMER FAULT
820	30-Mar-19	BENGALURU	66	HV1	NAGANATHPURA 220	13:21	14:24	1:02	TRANSFORMER FAULT
821	30-Mar-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:47	17:53	0:05	LINE FAULT
822	30-Mar-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	6:35	6:41	0:06	LINE FAULT
823	30-Mar-19	BENGALURU	66	HV1	TYAMAGONDALU	16:55	18:15	1:20	TRANSFORMER FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
824	30-Mar-19	BENGALURU	66	HV2	TYAMAGONDALU	20:55	21:05	0:10	TRANSFORMER FAULT
825	30-Mar-19	GULBARGA	400	BTPS-RTPS	RTPS_400	12:35	13:19	0:44	LINE CLEAR AVAILED
826	30-Mar-19	GULBARGA	400	BTPS-JINDAL	JINDAL_400	10:44	12:06	1:22	LINE CLEAR AVAILED
827	30-Mar-19	GULBARGA	220	HV2	HALBURGA_220	19:28	19:30	0:02	TRANSFORMER FAULT
828	30-Mar-19	GULBARGA	110	HV1	AFZALPUR_110	12:15	12:20	0:05	TRANSFORMER FAULT
829	30-Mar-19	GULBARGA	110	HV4	ALAND_110	11:10	14:20	3:10	LINE CLEAR AVAILED
830	30-Mar-19	GULBARGA	110	HV3	HANUMASAGAR_110	5:50	6:02	0:12	LOAD CURTAILMENT
831	30-Mar-19	GULBARGA	110	KAPNOOR-GULBARGA NORTH 1,2	GULBARGANORTH_110,GULBARGAUNI VERSITY_110	12:21	12:29	0:08	LINE CLEAR AVAILED
832	30-Mar-19	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,ASKI_11 0	4:15	4:25	0:10	LINE FAULT
833	30-Mar-19	GULBARGA	110	KEMBHAVI-HUNSGI	HUNSAGI_110	9:20	10:00	0:40	LINE CLEAR AVAILED
834	30-Mar-19	GULBARGA	110	HV1	KEMBHAVI_110	4:56	5:01	0:05	LOAD CURTAILMENT
835	30-Mar-19	GULBARGA	110	HV1	KEMBHAVI_110	5:32	5:37	0:05	LOAD CURTAILMENT
836	30-Mar-19	GULBARGA	110	HV2	KOLHAR_110	4:56	5:15	0:19	LOAD CURTAILMENT
837	30-Mar-19	GULBARGA	110	HV2	KOLHAR_110	5:32	5:45	0:13	LOAD CURTAILMENT
838	30-Mar-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110, BYAGWAT_110,VALKAMDINI_110	11:08	11:15	0:07	LINE FAULT
839	30-Mar-19	GULBARGA	110	HV1	RAICHUR_220	12:00	12:24	0:24	LINE CLEAR AVAILED
840	30-Mar-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	4:56	5:05	0:09	LOAD CURTAILMENT
841	30-Mar-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	5:32	5:38	0:06	LOAD CURTAILMENT
842	30-Mar-19	GULBARGA	110	SEDAM-VICTASAGAR CEMENTS	VICTASAGAR CEMENTS_IPP	5:14	5:30	0:16	LINE FAULT
843	30-Mar-19	GULBARGA	110	HV1	SHAHPUR_110	16:05	16:20	0:15	TRANSFORMER FAULT
844	30-Mar-19	GULBARGA	110	HV1	SHORAPUR_110	14:00	14:13	0:13	LINE CLEAR AVAILED
845	30-Mar-19	GULBARGA	110	HV1	WADAGERA_110	4:56	5:00	0:04	LOAD CURTAILMENT
846	30-Mar-19	GULBARGA	110	HV1	WADAGERA_110	5:32	5:35	0:03	LOAD CURTAILMENT
847	30-Mar-19	GULBARGA	110	HV4	YELBURGA_110	4:56	5:17	0:21	LOAD CURTAILMENT
848	30-Mar-19	GULBARGA	110	HV4	YELBURGA_110	5:50	6:09	0:19	LOAD CURTAILMENT
849	30-Mar-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOA_110, KAMALNAGAR_110	19:28	19:35	0:07	LINE FAULT
850	30-Mar-19	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	9:29	19:05	9:36	LINE CLEAR AVAILED
851	30-Mar-19	GULBARGA	110	HV1	SIRWAR_110	17:01	22:20	5:19	TRANSFORMER FAULT
852	30-Mar-19	GULBARGA	110	SEDAM-VASAVADATTA	SEDAM_220	22:07	22:13	0:06	LINE FAULT
853	30-Mar-19	GULBARGA	66	HV1	CJHALLI_66	5:14	5:28	0:14	LOAD CURTAILMENT
854	30-Mar-19	GULBARGA	66	HV1	CJHALLI_66	5:50	6:02	0:12	LOAD CURTAILMENT
855	30-Mar-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	10:30	11:45	1:15	LINE CLEAR AVAILED
856	30-Mar-19	GULBARGA	66	HV1	SOVENAHALLI_66	4:56	5:00	0:04	LOAD CURTAILMENT
857	30-Mar-19	GULBARGA	66	HV1	SOVENAHALLI_66	5:32	5:40	0:08	LOAD CURTAILMENT
858	30-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	7:20	7:37	0:17	LINE CLEAR AVAILED
859	30-Mar-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	11:14	15:15	4:01	NFBC ISSUED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
860	30-Mar-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:42	10:46	0:04	HAND TRIPPED
861	30-Mar-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:49	10:59	0:10	HAND TRIPPED
862	30-Mar-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	11:02	15:17	4:15	LINE CLEAR AVAILED
863	30-Mar-19	HASSAN	220	HV1	SHIRALKOPPA_220	17:18	19:57	2:39	LINE CLEAR AVAILED
864	30-Mar-19	HASSAN	110	MSEZ-GSS31	MSEZ_220	10:06	15:08	5:02	LINE CLEAR AVAILED
865	30-Mar-19	HASSAN	110	HV2	MSEZ_220	11:53	14:22	2:29	LINE CLEAR AVAILED
866	30-Mar-19	HASSAN	110	LV1	SHIRALKOPPA_220	17:18	19:57	2:39	LINE CLEAR AVAILED
867	30-Mar-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	17:11	20:16	3:05	LINE CLEAR AVAILED
868	30-Mar-19	HASSAN	110	HV1	HALADY_110	5:15	5:30	0:15	LOAD CURTAILMENT
869	30-Mar-19	HASSAN	110	HV2	GANDASI_110	5:50	5:58	0:08	LOAD CURTAILMENT
870	30-Mar-19	HASSAN	110	HV2	GERUMARA_110	5:50	6:02	0:12	LOAD CURTAILMENT
871	30-Mar-19	HASSAN	110	SORABA-SHR220	SORABA_110	17:49	20:24	2:35	LINE CLEAR AVAILED
872	30-Mar-19	HASSAN	66	HV1	HANGRANAHALLY_66	5:50	6:08	0:18	LOAD CURTAILMENT
873	30-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	7:37	18:30	10:53	LINE CLEAR AVAILED
874	30-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	7:37	18:30	10:53	LINE CLEAR AVAILED
875	30-Mar-19	MYSORE	66	HV1	BESAGARAHALLI_66	5:50	23:59	18:08	LOAD CURTAILMENT
876	30-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	5:50	6:06	0:15	LOAD CURTAILMENT
877	30-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	17:49	18:34	0:44	LOAD CURTAILMENT
878	30-Mar-19	MYSORE	66	HV2	CHINAKURALI_66	5:50	6:05	0:15	LOAD CURTAILMENT
879	30-Mar-19	MYSORE	66	HV1	CRNAGAR_220	12:55	14:07	1:12	LINE CLEAR AVAILED
880	30-Mar-19	MYSORE	66	HV2	ELAVALA_66	5:50	6:16	0:25	LOAD CURTAILMENT
881	30-Mar-19	MYSORE	66	HV1	HANAGODU_66	5:51	6:36	0:44	LOAD CURTAILMENT
882	30-Mar-19	MYSORE	66	HV2	HDKOTE_66	5:50	6:30	0:39	LOAD CURTAILMENT
883	30-Mar-19	MYSORE	66	HV2	JAIPUR_66	5:50	6:07	0:17	LOAD CURTAILMENT
884	30-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	10:03	10:08	0:04	LINE FAULT
885	30-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66,	10:03	10:07	0:04	LINE FAULT
886	30-Mar-19	MYSORE	66	HV2	KMDODDI_66	5:50	5:59	0:08	TRANSFORMER FAULT
887	30-Mar-19	MYSORE	66	HV3	KUSHALANAGARA_66	16:44	17:03	0:19	HAND TRIPPED
888	30-Mar-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:49	7:14	0:24	LINE CLEAR AVAILED
889	30-Mar-19	MYSORE	66	HV1	NAGAMANGALA_66	5:50	5:55	0:04	LOAD CURTAILMENT
890	30-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	0:10	0:20	0:10	TRANSFORMER FAULT
891	30-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	15:09	23:59	8:49	LINE CLEAR AVAILED
892	30-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	16:31	16:36	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
893	30-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	17:49	17:56	0:06	LINE FAULT
894	30-Mar-19	TUMKUR	220	TR-3	CHITRADURGA_220	13:44	13:50	0:06	TRANSFORMER FAULT
895	30-Mar-19	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	15:41	16:04	0:23	LINE CLEAR AVAILED
896	30-Mar-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	5:51	6:35	0:43	LOAD CURTAILMENT
897	30-Mar-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	6:18	6:50	0:31	LOAD CURTAILMENT
898	30-Mar-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	5:31	6:18	0:47	LOAD CURTAILMENT
899	30-Mar-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	13:49	13:52	0:03	LINE CLEAR AVAILED
900	30-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:29	8:32	0:02	TRANSFORMER FAULT
901	30-Mar-19	TUMKUR	66	TR-2	DAVANAGERE_66	19:04	19:32	0:27	LINE CLEAR AVAILED
902	30-Mar-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	5:33	6:28	0:55	LOAD CURTAILMENT
903	30-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	13:07	13:17	0:10	MAIN SUPPLY FAILURE
904	31-Mar-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	8:40	11:00	2:20	LINE CLEAR AVAILED
905	31-Mar-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	11:50	12:05	0:15	LINE FAULT
906	31-Mar-19	BAGALKOT	110	GOPPANKOPPA-MRUTHYUNJAY NAGAR 1 (MR2)	GOPANKOPPA_110	23:56	23:59	0:03	LINE FAULT
907	31-Mar-19	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,KAMATAGI_33KV, SHIRUR_33KV	20:48	20:58	0:10	TRANSFORMER FAULT
908	31-Mar-19	BAGALKOT	110	110/11KV,HV1(HV4)	HUKKERI_110	10:40	10:44	0:04	TRANSFORMER FAULT
909	31-Mar-19	BAGALKOT	110	ITNAL-RAIBAG1(HIDIKAL2)	ITNAL_110	18:13	18:30	0:17	LINE CLEAR AVAILED
910	31-Mar-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADWAD_33,VANTAGODI_33	19:57	20:07	0:10	TRANSFORMER FAULT
911	31-Mar-19	BAGALKOT	110	110/33KV, HV2	UGARKHUD_110, MANGSULI_33, SHEDBAL_33	2:44	2:49	0:05	TRANSFORMER FAULT
912	31-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	7:30	7:45	0:15	TRANSFORMER FAULT
913	31-Mar-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	9:55	10:37	0:42	LINE FAULT
914	31-Mar-19	BAGALKOT	110	NAREGAL-BETAGERI	BETAGERI_110	8:44	11:00	2:16	LINE CLEAR AVAILED
915	31-Mar-19	BAGALKOT	110	RON-NAREGAL	NAREGAL_110	9:03	9:10	0:07	HAND TRIPPED
916	31-Mar-19	BAGALKOT	110	RON-NAREGAL	NAREGAL_110	10:43	11:00	0:17	HAND TRIPPED
917	31-Mar-19	BAGALKOT	110	110/33KV, HV2	MATTIHAL_110,KARJOL LIS_33	19:56	21:09	1:13	TRANSFORMER FAULT
918	31-Mar-19	BAGALKOT	110	110/33KV, HV4	MACHE_110,KHANAPUR_33,ASHOKA IRON PLANT_33	10:55	11:33	0:38	LINE CLEAR AVAILED
919	31-Mar-19	BENGALURU	66	HV2	SUBRAMANYAPURA 66	6:51	7:02	0:10	TRANSFORMER FAULT
920	31-Mar-19	BENGALURU	66	HV1	TK HALLI 220	1:50	5:05	3:14	TRANSFORMER FAULT
921	31-Mar-19	BENGALURU	66	HV1	TK HALLI 220	5:06	5:08	0:02	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
922	31-Mar-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:18	17:22	0:03	LINE FAULT
923	31-Mar-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:37	17:40	0:03	LINE FAULT
924	31-Mar-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	14:38	15:05	0:26	LINE FAULT
925	31-Mar-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	12:50	13:05	0:15	TRANSFORMER FAULT
926	31-Mar-19	BENGALURU	66	HV2	TYAMAGONDALU	0:05	0:10	0:05	TRANSFORMER FAULT
927	31-Mar-19	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	22:53	23:34	0:41	LINE FAULT
928	31-Mar-19	GULBARGA	110	HV1	HANUMASAGAR_110	21:10	21:20	0:10	TRANSFORMER FAULT
929	31-Mar-19	GULBARGA	110	HV1	HATTI_110	10:15	10:36	0:21	TRANSFORMER FAULT
930	31-Mar-19	GULBARGA	110	HV1	SRERAMANAGAR_110	9:35	16:05	6:30	LINE CLEAR AVAILED
931	31-Mar-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	21:58	23:59	2:01	LINE FAULT
932	31-Mar-19	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	21:58	22:24	0:26	MAIN SUPPLY FAILURE
933	31-Mar-19	GULBARGA	110	SHAHPUR-KHANAPUR	WADAGERA_110, SAIDAPUR_GLB_110,KHANAPUR_GLB_1 10	20:02	23:13	3:11	LINE FAULT
934	31-Mar-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,BTPS _WATERWORKS	22:00	22:18	0:18	LINE FAULT
935	31-Mar-19	GULBARGA	66	LV2	ITTAGI_220	7:10	11:55	4:45	LINE CLEAR AVAILED
936	31-Mar-19	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINA_HADAGALLI_66, HOLAGUNDI_66	14:30	19:30	5:00	LINE CLEAR AVAILED
937	31-Mar-19	HASSAN	220	HASSN22-CHIKMAGALUR	HASSAN_220	1:40	1:47	0:07	LINE FAULT
938	31-Mar-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:20	15:52	1:32	LINE CLEAR AVAILED
939	31-Mar-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:23	15:55	1:32	NFBC ISSUED
940	31-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	14:25	16:05	1:40	LINE CLEAR AVAILED
941	31-Mar-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:05	16:16	2:11	LINE CLEAR AVAILED
942	31-Mar-19	HASSAN	110	HV3	BAIKAMPADY_110	14:08	14:43	0:35	LINE CLEAR AVAILED
943	31-Mar-19	HASSAN	110	HV2	ESSUR_110	7:16	10:50	3:34	LINE CLEAR AVAILED
944	31-Mar-19	HASSAN	110	HV1	KALLUSADARAHALLI_110	12:03	12:16	0:13	HAND TRIPPED
945	31-Mar-19	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	8:45	14:40	5:55	NFBC ISSUED
946	31-Mar-19	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	8:45	14:40	5:55	NFBC ISSUED
947	31-Mar-19	MYSORE	66	JAKKANAHALLI-NAGAMANGALA	BOGADHI MANDYA_66 GUDDENAHALLI_66 G MALLIGERE_66 NAGAMANGALA_66	6:56	7:07	0:10	LINE FAULT
948	31-Mar-19	MYSORE	66	HV3	KUSHALANAGARA_66	16:20	16:31	0:11	TRANSFORMER FAULT
949	31-Mar-19	MYSORE	66	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	8:45	10:02	1:16	NFBC ISSUED
950	31-Mar-19	MYSORE	66	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	10:13	10:26	0:12	HAND TRIPPED
951	31-Mar-19	MYSORE	66	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	10:38	14:37	3:59	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
952	31-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	6:17	8:15	1:58	TRANSFORMER FAULT
953	31-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	18:10	18:12	0:02	TRANSFORMER FAULT
954	31-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	17:54	23:59	6:04	LINE CLEAR AVAILED
955	31-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	17:54	18:03	0:08	LINE FAULT
956	31-Mar-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	17:01	17:10	0:09	LINE FAULT
957	31-Mar-19	TUMKUR	110	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	12:14	12:21	0:06	LINE FAULT
958	31-Mar-19	TUMKUR	66	TR-1 & TR-2	CHANNAGIRI_66	9:41	19:05	9:24	MAIN SUPPLY FAILURE
959	31-Mar-19	TUMKUR	66	R-1& TR-2	CHANNAGIRI_66	20:53	21:55	1:02	LINE CLEAR AVAILED
960	31-Mar-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHILI)	CHANNAGIRI_66	23:10	23:14	0:04	LINE FAULT
961	31-Mar-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHILI)	CHANNAGIRI_66	9:41	19:03	9:22	MAIN SUPPLY FAILURE
962	31-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:19	7:29	0:09	LINE FAULT
963	31-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:04	12:16	0:12	LINE FAULT
964	31-Mar-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:50	8:09	1:18	LINE FAULT
965	31-Mar-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:40	19:04	9:23	LINE CLEAR AVAILED
966	31-Mar-19	TUMKUR	66	TR-2	KUKKAWADA_66	6:22	6:31	0:09	TRANSFORMER FAULT
967	31-Mar-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	21:04	21:05	0:01	TRANSFORMER FAULT
968	31-Mar-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	19:07	19:08	0:01	TRANSFORMER FAULT
969	1-Apr-19	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYANAGAR	GOPANAKOPPA_110	0:00	13:38	13:38	LINE CLEAR AVAILED
970	1-Apr-19	BAGALKOT	110	HUNGUND-B.BAGEWADI(K.SANGAM)	HUNGUND_110	11:53	11:54	0:01	LINE FAULT
971	1-Apr-19	BAGALKOT	110	HUNGUND-B.BAGEWADI(K.SANGAM)	HUNGUND_110	12:13	23:59	11:46	LINE FAULT
972	1-Apr-19	BAGALKOT	110	ITANAL-RAIBAG(HIDIKAL)	HIDIKAL_110	18:29	23:59	5:30	LINE CLEAR AVAILED
973	1-Apr-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	1:56	18:08	16:12	LINE FAULT
974	1-Apr-19	BAGALKOT	220	AMBEWADI-NARENDRA 1	AMBEWADI_220	18:57	23:59	5:02	LINE CLEAR AVAILED
975	1-Apr-19	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	10:39	16:39	6:00	LINE CLEAR AVAILED
976	1-Apr-19	BAGALKOT	220	BELGAUM-KANABARGI 2	BELGAUM_220	15:57	20:34	4:37	LINE FAULT
977	1-Apr-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	16:01	16:25	0:24	HAND TRIPPED
978	1-Apr-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	16:01	23:59	7:58	LINE CLEAR AVAILED
979	1-Apr-19	BAGALKOT	110	KUDALASANGAM-HUNAGUND	KUDALASANGAM_110	12:20	13:38	1:18	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
980	1-Apr-19	BAGALKOT	220	VAJRAMATTI220-KAVATAGI LIS	VAJRAMATTI_220	11:30	14:28	2:58	LINE CLEAR AVAILED
981	1-Apr-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	22:33	22:51	0:18	LINE FAULT
982	1-Apr-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	22:55	23:03	0:08	LINE FAULT
983	1-Apr-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	14:24	16:10	1:46	LINE CLEAR AVAILED
984	1-Apr-19	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	1:13	1:19	0:06	LINE FAULT
985	1-Apr-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:20	13:26	2:06	LINE CLEAR AVAILED
986	1-Apr-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	15:17	17:54	2:37	LINE FAULT
987	1-Apr-19	BAGALKOT	110	NARENDRA220-KUD1 DHARWAD1	KUD DHARWAD_110	0:38	0:52	0:14	LINE FAULT
988	1-Apr-19	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	12:20	12:31	0:11	LINE CLEAR AVAILED
989	1-Apr-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	18:52	19:12	0:20	LINE CLEAR AVAILED
990	1-Apr-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	20:30	20:42	0:12	LINE CLEAR AVAILED
991	1-Apr-19	BAGALKOT	110	110/33KV,HV4	LAKMANHALLI_110, ALNAVAR_33	0:51	1:01	0:10	HAND TRIPPED
992	1-Apr-19	BENGALURU	66	HV3	ADUGODI	10:32	10:41	0:09	LOAD CHANGEOR
993	1-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, HUNSENAHALLI, BIJJANAHALLI, KODIHALLI	20:18	20:44	0:26	LINE FAULT
994	1-Apr-19	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON (EHT)	14:46	15:41	0:54	LINE FAULT
995	1-Apr-19	BENGALURU	66	HV2	NRS 220	17:27	17:31	0:04	LOAD CHANGEOR
996	1-Apr-19	BENGALURU	66	HV2	SOUTH CITY	15:05	17:11	2:05	LINE CLEAR AVAILED
997	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	15:55	16:54	0:59	MAIN SUPPLY FAILURE
998	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 1 & 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	15:55	16:57	1:02	MAIN SUPPLY FAILURE
999	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - PLATINUM CITY	PLATINUM CITY	15:55	16:57	1:02	MAIN SUPPLY FAILURE
1000	1-Apr-19	BENGALURU	220	HV2	SRS PEENYA 220	15:55	16:41	0:46	TRANSFORMER FAULT
1001	1-Apr-19	BENGALURU	220	HV4	SRS PEENYA 220	15:55	16:41	0:46	TRANSFORMER FAULT
1002	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	15:55	16:02	0:07	MAIN SUPPLY FAILURE
1003	1-Apr-19	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	15:55	16:26	0:31	LINE FAULT
1004	1-Apr-19	BENGALURU	66	HV1	SRS PEENYA 220	15:57	16:32	0:35	MAIN SUPPLY FAILURE
1005	1-Apr-19	BENGALURU	66	HV3	SRS PEENYA 220	15:57	16:35	0:38	MAIN SUPPLY FAILURE
1006	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	15:55	16:37	0:42	MAIN SUPPLY FAILURE
1007	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	15:55	16:40	0:45	MAIN SUPPLY FAILURE
1008	1-Apr-19	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	BRINDAVANA	15:55	17:00	1:05	MAIN SUPPLY FAILURE
1009	1-Apr-19	BENGALURU	66	HV2	NRS 220	15:55	16:14	0:19	MAIN SUPPLY FAILURE
1010	1-Apr-19	BENGALURU	66	HV2	AKKURMOLE	11:50	11:59	0:09	LINE CLEAR AVAILED
1011	1-Apr-19	BENGALURU	66	HV2	AKKURMOLE	15:08	15:10	0:01	LINE CLEAR AVAILED
1012	1-Apr-19	BENGALURU	66	HV2	AKKURMOLE	17:15	17:16	0:01	LINE CLEAR AVAILED
1013	1-Apr-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:55	17:59	0:03	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1014	1-Apr-19	BENGALURU	66	HV2	HAROBEL	20:20	20:52	0:32	TRANSFORMER FAULT
1015	1-Apr-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	16:50	16:51	0:01	LOAD CHANGEOVER
1016	1-Apr-19	BENGALURU	66	HV1	A STATION 66	15:41	15:44	0:03	LINE CLEAR AVOID
1017	1-Apr-19	BENGALURU	66	HV1	A STATION 66	17:06	17:08	0:02	LINE CLEAR AVOID
1018	1-Apr-19	GULBARGA	110	YELBURGA-PARAMPUYA_IPP	YELBURGA_110	0:00	5:10	5:10	LINE FAULT
1019	1-Apr-19	GULBARGA	110	HV3	KOLHAR_110	13:30	13:40	0:10	TRANSFORMER FAULT
1020	1-Apr-19	GULBARGA	110	MALLAT-BYAGAWAT	BYAGAWAT_110	1:28	1:33	0:05	LINE FAULT
1021	1-Apr-19	GULBARGA	110	MASKI-SINDHANOOR220	MASKI_110	11:48	12:17	0:29	LINE CLEAR AVOID
1022	1-Apr-19	GULBARGA	110	MASKI-SINDHANOOR220	MASKI_110	13:13	15:25	2:12	LINE CLEAR AVOID
1023	1-Apr-19	GULBARGA	110	HV1	SIRWAR_110	7:51	8:25	0:34	LINE CLEAR AVOID
1024	1-Apr-19	GULBARGA	110	HV1	UPANAYAKANAHALLI_110	15:59	17:00	1:01	LINE CLEAR AVOID
1025	1-Apr-19	GULBARGA	110	KAPANOOR-HUMNABAD1	HUMNABAD_220	14:02	14:10	0:08	LINE FAULT
1026	1-Apr-19	GULBARGA	110	HV1	KAVITAL_110	17:15	17:20	0:05	HAND TRIPPED
1027	1-Apr-19	GULBARGA	110	HV2	KAVITAL_110	17:55	18:10	0:15	HAND TRIPPED
1028	1-Apr-19	GULBARGA	110	MASKI-HATTI	HATTI_110	15:25	23:59	8:34	LINE CLEAR AVOID
1029	1-Apr-19	GULBARGA	110	HV1	SEDAM_220	7:35	23:59	16:24	TRANSFORMER FAULT
1030	1-Apr-19	GULBARGA	110	KUSTAGI-ILKAL1 &2	ILKAL_110	11:30	11:55	0:25	LINE FAULT
1031	1-Apr-19	GULBARGA	110	KUSTAGI-INR SOLAR	KUSTAGI_220	12:40	13:10	0:30	LINE CLEAR AVOID
1032	1-Apr-19	GULBARGA	110	HV1	KUSTAGI_220	13:15	15:15	2:00	LINE CLEAR AVOID
1033	1-Apr-19	GULBARGA	110	HV1	KUSTAGI_220	15:35	15:50	0:15	LINE CLEAR AVOID
1034	1-Apr-19	GULBARGA	110	HV1	KUSTAGI_220	19:10	19:25	0:15	LINE CLEAR AVOID
1035	1-Apr-19	GULBARGA	110	HV1	KUSTAGI_220	21:00	21:10	0:10	TRANSFORMER FAULT
1036	1-Apr-19	GULBARGA	110	HV1	KUSTAGI_220	22:20	22:30	0:10	TRANSFORMER FAULT
1037	1-Apr-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR IPP	21:39	21:49	0:10	LINE FAULT
1038	1-Apr-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KEMBHAVI_110,KBJNL	21:39	23:59	2:20	LINE FAULT
1039	1-Apr-19	HASSAN	400	TALAGUP-NELAMANGALA#2	TALAGUPPA_400	0:00	16:44	16:44	LINE CLEAR AVOID
1040	1-Apr-19	HASSAN	400	TALAGUP-NELAMANGALA#2	TALAGUPPA_400	6:45	23:59	17:14	LINE FAULT
1041	1-Apr-19	HASSAN	220	HASSAN40-SHIMOGA1	SHANTHIGRAMA_400	16:11	19:30	3:19	LINE FAULT
1042	1-Apr-19	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	16:11	19:30	3:19	LINE FAULT
1043	1-Apr-19	HASSAN	110	HV1	GURUVAYANAKERE_110	8:47	8:54	0:07	TRANSFORMER FAULT
1044	1-Apr-19	HASSAN	110	HV1	MSEZ_220	10:08	11:23	1:15	LINE CLEAR AVOID
1045	1-Apr-19	HASSAN	110	HV2	MSEZ_220	10:08	11:18	1:10	LINE CLEAR AVOID
1046	1-Apr-19	HASSAN	66	HV2	BELUR_66	8:21	8:28	0:07	TRANSFORMER FAULT
1047	1-Apr-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	17:15	17:54	0:39	LINE FAULT
1048	1-Apr-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	16:11	16:24	0:13	HAND TRIPPED
1049	1-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	7:36	19:33	11:57	LINE CLEAR AVOID
1050	1-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	7:36	19:33	11:57	LINE CLEAR AVOID
1051	1-Apr-19	MYSORE	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI_66	6:30	10:33	4:03	LINE CLEAR AVOID
1052	1-Apr-19	MYSORE	66	DEVNUR(MYS)-VAJAMANGALA	BOGADHI MANDYA_66	6:24	7:17	0:52	LINE FAULT
1053	1-Apr-19	MYSORE	66	HV2	BOGADHI MANDYA_66	8:23	8:55	0:31	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1054	1-Apr-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	FTS_66 RAJEEVNAGARA_66	6:24	8:53	2:29	LINE FAULT
1055	1-Apr-19	MYSORE	66	KR PETE 220-MAHADESHWARA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	14:31	14:37	0:05	LINE FAULT
1056	1-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	8:07	8:22	0:14	TRANSFORMER FAULT
1057	1-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	10:08	14:50	4:41	LINE CLEAR AVAILED
1058	1-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 SHIVALLY_66	8:42	11:41	2:58	LINE CLEAR AVAILED
1059	1-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66	17:42	17:48	0:06	LINE FAULT
1060	1-Apr-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	13:52	16:01	2:09	LINE FAULT
1061	1-Apr-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	16:03	18:26	2:23	LINE CLEAR AVAILED
1062	1-Apr-19	TUMKUR	220	NITTUR 220kV-ARASIKERE	NITTUR_220	10:07	21:04	10:56	LOAD CURTAILMENT
1063	1-Apr-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	18:00	18:50	0:49	LINE FAULT
1064	1-Apr-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	18:19	21:12	2:53	TRANSFORMER FAULT
1065	1-Apr-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	18:00	18:12	0:11	LINE FAULT
1066	1-Apr-19	TUMKUR	110	TR-1	TIPTUR_110	14:24	14:38	0:14	TRANSFORMER FAULT
1067	1-Apr-19	TUMKUR	66	TR-1	CHALLAKERE_66	6:10	6:20	0:10	TRANSFORMER FAULT
1068	1-Apr-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:18	8:21	0:02	TRANSFORMER FAULT
1069	1-Apr-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHILI))	CHANNAGIRI_66	8:22	8:26	0:03	LINE FAULT
1070	1-Apr-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	12:05	12:26	0:21	LINE FAULT
1071	1-Apr-19	TUMKUR	66	TR-1	DASUDI_66	12:43	16:13	3:30	LINE CLEAR AVAILED
1072	1-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:14	7:35	0:21	LINE FAULT
1073	1-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:19	9:41	0:21	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1074	1-Apr-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:02	11:14	0:11	LINE FAULT
1075	1-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	14:24	15:22	0:58	LINE FAULT
1076	1-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	23:24	23:25	0:01	LINE CLEAR AVAILED
1077	1-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	23:24	23:25	0:01	LINE CLEAR AVAILED
1078	1-Apr-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:43	9:45	0:01	MAIN SUPPLY FAILURE
1079	1-Apr-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	6:01	6:09	0:07	LINE FAULT