

**400/220/110/66 kV TRANSMISSION OUTAGES FROM 08.03.22 TO 14.03.2022**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	8-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
2	8-Mar-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
3	8-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
4	8-Mar-2022	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11(23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
5	8-Mar-2022	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
6	8-Mar-2022	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)			LINE OPEN,LINE CLEAR AVAILED
7	8-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
8	8-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
9	8-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
10	8-Mar-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
11	8-Mar-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:42 (06.03.2022)			LINE OPEN,LINE CLEAR AVAILED
12	8-Mar-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:43 (06.03.2022)			LINE OPEN,LINE CLEAR AVAILED
13	8-Mar-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KUD DHARWAD_110	23:58 (07.03.2022)	12:48 (08.03.2022)	12:50HRS	TRANSFORMER CHARGED
14	8-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
15	8-Mar-2022	BAGALKOT	220	NARENDRA-HUBLI1&2	STATION NOT AFFECTED NARENDRA_220	10:27	18:44	8:17	LINE CLEAR AVAILED
16	8-Mar-2022	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:23	18:44	8:21	NFBC ISSUED
17	8-Mar-2022	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:24	18:47	8:23	NFBC ISSUED
18	8-Mar-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:30	15:53	5:23	HAND TRIPPED
19	8-Mar-2022	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	10:30	15:52	5:22	HAND TRIPPED
20	8-Mar-2022	BAGALKOT	220	SIRSI-SHARAVATI1	STATION NOT AFFECTED SIRSI_220	10:12	16:16	6:04	LINE CLEAR AVAILED
21	8-Mar-2022	BAGALKOT	220	SIRSI-SHARAVATI2	STATION NOT AFFECTED SIRSI_220	10:12	16:16	6:04	LINE CLEAR AVAILED
22	8-Mar-2022	BAGALKOT	400	400/220KV,ICT2(HV)	DHONI_400	10:59	16:10	5:11	LINE CLEAR AVAILED
23	8-Mar-2022	BAGALKOT	220	400/220KV,ICT2(LV)	DHONI_400	10:59	16:14	5:15	LINE CLEAR AVAILED
24	8-Mar-2022	BAGALKOT	110	110/11KV, HV2	ALMEL_110	11:35	11:36	0:01	TRANSFORMER FAULT
25	8-Mar-2022	BAGALKOT	110	110/11KV, HV2	ALMEL_110	17:10	17:20	0:10	LINE CLEAR AVAILED
26	8-Mar-2022	BAGALKOT	110	110/11KV, HV2	BABLESHWAR_110	11:25	13:29	2:04	LINE CLEAR AVAILED
27	8-Mar-2022	BAGALKOT	110	110/33KV, HV4	GADAG_110, LAKKUNDI_33, HULKOTI_33	11:30	15:22	3:52	LINE CLEAR AVAILED
28	8-Mar-2022	BAGALKOT	110	JAMKHANDI-PRABHULINGESHWAR SUGARS	STATION NOT AFFECTED JAMKHANDI_110	18:12	18:14	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
29	8-Mar-2022	BAGALKOT	110	JAMKHANDI-PRABHULINGESHWAR SUGARS	STATION NOT AFFECTED JAMKHANDI_110	18:15	18:42	0:27	HAND TRIPPED
30	8-Mar-2022	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	17:05	17:08	0:03	TRANSFORMER FAULT
31	8-Mar-2022	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	17:56	18:00	0:04	TRANSFORMER FAULT
32	8-Mar-2022	BAGALKOT	110	110/33KV, HV3	HORTI_33 STATION NOT AFFECTED ZALKI_110	17:59	19:14	1:15	LINE CLEAR AVOIDED
33	8-Mar-2022	BAGALKOT	110	TADASINAKOPP-NARENDRA(TARIHAL)	STATION NOT AFFECTED TADASINAKOPPA_110	11:10	14:26	3:16	NFBC ISSUED
34	8-Mar-2022	BAGALKOT	110	SOUDATTI-ENERCON1 IPP	ENERCON1 IPP_110 STATION NOT AFFECTED SOUDATTI_110	19:50	21:14	1:24	LINE FAULT
35	8-Mar-2022	BAGALKOT	110	SIRSI-KUMTA1&2	STATION NOT AFFECTED SIRSI_110	10:26	14:45	4:19	LINE CLEAR AVOIDED
36	8-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAVALAGI_110	16:11	18:08	1:57	LINE CLEAR AVOIDED
37	8-Mar-2022	BAGALKOT	110	MUDDEBIHAL-KNM SOLAR	KNM SOLAR_110 STATION NOT AFFECTED MUDDEBIHAL_110	8:18	8:35	0:17	LINE FAULT
38	8-Mar-2022	BAGALKOT	110	MUDDEBIHAL-KNM SOLAR	KNM SOLAR_110 STATION NOT AFFECTED MUDDEBIHAL_110	8:37	9:56	1:19	LINE FAULT
39	8-Mar-2022	BAGALKOT	110	MUDDEBIHAL-KNM SOLAR	KNM SOLAR_110 STATION NOT AFFECTED MUDDEBIHAL_110	10:26	10:32	0:06	HAND TRIPPED
40	8-Mar-2022	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN, LINE CLEAR AVOIDED
41	8-Mar-2022	BAGALKOT	110	110/11KV, HV1	MANTUR_110	12:30	14:00	1:30	LINE CLEAR AVOIDED
42	8-Mar-2022	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	4:04	4:19	0:15	TRANSFORMER FAULT
43	8-Mar-2022	BENGALURU	66	HV3	ADUGODI	10:36	10:38	0:02	LINE CLEAR AVOIDED
44	8-Mar-2022	BENGALURU	66	HV1	ANJANAPURA	19:32	19:50	0:18	TRANSFORMER FAULT
45	8-Mar-2022	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	8:26	8:48	0:22	MAIN SUPPLY FAILURE
46	8-Mar-2022	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	9:56	9:57	0:01	LOAD CHANGE OVER
47	8-Mar-2022	BENGALURU	66	HV2	CHATRA	10:32	16:39	6:07	LINE CLEAR AVOIDED
48	8-Mar-2022	BENGALURU	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK	18:13	18:22	0:09	LOAD CHANGE OVER
49	8-Mar-2022	BENGALURU	220	HOODY 220 - MALUR 220	VIKAS TECH PARK 220, SARJAPURA 220	12:13	12:49	0:36	LINE FAULT
50	8-Mar-2022	BENGALURU	66	KADUGODI - ARMY WELFARE	ARMY WELFARE	13:44	14:17	0:33	LINE FAULT
51	8-Mar-2022	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:15	17:24	7:09	LINE CLEAR AVOIDED
52	8-Mar-2022	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	8:26	8:48	0:22	LINE FAULT
53	8-Mar-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:54	13:22	1:28	LINE CLEAR AVOIDED
54	8-Mar-2022	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	13:30	13:34	0:04	LINE CLEAR AVOIDED
55	8-Mar-2022	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	13:46	13:56	0:10	LINE CLEAR AVOIDED
56	8-Mar-2022	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	14:04	14:14	0:10	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
57	8-Mar-2022	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	12:13	12:50	0:37	MAIN SUPPLY FAILURE
58	8-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:13	12:50	0:37	HAND TRIPPED
59	8-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:13	13:09	0:56	HAND TRIPPED
60	8-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	12:13	13:05	0:52	HAND TRIPPED
61	8-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	12:13	13:05	0:52	HAND TRIPPED
62	8-Mar-2022	BENGALURU	66	HV2	BIDADI 220	15:05	16:40	1:35	TRANSFORMER FAULT
63	8-Mar-2022	BENGALURU	66	HV1	MANDIKAL	14:13	16:34	2:20	LINE CLEAR AVOIDED
64	8-Mar-2022	BENGALURU	66	HV2	MAASTHI	8:04	8:10	0:05	TRANSFORMER FAULT
65	8-Mar-2022	BENGALURU	66	HV2	MAASTHI	21:12	21:22	0:10	TRANSFORMER FAULT
66	8-Mar-2022	BENGALURU	66	HV1	HUKUNDA	4:00	4:09	0:08	TRANSFORMER FAULT
67	8-Mar-2022	BENGALURU	66	PALLICHERLU - SOLAR (IPP)	NO STATION AFFECTED	18:55	18:58	0:03	LINE CLEAR AVOIDED
68	8-Mar-2022	BENGALURU	66	PALLICHERLU - SOLAR (IPP)	NO STATION AFFECTED	18:05	18:25	0:20	LINE FAULT
69	8-Mar-2022	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:14	18:45	0:31	LOAD CURTAILMENT
70	8-Mar-2022	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF	18:45	19:16	0:31	LOAD CURTAILMENT
71	8-Mar-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	19:23	20:08	0:45	LOAD CURTAILMENT
72	8-Mar-2022	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	18:39	19:08	0:29	LOAD CURTAILMENT
73	8-Mar-2022	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	19:10	19:40	0:30	LOAD CURTAILMENT
74	8-Mar-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	19:40	20:05	0:25	LOAD CURTAILMENT
75	8-Mar-2022	BENGALURU	66	GANJIUGUNTE - DIBBURAHALLI	DIBBURAHALLI	18:07	18:23	0:16	LINE FAULT
76	8-Mar-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:48	14:19	1:31	LINE CLEAR AVOIDED
77	8-Mar-2022	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:14	13:22	1:08	MAIN SUPPLY FAILURE
78	8-Mar-2022	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:14	12:58	0:44	MAIN SUPPLY FAILURE
79	8-Mar-2022	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:14	13:07	0:53	MAIN SUPPLY FAILURE
80	8-Mar-2022	BENGALURU	66	TUBUGERE - DB PURA 220	TUBUGERE	13:01	14:26	1:25	LINE CLEAR AVOIDED
81	8-Mar-2022	BENGALURU	66	KONDASPURA - HBR 220	KONDASPURA	18:21	18:26	0:04	LOAD CHANGE OVER
82	8-Mar-2022	BENGALURU	66	MALUR 220 - KAMASAMUDRA	KAMASAMUDRA	18:45	19:30	0:44	LOAD CURTAILMENT
83	8-Mar-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
84	8-Mar-2022	GULBARGA	220	HV2	SINDHANOOR_220	9:50	16:30	6:40	LINE CLEAR AVOIDED
85	8-Mar-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110, KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVOIDED
86	8-Mar-2022	GULBARGA	110	HV1	JEWARGI_110	8:55	15:45	6:50	LINE CLEAR AVOIDED
87	8-Mar-2022	GULBARGA	110	HV2	JEWARGI_110	16:00	17:40	1:40	LINE CLEAR AVOIDED
88	8-Mar-2022	GULBARGA	110	HV1	MYLAR_110	21:05	21:30	0:25	LINE CLEAR AVOIDED
89	8-Mar-2022	GULBARGA	110	HV2	MYLAR_110	21:05	21:30	0:25	LINE CLEAR AVOIDED
90	8-Mar-2022	GULBARGA	110	HV3	VALKAMDINNI_110	13:05	13:09	0:04	TRANSFORMER FAULT
91	8-Mar-2022	GULBARGA	110	HV1	MADIYAL_110	11:05	14:50	3:45	LINE CLEAR AVOIDED
92	8-Mar-2022	GULBARGA	110	HV2	MADIYAL_110	11:08	15:21	4:13	LINE CLEAR AVOIDED
93	8-Mar-2022	GULBARGA	110	HV3	MADIYAL_110	11:08	15:21	4:13	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
94	8-Mar-2022	GULBARGA	110	HV1	BEVOOR_110	10:15	14:10	3:55	LINE CLEAR AVAILED
95	8-Mar-2022	GULBARGA	110	YELBURGA-TALALUTAI IPP	YELBURGA_110	19:12(07.03.2022)	3:52(08.03.2022)	8:40HRS	LINE CHARGED
96	8-Mar-2022	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	10:24	12:35	2:11	LINE CLEAR AVAILED
97	8-Mar-2022	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	19:09	23:43	4:34	LINE CLEAR AVAILED
98	8-Mar-2022	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,CHOWDAPUR_110,JODHPUR WIND FARMS IPP	11:30	14:15	2:45	LINE CLEAR AVAILED
99	8-Mar-2022	GULBARGA	110	MADIYAL-NSL SUGAR IPP	MADIYAL_110	11:00	14:58	3:58	LINE CLEAR AVAILED
100	8-Mar-2022	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	11:25	14:20	2:55	MAIN SUPPLY FAILURE
101	8-Mar-2022	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	13:35	13:50	0:15	MAIN SUPPLY FAILURE
102	8-Mar-2022	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	20:40	20:45	0:05	MAIN SUPPLY FAILURE
103	8-Mar-2022	GULBARGA	110	BYGWAT-ACMBSLR	BYGWAT_110	20:40	20:50	0:10	LINE FAULT
104	8-Mar-2022	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	9:50	10:40	0:50	MAIN SUPPLY FAILURE
105	8-Mar-2022	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	12:05	12:35	0:30	MAIN SUPPLY FAILURE
106	8-Mar-2022	GULBARGA	110	GALAG-MALLAT	GALAG_110	5:00	5:35	0:35	MAIN SUPPLY FAILURE
107	8-Mar-2022	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	18:40	19:00	0:20	LOAD CURTAILMENT
108	8-Mar-2022	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	19:45	19:55	0:10	LINE FAULT
109	8-Mar-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:37	1:47	0:10	LINE FAULT
110	8-Mar-2022	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	9:00	18:30	9:30	LINE CLEAR AVAILED
111	8-Mar-2022	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	18:41	20:20	1:39	LOAD CURTAILMENT
112	8-Mar-2022	GULBARGA	110	HUMNABAD-MARGUTTI	MARGUTTI_110, MAHAGOAN_110	12:45(13/02/2022)	19:40(08/03/2022)	558:55HRS	LINE CHARGED
113	8-Mar-2022	GULBARGA	110	HUMNABAD-BIDAR1 (HALLIKHED)	HALLIKHED_110	12:45(13/02/2022)	19:53(08/03/2022)	559:55HRS	LINE CHARGED
114	8-Mar-2022	GULBARGA	66	HV1	HANASI_66	8:10	8:35	0:25	TRANSFORMER FAULT
115	8-Mar-2022	GULBARGA	66	UCHCHANGIDURGA-BILCHOD	BILCHOD_66	10:15	17:50	7:35	LINE CLEAR AVAILED
116	8-Mar-2022	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAK ANAHALLI_66,HAGARIBOMM ANAHALLI_66,RR STEELS_IPP	4:47	4:56	0:09	LINE FAULT
117	8-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
118	8-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
119	8-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
120	8-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
121	8-Mar-2022	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:30	12:02	1:32	NFBC ISSUED
122	8-Mar-2022	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:12	16:17	6:05	LINE CLEAR AVAILED
123	8-Mar-2022	HASSAN	110	LV1	SHIRALKOPPA_220	0:18	0:42	0:24	TRANSFORMER FAULT
124	8-Mar-2022	HASSAN	220	HV1	SHIRALKOPPA_220	0:18	0:41	0:23	TRANSFORMER FAULT
125	8-Mar-2022	HASSAN	220	HV2	SHIRALKOPPA_220	0:18	0:35	0:17	TRANSFORMER FAULT
126	8-Mar-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:18	0:55	0:37	MAIN SUPPLY FAILURE
127	8-Mar-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	0:18	0:58	0:40	MAIN SUPPLY FAILURE
128	8-Mar-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	9:18	9:28	0:10	HAND TRIPPED
129	8-Mar-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	0:18	0:47	0:29	MAIN SUPPLY FAILURE
130	8-Mar-2022	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	0:18	0:28	0:10	MAIN SUPPLY FAILURE
131	8-Mar-2022	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:10	13:29	2:19	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
132	8-Mar-2022	HASSAN	110	HV1	ARASIKERE_110	16:00	17:45	1:45	LINE CLEAR AVAILED
133	8-Mar-2022	HASSAN	110	HV2	BIRUR_110	12:36	13:51	1:15	LINE CLEAR AVAILED
134	8-Mar-2022	HASSAN	110	HV1	HALADY_110	11:38	14:30	2:52	LINE CLEAR AVAILED
135	8-Mar-2022	HASSAN	110	KADUR-NGNHL	KADUR_220	19:03	19:17	0:14	HAND TRIPPED
136	8-Mar-2022	HASSAN	110	KADUR-YGTI	KADUR_220	19:03	19:17	0:14	HAND TRIPPED
137	8-Mar-2022	HASSAN	110	HV2	MANIPAL_110	10:09	11:06	0:57	LINE CLEAR AVAILED
138	8-Mar-2022	HASSAN	110	HV1	NAVUNDA_110	11:41	16:24	4:43	TRANSFORMER FAULT
139	8-Mar-2022	HASSAN	110	HV2	NAVUNDA_110	10:15	15:28	5:13	LINE CLEAR AVAILED
140	8-Mar-2022	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	12:02	15:22	3:20	LINE CLEAR AVAILED
141	8-Mar-2022	HASSAN	110	HV1	PUTTUR_110	10:21	10:27	0:06	TRANSFORMER FAULT
142	8-Mar-2022	HASSAN	110	HV5	PUTTUR_110	9:29	9:34	0:05	TRANSFORMER FAULT
143	8-Mar-2022	HASSAN	110	SORABA-MAVNI	SORABA_110	0:20	0:35	0:15	MAIN SUPPLY FAILURE
144	8-Mar-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	20:00	20:21	0:21	MAIN SUPPLY FAILURE
145	8-Mar-2022	HASSAN	66	GANGUR-HASSAN	GANGUR_66	10:07	16:59	6:52	LINE CLEAR AVAILED
146	8-Mar-2022	HASSAN	66	GANGUR-HASSAN	HAGARE_66	10:10	16:15	6:05	LINE CLEAR AVAILED
147	8-Mar-2022	HASSAN	66	HV1	HAGARE_66	10:10	16:15	6:05	LINE CLEAR AVAILED
148	8-Mar-2022	HASSAN	66	HV1	HALEBEEDU_66	10:07	16:28	6:21	LINE CLEAR AVAILED
149	8-Mar-2022	HASSAN	66	HV2	HALEBEEDU_66	10:07	16:28	6:21	LINE CLEAR AVAILED
150	8-Mar-2022	HASSAN	66	HASSN22-HN PURA	HASSAN_220	16:01	16:52	0:51	LINE CLEAR AVAILED
151	8-Mar-2022	HASSAN	66	HV1	MALLIPATNA_66	12:26	12:39	0:13	TRANSFORMER FAULT
152	8-Mar-2022	HASSAN	66	MRSSHM-DVG1	MRSMG_220	5:51	6:00	0:09	LINE FAULT
153	8-Mar-2022	HASSAN	66	HV1	SAKLESH PURA_66	18:54	19:02	0:08	TRANSFORMER FAULT
154	8-Mar-2022	HASSAN	66	HV1	SAKLESH PURA_66	19:16	19:27	0:11	TRANSFORMER FAULT
155	8-Mar-2022	MYSURU	220	BEGUR 220-KADAKOLA 1	NO STATIONS EFFECTED	10:23	10:53	0:30	LINE FAULT
156	8-Mar-2022	MYSURU	66	CR NAGAR-HONGANUR	HONGANUR_66	13:47	13:58	0:10	LINE FAULT
157	8-Mar-2022	MYSURU	66	HOOTAGALLI -FTS 1	NO STATIONS EFFECTED	9:35	16:22	6:47	LINE CLEAR AVAILED
158	8-Mar-2022	MYSURU	66	HOOTAGALLI -FTS 2	NO STATIONS EFFECTED	9:35	16:22	6:47	LINE CLEAR AVAILED
159	8-Mar-2022	MYSURU	66	HOOTAGALLI -VIJAYANAGARA	VIJAYANAGARA_66	10:47	16:36	5:49	NFBC ISSUED
160	8-Mar-2022	MYSURU	220	HOOTAGALLI -KADAKOLA	NO STATIONS EFFECTED	11:06	13:15	2:09	HAND TRIPPED
161	8-Mar-2022	MYSURU	66	DKMAIDANA-VAJMANGLA	NO STATIONS EFFECTED	10:29	16:59	6:29	HAND TRIPPED
162	8-Mar-2022	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	11:09	13:07	1:58	LINE CLEAR AVAILED
163	8-Mar-2022	MYSURU	66	KADAKOLA-D K MAIDANA	NO STATIONS EFFECTED	18:34	18:41	0:07	LINE FAULT
164	8-Mar-2022	MYSURU	66	HV1	GUDDENAHALLI_66	10:00	18:15	8:15	LINE CLEAR AVAILED
165	8-Mar-2022	MYSURU	66	HV2	GUDDENAHALLI_66	10:00	18:15	8:15	LINE CLEAR AVAILED
166	8-Mar-2022	MYSURU	66	HV1	AJJIPURA_66	13:05	13:15	0:10	LINE CLEAR AVAILED
167	8-Mar-2022	MYSURU	66	HV2	SHEELUNERE_66	9:15	9:20	0:05	TRANSFORMER FAULT
168	8-Mar-2022	MYSURU	66	HV1	KIADBMANDYA_66	1:13	1:25	0:11	TRANSFORMER FAULT
169	8-Mar-2022	MYSURU	66	KIADBMANDYA-HV1	KIADBMANDYA_66	1:32	1:35	0:03	LINE FAULT
170	8-Mar-2022	MYSURU	66	KIADBMANDYA-HV1	KIADBMANDYA_66	11:59	12:03	0:03	LINE FAULT
171	8-Mar-2022	MYSURU	66	HV2	MYSORESOUTH_66	3:55	6:56	3:00	TRANSFORMER FAULT
172	8-Mar-2022	MYSURU	66	HEBBANI-SFC 2	NO STATIONS EFFECTED	22:34:00 (8.3.2022)			LINE OPEN,LINE CLEAR AVAILED
173	8-Mar-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
174	8-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
175	8-Mar-2022	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	10:27	12:55	2:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
176	8-Mar-2022	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	13:13	14:07	0:54	LINE CLEAR AVAILED
177	8-Mar-2022	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	6:26	16:30	10:03	NFBC ISSUED
178	8-Mar-2022	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	11:22	15:21	3:59	NFBC ISSUED
179	8-Mar-2022	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	11:23	15:22	3:58	NFBC ISSUED
180	8-Mar-2022	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	6:25	11:22	4:57	NFBC ISSUED
181	8-Mar-2022	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	15:19	15:21	0:02	LINE CLEAR AVAILED
182	8-Mar-2022	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	6:32	16:23	9:50	LINE CLEAR AVAILED
183	8-Mar-2022	TUMKUR	220	THALLAK 220kV- HIRIYUR 220KV	THALLAK_220	18:53	20:22	1:28	HAND TRIPPED
184	8-Mar-2022	TUMKUR	110	TR-1	BANDIHALLI_110	16:00	16:50	0:50	LINE CLEAR AVAILED
185	8-Mar-2022	TUMKUR	110	TR-1	KADABA_110	15:47	15:57	0:10	LINE CLEAR AVAILED
186	8-Mar-2022	TUMKUR	110	TR-1	KADEHALLI_110	12:26	15:04	2:38	LINE CLEAR AVAILED
187	8-Mar-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:48	17:54	0:05	LOAD CURTAILMENT
188	8-Mar-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	18:52	19:41	0:49	LOAD CURTAILMENT
189	8-Mar-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA &URDIGERE66	KOLALA_66, URDIGERE_66	18:52	19:41	0:49	LOAD CURTAILMENT
190	8-Mar-2022	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	10:34	11:21	0:47	LINE CLEAR AVAILED
191	8-Mar-2022	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	14:25	15:12	0:46	LINE CLEAR AVAILED
192	8-Mar-2022	TUMKUR	66	TR-2	BEVINAHALLI_66	9:20	9:39	0:18	LINE CLEAR AVAILED
193	8-Mar-2022	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	15:15	18:30	3:15	MAIN SUPPLY FAILURE
194	8-Mar-2022	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	6:24	11:48	5:23	MAIN SUPPLY FAILURE
195	8-Mar-2022	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP 66	11:48	12:47	0:59	LINE FAULT
196	8-Mar-2022	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP 66	13:14	14:59	1:44	HAND TRIPPED
197	8-Mar-2022	TUMKUR	66	TR-2	HOLALKERE_66	12:27	14:42	2:15	HAND TRIPPED
198	8-Mar-2022	TUMKUR	66	TR-2	HONNUDIKE_66	3:09	3:13	0:04	TRANSFORMER FAULT
199	8-Mar-2022	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	18:11	19:58	1:46	HAND TRIPPED
200	8-Mar-2022	TUMKUR	66	TR-2	KADAJJI_66	9:35	9:43	0:08	TRANSFORMER FAULT
201	8-Mar-2022	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	12:44	13:31	0:46	LINE CLEAR AVAILED
202	8-Mar-2022	TUMKUR	66	TR-2	RANGANATHAPURA_220	16:44	18:06	1:22	LINE CLEAR AVAILED
203	8-Mar-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:48	7:39	0:51	LINE CLEAR AVAILED
204	8-Mar-2022	TUMKUR	66	TR-1	PANDARAHALLI_66	6:20	7:49	1:29	MAIN SUPPLY FAILURE
205	8-Mar-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	13:35	14:14	0:39	LINE CLEAR AVAILED
206	8-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:04	4:15	0:11	LINE FAULT
207	8-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:02	9:12	0:10	LINE FAULT
208	8-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:18	14:24	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
209	8-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:35	17:44	0:08	LINE FAULT
210	8-Mar-2022	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	13:57	14:09	0:12	HAND TRIPPED
211	8-Mar-2022	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_66	10:27	14:08	3:41	LINE CLEAR AVAILED
212	8-Mar-2022	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	10:32	14:11	3:39	HAND TRIPPED
213	8-Mar-2022	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	23:05	23:23	0:17	HAND TRIPPED
214	9-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
215	9-Mar-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
216	9-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
217	9-Mar-2022	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11 (23.02.2022)	15:08 (09.03.2022)	337:57HR S	LINE CHARGED
218	9-Mar-2022	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)	22:18 (09.03.2022)	155:46HR S	LINE CHARGED
219	9-Mar-2022	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)	22:44 (09.03.2022)	156:12HR S	LINE CHARGED
220	9-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
221	9-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)	18:45 (09.03.2022)	152:13HR S	LINE CHARGED
222	9-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
223	9-Mar-2022	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
224	9-Mar-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:42 (06.03.2022)			LINE OPEN,LINE CLEAR AVAILED
225	9-Mar-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:43 (06.03.2022)			LINE OPEN,LINE CLEAR AVAILED
226	9-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
227	9-Mar-2022	BAGALKOT	110	110/11KV, HV1	ANAND NAGAR_110	10:46	13:24	2:38	LINE CLEAR AVAILED
228	9-Mar-2022	BAGALKOT	110	110/11KV, HV1	ANKALI_110	19:22	19:26	0:04	TRANSFORMER FAULT
229	9-Mar-2022	BAGALKOT	110	ANKOLA- ARGA	ANKOLA_110	13:32	13:34	0:02	HAND TRIPPED
230	9-Mar-2022	BAGALKOT	110	ANNIGERI- GADAG	ANNIGERI_110	15:11	15:31	0:20	HAND TRIPPED
231	9-Mar-2022	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	12:11	12:46	0:35	LINE CLEAR AVAILED
232	9-Mar-2022	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	14:31	15:01	0:30	LINE CLEAR AVAILED
233	9-Mar-2022	BAGALKOT	220	BIDNAL- SOUDATTI	BIDNAL_220	21:10	22:20	1:10	LINE FAULT
234	9-Mar-2022	BAGALKOT	110	BELLATTI- AB SOLAR	BELLATTI_110	17:05	17:33	0:28	HAND TRIPPED
235	9-Mar-2022	BAGALKOT	110	BELLATTI- ENERCON	BELLATTI_110	17:05	17:32	0:27	HAND TRIPPED
236	9-Mar-2022	BAGALKOT	110	110/33KV, HV2	BISNAL_110, TEGGI_33	16:30	16:36	0:06	TRANSFORMER FAULT
237	9-Mar-2022	BAGALKOT	110	110/33KV, HV2	BISNAL_110, TEGGI_33	16:40	16:52	0:12	TRANSFORMER FAULT
238	9-Mar-2022	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110	21:26	22:38	1:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
239	9-Mar-2022	BAGALKOT	110	110/11KV, HV1	GADAG_110	10:01	17:44	7:43	LINE CLEAR AVAILED
240	9-Mar-2022	BAGALKOT	110	GADAG- ANNIGERI	GADAG_110	12:42	15:32	2:50	LINE CLEAR AVAILED
241	9-Mar-2022	BAGALKOT	110	110/33KV, HV2	HANGAL_110, LAXMIPURA_33, BOMMANALLI_33, AKKIALUR_33	10:09	10:18	0:09	TRANSFORMER FAULT
242	9-Mar-2022	BAGALKOT	110	110/33KV, HV2	HANGAL_110, LAXMIPURA_33, BOMMANALLI_33, AKKIALUR_33	18:11	18:15	0:04	TRANSFORMER FAULT
243	9-Mar-2022	BAGALKOT	110	110/11KV, HV2	LAXMESHWAR_110	13:55	16:52	2:57	LINE CLEAR AVAILED
244	9-Mar-2022	BAGALKOT	110	110/11KV, HV1	MACHE_110	9:27	10:42	1:15	TRANSFORMER FAULT
245	9-Mar-2022	BAGALKOT	110	HUBLI- MUNDAGOD	STATION NOT AFFECTED MUNDAGOD_110	11:04	14:14	3:10	LINE CLEAR AVAILED
246	9-Mar-2022	BAGALKOT	110	110/11KV, HV3	MUNDARGI_110	22:28	22:30	0:02	TRANSFORMER FAULT
247	9-Mar-2022	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	10:11	19:10	8:59	LINE CLEAR AVAILED
248	9-Mar-2022	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	7:53	7:55	0:02	TRANSFORMER FAULT
249	9-Mar-2022	BAGALKOT	110	SOUDATTI- ENERCON1	SOUDATTI_110	22:02	22:05	0:03	HAND TRIPPED
250	9-Mar-2022	BAGALKOT	110	SOUDATTI- ENERCON12	SOUDATTI_110	22:02	22:06	0:04	HAND TRIPPED
251	9-Mar-2022	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	12:14	17:03	4:49	LINE CLEAR AVAILED
252	9-Mar-2022	BAGALKOT	110	110/33KV, HV3	TILUVALLI_110, KALKERI_33, KNNL_33	12:14	15:19	3:05	LINE CLEAR AVAILED
253	9-Mar-2022	BAGALKOT	110	110/11KV, HV2	YELAMANAWADI_110	9:49	13:07	3:18	TRANSFORMER FAULT
254	9-Mar-2022	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	10:12	10:16	0:04	TRANSFORMER FAULT
255	9-Mar-2022	BAGALKOT	110	110/33KV, HV2	RATTIHALL_110, HALLUR_33, MASUR_33	18:24	18:27	0:03	TRANSFORMER FAULT
256	9-Mar-2022	BAGALKOT	110	HAVERI220- TILUVALLI (HANGAL)	HANGAL_110	16:45	17:43	0:58	LINE CLEAR AVAILED
257	9-Mar-2022	BAGALKOT	110	GADAG-GADAG1	STATION NOT AFFECTED GADAG_220	12:39	19:15	6:36	LINE CLEAR AVAILED
258	9-Mar-2022	BAGALKOT	110	GADAG-LAXMESHWAR	STATION NOT AFFECTED GADAG_220	17:05	17:30	0:25	LINE CLEAR AVAILED
259	9-Mar-2022	BAGALKOT	110	110/11KV,HV2	MACHE_110	9:27	10:42	1:15	TRANSFORMER FAULT
260	9-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	RANEBENNUR_220,HIREKERU R_110,HONNATTI_110,BYADA GI_110,TUMMINAKATTI_110, RANEBENNUR_110	15:05	15:32	0:27	HAND TRIPPED
261	9-Mar-2022	BAGALKOT	220	NARENDRA-HUBLI1&2	STATION NOT AFFECTED NARENDRA_220	12:49	18:05	5:16	LINE CLEAR AVAILED
262	9-Mar-2022	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTED CHIKKODI_220	7:17	7:42	0:25	TRANSFORMER FAULT
263	9-Mar-2022	BAGALKOT	220	220/110KV,HV2,LV2	CHIKKODI_220,CHIKKODI_110 ,ANKALI_110,NANADI_110,KA DAKLAT_110,SADALAGA_110	7:17	7:45	0:28	TRANSFORMER FAULT
264	9-Mar-2022	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	7:17	8:04	0:47	LINE FAULT
265	9-Mar-2022	BAGALKOT	110	CHIKKOD-BHOJ/(GALATAGA)	BHOJ_110	7:20	8:20	1:00	HAND TRIPPED
266	9-Mar-2022	BAGALKOT	220	BAGEWADI-RBRK	STATION NOT AFFECTED BAGEWADI_220	15:11	15:25	0:14	LINE FAULT
267	9-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	BAGEWADI_220	11:38	15:48	4:10	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
268	9-Mar-2022	BAGALKOT	400	400/220KV,ICT1(HV)	DHONI_400	11:34	16:46	5:12	LINE CLEAR AVAILED
269	9-Mar-2022	BAGALKOT	220	400/220KV,ICT1(LV)	DHONI_400	11:33	16:50	5:17	LINE CLEAR AVAILED
270	9-Mar-2022	BAGALKOT	220	220/110KV,HV2,LV1	STATION NOT AFFECTED SLOUDATTI_220	21:10	21:55	0:45	TRANSFORMER FAULT
271	9-Mar-2022	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED SLOUDATTI_220	21:15	21:55	0:40	TRANSFORMER FAULT
272	9-Mar-2022	BAGALKOT	220	SLOUDATTI-BIDNAL	STATION NOT AFFECTED SLOUDATTI_220	21:50	22:19	0:29	HAND TRIPPED
273	9-Mar-2022	BAGALKOT	110	SLOUDATTI_YARAGATTI	YARAGATTI_110	21:56	22:34	0:38	HAND TRIPPED
274	9-Mar-2022	BAGALKOT	110	SLOUDATTI_MUNAVALLI	MUNAVALLI_110	21:57	22:25	0:28	HAND TRIPPED
275	9-Mar-2022	BAGALKOT	110	SLOUDATTI_UDIKERI	UDIKERI_110	21:10	22:14	1:04	HAND TRIPPED
276	9-Mar-2022	BAGALKOT	110	SLOUDATTI-MMCL	SLOUDATTI_220	21:10 (09.03.2022)			LINE OPEN,LINE FAULT
277	9-Mar-2022	BAGALKOT	220	HUBLI-NARENDRA1&2	STATION NOT AFFECTED HUBLI_220	13:30	18:06	4:36	NFBC ISSUED
278	9-Mar-2022	BAGALKOT	110	AMBEWADI- KAVALWADA(NK1)	AMBEWADI_220	10:51	12:25	1:34	LINE CLEAR AVAILED
279	9-Mar-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
280	9-Mar-2022	BAGALKOT	110	110/11KV,HV1	MANTUR_110	12:20	16:25	4:05	LINE CLEAR AVAILED
281	9-Mar-2022	BAGALKOT	110	110/11KV,HV2	KATARAKI_110	4:28	10:40	6:12	TRANSFORMER FAULT
282	9-Mar-2022	BAGALKOT	110	BAGALKOT-RAMDURG	STATION NOT AFFECTED BAGALKOT_220	21:40	21:42	0:02	HAND TRIPPED
283	9-Mar-2022	BAGALKOT	110	KAVALWADA-HALIYAL	STATION NOT AFFECTED HALIYAL_110	6:59	10:45	3:46	LINE FAULT
284	9-Mar-2022	BAGALKOT	110	KAVALWADA-HALIYAL	HALIYAL_110	10:45	12:01	1:16	LINE CLEAR AVAILED
285	9-Mar-2022	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	15:05	15:32	0:27	LINE FAULT
286	9-Mar-2022	BAGALKOT	110	110/11KV,HV1	SIRSI_220	7:40	7:50	0:10	TRANSFORMER FAULT
287	9-Mar-2022	BENGALURU	66	HV1	BANASAWADI	15:09	15:20	0:11	MAIN SUPPLY FAILURE
288	9-Mar-2022	BENGALURU	66	HV3	BANASAWADI	15:09	15:20	0:11	MAIN SUPPLY FAILURE
289	9-Mar-2022	BENGALURU	66	HV2	BIDADI 220	9:30	13:45	4:15	TRANSFORMER FAULT
290	9-Mar-2022	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI	16:07	17:05	0:58	LINE FAULT
291	9-Mar-2022	BENGALURU	66	HAL 220 - HOODY 1	NO STATION AFFECTED	17:05	17:25	0:20	LINE FAULT
292	9-Mar-2022	BENGALURU	66	HAL 220 - HOODY 1	NO STATION AFFECTED	17:25	18:47	1:22	LINE CLEAR AVAILED
293	9-Mar-2022	BENGALURU	66	HAL 220 - HOODY 1	NO STATION AFFECTED	18:47	19:54	1:07	LINE FAULT
294	9-Mar-2022	BENGALURU	66	HAL 220 - HOODY 1	NO STATION AFFECTED	19:54	22:59	3:05	LINE FAULT
295	9-Mar-2022	BENGALURU	66	HAL 220 - HOODY 1	NO STATION AFFECTED	22:59	23:27	0:28	LINE CLEAR AVAILED
296	9-Mar-2022	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	16:07	17:14	1:07	MAIN SUPPLY FAILURE
297	9-Mar-2022	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	15:09	15:20	0:11	LINE FAULT
298	9-Mar-2022	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	12:01	12:04	0:03	LINE FAULT
299	9-Mar-2022	BENGALURU	66	HV2	RR NAGAR	12:20	12:23	0:03	TRANSFORMER FAULT
300	9-Mar-2022	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	18:31	18:35	0:04	LOAD CHANGE OVER
301	9-Mar-2022	BENGALURU	66	HV2	TAVAREKERE	11:00	11:05	0:05	LINE CLEAR AVAILED
302	9-Mar-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE	4:04	4:10	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
303	9-Mar-2022	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	1:59	2:02	0:02	LINE FAULT
304	9-Mar-2022	BENGALURU	66	CHAKAVELU - MITTEMARI 220	CHAKAVELU	12:15	12:48	0:32	LINE FAULT
305	9-Mar-2022	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:25	10:40	0:15	LINE FAULT
306	9-Mar-2022	BENGALURU	66	HV2	THAYALUR	9:32	10:03	0:30	TRANSFORMER FAULT
307	9-Mar-2022	BENGALURU	66	HV2	THAYALUR	11:02	11:49	0:47	LINE CLEAR AVAILED
308	9-Mar-2022	BENGALURU	66	HV1	PATH PALYA	17:04	17:22	0:17	LINE CLEAR AVAILED
309	9-Mar-2022	BENGALURU	66	HV1	NELAMANGALA 66	14:02	14:35	0:33	LINE CLEAR AVAILED
310	9-Mar-2022	BENGALURU	66	HV3	NELAMANGALA 66	20:39	20:48	0:08	TRANSFORMER FAULT
311	9-Mar-2022	BENGALURU	66	HV1	MULBAGLU	1:02	1:54	0:52	TRANSFORMER FAULT
312	9-Mar-2022	BENGALURU	66	HV2	MULBAGLU	1:02	1:45	0:43	TRANSFORMER FAULT
313	9-Mar-2022	BENGALURU	66	HV3	KGF	11:57	12:17	0:20	LINE CLEAR AVAILED
314	9-Mar-2022	BENGALURU	66	HV3	KGF	22:06	22:18	0:11	TRANSFORMER FAULT
315	9-Mar-2022	BENGALURU	66	HV1	HUKUNDA	12:43	12:50	0:07	TRANSFORMER FAULT
316	9-Mar-2022	BENGALURU	66	HV1	GUNDLU KOTTUR	8:47	9:19	0:31	LINE CLEAR AVAILED
317	9-Mar-2022	BENGALURU	66	HV2	GUNDLU KOTTUR	9:20	9:30	0:10	LINE CLEAR AVAILED
318	9-Mar-2022	BENGALURU	66	BAGMANE WTC - ITI 220	BAGMANE WTC	18:55	19:05	0:10	LOAD CHANGE OVER
319	9-Mar-2022	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	15:30	15:35	0:04	LOAD CHANGE OVER
320	9-Mar-2022	BENGALURU	220	HV2	HAL 220	16:07(09/03/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
321	9-Mar-2022	GULBARGA	220	HV2, LV2	ALIPUR_220	17:09	17:19	0:10	TRANSFORMER FAULT
322	9-Mar-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110, KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
323	9-Mar-2022	GULBARGA	110	HV1	CHOWDAPUR_110	20:45(09.03.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
324	9-Mar-2022	GULBARGA	110	HV2, LV2	KAPNOOR_220	9:33	16:56	7:23	LINE CLEAR AVAILED
325	9-Mar-2022	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	5:55	6:02	0:07	LINE FAULT
326	9-Mar-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:52	4:57	0:05	LINE FAULT
327	9-Mar-2022	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	6:15	6:20	0:05	MAIN SUPPLY FAILURE
328	9-Mar-2022	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	15:50	16:10	0:20	MAIN SUPPLY FAILURE
329	9-Mar-2022	GULBARGA	110	GULBARGA-KAPNOOR1&2	GULBARGAWEST_110	9:30	17:35	8:05	LINE CLEAR AVAILED
330	9-Mar-2022	GULBARGA	110	HALBARGA-CHIDRI1(KAMTHANA)	CHIDRI_1_110, HABSİKOTE_110	6:15	6:20	0:05	LINE FAULT
331	9-Mar-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNAT HI_IPP, COREGREENSUGARS_I PP	21:52	22:00	0:08	LINE FAULT
332	9-Mar-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	3:48	4:20	0:32	LINE FAULT
333	9-Mar-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	11:13	11:24	0:11	LINE FAULT
334	9-Mar-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	4:37	4:47	0:10	LINE FAULT
335	9-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110, YERDONA_110, SRNAGAR_110, MALLAPURA_110	15:55	16:05	0:10	LINE FAULT
336	9-Mar-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110, KADAGANCHI_110	11:50	12:18	0:28	LINE FAULT
337	9-Mar-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110, KADAGANCHI_110	12:45	12:55	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
338	9-Mar-2022	GULBARGA	110	ALIPUR-BELLARY SOUTH2	BELLARY SOUTH_110,HALKUNDI_110	17:10	17:20	0:10	LINE CLEAR AVAILED
339	9-Mar-2022	GULBARGA	66	HV1	BENNEHALLI_66	3:59	4:10	0:11	TRANSFORMER FAULT
340	9-Mar-2022	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENN EHALLI_66	3:59	4:09	0:10	LINE FAULT
341	9-Mar-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	1:45	1:55	0:10	LINE FAULT
342	9-Mar-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	17:40	17:55	0:15	LINE FAULT
343	9-Mar-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	9:15	9:25	0:10	LINE FAULT
344	9-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
345	9-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
346	9-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
347	9-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
348	9-Mar-2022	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	6:10	12:10	6:00	LINE FAULT
349	9-Mar-2022	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	6:10	12:04	5:54	LINE FAULT
350	9-Mar-2022	HASSAN	220	HV3	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
351	9-Mar-2022	HASSAN	110	LV3	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
352	9-Mar-2022	HASSAN	220	HV1	MRSMSG_220	13:48	14:35	0:47	TRANSFORMER FAULT
353	9-Mar-2022	HASSAN	66	LV1	MRSMSG_220	13:48	14:35	0:47	TRANSFORMER FAULT
354	9-Mar-2022	HASSAN	66	LV1	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
355	9-Mar-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
356	9-Mar-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
357	9-Mar-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
358	9-Mar-2022	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:12	13:04	3:52	LINE CLEAR AVAILED
359	9-Mar-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:49	14:53	0:04	HAND TRIPPED
360	9-Mar-2022	HASSAN	110	LPH-MGHE 1	lph_gen	14:35(0.03.2022)			LINE OPEN,LINE FAULT
361	9-Mar-2022	HASSAN	110	HV3	KONAJE_110	10:15	13:58	3:43	LINE CLEAR AVAILED
362	9-Mar-2022	HASSAN	110	HV1	KADUR_220	10:37	11:57	1:20	LINE CLEAR AVAILED
363	9-Mar-2022	HASSAN	110	JOG110-LPH	JOG_110	14:35(0.03.2022)			LINE OPEN,LINE FAULT
364	9-Mar-2022	HASSAN	110	JOG-JLT4	mghejog_gen	14:35(0.03.2022)			LINE OPEN,LINE FAULT
365	9-Mar-2022	HASSAN	110	HV2	BELAGUMBA_110	11:48	15:46	3:58	LINE CLEAR AVAILED
366	9-Mar-2022	HASSAN	110	HV1	BELAGUMBA_110	11:48	15:46	3:58	LINE CLEAR AVAILED
367	9-Mar-2022	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	11:28	14:21	2:53	LINE CLEAR AVAILED
368	9-Mar-2022	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	5:46	19:43	13:57	LINE CLEAR AVAILED
369	9-Mar-2022	HASSAN	66	HV2	SINGAPURA_66	0:05	0:20	0:15	TRANSFORMER FAULT
370	9-Mar-2022	HASSAN	66	HV2	SINGAPURA_66	0:20	0:40	0:20	TRANSFORMER FAULT
371	9-Mar-2022	HASSAN	66	HV2	SINGAPURA_66	0:40	8:00	7:20	TRANSFORMER FAULT
372	9-Mar-2022	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	9:14	13:09	3:55	MAIN SUPPLY FAILURE
373	9-Mar-2022	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	9:14	13:14	4:00	MAIN SUPPLY FAILURE
374	9-Mar-2022	HASSAN	66	HV1	SIGEBAGE_66	9:14	14:06	4:52	MAIN SUPPLY FAILURE
375	9-Mar-2022	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:32	17:36	5:04	LINE CLEAR AVAILED
376	9-Mar-2022	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	12:32	17:36	5:04	LINE CLEAR AVAILED
377	9-Mar-2022	HASSAN	66	HV2	MATTANAVILE_66	12:56	13:07	0:11	LINE CLEAR AVAILED
378	9-Mar-2022	HASSAN	66	HV1	MALLIPATNA_66	12:21	12:25	0:04	LINE CLEAR AVAILED
379	9-Mar-2022	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	9:10	13:45	4:35	MAIN SUPPLY FAILURE
380	9-Mar-2022	HASSAN	66	HV1	KUDLIGERE_66	9:10	13:45	4:35	MAIN SUPPLY FAILURE
381	9-Mar-2022	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:10	13:45	4:35	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
382	9-Mar-2022	HASSAN	66	HV2	HOLEHONNUR_66	9:20	13:37	4:17	MAIN SUPPLY FAILURE
383	9-Mar-2022	HASSAN	66	HV1	HOLEHONNUR_66	9:20	13:37	4:17	MAIN SUPPLY FAILURE
384	9-Mar-2022	HASSAN	66	HV2	HOLALUR_66	9:15	13:37	4:22	MAIN SUPPLY FAILURE
385	9-Mar-2022	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	9:10	14:40	5:30	NFBC ISSUED
386	9-Mar-2022	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	9:10	14:40	5:30	NFBC ISSUED
387	9-Mar-2022	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:09	9:24	0:15	HAND TRIPPED
388	9-Mar-2022	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:36	14:43	0:07	HAND TRIPPED
389	9-Mar-2022	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	11:06	11:24	0:18	NFBC ISSUED
390	9-Mar-2022	HASSAN	66	HV1	BALLUPETE_66	10:00	14:50	4:50	LINE CLEAR AVAILED
391	9-Mar-2022	HASSAN	66	HV4	BALEHONNUR_66	11:13	12:02	0:49	TRANSFORMER FAULT
392	9-Mar-2022	MYSURU	66	HV1	ADDIHALLI_66	10:00	16:03	6:03	LINE CLEAR AVAILED
393	9-Mar-2022	MYSURU	66	HV2	ADDIHALLI_66	10:00	16:03	6:03	LINE CLEAR AVAILED
394	9-Mar-2022	MYSURU	66	ATIGULIPURA-HONNALLY	ATTIGULIPURA_66	9:33	16:45	7:12	LINE CLEAR AVAILED
395	9-Mar-2022	MYSURU	66	HV1	BGNAGAR_66	11:15	16:52	5:37	LINE CLEAR AVAILED
396	9-Mar-2022	MYSURU	66	HV2	BGNAGAR_66	11:20	16:50	5:30	LINE CLEAR AVAILED
397	9-Mar-2022	MYSURU	66	BGNAGAR-YEDIYUR	ADICHUNCHANGIRI_66 VADERAHALLI_66	16:00	17:29	1:28	LINE CLEAR AVAILED
398	9-Mar-2022	MYSURU	66	BOGADHI-HOOTGALLY	BOGHADI_66	10:05	16:52	6:46	LINE CLEAR AVAILED
399	9-Mar-2022	MYSURU	66	HV2	HD KOTE_66	4:03	4:08	0:05	TRANSFORMER FAULT
400	9-Mar-2022	MYSURU	66	HONNALLY-CRNAGAR	HONNALLY_66	9:31	16:45	7:13	LINE CLEAR AVAILED
401	9-Mar-2022	MYSURU	66	HV1	JAKKANAHALLI_66	0:03	0:17	0:14	TRANSFORMER FAULT
402	9-Mar-2022	MYSURU	66	KADABALLY-TUBINKERE	KADABALLY_66	12:03	12:09	0:06	LINE FAULT
403	9-Mar-2022	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	18:32	18:37	0:05	LINE FAULT
404	9-Mar-2022	MYSURU	66	MYSORE SOUTH-BOGADHI	KALAMANDIR_66	10:09	15:23	5:14	LINE CLEAR AVAILED
405	9-Mar-2022	MYSURU	66	PANDAVPURA-CHINKURLI	BANNANGADI_66	20:34	22:49	2:15	LINE CLEAR AVAILED
406	9-Mar-2022	MYSURU	66	PERIAPATNA-HUNSUR	KAMPLAPURA_66	10:28	14:57	4:28	LINE CLEAR AVAILED
407	9-Mar-2022	MYSURU	66	HV1	POONAMPETE_66	15:37	15:48	0:10	TRANSFORMER FAULT
408	9-Mar-2022	MYSURU	66	SFCSIVA-HEBBANI	NO STATIONS EFFECTED	12:05	13:14	1:09	LINE CLEAR AVAILED
409	9-Mar-2022	MYSURU	66	SFCSIVA-PPCL	NO STATIONS EFFECTED	9:45	11:12	1:27	LINE CLEAR AVAILED
410	9-Mar-2022	MYSURU	66	SHIVALLI-TUBINKERE	SHIVALLI_66	10:03	14:42	4:38	LINE CLEAR AVAILED
411	9-Mar-2022	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66 BANNANGADI_66	20:34	20:40	0:06	LINE FAULT
412	9-Mar-2022	MYSURU	66	VAJMANGLA-KADKOLA1	MARADIHUNDI_66 AYRAHALLI_66	18:55	19:26	0:31	LINE FAULT
413	9-Mar-2022	MYSURU	66	HV1	ARAKALWADI_66	9:30	16:45	7:15	LINE CLEAR AVAILED
414	9-Mar-2022	MYSURU	66	SOMANAHALLI-MADDUR	NO STATIONS EFFECTED	9:40	16:55	7:15	LINE CLEAR AVAILED
415	9-Mar-2022	MYSURU	66	SOMANAHALLI-K HONNALLGERE	SOMANAHALLI_66	9:50	16:30	6:40	LINE CLEAR AVAILED
416	9-Mar-2022	MYSURU	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66 KALAMANDIR_66	18:54	19:00	0:06	LINE FAULT
417	9-Mar-2022	MYSURU	66	AC GIRI-TUBINKERE	ADICHUNCHANGIRI_66	10:20	17:30	7:10	LINE CLEAR AVAILED
418	9-Mar-2022	MYSURU	66	HV1	VADERHALLI_66	11:30	18:30	7:00	LINE CLEAR AVAILED
419	9-Mar-2022	MYSURU	66	HEBBANI-SFC2	NO STATIONS EFFECTED	0:00	12:05	12:05	LINE CLEAR AVAILED
420	9-Mar-2022	MYSURU	66	HEBBANI-SFC2	NO STATIONS EFFECTED	12:05	13:14	1:09	LINE CLEAR AVAILED
421	9-Mar-2022	MYSURU	66	HEBBANI-SFC 2	NO STATIONS EFFECTED	22:34:00 (8.3.2022)	00:00:00 (9.3.2022)	1:26HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
422	9-Mar-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
423	9-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
424	9-Mar-2022	TUMKUR	400	JAGLUR_400-(BPS1) BALLARY PWOLING STATION 400KV	JAGLUR_400	10:28	15:15	4:46	LINE CLEAR AVAILED
425	9-Mar-2022	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	10:34	16:48	6:14	LINE CLEAR AVAILED
426	9-Mar-2022	TUMKUR	220	THALLAK 220kv- HIRIYUR 220KV	THALLAK_220	12:09	13:16	1:07	LINE CLEAR AVAILED
427	9-Mar-2022	TUMKUR	220	THALLAK 220kv- HIRIYUR 220KV	THALLAK_220	13:46	14:24	0:38	LINE CLEAR AVAILED
428	9-Mar-2022	TUMKUR	220	TR-3(HV SIDE)	THALLAK_220	14:46	14:58	0:12	TRANSFORMER FAULT
429	9-Mar-2022	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	5:47	19:42	13:55	LINE CLEAR AVAILED
430	9-Mar-2022	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	20:16	20:23	0:06	HAND TRIPPED
431	9-Mar-2022	TUMKUR	110	HONNAVALI 110-TIPTUR	HONNAVALI_110	5:47	20:23	14:36	LINE CLEAR AVAILED
432	9-Mar-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL 110	16:41	16:45	0:03	LINE FAULT
433	9-Mar-2022	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	9:12	13:35	4:23	LINE CLEAR AVAILED
434	9-Mar-2022	TUMKUR	66	YEDIYUR- BG NAGARA66	BGNAGARA_66	16:10	17:33	1:22	LINE CLEAR AVAILED
435	9-Mar-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	12:46	12:49	0:02	TRANSFORMER FAULT
436	9-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:25	14:33	0:08	LINE FAULT
437	9-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:38	18:48	0:10	LINE FAULT
438	9-Mar-2022	TUMKUR	66	TR-3	HARIYABB_66	10:03	10:08	0:05	TRANSFORMER FAULT
439	9-Mar-2022	TUMKUR	66	TR-3	HARIYABB_66	17:23	17:54	0:30	LINE CLEAR AVAILED
440	9-Mar-2022	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	8:10	9:26	1:16	LINE FAULT
441	9-Mar-2022	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	14:10	14:33	0:23	LINE FAULT
442	9-Mar-2022	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	15:57	16:09	0:12	LINE FAULT
443	9-Mar-2022	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	18:40	18:48	0:08	LINE FAULT
444	9-Mar-2022	TUMKUR	66	TR-2	HOLALKERE_66	19:20	19:26	0:06	LINE CLEAR AVAILED
445	9-Mar-2022	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	1:10	1:23	0:12	HAND TRIPPED
446	9-Mar-2022	TUMKUR	66	TR-1	KORA_66	10:23	13:22	2:59	LINE CLEAR AVAILED
447	9-Mar-2022	TUMKUR	66	TR-2	KORA_66	16:45	17:00	0:15	TRANSFORMER FAULT
448	9-Mar-2022	TUMKUR	66	TR-2	KEREBILACHI_66	3:40	3:45	0:05	TRANSFORMER FAULT
449	9-Mar-2022	TUMKUR	66	TR-1	KUNDUR_66	8:59	9:14	0:14	TRANSFORMER FAULT
450	9-Mar-2022	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66,HOLAVINAH ALLY_66	10:33	16:38	6:04	LINE CLEAR AVAILED
451	9-Mar-2022	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	10:34	16:50	6:16	LINE CLEAR AVAILED
452	9-Mar-2022	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	16:38	16:50	0:12	LINE CLEAR AVAILED
453	9-Mar-2022	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI 66	11:17	12:02	0:44	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
454	9-Mar-2022	TUMKUR	66	TR-1	PAVAGADA_220	14:00	14:09	0:08	TRANSFORMER FAULT
455	9-Mar-2022	TUMKUR	66	TR-1	PAVAGADA_220	16:04	16:12	0:07	TRANSFORMER FAULT
456	9-Mar-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	14:00	14:58	0:57	LINE FAULT
457	9-Mar-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	16:56	17:00	0:03	LINE FAULT
458	9-Mar-2022	TUMKUR	66	TR-1	SANTEMNAVATTUR_66	12:40	12:55	0:15	LINE CLEAR AVAILED
459	9-Mar-2022	TUMKUR	66	TR-2	SANTEMNAVATTUR_66	12:45	12:55	0:10	LINE CLEAR AVAILED
460	9-Mar-2022	TUMKUR	66	TR-3(LV SIDE)	THALLAK_220	14:46	14:59	0:13	TRANSFORMER FAULT
461	9-Mar-2022	TUMKUR	66	THALLAK 220-PR PURA	THALLAK_220	18:11	18:20	0:09	LINE FAULT
462	10-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
463	10-Mar-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
464	10-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
465	10-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
466	10-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)	17:41 (10.03.2022)	175:09HRS	LINE CHARGED
467	10-Mar-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
468	10-Mar-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:42 (06.03.2022)			LINE OPEN,LINE CLEAR AVAILED
469	10-Mar-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:43 (06.03.2022)			LINE OPEN,LINE CLEAR AVAILED
470	10-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
471	10-Mar-2022	BAGALKOT	110	SOUDATTI220-MMCL	SOUDATTI_220	21:10 (09.03.2022)	18:29 (10.03.2022)	21:19HRS	LINE CHARGED
472	10-Mar-2022	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	STATION NOT AFFECTED AMBEWADI_220	13:27	14:17	0:50	LINE FAULT
473	10-Mar-2022	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	16:51 (10.03.2022)			LINE OPEN,LINE FAULT
474	10-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	17:51	18:30	0:39	HAND TRIPPED
475	10-Mar-2022	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	18:41	19:42	1:01	HAND TRIPPED
476	10-Mar-2022	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	11:42	11:50	0:08	LINE FAULT
477	10-Mar-2022	BAGALKOT	110	BELGAUM220-BELGAUM(NEHARU NAGAR)	NEHARU NAGAR_110	18:43	18:58	0:15	LINE FAULT
478	10-Mar-2022	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	13:44	17:13	3:29	LINE CLEAR AVAILED
479	10-Mar-2022	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABAKAVI_110	10:44	10:52	0:08	LINE FAULT
480	10-Mar-2022	BAGALKOT	110	110/33KV,HV2	HALLURU_33,MALALI_33 MAHALINGAPUR_220	13:08	13:48	0:40	LINE CLEAR AVAILED
481	10-Mar-2022	BAGALKOT	220	NARENDRA-HUBLI 1&2	STATION NOT AFFECTED NARENDRA_220	11:46	17:41	5:55	NFBC ISSUED
482	10-Mar-2022	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	11:45	17:40	5:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
483	10-Mar-2022	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	11:46	17:40	5:54	LINE CLEAR AVOIDED
484	10-Mar-2022	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110	14:56	14:57	0:01	HAND TRIPPED
485	10-Mar-2022	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	16:15	16:45	0:30	LINE CLEAR AVOIDED
486	10-Mar-2022	BAGALKOT	110	110/11KV, HV2	ALMEL_110	8:40	8:48	0:08	TRANSFORMER FAULT
487	10-Mar-2022	BAGALKOT	110	110/11KV, HV3	BIJAPUR CITY_110	7:23	7:30	0:07	TRANSFORMER FAULT
488	10-Mar-2022	BAGALKOT	220	220/110KV, HV1&LV1	BIJAPUR_220	10:13	13:33	3:20	LINE CLEAR AVOIDED
489	10-Mar-2022	BAGALKOT	220	220/110KV, LV2	BIJAPUR_220, BIJAPUR CITY_110, KIADB BIJAPUR_110, THORVI_110, BHUTNAL_110, TAKKALAKI_110	11:11	11:20	0:09	TRANSFORMER FAULT
490	10-Mar-2022	BAGALKOT	110	BELGAUM- MACHE(BELGAUM 220)	BELGAUM_110	18:54	19:00	0:06	HAND TRIPPED
491	10-Mar-2022	BAGALKOT	110	110/33KV, HV3	GADAG_110	10:13	12:41	2:28	LINE CLEAR AVOIDED
492	10-Mar-2022	BAGALKOT	110	110/33KV, HV2	HANGAL_110, LAXMIPURA_33, AKKIALUR_33, BASAPUR_33, PALA_33	10:45	10:50	0:05	TRANSFORMER FAULT
493	10-Mar-2022	BAGALKOT	110	110/33KV, HV2	HANGAL_110, LAXMIPURA_33, AKKIALUR_33, BASAPUR_33, PALA_33	12:30	12:35	0:05	TRANSFORMER FAULT
494	10-Mar-2022	BAGALKOT	110	HIDIKALDAM- ANKALAGI	HIDIKAL DAM_110	12:53	12:58	0:05	HAND TRIPPED
495	10-Mar-2022	BAGALKOT	110	INDI220- HIREMASALI	HIREMASALI_110	6:34	6:42	0:08	LINE CLEAR AVOIDED
496	10-Mar-2022	BAGALKOT	110	ISLAMPUR- F1(ANKALAGI)	STATION NOT AFFECTED ISLAMPUR_110	12:53	17:38	4:45	HAND TRIPPED
497	10-Mar-2022	BAGALKOT	110	110/11KV, HV2	KHADAKALAT_110	11:28	12:48	1:20	TRANSFORMER FAULT
498	10-Mar-2022	BAGALKOT	110	110/11KV, HV2	KHADAKALAT_110	19:04	19:15	0:11	TRANSFORMER FAULT
499	10-Mar-2022	BAGALKOT	110	110/11KV, HV2	KHADAKALAT_110	19:30 (10.03.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
500	10-Mar-2022	BAGALKOT	110	110/11KV, HV1	LAKMANAHALLI_110	12:32	12:52	0:20	LINE CLEAR AVOIDED
501	10-Mar-2022	BAGALKOT	110	110/11KV, HV1	LAKMANAHALLI_110	13:42	19:13	5:31	LINE CLEAR AVOIDED
502	10-Mar-2022	BAGALKOT	110	110/11KV, HV2	LAKMANAHALLI_110	13:44	19:13	5:29	LINE CLEAR AVOIDED
503	10-Mar-2022	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110	10:30	22:15	11:45	LINE CLEAR AVOIDED
504	10-Mar-2022	BAGALKOT	110	KUD DHARWAD- LAKMANAHALLI	LAKMANAHALLI_110	12:45	12:51	0:06	HAND TRIPPED
505	10-Mar-2022	BAGALKOT	110	KUD DHARWAD- LAKMANAHALLI	LAKMANAHALLI_110	13:44	17:45	4:01	LINE CLEAR AVOIDED
506	10-Mar-2022	BAGALKOT	110	NARAGUND- BPCL	STATION NOT AFFECTED NARAGUND_110	21:38	22:16	0:38	LINE FAULT
507	10-Mar-2022	BAGALKOT	110	NARAGUND- BPCL	STATION NOT AFFECTED NARAGUND_110	22:19	23:03	0:44	LINE FAULT
508	10-Mar-2022	BAGALKOT	110	110/11KV, HV2	NAVALAGI_110	16:00	18:20	2:20	LINE CLEAR AVOIDED
509	10-Mar-2022	BAGALKOT	110	110/11KV, HV2 (HV1)	STATION NOT AFFECTED SALAHALLI_110	3:26	3:41	0:15	TRANSFORMER FAULT
510	10-Mar-2022	BAGALKOT	110	110/11KV, HV2 (HV1)	STATION NOT AFFECTED SALAHALLI_110	3:41	9:00	5:19	TRANSFORMER FAULT
511	10-Mar-2022	BAGALKOT	110	RAMADURG-BAGALKOT220	STATION NOT AFFECTED RAMADURG_110	11:24	11:34	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
512	10-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SHIRBUR_110	16:19	17:39	1:20	LINE CLEAR AVOIDED
513	10-Mar-2022	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
514	10-Mar-2022	BAGALKOT	220	VAJRAMATTI-ENERGON SOLAR	STATION NOT AFFECTED VAJRAMATTI_220	16:45	17:00	0:15	LINE FAULT
515	10-Mar-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110,GIRISAGARA_110, BISNAL_110, TOLAMATTI_110	6:25	6:40	0:15	LINE FAULT
516	10-Mar-2022	BAGALKOT	110	VAJRAMATTI -SHIRAGUPPI	SHIRAGUPPI_110	6:25	6:40	0:15	LINE FAULT
517	10-Mar-2022	BAGALKOT	110	LAKAMANAHALLI-NAVANAGAR(H)	LAKAMANAHALLI_110	10:30	21:25	4:04	LINE CLEAR AVOIDED
518	10-Mar-2022	BAGALKOT	110	LAKAMANAHALLI-NAVANAGAR(H)	STATION NOT AFFECTED NAVANAGAR(H)_110	10:26 (10.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
519	10-Mar-2022	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTED HUBLI_220	14:58 (10.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
520	10-Mar-2022	BENGALURU	66	HV2	VOLVO	13:07	13:16	0:09	TRANSFORMER FAULT
521	10-Mar-2022	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	9:05	9:16	0:11	LOAD CHANGE OVER
522	10-Mar-2022	BENGALURU	66	HV2	NELAMANGALA 66	15:42	15:53	0:10	LINE CLEAR AVOIDED
523	10-Mar-2022	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:18	14:48	0:29	LOAD CURTAILMENT
524	10-Mar-2022	BENGALURU	66	HV2	MAASTI	21:11	21:19	0:07	TRANSFORMER FAULT
525	10-Mar-2022	BENGALURU	66	SADLI - MITTEMARI 220	SADLI	14:05	14:25	0:20	LOAD CHANGE OVER
526	10-Mar-2022	BENGALURU	66	HV1	KUNDANA	23:46	23:50	0:03	LINE CLEAR AVOIDED
527	10-Mar-2022	BENGALURU	66	HV2	KONDASPURA	8:40	8:45	0:05	TRANSFORMER FAULT
528	10-Mar-2022	BENGALURU	66	HV2	KGF	12:21	14:45	2:23	LINE CLEAR AVOIDED
529	10-Mar-2022	BENGALURU	66	HV2	KGF	14:53	15:24	0:31	LINE CLEAR AVOIDED
530	10-Mar-2022	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	11:34	11:37	0:03	LOAD CHANGE OVER
531	10-Mar-2022	BENGALURU	66	HV1	HUKUNDA	8:30	8:35	0:05	TRANSFORMER FAULT
532	10-Mar-2022	BENGALURU	220	HV1	HOSKOTE 220	11:33	17:42	6:08	LINE CLEAR AVOIDED
533	10-Mar-2022	BENGALURU	220	LV1	HOSKOTE 220	11:33	17:42	6:09	LINE CLEAR AVOIDED
534	10-Mar-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	NO STATION AFFECTED	17:40	18:15	0:35	LINE FAULT
535	10-Mar-2022	BENGALURU	66	SULIBELE - HOSKOTE 220	SULIBELE	11:30	11:40	0:09	LOAD CHANGE OVER
536	10-Mar-2022	BENGALURU	66	HV1	GUNDLU KOTTUR	14:20	14:25	0:05	LINE CLEAR AVOIDED
537	10-Mar-2022	BENGALURU	66	ANDERSONPETE - T GOLAHALLI 220	ANDERSONPETE	11:14	12:50	1:36	LINE CLEAR AVOIDED
538	10-Mar-2022	BENGALURU	66	HV1	NANDAGUDI	11:48	13:00	1:12	TRANSFORMER FAULT
539	10-Mar-2022	BENGALURU	66	HV2	DODALAHALLI	6:00	6:20	0:20	TRANSFORMER FAULT
540	10-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	10:05	10:30	0:25	LINE CLEAR AVOIDED
541	10-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:27	16:38	0:11	LINE CLEAR AVOIDED
542	10-Mar-2022	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	7:59	8:18	0:19	LOAD CHANGE OVER
543	10-Mar-2022	BENGALURU	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK	16:22	16:40	0:18	LOAD CHANGE OVER
544	10-Mar-2022	BENGALURU	66	CESSNA PARK - ORACLE (EHT)	ORACLE (EHT)	12:15	12:30	0:15	MAIN SUPPLY FAILURE
545	10-Mar-2022	BENGALURU	66	CESSNA PARK - EXORA	EXORA	12:15	12:30	0:15	MAIN SUPPLY FAILURE
546	10-Mar-2022	BENGALURU	66	CESSNA PARK - CESSNA (EHT)	CESSNA (EHT)	12:15	12:30	0:15	MAIN SUPPLY FAILURE



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
547	10-Mar-2022	BENGALURU	66	CESSNA PARK - VIKAS TECH PARK 220	CESSNA PARK	12:15	12:30	0:15	LINE CLEAR AVAILED
548	10-Mar-2022	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	4:07	4:30	0:23	MAIN SUPPLY FAILURE
549	10-Mar-2022	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	4:07	4:29	0:22	MAIN SUPPLY FAILURE
550	10-Mar-2022	BENGALURU	66	VRISHBHAVATHI 220 - RR NAGAR	NO STATION AFFECTED	4:07	4:31	0:24	MAIN SUPPLY FAILURE
551	10-Mar-2022	BENGALURU	66	VRISHBHAVATHI 220 - BMRCL (EHT)	BMRCL (EHT)	4:10	4:31	0:21	MAIN SUPPLY FAILURE
552	10-Mar-2022	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	4:10	4:29	0:19	MAIN SUPPLY FAILURE
553	10-Mar-2022	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	4:07	4:30	0:23	MAIN SUPPLY FAILURE
554	10-Mar-2022	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	4:07	4:25	0:18	LINE FAULT
555	10-Mar-2022	BENGALURU	220	HV1	VRISHBHAVATHI 220	4:07	4:25	0:18	MAIN SUPPLY FAILURE
556	10-Mar-2022	BENGALURU	220	HV2	VRISHBHAVATHI 220	4:07	4:25	0:18	MAIN SUPPLY FAILURE
557	10-Mar-2022	BENGALURU	66	HV1	VRISHBHAVATHI 220	4:07	4:26	0:19	MAIN SUPPLY FAILURE
558	10-Mar-2022	BENGALURU	66	HV2	VRISHBHAVATHI 220	4:07	4:26	0:19	MAIN SUPPLY FAILURE
559	10-Mar-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	4:11	4:18	0:07	LINE FAULT
560	10-Mar-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	4:11	4:18	0:07	LINE FAULT
561	10-Mar-2022	BENGALURU	66	T GOLAHALLI 220 - KYASAMBALLI	NO STATION AFFECTED	18:01(10-03-2022)			LINE OPEN,LINE FAULT
562	10-Mar-2022	BENGALURU	220	HV2	HAL 220	16:07(09/03/2022)	20:51(10/03/2022 )	28:43HRS	TRANSFORMER CHARGED
563	10-Mar-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
564	10-Mar-2022	GULBARGA	220	HV2	HALBARGA_220	21:01	21:10	0:09	TRANSFORMER FAULT
565	10-Mar-2022	GULBARGA	220	HV1	MUNIRABAD_220	9:54	15:50	5:56	LINE CLEAR AVAILED
566	10-Mar-2022	GULBARGA	220	HV2,LV2	ALIPUR_220	11:48	11:59	0:11	TRANSFORMER FAULT
567	10-Mar-2022	GULBARGA	220	HV1,LV1	ALIPUR_220	11:49	11:54	0:05	TRANSFORMER FAULT
568	10-Mar-2022	GULBARGA	220	HV2,LV2	ALIPUR_220	12:50	12:58	0:08	TRANSFORMER FAULT
569	10-Mar-2022	GULBARGA	220	HV1	KAPNOOR_220	8:35	15:25	6:50	LINE CLEAR AVAILED
570	10-Mar-2022	GULBARGA	220	KUSTAGI-OSTRO WIND_IPP	KUSTAGI_220	9:15	19:28	10:13	LINE CLEAR AVAILED
571	10-Mar-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	5:08	5:22	0:14	LINE FAULT
572	10-Mar-2022	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	9:54	15:50	5:56	LINE CLEAR AVAILED
573	10-Mar-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
574	10-Mar-2022	GULBARGA	110	HV1	CHOWDAPUR_110	20:45(09.03.2022)	1:15(10.03.2022)	4:30HRS	TRANSFORMER CHARGED
575	10-Mar-2022	GULBARGA	110	HV1	BISILAHALLI_110	10:25	10:35	0:10	TRANSFORMER FAULT
576	10-Mar-2022	GULBARGA	110	HV1	BEVOOR_110	8:00	13:30	5:30	LINE CLEAR AVAILED
577	10-Mar-2022	GULBARGA	110	HV2	BEVOOR_110	14:45	19:05	4:20	LINE CLEAR AVAILED
578	10-Mar-2022	GULBARGA	110	PDHALLI-CLEAN MAX_SOLAR	PD_HALLI_110	11:42	11:48	0:06	LINE FAULT
579	10-Mar-2022	GULBARGA	110	PDHALLI-CLEAN MAX_SOLAR	PD_HALLI_110	12:32	12:39	0:07	LINE FAULT
580	10-Mar-2022	GULBARGA	110	PDHALLI-CLEAN MAX_SOLAR	PD_HALLI_110	12:48	13:19	0:31	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
581	10-Mar-2022	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	17:40	17:50	0:10	LINE FAULT
582	10-Mar-2022	GULBARGA	110	KEREHALLI-MUNIRABAD	KEREHALLI_110	9:05	16:20	7:15	LINE CLEAR AVAILED
583	10-Mar-2022	GULBARGA	110	KEREHALLI-MUNIRABAD	KEREHALLI_110	21:05	21:20	0:15	MAIN SUPPLY FAILURE
584	10-Mar-2022	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	6:00	6:10	0:10	MAIN SUPPLY FAILURE
585	10-Mar-2022	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	9:40	9:50	0:10	MAIN SUPPLY FAILURE
586	10-Mar-2022	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	16:10	16:20	0:10	MAIN SUPPLY FAILURE
587	10-Mar-2022	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	19:55	20:10	0:15	MAIN SUPPLY FAILURE
588	10-Mar-2022	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	10:05	15:02	4:57	LINE CLEAR AVAILED
589	10-Mar-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110, KADAGANCHI_110	9:25	9:31	0:06	LINE FAULT
590	10-Mar-2022	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_220	15:45	16:18	0:33	LOAD CURTAILMENT
591	10-Mar-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:10	6:15	0:05	LINE FAULT
592	10-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	6:02	6:12	0:10	LINE FAULT
593	10-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	9:45	9:50	0:05	LINE CLEAR AVAILED
594	10-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	16:10	16:20	0:10	LINE CLEAR AVAILED
595	10-Mar-2022	GULBARGA	110	ALIPUR-BELLAERY SOUTH2	BELLARY SOUTH_110,HALKUNDI_110	12:50	12:59	0:09	LINE CLEAR AVAILED
596	10-Mar-2022	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110, KURUGOD_110,SHATAVA HANA_IPP,AGRAWAL_IPP,SUZ LON_IPP,KAMALAPUR_110,M ATR_110,RBNS FACTORY	12:50	12:59	0:09	LINE CLEAR AVAILED
597	10-Mar-2022	GULBARGA	110	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110	9:25	17:49	8:24	LINE CLEAR AVAILED
598	10-Mar-2022	GULBARGA	110	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110	21:03	21:07	0:04	LINE FAULT
599	10-Mar-2022	GULBARGA	110	KAPNOOR-GULBARGA WEST1,2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:30	16:27	7:57	LINE CLEAR AVAILED
600	10-Mar-2022	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	11:50	12:00	0:10	MAIN SUPPLY FAILURE
601	10-Mar-2022	GULBARGA	110	GULBARGAWEST-KAPANOOR	GULBARGAWEST_110	8:28	16:25	7:57	LINE CLEAR AVAILED
602	10-Mar-2022	GULBARGA	110	HALAKUNDI-ALIPUR	HALAKUNDI_110	11:48	12:00	0:12	MAIN SUPPLY FAILURE
603	10-Mar-2022	GULBARGA	110	HALAKUNDI-ALIPUR	HALAKUNDI_110	12:49	13:03	0:14	MAIN SUPPLY FAILURE
604	10-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	9:07	13:00	3:53	LINE CLEAR AVAILED
605	10-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	13:00	16:18	3:18	LINE CLEAR AVAILED
606	10-Mar-2022	GULBARGA	110	MUNIRABAD-KOPPALL	KIRLOSHKAR_IPP,HARE KRISHNA_IPP, STATR METALIC IPP	9:23	11:08	1:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
607	10-Mar-2022	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSHKAR_IPP,HARE KRISHNA_IPP, STATR METALIC_IPP	11:08	16:40	5:32	LINE CLEAR AVAILED
608	10-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	21:06	21:20	0:14	LINE FAULT
609	10-Mar-2022	HASSAN	110	LPH-MGHE 1	lph_gen	14:35(09.03.2022)			LINE OPEN,LINE FAULT
610	10-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
611	10-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
612	10-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
613	10-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
614	10-Mar-2022	HASSAN	110	JOG110-LPH	JOG_110	14:35(09.03.2022)			LINE OPEN,LINE FAULT
615	10-Mar-2022	HASSAN	110	JOG-JLT4	mghejog_gen	14:35(09.03.2022)			LINE OPEN,LINE FAULT
616	10-Mar-2022	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavaty_gen	13:51	15:28	1:37	LINE CLEAR AVAILED
617	10-Mar-2022	HASSAN	220	TALAGU-SGS2	TALAGUppa_400	13:51	15:28	1:37	NFBC ISSUED
618	10-Mar-2022	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	9:20	18:23	9:03	LINE CLEAR AVAILED
619	10-Mar-2022	HASSAN	110	HV3	BANTWAla_110	9:23	13:57	4:34	LINE CLEAR AVAILED
620	10-Mar-2022	HASSAN	110	HV2	BAIKAMPady_110	9:33	11:30	1:57	LINE CLEAR AVAILED
621	10-Mar-2022	HASSAN	110	HV1	BAIKAMPady_110	11:31	13:25	1:54	LINE CLEAR AVAILED
622	10-Mar-2022	HASSAN	110	MRSSHM-MPM	MRSMSG_220	9:12	10:30	1:18	LINE CLEAR AVAILED
623	10-Mar-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:36	12:27	1:51	LINE FAULT
624	10-Mar-2022	HASSAN	110	HV1	NANDIKUR_110	11:35	12:40	1:05	LINE CLEAR AVAILED
625	10-Mar-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	12:24	12:42	0:18	HAND TRIPPED
626	10-Mar-2022	HASSAN	66	HV2	KIADB HASSAN_66	0:00	0:38	0:38	TRANSFORMER FAULT
627	10-Mar-2022	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	9:30	18:06	8:36	LINE CLEAR AVAILED
628	10-Mar-2022	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	9:30	18:06	8:36	LINE CLEAR AVAILED
629	10-Mar-2022	HASSAN	66	HV1	BYACHANAHALLY_66	6:55	10:00	3:05	LINE CLEAR AVAILED
630	10-Mar-2022	HASSAN	66	BALEHONNURALDUR-	ALDUR_66	10:05	16:49	6:44	LINE CLEAR AVAILED
631	10-Mar-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:20	16:41	6:21	LINE CLEAR AVAILED
632	10-Mar-2022	HASSAN	66	DODDAH-HOOTGALLI	DODDAHALLY_66	13:42	14:40	0:58	LINE FAULT
633	10-Mar-2022	HASSAN	66	HV1	DODDAHALLY_66	13:42	14:40	0:58	TRANSFORMER FAULT
634	10-Mar-2022	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66	14:44	14:50	0:05	LINE FAULT
635	10-Mar-2022	MYSURU	66	HV2	HDKOTE_66	2:13	2:22	0:08	TRANSFORMER FAULT
636	10-Mar-2022	MYSURU	66	HV2	HDKOTE_66	15:35	15:41	0:06	TRANSFORMER FAULT
637	10-Mar-2022	MYSURU	66	HV1	JAKKANAHALLI_66	0:19	0:33	0:13	TRANSFORMER FAULT
638	10-Mar-2022	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	13:50	14:49	0:58	LINE CLEAR AVAILED
639	10-Mar-2022	MYSURU	66	KADAKOLA-SARGUR2	HURA_66 DOORA_6 HULLALLI_66 CHANDRAWADI_66	13:35	13:38	0:03	HAND TRIPPED
640	10-Mar-2022	MYSURU	66	KADAKOLA-SARGUR1	HAMPAPURA_66 JAYAPURA_66	13:35	13:38	0:03	HAND TRIPPED
641	10-Mar-2022	MYSURU	66	HV3	KRPETE_66	10:04	11:42	1:37	LINE CLEAR AVAILED
642	10-Mar-2022	MYSURU	66	HV1	MADDUR_66 KK DODDI_66 KMDODDI_66 TUMBEKERE_66	4:12	4:18	0:06	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
643	10-Mar-2022	MYSURU	66	HV1	MADDUR_66 KK DODDI_66 KMDODDI_66 TUMBEKERE_66	4:25	4:28	0:03	HAND TRIPPED
644	10-Mar-2022	MYSURU	66	HV1	MADIKERI_66	15:52	17:07	1:14	LINE CLEAR AVAILED
645	10-Mar-2022	MYSURU	66	POONAMPETE-HANGODU	PONNAMPET_66 VIRAJPETE_66	18:44	18:53	0:09	LINE FAULT
646	10-Mar-2022	MYSURU	66	HV3	POONAMPETE_66	2:32	2:37	0:04	TRANSFORMER FAULT
647	10-Mar-2022	MYSURU	66	HV2	SANTESARGUR_66	10:10	16:35	6:25	LINE CLEAR AVAILED
648	10-Mar-2022	MYSURU	66	SFCSIVA-PPCL	NO STATIONS EFFECTED	8:25	11:20	2:55	LINE CLEAR AVAILED
649	10-Mar-2022	MYSURU	66	VAJMANGALA-KADAKOLA2	NO STATIONS EFFECTED	11:03	12:35	1:32	NFBC ISSUED
650	10-Mar-2022	MYSURU	66	HV2	VAJMANGALA_66	13:42	13:53	0:11	TRANSFORMER FAULT
651	10-Mar-2022	MYSURU	66	HEBBANI-MEGHALAPURA	THUMBLA_66 VYASARAJAPURA_66 GARGESHWARI_66	18:43	18:53	0:10	LINE FAULT
652	10-Mar-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
653	10-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
654	10-Mar-2022	TUMKUR	400	GUTUR_400-BTPS	GUTUR_400	12:10	15:50	3:40	LINE CLEAR AVAILED
655	10-Mar-2022	TUMKUR	400	JAGLUR_400- CHITRADURGA220	CHITRADURGA_220	11:40	14:45	3:05	LINE CLEAR AVAILED
656	10-Mar-2022	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	16:59	19:00	2:01	LINE CLEAR AVAILED
657	10-Mar-2022	TUMKUR	110	TR-1	SAMPIGE_110	11:02	14:10	3:08	LINE CLEAR AVAILED
658	10-Mar-2022	TUMKUR	110	TR-2	SAMPIGE_110	11:02	17:58	6:56	LINE CLEAR AVAILED
659	10-Mar-2022	TUMKUR	66	TR-1	SIRA_66	21:42	21:55	0:12	LINE CLEAR AVAILED
660	10-Mar-2022	TUMKUR	66	TR-1	SASALUHALLA_66	21:13	21:20	0:06	HAND TRIPPED
661	10-Mar-2022	TUMKUR	66	TR-1	GARAGA_66	10:04	14:33	4:29	LINE CLEAR AVAILED
662	10-Mar-2022	TUMKUR	66	TR-2	GARAGA_66	10:04	14:34	4:29	LINE CLEAR AVAILED
663	10-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:55	16:07	0:11	LINE FAULT
664	10-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:01	17:32	0:30	LINE FAULT
665	10-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	21:03	21:09	0:05	LINE FAULT
666	10-Mar-2022	TUMKUR	66	TR-1	RAMAPURA_66	13:00	18:17	5:17	LINE CLEAR AVAILED
667	10-Mar-2022	TUMKUR	66	TR-2	RAMAPURA_66	13:00	18:17	5:17	LINE CLEAR AVAILED
668	10-Mar-2022	TUMKUR	66	TR-1	HIRESHALLI_66	12:45	13:03	0:17	HAND TRIPPED
669	10-Mar-2022	TUMKUR	66	TR-2	HIRESHALLI_66	13:25	13:36	0:10	HAND TRIPPED
670	10-Mar-2022	TUMKUR	66	TR-2	HONNUDIKE_66	9:15	9:20	0:05	TRANSFORMER FAULT
671	10-Mar-2022	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEE LAGUNDA_66	19:18	19:26	0:08	HAND TRIPPED
672	10-Mar-2022	TUMKUR	66	TR-1	KEREBILACHI_66	4:30	4:35	0:05	TRANSFORMER FAULT
673	10-Mar-2022	TUMKUR	66	TR-1	KEREBILACHI_66	5:45	5:50	0:05	TRANSFORMER FAULT
674	10-Mar-2022	TUMKUR	66	H D PURA- SUZLON_IPP_66	SUZLON_IPP_66	7:14	16:28	9:14	HAND TRIPPED
675	10-Mar-2022	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	9:28	16:18	6:49	HAND TRIPPED
676	10-Mar-2022	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	16:18	16:25	0:06	HAND TRIPPED
677	10-Mar-2022	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	17:07	18:40	1:33	LINE CLEAR AVAILED
678	10-Mar-2022	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	17:07	18:38	1:30	LINE CLEAR AVAILED
679	10-Mar-2022	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:07	18:38	1:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
680	10-Mar-2022	TUMKUR	66	HIRIYUR 220KV- ENERCON1_IPP_66	ENERCON1_IPP_66	17:06	18:40	1:34	LINE CLEAR AVAILED
681	11-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
682	11-Mar-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
683	11-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
684	11-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
685	11-Mar-2022	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
686	11-Mar-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:42 (06.03.2022)	2:56 (11.03.2022)	107:14HR S	LINE CHARGED
687	11-Mar-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:43 (06.03.2022)	2:55 (11.03.2022)	107:12HR S	LINE CHARGED
688	11-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
689	11-Mar-2022	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	16:51 (10.03.2022)	18:25 (11.03.2022)	25:34HRS	LINE CHARGED
690	11-Mar-2022	BAGALKOT	110	110/11KV, HV2	KHADAKALAT_110	19:30 (10.03.2022)	13:03 (11.03.2022)	17:33HRS	TRANSFORMER CHARGED
691	11-Mar-2022	BAGALKOT	400	DHONI- GUDDADAHALLI	STATION NOT AFFECTED DHONI_400	11:16	18:44	7:28	LINE CLEAR AVAILED
692	11-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
693	11-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
694	11-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY2	STATION NOT AFFECTED SIRSI_220	2:55	18:17	15:22	HAND TRIPPED
695	11-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY1	STATION NOT AFFECTED SIRSI_220	2:56	18:16	15:22	HAND TRIPPED
696	11-Mar-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:15	22:54	4:39	HAND TRIPPED
697	11-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY2	STATION NOT AFFECTED SIRSI_220	22:53 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
698	11-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY1	STATION NOT AFFECTED SIRSI_220	22:53 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
699	11-Mar-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:57	18:15	5:55	LINE CLEAR AVAILED
700	11-Mar-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:58	18:15	5:55	LINE CLEAR AVAILED
701	11-Mar-2022	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	10:33	18:05	7:32	NFBC ISSUED
702	11-Mar-2022	BAGALKOT	220	AMBEWADI- PONDA1	STATION NOT AFFECTED AMBEWADI_220	13:29	18:23	4:54	LINE CLEAR AVAILED
703	11-Mar-2022	BAGALKOT	220	AMBEWADI- NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	13:51	14:01	0:09	LINE FAULT
704	11-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	10:57	17:11	6:14	LINE CLEAR AVAILED
705	11-Mar-2022	BAGALKOT	110	ANKOL-KUMTA(L2)	ANKOLA_110	2:38	11:01	8:23	LINE FAULT
706	11-Mar-2022	BAGALKOT	110	ANKOL-KUMTA(L2)	ANKOLA_110	12:03	12:11	0:08	HAND TRIPPED
707	11-Mar-2022	BAGALKOT	110	ANKOL-KUMTA(L2)	ANKOLA_110	22:09	22:53	0:44	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
708	11-Mar-2022	BAGALKOT	110	CNDKT-F2 (O/G ALMEL )	CHANDKAVATE_110,ALMEL_1 10	18:21	18:25	0:04	LINE FAULT
709	11-Mar-2022	BAGALKOT	110	CNDKT-F2 (O/G ALMEL )	CHANDKAVATE_110,ALMEL_1 11	23:13	23:20	0:07	LINE FAULT
710	11-Mar-2022	BAGALKOT	110	110/33KV,HV4(HV2)	GOPANKOPPA_110,KMC_33	10:00	15:01	5:01	LINE CLEAR AVAILED
711	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	9:12	10:08	0:56	TRANSFORMER FAULT
712	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	11:41	11:50	0:09	TRANSFORMER FAULT
713	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	12:00	12:13	0:13	TRANSFORMER FAULT
714	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	12:18	12:30	0:12	TRANSFORMER FAULT
715	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	14:10	14:21	0:11	TRANSFORMER FAULT
716	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	16:01	16:03	0:02	TRANSFORMER FAULT
717	11-Mar-2022	BAGALKOT	110	110/33KV,HV2	HANGAL_110,AKKI ALUR_33,BOMMANAHALLI_3 3,BELGAL PET_33, LAXMIPURA_33	16:05	16:07	0:02	TRANSFORMER FAULT
718	11-Mar-2022	BAGALKOT	110	110/11KV,HV1	HUDALI_110	9:58	16:00	6:02	HAND TRIPPED
719	11-Mar-2022	BAGALKOT	110	CHIKKODI220-KDLKT	KADAKLAT_110	12:18	12:45	0:27	LINE CLEAR AVAILED
720	11-Mar-2022	BAGALKOT	110	KDLKT-NIPPANI	KADAKLAT_110	12:18	12:49	0:31	LINE CLEAR AVAILED
721	11-Mar-2022	BAGALKOT	110	110/11KV,HV2	KADAKLAT_110	13:18	14:13	0:55	HAND TRIPPED
722	11-Mar-2022	BAGALKOT	110	110/11KV,HV2	KADAKLAT_110	15:07	15:11	0:04	HAND TRIPPED
723	11-Mar-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YALLAMANAWADI_110	4:38	4:40	0:02	TRANSFORMER FAULT
724	11-Mar-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJJRAMATTI_110	12:32	12:55	0:23	TRANSFORMER FAULT
725	11-Mar-2022	BAGALKOT	110	SULTANPUR- MAHALINGPUR220	SULTANPUR_110	11:59	12:18	0:19	LINE CLEAR AVAILED
726	11-Mar-2022	BAGALKOT	110	SHIGGAON-SAVANUR	SHIGGAON_110	6:12	6:30	0:18	LINE FAULT
727	11-Mar-2022	BAGALKOT	110	SHIGGAON-AVANTI SOLAR	AVANTI SOLAR_110 STATIO NOT AFFECTED SHIGGAON_110	6:12	7:10	0:58	LINE FAULT
728	11-Mar-2022	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	6:12	6:20	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
729	11-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SAVALAGI_110	10:02	13:59	3:57	LINE CLEAR AVOIDED
730	11-Mar-2022	BAGALKOT	110	SAMBAPUR ROAD-RVNL RAILWAY	RVNL RAILWAY_110 STATION NOT AFFECTED SAMBAPUR ROAD_110	16:38	16:54	0:16	LINE FAULT
731	11-Mar-2022	BAGALKOT	110	110/11KV ,HV2	STATION NOT AFFECTED RON_110	10:25	13:57	3:32	HAND TRIPPED
732	11-Mar-2022	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RAIBAG_110	16:43	16:56	0:13	TRANSFORMER FAULT
733	11-Mar-2022	BAGALKOT	110	NARAGUND-BPCL	BPCL_110 STATION NOT AFFECTED NARAGUND_110	2:13	2:34	0:21	LINE FAULT
734	11-Mar-2022	BAGALKOT	110	NARAGUND-BPCL	BPCL_110 STATION NOT AFFECTED NARAGUND_110	2:34	2:49	0:15	LINE FAULT
735	11-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAREGAL_110	14:20	14:31	0:11	TRANSFORMER FAULT
736	11-Mar-2022	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	13:42	22:27	8:45	HAND TRIPPED
737	11-Mar-2022	BAGALKOT	220	BAGEWADI -ADPH2	STATION NOT AFFECTED BAGEWADI_220	10:16	13:30	3:14	LINE CLEAR AVOIDED
738	11-Mar-2022	BAGALKOT	220	BIJAPUR-INDI2	STATION NOT AFFECTED BIJAPUR_220	10:27	17:30	7:03	LINE CLEAR AVOIDED
739	11-Mar-2022	BAGALKOT	110	KUDUCHI-TERDAL(MORAB)	STATION NOT AFFECTED MORAB_110	9:41	15:29	5:48	LINE CLEAR AVOIDED
740	11-Mar-2022	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	1:04	1:14	0:10	LINE FAULT
741	11-Mar-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
742	11-Mar-2022	BAGALKOT	110	LAKAMANAHALLI- NAVANAGAR(H)	STATION NOT AFFECTED NAVANAGAR(H)_110	10:26 (10.03.2022)	8:25 (11.03.2022)	21:59HRS	LINE CHARGED
743	11-Mar-2022	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTED HUBLI_220	14:58 (10.03.2022)	18:15 (11.03.2022)	3:17HRS	TRANSFORMER CHARGED
744	11-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
745	11-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM1	CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
746	11-Mar-2022	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	18:16	22:54	4:38	HAND TRIPPED
747	11-Mar-2022	BAGALKOT	220	VAJRAMATTI- ENERCON	VAJRAMATTI_220	7:40	22:45	19:55	LINE FAULT
748	11-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	10:57	17:11	6:14	LINE CLEAR AVOIDED
749	11-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	6:13	6:42	0:29	LINE FAULT
750	11-Mar-2022	BAGALKOT	220	INDI- BIJAPUR2	INDI_220	9:28	17:43	8:15	HAND TRIPPED
751	11-Mar-2022	BAGALKOT	110	MKHUBLI220- BAILHONGAL	BAILHONGAL_110	13:05	13:31	0:26	LINE FAULT
752	11-Mar-2022	BENGALURU	66	HV3	ELECTRONIC CITY	3:50	4:15	0:25	TRANSFORMER FAULT
753	11-Mar-2022	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	11:50	12:08	0:18	MAIN SUPPLY FAILURE
754	11-Mar-2022	BENGALURU	66	SHOBHA CITY - HENNUR CROSS	SHOBHA CITY	13:56	14:01	0:05	LOAD CHANGE OVER
755	11-Mar-2022	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	11:50	13:43	1:53	LINE FAULT
756	11-Mar-2022	BENGALURU	220	HV2	HOODY 220	11:50	13:02	1:12	TRANSFORMER FAULT
757	11-Mar-2022	BENGALURU	220	HV4	HOODY 220	11:50	12:54	1:04	TRANSFORMER FAULT
758	11-Mar-2022	BENGALURU	220	HV3	HOODY 220	11:50	15:06	3:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
759	11-Mar-2022	BENGALURU	66	HV1	HOODY 220	11:50	13:07	1:17	HAND TRIPPED
760	11-Mar-2022	BENGALURU	220	HOODY 220 - HOODY 400	HOODY 220	11:50	12:58	1:08	LINE FAULT
761	11-Mar-2022	BENGALURU	220	HOODY 220 - ITI 220	ITI 220	11:50	13:05	1:15	HAND TRIPPED
762	11-Mar-2022	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	11:50	12:58	1:08	HAND TRIPPED
763	11-Mar-2022	BENGALURU	220	HOODY 220 - RAILWAYS 1 (EHT)	RAILWAYS 1 (EHT)	11:50	13:48	1:58	HAND TRIPPED
764	11-Mar-2022	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	11:50	13:37	1:47	HAND TRIPPED
765	11-Mar-2022	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	11:50	13:36	1:46	HAND TRIPPED
766	11-Mar-2022	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	11:50	13:30	1:40	HAND TRIPPED
767	11-Mar-2022	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK	11:50	13:53	2:03	HAND TRIPPED
768	11-Mar-2022	BENGALURU	66	HOODY 220 - HAL 2	NO STATION AFFECTED	11:50	13:54	2:04	HAND TRIPPED
769	11-Mar-2022	BENGALURU	66	HOODY 220 - BMRCL (EHT)	BMRCL (EHT)	11:50	12:57	1:07	HAND TRIPPED
770	11-Mar-2022	BENGALURU	66	HOODY 220 - HP (EHT)	HP (EHT)	11:50	13:35	1:45	HAND TRIPPED
771	11-Mar-2022	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:50	13:55	2:05	HAND TRIPPED
772	11-Mar-2022	BENGALURU	66	IISc - HEBBALA 220	IISc	12:51	12:56	0:05	LOAD CHANGE OVER
773	11-Mar-2022	BENGALURU	66	IISc - NRS 220	IISc	14:08	14:23	0:15	LOAD CHANGE OVER
774	11-Mar-2022	BENGALURU	220	ITI 220 - HOODY 220	ITI 220	11:50	13:35	1:45	MAIN SUPPLY FAILURE
775	11-Mar-2022	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	11:50	13:35	1:45	MAIN SUPPLY FAILURE
776	11-Mar-2022	BENGALURU	66	ITI 220 - ITI 66	ITI 66	11:50	13:35	1:45	MAIN SUPPLY FAILURE
777	11-Mar-2022	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	11:50	12:05	0:15	MAIN SUPPLY FAILURE
778	11-Mar-2022	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	13:43	13:45	0:02	LOAD CHANGE OVER
779	11-Mar-2022	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	11:50	14:23	2:33	MAIN SUPPLY FAILURE
780	11-Mar-2022	BENGALURU	66	HV2	BANASAWADI	11:50	12:37	0:47	MAIN SUPPLY FAILURE
781	11-Mar-2022	BENGALURU	66	HV2	BANASAWADI	13:44	13:47	0:03	LOAD CHANGE OVER
782	11-Mar-2022	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	6:47	6:52	0:05	LOAD CHANGE OVER
783	11-Mar-2022	BENGALURU	66	HV3	MANYATHA TECH PARK 220	11:50	12:08	0:18	MAIN SUPPLY FAILURE
784	11-Mar-2022	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	16:00	18:20	2:20	LINE FAULT
785	11-Mar-2022	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	6:53	7:01	0:08	LOAD CHANGE OVER
786	11-Mar-2022	BENGALURU	220	HV1	VIKAS TECH PARK 220	8:40	9:00	0:20	TRANSFORMER FAULT
787	11-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	8:40	9:00	0:20	HAND TRIPPED
788	11-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	8:40	9:00	0:20	HAND TRIPPED
789	11-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	8:40	9:15	0:35	HAND TRIPPED
790	11-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	8:40	9:02	0:22	HAND TRIPPED
791	11-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	8:40	9:02	0:22	HAND TRIPPED
792	11-Mar-2022	BENGALURU	66	AGALKOTE - KEMPANAHALLI	AGALKOTE, MATHIKERE(NEL)	6:35	7:00	0:25	LINE FAULT
793	11-Mar-2022	BENGALURU	66	HV1	AVANI	11:40	11:45	0:05	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
794	11-Mar-2022	BENGALURU	220	BEGUR 220 - HOODY 220	HOODY 220	11:50	13:44	1:54	LINE FAULT
795	11-Mar-2022	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	12:54	17:51	4:57	LOAD CURTAILMENT
796	11-Mar-2022	BENGALURU	66	HV1	HUKUNDA	21:05	21:13	0:08	TRANSFORMER FAULT
797	11-Mar-2022	BENGALURU	66	HV1	KGF	17:39	17:47	0:07	LINE CLEAR AVAILED
798	11-Mar-2022	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	22:49	22:59	0:10	LOAD CHANGE OVER
799	11-Mar-2022	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	KEMPANAHALLI, AGALKOTE, MATHIKERE (NEL)	15:20	15:25	0:05	MAIN SUPPLY FAILURE
800	11-Mar-2022	BENGALURU	66	LAKSMIPURA - ADDGAL	ADDAGAL	13:06	13:22	0:16	LINE FAULT
801	11-Mar-2022	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:13	6:19	0:06	LINE FAULT
802	11-Mar-2022	BENGALURU	66	HV2	THIMMAMPALLI	11:27	12:19	0:52	LINE CLEAR AVAILED
803	11-Mar-2022	BENGALURU	66	HV2	THAYALUR	12:31	13:04	0:32	LINE CLEAR AVAILED
804	11-Mar-2022	BENGALURU	66	HV2	THAYALUR	14:29	15:18	0:49	LINE CLEAR AVAILED
805	11-Mar-2022	BENGALURU	66	HV2	VOLVO	15:16	15:45	0:28	LINE CLEAR AVAILED
806	11-Mar-2022	BENGALURU	66	HV1	THYAMAGONDLU	14:24	14:30	0:06	LINE CLEAR AVAILED
807	11-Mar-2022	BENGALURU	66	HV2	THYAMAGONDLU	14:30	14:35	0:05	TRANSFORMER FAULT
808	11-Mar-2022	BENGALURU	66	HV2	MAASTHI	19:23	20:00	0:37	TRANSFORMER FAULT
809	11-Mar-2022	BENGALURU	66	HV2	MAASTHI	8:18	8:23	0:05	TRANSFORMER FAULT
810	11-Mar-2022	BENGALURU	66	KONDASPURA - HBR LAYOUT 66	KONDASPURA	13:40	13:45	0:05	LOAD CHANGE OVER
811	11-Mar-2022	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	14:20	14:30	0:10	LOAD CHANGE OVER
812	11-Mar-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	14:00	14:15	0:15	LINE CLEAR AVAILED
813	11-Mar-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	16:12	16:34	0:22	LINE CLEAR AVAILED
814	11-Mar-2022	BENGALURU	66	T GOLAHALLI 220 - KYASAMBALLI	NO STATION AFFECTED	18:01(10-03-2022)			LINE OPEN,LINE FAULT
815	11-Mar-2022	GULBARGA	400	DONI-GD HALLI	DONI_400	11:16	18:44	7:28	LINE CLEAR AVAILED
816	11-Mar-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
817	11-Mar-2022	GULBARGA	220	HV1,HV2	ALIPUR_220	11:02	11:20	0:18	TRANSFORMER FAULT
818	11-Mar-2022	GULBARGA	220	HV1,HV2	ALIPUR_220	11:47	11:56	0:09	TRANSFORMER FAULT
819	11-Mar-2022	GULBARGA	220	HV1,HV2	ALIPUR_220	12:21	12:35	0:14	TRANSFORMER FAULT
820	11-Mar-2022	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	9:48	12:34	2:46	LINE CLEAR AVAILED
821	11-Mar-2022	GULBARGA	220	KUSTAGI-OSTRO WIND_IPP	KUSTAGI_220	9:00	19:56	10:56	LINE CLEAR AVAILED
822	11-Mar-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
823	11-Mar-2022	GULBARGA	110	HV2	HATTI_110	8:54	8:57	0:03	TRANSFORMER FAULT
824	11-Mar-2022	GULBARGA	110	HV1	GHATTARGA_110	10:16	10:22	0:06	TRANSFORMER FAULT
825	11-Mar-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	2:46	2:52	0:06	LINE FAULT
826	11-Mar-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	2:46	2:52	0:06	LINE FAULT
827	11-Mar-2022	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	1:00	1:06	0:06	MAIN SUPPLY FAILURE
828	11-Mar-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110, KADAGANCHI_110	21:02 (10/03/2022)	10:10 (11/03/2022)	13:08HRS	LINE CHARGED
829	11-Mar-2022	GULBARGA	110	PDHALLI-CLEAN MAX SOLAR	PD_HALLI_110	10:58	11:25	0:27	LINE FAULT
830	11-Mar-2022	GULBARGA	110	PDHALLI-CLEAN MAX SOLAR	PD_HALLI_110	11:44	12:06	0:22	LINE FAULT
831	11-Mar-2022	GULBARGA	110	PDHALLI-CLEAN MAX SOLAR	PD_HALLI_110	12:16	12:24	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
832	11-Mar-2022	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	22:34	23:00	0:26	LINE FAULT
833	11-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	2:15	2:25	0:10	LINE FAULT
834	11-Mar-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:30	4:38	0:08	LINE FAULT
835	11-Mar-2022	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	5:05	5:16	0:11	LINE FAULT
836	11-Mar-2022	GULBARGA	110	ALIPUR-BELLARAY NORTH	SOMASAMUDRA_110,BELLAR Y NORTH_110,MOKA, PD HALLI_110,BISIHALLI_110,JAN AKI_IPP, BASAI STEELS ACC_IPP	1:01	1:07	0:06	LINE FAULT
837	11-Mar-2022	GULBARGA	110	ALIPUR-BELLARAY NORTH	SOMASAMUDRA_110,BELLAR Y NORTH_110,MOKA, PD HALLI_110,BISIHALLI_110,JAN AKI_IPP, BASAI STEELS ACC_IPP	22:02	22:17	0:15	LINE FAULT
838	11-Mar-2022	GULBARGA	66	HV1	ITTAGI_220	20:32 (11.03.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
839	11-Mar-2022	GULBARGA	66	HV1	ITTAGI_220	15:10 (5.03.2022)	20:28 (11.03.2022)	149:18 HRS	TRANSFORMER CHARGED
840	11-Mar-2022	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPUR _66,MANGALA_66,SOVENHAL LI_66, TUNGA BHADRA_IPP	18:21	18:37	0:16	LINE FAULT
841	11-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
842	11-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
843	11-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
844	11-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
845	11-Mar-2022	HASSAN	110	LPH-MGHE 1	plph_gen	14:35(09.03.2022)	11:59(11.03.2022)	45:64HRS	LINE CHARGED
846	11-Mar-2022	HASSAN	110	JOG-JLT4	mghejog_gen	14:35(09.03.2022)	14:45(11.03.2022)	48:10HRS	LINE CHARGED
847	11-Mar-2022	HASSAN	110	JOG110-LPH	JOG_110	14:35(09.03.2022)	11:46(11.03.2022)	45:11HRS	LINE CHARGED
848	11-Mar-2022	HASSAN	110	HV2	BAIKAMPADY_110	17:29(11.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
849	11-Mar-2022	HASSAN	110	SORABA-MAVALLI	SORABA_110	18:02(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
850	11-Mar-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
851	11-Mar-2022	HASSAN	220	MRSSH-VARAH13	MRS MG_220	10:25	15:31	5:06	LINE CLEAR AVAILED
852	11-Mar-2022	HASSAN	66	MRSSH-VARAH13	MRS MG_220	9:23	9:26	0:03	LINE FAULT
853	11-Mar-2022	HASSAN	66	MRSSH-VARAH13	MRS MG_220	12:10	12:19	0:09	LINE FAULT
854	11-Mar-2022	HASSAN	66	MRSSH-VARAH13	MRS MG_220	12:30	12:37	0:07	LINE FAULT
855	11-Mar-2022	HASSAN	220	HV2	MSEZ_220	11:53	13:15	1:22	LINE CLEAR AVAILED
856	11-Mar-2022	HASSAN	110	LV2	MSEZ_220	11:52	13:16	1:24	LINE CLEAR AVAILED
857	11-Mar-2022	HASSAN	220	SHRAVITY-TALGUPPA3	sharavathy_gen	11:18	17:03	5:45	LINE CLEAR AVAILED
858	11-Mar-2022	HASSAN	220	TALAGU-SGS3	TALAGUPPA_400	11:17	17:01	5:44	LINE CLEAR AVAILED
859	11-Mar-2022	HASSAN	220	VARAH1-KEMAR1	varahi_gen	10:19	13:29	3:10	NFBC ISSUED
860	11-Mar-2022	HASSAN	220	VARAH1-SHMG3	varahi_gen	10:25	15:09	4:44	NFBC ISSUED
861	11-Mar-2022	HASSAN	220	KEMAR-VARAH11	KEMAR_220	10:18	13:24	3:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
862	11-Mar-2022	HASSAN	110	HV2	ANANDURA_110	7:21	7:56	0:35	TRANSFORMER FAULT
863	11-Mar-2022	HASSAN	110	HV2	ANANDURA_110	22:23	22:53	0:30	TRANSFORMER FAULT
864	11-Mar-2022	HASSAN	110	HV1	BAIKAMPADY_110	11:48	13:54	2:06	LINE CLEAR AVAILED
865	11-Mar-2022	HASSAN	110	HV2	BAIKAMPADY_110	13:56	15:39	1:43	LINE CLEAR AVAILED
866	11-Mar-2022	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:07	19:27	9:20	LINE CLEAR AVAILED
867	11-Mar-2022	HASSAN	110	JOG-JLT3	mghejog_gen	17:03	18:17	1:14	LINE FAULT
868	11-Mar-2022	HASSAN	110	JOG-JLT3	mghejog_gen	18:18	18:37	0:19	LINE FAULT
869	11-Mar-2022	HASSAN	110	JOG-JLT3	mghejog_gen	18:44	20:09	1:25	LINE FAULT
870	11-Mar-2022	HASSAN	110	JOG110-MGHE	JOG_110	19:04	19:58	0:54	LINE CLEAR AVAILED
871	11-Mar-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:16	9:54	0:38	HAND TRIPPED
872	11-Mar-2022	HASSAN	110	HV3	PUTTUR_110	16:13	16:42	0:29	LINE CLEAR AVAILED
873	11-Mar-2022	HASSAN	110	HV4	PUTTUR_110	16:13	16:42	0:29	LINE CLEAR AVAILED
874	11-Mar-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:31	12:57	1:26	LINE CLEAR AVAILED
875	11-Mar-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:32	12:57	1:25	LINE CLEAR AVAILED
876	11-Mar-2022	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_66	11:28	12:58	1:30	NFBC ISSUED
877	11-Mar-2022	HASSAN	66	HV1	HANBALU_66	11:02	12:56	1:54	NFBC ISSUED
878	11-Mar-2022	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	11:02	12:56	1:54	NFBC ISSUED
879	11-Mar-2022	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	11:21	12:55	1:34	LINE CLEAR AVAILED
880	11-Mar-2022	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:17	18:33	8:16	LINE CLEAR AVAILED
881	11-Mar-2022	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:17	18:33	8:16	LINE CLEAR AVAILED
882	11-Mar-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHTANAHALLY_66	9:25	9:35	0:10	MAIN SUPPLY FAILURE
883	11-Mar-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHTANAHALLY_66	12:15	12:25	0:10	MAIN SUPPLY FAILURE
884	11-Mar-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHTANAHALLY_66	12:35	12:45	0:10	MAIN SUPPLY FAILURE
885	11-Mar-2022	MYSURU	66	HV2	HONNALY_MYS_66	16:02	17:22	1:20	LINE CLEAR AVAILED
886	11-Mar-2022	MYSURU	66	HUNSUR-HANGODU	HUNSUR_66 BANNIKUPPE_66, HOSURGATE_66	10:30	18:02	7:32	LINE CLEAR AVAILED
887	11-Mar-2022	MYSURU	66	HUNSUR-BANNIKUPPE	HUNSUR_66 BANNIKUPPE_66, HOSURGATE_66	10:30	17:43	7:13	LINE CLEAR AVAILED
888	11-Mar-2022	MYSURU	66	HUNSUR-ELAVALA	HUNSUR_66 BANNIKUPPE_66, HOSURGATE_66	10:30	17:43	7:13	LINE CLEAR AVAILED
889	11-Mar-2022	MYSURU	66	KABHALLY-ATRIA SOLAR	KABHALLY_66	5:59	7:20	1:20	LINE CLEAR AVAILED
890	11-Mar-2022	MYSURU	66	KABHALLY-CHAMARAJNAGAR	KABHALLY_66	6:00	7:20	1:19	LINE CLEAR AVAILED
891	11-Mar-2022	MYSURU	66	KABHALLY-CLEAN SOLAR	KABHALLY_66	5:59	7:20	1:20	LINE CLEAR AVAILED
892	11-Mar-2022	MYSURU	66	KABHALLY-GUNDLUPETE	KABHALLY_66	6:00	7:19	1:19	LINE CLEAR AVAILED
893	11-Mar-2022	MYSURU	220	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	10:38	16:48	6:10	LINE CLEAR AVAILED
894	11-Mar-2022	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	11:22	14:20	2:58	LINE CLEAR AVAILED
895	11-Mar-2022	MYSURU	66	KADAKOLA-NANJANGUDU	NANJANGUDU_66	11:13	11:28	0:15	LINE FAULT
896	11-Mar-2022	MYSURU	220	HV1	KADAKOLA_220	16:58	18:57	1:59	LINE CLEAR AVAILED
897	11-Mar-2022	MYSURU	66	K HONALAGERE-IGGALUR	K_HONNALGERE_66	11:52	12:16	0:24	MAIN SUPPLY FAILURE
898	11-Mar-2022	MYSURU	66	K HONALAGERE-MADDUR	K_HONNALGERE_66	11:50	12:43	0:53	MAIN SUPPLY FAILURE
899	11-Mar-2022	MYSURU	66	HV2	KIKKERI_66	23:05	23:40	0:34	LINE CLEAR AVAILED
900	11-Mar-2022	MYSURU	66	HV2	KMDODDI_66	19:18:18 (11/03/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
901	11-Mar-2022	MYSURU	66	MADHUVANAHALLI 220KV- MAMBALLI	NO STATIONS EFFECTED	10:10	10:16	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
902	11-Mar-2022	MYSURU	66	PANDAVAPURA-CHINAKURLI	BANANGADI_66	8:00	10:13	2:13	LINE CLEAR AVAILED
903	11-Mar-2022	MYSURU	66	HV1	SRIRANGAPATNA_66	10:38	11:26	0:48	LINE CLEAR AVAILED
904	11-Mar-2022	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	16:56	19:00	2:04	HAND TRIPPED
905	11-Mar-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
906	11-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
907	11-Mar-2022	TUMKUR	400	GUTTUR 400KV- KAIGA 2	GUTUR_400	10:40	17:56	7:16	LINE CLEAR AVAILED
908	11-Mar-2022	TUMKUR	220	GUTTUR 400KV- KAIGA 2	GUTUR_400	11:20	15:30	4:10	LINE CLEAR AVAILED
909	11-Mar-2022	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	6:41	6:51	0:10	TRANSFORMER FAULT
910	11-Mar-2022	TUMKUR	220	TR-2(HV SIDE)	KIADB V N PURA_220	10:29	14:55	4:26	LINE CLEAR AVAILED
911	11-Mar-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110,KATRIKEHAL 110	15:20	15:30	0:09	LINE FAULT
912	11-Mar-2022	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110	6:48	6:52	0:04	HAND TRIPPED
913	11-Mar-2022	TUMKUR	110	KB CROSS 220kv- AMMASANDRA_66	AMMASANDRA_110,SAMPIGE _110	6:47	6:48	0:01	HAND TRIPPED
914	11-Mar-2022	TUMKUR	110	TR-2	SHEITYKERE_110	16:14	16:55	0:40	LINE CLEAR AVAILED
915	11-Mar-2022	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,YEDAV ANI_66	10:53	11:01	0:08	HAND TRIPPED
916	11-Mar-2022	TUMKUR	66	TR-1	BUKKAPATNA_66	11:03	15:47	4:43	LINE CLEAR AVAILED
917	11-Mar-2022	TUMKUR	66	TR-2	BUKKAPATNA_66	16:06	16:37	0:31	LINE CLEAR AVAILED
918	11-Mar-2022	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	15:05	15:42	0:36	HAND TRIPPED
919	11-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:15	4:24	0:08	LINE FAULT
920	11-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:04	15:42	0:38	LINE FAULT
921	11-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:45	9:55	0:10	LINE FAULT
922	11-Mar-2022	TUMKUR	66	TR-2	HARIYABBE_66	10:04	10:52	0:47	TRANSFORMER FAULT
923	11-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:13	12:23	0:10	LINE FAULT
924	12-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
925	12-Mar-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
926	12-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
927	12-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
928	12-Mar-2022	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
929	12-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
930	12-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
931	12-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
932	12-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY2	STATION NOT AFFECTED SIRSI_220	22:53 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
933	12-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY1	STATION NOT AFFECTED SIRSI_220	22:53 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
934	12-Mar-2022	BAGALKOT	400	DHONI- GUTTUR	STATION NOT AFFECTED DHONI_400	9:53	15:03	5:10	LINE CLEAR AVAILED
935	12-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	10:00	15:53	5:52	LINE CLEAR AVAILED
936	12-Mar-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
937	12-Mar-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:00	15:53	5:52	LINE CLEAR AVAILED
938	12-Mar-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:00	15:53	5:52	LINE CLEAR AVAILED
939	12-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	10:01	15:53	5:52	LINE CLEAR AVAILED
940	12-Mar-2022	BAGALKOT	110	CNDKT-F2 (O/G ALMEL )	CHANDKAVATE_110,ALMEL_1 12	1:31	1:35	0:04	LINE FAULT
941	12-Mar-2022	BAGALKOT	110	110/33KV,HV3	GAJENDRGAD_110	9:00	9:12	0:12	TRANSFORMER FAULT
942	12-Mar-2022	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33, MAITRA IPP	11:05	11:42	0:37	HAND TRIPPED
943	12-Mar-2022	BAGALKOT	110	HUDALI-ANKALAGI	HUDALI_110	19:26 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
944	12-Mar-2022	BAGALKOT	110	ISMPR-F1(ANKALAGI)	ISLAMAPUR_110	17:40 (10.03.2022)	9:59 (12.03.2022)	40:19HRS	LINE CHARGED
945	12-Mar-2022	BAGALKOT	110	110/11KV,HV1	ISLAMAPUR_110	19:27	20:42	1:15	TRANSFORMER FAULT
946	12-Mar-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YALLAMANAWADI_110	15:17	15:22	0:05	TRANSFORMER FAULT
947	12-Mar-2022	BAGALKOT	110	110/11KV, HV2 (HV3)	STATION NOT AFFECTED TIKOTA_110	13:55	14:05	0:10	LINE CLEAR AVAILED
948	12-Mar-2022	BAGALKOT	110	110/11KV, HV1 (HV2)	STATION NOT AFFECTED TIKOTA_110	13:55	14:05	0:10	LINE CLEAR AVAILED
949	12-Mar-2022	BAGALKOT	220	KUDUCHI-ATHANI	STATION NOT AFFECTED KUDUCHI_220	10:10	20:20	10:10	LINE CLEAR AVAILED
950	12-Mar-2022	BAGALKOT	110	KUDUCHI-TERDAL(MORAB)	STATION NOT AFFECTED MORAB_110	5:57	6:12	0:15	LINE CLEAR AVAILED
951	12-Mar-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
952	12-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
953	12-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM1	CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
954	12-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	10:00	15:53	5:52	LINE CLEAR AVAILED
955	12-Mar-2022	BAGALKOT	110	ANKOL-KUMTA(L2)	ANKOLA_110	9:32	9:34	0:02	HAND TRIPPED
956	12-Mar-2022	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	12:00	12:05	0:05	TRANSFORMER FAULT
957	12-Mar-2022	BAGALKOT	110	110/11KV, HV1	LAKAMANAHALLI_110	20:40	21:08	0:28	TRANSFORMER FAULT
958	12-Mar-2022	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	10:14 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
959	12-Mar-2022	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	10:01	15:53	5:52	LINE CLEAR AVAILED
960	12-Mar-2022	BAGALKOT	220	ATHANI- KUDACHI	ATHANI_220	10:15	20:20	10:05	NFBC ISSUED
961	12-Mar-2022	BENGALURU	66	ADUGODI - HSR LAYOUT 2 220	ADUGODI	18:16	19:02	0:46	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
962	12-Mar-2022	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	14:24	14:28	0:04	LOAD CHANGE OVER
963	12-Mar-2022	BENGALURU	66	HV2	BMTCT	22:25	22:30	0:05	TRANSFORMER FAULT
964	12-Mar-2022	BENGALURU	66	HV1	ELECTRONIC CITY	2:14	4:09	1:55	LINE CLEAR AVAILED
965	12-Mar-2022	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	16:20	16:40	0:20	LOAD CHANGE OVER
966	12-Mar-2022	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	17:35	17:40	0:05	LOAD CHANGE OVER
967	12-Mar-2022	BENGALURU	66	HSR LAYOUT 220 - ADUGODI	ADUGODI	18:16	19:02	0:46	LINE FAULT
968	12-Mar-2022	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	6:58	7:25	0:27	MAIN SUPPLY FAILURE
969	12-Mar-2022	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	14:22	14:27	0:05	LOAD CHANGE OVER
970	12-Mar-2022	BENGALURU	66	HV2	REMCOT	6:57	7:27	0:30	MAIN SUPPLY FAILURE
971	12-Mar-2022	BENGALURU	66	HV2	REMCOT	14:20	14:28	0:08	LOAD CHANGE OVER
972	12-Mar-2022	BENGALURU	66	HV2	ST.JOHNS WOOD	0:01	0:07	0:06	TRANSFORMER FAULT
973	12-Mar-2022	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	RR NAGAR, GLOBAL VILLAGE (EHT)	6:58	7:25	0:27	LINE FAULT
974	12-Mar-2022	BENGALURU	220	LV2	BIDADI 220	11:05	11:29	0:24	TRANSFORMER FAULT
975	12-Mar-2022	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	11:05	11:29	0:24	LINE FAULT
976	12-Mar-2022	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	11:05	11:29	0:24	HAND TRIPPED
977	12-Mar-2022	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	21:14	21:58	0:44	LINE FAULT
978	12-Mar-2022	BENGALURU	66	HV2	BIDADI 220	11:05	11:32	0:27	HAND TRIPPED
979	12-Mar-2022	BENGALURU	66	HV3	BIDADI 220	11:05	11:32	0:27	HAND TRIPPED
980	12-Mar-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	17:38	17:53	0:15	LINE FAULT
981	12-Mar-2022	BENGALURU	66	HV1	DALASNUR	13:00	14:35	1:35	LINE CLEAR AVAILED
982	12-Mar-2022	BENGALURU	66	HV1	DALASNUR	17:34	18:24	0:49	LINE CLEAR AVAILED
983	12-Mar-2022	BENGALURU	66	HV1	GODUR	10:10	12:00	1:50	LINE CLEAR AVAILED
984	12-Mar-2022	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	6:34	9:04	2:30	LINE FAULT
985	12-Mar-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	23:16	23:31	0:15	LINE FAULT
986	12-Mar-2022	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	9:40	9:43	0:03	LOAD CHANGE OVER
987	12-Mar-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	6:52	7:02	0:10	LINE FAULT
988	12-Mar-2022	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	KEMPANAHALLI, AGALKOTE, MATHIKERE (NEL)	15:30	15:35	0:05	MAIN SUPPLY FAILURE
989	12-Mar-2022	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	5:46	5:56	0:10	LINE FAULT
990	12-Mar-2022	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU, HANUMANTHNAGAR	16:15	17:00	0:45	LINE FAULT
991	12-Mar-2022	BENGALURU	66	HV1	MULBAGLU	14:28	14:47	0:18	TRANSFORMER FAULT
992	12-Mar-2022	BENGALURU	66	HV2	MAASTHI	7:09	7:15	0:05	TRANSFORMER FAULT
993	12-Mar-2022	BENGALURU	66	HBR LAYOUT 66 - DG3	KONDASPURA	11:35	11:50	0:15	LINE FAULT
994	12-Mar-2022	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	15:05	15:10	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
995	12-Mar-2022	BENGALURU	66	T GOLAHALLI 220 - KYASAMBALLI	NO STATION AFFECTED	18:01(10-03-2022)			LINE OPEN,LINE FAULT
996	12-Mar-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
997	12-Mar-2022	GULBARGA	220	KUDLIGI-HIREMALLANHALLI2	HIREMALLANHALLI_220	13:50	15:10	1:20	NFBC ISSUED
998	12-Mar-2022	GULBARGA	110	HV1	GHATTARGA_110	12:23	12:30	0:07	TRANSFORMER FAULT
999	12-Mar-2022	GULBARGA	110	HV2	GULBARGA SOUTH_110	11:20	11:25	0:05	TRANSFORMER FAULT
1000	12-Mar-2022	GULBARGA	110	HV2	GULBARGA SOUTH_110	11:30	12:25	0:55	TRANSFORMER FAULT
1001	12-Mar-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1002	12-Mar-2022	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	22:20	22:30	0:10	LINE FAULT
1003	12-Mar-2022	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	6:17	6:22	0:05	LINE FAULT
1004	12-Mar-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA N_110,DIGGI_110	12:53	12:58	0:05	LINE FAULT
1005	12-Mar-2022	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	11:12	11:32	0:20	LOAD CURTAILMENT
1006	12-Mar-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	16:14	16:20	0:06	LINE FAULT
1007	12-Mar-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:16	5:20	0:04	LINE FAULT
1008	12-Mar-2022	GULBARGA	66	HV1	ITTAGI_220	20:32 (11.03.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1009	12-Mar-2022	GULBARGA	66	HV2	TAMBRAHALLI_66	7:10	7:15	0:05	TRANSFORMER FAULT
1010	12-Mar-2022	GULBARGA	66	HV2	TAMBRAHALLI_66	9:45	9:55	0:10	TRANSFORMER FAULT
1011	12-Mar-2022	GULBARGA	66	HV2	HALVAGALU_66	14:55	15:00	0:05	TRANSFORMER FAULT
1012	12-Mar-2022	GULBARGA	66	HV2	HALVAGALU_66	16:55	17:00	0:05	TRANSFORMER FAULT
1013	12-Mar-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	10:55	11:05	0:10	LINE FAULT
1014	12-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1015	12-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1016	12-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1017	12-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1018	12-Mar-2022	HASSAN	110	SORABA-MAVALLI	SORABA_110	18:02(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1019	12-Mar-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1020	12-Mar-2022	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	6:06((12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1021	12-Mar-2022	HASSAN	220	KADUR-DABUSET	KADUR_220	5:46((12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1022	12-Mar-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	6:23(12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1023	12-Mar-2022	HASSAN	110	HV2	BAIKAMPADY_110	17:29(11.03.2022)	13:00 (12.03.2022)	19:31HRS	TRANSFORMER CHARGED
1024	12-Mar-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	22:01	22:12	0:11	LINE FAULT
1025	12-Mar-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	3:08	3:18	0:10	LINE FAULT
1026	12-Mar-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	12:43	12:48	0:05	LINE FAULT
1027	12-Mar-2022	HASSAN	220	SHRAVITY-ST3	gen_sharavathy	22:49	23:23	0:34	LINE FAULT
1028	12-Mar-2022	HASSAN	110	JOG-JLT4	JOG_110	10:05	16:25	6:20	LINE CLEAR AVAILED
1029	12-Mar-2022	HASSAN	110	HV1	KALLUSADARAHALLI_110	10:08	16:47	6:39	LINE CLEAR AVAILED
1030	12-Mar-2022	HASSAN	110	LPH-MGHE 2	gen_lph	10:05	16:25	6:20	LINE CLEAR AVAILED
1031	12-Mar-2022	HASSAN	66	HV1	MALLAPURA_66	16:50	18:58	2:08	MAIN SUPPLY FAILURE
1032	12-Mar-2022	HASSAN	66	HV2	MALLAPURA_66	16:50	18:58	2:08	MAIN SUPPLY FAILURE
1033	12-Mar-2022	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	16:50	18:43	1:53	MAIN SUPPLY FAILURE
1034	12-Mar-2022	HASSAN	66	HV2	CHIKKAMAGLRE_6	9:54	10:44	0:50	LINE CLEAR AVAILED
1035	12-Mar-2022	HASSAN	66	HV2	CHIKKAMAGLRE_6	11:10	11:15	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1036	12-Mar-2022	HASSAN	66	HV1	HANUBAL_66	18:15	18:35	0:20	MAIN SUPPLY FAILURE
1037	12-Mar-2022	HASSAN	66	HV1	MATTANAVILE_66	15:07	17:20	2:13	LINE CLEAR AVAILED
1038	12-Mar-2022	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	18:15	18:35	0:20	LINE FAULT
1039	12-Mar-2022	HASSAN	66	HV1	SAKALESH PURA_66	18:40	18:45	0:05	TRANSFORMER FAULT
1040	12-Mar-2022	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	10:44	17:56	7:12	LINE CLEAR AVAILED
1041	12-Mar-2022	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	10:44	17:56	7:12	LINE CLEAR AVAILED
1042	12-Mar-2022	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	23:21	23:59	0:38	LINE FAULT
1043	12-Mar-2022	MYSURU	66	HV2	ARAKERE_66	12:03	12:07	0:03	TRANSFORMER FAULT
1044	12-Mar-2022	MYSURU	66	HV2	BILIKERE_66	9:51	10:06	0:15	TRANSFORMER FAULT
1045	12-Mar-2022	MYSURU	66	DEVANUR(NANJ)-KADAKOLA	NO STATIONS EFFECTED	11:03	12:32	1:29	LINE CLEAR AVAILED
1046	12-Mar-2022	MYSURU	66	HAMPAPURA-CHICKMANDYA	HAMPAPURA_66	8:36	8:38	0:01	LINE FAULT
1047	12-Mar-2022	MYSURU	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	8:36	8:38	0:01	LINE FAULT
1048	12-Mar-2022	MYSURU	66	HOSUR GATE-HUNSUR	HOSUR GATE_66	4:05	4:15	0:10	LINE FAULT
1049	12-Mar-2022	MYSURU	66	HV1	JAKKANALLY_66	11:16	11:22	0:05	TRANSFORMER FAULT
1050	12-Mar-2022	MYSURU	66	HV1	JAKKANALLY_66	11:51	11:59	0:08	TRANSFORMER FAULT
1051	12-Mar-2022	MYSURU	66	HV1	KABHALLY_66	10:03	15:04	5:01	LINE CLEAR AVAILED
1052	12-Mar-2022	MYSURU	66	HV1	KABHALLY_66	15:56	16:46	0:49	LINE CLEAR AVAILED
1053	12-Mar-2022	MYSURU	66	HV2	KIKKERI_66	8:26	13:21	4:54	LINE CLEAR AVAILED
1054	12-Mar-2022	MYSURU	66	HOOTAGALLY-FTS 1	NO STATIONS EFFECTED	14:22	17:58	3:36	LINE CLEAR AVAILED
1055	12-Mar-2022	MYSURU	66	HOOTAGALLY-FTS 2	NO STATIONS EFFECTED	14:22	17:58	3:36	LINE CLEAR AVAILED
1056	12-Mar-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)	12:32:20 (12/3/2022)	1483:59H RS	LINE CHARGED
1057	12-Mar-2022	MYSURU	66	HV2	KMDODDI_66	19:18:18 (11/03/2022)	10:55:23 (12/03/2022)	15:37HRS	TRANSFORMER CHARGED
1058	12-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1059	12-Mar-2022	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	8:11:00 (12/03/2022)			LINE OPEN,LINE CLEAR AVAILED
1060	12-Mar-2022	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	18:07	18:16	0:09	TRANSFORMER FAULT
1061	12-Mar-2022	TUMKUR	220	THALLAK 220kV- HRLMN1	THALLAK_220	15:38	19:45	4:07	NFBC ISSUED
1062	12-Mar-2022	TUMKUR	220	THALLAK 220kV- HRLMN1	THALLAK_220	19:42	21:58	2:16	LINE CLEAR AVAILED
1063	12-Mar-2022	TUMKUR	220	JAGLUR_400-KDLGI2	JAGLUR_400	13:38	15:22	1:43	LINE CLEAR AVAILED
1064	12-Mar-2022	TUMKUR	220	JAGLUR_400-KDLGI2	JAGLUR_400	15:35	19:40	4:05	LINE CLEAR AVAILED
1065	12-Mar-2022	TUMKUR	220	JAGLUR_400-KDLGI2	JAGLUR_400	19:50	22:19	2:29	LINE CLEAR AVAILED
1066	12-Mar-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL 110	13:14	13:27	0:13	LINE FAULT
1067	12-Mar-2022	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	18:07	18:17	0:10	TRANSFORMER FAULT
1068	12-Mar-2022	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66,THIPPUR_66,JID DEGERE_66	15:42	15:50	0:07	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1069	12-Mar-2022	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	12:17	12:25	0:07	LINE FAULT
1070	12-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:10	7:20	0:10	LINE FAULT
1071	12-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:04	9:19	0:14	LINE FAULT
1072	12-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:21	15:31	1:09	LINE FAULT
1073	12-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:01	17:57	0:55	LINE FAULT
1074	12-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:27	22:38	0:10	LINE FAULT
1075	12-Mar-2022	TUMKUR	66	MELKOTE-BADDIHALLI	MELKOTE_66	10:38	11:43	1:04	LINE CLEAR AVAILED
1076	12-Mar-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:57	6:59	0:01	LINE FAULT
1077	12-Mar-2022	TUMKUR	66	TR-2	KOLALA_66	17:53	18:09	0:15	TRANSFORMER FAULT
1078	12-Mar-2022	TUMKUR	66	TR-2	KIADB V N PURA_220	2:48	8:48	6:00	LINE CLEAR AVAILED
1079	12-Mar-2022	TUMKUR	66	TR-2	HONNUDIKE_66	10:43	10:50	0:06	TRANSFORMER FAULT
1080	12-Mar-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:52	13:57	4:05	LINE CLEAR AVAILED
1081	12-Mar-2022	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1 IPP_66	MEGMICON 1_IPP_66	7:24	9:20	1:56	LINE CLEAR AVAILED
1082	12-Mar-2022	TUMKUR	66	TR-3	HARIYABBE_66	10:06	10:11	0:04	TRANSFORMER FAULT
1083	13-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1084	13-Mar-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
1085	13-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1086	13-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1087	13-Mar-2022	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1088	13-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1089	13-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1090	13-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1091	13-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY2	STATION NOT AFFECTED SIRSI_220	22:53 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1092	13-Mar-2022	BAGALKOT	220	SIRSI- SHARAVTHY1	STATION NOT AFFECTED SIRSI_220	22:53 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1093	13-Mar-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1094	13-Mar-2022	BAGALKOT	110	HUDALI-ANKALAGI	HUDALI_110	19:26 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1095	13-Mar-2022	BAGALKOT	110	BELGAUM220- VODAGOAN	VODAGOAN_110	9:25	14:04	4:39	NFBC ISSUED
1096	13-Mar-2022	BAGALKOT	110	BELGAUM220- HUKKERI(HONAGA)	HONAGA_110	15:00	19:40	4:40	LINE CLEAR AVAILED
1097	13-Mar-2022	BAGALKOT	220	VAJRAMATTI- BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	9:34	19:07	9:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1098	13-Mar-2022	BAGALKOT	220	VAJRAMATTI- BAGALKOT2	STATION NOT AFFECTED VAJRAMATTI_220	9:35	19:08	9:34	LINE CLEAR AVOID
1099	13-Mar-2022	BAGALKOT	220	BAGALKOT - ALAMATTI1	BAGALKOT_220	9:18	18:56	9:38	LINE CLEAR AVOID
1100	13-Mar-2022	BAGALKOT	220	BAGALKOT - ALAMATTI-2	BAGALKOT_220	9:18	18:58	9:40	LINE CLEAR AVOID
1101	13-Mar-2022	BAGALKOT	220	BAGALKOT - VAJARAMATTI2	BAGALKOT_220	9:32	19:07	9:33	LINE CLEAR AVOID
1102	13-Mar-2022	BAGALKOT	220	BAGALKOT - GADAG-1	BAGALKOT_220	9:21	18:02	8:41	LINE CLEAR AVOID
1103	13-Mar-2022	BAGALKOT	220	BAGALKOT - GADAG-2	BAGALKOT_220	9:21	18:00	8:39	LINE CLEAR AVOID
1104	13-Mar-2022	BAGALKOT	110	BAGALKOT220-BAGALKOT-2	BAGALKOT_220	9:12	18:53	2:38	LINE CLEAR AVOID
1105	13-Mar-2022	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	BAGALKOT_220	10:10	18:21	0:58	LINE CLEAR AVOID
1106	13-Mar-2022	BAGALKOT	110	BAGALKOT220-NAVANAGAR2	BAGALKOT_220	10:10	18:21	0:58	LINE CLEAR AVOID
1107	13-Mar-2022	BAGALKOT	110	BAGALKOT220- GULEDAGUDDA	BAGALKOT_220	9:55	19:18	9:23	LINE CLEAR AVOID
1108	13-Mar-2022	BAGALKOT	110	BAGALKOT220-KERUR	BAGALKOT_220	9:50	19:18	0:38	LINE CLEAR AVOID
1109	13-Mar-2022	BAGALKOT	110	BAGALKOT220-LOKAPUR	BAGALKOT_220	9:13	19:11	9:57	LINE CLEAR AVOID
1110	13-Mar-2022	BAGALKOT	110	BAGALKOT220- KATARKI(NEERBUDIHAL)	BAGALKOT_220	9:13	19:04	9:51	LINE CLEAR AVOID
1111	13-Mar-2022	BAGALKOT	220	220/110KV, HV1&LV1	BAGALKOT_220	9:14	18:39	9:25	LINE CLEAR AVOID
1112	13-Mar-2022	BAGALKOT	220	220/110KV, HV2&LV2	BAGALKOT_220	9:14	18:03	9:38	LINE CLEAR AVOID
1113	13-Mar-2022	BAGALKOT	220	220/110KV, HV3&LV3	BAGALKOT_220	9:35	18:34	8:49	LINE CLEAR AVOID
1114	13-Mar-2022	BAGALKOT	110	110/11KV, HV3	BAGALKOT_220	9:12	18:54	9:42	LINE CLEAR AVOID
1115	13-Mar-2022	BAGALKOT	110	110/33KV, HV4	BAGALKOT_220	9:33	18:13	8:40	LINE CLEAR AVOID
1116	13-Mar-2022	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MK HUBLI_220	14:18	18:48	9:48	LINE CLEAR AVOID
1117	13-Mar-2022	BAGALKOT	110	DADDI-F2( HONAGA)	STATION NOT AFFECTED DADDI_110	15:39	19:38	3:59	NFBC ISSUED
1118	13-Mar-2022	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	8:58	9:18	0:20	HAND TRIPPED
1119	13-Mar-2022	BAGALKOT	110	HIREHAL-BADAMI	HIREHAL_110	9:18	21:20	12:02	HAND TRIPPED
1120	13-Mar-2022	BAGALKOT	110	HIREHAL-MFRSOLAR	HIREHAL_110,MFRSOLAR_IPP	9:05	9:26	0:21	HAND TRIPPED
1121	13-Mar-2022	BAGALKOT	110	110/11KV, HV2	KAGWAD_110	8:46	10:01	1:15	LINE CLEAR AVOID
1122	13-Mar-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YALLAMANAWADI_110	9:54	10:10	0:16	TRANSFORMER FAULT
1123	13-Mar-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YALLAMANAWADI_110	14:05	14:21	0:16	TRANSFORMER FAULT
1124	13-Mar-2022	BAGALKOT	110	VADAGAON-BELGAUM220	VADAGAON_110	9:20	14:04	4:44	NFBC ISSUED
1125	13-Mar-2022	BAGALKOT	110	UDAKERI-NOKAR SOLAR(SOUDATTI)	NOKAR SOLAR_110 UDAKERI_110	10:04	16:13	6:09	LINE CLEAR AVOID
1126	13-Mar-2022	BAGALKOT	110	SUARNASOUDHA-MACHE	MACHE_110	9:16	18:39	9:23	NFBC ISSUED
1127	13-Mar-2022	BAGALKOT	110	SIRSI- SIDDAPUR (JOG2)	STATION NOT AFFECTED SIRSI_110	10:00	14:39	4:39	NFBC ISSUED
1128	13-Mar-2022	BAGALKOT	110	SIRSI- SIDDAPUR (JOG2)	STATION NOT AFFECTED SIRSI_110	14:39	16:40	2:01	LINE FAULT
1129	13-Mar-2022	BAGALKOT	110	SIRSI- SIDDAPUR (JOG2)	STATION NOT AFFECTED SIRSI_110	16:49 (13.03.2022)			LINE OPEN,LINE CLEAR AVOID
1130	13-Mar-2022	BAGALKOT	110	110/11KV HV1	SALAHALLI_110	16:42	17:24	0:42	HAND TRIPPED
1131	13-Mar-2022	BAGALKOT	110	110/33KV HV3	HUAKUND_33 SALAHALLI_110	16:42	17:24	0:42	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1132	13-Mar-2022	BAGALKOT	110	SALAHALLI-GMNAVAR IPP	GMNAVAR IPP_110 STATION NOT AFFECTED SALAHALLI_110	16:42	17:24	0:42	HAND TRIPPED
1133	13-Mar-2022	BAGALKOT	110	RON-GAMESH IPP	GAMESH IPP_110 STATION NOT AFFECTED RON_110	9:15	9:17	0:02	HAND TRIPPED
1134	13-Mar-2022	BAGALKOT	110	NEERABUDIHAI-KATARKI	STATION NOT AFFECTED NEERBUDIHAI_110	19:10 (13.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
1135	13-Mar-2022	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(B)_110	9:13	18:20	9:07	HAND TRIPPED
1136	13-Mar-2022	BAGALKOT	110	MUKARTIHAI-SPV SOLAR	SPV SOLAR_110 STATION NOT AFFECTED MUKARTIHAI_110	18:56 (13.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
1137	13-Mar-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(B)_110	11:15	11:35	0:20	TRANSFORMER FAULT
1138	13-Mar-2022	BAGALKOT	110	LOKAPUR-BAGALKOT220	STATION NOT AFFECTED LOKAPUR_110	9:34	19:16	9:42	HAND TRIPPED
1139	13-Mar-2022	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED LOKAPUR_110	9:34	17:54	8:20	LINE CLEAR AVOIDED
1140	13-Mar-2022	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	9:34	16:31	6:57	LINE CLEAR AVOIDED
1141	13-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LOKAPUR_110	9:34	17:54	8:20	LINE CLEAR AVOIDED
1142	13-Mar-2022	BAGALKOT	220	KUDUCHI-ATHANI	STATION NOT AFFECTED KUDUCHI_220	4:08	4:54	0:46	LINE CLEAR AVOIDED
1143	13-Mar-2022	BAGALKOT	110	RANEENNUR- RATTIHALLI(TUMMINAKATTI)	TUMMINAKATTI_110	21:49	21:57	0:08	LINE FAULT
1144	13-Mar-2022	BAGALKOT	110	RANEENNUR- RATTIHALLI(TUMMINAKATTI)	TUMMINAKATTI_110	23:11	23:20	0:09	LINE FAULT
1145	13-Mar-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
1146	13-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
1147	13-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM1	CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVOIDED
1148	13-Mar-2022	BAGALKOT	110	110/11KV, HV1	VODAGOAN_110	8:50	16:53	8:03	LINE CLEAR AVOIDED
1149	13-Mar-2022	BAGALKOT	110	110/11KV, HV2	VODAGOAN_110	8:50	16:53	8:03	LINE CLEAR AVOIDED
1150	13-Mar-2022	BAGALKOT	110	BELGAUM220- MACHE	MACHE_110	9:06	15:07	6:01	LINE CLEAR AVOIDED
1151	13-Mar-2022	BAGALKOT	110	BELGAUM220- UCHAGOAN	UCHAGOAN_110	15:40	19:40	4:00	LINE CLEAR AVOIDED
1152	13-Mar-2022	BAGALKOT	220	GADAG-BAGALKOT1	STATION NOT AFFECTED GADAG_220	9:21	18:02	8:41	LINE CLEAR AVOIDED
1153	13-Mar-2022	BAGALKOT	220	GADAG-BAGALKOT2	STATION NOT AFFECTED GADAG_220	9:21	18:02	8:41	LINE CLEAR AVOIDED
1154	13-Mar-2022	BAGALKOT	110	VAJRAMATTI220- KATARAKI	STATION NOT AFFECTED VAJRAMATTI_220	14:27	14:41	0:14	LINE FAULT
1155	13-Mar-2022	BAGALKOT	110	VAJRAMATTI220- SHIRAGUPPI	SHIRAGUPPI_110	14:27	14:40	0:13	LINE FAULT
1156	13-Mar-2022	BAGALKOT	220	BAGALKOT - VAJRAMATTI1	BAGALKOT_220	9:33	19:06	9:33	LINE CLEAR AVOIDED
1157	13-Mar-2022	BAGALKOT	220	BAGALKOT - KOPPAL LIS	BAGALKOT_220	9:35	20:24	10:49	LINE CLEAR AVOIDED
1158	13-Mar-2022	BAGALKOT	110	BAGALKOT220-LOKAPUR	BAGALKOT_220	9:13	19:11	9:57	LINE CLEAR AVOIDED
1159	13-Mar-2022	BAGALKOT	110	BAGALKOT220-KALADAGI	BAGALKOT_220	11:10	19:00	1:57	LINE CLEAR AVOIDED
1160	13-Mar-2022	BAGALKOT	110	SODATTI220- UDIKERI	UDIKERI_110	10:25	16:10	5:45	LINE CLEAR AVOIDED
1161	13-Mar-2022	BAGALKOT	220	ATHANI- KUDACHI	ATHANI_220	4:08	4:58	0:50	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1162	13-Mar-2022	BENGALURU	66	ADUGODI - HSR LAYOUT 1 220	ADUGODI	7:00	7:05	0:05	LOAD CHANGE OVER
1163	13-Mar-2022	BENGALURU	220	HV2	EPIP 220	12:58	14:52	1:54	TRANSFORMER FAULT
1164	13-Mar-2022	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION	12:58	13:11	0:13	MAIN SUPPLY FAILURE
1165	13-Mar-2022	BENGALURU	66	HV2	EPIP 220	12:58	13:11	0:13	MAIN SUPPLY FAILURE
1166	13-Mar-2022	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	13:06	13:15	0:09	LINE CLEAR AVAILED
1167	13-Mar-2022	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	9:00	17:40	8:40	LINE CLEAR AVAILED
1168	13-Mar-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:32	17:10	1:38	LINE CLEAR AVAILED
1169	13-Mar-2022	BENGALURU	220	HV2	TK HALLI 220	15:46	16:09	0:23	MAIN SUPPLY FAILURE
1170	13-Mar-2022	BENGALURU	220	HV1	TK HALLI 220	15:46	16:09	0:23	MAIN SUPPLY FAILURE
1171	13-Mar-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	15:46	16:21	0:35	MAIN SUPPLY FAILURE
1172	13-Mar-2022	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	15:46	16:23	0:37	MAIN SUPPLY FAILURE
1173	13-Mar-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:46	16:40	0:54	MAIN SUPPLY FAILURE
1174	13-Mar-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:46	16:41	0:55	MAIN SUPPLY FAILURE
1175	13-Mar-2022	BENGALURU	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB 1 (EHT)	15:46	16:10	0:24	MAIN SUPPLY FAILURE
1176	13-Mar-2022	BENGALURU	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	15:46	16:10	0:24	MAIN SUPPLY FAILURE
1177	13-Mar-2022	BENGALURU	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB 3 (EHT)	15:46	16:10	0:24	MAIN SUPPLY FAILURE
1178	13-Mar-2022	BENGALURU	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	15:46	16:10	0:24	MAIN SUPPLY FAILURE
1179	13-Mar-2022	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	15:46	17:07	1:21	MAIN SUPPLY FAILURE
1180	13-Mar-2022	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATION AFFECTED	15:46	17:27	1:41	LINE FAULT
1181	13-Mar-2022	BENGALURU	220	HV1	YARANDANAHALLI 220	12:50	13:50	1:00	LINE CLEAR AVAILED
1182	13-Mar-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:50	13:50	1:00	HAND TRIPPED
1183	13-Mar-2022	BENGALURU	220	HV3	YARANDANAHALLI 220	14:00	14:10	0:10	LINE CLEAR AVAILED
1184	13-Mar-2022	BENGALURU	66	HV1	CHANDAPURA	21:58	22:04	0:06	LINE CLEAR AVAILED
1185	13-Mar-2022	BENGALURU	66	HV2	HUKUNDA	15:00	15:10	0:09	TRANSFORMER FAULT
1186	13-Mar-2022	BENGALURU	66	HV1	KACHMARANAHALLI	9:30	9:35	0:05	LINE CLEAR AVAILED
1187	13-Mar-2022	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	13:30	14:06	0:36	LINE FAULT
1188	13-Mar-2022	BENGALURU	66	HV2	KOLAR 220	18:41	18:45	0:04	LINE CLEAR AVAILED
1189	13-Mar-2022	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	KEMPANAHALLI, AGALKOTE, MATHIKERE (NEL)	0:25	0:40	0:15	MAIN SUPPLY FAILURE
1190	13-Mar-2022	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	KEMPANAHALLI, AGALKOTE, MATHIKERE (NEL)	16:30	16:45	0:15	MAIN SUPPLY FAILURE
1191	13-Mar-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	9:30	18:57	9:27	LINE CLEAR AVAILED
1192	13-Mar-2022	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	9:30	18:57	9:27	LINE CLEAR AVAILED
1193	13-Mar-2022	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	9:30	18:57	9:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1194	13-Mar-2022	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:30	18:57	9:27	LINE CLEAR AVAILED
1195	13-Mar-2022	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	9:30	18:57	9:27	LINE CLEAR AVAILED
1196	13-Mar-2022	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	9:30	18:57	9:27	LINE CLEAR AVAILED
1197	13-Mar-2022	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	9:30	18:57	9:27	LINE CLEAR AVAILED
1198	13-Mar-2022	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	9:30	18:57	9:27	LINE CLEAR AVAILED
1199	13-Mar-2022	BENGALURU	220	HV1	MALUR 220	9:04	18:47	9:43	LINE CLEAR AVAILED
1200	13-Mar-2022	BENGALURU	220	HV2	MALUR 220	9:04	18:47	9:43	LINE CLEAR AVAILED
1201	13-Mar-2022	BENGALURU	220	MALUR 220 - KOLAR 220	MALUR 220	9:06	18:46	9:40	LINE CLEAR AVAILED
1202	13-Mar-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL-1	NO STATION AFFECTED	8:17	17:38	9:21	LINE CLEAR AVAILED
1203	13-Mar-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL-2	NO STATION AFFECTED	8:17	17:40	9:23	LINE CLEAR AVAILED
1204	13-Mar-2022	BENGALURU	66	T GOLAHALLI 220 - KYASAMBALLI	NO STATION AFFECTED	18:01(10-03-2022)	14:10(13/03/2022 )	68:09HRS	LINE CHARGED
1205	13-Mar-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1206	13-Mar-2022	GULBARGA	220	HV2	HALBARGA_220	6:18	6:28	0:10	TRANSFORMER FAULT
1207	13-Mar-2022	GULBARGA	220	HALBARGA-HUMNABAD 1&2	HALBARGA_220	9:13	14:27	5:14	LINE CLEAR AVAILED
1208	13-Mar-2022	GULBARGA	220	BUS 1 &2	HALBARGA_220	10:02	13:38	3:36	LINE CLEAR AVAILED
1209	13-Mar-2022	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	13:31	13:50	0:19	LINE FAULT
1210	13-Mar-2022	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	14:17	19:00	4:43	LINE FAULT
1211	13-Mar-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1212	13-Mar-2022	GULBARGA	110	HV1	HATTI_110	8:59	9:09	0:10	TRANSFORMER FAULT
1213	13-Mar-2022	GULBARGA	110	HV3	BISIHALLI_110	16:21	16:30	0:09	TRANSFORMER FAULT
1214	13-Mar-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	2:10	2:20	0:10	LINE FAULT
1215	13-Mar-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	4:00	4:10	0:10	LINE FAULT
1216	13-Mar-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	5:50	5:55	0:05	LINE FAULT
1217	13-Mar-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	6:20	6:25	0:05	LINE FAULT
1218	13-Mar-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	14:30	15:00	0:30	LINE CLEAR AVAILED
1219	13-Mar-2022	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	9:28	15:12	5:44	LINE CLEAR AVAILED
1220	13-Mar-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA N_110,DIGGI_110	0:21	0:25	0:04	LINE FAULT
1221	13-Mar-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA N_110,DIGGI_110	6:18	6:29	0:11	LINE FAULT
1222	13-Mar-2022	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	6:58	18:48	11:50	LINE CLEAR AVAILED
1223	13-Mar-2022	GULBARGA	110	SINDHANOOR-JAWALGERA	JAWALGERA_110,ADVAMER ASHWAR_110	4:05	4:15	0:10	LINE FAULT
1224	13-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	13:02	13:12	0:10	LINE FAULT
1225	13-Mar-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:03	19:10	0:07	LINE FAULT
1226	13-Mar-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:23	20:28	0:05	LINE FAULT
1227	13-Mar-2022	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	21:08	21:19	0:11	LINE FAULT
1228	13-Mar-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	19:55	20:05	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1229	13-Mar-2022	GULBARGA	110	ALIPUR-BELLARAY NORTH	SOMASAMUDRA_110,BELLAR Y NORTH_110,MOKA, PD HALLI_110,BISIHALLI_110,JAN AKI_IPP, BASAI STEELS ACC IPP	16:21	16:26	0:05	LINE FAULT
1230	13-Mar-2022	GULBARGA	66	HV1	ITTAGI_220	20:32 (11.03.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1231	13-Mar-2022	GULBARGA	66	HV1	SOVENHALLI_66	17:30	19:14	1:44	LINE CLEAR AVAILED
1232	13-Mar-2022	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	6:10	6:20	0:10	LINE FAULT
1233	13-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1234	13-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1235	13-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1236	13-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1237	13-Mar-2022	HASSAN	110	SORABA-MAVALLI	SORABA_110	18:02(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1238	13-Mar-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1239	13-Mar-2022	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	6:06((12.03.2022)	11:49(13.03.2022)	29:33HRS	LINE CHARGED
1240	13-Mar-2022	HASSAN	220	KADUR-DABUSET	KADUR_220	5:46((12.03.2022)	11:47(13.03.2022)	30:01HRS	LINE CHARGED
1241	13-Mar-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	6:23(12.03.2022)	11:48(13.03.2022)	29:25HRS	LINE CHARGED
1242	13-Mar-2022	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	17:37(13.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1243	13-Mar-2022	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_110	17:48(13.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1244	13-Mar-2022	HASSAN	220	SHRAVITY-ST3	gen_sharavathy	2:25	12:25	10:00	LINE FAULT
1245	13-Mar-2022	HASSAN	220	TALAGU-ST3	TALAGUPPA_400	11:38	12:25	0:47	HAND TRIPPED
1246	13-Mar-2022	HASSAN	110	HV1	ALKOLA_110	2:26	5:33	3:07	TRANSFORMER FAULT
1247	13-Mar-2022	HASSAN	110	HV2	ALKOLA_110	4:09	4:59	0:50	HAND TRIPPED
1248	13-Mar-2022	HASSAN	110	HV1	BAIKAMPADI_110	10:31	11:04	0:33	LINE CLEAR AVAILED
1249	13-Mar-2022	HASSAN	110	HV2	BAIKAMPADI_110	10:31	11:05	0:34	LINE CLEAR AVAILED
1250	13-Mar-2022	HASSAN	110	HV3	BAIKAMPADI_110	10:31	11:05	0:34	LINE CLEAR AVAILED
1251	13-Mar-2022	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	6:10	6:21	0:11	MAIN SUPPLY FAILURE
1252	13-Mar-2022	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	6:10	6:21	0:11	LINE FAULT
1253	13-Mar-2022	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	19:13	19:25	0:12	LINE FAULT
1254	13-Mar-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:41	18:36	8:55	LINE CLEAR AVAILED
1255	13-Mar-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:41	18:36	8:55	LINE CLEAR AVAILED
1256	13-Mar-2022	MYSURU	66	KR NAGARA-BILIKERE	DMG_HALLI_66 BILIKERE_66GVGUDI_66	6:51	7:00	0:08	LINE FAULT
1257	13-Mar-2022	MYSURU	66	KR NAGARA-KUSHALNAGARA	MIRLE_66	18:05	18:20	0:15	LINE FAULT
1258	13-Mar-2022	MYSURU	66	PERIYAPATNA-HANAGUDU	PONNAMPET_66 VIRAJPET_66	7:34	7:44	0:10	LINE FAULT
1259	13-Mar-2022	MYSURU	66	PONNAMPETE-HANAGODU	PONNAMPET_66 VIRAJPET_66	8:08	12:50	4:41	HAND TRIPPED
1260	13-Mar-2022	MYSURU	220	HV3	HOOTAGALLY_220	13:20	13:40	0:20	TRANSFORMER FAULT
1261	13-Mar-2022	MYSURU	220	HV3	HOOTAGALLY_220	18:51	19:33	0:42	TRANSFORMER FAULT
1262	13-Mar-2022	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	13:40	14:38	0:58	HAND TRIPPED
1263	13-Mar-2022	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	18:19	18:51	0:32	HAND TRIPPED
1264	13-Mar-2022	MYSURU	220	VAJAMANGALA-TK HALLI	NO STATIONS EFFECTED	15:47	16:52	1:05	LINE FAULT
1265	13-Mar-2022	MYSURU	66	HV1	KIADBMANDYA_66	15:47	16:44	0:56	HAND TRIPPED
1266	13-Mar-2022	MYSURU	66	TUMBLA-MEGALAPURA	THUMBLA_66	0:52	1:00	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1267	13-Mar-2022	MYSURU	66	CHANDALLI-THALKADU	CHANDALLI_66	23:42	23:47	0:05	LINE FAULT
1268	13-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	15:40	15:57	0:17	HAND TRIPPED
1269	13-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	15:57	16:09	0:12	LINE FAULT
1270	13-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	15:40	15:59	0:19	HAND TRIPPED
1271	13-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	15:59	16:09	0:10	LINE FAULT
1272	13-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	21:10:00			LINE OPEN,LINE CLEAR AVAILED
1273	13-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	21:10:00			LINE OPEN,LINE CLEAR AVAILED
1274	13-Mar-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00			LINE OPEN,LINE CLEAR AVAILED
1275	13-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1276	13-Mar-2022	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	8:11:00 (12/03/2022)	15:36:00 (13/03/2022)	30:47HRS	LINE CHARGED
1277	13-Mar-2022	TUMKUR	220	JAGLUR_400-THALLAK220	THALLAK_220	10:03	18:23	8:20	LINE CLEAR AVAILED
1278	13-Mar-2022	TUMKUR	220	JAGLUR_400-THALLAK220	THALLAK_220	20:22	23:05	2:43	LINE CLEAR AVAILED
1279	13-Mar-2022	TUMKUR	220	THALLAK 220kv- HRLMN1	THALLAK_220	20:24	23:06	2:42	NFBC ISSUED
1280	13-Mar-2022	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66,MATTIKERE_66	0:23	0:38	0:15	HAND TRIPPED
1281	13-Mar-2022	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	17:20	17:30	0:10	MAIN SUPPLY FAILURE
1282	13-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:19	12:28	0:08	LINE FAULT
1283	13-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:10	16:22	0:11	LINE FAULT
1284	13-Mar-2022	TUMKUR	66	GULIGENAHALLI- SIRA2	GULIGENAHALLI_66	10:26	10:44	0:18	LINE FAULT
1285	13-Mar-2022	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	2:24	2:31	0:06	MAIN SUPPLY FAILURE
1286	13-Mar-2022	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	4:30	8:15	3:45	LINE CLEAR AVAILED
1287	13-Mar-2022	TUMKUR	66	MADANAYAKANAHALLI66- TURUVANUR66	MADANAYAKANAHALLI_66	18:20	19:43	1:23	MAIN SUPPLY FAILURE
1288	13-Mar-2022	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER _IPP_66	8:35	10:05	1:30	MAIN SUPPLY FAILURE
1289	13-Mar-2022	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR _IPP_66	10:25	11:00	0:35	MAIN SUPPLY FAILURE
1290	13-Mar-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	10:08	10:27	0:18	MAIN SUPPLY FAILURE
1291	13-Mar-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	17:23	17:33	0:10	MAIN SUPPLY FAILURE
1292	13-Mar-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	12:10	12:30	0:20	MAIN SUPPLY FAILURE
1293	13-Mar-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	14:43	14:55	0:12	MAIN SUPPLY FAILURE
1294	13-Mar-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	16:23	16:35	0:12	HAND TRIPPED
1295	13-Mar-2022	TUMKUR	66	TR-2	TAVAREKERE_66	18:30	18:50	0:20	TRANSFORMER FAULT
1296	13-Mar-2022	TUMKUR	66	TAVAREKERE (H)- I/CHIRIYUR	TAVAREKERE(H)_66	1:41	9:25	7:43	LINE CLEAR AVAILED
1297	13-Mar-2022	TUMKUR	66	TAVAREKERE (H)- PATTNAYAKANAHALLI	TAVAREKERE(H)_66	1:41	9:25	7:43	LINE CLEAR AVAILED
1298	13-Mar-2022	TUMKUR	66	TR-1	CHITRADURGA_66	8:50	8:56	0:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1299	14-Mar-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1300	14-Mar-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
1301	14-Mar-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1302	14-Mar-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1303	14-Mar-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1304	14-Mar-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1305	14-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1306	14-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1307	14-Mar-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1308	14-Mar-2022	BAGALKOT	110	HUDALI-ANKALAGI	HUDALI_110	19:26 (12.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1309	14-Mar-2022	BAGALKOT	110	SIRSI- SIDDAPUR (JOG2)	STATION NOT AFFECTED SIRSI_110	16:49 (13.03.2022)	14:05 (14.03.2022)	21:16HRS	LINE CHARGED
1310	14-Mar-2022	BAGALKOT	110	NEERABUDIHAI-KATARKI	STATION NOT AFFECTED NEERBUDIHAI_110	19:10 (13.03.2022)	13:30 (14.03.2022)	18:20HRS	LINE CHARGED
1311	14-Mar-2022	BAGALKOT	110	MUKARTIHAL-SPV SOLAR	SPV SOLAR_110 STATION NOT AFFECTED MUKARTIHAL_110	18:56 (13.03.2022)	2:32 (14.03.2022)	7:36HRS	LINE CHARGED
1312	14-Mar-2022	BAGALKOT	220	ATHANI220-THAVASI(BALIGERI)	ATHANI_220	5:35	5:43	0:08	LINE FAULT
1313	14-Mar-2022	BAGALKOT	110	GAJENDRAGAD- RON1&2	STATION NOT AFFECTED GAJENDRAGAD_110	8:20	11:44	3:24	HAND TRIPPED
1314	14-Mar-2022	BAGALKOT	110	NARENDRA220- GARAG	STATION NOT AFFECTED GARAG_110	11:44	13:20	1:36	HAND TRIPPED
1315	14-Mar-2022	BAGALKOT	110	HIREHAL- MYFAIR SOLAR	HIREHAL_110	8:05	8:11	0:06	HAND TRIPPED
1316	14-Mar-2022	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	8:05	8:26	0:21	HAND TRIPPED
1317	14-Mar-2022	BAGALKOT	110	HIREHAL- MYFAIR SOLAR	HIREHAL_110	11:41	11:58	0:17	HAND TRIPPED
1318	14-Mar-2022	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	11:39	11:58	0:19	HAND TRIPPED
1319	14-Mar-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	11:15	18:50	7:35	LINE CLEAR AVAILED
1320	14-Mar-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	11:15	18:50	7:35	LINE CLEAR AVAILED
1321	14-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ISLAMPUR_110	12:27	15:00	2:33	LINE CLEAR AVAILED
1322	14-Mar-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	02:11	02:19	0:08	TRANSFORMER FAULT
1323	14-Mar-2022	BAGALKOT	110	RON-GAMESH IPP	GAMESH_110_IPP RON_110	11:40	11:45	0:05	HAND TRIPPED
1324	14-Mar-2022	BAGALKOT	110	RON-GAMESH IPP	GAMESH_110_IPP RON_110	08:30	08:32	0:02	HAND TRIPPED
1325	14-Mar-2022	BAGALKOT	110	RON-GAJENDRAGAD 1&2	STATION NOT AFFECTED RON_110	08:30	11:54	3:24	HAND TRIPPED
1326	14-Mar-2022	BAGALKOT	110	SALAHALLI-GMNAVAR IPP	GMNAVAR110_IPP STATION NOT AFFECTED SALAHALLI_110	09:38	18:48	9:10	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1327	14-Mar-2022	BAGALKOT	110	RANEENNUR220-TUMMINAKATTI	STATION NOT AFFECTED TUMMINAKATTI 110	13:04	13:40	0:36	LINE CLEAR AVOID
1328	14-Mar-2022	BAGALKOT	110	YADAWAD-IZRA SOLAR	IZRA SOLAR_IPP STATION NOT AFFECTED YADAWAD 110	03:05	05:45	2:40	LINE FAULT
1329	14-Mar-2022	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR 220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOID
1330	14-Mar-2022	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVOID
1331	14-Mar-2022	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI 220	10:42 (11.03.2022)			LINE OPEN,LINE CLEAR AVOID
1332	14-Mar-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI 220	10:14 (12.03.2022)			LINE OPEN,LINE CLEAR AVOID
1333	14-Mar-2022	BAGALKOT	110	SIRSI220- SIRSI2	STATION NOT AFFECTED SIRSI 220	12:53	12:55	0:02	LINE FAULT
1334	14-Mar-2022	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	5:15	5:30	0:15	LINE FAULT
1335	14-Mar-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MKHUBLI 220	6:06	6:58	0:52	LINE CLEAR AVOID
1336	14-Mar-2022	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED MKHUBLI 220	6:06	7:01	0:55	LINE CLEAR AVOID
1337	14-Mar-2022	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	12:30	13:00	0:30	LINE CLEAR AVOID
1338	14-Mar-2022	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED HUBLI 220	9:26 (14.03.2022)			TRANSFORMER OPEN,LINE CLEAR AVOID
1339	14-Mar-2022	BAGALKOT	110	RANEENNUR- RATTIHALLI (TUMMINKATTE)	TUMMIINKATTE_110	3:48	3:56	0:08	LINE FAULT
1340	14-Mar-2022	BAGALKOT	110	RANEENNUR- RATTIHALLI (TUMMINKATTE)	STATION NOT AFFECTED RANEENNUR 220	12:58	13:45	0:47	LINE CLEAR AVOID
1341	14-Mar-2022	BAGALKOT	110	110/11KV, HV1	SANKESHWAR_110	16:40	16:45	0:05	LINE CLEAR AVOID
1342	14-Mar-2022	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	17:42	17:51	0:09	MAIN SUPPLY FAILURE
1343	14-Mar-2022	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	19:07	19:23	0:16	LINE FAULT
1344	14-Mar-2022	BENGALURU	66	HV1	BRIGADE MEADOWS	10:25	10:36	0:11	LINE CLEAR AVOID
1345	14-Mar-2022	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	14:41	14:46	0:05	LOAD CHANGE OVER
1346	14-Mar-2022	BENGALURU	66	HV1	BRIGADE MEADOWS	15:16	15:17	0:01	LOAD CHANGE OVER
1347	14-Mar-2022	BENGALURU	66	HV2	BRIGADE MEADOWS	15:17	15:18	0:01	LOAD CHANGE OVER
1348	14-Mar-2022	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	BRIGADE MEADOWS	18:13	18:19	0:06	LOAD CHANGE OVER
1349	14-Mar-2022	BENGALURU	66	HV2	DEVARABISANAHALLI	12:32	12:38	0:06	TRANSFORMER FAULT
1350	14-Mar-2022	BENGALURU	66	HV1	DEVARABISANAHALLI	17:28	17:52	0:24	LINE CLEAR AVOID
1351	14-Mar-2022	BENGALURU	66	EAST DIVISION COMPOUND - BMTC	BMTC	19:07	19:23	0:16	LINE FAULT
1352	14-Mar-2022	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	12:03	12:05	0:02	LOAD CHANGE OVER
1353	14-Mar-2022	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	19:32	19:35	0:03	LOAD CHANGE OVER
1354	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	9:14	9:18	0:04	LINE FAULT
1355	14-Mar-2022	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	17:42	18:04	0:22	MAIN SUPPLY FAILURE
1356	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	17:42	18:05	0:23	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1357	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	17:42	18:05	0:23	HAND TRIPPED
1358	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 3	HONNIGANAHALLI, ACHALU, HALAGURU	17:42	18:05	0:23	HAND TRIPPED
1359	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	17:42	18:05	0:23	HAND TRIPPED
1360	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:42	18:05	0:23	HAND TRIPPED
1361	14-Mar-2022	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	17:42	18:05	0:23	HAND TRIPPED
1362	14-Mar-2022	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	18:22	18:26	0:04	LOAD CHANGE OVER
1363	14-Mar-2022	BENGALURU	66	NIMHANS 220 - BMTC	BMTC	19:26	19:30	0:04	LINE FAULT
1364	14-Mar-2022	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI 220(EHT)	VRISHABHAVATHI 220	17:42	18:00	0:18	MAIN SUPPLY FAILURE
1365	14-Mar-2022	BENGALURU	220	HAROHALLI BWSSB	HAROHALLI BWSSB	17:42	18:02	0:20	MAIN SUPPLY FAILURE
1366	14-Mar-2022	BENGALURU	66	SOBHA FOREST - SOMANAHALLI 220	SOBHA FOREST	11:01	11:27	0:26	LOAD CHANGE OVER
1367	14-Mar-2022	BENGALURU	66	SOBHA FOREST - SUBRAMANYAPURA 220	SOBHA FOREST	18:35	18:38	0:03	LOAD CHANGE OVER
1368	14-Mar-2022	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHABHAVATHI 220	17:42	18:00	0:18	MAIN SUPPLY FAILURE
1369	14-Mar-2022	BENGALURU	66	VRISHABHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	17:42	18:01	0:19	HAND TRIPPED
1370	14-Mar-2022	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	17:42	18:22	0:40	HAND TRIPPED
1371	14-Mar-2022	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	REMCO	17:42	18:03	0:21	HAND TRIPPED
1372	14-Mar-2022	BENGALURU	66	ST.JOHN WOOD - HSR LAYOUT 220	ST.JOHN WOOD	11:58	12:05	0:07	LOAD CHANGE OVER
1373	14-Mar-2022	BENGALURU	66	ST.JOHN WOOD - ADUGODI	ST.JOHN WOOD	16:09	16:15	0:06	LOAD CHANGE OVER
1374	14-Mar-2022	BENGALURU	220	HV1	VIKAS TECH PARK 220	11:05	11:10	0:05	TRANSFORMER FAULT
1375	14-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	11:05	11:12	0:07	HAND TRIPPED
1376	14-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:05	11:15	0:10	HAND TRIPPED
1377	14-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	11:05	11:15	0:10	HAND TRIPPED
1378	14-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	11:05	11:15	0:10	HAND TRIPPED
1379	14-Mar-2022	BENGALURU	66	VIKAS TECH PARK 220 - CESSNA TECH PARK 2	CESSNA	11:05	11:13	0:08	HAND TRIPPED
1380	14-Mar-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA	0:31	0:50	0:19	LINE FAULT
1381	14-Mar-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA	2:09	3:03	0:54	LINE FAULT
1382	14-Mar-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA	4:12	4:39	0:26	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1383	14-Mar-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA	12:55	14:15	1:20	LINE CLEAR AVAILED
1384	14-Mar-2022	BENGALURU	66	HV2	GUNDAMGERE	8:31	8:40	0:08	TRANSFORMER FAULT
1385	14-Mar-2022	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	11:31	18:19	6:48	LOAD CURTAILMENT
1386	14-Mar-2022	BENGALURU	66	HV2	MAASTI	21:13	21:19	0:06	TRANSFORMER FAULT
1387	14-Mar-2022	GULBARGA	110	HV1	HUNSAGI_110	13:20	14:15	0:55	LINE CLEAR AVAILED
1388	14-Mar-2022	GULBARGA	110	HV2	SIRIGERICROSS_110	12:45	12:50	0:05	TRANSFORMER FAULT
1389	14-Mar-2022	GULBARGA	110	HV2	BISILAHALLI_110	11:55	12:10	0:15	TRANSFORMER FAULT
1390	14-Mar-2022	GULBARGA	110	HV1	RAJESHWAR_110	9:54	10:12	0:18	TRANSFORMER FAULT
1391	14-Mar-2022	GULBARGA	110	KAPNOOR-HUMNABAD1 &2	MAHAGOAN_110,MARGUTTI _110,ALAND_110,KADAGANC HI_110	11:40	11:44	0:04	LINE CLEAR AVAILED
1392	14-Mar-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	3:01	3:11	0:10	LINE FAULT
1393	14-Mar-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	10:20	18:15	7:55	LINE CLEAR AVAILED
1394	14-Mar-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	10:12	17:37	7:25	LINE CLEAR AVAILED
1395	14-Mar-2022	GULBARGA	110	SINDHANOOR- ADAVIAMARESHAWR	JAWALGERA_110,ADVAMER ASHWAR_110	3:20	3:30	0:10	LINE FAULT
1396	14-Mar-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	5:10	5:20	0:10	LINE FAULT
1397	14-Mar-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:45	5:50	0:05	LINE FAULT
1398	14-Mar-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_11 0	11:55	14:02	2:07	LINE CLEAR AVAILED
1399	14-Mar-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_1 10,DEVANGAON_110,RENUK A_IPP,AZALPUR_110,KARAJA GI_110	11:43	12:00	0:17	LINE CLEAR AVAILED
1400	14-Mar-2022	GULBARGA	110	HUNSAGI-KEMBHAVI	HUNSAGI_110	13:20	14:15	0:55	LINE CLEAR AVAILED
1401	14-Mar-2022	GULBARGA	110	HUNSAGI-KEMBHAVI	HUNSAGI_110	16:05	16:45	0:40	LINE CLEAR AVAILED
1402	14-Mar-2022	GULBARGA	110	GALAG-ALKOD	GALAG_110	10:10	17:40	7:30	MAIN SUPPLY FAILURE
1403	14-Mar-2022	GULBARGA	110	HALKUNDI-ALIPUR	HALAKUNDI_110	11:45	11:57	0:12	MAIN SUPPLY FAILURE
1404	14-Mar-2022	GULBARGA	110	HALKUNDI-ALIPUR	HALAKUNDI_110	12:38	12:45	0:07	MAIN SUPPLY FAILURE
1405	14-Mar-2022	GULBARGA	110	HALKUNDI-ALIPUR	HALAKUNDI_110	13:30	13:44	0:14	MAIN SUPPLY FAILURE
1406	14-Mar-2022	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	11:40	11:50	0:10	MAIN SUPPLY FAILURE
1407	14-Mar-2022	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	11:42	11:44	0:02	MAIN SUPPLY FAILURE
1408	14-Mar-2022	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	11:44	11:54	0:10	MAIN SUPPLY FAILURE
1409	14-Mar-2022	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	12:35	12:45	0:10	MAIN SUPPLY FAILURE
1410	14-Mar-2022	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	13:30	13:45	0:15	MAIN SUPPLY FAILURE
1411	14-Mar-2022	GULBARGA	66	HV1	ITTAGI_220	20:32 (11.03.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1412	14-Mar-2022	GULBARGA	66	NEELAGUNDA- HARAPANAHALLI	HARAPANAHALLI_66	18:54	19:03	0:09	LINE FAULT
1413	14-Mar-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1414	14-Mar-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1415	14-Mar-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1416	14-Mar-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1417	14-Mar-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1418	14-Mar-2022	HASSAN	110	SORABA-MAVALLI	SORABA_110	18:02(11.03.2022)	8:36(14.03.2022)	62:34HRS	LINE CHARGED
1419	14-Mar-2022	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	17:37(13.03.2022)	18:49(14.3.2022)	25:12HRS	LINE CHARGED
1420	14-Mar-2022	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	17:48(13.03.2022)	7:00(14.3.2022)	13:12HRS	LINE CHARGED
1421	14-Mar-2022	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	18:45(14.3.2022)			LINE OPEN,LINE CLEAR AVAILED
1422	14-Mar-2022	HASSAN	220	SHRAVITY-SHIMOGA 2	gen_sharaathy	10:57	13:25	2:28	LINE CLEAR AVAILED
1423	14-Mar-2022	HASSAN	220	TALAGU-ST3	TALAGUPPA_400	10:57	13:25	2:28	LINE CLEAR AVAILED
1424	14-Mar-2022	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	13:32	14:55	1:23	MAIN SUPPLY FAILURE
1425	14-Mar-2022	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	17:13	17:16	0:03	HAND TRIPPED
1426	14-Mar-2022	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	17:16	17:56	0:40	HAND TRIPPED
1427	14-Mar-2022	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	15:56	18:49	2:53	LINE CLEAR AVAILED
1428	14-Mar-2022	HASSAN	110	LPH-LST3	gen_lph	13:51	14:21	0:30	LINE FAULT
1429	14-Mar-2022	HASSAN	110	LPH-LST4	gen_lph	13:51	14:47	0:56	LINE FAULT
1430	14-Mar-2022	HASSAN	110	LPH-MGHE 1	gen_lph	13:51	14:18	0:27	LINE FAULT
1431	14-Mar-2022	HASSAN	110	LPH-MGHE 2	gen_lph	13:51	14:19	0:28	LINE FAULT
1432	14-Mar-2022	HASSAN	220	HV1	MRSMSG_220	13:31	14:42	1:11	TRANSFORMER FAULT
1433	14-Mar-2022	HASSAN	110	HV1	MRSMSG_220	10:27	18:36	8:09	LINE CLEAR AVAILED
1434	14-Mar-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:02	9:12	0:10	LINE FAULT
1435	14-Mar-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	12:22	12:30	0:08	LINE FAULT
1436	14-Mar-2022	HASSAN	110	HV1	MSEZ_220	9:52	15:52	6:00	LINE CLEAR AVAILED
1437	14-Mar-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:51	14:29	0:38	LINE CLEAR AVAILED
1438	14-Mar-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:51	14:29	0:38	LINE CLEAR AVAILED
1439	14-Mar-2022	HASSAN	66	HV2	MATTANAVILE_66	12:37	13:28	0:51	LINE CLEAR AVAILED
1440	14-Mar-2022	HASSAN	66	HV1	RAMESHWARNAGAR_66	8:16	8:42	0:26	TRANSFORMER FAULT
1441	14-Mar-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:32	17:57	8:25	LINE CLEAR AVAILED
1442	14-Mar-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:32	17:57	8:25	LINE CLEAR AVAILED
1443	14-Mar-2022	HASSAN	66	HV2	UDAYAPURA_66	5:05	5:33	0:28	TRANSFORMER FAULT
1444	14-Mar-2022	MYSURU	220	HOOTAGALLI-BASTIPURA 1	NO STATIONS EFFECTED	16:51	19:10	2:19	NFBC ISSUED
1445	14-Mar-2022	MYSURU	66	HOOTAGALLI-DATTAGALLY	NO STATIONS EFFECTED	16:35	19:15	2:40	HAND TRIPPED
1446	14-Mar-2022	MYSURU	220	VAJMANGALA-T K HALLI	NO STATIONS EFFECTED	16:14	17:38	1:24	LINE CLEAR AVAILED
1447	14-Mar-2022	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	13:25	18:29	5:04	HAND TRIPPED
1448	14-Mar-2022	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	13:25	17:37	4:12	HAND TRIPPED
1449	14-Mar-2022	MYSURU	66	DEVANURU NANJANGUDU-KADAKOLA	DEVANOORNGUDU_66	21:54	22:05	0:10	LINE FAULT
1450	14-Mar-2022	MYSURU	66	DEVANURU NANJANGUDU-SUTTUR	SUTTUR_66	21:54	22:07	0:12	LINE FAULT
1451	14-Mar-2022	MYSURU	66	HV1	GAMANAHALLY_66	7:35	7:48	0:13	LINE CLEAR AVAILED
1452	14-Mar-2022	MYSURU	66	HV1	AJJIPURA_66	14:00	14:05	0:05	TRANSFORMER FAULT
1453	14-Mar-2022	MYSURU	66	HV1	HALAGUR_66	17:39	18:15	0:36	HAND TRIPPED
1454	14-Mar-2022	MYSURU	66	HV2	HALAGUR_66	17:39	18:15	0:36	HAND TRIPPED
1455	14-Mar-2022	MYSURU	66	HV2	THUMBLA_66	11:08	16:11	5:03	LINE CLEAR AVAILED
1456	14-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	21:10:00 (13.03.2022)	16:10:00 (14/3/2022)	19:00HRS	LINE CHARGED
1457	14-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	21:10:00 (13.03.2022)	16:10:00 (14/3/2022)	19:00HRS	LINE CHARGED
1458	14-Mar-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1459	14-Mar-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1460	14-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	19:16			LINE OPEN,LINE CLEAR AVAILED
1461	14-Mar-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	19:16			LINE OPEN,LINE CLEAR AVAILED
1462	14-Mar-2022	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	9:49	10:52	1:02	LINE CLEAR AVAILED
1463	14-Mar-2022	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA-1	ANCHEPALYA_220	9:49	10:51	1:02	LINE CLEAR AVAILED
1464	14-Mar-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:22	17:42	0:20	LINE FAULT
1465	14-Mar-2022	TUMKUR	66	TR-2	BILCHODU_66	14:00	14:05	0:05	TRANSFORMER FAULT
1466	14-Mar-2022	TUMKUR	66	TR-3	HARIYABBE_66	10:14	10:18	0:03	TRANSFORMER FAULT
1467	14-Mar-2022	TUMKUR	66	KATTIGE- RENEW WIND ENERGY_ IPP_66	RENEW WIND ENERGY_ IPP_66	16:45	18:30	1:45	LINE CLEAR AVAILED
1468	14-Mar-2022	TUMKUR	66	TR-1	KIADB V N PURA_220	13:22	17:06	3:44	LINE CLEAR AVAILED
1469	14-Mar-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	10:47	10:56	0:09	HAND TRIPPED
1470	14-Mar-2022	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI 66	13:16	13:20	0:03	LINE FAULT
1471	14-Mar-2022	TUMKUR	66	TR-1	MAVINAKATTE_66	10:11	10:25	0:13	TRANSFORMER FAULT
1472	14-Mar-2022	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	22:10	22:56	0:45	LINE FAULT
1473	14-Mar-2022	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	22:58	23:12	0:13	LINE FAULT
1474	14-Mar-2022	TUMKUR	66	TR-2	PAVAGADA_66	0:08	0:15	0:07	TRANSFORMER FAULT
1475	14-Mar-2022	TUMKUR	66	TR-2	PAVAGADA_66	3:10	3:40	0:30	TRANSFORMER FAULT
1476	14-Mar-2022	TUMKUR	66	TR-2	PAVAGADA_66	7:10	7:15	0:05	TRANSFORMER FAULT
1477	14-Mar-2022	TUMKUR	66	TR-1	THOVINAKERE_66	13:15	14:35	1:20	LINE CLEAR AVAILED
1478	14-Mar-2022	TUMKUR	66	TR-2	THOVINAKERE_66	11:50	13:15	1:25	LINE CLEAR AVAILED
1479	14-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:29	19:39	0:09	LINE FAULT
1480	14-Mar-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:40	16:56	0:16	LINE FAULT
1481	14-Mar-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:12	7:31	0:19	LINE FAULT
1482	14-Mar-2022	TUMKUR	66	THALLAK 220-PR PURA	THALLAK_220	10:45	10:55	0:10	LINE FAULT
1483	14-Mar-2022	TUMKUR	66	THALLAK 220-PR PURA	THALLAK_220	10:54	11:18	0:24	LINE FAULT
1484	14-Mar-2022	TUMKUR	66	THALLAK 220-PR PURA	THALLAK_220	11:56	12:01	0:05	LINE FAULT