

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 20.07.21 TO 26.07.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	20-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVILED
2	20-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
3	20-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALLI_110	15:16	15:52	0:36	LINE CLEAR AVAILED
4	20-Jul-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJJRAMATTI_110	14:00	14:25	0:25	TRANSFORMER FAULT
5	20-Jul-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED PH COMPOUND_110	10:19	12:56	2:37	TRANSFORMER FAULT
6	20-Jul-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUNDAGANUR_110	13:22	14:45	1:23	LINE CLEAR AVAILED
7	20-Jul-21	BAGALKOT	110	110/11KV,HV1	AIGALI_110	21:05 (19.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
8	20-Jul-21	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	10:12	10:33	0:21	LINE CLEAR AVAILED
9	20-Jul-21	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	9:05	16:28	7:23	LINE CLEAR AVAILED
10	20-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
11	20-Jul-21	BAGALKOT	110	220/110KV, LV1	VAJJRAMATTI_220 JK CEMANT_110, VAJJRAMATTI_110, MANTUR_110, MUDHOL_110, MELLIGERI_110, BILAGI_110 KATARKI_110, & SHIRGUPPI_110	22:12	22:52	0:40	TRANSFORMER FAULT
12	20-Jul-21	BAGALKOT	110	220/110KV, LV2	VAJJRAMATTI_220 JK CEMANT_110, VAJJRAMATTI_110, MANTUR_110, MUDHOL_110, MELLIGERI_110, BILAGI_110 KATARKI_110, & SHIRGUPPI_110	22:12	23:05	0:53	TRANSFORMER FAULT
13	20-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
14	20-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
15	20-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
16	20-Jul-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	2:42	2:52	0:10	LINE FAULT
17	20-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
18	20-Jul-21	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110	16:28	17:30	1:02	LINE FAULT
19	20-Jul-21	BAGALKOT	110	HATTARAGI-DADDI	DADDI_110	13:58	14:35	0:37	LINE FAULT
20	20-Jul-21	BAGALKOT	110	HATTARAGI-DADDI	DADDI_110	13:41	13:57	0:16	HAND TRIPPED
21	20-Jul-21	BAGALKOT	110	HATTARGI-HUKKERI	HUKKERI_110	14:40	14:58	0:18	HAND TRIPPED
22	20-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
23	20-Jul-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
24	20-Jul-21	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	14:40	14:50	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
25	20-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
26	20-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
27	20-Jul-21	BAGALKOT	110	TODALBAGI-JAMKHANDI SUGARS	JAMKHNADI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	8:45	16:42	7:57	LINE CLEAR AVAILED
28	20-Jul-21	BAGALKOT	110	VAJRAMATTI220-SHIRGUPPI(BILAGI)	SHIRGUPPI_110	22:51	23:00	0:09	HAND TRIPPED
29	20-Jul-21	BAGALKOT	110	VAJRAMATTI220-JAMBAGI	JAMBAGI_110	22:10	22:50	0:40	LINE FAULT
30	20-Jul-21	BAGALKOT	220	220/110KV, HV1	VAJRAMATTI_220 JK CEMANT_110, VAJRAMATTI_110, MANTUR_110, MUDHOL_110, MELLIGERI_110, BILAGI_110 KATARKI_110, & SHIRGUPPI_110	22:12	22:51	0:39	TRANSFORMER FAULT
31	20-Jul-21	BAGALKOT	220	220/110KV, HV2	VAJRAMATTI_220 JK CEMANT_110, VAJRAMATTI_110, MANTUR_110, MUDHOL_110, MELLIGERI_110, BILAGI_110 KATARKI_110, & SHIRGUPPI_110	22:12	23:05	0:53	TRANSFORMER FAULT
32	20-Jul-21	BAGALKOT	220	AMBEWADI-NAGZARI2	STATION NOT AFFECTED AMBEWADI_220	2:26 (19.07.2021)	9:09 (19.07.2021)	6:43	LINE CHARGED
33	20-Jul-21	BAGALKOT	220	AMBEWADI-NARENDRDRA2	STATION NOT AFFECTED AMBEWADI_220	2:31 (19.07.2021)	9:16 (19.07.2021)	6:45	LINE CHARGED
34	20-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI 2	STATION NOT AFFECTED BELGAUM_220	18:14 (11.07.2021)			LINE OPEN:LINE CLEAR AVILED
35	20-Jul-21	BAGALKOT	220	CHIKKODI-SANKESHWAR	SANKESHWAR_110	13:29	13:30	0:01	LINE FAULT
36	20-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
37	20-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
38	20-Jul-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:01 (12.07.2021)			LINE OPEN:LINE CLEAR AVILED
39	20-Jul-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	16:18 (12.07.1011)			LINE OPEN:LINE CLEAR AVILED
40	20-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
41	20-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
42	20-Jul-21	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	10:20	10:27	0:07	LINE CLEAR AVAILED
43	20-Jul-21	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	14:58	15:01	0:03	LINE CLEAR AVAILED
44	20-Jul-21	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	10:20	10:27	0:07	LINE CLEAR AVAILED
45	20-Jul-21	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	14:58	15:01	0:03	LINE CLEAR AVAILED
46	20-Jul-21	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	16:23	16:28	0:05	LOAD CHANGE OVER
47	20-Jul-21	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	14:54	15:02	0:08	LOAD CHANGE OVER
48	20-Jul-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:28	17:36	0:08	LOAD CHANGE OVER
49	20-Jul-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	10:56	11:05	0:09	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
50	20-Jul-21	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	23:50:00(20/07/2021)			LINE OPEN:LINE CLEAR AVILED
51	20-Jul-21	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	23:50:00(20/07/2021)			LINE OPEN:LINE CLEAR AVILED
52	20-Jul-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	12:22	13:57	1:35	LINE CLEAR AVAILED
53	20-Jul-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:38	12:17	0:39	LINE CLEAR AVAILED
54	20-Jul-21	BENGALURU	66	HAROBEL - KODIHALLI	KODIHALLI, HUNSENHALLI, BIJJAHALLI, HUKUNDA	19:00	19:40	0:40	LINE CLEAR AVAILED
55	20-Jul-21	BENGALURU	66	HV1	BOODIGERE	11:35	16:25	4:50	LINE CLEAR AVAILED
56	20-Jul-21	BENGALURU	66	HV1	GOKULA	12:18	12:33	0:15	TRANSFORMER FAULT
57	20-Jul-21	BENGALURU	66	HV1	KADUGODI	19:11	19:19	0:08	TRANSFORMER FAULT
58	20-Jul-21	BENGALURU	66	HV1	VIJAYANAGARA	10:21	10:56	0:35	MAIN SUPPLY FAILURE
59	20-Jul-21	BENGALURU	66	HV1	VIJAYANAGARA	14:57	15:16	0:19	MAIN SUPPLY FAILURE
60	20-Jul-21	BENGALURU	66	HV1	VIJAYANAGARA	18:30	18:35	0:05	MAIN SUPPLY FAILURE
61	20-Jul-21	BENGALURU	66	HV1	HAROBEL	12:20	13:40	1:19	LINE CLEAR AVAILED
62	20-Jul-21	BENGALURU	66	HV1	CHAKAVELU	17:52	19:23	1:31	LINE CLEAR AVAILED
63	20-Jul-21	BENGALURU	66	HV1	HUKUNDA	19:00	19:47	0:47	LINE CLEAR AVAILED
64	20-Jul-21	BENGALURU	66	HV1	KIADB HARDWARE PARK DEVANAHALLI 220	23:34	23:54	0:19	TRANSFORMER FAULT
65	20-Jul-21	BENGALURU	66	HV1	T GOLAHALLI 220	12:30	14:59	2:29	MAIN SUPPLY FAILURE
66	20-Jul-21	BENGALURU	66	HV1	BIDADI 220	23:50:00(20/07/2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
67	20-Jul-21	BENGALURU	66	HV2	EAST DIVISION COMPOUND 220	10:35	10:37	0:02	LINE CLEAR AVAILED
68	20-Jul-21	BENGALURU	66	HV2	ITI 220	9:28	9:40	0:12	TRANSFORMER FAULT
69	20-Jul-21	BENGALURU	66	HV2	VIJAYANAGARA	10:21	10:57	0:36	MAIN SUPPLY FAILURE
70	20-Jul-21	BENGALURU	66	HV2	VIJAYANAGARA	14:57	15:16	0:19	MAIN SUPPLY FAILURE
71	20-Jul-21	BENGALURU	66	HV2	VIJAYANAGARA	18:30	18:35	0:05	MAIN SUPPLY FAILURE
72	20-Jul-21	BENGALURU	66	HV2	PADMANABHANAGARA	15:55	15:59	0:04	LINE CLEAR AVAILED
73	20-Jul-21	BENGALURU	66	HV2	VIDHURASHWATHA	8:29	8:40	0:10	TRANSFORMER FAULT
74	20-Jul-21	BENGALURU	66	HV2	HOSKOTE 66	13:45	14:27	0:42	LINE CLEAR AVAILED
75	20-Jul-21	BENGALURU	66	HV2	HUKUNDA	19:00	19:47	0:47	LINE CLEAR AVAILED
76	20-Jul-21	BENGALURU	66	HV2	HUKUNDA	13:00	13:10	0:10	TRANSFORMER FAULT
77	20-Jul-21	BENGALURU	66	HV2	BIDADI 220	23:50:00(20/07/2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
78	20-Jul-21	BENGALURU	66	HV3	BIDADI 220	23:50:00(20/07/2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
79	20-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:25	21:32	0:06	LINE FAULT
80	20-Jul-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:25	21:35	0:09	LINE FAULT
81	20-Jul-21	BENGALURU	66	KYSAMBALLI - KGF	KYASAMBALLI, DODAKKARI, ANERSONPETE	15:23	15:28	0:05	LOAD CHANGE OVER
82	20-Jul-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	10:47	11:04	0:16	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
83	20-Jul-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	8:46	8:53	0:06	MAIN SUPPLY FAILURE
84	20-Jul-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	8:46	8:53	0:06	MAIN SUPPLY FAILURE
85	20-Jul-21	BENGALURU	66	MANCHENAHALLI - GOWRIBIDANUR 220	MANCHENAHALLI	15:19	17:10	1:50	LINE CLEAR AVAILED
86	20-Jul-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	10:20	11:03	0:43	LINE CLEAR AVAILED
87	20-Jul-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	14:58	15:16	0:18	LINE CLEAR AVAILED
88	20-Jul-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	18:30	18:37	0:07	LINE CLEAR AVAILED
89	20-Jul-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	10:20	11:03	0:43	LINE CLEAR AVAILED
90	20-Jul-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	14:58	15:16	0:18	LINE CLEAR AVAILED
91	20-Jul-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	18:30	18:37	0:07	LINE CLEAR AVAILED
92	20-Jul-21	BENGALURU	66	T GOLAHALLI - KGF	KYASAMBALLI, DODAKKARI, ANERSONPETE	12:30	12:35	0:05	MAIN SUPPLY FAILURE
93	20-Jul-21	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI, GOWNPALLI	21:45	22:07	0:22	LINE FAULT
94	20-Jul-21	BENGALURU	66	TADIGOLU - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI, GOWNPALLI	21:45	22:07	0:22	LINE FAULT
95	20-Jul-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	9:05	9:59	0:54	LINE CLEAR AVAILED
96	20-Jul-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	16:32	17:22	0:50	LINE CLEAR AVAILED
97	20-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
98	20-Jul-21	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	10:20	10:27	0:07	MAIN SUPPLY FAILURE
99	20-Jul-21	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	14:58	15:01	0:03	MAIN SUPPLY FAILURE
100	20-Jul-21	BENGALURU	220	HV1	T GOLAHALLI 220	12:30	14:59	2:29	MAIN SUPPLY FAILURE
101	20-Jul-21	BENGALURU	220	HV2	SRS PEENYA 220	10:20	11:05	0:45	TRANSFORMER FAULT
102	20-Jul-21	BENGALURU	220	HV2	T GOLAHALLI 220	12:30	14:59	2:29	MAIN SUPPLY FAILURE
103	20-Jul-21	BENGALURU	220	HV2	BIDADI 220	23:50:00(20/07/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
104	20-Jul-21	BENGALURU	220	HV5	SRS PEENYA 220	16:30	18:48	2:18	TRANSFORMER FAULT
105	20-Jul-21	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	10:20	10:40	0:20	MAIN SUPPLY FAILURE
106	20-Jul-21	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	14:58	15:06	0:08	MAIN SUPPLY FAILURE
107	20-Jul-21	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	18:30	18:35	0:05	MAIN SUPPLY FAILURE
108	20-Jul-21	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	NO STATION AFFECTED	10:20	10:50	0:30	LINE FAULT
109	20-Jul-21	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	10:20	10:40	0:20	LINE FAULT
110	20-Jul-21	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	14:58	15:06	0:08	LINE FAULT
111	20-Jul-21	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	18:30	18:35	0:05	LINE FAULT
112	20-Jul-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	10:20	11:28	1:08	LINE FAULT
113	20-Jul-21	BENGALURU	220	SRS PEENYA 220 - HEBBAL 220	NO STATION AFFECTED	10:20	11:03	0:43	LINE FAULT
114	20-Jul-21	BENGALURU	220	T GOLAHALLI 220 - PGCIL 1	T GOLAHALLI 220	12:30	14:59	2:29	LINE CLEAR AVAILED
115	20-Jul-21	BENGALURU	220	T GOLAHALLI 220 - PGCIL 2	T GOLAHALLI 220	12:30	14:59	2:29	LINE CLEAR AVAILED
116	20-Jul-21	GULBARGA	66	ITTAGI-SUZLON1,2	ITTAGI_220	10:05	10:15	0:10	LINE CLEAR AVAILED
117	20-Jul-21	GULBARGA	66	KOGALI-ATRSLR	KOGALI_66	10:03	10:18	0:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
118	20-Jul-21	GULBARGA	66	KUDALIGI-BANAVEKAL	BANAVEKAL_66	2:10	4:20	2:10	LINE CLEAR AVAILED
119	20-Jul-21	GULBARGA	66	KUDALIGI-BANAVEKAL	BANAVEKAL_66	13:32	13:42	0:10	LINE CLEAR AVAILED
120	20-Jul-21	GULBARGA	110	GUTKAL-MYLAR	MYLAR_110	14:30	14:50	0:20	LINE CLEAR AVAILED
121	20-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
122	20-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
123	20-Jul-21	GULBARGA	110	HV1	CHORNOOR_66	13:35	14:00	0:25	TRANSFORMER FAULT
124	20-Jul-21	GULBARGA	110	HV1	NIRNA_110	18:53	19:00	0:07	TRANSFORMER FAULT
125	20-Jul-21	GULBARGA	110	HV2	SHAKTINAGAR_110	10:03	10:50	0:47	LINE CLEAR AVAILED
126	20-Jul-21	GULBARGA	110	HV2	SREERAMANAGAR_110	10:40	11:10	0:30	TRANSFORMER FAULT
127	20-Jul-21	GULBARGA	110	HV2	CHORNOOR_66	16:05	16:40	0:35	LINE CLEAR AVAILED
128	20-Jul-21	GULBARGA	110	HV2	CHORNOOR_66	16:50	17:00	0:10	LINE CLEAR AVAILED
129	20-Jul-21	GULBARGA	110	KAPNOOR-ALAND	ALAND110_KADGANCHI110	7:01	7:15	0:14	LINE FAULT
130	20-Jul-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	6:16	6:23	0:07	LINE FAULT
131	20-Jul-21	GULBARGA	110	MADIYAL-MADIYAL	MADIYAL_110	6:15	6:26	0:11	MAIN SUPPLY FAILURE
132	20-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	21:51	21:59	0:08	LINE FAULT
133	20-Jul-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	20:48	20:58	0:10	LINE FAULT
134	20-Jul-21	GULBARGA	110	MALLAT-RTPS	MALLAT_220	17:22	17:40	0:18	LINE FAULT
135	20-Jul-21	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSKAR,HARE KRISHNA_IPP	9:02	12:32	3:30	LINE CLEAR AVAILED
136	20-Jul-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	3:05	3:10	0:05	LINE FAULT
137	20-Jul-21	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	9:13	14:55	5:42	LINE CLEAR AVAILED
138	20-Jul-21	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	9:15	13:35	4:20	MAIN SUPPLY FAILURE
139	20-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDHAPUR_110,WA DEGERA_110,SANNATHI_IPP,CORE GREEN SUGAR	5:15	5:42	0:27	LINE FAULT
140	20-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDHAPUR_110,WA DEGERA_110,SANNATHI_IPP,CORE GREEN SUGAR	14:10	16:15	2:05	LINE CLEAR AVAILED
141	20-Jul-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:02	4:12	0:10	LINE FAULT
142	20-Jul-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	4:00	4:10	0:10	LINE FAULT
143	20-Jul-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	23:30	23:40	0:10	LINE FAULT
144	20-Jul-21	GULBARGA	110	SUZLON2-MYLAR	MYLAR_110	14:30	14:50	0:20	LINE CLEAR AVAILED
145	20-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
146	20-Jul-21	GULBARGA	220	HV1	HUMNABAD_220	13:57	14:30	0:33	TRANSFORMER FAULT
147	20-Jul-21	GULBARGA	220	HV1	HUMNABAD_220	14:30	14:53	0:23	LINE CLEAR AVAILED
148	20-Jul-21	GULBARGA	220	HV1	SHAHAPUR_220	5:15	5:43	0:28	TRANSFORMER FAULT
149	20-Jul-21	GULBARGA	220	ITTAGI-BMM_IPP	BMM_220	11:36	12:28	0:52	LINE FAULT
150	20-Jul-21	GULBARGA	220	KUSHTAGI-ODPWIND_IPP	KUSHTAGI_220	14:24	15:49	1:25	LINE CLEAR AVAILED
151	20-Jul-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	17:40(20.07.21)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
152	20-Jul-21	GULBARGA	220	SEDAM-RTPS1	RTPS_220	15:36	15:42	0:06	LINE CLEAR AVAILED
153	20-Jul-21	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	4:21(19.07.2021)	20:20(20.07.2021)	39:59HRS	LINE CHARGED
154	20-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	23:11(19.07.2021)			LINE OPEN:LINE CLEAR AVILED
155	20-Jul-21	HASSAN	66	BELUR66-HASSAN	BELUR_6666	15:25	15:47	0:22	MAIN SUPPLY FAILURE
156	20-Jul-21	HASSAN	66	BELUR66-MUDIGERE	BELUR_6666	15:25	15:52	0:27	LINE FAULT
157	20-Jul-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	0:41	7:55	7:14	LINE FAULT
158	20-Jul-21	HASSAN	66	HV1	MAGGE_66	12:49	14:42	1:53	LINE CLEAR AVAILED
159	20-Jul-21	HASSAN	66	HV1	NAGARTHI_66	11:03	11:49	0:46	LINE CLEAR AVAILED
160	20-Jul-21	HASSAN	66	HV2	MAGGE_66	12:39	14:41	2:02	LINE CLEAR AVAILED
161	20-Jul-21	HASSAN	66	HV2	SALAGAME_66	10:57	12:02	1:05	LINE CLEAR AVAILED
162	20-Jul-21	HASSAN	66	LV2	CRPATNA_220	11:41	12:04	0:23	LINE CLEAR AVAILED
163	20-Jul-21	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLY_66	15:30	15:49	0:19	LINE CLEAR AVAILED
164	20-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
165	20-Jul-21	HASSAN	110	HV1	KARAYA_110	10:04	13:28	3:24	LINE CLEAR AVAILED
166	20-Jul-21	HASSAN	110	HV1	MOODABIDRE_110	9:00	17:40	8:40	LINE CLEAR AVAILED
167	20-Jul-21	HASSAN	110	HV2	HALADY_110	14:56	15:00	0:04	TRANSFORMER FAULT
168	20-Jul-21	HASSAN	110	HV2	BAIKAMPADY_110	10:55	12:18	1:23	LINE CLEAR AVAILED
169	20-Jul-21	HASSAN	110	HV2	MOODABIDRE_110	9:00	10:47	1:47	LINE CLEAR AVAILED
170	20-Jul-21	HASSAN	110	HV2	MOODABIDRE_110	11:30	17:40	6:10	LINE CLEAR AVAILED
171	20-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
172	20-Jul-21	HASSAN	220	HV2	CRPATNA_220	11:41	12:04	0:23	LINE CLEAR AVAILED
173	20-Jul-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:06	11:56	1:50	LINE CLEAR AVAILED
174	20-Jul-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:06	12:00	1:54	NFBC ISSUED
175	20-Jul-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	6:52	13:52	7:00	LINE FAULT
176	20-Jul-21	MYSURU	66	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	10:49	13:39	2:49	HAND TRIPPED
177	20-Jul-21	MYSURU	66	HV1	BETTADHAPURA_66	11:30	13:53	2:22	LINE CLEAR AVAILED
178	20-Jul-21	MYSURU	66	HV1	CHINAKURALI_66	13:55	14:00	0:04	HAND TRIPPED
179	20-Jul-21	MYSURU	66	HV1	DATTAGALLY_66	11:43	12:11	0:27	LINE CLEAR AVAILED
180	20-Jul-21	MYSURU	66	HV1	HALAGUR_66	12:06	13:22	1:15	LINE CLEAR AVAILED
181	20-Jul-21	MYSURU	66	HV2	BGPURA_66	9:34	10:13	0:39	LINE CLEAR AVAILED
182	20-Jul-21	MYSURU	66	HV2	DATTAGALLY_66	11:34	16:19	4:44	LINE CLEAR AVAILED
183	20-Jul-21	MYSURU	66	HV2	HALAGUR_66	10:15	12:07	1:52	LINE CLEAR AVAILED
184	20-Jul-21	MYSURU	66	KHONALAGERE-IGLOOR	K_HONNALGERE_66	9:05	17:25	8:20	HAND TRIPPED
185	20-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
186	20-Jul-21	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	18:41	20:57	2:16	LINE CLEAR AVAILED
187	20-Jul-21	MYSURU	66	TUBINKERE-MANDYA 4	NO STATIONS EFFECTED	11:29	12:50	1:20	LINE CLEAR AVAILED
188	20-Jul-21	MYSURU	66	VAJMANGALA-DEVVNOOR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	13:24	13:35	0:11	HAND TRIPPED
189	20-Jul-21	MYSURU	66	VAJMANGALA-DEVVNOOR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	11:07	11:28	0:20	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
190	20-Jul-21	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	11:07	11:28	0:20	HAND TRIPPED
191	20-Jul-21	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	13:23	13:36	0:13	HAND TRIPPED
192	20-Jul-21	MYSURU	220	HV2	VAJAMANGALA_220	11:02	13:29	2:27	LINE CLEAR AVAILED
193	20-Jul-21	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	22:23	22:25	0:01	HAND TRIPPED
194	20-Jul-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	12:47	12:57	0:10	MAIN SUPPLY FAILURE
195	20-Jul-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:03	13:06	0:02	MAIN SUPPLY FAILURE
196	20-Jul-21	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66	13:06	13:09	0:03	MAIN SUPPLY FAILURE
197	20-Jul-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:04	17:45	1:40	LINE CLEAR AVAILED
198	20-Jul-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	7:16	17:36	10:19	LINE CLEAR AVAILED
199	20-Jul-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:31	18:37	0:05	LINE FAULT
200	20-Jul-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:42	18:55	0:13	LINE FAULT
201	20-Jul-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	19:09	19:16	0:06	LINE FAULT
202	20-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:42	9:54	0:12	LINE FAULT
203	20-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:07	10:44	0:36	LINE FAULT
204	20-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	16:15	16:34	0:19	LINE FAULT
205	20-Jul-21	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	14:45	15:35	0:49	HAND TRIPPED
206	20-Jul-21	TUMKUR	66	NAYAKANHATTI- HIREMALLANAHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	11:12	11:14	0:02	LINE FAULT
207	20-Jul-21	TUMKUR	66	THALLAK 220kV -BGKERE 1	BG KERE66	12:46	12:56	0:09	LINE FAULT
208	20-Jul-21	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	13:54	14:10	0:15	HAND TRIPPED
209	20-Jul-21	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	19:00	19:03	0:03	HAND TRIPPED
210	20-Jul-21	TUMKUR	66	TR-1	GARAGA_66	11:01	15:05	4:03	LINE CLEAR AVAILED
211	20-Jul-21	TUMKUR	66	TR-2	GARAGA_66	11:02	15:05	4:03	LINE CLEAR AVAILED
212	20-Jul-21	TUMKUR	66	TR-2	RANGANATHAPURA_66	7:49	8:44	0:54	LINE CLEAR AVAILED
213	20-Jul-21	TUMKUR	66	TR-3	HARIYABBE_66	17:15	17:45	0:30	LINE CLEAR AVAILED
214	20-Jul-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:33	15:07	3:34	LINE FAULT
215	21-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
216	21-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
217	21-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_110	6:04	6:22	0:18	TRANSFORMER FAULT
218	21-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SHIRGAON_110	14:30	15:02	0:32	LINE CLEAR AVAILED
219	21-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HUBLI_220	10:52	13:49	2:57	LINE CLEAR AVAILED
220	21-Jul-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED RANEBENNUR_220	11:45	15:57	4:12	LINE CLEAR AVAILED
221	21-Jul-21	BAGALKOT	110	110/11KV,HV1	AIGALI_110	21:05 (19.07.2021)	12:35 (21.07.2021)	15:30	TRANSFORMER CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
222	21-Jul-21	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	12:30	12:59	0:29	TRANSFORMER FAULT
223	21-Jul-21	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	14:31	14:35	0:04	LINE CLEAR AVAILED
224	21-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
225	21-Jul-21	BAGALKOT	110	110/33KV,HV1	ALAGAWADI_33 HIDIKAL_110	21:07 (21.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
226	21-Jul-21	BAGALKOT	110	110/33KV,HV1	BALEKUNDRI_33,GYARISAN_33 KANABARGI LAYOUT_110	13:52	16:19	2:27	HAND TRIPPED
227	21-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
228	21-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
229	21-Jul-21	BAGALKOT	110	AMBEWADI-SUPA2	AMBEWADI_220	0:49	0:57	0:08	LINE FAULT
230	21-Jul-21	BAGALKOT	110	ASHOK IRON PLANT-MACHE	MACHE_110	15:09	16:03	0:54	LINE CLEAR AVAILED
231	21-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
232	21-Jul-21	BAGALKOT	110	BELGAUM220-HUDLI(ANKALAGI)	HUDLI_110	16:31	20:10	3:39	HAND TRIPPED
233	21-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
234	21-Jul-21	BAGALKOT	110	HAVERI220 -BYADAGI	BYADAGI_110	19:01	19:24	0:23	LINE FAULT
235	21-Jul-21	BAGALKOT	110	MALGHAN(B)-BASAVA SUGAR	MALGHAN(B)_110	8:54	9:02	0:08	LINE FAULT
236	21-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
237	21-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
238	21-Jul-21	BAGALKOT	110	TAKKALKI-TIKOTA	TIKOTA_110	13:50	14:36	0:46	LINE CLEAR AVAILED
239	21-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
240	21-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
241	21-Jul-21	BAGALKOT	220	220/110KV,HV1,LV1	BELGAUM_220,UCHHAGOAN_110,NE HARUNAGAR_110,VADAGOAN_110	16:31	19:53	3:22	TRANSFORMER FAULT
242	21-Jul-21	BAGALKOT	220	220/110KV,LV2	BELGAUM_220	16:07	16:16	0:09	HAND TRIPPED
243	21-Jul-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	4:04	9:06	5:02	LOAD CURTAILMENT
244	21-Jul-21	BAGALKOT	220	BAGEWADI-ATRIA1	BAGEWADI_220	10:52	11:40	0:48	LOAD CURTAILMENT
245	21-Jul-21	BAGALKOT	220	BAGEWADI-FORTUNE LINE 1	BAGEWADI_220	10:52	11:40	0:48	LOAD CURTAILMENT
246	21-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI 2	STATION NOT AFFECTED BELGAUM_220	18:14 (11.07.2021)	16:15 (21.07.2021)	22:01	LINE CHARGED
247	21-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
248	21-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
249	21-Jul-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:01 (12.07.2021)	17:20 (21.07.2021)	23:19	LINE CHARGED
250	21-Jul-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	16:18 (12.07.1011)	17:20 (21.07.2021)	1:02	LINE CHARGED
251	21-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
252	21-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
253	21-Jul-21	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	23:50:00(20/07/2021)	00:19:00(21/07/2021)	0:29	LINE CHARGED
254	21-Jul-21	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	23:50:00(20/07/2021)	00:19:00(21/07/2021)	0:29	LINE CHARGED
255	21-Jul-21	BENGALURU	66	DODALAHALLI - GRT SOLAR (IPP)	NO STATION AFFECTED	9:20	17:17	7:57	MAIN SUPPLY FAILURE
256	21-Jul-21	BENGALURU	66	DODALAHALLI - KANAKPURA 220	DODALAHALLI	9:20	12:50	3:30	LINE FAULT
257	21-Jul-21	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	10:10	10:15	0:05	LOAD CHANGE OVER
258	21-Jul-21	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	8:28	8:58	0:30	MAIN SUPPLY FAILURE
259	21-Jul-21	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	10:17	10:32	0:15	MAIN SUPPLY FAILURE
260	21-Jul-21	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	8:28	8:58	0:30	MAIN SUPPLY FAILURE
261	21-Jul-21	BENGALURU	66	HV1	BOODIGERE	8:30	10:00	1:30	LINE CLEAR AVAILED
262	21-Jul-21	BENGALURU	66	HV1	DODALAHALLI	9:20	12:44	3:24	MAIN SUPPLY FAILURE
263	21-Jul-21	BENGALURU	66	HV1	BIDADI 220	23:50:00(20/07/2021)	00:21:00(21/07/2021)	0:31	TRANSFORMER CHARGED
264	21-Jul-21	BENGALURU	66	HV2	DODALAHALLI	9:20	12:50	3:30	MAIN SUPPLY FAILURE
265	21-Jul-21	BENGALURU	66	HV2	BIDADI 220	23:50:00(20/07/2021)	00:21:00(21/07/2021)	0:31	TRANSFORMER CHARGED
266	21-Jul-21	BENGALURU	66	HV3	BIDADI 220	23:50:00(20/07/2021)	00:22:00(21/07/2021)	0:32	TRANSFORMER CHARGED
267	21-Jul-21	BENGALURU	66	IISC - HEBBAL 220	IISC	9:07	9:10	0:03	LOAD CHANGE OVER
268	21-Jul-21	BENGALURU	66	IISC - NRS 220	IISC	14:13	14:17	0:04	LOAD CHANGE OVER
269	21-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:55	22:08	0:13	LINE FAULT
270	21-Jul-21	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	8:28	8:40	0:12	LINE FAULT
271	21-Jul-21	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	13:55	15:00	1:05	LINE CLEAR AVAILED
272	21-Jul-21	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	8:28	8:42	0:14	MAIN SUPPLY FAILURE
273	21-Jul-21	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	13:40	13:44	0:04	LOAD CHANGE OVER
274	21-Jul-21	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	8:28	10:10	1:42	LINE FAULT
275	21-Jul-21	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	8:28	13:00	4:32	LINE FAULT
276	21-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
277	21-Jul-21	BENGALURU	220	HV2	BIDADI 220	23:50:00(20/07/2021)	00:11:00(21/07/2021)	0:21	TRANSFORMER CHARGED
278	21-Jul-21	BENGALURU	220	HV3	SRS PEENYA 220	16:13	17:36	1:23	TRANSFORMER FAULT
279	21-Jul-21	BENGALURU	220	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI	16:13	17:36	1:23	LINE FAULT
280	21-Jul-21	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	5:25	5:40	0:15	LINE FAULT
281	21-Jul-21	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINHADAGALI_66,HOLAGUNDI_66	11:38	12:05	0:27	LINE CLEAR AVAILED
282	21-Jul-21	GULBARGA	110	BADALADKU-HANASI	HANSI_66	11:00	12:25	1:25	MAIN SUPPLY FAILURE
283	21-Jul-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	2:31	2:39	0:08	LINE FAULT
284	21-Jul-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	6:08	6:17	0:09	LINE FAULT
285	21-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, KAMALNAGAR_110	4:18	4:26	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
286	21-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
287	21-Jul-21	GULBARGA	110	HV1	CHORNOOR_66	8:10	9:25	1:15	LINE CLEAR AVAILED
288	21-Jul-21	GULBARGA	110	HV2	MANVI_110	11:29	11:35	0:06	TRANSFORMER FAULT
289	21-Jul-21	GULBARGA	110	KAPNOOR-GULBARGA1,2	GULBARGA NORTH_110,GULBARGA SOUTH_110,GULBARGA UNIVERSITY_110	1:09	1:20	0:11	LINE FAULT
290	21-Jul-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS_IPP	4:45	4:52	0:07	LINE FAULT
291	21-Jul-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	15:51	16:25	0:34	LINE CLEAR AVAILED
292	21-Jul-21	GULBARGA	110	MASKI-RENEW SLR	MASKI_110	4:02	4:12	0:10	LINE FAULT
293	21-Jul-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	4:03	4:13	0:10	LINE FAULT
294	21-Jul-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	5:38	5:53	0:15	LINE FAULT
295	21-Jul-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	16:06	16:20	0:14	LINE FAULT
296	21-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	3:50	4:20	0:30	LINE FAULT
297	21-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	5:15	5:50	0:35	LINE FAULT
298	21-Jul-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	5:23	5:35	0:12	LINE FAULT
299	21-Jul-21	GULBARGA	110	PDHALLI-BASAI_IPP	PD_HALLI_110	21:50	23:05	1:15	LINE FAULT
300	21-Jul-21	GULBARGA	110	PDHALLI-HALKUNDI	PD_HALLI_110	21:50	22:15	0:25	MAIN SUPPLY FAILURE
301	21-Jul-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	9:03	9:09	0:06	LINE FAULT
302	21-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT H_110, VALKAMDINNI_110(IDLE)	23:17	23:39	0:22	LINE FAULT
303	21-Jul-21	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	0:20	0:24	0:04	MAIN SUPPLY FAILURE
304	21-Jul-21	GULBARGA	110	SEDAM-VICAT SAGAR	VICAT SAGAR_IPP	5:54	6:20	0:26	LINE FAULT
305	21-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	11:09	16:45	5:36	LINE FAULT
306	21-Jul-21	GULBARGA	110	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	20:38(21.07.21)			LINE OPEN:LINE CLEAR AVAILED
307	21-Jul-21	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110.MUDDUR_110	16:05	16:15	0:10	LINE FAULT
308	21-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
309	21-Jul-21	GULBARGA	220	HV1	SEDAM_220	2:34	3:15	0:41	TRANSFORMER FAULT
310	21-Jul-21	GULBARGA	220	LINGAPUR-JINDAL2	JINDAL_220	10:45	14:30	3:45	NFBC ISSUED
311	21-Jul-21	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	21:25	21:40	0:15	LINE FAULT
312	21-Jul-21	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	12:23	15:38	3:15	NFBC ISSUED
313	21-Jul-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	17:40(20.07.2021)			LINE OPEN:LINE CLEAR AVAILED
314	21-Jul-21	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	1:15	3:48	2:33	LINE CLEAR AVAILED
315	21-Jul-21	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	3:00	4:08	1:08	LINE FAULT
316	21-Jul-21	GULBARGA	220	SEDAM-TANDUR(IDLE LINE)	TANDUR_220	2:34	6:06	3:32	LINE FAULT
317	21-Jul-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	23:38(21.07.21)			LINE OPEN:LINE CLEAR AVAILED
318	21-Jul-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	0:38	6:17	5:39	LINE CLEAR AVAILED
319	21-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	23:11(19.07.2021)	10:30(21.07.2021)	35:19HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
320	21-Jul-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	16:20	16:25	0:05	LINE FAULT
321	21-Jul-21	HASSAN	110	BLGMBA-ASIAN FAB_SLR	BELAGUMBA_110	10:08	11:27	1:19	HAND TRIPPED
322	21-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
323	21-Jul-21	HASSAN	110	HV1	HOSUR_110	12:51	13:31	0:40	LINE CLEAR AVAILED
324	21-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
325	21-Jul-21	HASSAN	110	LPH-LST3	lph_gen	21:03(21.7.2021)			LINE OPEN:LINE FAULT
326	21-Jul-21	HASSAN	110	LPH-LST3	lph_gen	11:12	13:40	2:28	NFBC ISSUED
327	21-Jul-21	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	21:03(21.7.2021)			LINE OPEN:LINE FAULT
328	21-Jul-21	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	11:20	13:39	2:19	LINE CLEAR AVAILED
329	21-Jul-21	MYSURU	66	BETTADAPURA-KUSHALNAGARA	BETTADHAPURA_66	23:00	23:27	0:27	LINE FAULT
330	21-Jul-21	MYSURU	66	DATAGALLY-HOOTAGALLY	DATAGALLY_66	23:34 (21/07/2021)			LINE OPEN:LINE FAULT
331	21-Jul-21	MYSURU	66	HV1	DATAGALLY_66	23:50 (21/07/2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
332	21-Jul-21	MYSURU	66	HV2	DATAGALLY_66	23:50 (21/07/2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
333	21-Jul-21	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	16:01	17:20	1:18	LINE CLEAR AVAILED
334	21-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
335	21-Jul-21	MYSURU	66	PERYAPATNA-HANGUD	POMMANPETE_66,VIRAJPETE_66 & HANGUD_66	2:00	2:07	0:07	LINE FAULT
336	21-Jul-21	TUMKUR	66	BEVINAHALI- AFTL SOLAR	AFTLSOLAR_IPP_66	19:03	19:15	0:11	LINE FAULT
337	21-Jul-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:33	16:27	0:54	HAND TRIPPED
338	21-Jul-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:39	10:41	0:01	LINE CLEAR AVAILED
339	21-Jul-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	9:56	10:29	0:32	LINE FAULT
340	21-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:20	12:42	0:22	LINE FAULT
341	21-Jul-21	TUMKUR	66	TR-1	MADADAKERE_66	15:39	15:48	0:08	TRANSFORMER FAULT
342	21-Jul-21	TUMKUR	66	TR-2	ANCHEPALYA_220	9:14	17:50	8:35	LINE CLEAR AVAILED
343	21-Jul-21	TUMKUR	66	TR-3	HARIYABBE_66	15:21	15:41	0:20	LINE CLEAR AVAILED
344	21-Jul-21	TUMKUR	220	TR-2	ANCHEPALYA_220	9:14	17:50	8:35	LINE CLEAR AVAILED
345	21-Jul-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	0:02	9:35	9:32	LINE FAULT
346	22-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVILED
347	22-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
348	22-Jul-21	BAGALKOT	110	110/11KV,HV2	RON_110	14:57	15:35	0:38	TRANSFORMER FAULT
349	22-Jul-21	BAGALKOT	110	110/11KV,HV2	HIREKERUR_110	21:39 (22.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
350	22-Jul-21	BAGALKOT	110	110/11KV,HV2	TUMMINAKATTI_110	12:35	12:51	0:16	TRANSFORMER FAULT
351	22-Jul-21	BAGALKOT	110	110/11KV,HV2	TUMMINAKATTI_110	16:58	17:33	0:35	TRANSFORMER FAULT
352	22-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
353	22-Jul-21	BAGALKOT	110	110/33KV,HV1	ALAGAWADI_33 HIDIKAL_110	21:07 (21.07.2021)	12:04 (22.07.2021)	14:57 hrs	TRANSFORMER CHARGED
354	22-Jul-21	BAGALKOT	110	ALAMEL-JAMAKHANDI SUGARS	ALMEL_110	19:49	20:06	0:17	LINE FAULT
355	22-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
356	22-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
357	22-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
358	22-Jul-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_220	3:58	4:09	0:11	LINE FAULT
359	22-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
360	22-Jul-21	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	11:55	12:05	0:10	HAND TRIPPED
361	22-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
362	22-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
363	22-Jul-21	BAGALKOT	110	SAMBAPUR ROAD-RVNL	STATION NOT AFFECTED SAMBAPUR ROAD_110	12:35	13:29	0:54	NFBC ISSUED
364	22-Jul-21	BAGALKOT	110	SAVANUR-AFTL SOLAR (HAVERI)	SAVANUR_110	20:37	20:45	0:08	LINE FAULT
365	22-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
366	22-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
367	22-Jul-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	19:09 (22.07.2021)			LOAD CURTAILMENT
368	22-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
369	22-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
370	22-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)			LOAD CURTAILMENT
371	22-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)			LOAD CURTAILMENT
372	22-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
373	22-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
374	22-Jul-21	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	15:20	15:25	0:05	LOAD CHANGE OVER
375	22-Jul-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENNIGADALE, CHELUR, CHAKAVELU	14:53	15:03	0:09	LINE FAULT
376	22-Jul-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	8:11	8:14	0:03	LOAD CHANGE OVER
377	22-Jul-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	6:38	6:51	0:13	MAIN SUPPLY FAILURE
378	22-Jul-21	BENGALURU	66	HV1	BOODIGERE	14:20	14:30	0:10	LINE CLEAR AVILED
379	22-Jul-21	BENGALURU	66	HV1	DODDABELAVANGALA	12:12	12:46	0:34	LINE CLEAR AVILED
380	22-Jul-21	BENGALURU	66	HV1	HAROBEL	15:16	16:35	1:19	LINE CLEAR AVILED
381	22-Jul-21	BENGALURU	66	HV1	HOSPALYA CIRCLE	9:31	9:34	0:02	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
382	22-Jul-21	BENGALURU	66	HV1	T GOLLAHALLI	23:10:00(23/07/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
383	22-Jul-21	BENGALURU	66	HV2	HONNIGANAHALLI	13:23	15:55	2:31	LINE CLEAR AVAILED
384	22-Jul-21	BENGALURU	66	HV2	MELUR	12:05	13:00	0:54	LINE CLEAR AVAILED
385	22-Jul-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	5:53	6:10	0:17	LINE FAULT
386	22-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:55	17:25	0:30	LOAD CURTAILMENT
387	22-Jul-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	6:38	6:51	0:12	LINE FAULT
388	22-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
389	22-Jul-21	GULBARGA	110	HUMNABAD-MANEKHELI	MANEKHELI_110	6:10	6:20	0:10	LINE FAULT
390	22-Jul-21	GULBARGA	110	HUMNABAD-MANEKHELI	MANEKHELI_110	17:57	19:09	1:12	LINE FAULT
391	22-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
392	22-Jul-21	GULBARGA	110	HV2	SREERAMANAGAR_110	10:45	11:23	0:38	TRANSFORMER FAULT
393	22-Jul-21	GULBARGA	110	KOTTUR-UJJANI	KOTTUR_66	14:55	15:15	0:20	LINE CLEAR AVAILED
394	22-Jul-21	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	12:10	12:15	0:05	MAIN SUPPLY FAILURE
395	22-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	23:00	23:30	0:30	LINE FAULT
396	22-Jul-21	GULBARGA	110	PDHALLI-CLN SLR	PD_HALLI_110	5:26(22.07.2021)			LINE OPEN:LINE FAULT
397	22-Jul-21	GULBARGA	110	PDHALLI-HALKUNDI	PD_HALLI_110	5:26	5:49	0:23	MAIN SUPPLY FAILURE
398	22-Jul-21	GULBARGA	110	PDHALLI-HALKUNDI	PD_HALLI_110	5:50	6:00	0:10	MAIN SUPPLY FAILURE
399	22-Jul-21	GULBARGA	110	PDHALLI-JANAKI_IPP	PD_HALLI_110	5:26	6:00	0:34	LINE FAULT
400	22-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDHAPUR_110,WA DEGERA_110,SANNATHI_IPP,CORE GREEN SUGAR	2:36	2:46	0:10	LINE FAULT
401	22-Jul-21	GULBARGA	110	SINDHNOOR220 -RAICHUR2	ADAVI AMBRESHWARA_110	20:25	20:35	0:10	LINE FAULT
402	22-Jul-21	GULBARGA	110	SINDHNOOR220 -RAICHUR2	ADAVI AMBRESHWARA_110	22:27	22:37	0:10	LINE FAULT
403	22-Jul-21	GULBARGA	110	SINDHNOOR220 -SINDHNOOR1	SINDHNOOR_110	5:50	6:00	0:10	LINE FAULT
404	22-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
405	22-Jul-21	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	12:13	16:58	4:45	NFBC ISSUED
406	22-Jul-21	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	17:40(20.07.2021)	15:45(22.07.2021)	46:05HRS	LINE CHARGED
407	22-Jul-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	5:38	10:06	4:28	LINE FAULT
408	22-Jul-21	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	20:38(21.07.2021)	00:50(22.07.2021)	04:12HRS	LINE CHARGED
409	22-Jul-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	23:38(21.07.2021)	07:20(22.07.2021)	08:12HRS	LINE CHARGED
410	22-Jul-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	5:35	6:23	0:48	LINE FAULT
411	22-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	21:22(21.07.2021)	8:03(22.07.2021)	10:41HRS	LINE CHARGED
412	22-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	22:53(22.07.2021)			LINE OPEN:LINE CLEAR AVAILED
413	22-Jul-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:42	9:54	0:12	LINE FAULT
414	22-Jul-21	HASSAN	66	HV1	SHANTHIGRAMA_66	10:31	11:04	0:33	LINE CLEAR AVAILED
415	22-Jul-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	17:01	18:02	1:01	HAND TRIPPED
416	22-Jul-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	16:55	17:21	0:26	HAND TRIPPED
417	22-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
418	22-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
419	22-Jul-21	HASSAN	110	KADUR-NERALK	KADUR_220	18:10	18:40	0:30	HAND TRIPPED
420	22-Jul-21	HASSAN	110	KADUR-NGNHL	KADUR_220	16:59	18:30	1:31	HAND TRIPPED
421	22-Jul-21	HASSAN	110	KADUR-TNGL	KADUR_220	17:00	17:12	0:12	HAND TRIPPED
422	22-Jul-21	HASSAN	110	LPH-LST3	lph_gen	21:03(21.7.2021)	12:46 (22.07.2021)	15:43hrs	LINE CHARGED
423	22-Jul-21	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:35	12:54	2:19	LINE CLEAR AVAILED
424	22-Jul-21	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_400	21:03(21.7.2021)	12:42 (22.07.2021)	15:39hrs	LINE CHARGED
425	22-Jul-21	HASSAN	220	KEMAR-UPCL2	KEMAR_220	10:08	16:02	5:54	LINE CLEAR AVAILED
426	22-Jul-21	HASSAN	220	UPCL-KEMAR1	upcl_gen	15:08	15:15	0:07	LINE FAULT
427	22-Jul-21	HASSAN	220	UPCL-KEMAR2	upcl_gen	10:08	16:02	5:54	LINE CLEAR AVAILED
428	22-Jul-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	15:05	20:56	5:51	LINE FAULT
429	22-Jul-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	15:08	20:57	5:49	LINE FAULT
430	22-Jul-21	MYSURU	66	DATAGALLY-HOOTAGALLY	DATAGALLY_66	23:34 (21/07/2021)	0:45 (22/07/2021)	1:11 HRS	LINE CHARGED
431	22-Jul-21	MYSURU	66	HV1	DATAGALLY_66	23:50 (21/07/2021)	1:15 (22/07/2021)	1:25 HRS	TRANSFORMER CHARGED
432	22-Jul-21	MYSURU	66	HV2	DATAGALLY_66	23:50 (21/07/2021)	1:02 (22/07/2021)	1:12 HRS	TRANSFORMER CHARGED
433	22-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
434	22-Jul-21	MYSURU	66	PONNAMPETE-HV1	PONNAMPET_66	9:53	10:17	0:24	LINE FAULT
435	22-Jul-21	MYSURU	66	SHANIVARASANTE-HV1	SANIVARASANTHE_66	11:15	11:40	0:25	LINE CLEAR AVAILED
436	22-Jul-21	MYSURU	66	SUNTIKOPPA-KUSHALANAGARA	SUNTIKOPPA_66	4:02	10:28	6:25	LINE FAULT
437	22-Jul-21	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	4:05	4:15	0:10	HAND TRIPPED
438	22-Jul-21	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	8:50	10:28	1:38	NFBC ISSUED
439	22-Jul-21	TUMKUR	66	CHITRADURGA 220kV-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	1:18	1:52	0:33	LOAD CURTAILMENT
440	22-Jul-21	TUMKUR	66	CHITRADURGA 220kV-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	22:46	23:00	0:14	LINE FAULT
441	22-Jul-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:32	5:50	0:18	LINE FAULT
442	22-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:44	6:51	0:06	LINE FAULT
443	22-Jul-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	6:14	6:29	0:15	LINE FAULT
444	22-Jul-21	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	17:18	17:27	0:08	MAIN SUPPLY FAILURE
445	22-Jul-21	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	14:52	16:35	1:42	HAND TRIPPED
446	22-Jul-21	TUMKUR	66	TR-1	HIRIYUR_66	8:22	8:29	0:07	HAND TRIPPED
447	22-Jul-21	TUMKUR	66	TR-1	MYLANAHALLI_66	5:52	10:54	5:01	TRANSFORMER FAULT
448	22-Jul-21	TUMKUR	66	TR-1	PAVAGADA_220	22:24	22:28	0:03	TRANSFORMER FAULT
449	22-Jul-21	TUMKUR	66	TR-1	SHYLAPURA_66	13:45	14:05	0:20	HAND TRIPPED
450	22-Jul-21	TUMKUR	66	TR-1	SOKKE_66	13:34	14:25	0:50	TRANSFORMER FAULT
451	22-Jul-21	TUMKUR	66	TR-2	BALENAHALLI_66	3:03	11:29	8:26	TRANSFORMER FAULT
452	22-Jul-21	TUMKUR	66	TR-2	HALURAMESHWARA_66	12:06	16:30	4:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
453	22-Jul-21	TUMKUR	66	TR-2	SHYLAPURA_66	13:20	13:45	0:25	HAND TRIPPED
454	22-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	16:35	16:55	0:19	LINE CLEAR AVAILED
455	23-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVILED
456	23-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
457	23-Jul-21	BAGALKOT	110	110/11KV, HV1	SIRSI_110	7:35	10:32	2:57	TRANSFORMER FAULT
458	23-Jul-21	BAGALKOT	110	110/11KV, HV1	SIRSI_110	16:48	17:40	0:52	TRANSFORMER FAULT
459	23-Jul-21	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110	9:54	12:56	3:02	TRANSFORMER FAULT
460	23-Jul-21	BAGALKOT	110	110/11KV, HV2	TUMMINKATTI_110	11:21	16:14	4:53	LINE CLEAR AVAILED
461	23-Jul-21	BAGALKOT	110	110/11KV, HV2	RON_110	5:30	5:37	0:07	TRANSFORMER FAULT
462	23-Jul-21	BAGALKOT	110	110/11KV, HV3	RATTIHALLI_110	21:01 (23.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
463	23-Jul-21	BAGALKOT	110	110/11KV,HV2	HIREKERUR_110	21:39 (22.07.2021)	13:27 (23.07.2021)	15:48	TRANSFORMER CHARGED
464	23-Jul-21	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	2:17	2:30	0:13	TRANSFORMER FAULT
465	23-Jul-21	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	17:45	17:54	0:09	TRANSFORMER FAULT
466	23-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
467	23-Jul-21	BAGALKOT	110	ALABAL-KPR SUGARS	ALABAL_110	16:03	18:31	2:28	LINE CLEAR AVAILED
468	23-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
469	23-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
470	23-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
471	23-Jul-21	BAGALKOT	110	BIJAPUR KIADB-B BAGEWADI	JUMANAL_110	12:00	15:01	3:01	LINE CLEAR AVAILED
472	23-Jul-21	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	18:31	18:43	0:12	LINE FAULT
473	23-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
474	23-Jul-21	BAGALKOT	110	HAVERI-TILUVALLI(HANAGALL)	TILUVALLI_110	5:49	6:16	0:27	LINE FAULT
475	23-Jul-21	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	6:15	6:20	0:05	LINE FAULT
476	23-Jul-21	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	19:19	19:30	0:11	LINE FAULT
477	23-Jul-21	BAGALKOT	110	MANTUR- TUNGA BHADRA SOLAR	MANTUR(G)_110	23:44 (23.07.2021)			LINE OPEN:LINE FAULT
478	23-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
479	23-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
480	23-Jul-21	BAGALKOT	110	SOUDATTI220- NARAGUND (RAMDURGA1)	SOUDATTI_220	13:35	14:07	0:32	HAND TRIPPED
481	23-Jul-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_220	13:12	14:06	0:54	HAND TRIPPED
482	23-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
483	23-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
484	23-Jul-21	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	11:26	16:17	4:51	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
485	23-Jul-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	19:09 (22.07.2021)	15:53 (23.07.2021)	20:34	LINE CHARGED
486	23-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
487	23-Jul-21	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	20:10 (23.07.2021)			LINE OPEN:LINE FAULT
488	23-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
489	23-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)			LOAD CURTAILMENT
490	23-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)			LOAD CURTAILMENT
491	23-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
492	23-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
493	23-Jul-21	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI	9:12	9:55	0:43	MAIN SUPPLY FAILURE
494	23-Jul-21	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	10:42	10:52	0:10	LOAD CHANGE OVER
495	23-Jul-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	8:38	8:44	0:06	LOAD CURTAILMENT
496	23-Jul-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	8:38	8:44	0:06	LOAD CURTAILMENT
497	23-Jul-21	BENGALURU	66	DODALAHALLI - GRT SOLAR (IPP)	NO STATION AFFECTED	16:20	16:25	0:05	LINE FAULT
498	23-Jul-21	BENGALURU	66	DODALAHALLI - GRT SOLAR (IPP)	NO STATION AFFECTED	17:00	17:25	0:25	LINE FAULT
499	23-Jul-21	BENGALURU	66	DODALAHALLI - KANAKPURA 220	DODALAHALLI	15:50	16:05	0:15	LINE CLEAR AVAILED
500	23-Jul-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	12:18	12:23	0:05	LOAD CHANGE OVER
501	23-Jul-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	9:12	9:20	0:08	LINE FAULT
502	23-Jul-21	BENGALURU	66	HV1	ALLIMARADANAHALLI	15:40	15:55	0:15	TRANSFORMER FAULT
503	23-Jul-21	BENGALURU	66	HV1	VOLVO	10:41	10:45	0:03	LINE CLEAR AVAILED
504	23-Jul-21	BENGALURU	66	HV1	MAASTHI	7:47	7:48	0:01	LINE CLEAR AVAILED
505	23-Jul-21	BENGALURU	66	HV1	DODALAHALLI	15:50	16:05	0:15	LINE CLEAR AVAILED
506	23-Jul-21	BENGALURU	66	HV1	T GOLLAHALLI	23:10:00(23/07/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
507	23-Jul-21	BENGALURU	66	HV1	TADIGOLU	11:00	11:45	0:45	LINE CLEAR AVAILED
508	23-Jul-21	BENGALURU	66	HV1	HUKUNDA	14:46	14:53	0:06	TRANSFORMER FAULT
509	23-Jul-21	BENGALURU	66	HV2	VOLVO	12:45	12:55	0:09	LINE CLEAR AVAILED
510	23-Jul-21	BENGALURU	66	HV2	KUNDANA	14:54	15:45	0:50	LINE CLEAR AVAILED
511	23-Jul-21	BENGALURU	66	HV2	MAASTHI	7:47	7:48	0:01	LINE CLEAR AVAILED
512	23-Jul-21	BENGALURU	66	HV2	DODALAHALLI	15:50	16:15	0:25	LINE CLEAR AVAILED
513	23-Jul-21	BENGALURU	66	HV3	NELEMANGALA 66	3:10	3:25	0:15	TRANSFORMER FAULT
514	23-Jul-21	BENGALURU	66	JAKKASANDRA - ADUGODI	ADUGODI	9:12	9:55	0:43	LINE FAULT
515	23-Jul-21	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	9:12	9:23	0:11	LINE FAULT
516	23-Jul-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	8:30	9:18	0:48	LOAD CURTAILMENT
517	23-Jul-21	BENGALURU	66	KODIGEHALLI - SRS PEENYA 220	KODIGEHALLI,TAVAREKERE	12:06	12:13	0:07	LINE FAULT
518	23-Jul-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:30	13:48	0:18	LINE CLEAR AVAILED
519	23-Jul-21	BENGALURU	66	MAASTHI - ADANI SOLAR (IPP)	NO STATION AFFECTED	7:30	7:50	0:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
520	23-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	6:18	6:26	0:07	LINE FAULT
521	23-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
522	23-Jul-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	5:42	5:57	0:15	LINE FAULT
523	23-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, KAMALNAGAR_110	20:09	20:17	0:08	LINE FAULT
524	23-Jul-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	20:40	20:42	0:02	MAIN SUPPLY FAILURE
525	23-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
526	23-Jul-21	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADGANCHI_110	5:43	5:50	0:07	LINE FAULT
527	23-Jul-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	6:50	7:40	0:50	LINE FAULT
528	23-Jul-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	8:30	9:30	1:00	LINE CLEAR AVAILED
529	23-Jul-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	23:18	23:24	0:06	LINE FAULT
530	23-Jul-21	GULBARGA	110	MUNIRABAD-STATMETALLIC	STARMETALLI_IPP	4:04	4:13	0:09	LINE FAULT
531	23-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	19:32(23.07.2021)			LINE OPEN:LINE CLEAR AVAILED
532	23-Jul-21	GULBARGA	110	PDHALLI-CLN SLR	PD_HALLI_110	5:26(22.07.2021)			LINE OPEN:LINE FAULT
533	23-Jul-21	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHAKTI NAGAR_110	17:12	17:21	0:09	LINE FAULT
534	23-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110	20:20(23.07.2021)			MAIN SUPPLY FAILURE
535	23-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110	19:40	19:45	0:05	MAIN SUPPLY FAILURE
536	23-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110	19:50	20:20	0:30	MAIN SUPPLY FAILURE
537	23-Jul-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:31	17:42	0:11	LINE FAULT
538	23-Jul-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:34	17:43	0:09	LINE FAULT
539	23-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDHAPUR_110,WA DEGERA_110,SANNATHI_IPP,CORE GREEN SUGAR	2:36	2:46	0:10	LINE FAULT
540	23-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
541	23-Jul-21	GULBARGA	220	HV1	SEDAM_220	5:44	17:27	11:43	TRANSFORMER FAULT
542	23-Jul-21	GULBARGA	220	HV1	SHAHAPUR_220	18:20	19:43	1:23	TRANSFORMER FAULT
543	23-Jul-21	GULBARGA	220	LINGASUGUR-RTPS1,2	RTPS_220	18:18(23.07.2021)	00:24(24.07.2021)	6:06HRS	LINE CHARGED
544	23-Jul-21	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	18:15(24.07.2021)			LINE OPEN:LINE FAULT
545	23-Jul-21	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	18:21(23.07.2021)			LINE OPEN:LINE CLEAR AVAILED
546	23-Jul-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	16:20(23.07.2021)			LINE OPEN:LINE FAULT
547	23-Jul-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	19:13(23.07.2021)			LINE OPEN:LINE CLEAR AVAILED
548	23-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	22:53(22.07.2021)			LINE OPEN:LINE CLEAR AVAILED
549	23-Jul-21	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	23:11	23:34	0:23	LINE FAULT
550	23-Jul-21	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	22:47	23:30	0:43	LINE FAULT
551	23-Jul-21	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	9:30	11:03	1:33	MAIN SUPPLY FAILURE
552	23-Jul-21	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	9:30	11:32	2:02	MAIN SUPPLY FAILURE
553	23-Jul-21	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	15:13	15:25	0:12	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
554	23-Jul-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	9:30	11:46	2:16	MAIN SUPPLY FAILURE
555	23-Jul-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	15:13	15:25	0:12	MAIN SUPPLY FAILURE
556	23-Jul-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	9:30	16:04	6:34	MAIN SUPPLY FAILURE
557	23-Jul-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	9:30	9:54	0:24	MAIN SUPPLY FAILURE
558	23-Jul-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	15:13	15:25	0:12	MAIN SUPPLY FAILURE
559	23-Jul-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	9:30	11:50	2:20	MAIN SUPPLY FAILURE
560	23-Jul-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	15:12	15:25	0:13	MAIN SUPPLY FAILURE
561	23-Jul-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	9:30	11:47	2:17	MAIN SUPPLY FAILURE
562	23-Jul-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	15:12	15:25	0:13	MAIN SUPPLY FAILURE
563	23-Jul-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	9:30	12:27	2:57	MAIN SUPPLY FAILURE
564	23-Jul-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	15:12	15:25	0:13	MAIN SUPPLY FAILURE
565	23-Jul-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	9:30	11:12	1:42	MAIN SUPPLY FAILURE
566	23-Jul-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	15:12	15:25	0:13	MAIN SUPPLY FAILURE
567	23-Jul-21	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	11:11	11:12	0:01	MAIN SUPPLY FAILURE
568	23-Jul-21	HASSAN	66	HV1	BAGUR_66	10:21	14:10	3:49	LINE CLEAR AVAILED
569	23-Jul-21	HASSAN	66	HV1	BALLUPETE_66	9:31	11:48	2:17	MAIN SUPPLY FAILURE
570	23-Jul-21	HASSAN	66	HV1	DODDAKADANUR_66	15:12	15:26	0:14	MAIN SUPPLY FAILURE
571	23-Jul-21	HASSAN	66	HV1	HALEBEEDU_66	11:14	11:38	0:24	LINE CLEAR AVAILED
572	23-Jul-21	HASSAN	66	HV1	HANGRANAHALLY_66	11:19	11:35	0:16	MAIN SUPPLY FAILURE
573	23-Jul-21	HASSAN	66	HV1	HANGRANAHALLY_66	15:30	15:47	0:17	MAIN SUPPLY FAILURE
574	23-Jul-21	HASSAN	66	HV1	HNPURA_66	9:41	11:14	1:33	MAIN SUPPLY FAILURE
575	23-Jul-21	HASSAN	66	HV1	HNPURA_66	15:13	15:26	0:13	MAIN SUPPLY FAILURE
576	23-Jul-21	HASSAN	66	HV1	MAGGE_66	6:50	8:25	1:35	LINE CLEAR AVAILED
577	23-Jul-21	HASSAN	66	HV1	MAGGE_66	9:02	9:15	0:13	LINE CLEAR AVAILED
578	23-Jul-21	HASSAN	66	HV1	MAGGE_66	23:13	23:35	0:22	MAIN SUPPLY FAILURE
579	23-Jul-21	HASSAN	66	HV1	MOSALEHOSAHALLY_66	11:27	11:34	0:07	HAND TRIPPED
580	23-Jul-21	HASSAN	66	HV1	MOSALEHOSAHALLY_66	16:00	16:05	0:05	HAND TRIPPED
581	23-Jul-21	HASSAN	66	HV1	YESLUR_66	15:57	16:07	0:10	TRANSFORMER FAULT
582	23-Jul-21	HASSAN	66	HV1	YESLUR_66	16:28	16:45	0:17	TRANSFORMER FAULT
583	23-Jul-21	HASSAN	66	HV1 CB	NAGARTHI_66	9:29	11:48	2:19	MAIN SUPPLY FAILURE
584	23-Jul-21	HASSAN	66	HV1 CB	NAGARTHI_66	15:12	15:29	0:17	MAIN SUPPLY FAILURE
585	23-Jul-21	HASSAN	66	HV2	BAGUR_66	10:14	14:04	3:50	LINE CLEAR AVAILED
586	23-Jul-21	HASSAN	66	HV2	HANGRANAHALLY_66	11:19	11:35	0:16	MAIN SUPPLY FAILURE
587	23-Jul-21	HASSAN	66	HV2	HASSAN_66	11:35	11:50	0:15	TRANSFORMER FAULT
588	23-Jul-21	HASSAN	66	HV2	HASSAN_66	13:35	13:45	0:10	TRANSFORMER FAULT
589	23-Jul-21	HASSAN	66	HV2	HNPURA_66	9:41	11:14	1:33	MAIN SUPPLY FAILURE
590	23-Jul-21	HASSAN	66	HV2	HNPURA_66	15:12	15:26	0:14	MAIN SUPPLY FAILURE
591	23-Jul-21	HASSAN	66	HV2	MAGGE_66	3:48	14:15	10:27	TRANSFORMER FAULT
592	23-Jul-21	HASSAN	66	HV2	MAGGE_66	23:13	23:40	0:27	MAIN SUPPLY FAILURE
593	23-Jul-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	23:30	23:33	0:03	HAND TRIPPED
594	23-Jul-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:19	19:15	0:56	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
595	23-Jul-21	HASSAN	66	L1 CB	NAGARTHI_66	15:11	15:28	0:17	MAIN SUPPLY FAILURE
596	23-Jul-21	HASSAN	66	Lv1	HOLENARASIPURA_220	9:30	15:24	5:54	MAIN SUPPLY FAILURE
597	23-Jul-21	HASSAN	66	Lv2	HOLENARASIPURA_220	15:13	15:24	0:11	MAIN SUPPLY FAILURE
598	23-Jul-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:43	16:31	4:48	MAIN SUPPLY FAILURE
599	23-Jul-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	21:28	21:40	0:12	LINE FAULT
600	23-Jul-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLY_66	9:25	16:05	6:40	MAIN SUPPLY FAILURE
601	23-Jul-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	12:00	13:14	1:14	HAND TRIPPED
602	23-Jul-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:55	13:15	1:20	HAND TRIPPED
603	23-Jul-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	11:28	11:32	0:04	HAND TRIPPED
604	23-Jul-21	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	11:30	16:31	5:01	LINE CLEAR AVAILED
605	23-Jul-21	HASSAN	66	SIGEBAG-SMG-DVG2	SHANTHIGRAMA_66	12:01	13:14	1:13	NFBC ISSUED
606	23-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
607	23-Jul-21	HASSAN	110	HV2	KADUR_220	11:35	13:13	1:38	LINE CLEAR AVAILED
608	23-Jul-21	HASSAN	110	HV2	SAGARA_110	16:20	20:15	3:55	TRANSFORMER FAULT
609	23-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
610	23-Jul-21	HASSAN	110	KADUR-NGNHL	KADUR_220	8:51	10:03	1:12	LOAD CURTAILMENT
611	23-Jul-21	HASSAN	110	KADUR-YGTI	KADUR_220	8:51	10:02	1:11	LOAD CURTAILMENT
612	23-Jul-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:00	15:53	0:53	LINE FAULT
613	23-Jul-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:00(23.7.2021)			LINE OPEN:LINE FAULT
614	23-Jul-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:26	13:54	3:28	NFBC ISSUED
615	23-Jul-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:50	11:57	0:07	HAND TRIPPED
616	23-Jul-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:50	11:58	0:08	HAND TRIPPED
617	23-Jul-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:50	11:55	0:05	HAND TRIPPED
618	23-Jul-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:50	12:00	0:10	HAND TRIPPED
619	23-Jul-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:50	12:00	0:10	HAND TRIPPED
620	23-Jul-21	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	9:30	12:00	2:30	LINE FAULT
621	23-Jul-21	HASSAN	220	GOPALAP-HNPUR22	GOPALPURA_220	9:30	12:10	2:40	LINE FAULT
622	23-Jul-21	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	9:17 (23.07.2021)			LINE OPEN:LINE FAULT
623	23-Jul-21	HASSAN	220	HNPR2-GPLPR1	HOLENARASIPURA_220	9:30	0:00	14:30	MAIN SUPPLY FAILURE
624	23-Jul-21	HASSAN	220	HNPR2-GPLPR2	HOLENARASIPURA_220	9:30	12:10	2:40	MAIN SUPPLY FAILURE
625	23-Jul-21	HASSAN	220	HV1	GOPALPURA_220	9:30	12:30	3:00	TRANSFORMER FAULT
626	23-Jul-21	HASSAN	220	HV2	GOPALPURA_220	9:30	12:30	3:00	TRANSFORMER FAULT
627	23-Jul-21	HASSAN	220	KEMAR-UPCL2	KEMAR_220	16:34	19:11	2:37	LINE CLEAR AVAILED
628	23-Jul-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:50	17:31	5:41	LINE FAULT
629	23-Jul-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:50	17:31	5:41	LINE FAULT
630	23-Jul-21	HASSAN	220	UPCL-KEMAR2	upcl_gen	16:34	19:11	2:37	NFBC ISSUED
631	23-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47(23.7.2021)			LINE OPEN:LINE CLEAR AVILED
632	23-Jul-21	MYSURU	66	DEVANUR(N'GUD))-SUTTUR	SUTTUR_66	16:56	17:26	0:30	LINE CLEAR AVAILED
633	23-Jul-21	MYSURU	66	HEBBANI-VADKEPURA	VADKEPURA_66 KIRUGAVALU_66 MALIYURU_66	12:43	12:51	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
634	23-Jul-21	MYSURU	66	HV1	SHIVALLY_66	10:27	10:30	0:02	HAND TRIPPED
635	23-Jul-21	MYSURU	66	HV1	BOGADHI_66	11:20	14:26	3:05	LINE CLEAR AVAILED
636	23-Jul-21	MYSURU	66	HV1	CHINAKURALI_66	16:10	16:35	0:25	TRANSFORMER FAULT
637	23-Jul-21	MYSURU	66	HV1	GAMANAHALLY_66	15:45	17:38	1:53	LINE CLEAR AVAILED
638	23-Jul-21	MYSURU	66	HV2	SHIVALLY_66	10:30	13:25	2:55	LINE CLEAR AVAILED
639	23-Jul-21	MYSURU	66	HV2	ADDIHALLI_66	16:03	16:08	0:04	TRANSFORMER FAULT
640	23-Jul-21	MYSURU	66	MADHUVANALLY-HANNUR 1	NO STATIONS EFFECTED	8:51	8:56	0:04	LINE FAULT
641	23-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
642	23-Jul-21	MYSURU	66	TALAKADU-ADANI SOLAR	NO STATIONS EFFECTED	18:36	19:40	1:03	LINE CLEAR AVAILED
643	23-Jul-21	MYSURU	66	YELANDURU -MADHUVANAHLLI	NO STATIONS EFFECTED	19:15	19:18	0:02	LINE FAULT
644	23-Jul-21	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	20:46	20:52	0:05	HAND TRIPPED
645	23-Jul-21	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	4:18	5:20	1:01	LINE FAULT
646	23-Jul-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:22	7:38	0:15	LINE FAULT
647	23-Jul-21	TUMKUR	66	DEVARAHALLI- NALLUR66	DEVARAHALLI_66	13:01	14:06	1:04	MAIN SUPPLY FAILURE
648	23-Jul-21	TUMKUR	66	DEVARAHALLI- NALLUR66	DEVARAHALLI_66	18:53	19:39	0:45	MAIN SUPPLY FAILURE
649	23-Jul-21	TUMKUR	66	HINDASGHATTA66-HIRIYUR1	HINDASGHATTA_66	6:06	6:11	0:05	MAIN SUPPLY FAILURE
650	23-Jul-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	11:43	18:35	6:52	LINE CLEAR AVAILED
651	23-Jul-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:39	7:53	0:13	LINE FAULT
652	23-Jul-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:41	16:53	0:11	LINE FAULT
653	23-Jul-21	TUMKUR	66	SANIKERE- HIRIYUR	SANIKERE_66	10:25	21:22	10:57	NFBC ISSUED
654	23-Jul-21	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	7:28	7:37	0:08	LINE FAULT
655	23-Jul-21	TUMKUR	66	TR-1	DEVARAHALLI_66	13:01	14:06	1:04	MAIN SUPPLY FAILURE
656	23-Jul-21	TUMKUR	66	TR-1	DEVARAHALLI_66	18:53	19:39	0:45	MAIN SUPPLY FAILURE
657	23-Jul-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	12:01	12:11	0:09	TRANSFORMER FAULT
658	23-Jul-21	TUMKUR	66	TR-1	MATHOD_66	5:59	6:09	0:09	TRANSFORMER FAULT
659	23-Jul-21	TUMKUR	66	TR-1	MATHOD_66	8:01	8:08	0:06	TRANSFORMER FAULT
660	23-Jul-21	TUMKUR	66	TR-1	MATHOD_66	9:24	9:32	0:07	TRANSFORMER FAULT
661	23-Jul-21	TUMKUR	110	TR-1	HALKURKE_110	13:28	13:43	0:14	LINE CLEAR AVAILED
662	23-Jul-21	TUMKUR	110	TR-2	HALKURKE_110	13:45	14:00	0:15	LINE CLEAR AVAILED
663	23-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	9:20	20:37	11:16	LINE CLEAR AVAILED
664	23-Jul-21	TUMKUR	110	TR-3	GUBBI_110	12:39	13:30	0:51	LINE CLEAR AVAILED
665	24-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVILED
666	24-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
667	24-Jul-21	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	12:09	13:53	1:44	LINE CLEAR AVAILED
668	24-Jul-21	BAGALKOT	110	110/11KV, HV3	RATTIHALLI_110	21:01 (23.07.2021)	11:18 (24.07.2021)	14:17	TRANSFORMER CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
669	24-Jul-21	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	14:18	14:23	0:05	TRANSFORMER FAULT
670	24-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
671	24-Jul-21	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110 &ALAGAWADI_33	6:40	8:44	2:04	TRANSFORMER FAULT
672	24-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
673	24-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
674	24-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
675	24-Jul-21	BAGALKOT	110	BAGEWADI- MUDEBIHAL	MUDEBIHAL_110	9:39	14:07	4:28	LINE CLEAR AVAILED
676	24-Jul-21	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2,NIDAGUNDI,MUDEBIHAL	MAMADAPUR 1&2,NIDAGUNDI,MUDEBIHAL_110	9:42	12:23	2:41	HAND TRIPPED
677	24-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
678	24-Jul-21	BAGALKOT	110	HUDLI-BSPL	HUDLI_110	0:01	0:04	0:03	HAND TRIPPED
679	24-Jul-21	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	5:55	6:00	0:05	LINE FAULT
680	24-Jul-21	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	8:23	8:39	0:16	HAND TRIPPED
681	24-Jul-21	BAGALKOT	110	MANTUR- TUNGA BHADRA SOLAR	MANTUR(G)_110	23:44 (23.07.2021)	00:19 (24.07.2021)	0:35	LINE CHARGED
682	24-Jul-21	BAGALKOT	110	MUDEBIHAL- KN SOLAR	MUDEBIHAL_110	14:07	14:11	0:04	LINE CLEAR AVAILED
683	24-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
684	24-Jul-21	BAGALKOT	110	RAMANKOPPA- SAVANUR (MUNDAGOD)	RAMANKOPPA_110	12:00	13:08	1:08	LINE CLEAR AVAILED
685	24-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
686	24-Jul-21	BAGALKOT	110	SHIGGOAN- MUNDAGOD	SHIGGOAN_110	11:37	16:00	4:23	LINE CLEAR AVAILED
687	24-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
688	24-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
689	24-Jul-21	BAGALKOT	220	BAGEWADI-ADPH2	BAGEWADI_220	9:47	12:12	2:25	HAND TRIPPED
690	24-Jul-21	BAGALKOT	220	BAGEWADI-ATRIA1	BAGEWADI_220	9:42	12:39	2:57	HAND TRIPPED
691	24-Jul-21	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	9:42	12:40	2:58	HAND TRIPPED
692	24-Jul-21	BAGALKOT	220	BAGEWADI-FORTUNE 1&2	BAGEWADI_220	9:44	12:37	2:53	HAND TRIPPED
693	24-Jul-21	BAGALKOT	220	BAGEWADI-NANDIHAL1&2	BAGEWADI_220	9:48	16:10	6:22	HAND TRIPPED
694	24-Jul-21	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	9:42	12:39	2:57	HAND TRIPPED
695	24-Jul-21	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	10:58	12:09	1:11	LINE FAULT
696	24-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
697	24-Jul-21	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	20:10 (23.07.2021)	16:28 (24.07.2021)	20:18	LINE CHARGED
698	24-Jul-21	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	18:44	18:48	0:04	HAND TRIPPED
699	24-Jul-21	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	19:12 (24.07.2021)			LINE OPEN:LINE CLEAR AVILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
700	24-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
701	24-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)			LOAD CURTAILMENT
702	24-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)			LOAD CURTAILMENT
703	24-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
704	24-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
705	24-Jul-21	BENGALURU	66	AMAR JYOTHI - LEELE VENTURE 1	AMAR JYOTHI	18:07	18:27	0:20	LOAD CHANGE OVER
706	24-Jul-21	BENGALURU	66	HV1	AMAR JYOTHI	18:09	18:31	0:22	LINE CLEAR AVAILED
707	24-Jul-21	BENGALURU	66	HV1	KHODAYS 220	10:22	10:29	0:07	LINE CLEAR AVAILED
708	24-Jul-21	BENGALURU	66	HV1	VOLVO	16:17	16:49	0:32	TRANSFORMER FAULT
709	24-Jul-21	BENGALURU	66	HV1	CHELUR	16:04	18:40	2:36	LINE CLEAR AVAILED
710	24-Jul-21	BENGALURU	66	HV1	KHW PARK	8:14	8:25	1:33	TRANSFORMER FAULT
711	24-Jul-21	BENGALURU	66	HV1	T GOLLAHALLI	23:10:00(23/07/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
712	24-Jul-21	BENGALURU	66	HV1	HUKUNDA	11:54	13:16	1:21	LINE CLEAR AVAILED
713	24-Jul-21	BENGALURU	66	HV1	HUKUNDA	13:40	14:37	0:56	LINE CLEAR AVAILED
714	24-Jul-21	BENGALURU	66	HV2	ANJANAPURA	12:41	12:43	0:02	LINE CLEAR AVAILED
715	24-Jul-21	BENGALURU	66	HV2	APPAREL PARK	10:07	10:25	0:18	LINE CLEAR AVAILED
716	24-Jul-21	BENGALURU	66	HV2	KHODAYS 220	10:22	10:29	0:07	LINE CLEAR AVAILED
717	24-Jul-21	BENGALURU	66	HV2	SADLI	13:00	13:27	0:26	LINE CLEAR AVAILED
718	24-Jul-21	BENGALURU	66	HV3	EPIP 220	15:37	15:58	0:21	LINE CLEAR AVAILED
719	24-Jul-21	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	12:07	12:40	0:33	LINE FAULT
720	24-Jul-21	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:22	10:29	0:07	LINE CLEAR AVAILED
721	24-Jul-21	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:22	10:29	0:07	LINE CLEAR AVAILED
722	24-Jul-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:07	17:25	0:18	LINE FAULT
723	24-Jul-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	11:55	12:05	0:10	LINE FAULT
724	24-Jul-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	12:06	12:14	0:08	LINE CLEAR AVAILED
725	24-Jul-21	BENGALURU	66	TADIGOL - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	0:40	0:45	0:05	LINE FAULT
726	24-Jul-21	BENGALURU	66	TADIGOL - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	0:40	0:45	0:05	LINE FAULT
727	24-Jul-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	8:33	9:38	1:05	LINE CLEAR AVAILED
728	24-Jul-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	17:35	18:33	0:58	LINE CLEAR AVAILED
729	24-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
730	24-Jul-21	BENGALURU	220	KOLAR 220 - BANGARPET 2	BANGARPET	11:35	12:50	1:15	LINE CLEAR AVAILED
731	24-Jul-21	GULBARGA	66	BADALADUKU-HANASI	HANSI_66	8:06	14:41	6:35	MAIN SUPPLY FAILURE
732	24-Jul-21	GULBARGA	66	ITTAGI-BENNIHALLI	BENNIHALLI_66	14:48	14:58	0:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
733	24-Jul-21	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	16:08	16:18	0:10	LINE FAULT
734	24-Jul-21	GULBARGA	66	ITTAGI-RENEWSOLAR1&2	ITTAGI_220	15:00	15:05	0:05	LINE CLEAR AVAILED
735	24-Jul-21	GULBARGA	66	KUDLIGI-BANAVEKAL	BANAVEKAL_66	4:20	4:50	0:30	LINE FAULT
736	24-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, KAMALNAGAR_110	18:51	18:56	0:05	LINE FAULT
737	24-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
738	24-Jul-21	GULBARGA	110	HV1	MANTHAL_110	10:45(24.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
739	24-Jul-21	GULBARGA	110	KOGALI-ATRSOLR	KOGALI_66	15:02	15:13	0:11	LINE CLEAR AVAILED
740	24-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	19:20(24.07.2021)			LINE OPEN:LINE CLEAR AVILED
741	24-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	19:32(23.07.2021)	3:25(24.07.2021)	7:53 HRS	LINE CHARGED
742	24-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	3:41	3:50	0:09	LINE FAULT
743	24-Jul-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	11:10	11:20	0:10	MAIN SUPPLY FAILURE
744	24-Jul-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	14:00	14:50	0:50	MAIN SUPPLY FAILURE
745	24-Jul-21	GULBARGA	110	NIRNA-RENEW SOLAR1	NIRNA_110	15:05	15:10	0:05	LINE CLEAR AVAILED
746	24-Jul-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	16:05	16:20	0:15	MAIN SUPPLY FAILURE
747	24-Jul-21	GULBARGA	110	PDHALLI-CLN SLR	PD_HALLI_110	5:26(22.07.2021)	17:17(24.07.2021)	59:51 HRS	LINE CHARGED
748	24-Jul-21	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	14:29	15:04	0:35	MAIN SUPPLY FAILURE
749	24-Jul-21	GULBARGA	110	SINDHNOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	2:31	2:41	0:10	LINE FAULT
750	24-Jul-21	GULBARGA	220	HALBARGA-HUMNABAD 1,2	HALBARGA_220	14:04	14:50	0:46	MAIN SUPPLY FAILURE
751	24-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
752	24-Jul-21	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	18:10	19:12	1:02	LINE CLEAR AVAILED
753	24-Jul-21	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	17:30(24.07.2021)			LINE OPEN:LINE CLEAR AVILED
754	24-Jul-21	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	14:02	14:38	0:36	LINE FAULT
755	24-Jul-21	GULBARGA	220	LINGASUGUR-RTPS1,2	RTPS_220	0:30	12:10	11:40	LINE CLEAR AVAILED
756	24-Jul-21	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	18:15(24.07.2021)	1:47(25.04.2021)	7:32	LINE CHARGED
757	24-Jul-21	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	13:21	20:18	6:57	LINE CLEAR AVAILED
758	24-Jul-21	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	18:21(23.07.2021)	6:13(24.07.2021)	11:52HRS	LINE CHARGED
759	24-Jul-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	8:28	17:28	9:00	LINE CLEAR AVAILED
760	24-Jul-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	16:20(23.07.2021)	17:35(24.07.2021)	1:15	LINE CHARGED
761	24-Jul-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	19:13(23.07.2021)	6:10(24.07.2021)	10:57HRS	LINE CHARGED
762	24-Jul-21	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	2:20	5:57	3:37	LINE CLEAR AVAILED
763	24-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	22:53(22.07.2021)			LINE OPEN:LINE CLEAR AVILED
764	24-Jul-21	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	12:01	12:14	0:13	LINE FAULT
765	24-Jul-21	HASSAN	66	HV1	HNPURA_66	11:50	12:26	0:36	LINE CLEAR AVAILED
766	24-Jul-21	HASSAN	66	HV1	SAKLESH PURA_66	11:16	12:58	1:42	LINE CLEAR AVAILED
767	24-Jul-21	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	8:47	9:03	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
768	24-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
769	24-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
770	24-Jul-21	HASSAN	110	KADUR-TNGL	KADUR_220	12:12	12:23	0:11	LINE FAULT
771	24-Jul-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	9:15	16:25	7:10	LINE CLEAR AVAILED
772	24-Jul-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:00(23.7.2021)			LINE OPEN:LINE FAULT
773	24-Jul-21	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	11:13	12:30	1:17	LINE CLEAR AVAILED
774	24-Jul-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:53	12:34	1:41	NFBC ISSUED
775	24-Jul-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	11:13	12:34	1:21	MAIN SUPPLY FAILURE
776	24-Jul-21	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	9:17 (23.07.2021)	19:58 (24.07.2021)	34:41hrs	LINE CHARGED
777	24-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47(23.7.2021)	11:45(24.7.2021)	11:48hrs	LINE CHARGED
778	24-Jul-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:26(24.7.2021)			LINE OPEN:LINE CLEAR AVILED
779	24-Jul-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	13:59	18:50	4:51	LINE CLEAR AVAILED
780	24-Jul-21	MYSURU	66	HV1	K_HONNALGERE_66	8:34	9:02	0:28	HAND TRIPPED
781	24-Jul-21	MYSURU	66	HV1	PANDAVAPURA_66	10:19	11:01	0:42	LINE CLEAR AVAILED
782	24-Jul-21	MYSURU	66	HV2	K_HONNALGERE_66	8:34	9:02	0:28	HAND TRIPPED
783	24-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
784	24-Jul-21	MYSURU	66	PERIAPATNA-HANGUDU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	13:07	13:22	0:14	LINE FAULT
785	24-Jul-21	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	3:29	3:32	0:03	HAND TRIPPED
786	24-Jul-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	0:21	0:42	0:21	LINE FAULT
787	24-Jul-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	11:11	11:30	0:19	MAIN SUPPLY FAILURE
788	24-Jul-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:07	11:21	0:14	LINE FAULT
789	24-Jul-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	11:09	11:21	0:12	LINE FAULT
790	24-Jul-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1 IPP_66	INFOSYS-1_IPP_66	10:59	11:11	0:12	LINE FAULT
791	24-Jul-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1 IPP_66	INFOSYS-1_IPP_66	11:35	11:45	0:09	LINE FAULT
792	24-Jul-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1 IPP_66	INFOSYS-1_IPP_66	12:03	12:08	0:05	LINE FAULT
793	24-Jul-21	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	11:05	11:22	0:17	LINE FAULT
794	24-Jul-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:32	13:45	0:13	TRANSFORMER FAULT
795	24-Jul-21	TUMKUR	66	TR-1	KUNDUR_66	15:07	15:31	0:24	TRANSFORMER FAULT
796	24-Jul-21	TUMKUR	66	TR-1	SASALUHALLA_66	15:32	16:57	1:24	LINE CLEAR AVAILED
797	24-Jul-21	TUMKUR	66	TR-2	KUNDUR_66	14:00	14:20	0:20	TRANSFORMER FAULT
798	24-Jul-21	TUMKUR	66	TR-3	HIRIYUR_220	11:03	11:15	0:12	TRANSFORMER FAULT
799	24-Jul-21	TUMKUR	66	TR-3	HONNALI_66	15:28	16:01	0:33	HAND TRIPPED
800	24-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	8:33	10:28	1:55	LINE CLEAR AVAILED
801	24-Jul-21	TUMKUR	220	TR-3	HIRIYUR_220	11:03	11:15	0:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
802	25-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVILED
803	25-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
804	25-Jul-21	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	15:25 (25.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
805	25-Jul-21	BAGALKOT	110	110/11KV,HV1	ANKALI_110	17:55	18:06	0:11	TRANSFORMER FAULT
806	25-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
807	25-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
808	25-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
809	25-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
810	25-Jul-21	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	5:49	6:07	0:18	LINE FAULT
811	25-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
812	25-Jul-21	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	6:18	6:39	0:21	LINE FAULT
813	25-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
814	25-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
815	25-Jul-21	BAGALKOT	110	SOUDATTI- ENERCON2	SOUDATTI_110	20:44	21:58	1:14	LINE FAULT
816	25-Jul-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	20:44	21:15	0:31	LINE FAULT
817	25-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
818	25-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
819	25-Jul-21	BAGALKOT	110	THORVI-TIKOTA	TAKKALAKI_110	14:20	15:43	1:23	LINE CLEAR AVILED
820	25-Jul-21	BAGALKOT	110	UDIKERI- NOKAR SOLAR	UDIKERI_110	13:42	15:10	1:28	LINE FAULT
821	25-Jul-21	BAGALKOT	220	BELGAUM- KANABARGI2 (NARENDRA2)	BELGAUM_220	22:45 (24.07.2021)	7:33 (25.07.2021)	8:48	LINE CHARGED
822	25-Jul-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	5:30	6:46	1:16	HAND TRIPPED
823	25-Jul-21	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	5:32	6:46	1:14	HAND TRIPPED
824	25-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
825	25-Jul-21	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	19:12 (24.07.2021)	7:22 (25.07.2021)	12:10	LINE CHARGED
826	25-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
827	25-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)	3:45 (25.07.2021)	11:11	LINE CHARGED
828	25-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:34 (22.07.2021)	3:45 (25.07.2021)	11:11	LINE CHARGED
829	25-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
830	25-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
831	25-Jul-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	21:30	21:35	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
832	25-Jul-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	14:52	14:56	0:04	LOAD CHANGE OVER
833	25-Jul-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	9:04	9:10	0:06	LOAD CHANGE OVER
834	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:41	17:58	7:17	LINE CLEAR AVAILED
835	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	10:41	17:49	7:08	LINE CLEAR AVAILED
836	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, PALLICHERLU	10:41	18:00	7:19	LINE CLEAR AVAILED
837	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	10:41	18:17	7:36	LINE CLEAR AVAILED
838	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	10:41	17:50	7:09	LINE CLEAR AVAILED
839	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	10:41	18:16	7:35	LINE CLEAR AVAILED
840	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	10:41	18:18	7:37	LINE CLEAR AVAILED
841	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:41	17:56	7:15	LINE CLEAR AVAILED
842	25-Jul-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS	10:41	18:01	7:20	LINE CLEAR AVAILED
843	25-Jul-21	BENGALURU	66	DOMMASANDRA - EPIP 220	DOMMASANDRA	21:25	21:30	0:05	LOAD CHANGE OVER
844	25-Jul-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	12:00	12:05	0:05	MAIN SUPPLY FAILURE
845	25-Jul-21	BENGALURU	66	HV1	EAST DIVISION COMPOUND	13:39	13:47	0:08	TRANSFORMER FAULT
846	25-Jul-21	BENGALURU	66	HV1	KOLAR 220	10:36	18:58	8:22	LINE CLEAR AVAILED
847	25-Jul-21	BENGALURU	66	HV1	GUNDLU KOTTUR	11:07	12:19	1:11	LINE CLEAR AVAILED
848	25-Jul-21	BENGALURU	66	HV1	MULBAGLU	19:52	20:38	0:46	LINE CLEAR AVAILED
849	25-Jul-21	BENGALURU	66	HV1	SARJAPURA 220	9:51	21:17	11:26	LINE CLEAR AVAILED
850	25-Jul-21	BENGALURU	66	HV1	T GOLLAHALLI	23:10:00(23/07/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
851	25-Jul-21	BENGALURU	66	HV2	KOLAR 220	10:36	18:59	8:23	LINE CLEAR AVAILED
852	25-Jul-21	BENGALURU	66	HV2	DODDABELAVANGALA	18:27	18:56	0:29	LINE CLEAR AVAILED
853	25-Jul-21	BENGALURU	66	HV2	MAASTHI	14:53	15:25	0:32	LINE CLEAR AVAILED
854	25-Jul-21	BENGALURU	66	HV2	SARJAPURA 220	9:51	10:00	0:09	LINE CLEAR AVAILED
855	25-Jul-21	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:54	14:58	0:04	LOAD CHANGE OVER
856	25-Jul-21	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	9:24	9:29	0:05	LOAD CHANGE OVER
857	25-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	10:35	19:01	8:26	LINE CLEAR AVAILED
858	25-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	10:35	19:01	8:26	LINE CLEAR AVAILED
859	25-Jul-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:35	19:24	8:49	LINE CLEAR AVAILED
860	25-Jul-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:35	19:26	8:51	LINE CLEAR AVAILED
861	25-Jul-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT)	10:36	19:17	8:41	LINE CLEAR AVAILED
862	25-Jul-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	10:36	19:56	9:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
863	25-Jul-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	10:35	19:08	8:33	LINE CLEAR AVAILED
864	25-Jul-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	11:09	19:23	8:14	LINE CLEAR AVAILED
865	25-Jul-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:35	19:25	8:50	LINE CLEAR AVAILED
866	25-Jul-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:35	19:00	8:25	LINE CLEAR AVAILED
867	25-Jul-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	14:30	15:15	0:45	LINE CLEAR AVAILED
868	25-Jul-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	14:30	15:15	0:45	LINE CLEAR AVAILED
869	25-Jul-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	14:50	14:55	0:05	LOAD CHANGE OVER
870	25-Jul-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	9:15	9:41	0:26	LOAD CHANGE OVER
871	25-Jul-21	BENGALURU	66	SARAKKI - JAYADEVA 1 & 2	SARAKKI	15:40	15:45	0:05	LOAD CHANGE OVER
872	25-Jul-21	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	9:40	9:44	0:04	LOAD CHANGE OVER
873	25-Jul-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE(HV2)	8:22	8:30	0:08	MAIN SUPPLY FAILURE
874	25-Jul-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:48	8:55	0:07	LINE CLEAR AVAILED
875	25-Jul-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:45	10:05	0:20	LINE CLEAR AVAILED
876	25-Jul-21	BENGALURU	66	TADIGOL - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	10:40	18:10	7:30	LINE CLEAR AVAILED
877	25-Jul-21	BENGALURU	66	TK HALLI 220 - LIMBAVALI	NO STATION AFFECTED	19:03	19:53	0:50	LINE FAULT
878	25-Jul-21	BENGALURU	66	VOKKALERI - MALUR 220	VOKKALERI	11:35	19:20	7:45	MAIN SUPPLY FAILURE
879	25-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
880	25-Jul-21	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	10:41	17:41	7:00	LINE CLEAR AVAILED
881	25-Jul-21	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	10:41	17:41	7:00	LINE CLEAR AVAILED
882	25-Jul-21	BENGALURU	220	HV1	CHINTAMANI 220	10:41	17:44	7:03	LINE CLEAR AVAILED
883	25-Jul-21	BENGALURU	220	HV1	KOLAR 220	10:38	18:55	8:17	LINE CLEAR AVAILED
884	25-Jul-21	BENGALURU	220	HV1	SARJAPURA 220	9:52	21:17	11:25	LINE CLEAR AVAILED
885	25-Jul-21	BENGALURU	220	HV2	CHINTAMANI 220	10:41	17:44	7:03	LINE CLEAR AVAILED
886	25-Jul-21	BENGALURU	220	HV2	SARJAPURA 220	9:52	21:22	11:30	LINE CLEAR AVAILED
887	25-Jul-21	BENGALURU	220	HV3	KOLAR 220	10:37	18:52	8:15	LINE CLEAR AVAILED
888	25-Jul-21	BENGALURU	220	KOLAR 220 - MALUR 1	NO STATION AFFECTED	11:15	20:53	9:38	LINE CLEAR AVAILED
889	25-Jul-21	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	10:00	20:54	10:54	LINE CLEAR AVAILED
890	25-Jul-21	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	10:55	18:46	7:51	LINE CLEAR AVAILED
891	25-Jul-21	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	10:56	19:02	8:06	LINE CLEAR AVAILED
892	25-Jul-21	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	11:18	19:03	7:45	LINE CLEAR AVAILED
893	25-Jul-21	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 2	RAILWAY TRACTION (EHT)	11:18	19:03	7:45	LINE CLEAR AVAILED
894	25-Jul-21	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	11:10	20:54	9:44	LINE CLEAR AVAILED
895	25-Jul-21	GULBARGA	110	HALBARGA-ACME SOLAR_IPP	HALBARGA_220	19:04(24.05.2021)	00:16(25.07.2021)	5:12HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
896	25-Jul-21	GULBARGA	110	HUMNABAD-CHIGUPPA	CHITGUPPA_110	12:26	12:27	0:01	MAIN SUPPLY FAILURE
897	25-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
898	25-Jul-21	GULBARGA	110	HV1,HV2	MYLAR_110	15:22	16:26	1:04	LINE CLEAR AVAILED
899	25-Jul-21	GULBARGA	110	HV2	KAVITAL_110	11:59	12:40	0:41	LINE CLEAR AVAILED
900	25-Jul-21	GULBARGA	110	HV2	SREERAMANAGAR_110	11:55	12:35	0:40	TRANSFORMER FAULT
901	25-Jul-21	GULBARGA	110	HV2,HV3	MANTHAL_110	17:30	18:00	0:30	LINE CLEAR AVAILED
902	25-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	19:20(24.07.2021)	4:00(25.07.2021)	8:40 HRS	LINE CHARGED
903	25-Jul-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	5:25	5:29	0:04	LINE FAULT
904	25-Jul-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	10:10	11:20	1:10	MAIN SUPPLY FAILURE
905	25-Jul-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:00	12:20	0:20	MAIN SUPPLY FAILURE
906	25-Jul-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:50	13:00	0:10	MAIN SUPPLY FAILURE
907	25-Jul-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	7:44	7:50	0:06	MAIN SUPPLY FAILURE
908	25-Jul-21	GULBARGA	110	PDHALLI-BASAI_IPP	PD_HALLI_110	23:09	23:14	0:05	LINE FAULT
909	25-Jul-21	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	23:13	23:15	0:02	LINE FAULT
910	25-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110	20:20(23.07.2021)	6:55(25.07.2021)	34:05 hrs	LINE CHARGED
911	25-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110,SAST HAPUR_110	10:15	10:50	0:35	MAIN SUPPLY FAILURE
912	25-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110,SAST HAPUR_110	12:05	12:35	0:30	MAIN SUPPLY FAILURE
913	25-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,MANTHAL_110,SAST HAPUR_110	12:50	13:00	0:10	MAIN SUPPLY FAILURE
914	25-Jul-21	GULBARGA	110	SEDAM-CHINCHOLI	CHILCHOLI_110	11:28	13:52	2:24	MAIN SUPPLY FAILURE
915	25-Jul-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	3:44	4:02	0:18	LINE FAULT
916	25-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDHAPUR_110,WA DEGERA_110,SANNATHI_IPP,CORE GREEN SUGAR	4:43	4:45	0:02	LINE FAULT
917	25-Jul-21	GULBARGA	110	SINDHNOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	4:17	4:27	0:10	LINE FAULT
918	25-Jul-21	GULBARGA	220	HALBARGA-HUMNABAD 1,2	HALBARGA_220	10:10	11:08	0:58	MAIN SUPPLY FAILURE
919	25-Jul-21	GULBARGA	220	HALBARGA-HUMNABAD 1,2	HALBARGA_220	12:03	12:22	0:19	MAIN SUPPLY FAILURE
920	25-Jul-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	10:10	10:42	0:32	LINE FAULT
921	25-Jul-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	12:03	12:14	0:11	LINE FAULT
922	25-Jul-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	12:47	12:54	0:07	LINE FAULT
923	25-Jul-21	GULBARGA	220	HUMNABAD-SEDAM	SEDAM_220	10:10	11:27	1:17	LINE FAULT
924	25-Jul-21	GULBARGA	220	HUMNABAD-SEDAM	SEDAM_220	12:03	12:28	0:25	LINE FAULT
925	25-Jul-21	GULBARGA	220	HUMNABAD-SEDAM	SEDAM_220	12:47	13:34	0:47	LINE FAULT
926	25-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
927	25-Jul-21	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	17:30(24.07.2021)			LINE OPEN:LINE CLEAR AVAILED
928	25-Jul-21	GULBARGA	220	LINGASUGUR-BAGEWADI1,2	BAGEWADI_220	11:26	14:22	2:56	LINE CLEAR AVAILED
929	25-Jul-21	GULBARGA	220	LINGASUGUR-BAGEWADI1,2	BAGEWADI_220	14:23	15:55	1:32	LINE CLEAR AVAILED
930	25-Jul-21	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	4:58	5:15	0:17	LINE FAULT
931	25-Jul-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	8:13	13:32	5:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
932	25-Jul-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	9:22(25.07.2021)			LINE OPEN:LINE CLEAR AVILED
933	25-Jul-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	13:50	19:36	5:46	LINE CLEAR AVAILED
934	25-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	18:18 (25.07.21)			LINE OPEN:LINE CLEAR AVILED
935	25-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	22:53(22.07.2021)	14:49(25.07.2021)	63:56HRS	LINE CHARGED
936	25-Jul-21	HASSAN	66	HV1	SAKLESH PURA_66	1:48	14:58	13:10	TRANSFORMER FAULT
937	25-Jul-21	HASSAN	66	HV1	MALLAPURA_66	9:37	20:22	10:45	MAIN SUPPLY FAILURE
938	25-Jul-21	HASSAN	66	HV2	MALLAPURA_66	9:37	20:22	10:45	MAIN SUPPLY FAILURE
939	25-Jul-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:51	7:10	0:19	LINE FAULT
940	25-Jul-21	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	9:37	20:22	10:45	MAIN SUPPLY FAILURE
941	25-Jul-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
942	25-Jul-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	7:42	8:21	0:39	LINE FAULT
943	25-Jul-21	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	9:52	10:16	0:24	LINE CLEAR AVAILED
944	25-Jul-21	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	9:52	10:16	0:24	LINE CLEAR AVAILED
945	25-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
946	25-Jul-21	HASSAN	110	HV1	BAIKAMPADY_110	9:00	15:08	6:08	MAIN SUPPLY FAILURE
947	25-Jul-21	HASSAN	110	HV2	BAIKAMPADY_110	9:00	15:08	6:08	MAIN SUPPLY FAILURE
948	25-Jul-21	HASSAN	110	HV4	BAIKAMPADY_110	9:00	15:08	6:08	MAIN SUPPLY FAILURE
949	25-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
950	25-Jul-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	9:00	15:02	6:02	LINE CLEAR AVAILED
951	25-Jul-21	HASSAN	110	KAVOOR-BEJAI	KAVOOR_220	12:25	15:05	2:40	NFBC ISSUED
952	25-Jul-21	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	12:20	15:02	2:42	NFBC ISSUED
953	25-Jul-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:00(23.7.2021)			LINE OPEN:LINE FAULT
954	25-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:10(25.7.2021)			LINE OPEN:LINE CLEAR AVILED
955	25-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	4:01	9:25	5:24	HAND TRIPPED
956	25-Jul-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:26(24.7.2021)	8:49(25.7.2021)	8:23hrs	LINE CHARGED
957	25-Jul-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:45(25.7.2021)			LINE OPEN:LINE CLEAR AVILED
958	25-Jul-21	MYSURU	66	HEBBANI-TK HALLY	NO STATIONS EFFECTED	19:03	19:17	0:14	LINE FAULT
959	25-Jul-21	MYSURU	66	JYOTHINAGARA-DKMAIDANA	DKMAIDANA_66	14:36	14:47	0:10	LINE FAULT
960	25-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
961	25-Jul-21	MYSURU	66	TUBINKERE-MANDYA 2	KOPPA_66 BESAGARAHALLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 MANDYA_66 KADKOTHANAHALLI_66	18:51	18:59	0:08	LINE FAULT
962	25-Jul-21	MYSURU	66	TUBINKERE-MANDYA 4	KOPPA_66 BESAGARAHALLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 MANDYA_66 KADKOTHANAHALLI_66	18:51	18:59	0:08	LINE FAULT
963	25-Jul-21	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66	12:06	12:16	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
964	25-Jul-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	7:52	8:13	0:20	LINE FAULT
965	25-Jul-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:38	10:52	0:14	HAND TRIPPED
966	25-Jul-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:30	12:44	0:13	HAND TRIPPED
967	25-Jul-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:02	13:07	0:04	HAND TRIPPED
968	25-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:15	13:21	0:06	LINE FAULT
969	25-Jul-21	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:02	10:11	0:08	HAND TRIPPED
970	25-Jul-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	8:15	8:28	0:13	LINE CLEAR AVAILED
971	25-Jul-21	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	12:38	13:21	0:43	LINE CLEAR AVAILED
972	25-Jul-21	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	9:22	18:52	9:29	MAIN SUPPLY FAILURE
973	25-Jul-21	TUMKUR	66	TR-1	HAALURAMESHWARA_66	15:17	15:28	0:10	TRANSFORMER FAULT
974	25-Jul-21	TUMKUR	66	TR-1	HAALURAMESHWARA_66	17:18	17:26	0:08	TRANSFORMER FAULT
975	25-Jul-21	TUMKUR	66	TR-1	NYAMATHI_66	20:38	20:45	0:06	LINE CLEAR AVAILED
976	25-Jul-21	TUMKUR	66	TR-1	PAVAGADA-220	13:04	13:11	0:07	TRANSFORMER FAULT
977	25-Jul-21	TUMKUR	66	TR-1	SAVALANGA_66	9:22	20:19	10:57	MAIN SUPPLY FAILURE
978	26-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVILED
979	26-Jul-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
980	26-Jul-21	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	15:03	16:20	1:17	LINE CLEAR AVAILED
981	26-Jul-21	BAGALKOT	110	110/11KV, HV1	KULIGERI CROSS_110	14:15	15:50	1:35	LINE CLEAR AVAILED
982	26-Jul-21	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	14:23	14:33	0:10	TRANSFORMER FAULT
983	26-Jul-21	BAGALKOT	110	110/11KV, HV1	GADAG_110	14:08	14:53	0:45	TRANSFORMER FAULT
984	26-Jul-21	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	15:25 (25.07.2021)	14:09 (26.07.2021)	22:44 hrs	TRANSFORMER CHARGED
985	26-Jul-21	BAGALKOT	110	110/11KV, HV2	KULIGOD_110	14:59	16:00	1:01	LINE CLEAR AVAILED
986	26-Jul-21	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	16:00	16:19	0:19	TRANSFORMER FAULT
987	26-Jul-21	BAGALKOT	110	110/11KV,HV3	BAGALKOT_220	14:06	14:58	0:52	HAND TRIPPED
988	26-Jul-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
989	26-Jul-21	BAGALKOT	110	220/110KV,LV1	CHIKKODI-220	16:48	17:14	0:26	HAND TRIPPED
990	26-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
991	26-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVILED
992	26-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVILED
993	26-Jul-21	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	14:06	15:04	0:58	HAND TRIPPED
994	26-Jul-21	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	14:06	15:17	1:11	HAND TRIPPED
995	26-Jul-21	BAGALKOT	110	BAGALKOT-LOKAPUR	LOKAPUR_110	14:14	15:18	1:04	HAND TRIPPED
996	26-Jul-21	BAGALKOT	110	BAGALKOT-NAVANAGAR2	NAVANAGAR_110	14:06	15:16	1:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
997	26-Jul-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAI	NEERBUDIHAI_110	14:06	15:08	1:02	HAND TRIPPED
998	26-Jul-21	BAGALKOT	110	BAGEWADI- MUDEDEBIHAL	MUDEDEBIHAL_110	20:58	21:04	0:06	HAND TRIPPED
999	26-Jul-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	16:36	17:27	0:51	HAND TRIPPED
1000	26-Jul-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	14:15	15:23	1:08	HAND TRIPPED
1001	26-Jul-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	16:36	17:27	0:51	HAND TRIPPED
1002	26-Jul-21	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	14:15	15:23	1:08	HAND TRIPPED
1003	26-Jul-21	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	16:36	17:28	0:52	HAND TRIPPED
1004	26-Jul-21	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	14:09	17:49	3:40	HAND TRIPPED
1005	26-Jul-21	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	14:09	15:10	1:01	HAND TRIPPED
1006	26-Jul-21	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	14:15	15:05	0:50	HAND TRIPPED
1007	26-Jul-21	BAGALKOT	110	DAMBAL-SUZLON(L2&3)	DAMBAL_110	14:15	18:55	4:40	HAND TRIPPED
1008	26-Jul-21	BAGALKOT	110	GADAG-DAMBAL 1&2	DAMBAL_110	14:55	14:59	0:04	HAND TRIPPED
1009	26-Jul-21	BAGALKOT	110	GADAG-DAMBAL 1&2	DAMBAL_110	16:29	17:21	0:52	HAND TRIPPED
1010	26-Jul-21	BAGALKOT	110	GADAG-LAXMESHWAR2	LAXMESHWWAR_110	14:55	14:56	0:01	HAND TRIPPED
1011	26-Jul-21	BAGALKOT	110	GADAG-LAXMESHWAR2	LAXMESHWWAR_110	16:29	17:11	0:42	HAND TRIPPED
1012	26-Jul-21	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	16:29	17:09	0:40	HAND TRIPPED
1013	26-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVILED
1014	26-Jul-21	BAGALKOT	110	INDI220- ZALKI	ZALKI_110	11:20	12:28	1:08	LINE CLEAR AVAILED
1015	26-Jul-21	BAGALKOT	110	KERUR- BADAMI	BADAMI_110	14:18	15:21	1:03	HAND TRIPPED
1016	26-Jul-21	BAGALKOT	110	MACHE- UDYAMBAG	MACHE_110	6:39	16:45	10:06	HAND TRIPPED
1017	26-Jul-21	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	14:10	15:10	1:00	HAND TRIPPED
1018	26-Jul-21	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	16:25	17:24	0:59	HAND TRIPPED
1019	26-Jul-21	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	23:26 (26.07.2021)			LINE OPEN:LINE CLEAR AVILED
1020	26-Jul-21	BAGALKOT	110	NARENDRA- MRUTHYUNJAY NAGAR1	MRUTHYUNJAY NAGAR_110	11:30	16:25	4:55	HAND TRIPPED
1021	26-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVILED
1022	26-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1023	26-Jul-21	BAGALKOT	110	RON- GAMESHA	RON_110	17:07	18:07	1:00	HAND TRIPPED
1024	26-Jul-21	BAGALKOT	110	SAMBAPUR ROAD- DAMBAL	DAMBAL_110	14:20	15:03	0:43	HAND TRIPPED
1025	26-Jul-21	BAGALKOT	110	SAMBAPUR ROAD- DAMBAL	DAMBAL_110	17:10	17:36	0:26	HAND TRIPPED
1026	26-Jul-21	BAGALKOT	110	SHIRHATTI- BPCL1	SHIRHATTI_110	17:23	18:20	0:57	HAND TRIPPED
1027	26-Jul-21	BAGALKOT	110	SHIRHATTI- BPCL1&2	SHIRHATTI_110	14:15	15:15	1:00	HAND TRIPPED
1028	26-Jul-21	BAGALKOT	110	SHIRHATTI- BPCL2	SHIRHATTI_110	17:23	18:30	1:07	HAND TRIPPED
1029	26-Jul-21	BAGALKOT	110	SHIRHATTI- LAXMESHWAR	LAXMESHWAR_110	14:15	15:10	0:55	HAND TRIPPED
1030	26-Jul-21	BAGALKOT	110	SIRSI- JOG1	SIRSI_110	11:36	12:40	1:04	LINE CLEAR AVAILED
1031	26-Jul-21	BAGALKOT	110	SIRSI- JOG2 (SIDDAPUR)	SIDDAPUR_110	11:36	12:48	1:12	LINE CLEAR AVAILED
1032	26-Jul-21	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	8:43	8:53	0:10	LINE FAULT
1033	26-Jul-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1034	26-Jul-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN:LINE CLEAR AVILED
1035	26-Jul-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110, GIRISAGAR_110, SHIRGUPPI_110, TOLAMATTI_110, BISNAL_110	14:58	15:35	0:37	HAND TRIPPED
1036	26-Jul-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110, GIRISAGAR_110, SHIRGUPPI_110, TOLAMATTI_110, BISNAL_110	17:39	17:47	0:08	HAND TRIPPED
1037	26-Jul-21	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	12:45	16:15	3:30	LINE CLEAR AVAILED
1038	26-Jul-21	BAGALKOT	220	220/110KV,HV1 &LV1	BAGALKOT_220	15:03	15:06	20:18	HAND TRIPPED
1039	26-Jul-21	BAGALKOT	220	220/110KV,HV1 &LV1	CHIKKODI-220	12:51	12:53	0:02	HAND TRIPPED
1040	26-Jul-21	BAGALKOT	220	220/110KV,HV2 &LV2	GADAG_220	16:29	17:26	0:57	HAND TRIPPED
1041	26-Jul-21	BAGALKOT	220	ADPH1&2-BAGEWADI	BAGEWADI_220	14:15	15:18	1:03	HAND TRIPPED
1042	26-Jul-21	BAGALKOT	220	ADPH1&2-BAGEWADI	BAGEWADI_220	16:25	17:25	1:00	HAND TRIPPED
1043	26-Jul-21	BAGALKOT	220	BAGALKOT-GADAG 1&2	BAGALKOT_220	14:06	15:03	0:57	LINE FAULT
1044	26-Jul-21	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	BAGALKOT_220	15:03	15:25	0:22	HAND TRIPPED
1045	26-Jul-21	BAGALKOT	220	BAGEWADI-ATRIA 1&2	BAGEWADI_220	14:15	15:34	1:19	HAND TRIPPED
1046	26-Jul-21	BAGALKOT	220	BAGEWADI-ATRIA 1&2	BAGEWADI_220	16:25	17:40	1:15	HAND TRIPPED
1047	26-Jul-21	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 1&2	BAGEWADI_220	14:15	15:36	1:21	HAND TRIPPED
1048	26-Jul-21	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 1&2	BAGEWADI_220	16:25	17:41	1:16	HAND TRIPPED
1049	26-Jul-21	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	14:15	15:36	1:21	HAND TRIPPED
1050	26-Jul-21	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	16:25	17:47	1:22	HAND TRIPPED
1051	26-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	20:30 (26.07.2021)			LINE OPEN:LINE CLEAR AVILED
1052	26-Jul-21	BAGALKOT	220	BELGAUM-NARENDRA 2(KANABARGI)	BELGAUM_220	11:08	15:23	4:15	LINE CLEAR AVAILED
1053	26-Jul-21	BAGALKOT	220	DHONI2-GADAG	GADAG_220	14:07	14:55	0:48	LINE FAULT
1054	26-Jul-21	BAGALKOT	220	DHONI-GADAG1	DHONI_400	14:08	16:38	2:30	LINE FAULT
1055	26-Jul-21	BAGALKOT	220	DHONI-GADAG2	DHONI_400	17:16	17:24	0:08	LINE FAULT
1056	26-Jul-21	BAGALKOT	220	KADRA1- KARWAR220	KARWAR_220	12:18	12:21	0:03	LINE CLEAR AVAILED
1057	26-Jul-21	BAGALKOT	220	KADRA2- KARWAR220	KARWAR_220	16:11	17:58	1:47	LINE CLEAR AVAILED
1058	26-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
1059	26-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1060	26-Jul-21	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	14:25 (26.07.2021)			LINE OPEN:LINE CLEAR AVILED
1061	26-Jul-21	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	14:27 (26.07.2021)			LINE OPEN:LINE CLEAR AVILED
1062	26-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1063	26-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVILED
1064	26-Jul-21	BAGALKOT	220	VAJRAMATTI220- KUDAGI1	VAJRAMATTI_220	15:17	19:00	3:43	LOAD CURTAILMENT
1065	26-Jul-21	BAGALKOT	220	VAJRAMATTI220- KUDAGI2	VAJRAMATTI_220	14:10	19:01	4:51	LINE FAULT
1066	26-Jul-21	BENGALURU	66	B G ROAD - JIGANI	NO STATION AFFECTED	5:49	6:59	1:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1067	26-Jul-21	BENGALURU	66	CHANDAPURA - YARANANAHALLI	CHANDAPURA	6:18	6:28	0:10	LOAD CHANGE OVER
1068	26-Jul-21	BENGALURU	66	EXORA - CESSNA	EXORA	10:20	12:00	1:40	LINE CLEAR AVAILED
1069	26-Jul-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:00	17:05	0:05	LOAD CHANGE OVER
1070	26-Jul-21	BENGALURU	66	HV1	HAL 220	9:45	11:27	1:42	LINE CLEAR AVAILED
1071	26-Jul-21	BENGALURU	66	HV1	HAL 220	13:38	13:42	0:04	TRANSFORMER FAULT
1072	26-Jul-21	BENGALURU	66	HV1	HOODY 220	11:14	11:21	0:07	LINE CLEAR AVAILED
1073	26-Jul-21	BENGALURU	66	HV1	RMZ	12:54	12:56	0:02	LINE CLEAR AVAILED
1074	26-Jul-21	BENGALURU	66	HV1	KIADB DB PURA 220	10:56	10:58	0:02	LINE CLEAR AVAILED
1075	26-Jul-21	BENGALURU	66	HV1	KIADB DB PURA 220	17:12	17:17	0:05	LINE CLEAR AVAILED
1076	26-Jul-21	BENGALURU	66	HV1	T GOLLAHALLI	23:10:00(23/07/2021)	19:33(26/07/2021)	20:23 hrs	TRANSFORMER CHARGED
1077	26-Jul-21	BENGALURU	66	HV1	SOMENAHALLI	13:04	15:01	1:56	LINE CLEAR AVAILED
1078	26-Jul-21	BENGALURU	66	HV2	BMTC	14:30	14:44	0:14	LINE CLEAR AVAILED
1079	26-Jul-21	BENGALURU	66	HV2	BMTC	16:14	16:20	0:06	LINE CLEAR AVAILED
1080	26-Jul-21	BENGALURU	66	HV2	HAL 220	12:56	13:40	0:44	LINE CLEAR AVAILED
1081	26-Jul-21	BENGALURU	66	HV2	RMZ	12:58	13:00	0:02	LINE CLEAR AVAILED
1082	26-Jul-21	BENGALURU	66	HV2	TEMAGONDALU	11:29	11:45	0:15	LINE CLEAR AVAILED
1083	26-Jul-21	BENGALURU	66	HV3	RMZ	13:04	13:07	0:03	LINE CLEAR AVAILED
1084	26-Jul-21	BENGALURU	66	HV4	B STATION	21:25	22:05	0:40	TRANSFORMER FAULT
1085	26-Jul-21	BENGALURU	66	HV4	B STATION	22:18:00(26/07/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1086	26-Jul-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	20:23	20:55	0:32	LOAD CURTAILMENT
1087	26-Jul-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	20:21	20:59	0:37	LOAD CURTAILMENT
1088	26-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
1089	26-Jul-21	GULBARGA	110	CHITGUPPA-ACMSLR	CHITGUPPA_110	13:35	14:30	0:55	LINE CLEAR AVAILED
1090	26-Jul-21	GULBARGA	110	GABBUR-BPSLR	GABBUR_110	11:37	12:50	1:13	LINE FAULT
1091	26-Jul-21	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_1110	5:21	5:29	0:08	LINE FAULT
1092	26-Jul-21	GULBARGA	110	HALBARGA-ACME SOLAR_IPP	HALBARGA_220	20:27	22:14	1:47	LINE CLEAR AVAILED
1093	26-Jul-21	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110	5:47	5:51	0:04	LINE FAULT
1094	26-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1095	26-Jul-21	GULBARGA	110	HV1	MARGUTTI_110	15:06	15:42	0:36	LINE CLEAR AVAILED
1096	26-Jul-21	GULBARGA	110	HV1	MYLAR_110	15:29	16:50	1:21	LINE CLEAR AVAILED
1097	26-Jul-21	GULBARGA	110	HV2	SREERAMNAGAR_110	11:10	12:25	1:15	LINE CLEAR AVAILED
1098	26-Jul-21	GULBARGA	110	YELBURGA-PRPJSR	YELBURGA_110	11:43	15:37	3:54	LINE CLEAR AVAILED
1099	26-Jul-21	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	13:48	14:54	1:06	LINE CLEAR AVAILED
1100	26-Jul-21	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	14:40	15:05	0:25	LINE CLEAR AVAILED
1101	26-Jul-21	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	14:40	15:08	0:28	LINE CLEAR AVAILED
1102	26-Jul-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1103	26-Jul-21	GULBARGA	220	HV1 & HV2	ITTAGI_220	9:50	10:05	0:15	TRANSFORMER FAULT
1104	26-Jul-21	GULBARGA	220	ITTAGI-BMMISPAT_IPP	ITTAGI_220	14:13	14:26	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1105	26-Jul-21	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	17:30(24.07.2021)	15:06(26.2021)	45:36HRS	LINE CHARGED
1106	26-Jul-21	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	23:14	23:26	0:12	LINE FAULT
1107	26-Jul-21	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	11:50(26.07.2021)			LINE OPEN:LINE CLEAR AVILED
1108	26-Jul-21	GULBARGA	220	SEDAM-RTPS1	RTPS_220	11:06	16:22	5:16	LINE CLEAR AVAILED
1109	26-Jul-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	9:22(25.07.2021)	18:21(26.07.2021)	32:59HRS	LINE CHARGED
1110	26-Jul-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	21:30(26.07.2021)			LINE OPEN:LINE CLEAR AVILED
1111	26-Jul-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	0:26	6:02	5:36	LINE CLEAR AVAILED
1112	26-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	18:18(25.07.2021)	13:57(26.07.2021)	19:39HRS	LINE CHARGED
1113	26-Jul-21	HASSAN	66	BASAVAG-DUDDA	BASAVAGHATTA_66	11:07	14:57	3:50	MAIN SUPPLY FAILURE
1114	26-Jul-21	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	10:24	15:40	5:16	LINE CLEAR AVAILED
1115	26-Jul-21	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA_66	10:26	15:42	5:16	MAIN SUPPLY FAILURE
1116	26-Jul-21	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	10:26	15:41	5:15	LINE CLEAR AVAILED
1117	26-Jul-21	HASSAN	66	GANGUR-HASSAN	GANGUR_66	12:00	13:05	1:05	MAIN SUPPLY FAILURE
1118	26-Jul-21	HASSAN	66	HAGARE-HASSAN	HAGARE_66	12:00	13:20	1:20	MAIN SUPPLY FAILURE
1119	26-Jul-21	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:36	11:09	0:33	LINE CLEAR AVAILED
1120	26-Jul-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	9:52	9:55	0:03	HAND TRIPPED
1121	26-Jul-21	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	17:06	17:10	0:04	HAND TRIPPED
1122	26-Jul-21	HASSAN	66	HV1	SAKLESHPURA_66	20:26 (26.7.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1123	26-Jul-21	HASSAN	66	HV1	GANGUR_66	12:00	13:05	1:05	HAND TRIPPED
1124	26-Jul-21	HASSAN	66	HV1	HALEBEEDU_66	12:03	13:48	1:45	MAIN SUPPLY FAILURE
1125	26-Jul-21	HASSAN	66	HV1	HANGRANAHALLY_66	15:03	15:56	0:53	LINE CLEAR AVAILED
1126	26-Jul-21	HASSAN	66	HV1	NAGARTHI_66	9:52	9:58	0:06	MAIN SUPPLY FAILURE
1127	26-Jul-21	HASSAN	66	HV1	NAGARTHI_66	17:07	17:09	0:02	MAIN SUPPLY FAILURE
1128	26-Jul-21	HASSAN	66	HV1	RAMPURA_66	14:35	16:09	1:34	LINE CLEAR AVAILED
1129	26-Jul-21	HASSAN	66	HV1	SAKLESHPURA_66	11:07	11:17	0:10	TRANSFORMER FAULT
1130	26-Jul-21	HASSAN	66	HV1	SIGEBAGE_66	12:54	13:51	0:57	LINE CLEAR AVAILED
1131	26-Jul-21	HASSAN	66	HV1	SINGAPURA_66	13:51	14:40	0:49	LINE CLEAR AVAILED
1132	26-Jul-21	HASSAN	66	HV2	DIDIGA_66	11:46	12:54	1:08	LINE CLEAR AVAILED
1133	26-Jul-21	HASSAN	66	HV2	HALEBEEDU_66	12:04	13:48	1:44	MAIN SUPPLY FAILURE
1134	26-Jul-21	HASSAN	66	HV2	HASSAN_66	2:25	2:30	0:05	TRANSFORMER FAULT
1135	26-Jul-21	HASSAN	66	HV2	KANDLI_66	11:41	13:06	1:25	LINE CLEAR AVAILED
1136	26-Jul-21	HASSAN	66	HV2	RAMPURA_66	14:35	16:09	1:34	LINE CLEAR AVAILED
1137	26-Jul-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	11:00	17:17	6:17	LINE CLEAR AVAILED
1138	26-Jul-21	HASSAN	66	HV2	SINGAPURA_66	13:52	14:40	0:48	LINE CLEAR AVAILED
1139	26-Jul-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:43(25.7.2021)			LINE OPEN:LINE FAULT
1140	26-Jul-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVILED
1141	26-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVILED
1142	26-Jul-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:00(23.7.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1143	26-Jul-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	14:32	16:55	2:23	HAND TRIPPED
1144	26-Jul-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	14:32	16:55	2:23	HAND TRIPPED
1145	26-Jul-21	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	21:39 (26.7.2021)			LINE OPEN:LINE FAULT
1146	26-Jul-21	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	10:44	15:28	4:44	LINE CLEAR AVAILED
1147	26-Jul-21	HASSAN	220	SHRAVITY-SHARAVATHY3	sharavathy_gen	14:09	16:56	2:47	LINE FAULT
1148	26-Jul-21	HASSAN	220	SHRAVITY-SHARAVATHY4	sharavathy_gen	14:09	16:54	2:45	LINE FAULT
1149	26-Jul-21	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	14:09 (26.7.2021)			LINE OPEN:LINE FAULT
1150	26-Jul-21	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	14:09 (26.7.2021)			LINE OPEN:LINE FAULT
1151	26-Jul-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	14:09	16:52	2:43	LINE FAULT
1152	26-Jul-21	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	14:41	16:52	2:11	HAND TRIPPED
1153	26-Jul-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	21:39 (26.7.2021)			LINE OPEN:LINE FAULT
1154	26-Jul-21	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	10:44	15:28	4:44	NFBC ISSUED
1155	26-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:10(25.7.2021)	7:03 (26.7.2021)	7:53hrs	LINE CHARGED
1156	26-Jul-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:59(26.7.2021)			LINE OPEN:LINE CLEAR AVILED
1157	26-Jul-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:45(25.7.2021)	7:24(26.7.2021)	9:39hrs	LINE CHARGED
1158	26-Jul-21	MYSURU	66	HV1	PONNAMPET_66	15:53	16:01	0:07	TRANSFORMER FAULT
1159	26-Jul-21	MYSURU	66	HV1	SUTTUR_66	11:35	13:43	2:08	LINE CLEAR AVAILED
1160	26-Jul-21	MYSURU	66	HV2	SUTTUR_66	13:45	15:24	1:38	LINE CLEAR AVAILED
1161	26-Jul-21	MYSURU	66	HV3	KIKKERI_66	14:38	14:39	0:01	HAND TRIPPED
1162	26-Jul-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVILED
1163	26-Jul-21	MYSURU	66	YELANDURU-MADHUNALLY	NO STATIONS EFFECTED	19:35	19:42	0:07	LINE FAULT
1164	26-Jul-21	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	11:32	11:40	0:07	LINE FAULT
1165	26-Jul-21	TUMKUR	66	HIRIYURKV 220kV- SUZLON 2	SUZLON1_IPP_66	13:47	15:13	1:25	LINE CLEAR AVAILED
1166	26-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:40	15:08	0:28	LINE FAULT
1167	26-Jul-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	8:53	8:58	0:05	LINE FAULT
1168	26-Jul-21	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	ENERCON1_IPP_66	11:58	12:23	0:25	LOAD CURTAILMENT
1169	26-Jul-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WLSPNSOLAR1	11:38	11:47	0:08	HAND TRIPPED
1170	26-Jul-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WLSPNSOLAR2	11:38	11:47	0:08	HAND TRIPPED
1171	26-Jul-21	TUMKUR	66	TR-1	BUKKAPATNA_66	12:02	13:47	1:45	LINE CLEAR AVAILED
1172	26-Jul-21	TUMKUR	66	TR-1	HIRIYUR_66	7:10	7:16	0:06	TRANSFORMER FAULT
1173	26-Jul-21	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:53	9:15	0:22	LINE CLEAR AVAILED
1174	26-Jul-21	TUMKUR	66	TR-2	ANCHEPALYA_220	9:36	15:01	5:25	LINE CLEAR AVAILED
1175	26-Jul-21	TUMKUR	66	TR-2	HIRIYUR_66	10:38	11:08	0:30	LINE CLEAR AVAILED
1176	26-Jul-21	TUMKUR	66	TR-2	HOLALKERE_66	22:40	22:45	0:05	TRANSFORMER FAULT
1177	26-Jul-21	TUMKUR	66	TR-2	THALLAKK_220	15:34	16:10	0:35	HAND TRIPPED
1178	26-Jul-21	TUMKUR	66	TR-2	TUMKUR_66	14:00	14:42	0:42	LINE CLEAR AVAILED
1179	26-Jul-21	TUMKUR	110	TR-2	TURUVEKERE_110	22:03	22:08	0:04	HAND TRIPPED
1180	26-Jul-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:49	11:54	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1181	26-Jul-21	TUMKUR	220	JAGALUR 400kV-THALLAKK 220kV	THALLAKK_220	11:29	14:42	3:12	LINE CLEAR AVAILED
1182	26-Jul-21	TUMKUR	220	THALLAK 220kV- HIREMALLANAHOLE 1	HIREMALLANAHOLE 1	11:35	14:42	3:07	NFBC ISSUED
1183	26-Jul-21	TUMKUR	220	TR-2	ANCHEPALYA_220	9:36	13:42	4:06	LINE CLEAR AVAILED
1184	26-Jul-21	TUMKUR	220	TR-2	THALLAKK_220	15:34	16:07	0:33	HAND TRIPPED