

400/220/110/66 kV TRANSMISSION OUTAGES : 08.09. 2020 TO 14.09.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	8-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
2	8-Sep-20	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	17:29	17:36	00:07	LINE CLEAR AVAILED
3	8-Sep-20	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	12:50	16:41	03:51	LINE CLEAR AVAILED
4	8-Sep-20	BAGALKOT	110	110/11KV, HV3, HV2A, HV1A	JAMKHANDI_110	15:59	16:16	00:17	LINE CLEAR AVAILED
5	8-Sep-20	BAGALKOT	110	110/11KV,HV 1	BYADAGI_110	03:19	12:10	08:51	TRANSFORMER FAULT
6	8-Sep-20	BAGALKOT	110	110/11KV,HV 1	HATTARAGI_110	12:41	13:28	00:47	HAND TRIPPED
7	8-Sep-20	BAGALKOT	110	110/11KV,HV 2	BYADAGI_110	06:31	07:12	00:41	HAND TRIPPED
8	8-Sep-20	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110, KANAGALA 33, HEBBAL 33	17:26	17:29	00:03	LINE CLEAR AVAILED
9	8-Sep-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG 110	15:54 (04.08.2020)	18:14 (8.9.2020)	86 hrs	TRANSFORMER CHARGED
10	8-Sep-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	10:02 (06.09.2020)	10:42 (08.09.2020)	56:13 hrs	TRANSFORMER CHARGED
11	8-Sep-20	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT 220	13:05 (27.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVILED
12	8-Sep-20	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	13:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
13	8-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
14	8-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA 110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
15	8-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
16	8-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
17	8-Sep-20	BAGALKOT	110	HAVERI-TILUVALLI	TILUVALLI_110	06:46	11:28	04:42	LINE FAULT
18	8-Sep-20	BAGALKOT	110	HUNGUND- KUDALSANGAM	KUDAL SANGAM_110	09:04	09:20	00:16	HAND TRIPPED
19	8-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR 110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AVAILED
20	8-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
21	8-Sep-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)	6:47 (8.9.2020)	2441.20 hrs	LINE CHARGED
22	8-Sep-20	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	17:10	17:15	00:05	LINE CLEAR AVAILED
23	8-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
24	8-Sep-20	BAGALKOT	110	VIJAYANAGAR SUGARS- MUNDARGI	MUNDARGI_110	10:47	10:52	00:05	LINE FAULT
25	8-Sep-20	BAGALKOT	220	220/110KV, HV1&LV1	RANEENNUR_220	15:40	19:40	04:00	TRANSFORMER FAULT
26	8-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
27	8-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
28	8-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:56	11:08	00:12	HAND TRIPPED
29	8-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	23:58			LOAD CURTAILMENT
30	8-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
31	8-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
32	8-Sep-20	BENGALURU	66	BANASAWADI - ITI 220	BANASAWADI	07:50	07:54	00:04	LOAD CHANGE OVER
33	8-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
34	8-Sep-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY PH-2 SEC-1	ELECTRONIC CITY, INFOSYS (EHT)	15:37	16:00	00:23	MAIN SUPPLY FAILURE
35	8-Sep-20	BENGALURU	66	ELECTRONIC CITY PH 2 SEC 1 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC -1	15:37	16:40	01:03	MAIN SUPPLY FAILURE
36	8-Sep-20	BENGALURU	66	ELECTRONIC CITY PH2 SEC 2 - NAGNATHPURA 220	ELECTRONIC CITY PH -2 SEC- 2,BIOCON(EHT)	15:37	16:39	01:02	MAIN SUPPLY FAILURE
37	8-Sep-20	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	10:46	10:51	00:05	LOAD CHANGE OVER
38	8-Sep-20	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	07:14	08:44	01:30	LINE FAULT
39	8-Sep-20	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	09:49	10:14	00:25	LINE FAULT
40	8-Sep-20	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	07:02	07:14	00:12	LINE FAULT
41	8-Sep-20	BENGALURU	66	HV1	KADUBISANAHLLI	08:35	10:50	02:15	LINE CLEAR AVAILED
42	8-Sep-20	BENGALURU	66	HV1	KORAMANGALA	15:28	15:32	00:04	LINE CLEAR AVAILED
43	8-Sep-20	BENGALURU	66	HV1	D CROSS	15:25	15:34	00:08	LINE CLEAR AVAILED
44	8-Sep-20	BENGALURU	66	HV1	HAROBELE	15:00	15:15	00:15	LINE CLEAR AVAILED
45	8-Sep-20	BENGALURU	66	HV1	KUMBALAGODU	21:05(07/09/2020)	11:20(08/09/2020)	14:15HRS	TRANSFORMER FAULT
46	8-Sep-20	BENGALURU	66	HV2	SARJAPURA 220	11:55	13:53	01:58	LINE CLEAR AVAILED
47	8-Sep-20	BENGALURU	66	HV2	SARJAPURA 220	13:53	15:05	01:11	LINE CLEAR AVAILED
48	8-Sep-20	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	14:31	14:42	00:11	LINE CLEAR AVAILED
49	8-Sep-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:31	14:42	00:11	LINE CLEAR AVAILED
50	8-Sep-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:31	16:08	01:37	LINE CLEAR AVAILED
51	8-Sep-20	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	12:15	12:20	00:05	LINE CLEAR AVAILED
52	8-Sep-20	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	13:15	13:20	00:05	LINE CLEAR AVAILED
53	8-Sep-20	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	13:40	13:50	00:10	LINE CLEAR AVAILED
54	8-Sep-20	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	14:15	14:20	00:05	LINE CLEAR AVAILED
55	8-Sep-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	10:41	17:06	06:25	LINE CLEAR AVAILED
56	8-Sep-20	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	18:14 (ON 09-09-2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
57	8-Sep-20	BENGALURU	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	15:40	16:36	00:56	MAIN SUPPLY FAILURE
58	8-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
59	8-Sep-20	BENGALURU	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220	15:39	16:30	00:51	LINE FAULT
60	8-Sep-20	GULBARGA	110	HV1	KEMBHAVI_110	10:30	11:05	00:35	TRANSFORMER FAULT
61	8-Sep-20	GULBARGA	110	HV1	KEMBHAVI_110	11:15	11:50	00:35	TRANSFORMER FAULT
62	8-Sep-20	GULBARGA	110	HV2	MADIYAL	11:30	11:43	00:13	LINE CLEAR AVOIDED
63	8-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
64	8-Sep-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	18:12	18:26	00:14	LINE FAULT
65	8-Sep-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	06:20	06:42	00:22	LINE FAULT
66	8-Sep-20	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	18:40(8.9.2020)			LINE OPEN:LINE FAULT
67	8-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	16:33	16:47	00:14	LINE FAULT
68	8-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	17:34	18:30	00:56	LINE FAULT
69	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	00:54	01:09	00:15	LINE FAULT
70	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	02:16	02:36	00:20	LINE FAULT
71	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	03:47	04:08	00:21	LINE FAULT
72	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	05:29	05:52	00:23	LINE FAULT
73	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	12:39	13:02	00:23	LINE CLEAR AVOIDED
74	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	13:50	15:02	01:12	LINE CLEAR AVOIDED
75	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:48	19:56	00:08	LINE FAULT
76	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:51	22:26	00:35	LINE FAULT
77	8-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:03	23:39	00:36	LINE FAULT
78	8-Sep-20	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	04:00	04:30	00:30	MAIN SUPPLY FAILURE
79	8-Sep-20	GULBARGA	220	HV1	KUSHTAGI_220	04:00	06:00	02:00	TRANSFORMER FAULT
80	8-Sep-20	GULBARGA	220	HV1	SEDAM_220	18:46	19:36	00:50	TRANSFORMER FAULT
81	8-Sep-20	GULBARGA	220	HV2	KUSHTAGI_220	04:00	06:32	02:32	LINE CLEAR AVOIDED
82	8-Sep-20	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	04:00	05:46	01:46	LINE FAULT
83	8-Sep-20	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	12:17	13:28	01:11	LINE CLEAR AVOIDED
84	8-Sep-20	GULBARGA	220	KUSHTAGI-SUZLON WIND1	KUSHTAGI_220	04:00	13:06	09:06	LINE CLEAR AVOIDED
85	8-Sep-20	GULBARGA	220	KUSHTAGI-SUZLON WIND2	KUSHTAGI_220	04:00			LINE OPEN:LINE FAULT
86	8-Sep-20	GULBARGA	220	LINGAPUR-KUSHTAGI	KUSHTAGI_220	04:00	06:30	02:30	LINE FAULT
87	8-Sep-20	GULBARGA	400	BTPS-RTPS	BTPS_400	05:48	15:00	09:12	LINE FAULT
88	8-Sep-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:00	12:46	01:46	LINE CLEAR AVOIDED
89	8-Sep-20	HASSAN	66	BHARA-LINGADAHALLI	bhadra_gen	12:54	13:00	00:06	LINE FAULT
90	8-Sep-20	HASSAN	66	HV1	RAMPURA_66	12:00	12:30	00:30	LINE CLEAR AVOIDED
91	8-Sep-20	HASSAN	66	HV1	SOMANAHALLI_66	07:58	08:42	00:44	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
92	8-Sep-20	HASSAN	66	HV2	TAVARECHANAHALLI_66	14:43	15:16	00:33	TRANSFORMER FAULT
93	8-Sep-20	HASSAN	110	HV1	ANAVATTI_110	07:40	07:45	00:05	MAIN SUPPLY FAILURE
94	8-Sep-20	HASSAN	110	HV1	ARASIKERE_110	13:05	13:25	00:20	LINE CLEAR AVAILED
95	8-Sep-20	HASSAN	110	HV2	ANAVATTI_110	07:40	07:45	00:05	TRANSFORMER FAULT
96	8-Sep-20	HASSAN	110	HV3	HIRIYADKA_110	11:11	15:54	04:43	LINE CLEAR AVAILED
97	8-Sep-20	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	10:00	13:15	03:15	LINE CLEAR AVAILED
98	8-Sep-20	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	19:07 (6.09.2020)			MAIN SUPPLY FAILURE
99	8-Sep-20	HASSAN	220	KADUR-DABUSET	KADUR_220	18:15 (8.09.2020)			LINE OPEN: LINE FAULT
100	8-Sep-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	17:23 (7.09.2020)	15:59 (8.09.2020)	22:37 hrs	LINE CHARGED
101	8-Sep-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	17:23 (7.09.2020)	16:05 (8.09.2020)	22:41 hrs	LINE CHARGED
102	8-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47 (8.09.2020)			LINE OPEN: LINE CLEAR AVAILED
103	8-Sep-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:50 (7.09.2020)	6:38 (8.09.2020)	7:47 hrs	LINE CHARGED
104	8-Sep-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN: LINE CLEAR AVAILED
105	8-Sep-20	MYSURU	66	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	09:09	13:50	04:41	HAND TRIPPED
106	8-Sep-20	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	09:19	13:40	04:20	HAND TRIPPED
107	8-Sep-20	MYSURU	66	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66 RKNAGARA_66	19:54	19:57	00:03	HAND TRIPPED
108	8-Sep-20	MYSURU	66	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66	13:00	13:33	00:33	HAND TRIPPED
109	8-Sep-20	MYSURU	66	HOOTAGALLI-MCF	NO STATIONS EFFECTED	08:43	13:50	05:07	HAND TRIPPED
110	8-Sep-20	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	NO STATIONS EFFECTED	09:25	13:46	04:21	HAND TRIPPED
111	8-Sep-20	MYSURU	66	HV1	BANANGADI_66	18:10	18:15	00:04	TRANSFORMER FAULT
112	8-Sep-20	MYSURU	66	HV1	GUNDULPET_66	12:46	14:19	01:33	LINE CLEAR AVAILED
113	8-Sep-20	MYSURU	66	HV2	PGPALYA_66	12:00	13:45	01:45	LINE CLEAR AVAILED
114	8-Sep-20	MYSURU	66	HV2	SATHEGALA_66	06:15	08:11	01:56	LINE CLEAR AVAILED
115	8-Sep-20	MYSURU	66	HV2	SANTHEBACHALLI_66	12:55	14:06	01:11	LINE CLEAR AVAILED
116	8-Sep-20	MYSURU	66	KUSHALNAGARA 220- BYLKUPPE	BYLKUPPE_66 PERIYAPATNA_66 HANAGODU_66 PONNAMPET_66 VIRAJPET_66	12:07	12:15	00:07	LINE FAULT
117	8-Sep-20	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	14:15	14:20	00:05	HAND TRIPPED
118	8-Sep-20	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	18:47	18:58	00:11	LINE FAULT
119	8-Sep-20	MYSURU	66	RK NAGARA-DATTAGALLI	RKNAGARA_66	10:00	16:20	06:20	LINE CLEAR AVAILED
120	8-Sep-20	MYSURU	66	RK NAGARA-MANTAGALLY	RKNAGARA_66	10:00	16:29	06:29	LINE CLEAR AVAILED
121	8-Sep-20	MYSURU	66	TUBINKERE -NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	08:40	08:45	00:05	LINE FAULT
122	8-Sep-20	MYSURU	220	HV1	HOOTAGALLY_220	10:02	13:26	03:24	LINE CLEAR AVAILED
123	8-Sep-20	MYSURU	220	HV1	KADAKOLA_220	13:58	14:21	00:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
124	8-Sep-20	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	11:03:04 PM(23:12:25)			LINE OPEN:LINE FAULT
125	8-Sep-20	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	19:16	19:17	00:01	LINE FAULT
126	8-Sep-20	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	09:18	09:27	00:08	LINE FAULT
127	8-Sep-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS- 1	INFOSYS-1	11:10	11:20	00:10	LINE FAULT
128	8-Sep-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	06:18	06:33	00:14	LINE FAULT
129	8-Sep-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	07:12	08:38	01:25	LINE FAULT
130	8-Sep-20	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	18:29	18:41	00:11	LINE FAULT
131	8-Sep-20	TUMKUR	66	PAVAGADA66-VENKATAPURA	PAVAGADA_66	18:29	18:52	00:23	LINE FAULT
132	8-Sep-20	TUMKUR	66	TR-1	BADAVANAHALLI_66	16:21	16:57	00:35	LINE CLEAR AVAILED
133	8-Sep-20	TUMKUR	66	TR-1	KUNDUR_66	17:53	18:05	00:11	LINE CLEAR AVAILED
134	8-Sep-20	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	12:25	13:12	00:46	LINE CLEAR AVAILED
135	8-Sep-20	TUMKUR	66	TR-1	MYLANAHALLI_66	07:22	07:36	00:14	TRANSFORMER FAULT
136	8-Sep-20	TUMKUR	66	TR-1	NYAMATHI_66	15:21	18:10	02:48	LINE CLEAR AVAILED
137	8-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
138	8-Sep-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	10:34	11:43	01:09	TRANSFORMER FAULT
139	8-Sep-20	TUMKUR	66	TR-2	MANGALWADA_66	01:47	01:53	00:06	TRANSFORMER FAULT
140	8-Sep-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	10:20	13:08	02:47	LINE CLEAR AVAILED
141	8-Sep-20	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	07:46	18:50	11:03	MAIN SUPPLY FAILURE
142	8-Sep-20	TUMKUR	110	NITTUR 220kv- GUBBI	GUBBI_110, BIDARE_110	07:37	09:04	01:26	LINE CLEAR AVAILED
143	8-Sep-20	TUMKUR	110	NITTUR 220kv- GUBBI	GUBBI_110, BIDARE_110	17:34	18:50	01:16	LINE CLEAR AVAILED
144	8-Sep-20	TUMKUR	110	TR-1	BIDARE_110	13:35	18:50	05:14	MAIN SUPPLY FAILURE
145	8-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
146	8-Sep-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	10:35	12:19	01:44	LINE CLEAR AVAILED
147	8-Sep-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	12:23	14:09	01:46	LINE CLEAR AVAILED
148	8-Sep-20	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	10:34	12:20	01:45	LINE CLEAR AVAILED
149	8-Sep-20	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	9:50:16 PM(08.09.2020)			LINE OPEN: LINE CLEAR AVAILED
150	8-Sep-20	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	16:05	17:34	01:28	LINE CLEAR AVAILED
151	8-Sep-20	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	10:20	13:07	02:46	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
152	9-Sep-20	BAGALKOT	66	110/33KV,HV3	HARIHAR-HOSPET_66 (NO 33KV LINES)	0:09	16:20	16:11	TRANSFORMER FAULT
153	9-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
154	9-Sep-20	BAGALKOT	110	110/11KV, HV1	ITANAL_110	14:56	15:24	0:28	LINE CLEAR AVAILED
155	9-Sep-20	BAGALKOT	110	110/11KV,HV1&2	BYADAGI_110	16:15	16:40	0:25	HAND TRIPPED
156	9-Sep-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI 33, HALSANGI 33	18:17	18:26	0:09	TRANSFORMER FAULT
157	9-Sep-20	BAGALKOT	110	110/33KV,HV3	GOPPANAKOPPA_110	15:18	15:58	0:40	HAND TRIPPED
158	9-Sep-20	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVILED
159	9-Sep-20	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
160	9-Sep-20	BAGALKOT	110	AMBEWADI-NK 1	HALIYAL_110	14:40	15:14	0:34	HAND TRIPPED
161	9-Sep-20	BAGALKOT	110	ANKALAGI-HIDIKAL	HIDIKAL_110	4:05	4:21	0:16	LINE FAULT
162	9-Sep-20	BAGALKOT	110	ANKALAGI-HIDIKAL	HIDIKAL_110	5:48	6:10	0:22	LINE FAULT
163	9-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
164	9-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
165	9-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
166	9-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
167	9-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AVAILED
168	9-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
169	9-Sep-20	BAGALKOT	110	LAXMESHVAR- BELLATTI	BELLATTI_110	5:20	5:49	0:29	LINE FAULT
170	9-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
171	9-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
172	9-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AVAILED
173	9-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	23:58 (08.09.2020)	8:15 (09.09.2020)	8:17hrs	LINE CHARGED
174	9-Sep-20	BAGALKOT	220	BELGAUM- NARENDRA2(KANABARGI2)	BELGAUM_220	0:20	8:13	7:53	HAND TRIPPED
175	9-Sep-20	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	11:07	18:48	7:41	NFBC ISSUED
176	9-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
177	9-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
178	9-Sep-20	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	12:36	17:56	5:20	LINE FAULT
179	9-Sep-20	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	12:59	17:55	4:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
180	9-Sep-20	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	21:51 (09.09.2020)			LINE OPEN:LINE FAULT
181	9-Sep-20	BAGALKOT	400	DHONI-GUDDADAHALLI	DHONI_400	20:40 (09.09.2020)			LINE OPEN:LINE FAULT
182	9-Sep-20	BENGALURU	66	BANASAWADI - ITI 220	BASASAWADI	08:58	09:02	00:04	LOAD CHANGE OVER
183	9-Sep-20	BENGALURU	66	BANASAWADI - ITI 220	BASASAWADI	20:10	20:15	00:05	LOAD CHANGE OVER
184	9-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
185	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	12:01	12:14	00:13	LINE CLEAR AVAILED
186	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	12:55	12:58	00:03	LINE CLEAR AVAILED
187	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	12:01	12:14	00:13	LINE CLEAR AVAILED
188	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	12:55	12:58	00:03	LINE CLEAR AVAILED
189	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	12:01	12:14	00:13	LINE CLEAR AVAILED
190	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	12:55	12:58	00:03	LINE CLEAR AVAILED
191	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	12:01	12:14	00:13	LINE CLEAR AVAILED
192	9-Sep-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	12:55	12:58	00:03	LINE CLEAR AVAILED
193	9-Sep-20	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	03:00	03:15	00:15	LINE CHARGED
194	9-Sep-20	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	19:15	19:24	00:09	LINE FAULT
195	9-Sep-20	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	03:00	03:14	00:14	LINE CHARGED
196	9-Sep-20	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	08:35	08:59	00:24	LOAD CHANGE OVER
197	9-Sep-20	BENGALURU	66	HENNUR CROSS - VIDHYANAGARA	HENNUR CROSS	03:30	14:52	11:22	LINE CHARGED
198	9-Sep-20	BENGALURU	66	HV1	MELUR	10:19	13:59	03:40	LINE CLEAR AVAILED
199	9-Sep-20	BENGALURU	66	HV1	NARASAPURA	17:00	17:49	00:49	LINE CLEAR AVAILED
200	9-Sep-20	BENGALURU	66	HV1	YELAHANKA 220	01:51	02:50	00:58	TRANSFORMER FAULT
201	9-Sep-20	BENGALURU	66	HV2	BMTC	16:31	16:42	00:11	TRANSFORMER FAULT
202	9-Sep-20	BENGALURU	66	HV2	IISc	03:31	03:38	00:07	TRANSFORMER FAULT
203	9-Sep-20	BENGALURU	66	HV2	KADUGODI	02:33	05:00	02:27	TRANSFORMER FAULT
204	9-Sep-20	BENGALURU	66	HV2	RANGANDODDI	14:01	14:18	00:16	LINE CLEAR AVAILED
205	9-Sep-20	BENGALURU	66	HV2	BMTC	16:31(09/09/2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
206	9-Sep-20	BENGALURU	66	IISC - HEBBAL 220	IISC	03:26	03:28	00:02	LOAD CHANGE OVER
207	9-Sep-20	BENGALURU	66	IISC - NRS 220	IISC	11:20	11:25	00:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
208	9-Sep-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	22:14	22:47	00:33	LINE FAULT
209	9-Sep-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:50	13:34	01:44	LINE FAULT
210	9-Sep-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	17:47	17:49	00:01	LINE CLEAR AVAILED
211	9-Sep-20	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	04:30	04:35	00:04	LOAD CHANGE OVER
212	9-Sep-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:41	18:02	00:20	LINE FAULT
213	9-Sep-20	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	18:14 (ON 09-09-2020)	05:58:00(09/09/2020)	11:42hrs	LINE CHARGED
214	9-Sep-20	BENGALURU	220	HV2	HEBBALA 220	03:00	08:52	05:52	TRANSFORMER FAULT
215	9-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
216	9-Sep-20	GULBARGA	66	HOSAHALLI-AWADHSOLAR_IPP	HOSAHALLI_66	05:50	06:05	00:15	LINE FAULT
217	9-Sep-20	GULBARGA	66	HOSAHALLI-SMLWIND_IPP	HOSAHALLI_66	05:50	06:05	00:15	LINE FAULT
218	9-Sep-20	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	20:17	20:48	00:31	LINE FAULT
219	9-Sep-20	GULBARGA	110	HALBARGA-SANTHAPUR	DONGARGOAN_110,KAMAL ANAGAR_110,SANTHAPUR_110	06:05	06:11	00:06	LINE FAULT
220	9-Sep-20	GULBARGA	110	HV1	KAMPLI_110	08:40	08:50	00:10	TRANSFORMER FAULT
221	9-Sep-20	GULBARGA	110	HV1	KAMPLI_110	15:00	15:05	00:05	TRANSFORMER FAULT
222	9-Sep-20	GULBARGA	110	HV1	KAMPLI_110	16:10	16:20	00:10	LINE CLEAR AVAILED
223	9-Sep-20	GULBARGA	110	HV1	MALLAT_220	13:40	17:40	04:00	LINE CLEAR AVAILED
224	9-Sep-20	GULBARGA	110	HV2	KOLHAR_110	08:35	08:50	00:15	TRANSFORMER FAULT
225	9-Sep-20	GULBARGA	110	HV2	KOLHAR_110	12:00	12:10	00:10	TRANSFORMER FAULT
226	9-Sep-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_IPP,CHOWDAPUR_110	22:50	22:58	00:08	LINE FAULT
227	9-Sep-20	GULBARGA	110	KOLHAR-NSSKSUGARS_IPP	NSSK_SUGARS	15:20	15:25	00:05	LINE FAULT
228	9-Sep-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	00:35	00:45	00:10	LINE FAULT
229	9-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
230	9-Sep-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	11:30	11:36	00:06	LINE FAULT
231	9-Sep-20	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	19:45			LINE OPEN:LINE FAULT
232	9-Sep-20	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	18:40(8.9.2020)	14:05(9.9.2020)	19:25 HRS	LINE CHARGED
233	9-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	01:23	01:32	00:09	LINE FAULT
234	9-Sep-20	GULBARGA	110	SHAHAPUR-RAICHUR2	RAICHUR_220	20:24			LINE OPEN: LINE CLEAR AVAILED
235	9-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	12:10	18:18	06:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
236	9-Sep-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	18:20	18:24	00:04	LINE CLEAR AVAILED
237	9-Sep-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	23:28	23:38	00:10	LINE FAULT
238	9-Sep-20	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	20:05	20:15	00:10	LINE FAULT
239	9-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	03:20	03:28	00:08	LINE FAULT
240	9-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	06:00	06:20	00:20	LINE FAULT
241	9-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	18:10	18:20	00:10	LINE FAULT
242	9-Sep-20	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	00:42	01:26	00:44	LINE FAULT
243	9-Sep-20	GULBARGA	220	HV2	ITTAGGI_220	13:20	13:36	00:16	TRANSFORMER FAULT
244	9-Sep-20	GULBARGA	220	HV2	HUMNABAD_220	17:30	18:56	01:26	LINE CLEAR AVAILED
245	9-Sep-20	GULBARGA	220	KUSHTAGI-SUZLONWIND1	KUSHTAGI_220	17:46	22:46	05:00	LINE CLEAR AVAILED
246	9-Sep-20	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	15:25	18:10	02:45	LINE FAULT
247	9-Sep-20	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	20:40(9.9.2020)			LINE OPEN:LINE FAULT
248	9-Sep-20	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	11:35	13:47	02:12	LINE CLEAR AVAILED
249	9-Sep-20	HASSAN	66	HASSN220-HSN66	HASSAN_220	13:05	14:35	01:30	LINE CLEAR AVAILED
250	9-Sep-20	HASSAN	66	HASSN220-SUZLON	HASSAN_220	10:08	10:17	00:09	HAND TRIPPED
251	9-Sep-20	HASSAN	66	HASSN220-SUZLON	HASSAN_220	11:16	11:23	00:07	HAND TRIPPED
252	9-Sep-20	HASSAN	66	HV1	MALALI_66	10:25	12:35	02:10	LINE CLEAR AVAILED
253	9-Sep-20	HASSAN	66	HV2	TAVARECHATNAHALLY_66	01:10	02:17	01:07	TRANSFORMER FAULT
254	9-Sep-20	HASSAN	66	LV2	HASSAN_220	10:17	11:10	00:53	LINE CLEAR AVAILED
255	9-Sep-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:25	10:30	00:05	MAIN SUPPLY FAILURE
256	9-Sep-20	HASSAN	66	MALALI-HASSAN	MALALI_66	10:25	10:30	00:05	MAIN SUPPLY FAILURE
257	9-Sep-20	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:45	14:30	03:45	MAIN SUPPLY FAILURE
258	9-Sep-20	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	15:15	18:22	03:07	LINE CLEAR AVAILED
259	9-Sep-20	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	10:00	10:44	00:44	LINE CLEAR AVAILED
260	9-Sep-20	HASSAN	110	HV1	BIRUR_110	10:45	14:38	03:53	MAIN SUPPLY FAILURE
261	9-Sep-20	HASSAN	110	HV1	HIRENALLUR_110	08:30	14:40	06:10	LINE CLEAR AVAILED
262	9-Sep-20	HASSAN	110	HV1	HIRENALLUR_110	15:15	18:24	03:09	LINE CLEAR AVAILED
263	9-Sep-20	HASSAN	110	HV1	KONAJE_110	10:24	13:55	03:31	LINE CLEAR AVAILED
264	9-Sep-20	HASSAN	110	HV1	NITTUR_110	09:35	16:59	07:24	LINE CLEAR AVAILED
265	9-Sep-20	HASSAN	110	HV1	SHIVAPURA_110	10:45	14:30	03:45	MAIN SUPPLY FAILURE
266	9-Sep-20	HASSAN	110	HV2	BIRUR_110	10:45	14:38	03:53	MAIN SUPPLY FAILURE
267	9-Sep-20	HASSAN	110	HV2	KONAJE_110	11:12	11:17	00:05	HAND TRIPPED
268	9-Sep-20	HASSAN	110	HV2	KONAJE_110	13:08	13:12	00:04	HAND TRIPPED
269	9-Sep-20	HASSAN	110	HV2	KONAJE_110	13:44	13:50	00:06	HAND TRIPPED
270	9-Sep-20	HASSAN	110	HV3	KONAJE_110	11:12	11:17	00:05	HAND TRIPPED
271	9-Sep-20	HASSAN	110	HV3	KONAJE_110	13:08	13:12	00:04	HAND TRIPPED
272	9-Sep-20	HASSAN	110	HV3	KONAJE_110	13:44	13:50	00:06	HAND TRIPPED
273	9-Sep-20	HASSAN	110	JOG-JLT4	JOG_110	15:15	17:05	01:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
274	9-Sep-20	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	06:15	06:30	00:15	LINE FAULT
275	9-Sep-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	09:14	17:32	08:18	LINE CLEAR AVAILED
276	9-Sep-20	HASSAN	110	LV1	KADUR_220	10:10	19:05	08:55	LINE CLEAR AVAILED
277	9-Sep-20	HASSAN	110	LV2	KADUR_220	10:10	18:36	08:26	LINE CLEAR AVAILED
278	9-Sep-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	09:15	17:33	08:18	NFBC ISSUED
279	9-Sep-20	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	19:07 (6.09.2020)	17:35(9.09.2020)	70:28hrs	MAIN SUPPLY FAILURE
280	9-Sep-20	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	09:57	12:35	02:38	MAIN SUPPLY FAILURE
281	9-Sep-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	11:23	12:58	01:35	NFBC ISSUED
282	9-Sep-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	13:21	13:40	00:19	NFBC ISSUED
283	9-Sep-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:22	13:01	01:39	NFBC ISSUED
284	9-Sep-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	13:21	13:44	00:23	NFBC ISSUED
285	9-Sep-20	HASSAN	110	SHIVAPUR-NERLEKERE	SHIVAPURA_110	10:54	13:39	02:45	NFBC ISSUED
286	9-Sep-20	HASSAN	220	HV1	KADUR_220	10:10	19:05	08:55	LINE CLEAR AVAILED
287	9-Sep-20	HASSAN	220	HV2	KADUR_220	10:10	18:36	08:26	LINE CLEAR AVAILED
288	9-Sep-20	HASSAN	220	KADURD-ABUSET	KADUR_220	18:15 (8.09.2020)	5:54(09.09.2020)	11:39hrs	LINE CHARGED
289	9-Sep-20	HASSAN	220	KADURD-ABUSET	KADUR_220	07:29	09:04	01:35	LINE CLEAR AVAILED
290	9-Sep-20	HASSAN	220	KADURD-ABUSET	KADUR_220	10:50	18:30	07:40	LINE CLEAR AVAILED
291	9-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47 (8.09.2020)			LINE OPEN: LINE CLEAR AVAILED
292	9-Sep-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)	8:23 (9.09.2020)	200:47hrs	LINE CHARGED
293	9-Sep-20	MYSORE	66	BOOKANAKERE-CHINAKURALI	CHINAKURALI_66 BANANGADI_66	11:20	12:56	1:36	LINE CLEAR AVAILED
294	9-Sep-20	MYSORE	66	G UKKADA-SR PATNA	SRIRANGAPATNA_66	10:05	16:48	6:43	NFBC ISSUED
295	9-Sep-20	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	11:30	12:05	0:35	LINE CLEAR AVAILED
296	9-Sep-20	MYSORE	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	11:20	12:15	0:55	LINE CLEAR AVAILED
297	9-Sep-20	MYSORE	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	11:00	11:20	0:20	LINE CLEAR AVAILED
298	9-Sep-20	MYSORE	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	11:30	12:05	0:35	LINE CLEAR AVAILED
299	9-Sep-20	MYSORE	66	HANNUR-MADHUVANAHALLI 2	NO STATIONS EFFECTED	10:29	10:40	0:11	LINE CLEAR AVAILED
300	9-Sep-20	MYSORE	66	HANNUR-MADHUVANAHALLI 2	NO STATIONS EFFECTED	11:30	12:05	0:35	LINE CLEAR AVAILED
301	9-Sep-20	MYSORE	66	HV1	AKKIHEBBAL_66	17:03	17:28	0:25	LINE CLEAR AVAILED
302	9-Sep-20	MYSORE	66	HV1	DODDARAYAPET_66	10:00	14:45	4:45	LINE CLEAR AVAILED
303	9-Sep-20	MYSORE	66	HV1	DODDARAYAPET_66	16:04	16:39	0:35	LINE CLEAR AVAILED
304	9-Sep-20	MYSORE	66	HV1	HANNUR_66	11:30	12:45	1:15	LINE CLEAR AVAILED
305	9-Sep-20	MYSORE	66	HV1	HONNALLY_MYS_66	15:12	15:14	0:01	HAND TRIPPED
306	9-Sep-20	MYSORE	66	HV2	AKKIHEBBAL_66	15:52	17:28	1:36	LINE CLEAR AVAILED
307	9-Sep-20	MYSORE	66	HV2	HANNUR_66	11:30	12:30	1:00	LINE CLEAR AVAILED
308	9-Sep-20	MYSORE	66	HV2	KADAKOLA_220	13:12	13:20	0:08	HAND TRIPPED
309	9-Sep-20	MYSORE	66	KADAKOLA-RK NAGARA	NO STATIONS EFFECTED	11:30	13:31	2:01	HAND TRIPPED
310	9-Sep-20	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:06	11:15	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	9-Sep-20	MYSORE	66	KOLLEGALA-TALKADU	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	5:32	5:43	0:10	LINE FAULT
312	9-Sep-20	MYSORE	66	KOLLEGALA-TALKADU	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	13:52	13:57	0:05	LINE FAULT
313	9-Sep-20	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAIPURA_66 ADDIHALLI_66	4:15	4:26	0:11	LINE FAULT
314	9-Sep-20	MYSORE	66	TUBINKERE-NAGMANGALA 1	HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	23:07	23:11	0:04	LINE FAULT
315	9-Sep-20	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	23:03:04 (23:12:25)	14:47:53 (09.09.2020)	15:44hrs	LINE CHARGED
316	9-Sep-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	7:23	7:32	0:09	HAND TRIPPED
317	9-Sep-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:10	14:39	1:28	HAND TRIPPED
318	9-Sep-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	7:20	7:27	0:06	HAND TRIPPED
319	9-Sep-20	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	7:20	7:27	0:06	HAND TRIPPED
320	9-Sep-20	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	13:03	13:34	0:31	LINE FAULT
321	9-Sep-20	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	0:28	1:12	0:43	LINE FAULT
322	9-Sep-20	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:34	18:45	0:11	LINE FAULT
323	9-Sep-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	16:25	16:30	0:05	LINE FAULT
324	9-Sep-20	TUMKUR	66	TR-1	CHIKKABANAGERE_66	21:55	22:00	0:04	HAND TRIPPED
325	9-Sep-20	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	20:50	21:09	0:18	HAND TRIPPED
326	9-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
327	9-Sep-20	TUMKUR	66	TR-2	BAGUR_TMK_66	3:41	4:36	0:54	TRANSFORMER FAULT
328	9-Sep-20	TUMKUR	66	TR-2	CHIKKABANAGERE_66	21:55	22:00	0:04	HAND TRIPPED
329	9-Sep-20	TUMKUR	66	TR-2	HARIYABBE_66	20:50	22:09	1:19	HAND TRIPPED
330	9-Sep-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	23:32	23:41	0:08	TRANSFORMER FAULT
331	9-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
332	9-Sep-20	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	11:55	14:47	2:52	LINE CLEAR AVAILED
333	9-Sep-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	14:03	18:27	4:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
334	9-Sep-20	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	13:07	14:35	1:27	LINE CLEAR AVAILED
335	9-Sep-20	TUMKUR	220	NEELAGUNDA220kV- GUTTUR 220kV	NEELAGUNDA_220	10:35	13:52	3:16	LINE FAULT
336	9-Sep-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	21:50:16 (08.09.2020)			LINE OPEN: LINE CLEAR AVAILED
337	9-Sep-20	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	20:50	21:44	0:53	TRANSFORMER FAULT
338	10-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
339	10-Sep-20	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:15	17:10	6:55	LINE CLEAR AVAILED
340	10-Sep-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	9:33	10:03	0:30	LINE CLEAR AVAILED
341	10-Sep-20	BAGALKOT	110	110/11KV, HV1	MUNAVALLI_110	17:18	18:19	1:01	LINE CLEAR AVAILED
342	10-Sep-20	BAGALKOT	110	110/11KV, HV2	SIRSI_110	10:15	16:40	6:25	LINE CLEAR AVAILED
343	10-Sep-20	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
344	10-Sep-20	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:35	5:58	5:23	LOAD CURTAILMENT
345	10-Sep-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	22:54 (10.09.2020)			LOAD CURTAILMENT
346	10-Sep-20	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
347	10-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
348	10-Sep-20	BAGALKOT	110	ESALE1&2 (SIRSI220)- SIRSI	SIRSI_110	8:34	17:29	8:55	LINE CLEAR AVAILED
349	10-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
350	10-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
351	10-Sep-20	BAGALKOT	110	GSML 1-MAHALINGAPUR	MAHALINGAPUR_220	7:48	8:27	0:39	LINE FAULT
352	10-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
353	10-Sep-20	BAGALKOT	110	HUBLI- MUNDAGOD	MUNDAGOD_110	5:51	5:56	0:05	HAND TRIPPED
354	10-Sep-20	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	5:40	14:42	9:02	LINE FAULT
355	10-Sep-20	BAGALKOT	110	ITNAL-SULTANPUR	SULTANPUR_110	9:01	9:42	0:41	LOAD CHANGE OVER
356	10-Sep-20	BAGALKOT	110	JOG1(SIDDAPUR) - SIRSI	SIRSI_110	10:36	14:48	4:12	LINE CLEAR AVAILED
357	10-Sep-20	BAGALKOT	110	JOG2- SIRSI	SIRSI_110	10:36	15:27	4:51	LINE CLEAR AVAILED
358	10-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AVAILED
359	10-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
360	10-Sep-20	BAGALKOT	110	KUMATA-SIRSI 1	SIRSI_110	10:42	15:30	4:48	NFBC ISSUED
361	10-Sep-20	BAGALKOT	110	LAXMESHVAR-SHIRAHATTI	SHIRAHATTI_110	3:31	6:13	2:42	LINE FAULT
362	10-Sep-20	BAGALKOT	110	LAXMESHVAR-SHIRAHATTI	SHIRAHATTI_110	20:25	20:40	0:15	LINE FAULT
363	10-Sep-20	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	7:47	8:18	0:31	LINE FAULT
364	10-Sep-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	7:47	8:27	0:40	LINE FAULT
365	10-Sep-20	BAGALKOT	110	MAHALINGAPUR-TERADAL	TERADAL_110	7:47	8:29	0:42	LINE FAULT
366	10-Sep-20	BAGALKOT	110	MALINGAPUR-RABAKAVI	RABAKAVI_110	7:47	8:22	0:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
367	10-Sep-20	BAGALKOT	110	NAVALAGI-JAMAKHANDI	JAMAKHANDI_110	8:18	8:24	0:06	LINE FAULT
368	10-Sep-20	BAGALKOT	110	SPV SOLAR- MUKARTIHAL	MUKARTIHAL_110	11:27	12:54	1:27	LINE FAULT
369	10-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVOIDED
370	10-Sep-20	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220, ANAND NAGAR_110, AKSHAY COLONY_110	5:40	6:14	0:34	TRANSFORMER FAULT
371	10-Sep-20	BAGALKOT	220	220/110KV,HV1,HV2 & LV1,LV2	MAHALINGAPUR_220	7:24	8:16	0:52	TRANSFORMER FAULT
372	10-Sep-20	BAGALKOT	220	220/110KV,HV3 & LV3	MAHALINGAPUR_220	7:24	8:28	1:04	TRANSFORMER FAULT
373	10-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
374	10-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
375	10-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:26	7:53	7:27	LOAD CURTAILMENT
376	10-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:49 (10.09.2020)			LOAD CURTAILMENT
377	10-Sep-20	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	23:20 (10.09.202)			LOAD CURTAILMENT
378	10-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
379	10-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
380	10-Sep-20	BAGALKOT	220	MAHALINGAPUR-NARENDRA 1	MAHALINGAPUR_220	7:24	7:48	0:24	LINE FAULT
381	10-Sep-20	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	7:24	7:58	0:34	LINE FAULT
382	10-Sep-20	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	21:51 (09.09.2020)	21:02 (10.09.2020)	23:11hrs	LINE CHARGED
383	10-Sep-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	10:17	12:52	2:35	LINE CLEAR AVOIDED
384	10-Sep-20	BAGALKOT	400	DHONI-GUDDADAHALLI	DHONI_400	20:40 (09.09.2020)	10:14 (10.09.2020)	13:34hrs	LINE CHARGED
385	10-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
386	10-Sep-20	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - BHP (EHT)	BHP (EHT)	12:33	12:51	00:17	MAIN SUPPLY FAILURE
387	10-Sep-20	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	12:33	12:51	00:17	MAIN SUPPLY FAILURE
388	10-Sep-20	BENGALURU	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	12:33	13:08	00:35	MAIN SUPPLY FAILURE
389	10-Sep-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	12:33	13:09	00:35	MAIN SUPPLY FAILURE
390	10-Sep-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:33	13:09	00:35	MAIN SUPPLY FAILURE
391	10-Sep-20	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	12:33	13:08	00:35	MAIN SUPPLY FAILURE
392	10-Sep-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:33	13:08	00:35	MAIN SUPPLY FAILURE
393	10-Sep-20	BENGALURU	66	HV1	KUMBALAGODU	13:24	13:33	00:09	TRANSFORMER FAULT
394	10-Sep-20	BENGALURU	66	HV1	HOSKOTE 66	12:02	12:28	00:25	LINE CLEAR AVOIDED
395	10-Sep-20	BENGALURU	66	HV1	BANGARPET	05:52	06:04	00:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
396	10-Sep-20	BENGALURU	66	HV1	DEVANAHALLI HARDWARE PARK 220	12:33	12:51	00:17	MAIN SUPPLY FAILURE
397	10-Sep-20	BENGALURU	66	HV1	SIDDALAGATTA	11:51	14:38	02:46	LINE CLEAR AVAILED
398	10-Sep-20	BENGALURU	66	HV2	R R NAGAR	13:05	13:10	00:05	LINE CLEAR AVAILED
399	10-Sep-20	BENGALURU	66	HV2	WEL CAST STEEL	13:08	13:42	00:33	LINE CLEAR AVAILED
400	10-Sep-20	BENGALURU	66	HV2	HOSKOTE 66	11:01	11:50	00:48	LINE CLEAR AVAILED
401	10-Sep-20	BENGALURU	66	HV2	SIDDALAGATTA	14:38	14:45	00:06	LINE CLEAR AVAILED
402	10-Sep-20	BENGALURU	66	HV2	BMTC	16:31(09/09/2020)	10:22(10/09/2020)	17:51HRS	TRANSFORMER CHARGED
403	10-Sep-20	BENGALURU	66	HV3	YARANDANAHALLI	16:38	16:49	00:11	LINE CLEAR AVAILED
404	10-Sep-20	BENGALURU	66	HV3	HOSKOTE 66	10:30	10:50	00:20	LINE CLEAR AVAILED
405	10-Sep-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	14:25	14:33	00:08	MAIN SUPPLY FAILURE
406	10-Sep-20	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	14:45	14:52	00:07	LOAD CHANGE OVER
407	10-Sep-20	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGENAHALLI	14:25	14:50	00:25	LINE CHARGED
408	10-Sep-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	12:39	13:00	00:21	LINE CLEAR AVAILED
409	10-Sep-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220, DEVANAHALLI HARDWARE PARK 220	12:33	12:39	00:06	MAIN SUPPLY FAILURE
410	10-Sep-20	BENGALURU	220	HV1	DEVANAHALLI HARDWARE PARK 220	12:33	12:51	00:17	MAIN SUPPLY FAILURE
411	10-Sep-20	BENGALURU	220	HV2	DEVANAHALLI HARDWARE PARK 220	12:33	12:51	00:17	MAIN SUPPLY FAILURE
412	10-Sep-20	BENGALURU	220	HV3	SRS PEENYA 220	14:25(10/09/2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
413	10-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
414	10-Sep-20	GULBARGA	66	HV1	GUDEKOTE_66	12:11	12:26	00:15	LINE CLEAR AVAILED
415	10-Sep-20	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66 ,UPNAYAKANAHALLI_66	06:35	06:41	00:06	LINE FAULT
416	10-Sep-20	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPU R_66,MAGALA_66,SOVENHALLI_66,TUNGABHADRA IPP	05:59	06:05	00:06	LINE FAULT
417	10-Sep-20	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINA_HADAGALLI_66	04:25	04:33	00:08	LINE FAULT
418	10-Sep-20	GULBARGA	66	KOTTUR-KUDLIGI	UJJAINI_66	18:50	19:20	00:30	LINE FAULT
419	10-Sep-20	GULBARGA	110	GABUR-BPSOLAR	GABUR_110	22:02	22:04	00:02	LINE FAULT
420	10-Sep-20	GULBARGA	110	HATTI-GAMESHAH_IPP	HATTI_110	05:46	06:01	00:15	LINE FAULT
421	10-Sep-20	GULBARGA	110	HIREGONNAGAR-HANUMNAL	HANUMANAL_110	23:45(10.09.2020)			MAIN SUPPLY FAILURE
422	10-Sep-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	00:55	01:05	00:10	LINE FAULT
423	10-Sep-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	05:57	06:05	00:08	LINE FAULT
424	10-Sep-20	GULBARGA	110	HV2	HATTI_110	04:05	04:15	00:10	TRANSFORMER FAULT
425	10-Sep-20	GULBARGA	110	HV2	KAMPLI_GLB_110	16:20	19:20	01:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
426	10-Sep-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110, KADAGANCHI_110	04:55	05:06	00:11	LINE FAULT
427	10-Sep-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	05:15	06:01	00:46	LINE FAULT
428	10-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
429	10-Sep-20	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	09:30	09:40	00:10	MAIN SUPPLY FAILURE
430	10-Sep-20	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	19:45(9.9.2020)	12:48(10.9.9.2020)	19:25 HRS	LINE CHARGED
431	10-Sep-20	GULBARGA	110	SHAHPUR-RAICHUR2	RAICHUR_220	20:24(9.9.2020)	11:12(10.8.2020)	14:48HRS	LINE CHARGED
432	10-Sep-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	05:54	08:05	02:11	NFBC ISSUED
433	10-Sep-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	08:19	08:51	00:32	LINE CHARGED
434	10-Sep-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	13:40	13:50	00:10	LINE FAULT
435	10-Sep-20	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	00:26	00:39	00:13	LINE FAULT
436	10-Sep-20	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	20:41	20:57	00:16	LINE FAULT
437	10-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	03:01	03:09	00:08	LINE FAULT
438	10-Sep-20	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOOR_220	01:47	02:22	00:35	LINE FAULT
439	10-Sep-20	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	23:45(10.09.2020)			MAIN SUPPLY FAILURE
440	10-Sep-20	GULBARGA	220	ALIPUR-GOOTY(RAGALPADU)	GOOTY_220	00:50	01:21	00:31	LINE FAULT
441	10-Sep-20	GULBARGA	220	ALIPUR-GOOTY(RAGALPADU)	GOOTY_220	11:18	14:26	03:08	LINE CHARGED
442	10-Sep-20	GULBARGA	220	HV2	ITTAGGI_220	18:50	18:58	00:08	TRANSFORMER FAULT
443	10-Sep-20	GULBARGA	220	LINGAPUR-JINDAL1	LINGAPUR_220	09:18	13:00	03:42	LINE CLEAR AVAILED
444	10-Sep-20	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	1:40(10.9.2020)			LINE OPEN: LINE CLEAR AVAILED
445	10-Sep-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_220	1:06(10.9.2020)			LINE OPEN: LINE CLEAR AVAILED
446	10-Sep-20	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	20:40(9.9.2020)	11:51(10.9.2020)	15:11 HRS	LINE CHARGED
447	10-Sep-20	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	10:49	11:27	00:38	LINE FAULT
448	10-Sep-20	HASSAN	66	HV1	KUDLIGERE_66	10:10	12:10	02:00	LINE CLEAR AVAILED
449	10-Sep-20	HASSAN	66	HV1	KUDLIGERE_66	13:10	14:10	01:00	LINE CLEAR AVAILED
450	10-Sep-20	HASSAN	66	HV1	KUDLIGERE_66	15:10	15:15	00:05	HAND TRIPPED
451	10-Sep-20	HASSAN	66	HV1	SINGAPURA_66	11:44	12:19	00:35	LINE CLEAR AVAILED
452	10-Sep-20	HASSAN	66	HV2	MALLAPURA_66	12:33	13:22	00:49	LINE CLEAR AVAILED
453	10-Sep-20	HASSAN	66	LV1	MRSMSG_220	16:17	17:04	00:47	TRANSFORMER FAULT
454	10-Sep-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:34	17:13	00:39	HAND TRIPPED
455	10-Sep-20	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	16:34	17:13	00:39	HAND TRIPPED
456	10-Sep-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:34	17:13	00:39	HAND TRIPPED
457	10-Sep-20	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	16:34	17:13	00:39	HAND TRIPPED
458	10-Sep-20	HASSAN	66	TAVAREC-MRS SMG	TAVARECHANAHALLI_66	16:40	17:11	00:31	MAIN SUPPLY FAILURE
459	10-Sep-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	12:43	12:50	00:07	LINE FAULT
460	10-Sep-20	HASSAN	110	HV1	KALLUSADARAHALLY_110	12:28	13:02	00:34	LINE CLEAR AVAILED
461	10-Sep-20	HASSAN	110	HV1	PUTTUR_110	10:08	15:56	05:48	LINE CLEAR AVAILED
462	10-Sep-20	HASSAN	110	HV2	PUTTUR_110	10:08	15:56	05:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
463	10-Sep-20	HASSAN	110	JOG-NK2	mghejog_gen	10:43	15:28	04:45	NFBC ISSUED
464	10-Sep-20	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLY_110	10:50	10:55	00:05	LINE CLEAR AVAILED
465	10-Sep-20	HASSAN	110	LV3	MRSMSG_220	16:17	17:00	00:43	TRANSFORMER FAULT
466	10-Sep-20	HASSAN	220	CRPATNA2-HSN400	CRPATNA_220	15:09 (10.09.2020)			LINE OPEN:LINE FAULT
467	10-Sep-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	04:31	14:18	09:47	LINE FAULT
468	10-Sep-20	HASSAN	220	GOPALAPR-HSN400	GOPALAPURA_220	19:22	22:27	03:05	LINE CLEAR AVAILED
469	10-Sep-20	HASSAN	220	HASSAN40-C R PATNA	SHANTHIGRAMMA_400	15:09 (10.09.2020)			LINE OPEN:LINE FAULT
470	10-Sep-20	HASSAN	220	HASSAN40-GOPALPURA	SHANTHIGRAMMA_400	19:19	22:27	03:08	NFBC ISSUED
471	10-Sep-20	HASSAN	220	HV3	MRSMSG_220	16:17	16:50	00:33	TRANSFORMER FAULT
472	10-Sep-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	12:42	13:27	00:45	LINE FAULT
473	10-Sep-20	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:05	15:46	04:41	NFBC ISSUED
474	10-Sep-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:38	15:23	04:45	LINE CLEAR AVAILED
475	10-Sep-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	04:31	14:18	09:47	LINE FAULT
476	10-Sep-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:42	13:27	00:45	LINE FAULT
477	10-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47 (8.09.2020)			LINE OPEN: LINE CLEAR AVAILED
478	10-Sep-20	MYSORE	66	DATTAGALLI-HOOTAGALLI	DATTAGALLY_66	10:31	16:45	6:13	NFBC ISSUED
479	10-Sep-20	MYSORE	66	DATTAGALLI-RK NAGARA	DATTAGALLY_66	10:31	16:45	6:13	NFBC ISSUED
480	10-Sep-20	MYSORE	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	12:45	13:05	0:20	HAND TRIPPED
481	10-Sep-20	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66	10:31	16:37	6:06	LINE CLEAR AVAILED
482	10-Sep-20	MYSORE	66	HOOTAGALLI-MCF	BELAGOLA_66	14:24	17:43	3:19	LINE CLEAR AVAILED
483	10-Sep-20	MYSORE	66	HV1	AKKIHEBBAL_66	16:55	17:21	0:26	LINE CLEAR AVAILED
484	10-Sep-20	MYSORE	66	HV1	MALAVALLI_66	10:12	13:32	3:19	LINE CLEAR AVAILED
485	10-Sep-20	MYSORE	66	HV2	AKKIHEBBAL_66	15:05	18:43	3:37	LINE CLEAR AVAILED
486	10-Sep-20	MYSORE	66	HV2	GVGUDI_66	15:44	16:20	0:35	LINE CLEAR AVAILED
487	10-Sep-20	MYSORE	66	HV2	MALAVALLI_66	13:35	15:56	2:20	LINE CLEAR AVAILED
488	10-Sep-20	MYSORE	66	KHB STATION-HOOTAGALLI	KHBCOLONY_66	10:08	16:19	6:10	NFBC ISSUED
489	10-Sep-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	18:36	18:41	0:05	LINE FAULT
490	10-Sep-20	MYSORE	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	19:30	20:00	0:29	LINE CLEAR AVAILED
491	10-Sep-20	MYSORE	220	CR NAGARA-BEGUR 2	NO STATIONS EFFECTED	14:56	17:26	2:30	LINE CLEAR AVAILED
492	10-Sep-20	MYSORE	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	12:33	14:39	2:05	LINE CLEAR AVAILED
493	10-Sep-20	MYSORE	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	9:40	13:23	3:43	LINE CLEAR AVAILED
494	10-Sep-20	TUMKUR	66	HANAGAL-AVADASOLAR IPP_66	AVADASOLAR_IPP_66	11:08:33	11:10:11	0:01	MAIN SUPPLY FAILURE
495	10-Sep-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	12:08:35	12:14:06	0:05	LINE FAULT
496	10-Sep-20	TUMKUR	66	BRAHMASANDRA-SIRA(KALLAMBELLA)	BRAHMASANDRA_66	13:40:01	15:52:12	2:12	LINE CLEAR AVAILED
497	10-Sep-20	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	11:52:15	13:31:48	1:39	LINE FAULT
498	10-Sep-20	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	DYAVARANAHALLI_66	08:56:34	09:13:49	0:17	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
499	10-Sep-20	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	DYAVARANAHALLI_66	14:30:09	15:43:36	1:13	HAND TRIPPED
500	10-Sep-20	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	10:55:22	11:08:33	0:13	MAIN SUPPLY FAILURE
501	10-Sep-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	11:08:33	11:12:01	0:03	MAIN SUPPLY FAILURE
502	10-Sep-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	09:57:58	15:48:56	5:50	MAIN SUPPLY FAILURE
503	10-Sep-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	02:49:43	02:53:29	0:03	LINE FAULT
504	10-Sep-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	08:26:01	08:36:38	0:10	LINE FAULT
505	10-Sep-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	07:32:45	07:44:27	0:11	LINE FAULT
506	10-Sep-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:37:36	11:42:21	0:04	LINE FAULT
507	10-Sep-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:49:46	13:20:50	1:31	LINE FAULT
508	10-Sep-20	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	10:47:46	12:14:10	1:26	LINE FAULT
509	10-Sep-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	11:55	12:06:47	0:11	LINE FAULT
510	10-Sep-20	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	IPP_SOLAR_66	11:39:38	11:44:03	0:04	HAND TRIPPED
511	10-Sep-20	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WELSPUN SOLAR_IPP_66	19:21:09	19:26:30	0:05	HAND TRIPPED
512	10-Sep-20	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WELSPUN SOLAR_IPP_66	19:21:09	19:26:24	0:05	HAND TRIPPED
513	10-Sep-20	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	10:10:49	10:57:47	0:46	HAND TRIPPED
514	10-Sep-20	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	RANGENAHALLI_66	15:47:02	15:48:16	0:01	LINE FAULT
515	10-Sep-20	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	08:11:22	08:30:53	0:19	MAIN SUPPLY FAILURE
516	10-Sep-20	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:15:08	13:25:06	1:09	HAND TRIPPED
517	10-Sep-20	TUMKUR	66	TR-1	HALUVAGALU_66	07:47:53	07:53:37	0:05	HAND TRIPPED
518	10-Sep-20	TUMKUR	66	TR-1	VENKATAPURA_66	09:17:31	09:28:18	0:10	TRANSFORMER FAULT
519	10-Sep-20	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	14:45:12	16:43:22	1:58	LINE CLEAR AVAILED
520	10-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
521	10-Sep-20	TUMKUR	66	TR-2	CHIKKABANAGERE_66	12:15:11	13:25:12	1:10	HAND TRIPPED
522	10-Sep-20	TUMKUR	66	TR-2	HARIYABBE_66	09:57:58	10:11:31	0:13	TRANSFORMER FAULT
523	10-Sep-20	TUMKUR	66	TR-2	HOSADURGA_66	11:06:05	11:42:04	0:35	LINE CLEAR AVAILED
524	10-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
525	10-Sep-20	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	14:45:12	16:43:07	1:57	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
526	11-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
527	11-Sep-20	BAGALKOT	110	110/11KV,HV1	ITNAL_110	6:30 (09.09.2020)	18:04 (11.09.2020)	59:34hrs	TRANSFORMER CHARGED
528	11-Sep-20	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	18:50	19:01	0:11	TRANSFORMER FAULT
529	11-Sep-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,DEVAR AGENNUR_33,LINGADALLI LIS_33	12:41	16:46	4:05	LINE CLEAR AVAILED
530	11-Sep-20	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVILED
531	11-Sep-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	22:54 (10.09.2020)	14:27 (13.09.2020)	63:33hrs	LINE CHARGED
532	11-Sep-20	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)	10:13 (13.09.2020)	309:08HRS	LINE CHARGED
533	11-Sep-20	BAGALKOT	110	ANKALAGI-HIDAKAL/ISLAMPUR	HIDAKAL/ISLAMPUR_110	2:00	2:22	0:22	LINE FAULT
534	11-Sep-20	BAGALKOT	110	ANKALAGI-HIDAKAL/ISLAMPUR	HIDAKAL/ISLAMPUR_110	6:05	7:10	1:05	LINE FAULT
535	11-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
536	11-Sep-20	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	22:00	22:02	0:02	HAND TRIPPED
537	11-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
538	11-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
539	11-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
540	11-Sep-20	BAGALKOT	110	HIRA SUGAR1-SANKESHWAR	SANKESHWAR_110	11:50	13:05	1:15	LINE CLEAR AVAILED
541	11-Sep-20	BAGALKOT	110	HIRA SUGAR2-SANKESHWAR	SANKESHWAR_110	9:36	12:40	3:04	LINE CLEAR AVAILED
542	11-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AVAILED
543	11-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
544	11-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
545	11-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
546	11-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AVAILED
547	11-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:49 (10.09.2020)	7:42 11.09.2020	8:43hrs	LINE CHARGED
548	11-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:47 (11.09.2020)			LINE OPEN: LINE CLEAR AVAILED
549	11-Sep-20	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	23:20 (10.09.202)	10:35 (12.09.2020)	35:15hrs	LINE CHARGED
550	11-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
551	11-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
552	11-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
553	11-Sep-20	BENGALURU	66	BOMMASANDRA - ELECTRONIC CITY	BOMMASANDRA	15:20	15:31	00:11	LOAD CHANGE OVER
554	11-Sep-20	BENGALURU	66	BOMMASANDRA - YARANDANAHALLI 220	BOMMASANDRA	14:10	14:17	00:07	LOAD CHANGE OVER
555	11-Sep-20	BENGALURU	66	HV1	ATTUR YELAHANAK	15:05	15:06	00:01	LINE CLEAR AVAILED
556	11-Sep-20	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	10:44	10:54	00:10	LINE CLEAR AVAILED
557	11-Sep-20	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	14:27	14:38	00:11	LINE CLEAR AVAILED
558	11-Sep-20	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:21	10:31	00:10	LINE CLEAR AVAILED
559	11-Sep-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:35	10:55	00:20	LINE FAULT
560	11-Sep-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:33	22:43	00:10	LINE FAULT
561	11-Sep-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:45	22:51	00:06	LINE FAULT
562	11-Sep-20	BENGALURU	220	HV3	SRS PEENYA 220	14:25(10/09/2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
563	11-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
564	11-Sep-20	GULBARGA	66	ITTAGGI-HANASI	HANASI_66	15:20	15:30	00:10	LINE FAULT
565	11-Sep-20	GULBARGA	66	ITTAGGI-HANASI	HANASI_66	23:50			LINE OPEN:LINE FAULT
566	11-Sep-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_110, KAMALAPUR_110, METRI_110, RBNS FACTORY	05:21	05:30	00:09	LINE FAULT
567	11-Sep-20	GULBARGA	110	CHITGUPPA-ACMESOLAR IPP	CHITAGUPPA_110	07:25	07:50	00:25	LINE FAULT
568	11-Sep-20	GULBARGA	110	GULBARGASOUTH-GULBARGA UNIVERSITY	GULUNI_110	11:45	12:50	01:05	LINE CHARGED
569	11-Sep-20	GULBARGA	110	HIREGONNAGAR-HANUMNAL	HANUMANAL_110	23:45(10.09.2020)	0:40(11.9.2020)	0:55 HRS	LINE CHARGED
570	11-Sep-20	GULBARGA	110	HV1	MANVI_110	09:05	09:18	00:13	TRANSFORMER FAULT
571	11-Sep-20	GULBARGA	110	HV1	KAMPLI_110_GLB	12:10	13:50	01:40	TRANSFORMER FAULT
572	11-Sep-20	GULBARGA	110	HV2	BELLARYSOUTH_110	10:54	11:32	00:38	LINE CLEAR AVAILED
573	11-Sep-20	GULBARGA	110	HV2	KAMPLI_110_GLB	13:59	15:05	01:06	TRANSFORMER FAULT
574	11-Sep-20	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110, HIREGONNAGAR_110,HANU MANAL_110	09:00	09:30	00:30	LINE FAULT
575	11-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
576	11-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	05:35	05:40	00:05	LINE FAULT
577	11-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	03:10	03:23	00:13	LINE FAULT
578	11-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:06	23:13	00:07	LINE FAULT
579	11-Sep-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	02:12	02:19	00:07	LINE FAULT
580	11-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	09:40	09:50	00:10	LINE FAULT
581	11-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	22:50	23:00	00:10	LINE FAULT
582	11-Sep-20	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	23:45(10.09.2020)	0:45(11.9.2020)	1:00 HRS	LINE CHARGED
583	11-Sep-20	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	1:40(10.9.2020)	13:30(11.9.2020)	35:50HRS	LINE CHARGED
584	11-Sep-20	GULBARGA	220	SEDAM- RTPS1	SEDAM_220	06:04	08:04	02:00	LINE FAULT
585	11-Sep-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	20:32	20:41	00:09	LINE FAULT
586	11-Sep-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:20	23:35	00:15	LINE FAULT
587	11-Sep-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_220	1:06(10.9.2020)			LINE OPEN: LINE CLEAR AVAILED
588	11-Sep-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	00:46	00:53	00:07	LINE FAULT
589	11-Sep-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN:LINE FAULT
590	11-Sep-20	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLY_66	00:45	00:55	00:10	MAIN SUPPLY FAILURE
591	11-Sep-20	HASSAN	66	HV1	BAGUR_66	10:03	14:33	04:30	LINE CLEAR AVAILED
592	11-Sep-20	HASSAN	66	HV1	BYACHANAHALLY_66	09:00	09:10	00:10	TRANSFORMER FAULT
593	11-Sep-20	HASSAN	66	HV2	BAGUR_66	10:03	14:30	04:27	LINE CLEAR AVAILED
594	11-Sep-20	HASSAN	66	HV2	SHANTHIGRAMA_66	11:16	11:40	00:24	LINE CLEAR AVAILED
595	11-Sep-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	15:25	16:42	01:17	HAND TRIPPED
596	11-Sep-20	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	15:25	16:43	01:18	HAND TRIPPED
597	11-Sep-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:25	16:41	01:16	HAND TRIPPED
598	11-Sep-20	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	15:25	17:02	01:37	HAND TRIPPED
599	11-Sep-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	11:16	11:40	00:24	LINE CLEAR AVAILED
600	11-Sep-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANHALLY_66	15:25	17:05	01:40	MAIN SUPPLY FAILURE
601	11-Sep-20	HASSAN	66	TAVAREC-IHONNALLI	TAVARECHATANHALLY_66	14:25	14:40	00:15	LINE FAULT
602	11-Sep-20	HASSAN	110	HV1	GANDASI_110	10:10	19:30	09:20	LINE CLEAR AVAILED
603	11-Sep-20	HASSAN	110	HV3	PUyTUR_110	14:38	14:47	00:09	TRANSFORMER FAULT
604	11-Sep-20	HASSAN	110	JOG110-MGHE	JOG_110	16:34	16:50	00:16	LINE FAULT
605	11-Sep-20	HASSAN	110	JOG-JLT4	mghejog_gen	16:30 (11.09.2020)			LINE OPEN:LINE FAULT
606	11-Sep-20	HASSAN	110	LV1	KEMAR_220	10:27	10:31	00:04	HAND TRIPPED
607	11-Sep-20	HASSAN	110	LV3	MRSMSG_220	15:24	16:35	01:11	TRANSFORMER FAULT
608	11-Sep-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_110	10:19	18:07	07:48	HAND TRIPPED
609	11-Sep-20	HASSAN	220	CRPATNA2-HSN400	CRPATNA_220	15:09 (10.09.2020)	13:40 (11.09.2020)	22:31hrs	LINE CHARGED
610	11-Sep-20	HASSAN	220	GOPALAPR-HSN400	GOPALAPURA_220	09:13	13:40	04:27	LINE CLEAR AVAILED
611	11-Sep-20	HASSAN	220	HASSAN40-C R PATNA	HASSAN_400	15:09 (10.09.2020)	13:40 (11.09.2020)	22:31hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
612	11-Sep-20	HASSAN	220	HASSAN40-GOPALPURA	HASSAN_400	09:13	13:40	04:27	NFBC ISSUED
613	11-Sep-20	HASSAN	220	HV1	KEMAR_220	10:27	10:31	00:04	HAND TRIPPED
614	11-Sep-20	HASSAN	220	HV3	MRSMSG_220	15:24	16:35	01:11	TRANSFORMER FAULT
615	11-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47 (8.09.2020)			LINE OPEN: LINE CLEAR AVAILED
616	11-Sep-20	MYSORE	66	HOOTAGALLY-DATTAGALLI	NO STATIONS EFFECTED	10:54	12:05	1:11	LINE CLEAR AVAILED
617	11-Sep-20	MYSORE	66	HV1	DATTAGALLY_66	14:34	14:38	0:04	HAND TRIPPED
618	11-Sep-20	MYSORE	66	HV1	KUNTHUR_66	11:18	11:50	0:31	LINE CLEAR AVAILED
619	11-Sep-20	MYSORE	66	HV1	SATHEGALA_66	15:10	15:30	0:20	HAND TRIPPED
620	11-Sep-20	MYSORE	66	HV1	YELANDUR_66	12:39	13:10	0:30	LINE CLEAR AVAILED
621	11-Sep-20	MYSORE	66	HV2	BGPURA_66	10:30	11:02	0:32	LINE CLEAR AVAILED
622	11-Sep-20	MYSORE	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	11:04	11:14	0:09	LINE CLEAR AVAILED
623	11-Sep-20	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66 SOMANAHALLI_66	22:33			LINE OPEN:LINE FAULT
624	11-Sep-20	MYSORE	66	PARINAMIPURA-TALAKADU	THALAKADU_66 CHANDALLI_66	18:12	18:17	0:04	LINE FAULT
625	11-Sep-20	MYSORE	66	SATHEGALA-BPCL2	NO STATIONS EFFECTED	15:10	17:20	2:10	HAND TRIPPED
626	11-Sep-20	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	15:20	17:20	2:00	LINE CLEAR AVAILED
627	11-Sep-20	MYSORE	66	SATHEGALA-KOLLEGALA	NO STATIONS EFFECTED	15:00	15:05	0:05	HAND TRIPPED
628	11-Sep-20	MYSORE	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	15:50	17:20	1:30	LINE CLEAR AVAILED
629	11-Sep-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:18	6:25	0:07	LINE FAULT
630	11-Sep-20	TUMKUR	66	TR-1	KATTIGE_66	18:18	18:35	0:16	LINE CLEAR AVAILED
631	11-Sep-20	TUMKUR	66	TR-1	PAVAGADA_220	0:36	1:03	0:26	TRANSFORMER FAULT
632	11-Sep-20	TUMKUR	66	TR-1	PAVAGADA_220	6:24	6:25	0:01	TRANSFORMER FAULT
633	11-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
634	11-Sep-20	TUMKUR	66	TR-2	AVAREGERE_66	16:49	18:11	1:22	LINE CLEAR AVAILED
635	11-Sep-20	TUMKUR	66	TR-2	BELLAVI_66	11:04	11:14	0:10	LINE CLEAR AVAILED
636	11-Sep-20	TUMKUR	66	TR-2	HALUVAGALU_66	5:15	5:22	0:07	TRANSFORMER FAULT
637	11-Sep-20	TUMKUR	66	TR-2	HARIYABBE_66	19:06	19:16	0:09	MAIN SUPPLY FAILURE
638	11-Sep-20	TUMKUR	66	TR-3	HARIYABBE_66	19:06	19:16	0:09	MAIN SUPPLY FAILURE
639	11-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
640	11-Sep-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	10:35	15:05	4:30	LINE CLEAR AVAILED
641	12-Sep-20	BAGALKOT	66	66/33KV, HV3	NO STATION EFFECTED HARIHAR-HOSPET_66	23:54 (12.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
642	12-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
643	12-Sep-20	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	2:06	2:18	0:12	TRANSFORMER FAULT
644	12-Sep-20	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	17:45	17:55	0:10	TRANSFORMER FAULT
645	12-Sep-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,N EVARGI_33,DHULKED_33	11:30	11:40	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
646	12-Sep-20	BAGALKOT	110	220/110KV, LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN :LINE CLEAR AILED
647	12-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AILED
648	12-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AILED
649	12-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AILED
650	12-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AILED
651	12-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AILED
652	12-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
653	12-Sep-20	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	1:59	2:01	0:02	LINE FAULT
654	12-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AILED
655	12-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
656	12-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AILED
657	12-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	22:34 (12.09.2020)			LINE OPEN: LINE CLEAR AILED
658	12-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:47 (11.09.2020)			LINE OPEN: LINE CLEAR AILED
659	12-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AILED
660	12-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AILED
661	12-Sep-20	BENGALURU	66	ATTUR YELAHANKA - PLATINUM CITY	PLATINUM CITY	23:45	23:57	00:12	LINE FAULT
662	12-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
663	12-Sep-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	12:14	13:06	00:52	LOAD CHANGE OVER
664	12-Sep-20	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	08:40	08:59	00:19	LOAD CHANGE OVER
665	12-Sep-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	00:26	00:54	00:28	LINE FAULT
666	12-Sep-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	00:54	01:17	00:23	LINE FAULT
667	12-Sep-20	BENGALURU	66	HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	09:56	10:03	00:07	LINE CLEAR AILED
668	12-Sep-20	BENGALURU	66	HV2	SARJAPURA 220	10:17	10:20	00:02	LINE CLEAR AILED
669	12-Sep-20	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	15:19	16:30	01:11	LINE CLEAR AILED
670	12-Sep-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:19	10:29	00:09	LINE CLEAR AILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
671	12-Sep-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:19	10:33	00:14	LINE CLEAR AVAILED
672	12-Sep-20	BENGALURU	220	HV3	SRS PEENYA 220	14:25(10/09/2020)	16:48(12/09/2020)	50:23HRS	TRANSFORMER CHARGED
673	12-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
674	12-Sep-20	GULBARGA	66	HOSAHALLI-SML_WIND	HOSAHALLI_66	23:29	23:31	00:02	LINE FAULT
675	12-Sep-20	GULBARGA	66	ITTAGGI-HANASI	HANASI_66	23:50(11.09.2020)	00:10(12.09.2020)	0:20 HRTS	LINE CHARGED
676	12-Sep-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:02	19:10	00:08	LINE FAULT
677	12-Sep-20	GULBARGA	110	GUDEKOTE-KUDLIGI	GUDEKOTE_66	13:20	23:05	09:45	MAIN SUPPLY FAILURE
678	12-Sep-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	22:22	22:45	00:23	LINE FAULT
679	12-Sep-20	GULBARGA	110	HV2	ITTAGI_220	11:10	11:17	00:07	TRANSFORMER FAULT
680	12-Sep-20	GULBARGA	110	HV2	ITTAGI_220	15:45	16:35	00:50	LINE CLEAR AVAILED
681	12-Sep-20	GULBARGA	110	HV2	ITTAGI_220	15:45	17:40	01:55	LINE CLEAR AVAILED
682	12-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
683	12-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNSAGI_110	23:47(12.09.2020)			LINE OPEN:LINE FAULT
684	12-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNSAGI_110	02:49	02:52	00:03	LINE FAULT
685	12-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNSAGI_110	05:01	05:08	00:07	LINE FAULT
686	12-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNSAGI_110	05:52	05:57	00:05	LINE FAULT
687	12-Sep-20	GULBARGA	110	SHAHAPUR-SHAHABAD	SHAHABAD_220	22:07(12.09.2020)			LINE OPEN:LINE FAULT
688	12-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	00:52	00:59	00:07	LINE FAULT
689	12-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	01:53	02:03	00:10	LINE FAULT
690	12-Sep-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:05	22:18	00:13	LINE FAULT
691	12-Sep-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	16:10	16:25	00:15	LINE FAULT
692	12-Sep-20	GULBARGA	220	ALIPUR-RAGHULAPADU	NEELGUNDA_220,GUTTI_220	20:28	20:51	00:23	LINE FAULT
693	12-Sep-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:08(12.09.2020)			LINE OPEN:LINE FAULT
694	12-Sep-20	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	01:11	02:10	00:59	LINE FAULT
695	12-Sep-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	03:59	04:34	00:35	LINE FAULT
696	12-Sep-20	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	23:48(12.09.2020)			LINE OPEN:LINE FAULT
697	12-Sep-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_220	1:06(10.9.2020)			LINE OPEN: LINE CLEAR AVAILED
698	12-Sep-20	GULBARGA	400	BTPS-RTPS	BTPS_400	00:02	17:31	17:29	LINE FAULT
699	12-Sep-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN:LINE FAULT
700	12-Sep-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_66	16:18	16:28	00:10	LINE FAULT
701	12-Sep-20	HASSAN	66	HV1	BYACHANAHALLY_66	03:20	03:25	00:05	TRANSFORMER FAULT
702	12-Sep-20	HASSAN	66	HV1	BYACHANAHALLY_66	07:00	07:10	00:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
703	12-Sep-20	HASSAN	66	HV1	HOLENARASIPURA_66	16:18	16:30	00:12	MAIN SUPPLY FAILURE
704	12-Sep-20	HASSAN	66	HV2	BYACHANAHALLY_66	08:00	08:10	00:10	TRANSFORMER FAULT
705	12-Sep-20	HASSAN	66	HV2	HOLENARASIPURA_66	16:18	16:30	00:12	MAIN SUPPLY FAILURE
706	12-Sep-20	HASSAN	66	HV2	SALGAME_66	10:05	10:25	00:20	TRANSFORMER FAULT
707	12-Sep-20	HASSAN	66	HV3	BYACHANAHALLY_66	14:10	16:20	02:10	LINE CLEAR AVAILED
708	12-Sep-20	HASSAN	110	JOG-JLT4	mghejog_gen	16:30 (11.09.2020)	13:55 (12.09.2020)	21:25hrs	LINE CHARGED
709	12-Sep-20	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	10:00	14:15	04:15	LINE CLEAR AVAILED
710	12-Sep-20	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	09:04	14:16	05:12	LINE CLEAR AVAILED
711	12-Sep-20	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	21:38	22:18	00:40	HAND TRIPPED
712	12-Sep-20	HASSAN	220	MRSSH-M-SHARAVATHY3	MRSMG_220	13:58	15:57	01:59	LINE FAULT
713	12-Sep-20	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	13:58	15:57	01:59	LINE FAULT
714	12-Sep-20	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
715	12-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47 (8.09.2020)	7:06 (12.09.2020)	79:19hrs	LINE CHARGED
716	12-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:47 (12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
717	12-Sep-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
718	12-Sep-20	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	6:21	6:28	0:07	LINE FAULT
719	12-Sep-20	MYSORE	66	HV1	BGPURA_66	10:45	11:11	0:25	LINE CLEAR AVAILED
720	12-Sep-20	MYSORE	66	HV1	PANDAVAPURA_66	10:03	17:16	7:12	LINE CLEAR AVAILED
721	12-Sep-20	MYSORE	66	HV2	PANDAVAPURA_66	10:03	17:16	7:12	LINE CLEAR AVAILED
722	12-Sep-20	MYSORE	66	HV2	TERAKANAMBE_66	10:00	13:10	3:09	LINE CLEAR AVAILED
723	12-Sep-20	MYSORE	66	KUSHALNAGARA 220-MYSORE - 2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	10:20	17:17	6:56	LINE CLEAR AVAILED
724	12-Sep-20	MYSORE	66	MADDUR-KIADB MANDYA	NO STATIONS EFFECTED	22:33 (11/09/2020)	12:45 (12/09/2020)	14:12 HRS	LINE CHARGED
725	12-Sep-20	MYSORE	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	6:07	6:13	0:06	LINE FAULT
726	12-Sep-20	MYSORE	66	TUBINKERE-G UKKADA	NO STATIONS EFFECTED	7:23	9:00	1:37	LINE CLEAR AVAILED
727	12-Sep-20	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	7:23	8:59	1:36	LINE CLEAR AVAILED
728	12-Sep-20	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	12:42	13:40	0:58	LINE CLEAR AVAILED
729	12-Sep-20	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	16:40	16:45	0:05	HAND TRIPPED
730	12-Sep-20	TUMKUR	66	ANTHRASANAHALI 220KV-MELEKOTE	DODDASARANGI_66,MELKOT E_66, BADDIHALI_66, HONNUDIKE_66, HIREHALI_66	10:16	14:22	4:05	LINE CLEAR AVAILED
731	12-Sep-20	TUMKUR	66	TR-1	KATTIGE_66	10:54	11:02	0:07	LINE CLEAR AVAILED
732	12-Sep-20	TUMKUR	66	TR-1	LINGDHALLI_66	11:02	11:10	0:07	TRANSFORMER FAULT
733	12-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
734	12-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
735	13-Sep-20	BAGALKOT	66	66/33KV, HV3	NO STATION EFFECTED HARIHAR-HOSPET_66	23:54 (12.09.2020)	14:21 (13.09.2020)	14:27	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
736	13-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
737	13-Sep-20	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	12:44	12:46	0:02	TRANSFORMER FAULT
738	13-Sep-20	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	13:48	14:54	1:06	LINE CLEAR AVOIDED
739	13-Sep-20	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	2:32	2:51	0:19	TRANSFORMER FAULT
740	13-Sep-20	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	16:58	17:06	0:08	TRANSFORMER FAULT
741	13-Sep-20	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	12:43	12:54	0:11	TRANSFORMER FAULT
742	13-Sep-20	BAGALKOT	110	110/33KV, HV3	AREMALLAPUR_110, CHALAGERI_33	12:44	12:46	0:02	TRANSFORMER FAULT
743	13-Sep-20	BAGALKOT	110	110/33KV,HV2	SANKESHWAR_110,HEBBAL_33,KANAGALA_33	11:44	13:53	2:09	LINE CLEAR AVOIDED
744	13-Sep-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_33KARADI_33,MYTRA SOLAR_33	2:07	2:13	0:06	TRANSFORMER FAULT
745	13-Sep-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_33KARADI_33,MYTRA SOLAR_33	18:47	18:57	0:10	TRANSFORMER FAULT
746	13-Sep-20	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVOIDED
747	13-Sep-20	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	21:53 (13.09.2020)			LOAD CURTAILMENT
748	13-Sep-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	21:38 (13.09.2020)			LOAD CURTAILMENT
749	13-Sep-20	BAGALKOT	110	ANNIGERI-GADAG	GADAG_110	14:45	15:01	0:16	LINE CLEAR AVOIDED
750	13-Sep-20	BAGALKOT	110	ATHANI220-HALIYAL LIS	HALIYAL LIS_110	9:10	17:38	8:28	LINE CLEAR AVOIDED
751	13-Sep-20	BAGALKOT	110	ATHANI220-KSSKN	KSSKN_110	7:39	7:54	0:15	LINE FAULT
752	13-Sep-20	BAGALKOT	110	ATHANI220-KSSKN	KSSKN_110	8:20	17:51	9:31	LINE CLEAR AVOIDED
753	13-Sep-20	BAGALKOT	110	BAGEWADI220-MAMADAPUR1	MAMADAPUR_110	6:21	6:33	0:12	HAND TRIPPED
754	13-Sep-20	BAGALKOT	110	BAGEWADI220-MAMADAPUR2, UKKALI & CHIMMALAGI LIS	BAGEWADI_220, MAMADAPUR_110, CHIMMALAGI LIS_110, & UKKALI_110	6:05	6:30	0:25	HAND TRIPPED
755	13-Sep-20	BAGALKOT	110	BALAJI SUGARS-MUDEDEBIHAL	MUDEDEBIHAL_110	6:35	6:45	0:10	LINE FAULT
756	13-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
757	13-Sep-20	BAGALKOT	110	DAMBAL-EILS(L1)/AKHILAGYA SOLAR	EILS(L1)/AKHILAGYA SOLAR_110	18:56	20:07	1:11	LINE FAULT
758	13-Sep-20	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	2:52	3:05	0:13	LINE FAULT
759	13-Sep-20	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	14:22	15:00	0:38	LINE FAULT
760	13-Sep-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
761	13-Sep-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
762	13-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
763	13-Sep-20	BAGALKOT	110	HUBLI-KADANAKOPPA	NO STATION EFFECTED KADANAKOPPA_110	9:59	15:19	5:20	LINE FAULT
764	13-Sep-20	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	10:13	15:34	5:21	HAND TRIPPED
765	13-Sep-20	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	7:45	8:15	0:30	LINE FAULT
766	13-Sep-20	BAGALKOT	110	JINDAL-HUNGUND	HUNGUND_110	6:21	6:41	0:20	LINE FAULT
767	13-Sep-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
768	13-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AVAILED
769	13-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
770	13-Sep-20	BAGALKOT	110	PG HUNSHYAL-NAGANUR(MUDALAGI)	NAGANUR_110	2:55	3:05	0:10	LOAD CURTAILMENT
771	13-Sep-20	BAGALKOT	110	PG HUNSHYAL-NAGANUR(MUDALAGI)	NAGANUR_110	14:25	15:10	0:45	LOAD CURTAILMENT
772	13-Sep-20	BAGALKOT	110	RANEBENNUR-GUTTAL&HONNATTI	HONNATTI_110GUTTAL_110	12:44	13:05	0:21	LOAD CURTAILMENT
773	13-Sep-20	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	6:51	7:00	0:09	LINE FAULT
774	13-Sep-20	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110,	12:44	12:53	0:09	LOAD CURTAILMENT
775	13-Sep-20	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI,HIREKERUR,HONNATTI& GUTTAL	TUMMINAKATTI_110,HIREKERUR_110,HONNATTI_110GUTTAL_110	12:44	12:46	0:02	HAND TRIPPED
776	13-Sep-20	BAGALKOT	110	SOUDATTI220-UDIKERI	UDIKERI_110	10:08	18:07	7:59	LINE CLEAR AVAILED
777	13-Sep-20	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	13:48 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
778	13-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
779	13-Sep-20	BAGALKOT	220	220/110KV, HV1	BAGEWADI_220, MAMADAPUR_110, CHIMMALAGI LIS_110, & UKKALI_110	6:05	6:30	0:25	TRANSFORMER FAULT
780	13-Sep-20	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED SOUDATTI_220	13:36	16:00	2:24	LINE CLEAR AVAILED
781	13-Sep-20	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED MK HYBLI_220	14:29	16:51	2:22	LINE CLEAR AVAILED
782	13-Sep-20	BAGALKOT	220	220/110KV,HV2	NO STATION AFFECTED MK HYBLI_220	9:40	14:24	4:44	LINE CLEAR AVAILED
783	13-Sep-20	BAGALKOT	220	AMBEWADI-NAGAJHARI	NO STATION EFFECTED AMBEWADI_220	22:57 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
784	13-Sep-20	BAGALKOT	220	AMBEWADI-NARENDRA	NO STATION EFFECTED AMBEWADI_220	22:57 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
785	13-Sep-20	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	23:07 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
786	13-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
787	13-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AVAILED
788	13-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	22:34 (12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
789	13-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:47 (11.09.2020)	8:18 (13.09.2020)	33:31hrs	LINE CHARGED
790	13-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:12 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
791	13-Sep-20	BAGALKOT	220	GADAG- BAGALKOT1	GADAG_220	23:07 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
792	13-Sep-20	BAGALKOT	220	HAVERI220-GUTTUR2	HAVERI_220	8:35	8:37	0:02	HAND TRIPPED
793	13-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
794	13-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
795	13-Sep-20	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	23:11 (13.09.2020)			LOAD CURTAILMENT
796	13-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
797	13-Sep-20	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	21:46	21:55	00:09	LINE FAULT
798	13-Sep-20	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	21:56	22:08	00:12	LINE FAULT
799	13-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:35	10:42	00:07	LINE FAULT
800	13-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:31	22:40	00:09	LINE FAULT
801	13-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:40	23:08	00:28	LINE FAULT
802	13-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:40(13/09/2020)			LINE OPEN:LINE FAULT
803	13-Sep-20	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	07:28	07:48	00:20	LINE FAULT
804	13-Sep-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:41	17:51	00:10	LINE FAULT
805	13-Sep-20	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	15:32	15:38	00:05	LOAD CHANGE OVER
806	13-Sep-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	13:13	15:33	02:20	LINE CLEAR AVAILED
807	13-Sep-20	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	14:01	14:07	00:06	TRANSFORMER FAULT
808	13-Sep-20	BENGALURU	66	HV1	YELAHANKA 220	10:00	10:10	00:09	TRANSFORMER FAULT
809	13-Sep-20	BENGALURU	66	HV1	MUDIYANUR	08:12	08:21	00:09	TRANSFORMER FAULT
810	13-Sep-20	BENGALURU	66	HV1	NARASAPURA	10:12	14:10	03:57	LINE CLEAR AVAILED
811	13-Sep-20	BENGALURU	66	HV1	KYALANUR	18:23	18:31	00:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
812	13-Sep-20	BENGALURU	66	HV2	APPAREL PARK	13:03	18:33	05:30	LINE CLEAR AVAILED
813	13-Sep-20	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	17:36	17:40	00:04	LOAD CHANGE OVER
814	13-Sep-20	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGENAHALLI	17:25	17:30	00:05	LOAD CHANGE OVER
815	13-Sep-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	18:12	18:25	00:13	LINE CLEAR AVAILED
816	13-Sep-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:12	18:25	00:13	LINE CLEAR AVAILED
817	13-Sep-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:12	18:25	00:13	LINE CLEAR AVAILED
818	13-Sep-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	18:12	18:26	00:14	LINE CLEAR AVAILED
819	13-Sep-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	18:12	18:34	00:22	LINE CLEAR AVAILED
820	13-Sep-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HONNIGANAHALLI	18:12	18:32	00:20	LINE FAULT
821	13-Sep-20	BENGALURU	220	HV2	T K HALLI 220	18:12	18:23	00:11	TRANSFORMER FAULT
822	13-Sep-20	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	23:20 (13-9-2020)			LINE OPEN:LINE FAULT
823	13-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
824	13-Sep-20	GULBARGA	66	HOSAHALLI-SML_WIND	HOSAHALLI_66	05:26	05:33	00:07	LINE FAULT
825	13-Sep-20	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR	07:25	07:30	00:05	LINE FAULT
826	13-Sep-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_110, KAMALAPUR_110, METRI_110, RBNS FACTORY	06:10	06:30	00:20	LINE FAULT
827	13-Sep-20	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MG SSK_IPP,BSSK_IPP	18:15	18:26	00:11	LINE FAULT
828	13-Sep-20	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MG SSK_IPP,BSSK_IPP	18:15	18:26	00:11	LINE FAULT
829	13-Sep-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	05:58	06:02	00:04	LINE FAULT
830	13-Sep-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	05:58	06:02	00:04	LINE FAULT
831	13-Sep-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	01:54	02:08	00:14	LINE FAULT
832	13-Sep-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	01:54	02:08	00:14	LINE FAULT
833	13-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
834	13-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
835	13-Sep-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	04:26	04:38	00:12	LINE FAULT
836	13-Sep-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	14:01	14:34	00:33	LINE FAULT
837	13-Sep-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	21:19	21:32	00:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
838	13-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	23:47(12.09.2020)	00:03(13.09.2020)	0:16 HRS	LINE CHARGED
839	13-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	00:11	00:22	00:11	LINE FAULT
840	13-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	04:27	04:52	00:25	LINE FAULT
841	13-Sep-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110,HUNSAGI_110	05:46	05:50	00:04	LINE FAULT
842	13-Sep-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110SAIDAPUR_1 10,WADAGERA_110,COREGR EEN SUGAR IPP	08:35	08:43	00:08	LINE FAULT
843	13-Sep-20	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	00:23	00:35	00:12	LINE FAULT
844	13-Sep-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MASKI_1 10,MUDDAPURA_110	21:20	21:30	00:10	LINE FAULT
845	13-Sep-20	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,TEKKALKOTE _110,DHADESUGUR_110	21:05	21:15	00:10	LINE FAULT
846	13-Sep-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:08(12.09.2020)	7:04(13.09.2020)	8:52HRS	LINE CHARGED
847	13-Sep-20	GULBARGA	220	HV1	KUSHTAGI_220	01:00	03:30	02:30	TRANSFORMER FAULT
848	13-Sep-20	GULBARGA	220	HV1	KUSHTAGI_220	03:51	04:19	00:28	TRANSFORMER FAULT
849	13-Sep-20	GULBARGA	220	HV1 & HV2	KUSHTAGI_220	21:44	22:12	00:28	TRANSFORMER FAULT
850	13-Sep-20	GULBARGA	220	HV2	KUSHTAGI_220	01:00	01:25	00:25	TRANSFORMER FAULT
851	13-Sep-20	GULBARGA	220	HV2	KUSHTAGI_220	03:51	04:09	00:18	TRANSFORMER FAULT
852	13-Sep-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	22:10(12.09.2020)	7:03(13.09.2020)	8:53HRS	LINE CHARGED
853	13-Sep-20	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	09:27	20:55	11:28	LINE CLEAR AVAILED
854	13-Sep-20	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	09:54	20:56	11:02	LINE CLEAR AVAILED
855	13-Sep-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	22:07(12.09.2020)	10:36(13.09.2020)	12:28HRS	LINE CHARGED
856	13-Sep-20	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	23:48(12.09.2020)	00:08(13.09.2020)	0:20HRS	LINE CHARGED
857	13-Sep-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_220	1:06(10.9.2020)			LINE OPEN: LINE CLEAR AVAILED
858	13-Sep-20	GULBARGA	400	BTPS-RTPS	BTPS_400	05:02	15:41	10:39	LINE FAULT
859	13-Sep-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN:LINE FAULT
860	13-Sep-20	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	09:06	09:44	00:38	LINE FAULT
861	13-Sep-20	HASSAN	66	HV1	SAKLESH PURA_66	12:33	12:44	00:11	TRANSFORMER FAULT
862	13-Sep-20	HASSAN	110	HV2	GURUVAYANAKERE_110	12:20	15:30	03:10	TRANSFORMER FAULT
863	13-Sep-20	HASSAN	110	HV2	SHIKARIPURA_110	12:20	12:55	00:35	LINE CLEAR AVAILED
864	13-Sep-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:32 (13.09.2020)			LINE OPEN:LINE FAULT
865	13-Sep-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	07:25	09:00	01:35	LINE FAULT
866	13-Sep-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	23:33(13.09.2020)			LINE OPEN:LINE FAULT
867	13-Sep-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	12:00	12:42	00:42	LINE FAULT
868	13-Sep-20	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	23:33(13.09.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
869	13-Sep-20	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	12:00	12:42	00:42	LINE FAULT
870	13-Sep-20	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
871	13-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:47 (12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
872	13-Sep-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
873	13-Sep-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	4:19(13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
874	13-Sep-20	MYSORE	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	12:41	15:25	2:43	HAND TRIPPED
875	13-Sep-20	MYSORE	66	HV1	TERAKANAMBE_66	15:55	16:10	0:15	LINE CLEAR AVAILED
876	13-Sep-20	MYSORE	66	HV2	METAGALLY_66	10:41	17:22	6:41	LINE CLEAR AVAILED
877	13-Sep-20	MYSORE	66	HV2	TERAKANAMBE_66	10:51	13:05	2:13	LINE CLEAR AVAILED
878	13-Sep-20	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	18:16	18:29	0:13	HAND TRIPPED
879	13-Sep-20	MYSORE	66	MEGHALAPURA-SFC	THUMBLA_66 VYASRAJPURA_66 GARGESHWARI_66 CHIDRAVALLI_66 BGPURA_66	5:28	5:39	0:10	LINE FAULT
880	13-Sep-20	MYSORE	66	MEGHALAPURA-SFC	THUMBLA_66 VYASRAJPURA_66 GARGESHWARI_66 CHIDRAVALLI_66 BGPURA_66	5:57	6:11	0:14	LINE FAULT
881	13-Sep-20	MYSORE	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	19:06	19:14	0:08	LINE FAULT
882	13-Sep-20	TUMKUR	66	ANCHEPALYA 220kV-HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	12:32	14:04	1:31	LINE CLEAR AVAILED
883	13-Sep-20	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	7:22	7:25	0:02	HAND TRIPPED
884	13-Sep-20	TUMKUR	66	CHAWDANKUPPE-ANCHEPALYA	CHAWANAKUPPE_66	12:38	14:22	1:43	LINE CLEAR AVAILED
885	13-Sep-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:36	19:34	8:58	HAND TRIPPED
886	13-Sep-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	15:33	15:43	0:09	LINE FAULT
887	13-Sep-20	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	21:03	21:16	0:13	LINE FAULT
888	13-Sep-20	TUMKUR	66	TR-1	NYAMATHI_66	11:49	19:11	7:21	LINE CLEAR AVAILED
889	13-Sep-20	TUMKUR	66	TR-1	PANDARAHALLI_66	19:24	19:27	0:02	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
890	13-Sep-20	TUMKUR	66	TR-1	PAVAGADA_220	12:13	12:17	0:04	TRANSFORMER FAULT
891	13-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
892	13-Sep-20	TUMKUR	66	TR-2	MADHUGIRI_66	9:43	9:49	0:05	TRANSFORMER FAULT
893	13-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
894	13-Sep-20	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	6:36	19:24	12:48	LINE CLEAR AVAILED
895	13-Sep-20	TUMKUR	220	THALLAK 220kV-CHITRADURGA	THALLAKK_220	6:42	19:07	12:24	LINE CLEAR AVAILED
896	14-Sep-20	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
897	14-Sep-20	BAGALKOT	110	110/11KV, HV1	AIGALI_110	18:00 (12.09.2020)	14:51 (14.09.2020)	20:51	TRANSFORMER FAULT
898	14-Sep-20	BAGALKOT	110	110/11KV, HV1	AIGALI_110	16:50	16:58	00:08	LINE CLEAR AVAILED
899	14-Sep-20	BAGALKOT	110	110/11KV,HV1	NAVALGUND_110	12:21	13:59	01:38	LINE CLEAR AVAILED
900	14-Sep-20	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	21:03	21:09	00:06	TRANSFORMER FAULT
901	14-Sep-20	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	15:25	16:52	01:27	TRANSFORMER FAULT
902	14-Sep-20	BAGALKOT	110	110/11KV,HV1&HV2	YARAGATTI_110	17:50	17:54	00:04	LOAD CURTAILMENT
903	14-Sep-20	BAGALKOT	110	110/11KV,HV1,HV2	KAGAWAD_110	10:20	19:03	08:43	LINE CLEAR AVAILED
904	14-Sep-20	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	14:10	17:26	03:16	TRANSFORMER FAULT
905	14-Sep-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:54	14:09	01:15	TRANSFORMER FAULT
906	14-Sep-20	BAGALKOT	110	110/33KV,HV3	YARAGATTI_110,BOSCH SOLAR_33,CHUNCHNUR LIS_33,SHIVAPUR_33	17:50	17:52	00:02	LOAD CURTAILMENT
907	14-Sep-20	BAGALKOT	110	110/33KV,HV4(HV3)	LAKAMANAHALLI_110,ALNA VAR_33	12:35	14:02	01:27	LINE CLEAR AVAILED
908	14-Sep-20	BAGALKOT	110	220/110KV,LV 1	STATIONS NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)	13:15 (14.09.2020)	00:10	TRANSFORMER CHARGED
909	14-Sep-20	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	21:53 (13.09.2020)	7:01 (14.09.2020)	09:08	TRANSFORMER CHARGED
910	14-Sep-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	21:38 (13.09.2020)	11:38 (14.09.2020)	14:00	TRANSFORMER CHARGED
911	14-Sep-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	21:57 (14.09.2020)			LOAD CURTAILMENT
912	14-Sep-20	BAGALKOT	110	BAGALKOT220-KALADAGI	KALADAGI_110	12:41	12:54	00:13	HAND TRIPPED
913	14-Sep-20	BAGALKOT	110	BAGALKOT220-NEERABUDIHAL	NEERABUDIHAL_110	12:33	13:09	00:36	HAND TRIPPED
914	14-Sep-20	BAGALKOT	110	BAGEWADI1-MAMADAPUR(B)	MAMADAPUR(B)_110	19:49	20:06	00:17	LINE FAULT
915	14-Sep-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
916	14-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
917	14-Sep-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
918	14-Sep-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
919	14-Sep-20	BAGALKOT	110	HIREKERUR-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	13:48 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
920	14-Sep-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
921	14-Sep-20	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN: LINE CLEAR AVAILED
922	14-Sep-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
923	14-Sep-20	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWAD	KAGAWAD_110	10:15	19:27	09:12	LOAD CURTAILMENT
924	14-Sep-20	BAGALKOT	110	UGAR KHUD-KAGAWAD	KAGAWAD_110	10:15	19:00	08:45	LINE CLEAR AVAILED
925	14-Sep-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
926	14-Sep-20	BAGALKOT	110	YARAGATTI-KATKOL	KATKOL_110	17:33	17:52	00:19	LOAD CURTAILMENT
927	14-Sep-20	BAGALKOT	220	220/110,HV1,LV1	KARWAR_220	12:30	12:49	00:19	LINE CLEAR AVAILED
928	14-Sep-20	BAGALKOT	220	220/110KV, HV2 & LV2	CHIKKODI_220	15:55	16:25	00:30	HAND TRIPPED
929	14-Sep-20	BAGALKOT	220	AMBEWADI-NAGAJHARI	NO STATION EFFECTED AMBEWADI_220	22:57 (13.09.2020)	6:33 (14.09.2020)	07:36	LINE CHARGED
930	14-Sep-20	BAGALKOT	220	AMBEWADI-NARENDRA2	NO STATION EFFECTED AMBEWADI_220	22:57 (13.09.2020)	6:32 (14.09.2020)	07:35	LINE CHARGED
931	14-Sep-20	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	23:07 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
932	14-Sep-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
933	14-Sep-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN: LINE CLEAR AVAILED
934	14-Sep-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	22:34 (12.09.2020)	8:12 (14.09.2020)	09:38	LINE CHARGED
935	14-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	22:12 (13.09.2020)	7:44 (14.09.2020)	09:32	LINE CHARGED
936	14-Sep-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	21:58 (14.09.2020)			LINE OPEN: LINE CLEAR AVAILED
937	14-Sep-20	BAGALKOT	220	CHIKKODI-BELGAUM	BELGAUM_220	13:36	15:40	02:04	HAND TRIPPED
938	14-Sep-20	BAGALKOT	220	GADAG- BAGALKOT1	GADAG_220	23:07 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
939	14-Sep-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)	22:06 (14.09.2020)	03:18	LINE CHARGED
940	14-Sep-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
941	14-Sep-20	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	23:11 (13.09.2020)	6:33 (14.09.2020)	07:22	LOAD CURTAILMENT
942	14-Sep-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
943	14-Sep-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALI, CHEEMANGALA	22:40(13/09/2020)	4:55(14/09/2020)	6:15HRS	LINE CHARGED
944	14-Sep-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:33	18:42	00:09	LINE FAULT
945	14-Sep-20	BENGALURU	66	HV1	CHELUR	06:55	13:36	06:41	TRANSFORMER FAULT
946	14-Sep-20	BENGALURU	66	HV1	N G HULKUR	15:17	17:30	02:13	LINE CLEAR AVAILED
947	14-Sep-20	BENGALURU	66	HV1	SARJAPURA 220	14:02	14:04	00:02	LINE CLEAR AVAILED
948	14-Sep-20	BENGALURU	66	HV1	PATHPALYA	08:55	09:05	00:10	TRANSFORMER FAULT
949	14-Sep-20	BENGALURU	66	HV1	PATHPALYA	11:37	12:22	00:45	LINE CLEAR AVAILED
950	14-Sep-20	BENGALURU	66	HV2	LEELA VENTURE	12:37	12:40	00:03	LINE CLEAR AVAILED
951	14-Sep-20	BENGALURU	66	HV2	ANEKAL	12:23	12:27	00:04	LINE CLEAR AVAILED
952	14-Sep-20	BENGALURU	66	HV2	N G HULKUR	11:51	14:52	03:01	LINE CLEAR AVAILED
953	14-Sep-20	BENGALURU	66	HV2	S M MANGALA	19:04	20:02	00:58	TRANSFORMER FAULT
954	14-Sep-20	BENGALURU	66	HV3	CHANDAPURA	11:25	11:30	00:05	TRANSFORMER FAULT
955	14-Sep-20	BENGALURU	66	KYALANUR - TALAGWARA	TALAGAWARA, Y HUNSENAHALI, CHEEMANGALA	02:02	02:16	00:14	LINE FAULT
956	14-Sep-20	BENGALURU	66	KYALANUR - TALAGWARA	TALAGAWARA, Y HUNSENAHALI, CHEEMANGALA	06:26	06:33	00:07	LOAD CHANGE OVER
957	14-Sep-20	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	02:02	02:13	00:11	LINE FAULT
958	14-Sep-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	06:04	06:08	00:04	LOAD CHANGE OVER
959	14-Sep-20	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:01	14:06	00:05	LINE CLEAR AVAILED
960	14-Sep-20	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	17:13	17:20	00:07	LINE CLEAR AVAILED
961	14-Sep-20	BENGALURU	66	T K HALLI 220 - LIMBAVALI	T K HALLI 220	09:26	14:10	04:44	LINE CLEAR AVAILED
962	14-Sep-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	16:58	18:33	01:35	LINE FAULT
963	14-Sep-20	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	23:02:00(13/09/2020)	06:32:00(14/09/2020)	07:29	LINE CHARGED
964	14-Sep-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
965	14-Sep-20	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	11:40	15:30	03:50	LINE CLEAR AVAILED
966	14-Sep-20	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	06:49	07:00	00:11	LINE FAULT
967	14-Sep-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	13:15	14:35	01:20	LINE FAULT
968	14-Sep-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	23:15	23:20	00:05	LINE FAULT
969	14-Sep-20	GULBARGA	110	HV1	HUMNABAD_220	13:09	14:20	01:11	LINE CLEAR AVAILED
970	14-Sep-20	GULBARGA	110	HV1	HUNUMANAL_110	06:00	08:50	02:50	TRANSFORMER FAULT
971	14-Sep-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	05:48	05:58	00:10	LINE FAULT
972	14-Sep-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDI NNI_110	05:48	06:14	00:26	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
973	14-Sep-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	00:56	01:07	00:11	LINE FAULT
974	14-Sep-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
975	14-Sep-20	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	23:55(14.9.2020)			LINE OPEN:LINE FAULT
976	14-Sep-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110 ,BTPSWATERWORKS	04:45	04:55	00:10	LINE FAULT
977	14-Sep-20	GULBARGA	220	HV1	HALBARGA_220	06:49	06:56	00:07	TRANSFORMER FAULT
978	14-Sep-20	GULBARGA	220	HV1,HV2	HUMNABAD_220	13:09	14:20	01:11	LINE CLEAR AVAILED
979	14-Sep-20	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	13:20	19:55	06:35	LINE CHARGED
980	14-Sep-20	GULBARGA	220	LINGAPUR-KUSHTAGI	KUSHTAGI_220	15:41	19:25	03:44	NFBC ISSUED
981	14-Sep-20	GULBARGA	220	LINGASUGUR-KUSHTAGI	LINGASUGUR_220	08:55	15:20	06:25	NFBC ISSUED
982	14-Sep-20	GULBARGA	220	LINGASUGUR-KUSHTAGI	LINGASUGUR_220	19:30	20:00	00:30	LINE CLEAR AVAILED
983	14-Sep-20	GULBARGA	220	MALLAT-RTPS	MALLAT_220	02:06	02:51	00:45	LINE FAULT
984	14-Sep-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	1:06(10.9.2020)	10:46(14.9.2020)	105:40HRS	LINE CHARGED
985	14-Sep-20	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	22:50			LINE OPEN: LINE CLEAR AVAILED
986	14-Sep-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN: LINE CLEAR AVAILED
987	14-Sep-20	HASSAN	66	HV1	MAGGE_66	11:17	12:12	00:55	LINE CLEAR AVAILED
988	14-Sep-20	HASSAN	66	HV2	MAGGE_66	11:17	12:12	00:55	LINE CLEAR AVAILED
989	14-Sep-20	HASSAN	66	LV1	MRSMSG_220	11:31	11:36	00:05	LINE CLEAR AVAILED
990	14-Sep-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:35	11:38	00:03	LINE CLEAR AVAILED
991	14-Sep-20	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:35	11:37	00:02	LINE CLEAR AVAILED
992	14-Sep-20	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	15:21	15:32	00:11	LINE FAULT
993	14-Sep-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	04:33	04:40	00:07	LINE FAULT
994	14-Sep-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	11:40	11:43	00:03	MAIN SUPPLY FAILURE
995	14-Sep-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	13:02	14:36	01:34	LINE FAULT
996	14-Sep-20	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	14:56	15:52	00:56	NFBC ISSUED
997	14-Sep-20	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	14:07	14:29	00:22	HAND TRIPPED
998	14-Sep-20	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	14:29	14:30	00:01	HAND TRIPPED
999	14-Sep-20	HASSAN	110	LV1	ARASIKERE_220	14:07	14:26	00:19	LINE CLEAR AVAILED
1000	14-Sep-20	HASSAN	110	LV1	ARASIKERE_220	16:22	18:38	02:16	LINE CLEAR AVAILED
1001	14-Sep-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:32 (13.09.2020)	12:09 (14.09.2020)	26:36 hrs	LINE CHARGED
1002	14-Sep-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	14:55	15:51	00:56	LINE CLEAR AVAILED
1003	14-Sep-20	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	10:45	18:31	07:46	NFBC ISSUED
1004	14-Sep-20	HASSAN	220	HV1	ARASIKERE_220	14:07	14:24	00:17	LINE CLEAR AVAILED
1005	14-Sep-20	HASSAN	220	HV1	ARASIKERE_220	16:23	18:37	02:14	LINE CLEAR AVAILED
1006	14-Sep-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	23:33(13.09.2020)	11:47(14.09.2020)	12:13 hrs	LINE CHARGED
1007	14-Sep-20	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	18:43(14.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1008	14-Sep-20	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	12:33	18:43	06:10	LINE FAULT
1009	14-Sep-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	12:33	12:57	00:24	LINE FAULT
1010	14-Sep-20	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	23:33(13.09.2020)	11:47(14.09.2020)	12:13 hrs	LINE CHARGED
1011	14-Sep-20	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	12:32 (14.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1012	14-Sep-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	16:23	16:42	00:19	LINE FAULT
1013	14-Sep-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	18:43	18:47	00:04	LINE FAULT
1014	14-Sep-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:34	12:57	00:23	LINE FAULT
1015	14-Sep-20	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1016	14-Sep-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:47 (12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1017	14-Sep-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(12.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1018	14-Sep-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	4:19(13.09.2020)	8:26 (14.09.2020)	28:6 hrs	LINE CHARGED
1019	14-Sep-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:08 (14.08.2020)			LINE OPEN: LINE CLEAR AVAILED
1020	14-Sep-20	MYSURU	66	ADDIHALLI-NAGMANGALA	ADDIHALLI_66	11:37	11:48	0:11	LINE CLEAR AVAILED
1021	14-Sep-20	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	12:00	12:16	0:15	LINE FAULT
1022	14-Sep-20	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	12:00	12:14	0:13	LINE FAULT
1023	14-Sep-20	MYSURU	66	HV1	AKKIHEBBAL_66	12:03	12:31	0:28	LINE CLEAR AVAILED
1024	14-Sep-20	MYSURU	66	HV1	CHANDAKAVADI_66	13:12	18:58	5:46	LINE CLEAR AVAILED
1025	14-Sep-20	MYSURU	66	HV2	AKKIHEBBAL_66	12:00	13:15	1:15	LINE CLEAR AVAILED
1026	14-Sep-20	MYSURU	66	K HONNALAGERE-IGLOOR	K_HONNALGERE_66	16:57	19:15	2:18	HAND TRIPPED
1027	14-Sep-20	MYSURU	66	SANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	12:45	13:00	0:15	LINE CLEAR AVAILED
1028	14-Sep-20	MYSURU	66	VIJAYANAGARA-BANNIMANTAPA	VIJAYANAGRAMYS_66	10:35	16:42	6:06	LINE CLEAR AVAILED
1029	14-Sep-20	MYSURU	66	VIJAYANAGARA-HOOTAGALLY	VIJAYANAGRAMYS_66	10:35	16:38	6:02	LINE CLEAR AVAILED
1030	14-Sep-20	MYSURU	220	HV1	MADHUVANAHALLI_220	10:33	13:12	2:38	LINE CLEAR AVAILED
1031	14-Sep-20	MYSURU	220	HV2	MADHUVANAHALLI_220	13:21	14:53	1:32	LINE CLEAR AVAILED
1032	14-Sep-20	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	11:58	12:03	00:04	HAND TRIPPED
1033	14-Sep-20	TUMKUR	66	CHITRADURGA 66kV-DAVANAGERE2	CHITRADURGA_66	11:59	13:09	01:10	HAND TRIPPED
1034	14-Sep-20	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 1	MEGMICON 1_IPP_66	12:30	13:04	00:34	LINE CLEAR AVAILED
1035	14-Sep-20	TUMKUR	66	HARIYABBE- PD KOTE	HARIYABBE_66	15:19	17:22	02:02	LINE CLEAR AVAILED
1036	14-Sep-20	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGI RI_66,BASAVAPATNA_66	10:56	11:03	00:07	LINE FAULT
1037	14-Sep-20	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGI RI_66,BASAVAPATNA_66	18:36	18:43	00:07	LINE FAULT
1038	14-Sep-20	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	15:43	16:05	00:22	LINE FAULT
1039	14-Sep-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	14:33	14:38	00:05	LINE FAULT
1040	14-Sep-20	TUMKUR	66	TR-1	CHITRADURGA_66	11:59	12:06	00:06	LINE CLEAR AVAILED
1041	14-Sep-20	TUMKUR	66	TR-1	HDPURA_66	09:14	09:25	00:11	TRANSFORMER FAULT
1042	14-Sep-20	TUMKUR	66	TR-1	HDPURA_66	10:01	10:10	00:08	TRANSFORMER FAULT
1043	14-Sep-20	TUMKUR	66	TR-1	MYLANAHALLI_66	15:06	16:30	01:23	TRANSFORMER FAULT
1044	14-Sep-20	TUMKUR	66	TR-1	SHYLAPURA_66	14:22	15:15	00:53	LINE CLEAR AVAILED
1045	14-Sep-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
1046	14-Sep-20	TUMKUR	66	TR-2	CHITRADURGA_66	11:59	12:06	00:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1047	14-Sep-20	TUMKUR	66	TR-2	HANAGAL_66	06:49	07:16	00:27	TRANSFORMER FAULT
1048	14-Sep-20	TUMKUR	66	TR-2	HOSADURGA_66	10:27	11:38	01:11	LINE CLEAR AVAILED
1049	14-Sep-20	TUMKUR	66	TR-2	NYAMATHI_66	11:09	18:15	07:05	LINE CLEAR AVAILED
1050	14-Sep-20	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	12:16	13:03	00:46	TRANSFORMER FAULT
1051	14-Sep-20	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	15:01	15:44	00:43	TRANSFORMER FAULT
1052	14-Sep-20	TUMKUR	66	TR-2	THOVINAKERE_66	12:34	13:10	00:35	LINE CLEAR AVAILED
1053	14-Sep-20	TUMKUR	110	TR-1	SAMPIGE_110	11:55	13:16	01:20	LINE CLEAR AVAILED
1054	14-Sep-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT