

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 09.07.2019 TO 15.07.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	9-Jul-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	0:00	14:53	14:53	LINE CLEAR AVAILED
2	9-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:39	7:39	LINE CLEAR AVAILED
3	9-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:07	23:59	5:52	LINE CLEAR AVAILED
4	9-Jul-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	4:50	5:42	0:52	TRANSFORMER FAULT
5	9-Jul-19	BAGALKOT	110	110/33KV, HV3	ANKALI_110, NANDIKURALI_33	16:07	16:33	0:26	TRANSFORMER FAULT
6	9-Jul-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	22:56	23:08	0:12	LINE FAULT
7	9-Jul-19	BAGALKOT	110	110/11KV, HV2	KAGWADA_110	11:05	11:16	0:11	TRANSFORMER FAULT
8	9-Jul-19	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	22:02	22:27	0:25	TRANSFORMER FAULT
9	9-Jul-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	18:05	23:59	5:54	LINE CLEAR AVAILED
10	9-Jul-19	BAGALKOT	220	SHARAVATHI 2-SIRSI	SIRSI_220	18:06	23:59	5:53	LINE CLEAR AVAILED
11	9-Jul-19	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	10:09	10:23	0:14	HAND TRIPPED
12	9-Jul-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	7:34	8:47	1:13	TRANSFORMER FAULT
13	9-Jul-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	10:40	12:20	1:40	LINE CLEAR AVAILED
14	9-Jul-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	12:43	13:13	0:30	TRANSFORMER FAULT
15	9-Jul-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	11:14	13:22	2:08	LINE CLEAR AVAILED
16	9-Jul-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	9:50	9:50	LINE CLEAR AVAILED
17	9-Jul-19	BAGALKOT	110	110/11KV,HV1	LAXMESHVAR_110	10:15	14:22	4:07	LINE CLEAR AVAILED
18	9-Jul-19	BAGALKOT	110	110/11KV,HV2	LAXMESHVAR_110	10:15	14:15	4:00	LINE CLEAR AVAILED
19	9-Jul-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33	13:13	13:17	0:04	TRANSFORMER FAULT
20	9-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	6:01	6:08	0:07	LINE FAULT
21	9-Jul-19	BENGALURU	66	HV2	BAGEPALLI	8:45	9:10	0:25	TRANSFORMER FAULT
22	9-Jul-19	BENGALURU	66	HV2	DODDABELAVANGALA	21:00	21:09	0:08	TRANSFORMER FAULT
23	9-Jul-19	BENGALURU	66	HV2	HONNIGANAHALLI	7:18	7:55	0:36	TRANSFORMER FAULT
24	9-Jul-19	BENGALURU	66	HV2	EPIP 220	12:19	12:47	0:28	TRANSFORMER FAULT
25	9-Jul-19	BENGALURU	66	HV2	EPIP 220	14:51	22:48	7:57	LINE CLEAR AVAILED
26	9-Jul-19	BENGALURU	66	HV2	ISRO LAYOUT	23:02	23:59	0:56	TRANSFORMER FAULT
27	9-Jul-19	BENGALURU	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	23:50	23:59	0:09	LOAD CHANGE OVER
28	9-Jul-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	5:47	5:56	0:08	LINE FAULT
29	9-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	19:20	19:59	0:38	LINE FAULT
30	9-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:07	19:16	0:08	LINE FAULT
31	9-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:16	21:29	2:13	LINE FAULT
32	9-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	0:00	9:33	9:33	LINE FAULT
33	9-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	18:00	23:59	5:59	LINE FAULT
34	9-Jul-19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	0:00	14:50	14:50	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
35	9-Jul-19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	14:51	14:58	0:07	LINE CLEAR AVAILED
36	9-Jul-19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	15:39	23:59	8:20	LINE FAULT
37	9-Jul-19	GULBARGA	220	HV1	ITTAGI_220	18:25	18:35	0:10	TRANSFORMER FAULT
38	9-Jul-19	GULBARGA	220	HV1	KUSTAGI_220	12:18	12:45	0:27	TRANSFORMER FAULT
39	9-Jul-19	GULBARGA	220	HV2	KUSTAGI_220	13:45	14:06	0:21	TRANSFORMER FAULT
40	9-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	0:10	0:20	0:10	LINE FAULT
41	9-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	1:50	2:04	0:14	LINE FAULT
42	9-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	4:15	4:25	0:10	LINE FAULT
43	9-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	8:50	16:26	7:36	LINE CLEAR AVAILED
44	9-Jul-19	GULBARGA	110	SHAHPUR-WARDHASOLAR_IPP	SHAHPUR_220	18:31	19:07	0:36	LINE CLEAR AVAILED
45	9-Jul-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110, MADALAPURA_110	22:49	23:01	0:12	LINE FAULT
46	9-Jul-19	GULBARGA	110	GURGUNTA-KHEL_IPP	KHEL_IPP	10:34	19:33	8:59	LINE CLEAR AVAILED
47	9-Jul-19	GULBARGA	110	GURGUNTA-LJVL_IPP	LJVL_IPP	10:34	19:33	8:59	LINE CLEAR AVAILED
48	9-Jul-19	GULBARGA	110	HV1	BYAGAWAT_110	18:49	20:31	1:42	LINE CLEAR AVAILED
49	9-Jul-19	GULBARGA	66	ITTAGI-CLNMAX2	ITTAGI_220	12:17	12:34	0:17	LINE CLEAR AVAILED
50	9-Jul-19	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	12:13	12:15	0:02	LINE CLEAR AVAILED
51	9-Jul-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	12:05	12:10	0:05	LINE CLEAR AVAILED
52	9-Jul-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	15:40	15:45	0:05	TRANSFORMER FAULT
53	9-Jul-19	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	12:15	12:20	0:05	LINE CLEAR AVAILED
54	9-Jul-19	GULBARGA	66	HV1	CHORNOOR_66	13:05	13:07	0:02	TRANSFORMER FAULT
55	9-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	9:25	9:25	LINE CLEAR AVAILED
56	9-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	12:58	23:59	11:01	LINE CLEAR AVAILED
57	9-Jul-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	16:55	17:15	0:20	HAND TRIPPED
58	9-Jul-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	16:55	17:15	0:20	HAND TRIPPED
59	9-Jul-19	HASSAN	220	KCVOOR-KEMAR3	KAVOOR_220	16:55	17:14	0:19	MAIN SUPPLY FAILURE
60	9-Jul-19	HASSAN	220	KCVOOR-KEMR1	KAVOOR_220	16:55	17:14	0:19	MAIN SUPPLY FAILURE
61	9-Jul-19	HASSAN	220	KCVOOR-KEMR2	KAVOOR_220	16:55	17:14	0:19	MAIN SUPPLY FAILURE
62	9-Jul-19	HASSAN	110	HV2	KAVOOR_220	16:55	17:07	0:12	TRANSFORMER FAULT
63	9-Jul-19	HASSAN	110	HV3	KAVOOR_220	16:55	17:07	0:12	TRANSFORMER FAULT
64	9-Jul-19	HASSAN	110	KCVOOR-MCFLine	KAVOOR_220	18:37	23:59	5:22	LINE FAULT
65	9-Jul-19	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	16:35	16:55	0:20	LINE FAULT
66	9-Jul-19	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	8:50	14:35	5:45	LINE CLEAR AVAILED
67	9-Jul-19	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	16:35	23:59	7:24	LINE FAULT
68	9-Jul-19	HASSAN	220	KEMAR-Kavoor3	KEMAR_220	16:56	17:13	0:17	LINE FAULT
69	9-Jul-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	16:56	17:10	0:14	LINE FAULT
70	9-Jul-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	16:56	17:10	0:14	LINE FAULT
71	9-Jul-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	16:56	17:14	0:18	LINE FAULT
72	9-Jul-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	16:56	17:14	0:18	LINE FAULT
73	9-Jul-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:56	17:13	0:17	LINE FAULT
74	9-Jul-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	16:56	17:13	0:17	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
75	9-Jul-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	16:56	17:13	0:17	LINE FAULT
76	9-Jul-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	8:31	14:30	5:59	LINE CLEAR AVAILED
77	9-Jul-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	16:56	17:22	0:26	LINE FAULT
78	9-Jul-19	HASSAN	110	HV1	KEMAR_220	16:56	17:06	0:10	MAIN SUPPLY FAILURE
79	9-Jul-19	HASSAN	110	HV2	KEMAR_220	16:56	17:06	0:10	MAIN SUPPLY FAILURE
80	9-Jul-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	17:00	17:15	0:15	MAIN SUPPLY FAILURE
81	9-Jul-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	17:00	17:15	0:15	MAIN SUPPLY FAILURE
82	9-Jul-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	16:34	16:55	0:21	LINE FAULT
83	9-Jul-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	17:00	19:36	2:36	MAIN SUPPLY FAILURE
84	9-Jul-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	8:50	14:35	5:45	LINE CLEAR AVAILED
85	9-Jul-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	16:34	23:59	7:25	LINE FAULT
86	9-Jul-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	16:56	17:11	0:15	MAIN SUPPLY FAILURE
87	9-Jul-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	16:57	17:16	0:19	HAND TRIPPED
88	9-Jul-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	16:57	17:14	0:17	HAND TRIPPED
89	9-Jul-19	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	0:00	15:46	15:46	LINE CLEAR AVAILED
90	9-Jul-19	HASSAN	110	HV1	BAIKAMPADI_110	16:57	17:17	0:20	MAIN SUPPLY FAILURE
91	9-Jul-19	HASSAN	110	HV1	BAIKAMPADI_110	18:42	23:59	5:17	MAIN SUPPLY FAILURE
92	9-Jul-19	HASSAN	110	HV3	BAIKAMPADI_110	16:57	17:17	0:20	MAIN SUPPLY FAILURE
93	9-Jul-19	HASSAN	110	HV3	BAIKAMPADI_110	18:39	23:59	5:20	MAIN SUPPLY FAILURE
94	9-Jul-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:34	17:07	0:33	MAIN SUPPLY FAILURE
95	9-Jul-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:34	17:07	0:33	MAIN SUPPLY FAILURE
96	9-Jul-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	12:50	13:03	0:13	MAIN SUPPLY FAILURE
97	9-Jul-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	13:11	14:36	1:25	MAIN SUPPLY FAILURE
98	9-Jul-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	16:57	17:27	0:30	MAIN SUPPLY FAILURE
99	9-Jul-19	HASSAN	110	HV2	HIRIYADKA_110	11:28	13:09	1:41	LINE CLEAR AVAILED
100	9-Jul-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	16:55	17:24	0:29	MAIN SUPPLY FAILURE
101	9-Jul-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	12:50	13:04	0:14	MAIN SUPPLY FAILURE
102	9-Jul-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	13:11	14:35	1:24	MAIN SUPPLY FAILURE
103	9-Jul-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	16:57	17:25	0:28	MAIN SUPPLY FAILURE
104	9-Jul-19	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	12:50	13:04	0:14	LINE FAULT
105	9-Jul-19	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	13:11	14:35	1:24	LINE FAULT
106	9-Jul-19	HASSAN	110	HV1	KARAYA_110	11:58	13:27	1:29	LINE CLEAR AVAILED
107	9-Jul-19	HASSAN	110	HV1	KITTADAHALLI_110	10:59	12:20	1:21	LINE CLEAR AVAILED
108	9-Jul-19	HASSAN	110	HV2	KONAJE_110	17:09	17:20	0:11	MAIN SUPPLY FAILURE
109	9-Jul-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:08	17:21	0:13	MAIN SUPPLY FAILURE
110	9-Jul-19	HASSAN	110	HV2	KONDENALU_110	10:25	15:45	5:20	LINE CLEAR AVAILED
111	9-Jul-19	HASSAN	110	HV1	KONDENALU_110	10:15	14:36	4:21	LINE CLEAR AVAILED
112	9-Jul-19	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	18:41	22:49	4:08	LINE FAULT
113	9-Jul-19	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	16:57	17:07	0:10	MAIN SUPPLY FAILURE
114	9-Jul-19	HASSAN	110	HV1	NAVUNDA_110	12:11	17:37	5:26	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
115	9-Jul-19	HASSAN	110	HV1	NAVUNDA_110	17:55	22:48	4:53	MAIN SUPPLY FAILURE
116	9-Jul-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	11:55	12:55	1:00	LINE CLEAR AVAILED
117	9-Jul-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	13:45	14:15	0:30	LINE CLEAR AVAILED
118	9-Jul-19	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	10:15	19:00	8:45	LINE CLEAR AVAILED
119	9-Jul-19	HASSAN	66	HV1	HARIHARAPURA_66	3:25	3:55	0:30	TRANSFORMER FAULT
120	9-Jul-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	12:04	12:33	0:29	LINE CLEAR AVAILED
121	9-Jul-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	13:04	13:15	0:11	HAND TRIPPED
122	9-Jul-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	14:28	15:14	0:46	HAND TRIPPED
123	9-Jul-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	11:21	11:40	0:19	HAND TRIPPED
124	9-Jul-19	HASSAN	66	HV2	SALAGAME-66	13:39	14:35	0:56	LINE CLEAR AVAILED
125	9-Jul-19	MYSORE	66	HV1	BOOKANAKERE_66	9:27	13:44	4:16	LINE CLEAR AVAILED
126	9-Jul-19	MYSORE	66	HV2	BOOKANAKERE_66	9:27	13:44	4:16	LINE CLEAR AVAILED
127	9-Jul-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:10	12:10	0:00	LINE CLEAR AVAILED
128	9-Jul-19	MYSORE	66	HV1	MADIKERI_66	20:18	21:51	1:32	TRANSFORMER FAULT
129	9-Jul-19	MYSORE	66	HV2	METAGALLY_66	21:00	21:06	0:06	HAND TRIPPED
130	9-Jul-19	MYSORE	66	MEGALAPURA-SFC	CHIDRAVALLI_66 THUMBLA_66	2:10	2:15	0:05	LINE FAULT
131	9-Jul-19	MYSORE	66	HV1	VIJAYANAGRAMYS_66	11:06	14:01	2:55	LINE CLEAR AVAILED
132	9-Jul-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	10:34	19:53	9:18	LINE CLEAR AVAILED
133	9-Jul-19	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	7:16	7:24	0:08	LINE CLEAR AVAILED
134	9-Jul-19	TUMKUR	66	TR-2	GARAGA_66	12:14	13:26	1:12	LINE CLEAR AVAILED
135	9-Jul-19	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	22:57	23:35	0:38	LINE FAULT
136	9-Jul-19	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR_IPP_66	MUNIRAJ SOLAR_IPP_66	11:34	11:41	0:06	LINE CLEAR AVAILED
137	9-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:05	16:20	8:15	LINE FAULT
138	10-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:14	7:14	LINE CLEAR AVAILED
139	10-Jul-19	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	9:47	18:05	8:18	LINE CLEAR AVAILED
140	10-Jul-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	9:41	12:14	2:33	LINE CLEAR AVAILED
141	10-Jul-19	BAGALKOT	220	220/110KV, HV1&LV1	BAGEWADI_220, MAMDAPUR_110, NIDAGUNDI_110	0:01	0:20	0:19	TRANSFORMER FAULT
142	10-Jul-19	BAGALKOT	220	220/110KV, HV2&LV2	BAGEWADI_220, MAMDAPUR_110, NIDAGUNDI_110	0:01	0:20	0:19	TRANSFORMER FAULT
143	10-Jul-19	BAGALKOT	220	ALAMATTI1&2-BAGALKOT	BAGALKOT_220	8:14	23:59	15:45	LINE CLEAR AVAILED
144	10-Jul-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	11:10	16:41	5:31	LINE CLEAR AVAILED
145	10-Jul-19	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	6:00	9:54	3:54	LINE FAULT
146	10-Jul-19	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	20:10	23:01	2:51	LINE CLEAR AVAILED
147	10-Jul-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	0:00	16:51	16:51	LINE CLEAR AVAILED
148	10-Jul-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	12:18	16:20	4:02	LINE CLEAR AVAILED
149	10-Jul-19	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	11:30	12:35	1:05	LINE CLEAR AVAILED
150	10-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	14:21	15:17	0:56	LINE FAULT
151	10-Jul-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	6:30	17:13	10:43	LINE FAULT
152	10-Jul-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	20:56	23:59	3:03	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
153	10-Jul-19	BAGALKOT	220	SHARAVATHI 1&2-SIRSI	SIRSI_220	0:00	9:21	9:21	LINE CLEAR AVAILED
154	10-Jul-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	15:41	23:59	8:18	LINE FAULT
155	10-Jul-19	BAGALKOT	110	RON-GAJENDRAGAD 2	GAJENDRAGAD_110	17:24	17:30	0:06	HAND TRIPPED
156	10-Jul-19	BAGALKOT	110	110/11KV,HV1	MURDESHWAR_110	12:00	12:10	0:10	LINE CLEAR AVAILED
157	10-Jul-19	BAGALKOT	110	110/33KV,HV2	MURDESHWAR_110,KASARAGUDU_33	12:00	12:17	0:17	LINE CLEAR AVAILED
158	10-Jul-19	BAGALKOT	110	110/33KV,HV3	MURDESHWAR_110,BATAKALA_33	12:00	12:17	0:17	LINE CLEAR AVAILED
159	10-Jul-19	BENGALURU	66	HV2	ISRO LAYOUT	0:00	0:01	0:01	TRANSFORMER FAULT
160	10-Jul-19	BENGALURU	66	HOSKOTE 220 - BEGUR 220	HOSKOTE 220	18:14	18:53	0:39	MAIN SUPPLY FAILURE
161	10-Jul-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	18:14	18:53	0:39	MAIN SUPPLY FAILURE
162	10-Jul-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	18:14	18:53	0:39	MAIN SUPPLY FAILURE
163	10-Jul-19	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	18:14	18:53	0:39	MAIN SUPPLY FAILURE
164	10-Jul-19	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	18:14	18:53	0:39	MAIN SUPPLY FAILURE
165	10-Jul-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:14	18:53	0:39	MAIN SUPPLY FAILURE
166	10-Jul-19	BENGALURU	220	HV1	BEGUR 220	18:14	18:19	0:05	MAIN SUPPLY FAILURE
167	10-Jul-19	BENGALURU	220	HV2	BEGUR 220	18:14	18:19	0:05	MAIN SUPPLY FAILURE
168	10-Jul-19	BENGALURU	66	BEGUR 220 - BIAL 1	BIAL	18:14	18:20	0:06	MAIN SUPPLY FAILURE
169	10-Jul-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	18:14	18:31	0:17	MAIN SUPPLY FAILURE
170	10-Jul-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	18:14	18:40	0:26	MAIN SUPPLY FAILURE
171	10-Jul-19	BENGALURU	66	DB PURA 220- BEGUR 220	BEGUR 220	18:14	18:19	0:05	LINE FAULT
172	10-Jul-19	BENGALURU	66	HV2	NRS 220	11:48	12:05	0:17	LINE CLEAR AVAILED
173	10-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	11:39	11:55	0:16	LINE FAULT
174	10-Jul-19	BENGALURU	66	HV1	CB PURA I/A	10:43	17:43	6:59	LINE CLEAR AVAILED
175	10-Jul-19	BENGALURU	66	HV1	KIADB DB PURA 220	2:06	2:13	0:06	TRANSFORMER FAULT
176	10-Jul-19	BENGALURU	66	HV1	KIADB DB PURA 220	2:24	2:28	0:03	TRANSFORMER FAULT
177	10-Jul-19	BENGALURU	66	HV1	CHAKAVELU	20:11	20:11	0:00	LINE CLEAR AVAILED
178	10-Jul-19	BENGALURU	66	HV1	NIMHANS 220	6:40	7:09	0:29	TRANSFORMER FAULT
179	10-Jul-19	BENGALURU	66	HV3	SHAMRAJ TECH PARK	10:44	11:20	0:35	LINE CLEAR AVAILED
180	10-Jul-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	23:02	23:59	0:56	LINE FAULT
181	10-Jul-19	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	9:25	9:56	0:31	HAND TRIPPED
182	10-Jul-19	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	12:13	12:20	0:07	LINE CLEAR AVAILED
183	10-Jul-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	10:00	16:19	6:19	LINE CLEAR AVAILED
184	10-Jul-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	10:00	16:20	6:20	LINE CLEAR AVAILED
185	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	10:00	16:59	6:59	LINE CLEAR AVAILED
186	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	10:00	17:20	7:20	LINE CLEAR AVAILED
187	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	10:00	17:04	7:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
188	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	10:00	16:26	6:26	LINE CLEAR AVAILED
189	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	10:00	17:10	7:10	LINE CLEAR AVAILED
190	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	10:00	16:51	6:51	LINE CLEAR AVAILED
191	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:00	17:20	7:20	LINE CLEAR AVAILED
192	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	10:00	16:41	6:41	LINE CLEAR AVAILED
193	10-Jul-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:00	17:01	7:01	LINE CLEAR AVAILED
194	10-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	0:00	9:40	9:40	LINE FAULT
195	10-Jul-19	GULBARGA	220	LINGAPUR-GUDADAHALLI2	GUDADAHALLI_220	12:16	13:22	1:06	LINE CLEAR AVAILED
196	10-Jul-19	GULBARGA	220	SHAHPUR-SHAHAPUR1	SHAHAPUR_110,NALWAR_110	16:34	19:40	3:06	LINE FAULT
197	10-Jul-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	1:30	1:36	0:06	LINE FAULT
198	10-Jul-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	5:09	5:13	0:04	LINE FAULT
199	10-Jul-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHAPUR_110	0:00	14:50	14:50	LINE FAULT
200	10-Jul-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	13:10	14:55	1:45	LINE CLEAR AVAILED
201	10-Jul-19	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_10,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS_IPP	6:15	6:20	0:05	LINE FAULT
202	10-Jul-19	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	10:20	10:25	0:05	LINE FAULT
203	10-Jul-19	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:00	11:10	0:10	LINE FAULT
204	10-Jul-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	17:12	18:53	1:41	MAIN SUPPLY FAILURE
205	10-Jul-19	HASSAN	66	HV1	GENDEHALLI_66	15:22	16:32	1:10	LINE CLEAR AVAILED
206	10-Jul-19	HASSAN	66	HV1	HANGARANAHALLY_66	21:23	21:51	0:28	TRANSFORMER FAULT
207	10-Jul-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:15	15:00	2:45	LINE CLEAR AVAILED
208	10-Jul-19	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	11:30	15:16	3:46	LINE CLEAR AVAILED
209	10-Jul-19	MYSORE	66	HV1	MYSORESOUTH_66	3:31	15:36	12:04	TRANSFORMER FAULT
210	10-Jul-19	MYSORE	66	HV2	ELAVALA_66	7:16	7:43	0:26	TRANSFORMER FAULT
211	10-Jul-19	MYSORE	66	HV2	JAKKANAHALLY_66	12:26	13:33	1:07	LINE CLEAR AVAILED
212	10-Jul-19	MYSORE	66	HV1	SANTHEBACHALLI_66	15:00	16:05	1:05	LINE CLEAR AVAILED
213	10-Jul-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	1:12	8:33	7:21	LINE CLEAR AVAILED
214	10-Jul-19	TUMKUR	66	TR-2	BELLAVI_66	9:18	9:47	0:29	LINE CLEAR AVAILED
215	10-Jul-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	16:44	16:52	0:07	LINE CLEAR AVAILED
216	10-Jul-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	22:12	22:35	0:22	LINE FAULT
217	10-Jul-19	TUMKUR	66	CHITRADURGA 66kv- DAVANAGERE2	CHITRADURGA_66	22:11	22:36	0:24	LINE FAULT
218	10-Jul-19	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA	SIRA_66, KALLAMBELLA_66	11:24	14:29	3:04	LINE CLEAR AVAILED
219	10-Jul-19	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	GULIGENAHALLI_66,SIRA_66	11:24	14:28	3:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
220	10-Jul-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	11:19	14:40	3:20	NFBC ISSUED
221	10-Jul-19	TUMKUR	66	TR-1	SIRA_66	11:47	14:44	2:56	NFBC ISSUED
222	10-Jul-19	TUMKUR	66	TR-2	SIRA_66	11:47	14:44	2:56	NFBC ISSUED
223	10-Jul-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	11:28	16:47	5:18	NFBC ISSUED
224	10-Jul-19	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66	11:28	14:30	3:02	NFBC ISSUED
225	10-Jul-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	11:28	16:37	5:09	NFBC ISSUED
226	11-Jul-19	BAGALKOT	110	110/11KV, HV2	ANANDNAGAR_110	11:25	11:43	0:18	LINE CLEAR AVAILED
227	11-Jul-19	BAGALKOT	110	110/11KV, HV2	BHUTHNAL_110	12:43	12:46	0:03	TRANSFORMER FAULT
228	11-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	1:12	16:31	15:19	LINE CLEAR AVAILED
229	11-Jul-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	18:01	23:59	5:58	LINE FAULT
230	11-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	18:01	23:59	5:58	LINE FAULT
231	11-Jul-19	BAGALKOT	110	220/110KV, LV2	BELGAUM_220	1:20	23:59	22:39	LINE CLEAR AVAILED
232	11-Jul-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, WIND1&2_33	17:27	17:50	0:23	TRANSFORMER FAULT
233	11-Jul-19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	1:13	1:26	0:13	LINE FAULT
234	11-Jul-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	22:29	22:53	0:24	LINE FAULT
235	11-Jul-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	23:08	23:31	0:23	LINE FAULT
236	11-Jul-19	BAGALKOT	110	110/11KV, HV1	GADAG_110	10:30	17:49	7:19	LINE CLEAR AVAILED
237	11-Jul-19	BAGALKOT	110	PARIS SUGAR-HALIYAL	HALIYAL_110	15:06	15:41	0:35	LINE FAULT
238	11-Jul-19	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	15:06	15:18	0:12	TRANSFORMER FAULT
239	11-Jul-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGADA_33, KARADI_33, SOLAR_33	3:14	3:17	0:03	TRANSFORMER FAULT
240	11-Jul-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGADA_33, KARADI_33, SOLAR_33	7:50	7:58	0:08	TRANSFORMER FAULT
241	11-Jul-19	BAGALKOT	220	KUDACHI-CHIKKODI 2	KUDACHI_220	1:13	9:35	8:22	LINE FAULT
242	11-Jul-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:06	23:59	23:53	LINE CLEAR AVAILED
243	11-Jul-19	BAGALKOT	220	KUDACHI-MAHALINGAPUR	KUDACHI_220	9:40	18:10	8:30	LINE CLEAR AVAILED
244	11-Jul-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	MAHALINGAPUR_220	17:16	18:04	0:48	LINE CLEAR AVAILED
245	11-Jul-19	BAGALKOT	110	110/33KV,HV3	MUDDEBIHAL_110,NALATWAD_33KV	13:48	13:57	0:09	TRANSFORMER FAULT
246	11-Jul-19	BAGALKOT	110	110/33KV,HV3	MUDDEBIHAL_110,NALATWAD_33KV	17:05	17:26	0:21	TRANSFORMER FAULT
247	11-Jul-19	BAGALKOT	110	110/33KV,HV3	MUDDEBIHAL_110,NALATWAD_33KV	17:43	18:11	0:28	TRANSFORMER FAULT
248	11-Jul-19	BAGALKOT	110	110/33KV,HV3	MUDDEBIHAL_110,NALATWAD_33KV	7:15	7:43	0:28	TRANSFORMER FAULT
249	11-Jul-19	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	MUDALAGI_110	22:56	23:02	0:06	LINE FAULT
250	11-Jul-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	4:48	14:27	9:39	LINE FAULT
251	11-Jul-19	BAGALKOT	220	SHARAVATHI 2-SIRSI	SIRSI_220	10:58	14:27	3:29	LINE CLEAR AVAILED
252	11-Jul-19	BAGALKOT	220	SHARAVATHI 1&2-SIRSI	SIRSI_220	18:11	23:59	5:48	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
253	11-Jul-19	BAGALKOT	220	MAHALINGAPUR 1-VAJRAMATTI	VAJRAMATTI_220	17:17	18:03	0:46	HAND TRIPPED
254	11-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	17:57	20:52	2:55	LINE FAULT
255	11-Jul-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	13:40	13:47	0:06	LINE FAULT
256	11-Jul-19	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	15:15	15:22	0:06	LINE CLEAR AVAILED
257	11-Jul-19	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR	16:19	16:30	0:10	MAIN SUPPLY FAILURE
258	11-Jul-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	16:19	17:08	0:49	LINE FAULT
259	11-Jul-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:19	16:30	0:10	MAIN SUPPLY FAILURE
260	11-Jul-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	16:19	16:37	0:18	MAIN SUPPLY FAILURE
261	11-Jul-19	BENGALURU	66	HV2	THIMMAMPALLI	16:29	18:17	1:48	LINE CLEAR AVAILED
262	11-Jul-19	BENGALURU	66	HV2	MAGADI 220	13:46	13:55	0:08	LINE CLEAR AVAILED
263	11-Jul-19	BENGALURU	66	HV2	MAGADI 220	14:00	14:15	0:15	LINE CLEAR AVAILED
264	11-Jul-19	BENGALURU	66	HV1	TK HALLI 220	16:19	16:31	0:12	MAIN SUPPLY FAILURE
265	11-Jul-19	BENGALURU	220	HV2	TK HALLI 220	16:19	16:29	0:09	TRANSFORMER FAULT
266	11-Jul-19	BENGALURU	220	IV2	TK HALLI 220	16:19	16:29	0:10	TRANSFORMER FAULT
267	11-Jul-19	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	13:33	13:38	0:05	LINE CLEAR AVAILED
268	11-Jul-19	BENGALURU	66	HV2	EPIP 220	5:40	6:40	1:00	TRANSFORMER FAULT
269	11-Jul-19	BENGALURU	66	HV2	EPIP 220	14:18	18:44	4:26	LINE CLEAR AVAILED
270	11-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	18:02	23:59	5:57	LINE FAULT
271	11-Jul-19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	0:00	17:27	17:27	LINE FAULT
272	11-Jul-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	16:00	19:24	3:24	LINE FAULT
273	11-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	10:15	10:50	0:35	LINE CLEAR AVAILED
274	11-Jul-19	GULBARGA	110	HALBARGA-ACMSLR_IPP	HALBARGA_220	3:42	3:52	0:10	LINE FAULT
275	11-Jul-19	GULBARGA	110	HALBARGA-ACMSLR_IPP	HALBARGA_220	11:55	12:04	0:09	LINE FAULT
276	11-Jul-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	8:40	8:50	0:10	LINE FAULT
277	11-Jul-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	17:13	17:20	0:07	LINE FAULT
278	11-Jul-19	GULBARGA	110	GURUGUNTA-LINGASUGUR	GURUGUNTA_110	22:50	23:01	0:11	LINE FAULT
279	11-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	LJVL_IPP	22:50	23:05	0:15	LINE FAULT
280	11-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	KHEL_IPP	22:50	23:59	1:09	LINE FAULT
281	11-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	16:15	17:35	1:20	LINE CLEAR AVAILED
282	11-Jul-19	GULBARGA	110	HV1	KOLHAR_110	18:32	18:42	0:10	TRANSFORMER FAULT
283	11-Jul-19	GULBARGA	110	HV1	KOLHAR_110	12:15	12:25	0:10	LINE CLEAR AVAILED
284	11-Jul-19	GULBARGA	110	HV1	KUDITINI_110	19:14	19:23	0:09	TRANSFORMER FAULT
285	11-Jul-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL	12:20	16:38	4:18	LINE CLEAR AVAILED
286	11-Jul-19	GULBARGA	110	SHAHPUR-SHAHPUR2	SHAHPUR_110	10:50	11:02	0:12	LINE CLEAR AVAILED
287	11-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	1:03	1:25	0:22	LINE FAULT
288	11-Jul-19	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	18:50	18:55	0:05	LINE FAULT
289	11-Jul-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	15:53	17:04	1:11	MAIN SUPPLY FAILURE
290	11-Jul-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	12:40	12:50	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
291	11-Jul-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	15:00	15:12	0:12	LINE FAULT
292	11-Jul-19	GULBARGA	110	MALLAT-BYAGWAT2	MADALAPURA_110	23:37	23:50	0:13	LINE FAULT
293	11-Jul-19	GULBARGA	66	HV1	CHORNOOR_66	14:24	14:30	0:06	TRANSFORMER FAULT
294	11-Jul-19	GULBARGA	66	ITTAGI-HAMPASAGAR	HAMPASAGAR_66	14:52	15:40	0:48	HAND TRIPPED
295	11-Jul-19	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	12:16	12:25	0:09	LINE CLEAR AVAILED
296	11-Jul-19	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	15:15	15:20	0:05	LINE FAULT
297	11-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:49	6:49	LINE CLEAR AVAILED
298	11-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:58	23:59	1:01	LINE CLEAR AVAILED
299	11-Jul-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:19	14:11	1:52	LINE CLEAR AVAILED
300	11-Jul-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	12:20	14:11	1:51	LINE CLEAR AVAILED
301	11-Jul-19	HASSAN	220	HV1	KADUR_220	10:17	12:35	2:18	LINE CLEAR AVAILED
302	11-Jul-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	18:44	19:47	1:03	LINE FAULT
303	11-Jul-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	11:21	11:59	0:38	LINE FAULT
304	11-Jul-19	HASSAN	110	LV1	KADUR_220	10:17	12:35	2:18	LINE CLEAR AVAILED
305	11-Jul-19	HASSAN	110	HV1	NANDIKUR_110	13:03	13:59	0:56	LINE CLEAR AVAILED
306	11-Jul-19	HASSAN	110	HV2	NANDIKUR_110	13:30	14:19	0:49	LINE CLEAR AVAILED
307	11-Jul-19	HASSAN	66	HV1	HANGRANAHALLY_66	14:40	23:59	9:19	TRANSFORMER FAULT
308	11-Jul-19	HASSAN	66	HV1	KANDLI_66	10:47	11:32	0:45	LINE CLEAR AVAILED
309	11-Jul-19	HASSAN	66	HV2	KANDLI_66	11:32	12:14	0:42	LINE CLEAR AVAILED
310	11-Jul-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	13:34	13:45	0:11	LINE FAULT
311	11-Jul-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	14:06	14:48	0:42	LINE FAULT
312	11-Jul-19	HASSAN	66	HV1	SIGEBAGE_66	13:29	14:02	0:33	LINE CLEAR AVAILED
313	11-Jul-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	0:21	0:50	0:29	LINE FAULT
314	11-Jul-19	MYSORE	66	HV1	K_HONNALGERE_66	16:19	16:31	0:12	HAND TRIPPED
315	11-Jul-19	MYSORE	66	HV2	K_HONNALGERE_66	16:19	16:31	0:11	HAND TRIPPED
316	11-Jul-19	MYSORE	66	HV1	KIADBMANDYA_66	16:21	16:34	0:13	HAND TRIPPED
317	11-Jul-19	MYSORE	66	HV2	KIADBMANDYA_66	16:21	16:34	0:13	HAND TRIPPED
318	11-Jul-19	MYSORE	66	HV1	KMDODDI_66	16:20	16:30	0:10	HAND TRIPPED
319	11-Jul-19	MYSORE	66	HV2	KMDODDI_66	16:20	16:30	0:10	HAND TRIPPED
320	11-Jul-19	MYSORE	66	KR PETE 220-SB HALLI	SANTHEBACHALLI_66	6:06	6:19	0:13	LINE FAULT
321	11-Jul-19	MYSORE	66	HV1	SANTHEBACHALLI_66	13:55	14:45	0:50	LINE CLEAR AVAILED
322	11-Jul-19	MYSORE	66	HV1	SANTHEBACHALLI_66	16:35	17:05	0:30	LINE CLEAR AVAILED
323	11-Jul-19	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	19:39	19:40	0:01	HAND TRIPPED
324	11-Jul-19	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	19:39	19:40	0:01	HAND TRIPPED
325	11-Jul-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	18:45	19:39	0:54	HAND TRIPPED
326	11-Jul-19	TUMKUR	66	TR-3(LV SIDE)	ANTHRASANAHALLI_220	18:45	19:39	0:54	LINE FAULT
327	11-Jul-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	16:41	16:48	0:06	TRANSFORMER FAULT
328	11-Jul-19	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	10:00	16:38	6:38	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
329	11-Jul-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	14:11	15:41	1:29	LINE CLEAR AVAILED
330	11-Jul-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	14:08	15:43	1:34	LINE CLEAR AVAILED
331	11-Jul-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66	14:10	15:44	1:33	LINE FAULT
332	11-Jul-19	TUMKUR	66	TR-1	GULIGENAHALLI_66	13:07	15:13	2:06	LINE CLEAR AVAILED
333	11-Jul-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	0:19	0:26	0:06	LINE FAULT
334	11-Jul-19	TUMKUR	66	TR-2	KOLALA_66	12:12	13:15	1:03	LINE CLEAR AVAILED
335	11-Jul-19	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:06	14:01	0:55	LINE CLEAR AVAILED
336	11-Jul-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:43	17:40	8:57	LINE FAULT
337	12-Jul-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	7:13	8:02	0:49	LOAD CURTAILMENT
338	12-Jul-19	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220,KATAGERI_33,GADDIN AKERI_33	6:28	6:34	0:06	LOAD CURTAILMENT
339	12-Jul-19	BAGALKOT	220	ALAMATTI1&2-BAGALKOT	BAGALKOT_220	0:00	15:19	15:19	LINE CLEAR AVAILED
340	12-Jul-19	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	3:50	3:57	0:07	HAND TRIPPED
341	12-Jul-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	0:00	7:02	7:02	LINE CLEAR AVAILED
342	12-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	7:03	7:03	LINE CLEAR AVAILED
343	12-Jul-19	BAGALKOT	110	220/110KV, LV2	BELGAUM_220	0:00	6:24	6:24	LINE CLEAR AVAILED
344	12-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:02	23:59	5:57	LINE FAULT
345	12-Jul-19	BAGALKOT	110	110/11KV,HV-2	HANAGALL_110	6:28	6:36	0:08	LOAD CURTAILMENT
346	12-Jul-19	BAGALKOT	110	KUDACHI-MORAB(TERADAL)	MORAB_110	0:09	0:21	0:12	LINE FAULT
347	12-Jul-19	BAGALKOT	110	110/11KV,HV-1	LAKAMANAHALLI_110	6:27	6:58	0:31	LOAD CURTAILMENT
348	12-Jul-19	BAGALKOT	110	JK CEMENT -VAJRAMATTI	VAJRAMATTI_220	14:51	18:06	3:15	LINE CLEAR AVAILED
349	12-Jul-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33,HALASANGI_33KV	8:16	8:21	0:05	TRANSFORMER FAULT
350	12-Jul-19	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	6:28	6:46	0:18	TRANSFORMER FAULT
351	12-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	18:33	19:18	0:45	HAND TRIPPED
352	12-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	20:35	21:16	0:41	HAND TRIPPED
353	12-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	22:18	23:59	1:41	LINE CLEAR AVAILED
354	12-Jul-19	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	11:34	22:03	10:29	LINE CLEAR AVAILED
355	12-Jul-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	0:00	15:48	15:48	LINE CLEAR AVAILED
356	12-Jul-19	BAGALKOT	220	220/110KV, HV1	SIRSI_220	15:30	17:04	1:34	LINE CLEAR AVAILED
357	12-Jul-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	21:59	22:17	0:18	TRANSFORMER FAULT
358	12-Jul-19	BAGALKOT	110	SATTI-RABKAVI	RABKAVI_110	8:05	11:59	3:54	LINE CLEAR AVAILED
359	12-Jul-19	BAGALKOT	110	RANEBENNUR220-BYADAGI, RATTIHALLI	RANEBENNUR_220,BYADAGI_110, RATTIHALLI_110	6:48	7:15	0:27	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
360	12-Jul-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	15:47	15:51	0:04	TRANSFORMER FAULT
361	12-Jul-19	BAGALKOT	110	110/11KV,HV2	MUNDARGI_110	13:10	19:12	6:02	LINE CLEAR AVAILED
362	12-Jul-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:00	10:31	10:31	LINE CLEAR AVAILED
363	12-Jul-19	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI_220	10:33	16:50	6:17	LINE CLEAR AVAILED
364	12-Jul-19	BAGALKOT	220	220/110KV, HV2&LV2	MK HUBLI_220	16:50	17:43	0:53	LINE CLEAR AVAILED
365	12-Jul-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	23:41	23:59	0:18	HAND TRIPPED
366	12-Jul-19	BAGALKOT	110	MAHALINGAPUR220-DAVLESHWAR	DAVLESHWAR_110	6:45	7:20	0:35	HAND TRIPPED
367	12-Jul-19	BENGALURU	220	HV1	CHINTAMANI 220	10:55	11:58	1:03	LINE CLEAR AVAILED
368	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	11:06	11:13	0:07	LOAD CHANGEOVER
369	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	11:06	11:13	0:07	LOAD CHANGEOVER
370	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	11:06	11:13	0:07	LOAD CHANGEOVER
371	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	11:06	11:13	0:07	LOAD CHANGEOVER
372	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	11:06	11:13	0:07	LOAD CHANGEOVER
373	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	11:06	11:13	0:07	LOAD CHANGEOVER
374	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	11:06	11:13	0:07	LOAD CHANGEOVER
375	12-Jul-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	11:06	11:13	0:07	LOAD CHANGEOVER
376	12-Jul-19	BENGALURU	66	HV1	DEVANAHALLI	7:15	7:20	0:05	TRANSFORMER FAULT
377	12-Jul-19	BENGALURU	66	HV1	DEVANAHALLI	17:28	17:33	0:05	TRANSFORMER FAULT
378	12-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220	MITTEMARI 220	18:05	18:30	0:25	LINE FAULT
379	12-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220	MITTEMARI 220	20:44	20:54	0:10	LINE FAULT
380	12-Jul-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	6:33	7:35	1:01	LOAD CURTAILMENT
381	12-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	5:19	5:34	0:14	LINE FAULT
382	12-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:47	6:05	0:17	LINE FAULT
383	12-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:04	9:11	0:06	LINE FAULT
384	12-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	22:18	23:00	0:41	LOAD CURTAILMENT
385	12-Jul-19	BENGALURU	66	SADLI - JULUPALYA	SADLI, JULUPALYA	18:20	18:25	0:05	LOAD CHANGEOVER
386	12-Jul-19	BENGALURU	66	HV2	THIMMAMPALLI	12:22	18:40	6:18	LINE CLEAR AVAILED
387	12-Jul-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	14:20	14:25	0:05	LOAD CHANGEOVER
388	12-Jul-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	21:56	22:30	0:34	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
389	12-Jul-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	22:35	23:01	0:26	LOAD CURTAILMENT
390	12-Jul-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	22:32	23:01	0:29	LOAD CURTAILMENT
391	12-Jul-19	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	14:26	14:36	0:10	LINE CLEAR AVAILED
392	12-Jul-19	BENGALURU	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	11:31	12:21	0:49	LINE CLEAR AVAILED
393	12-Jul-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	11:46	13:00	1:13	LINE FAULT
394	12-Jul-19	BENGALURU	66	HV2	HEJJALA	11:23	11:45	0:21	TRANSFORMER FAULT
395	12-Jul-19	BENGALURU	220	HV2	HSR LAYOUT 220	17:16	18:02	0:46	TRANSFORMER FAULT
396	12-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	17:16	18:02	0:46	LINE CLEAR AVAILED
397	12-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	17:16	18:02	0:46	LINE CLEAR AVAILED
398	12-Jul-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	20:55	21:50	0:55	LOAD CHANGEOVER
399	12-Jul-19	BENGALURU	66	HV1	SUBRAMANYAPURA 66	8:23	8:30	0:07	TRANSFORMER FAULT
400	12-Jul-19	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	21:55	22:00	0:05	LOAD CHANGEOVER
401	12-Jul-19	BENGALURU	66	ISKON - SUBRAMANYAPURA 66	ISKON	13:00	13:15	0:15	LOAD CHANGEOVER
402	12-Jul-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	21:46	21:50	0:03	LOAD CHANGEOVER
403	12-Jul-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	SUBRAMANYAPURA 66, ISKON	6:56	7:36	0:40	LINE FAULT
404	12-Jul-19	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	6:56	8:10	1:14	MAIN SUPPLY FAILURE
405	12-Jul-19	BENGALURU	66	HV1	YEDMADU	10:55	11:10	0:15	LINE CLEAR AVAILED
406	12-Jul-19	BENGALURU	66	HV2	YEDMADU	11:17	11:45	0:28	LINE CLEAR AVAILED
407	12-Jul-19	BENGALURU	66	YEDMADU - SOMANAHALLI 220	YEDMADU	21:51	22:04	0:13	LOAD CHANGEOVER
408	12-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	0:00	8:00	8:00	LINE FAULT
409	12-Jul-19	GULBARGA	220	HV1	RAICHUR_220	23:28	23:30	0:02	TRANSFORMER FAULT
410	12-Jul-19	GULBARGA	110	SHAHABAD-AFZALPUR	AFZALPUR_110	13:58	14:21	0:23	LINE CLEAR AVAILED
411	12-Jul-19	GULBARGA	110	GURGUNTA-KHEL_IPP	GURUGUNTA_110	10:40	23:59	13:19	LINE CLEAR AVAILED
412	12-Jul-19	GULBARGA	110	GURGUNTA-LJVL_IPP	GURUGUNTA_110	10:40	23:59	13:19	LINE CLEAR AVAILED
413	12-Jul-19	GULBARGA	110	HV1	GABBUR_110	6:25	6:30	0:05	TRANSFORMER FAULT
414	12-Jul-19	GULBARGA	110	HV1	HANUMANAL_110	7:15	9:30	2:15	LINE CLEAR AVAILED
415	12-Jul-19	GULBARGA	110	HV1	HANUMASAGAR_110	6:25	6:30	0:05	LOAD CURTAILMENT
416	12-Jul-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	0:23	0:35	0:12	LINE FAULT
417	12-Jul-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	1:03	1:25	0:22	LINE FAULT
418	12-Jul-19	GULBARGA	110	HV4	YADGIR_110	6:30	6:35	0:05	LOAD CURTAILMENT
419	12-Jul-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	1:10	1:20	0:10	LINE FAULT
420	12-Jul-19	GULBARGA	110	BHALKI-LADHA	LADHA_110	13:25	13:30	0:05	LINE CLEAR AVAILED
421	12-Jul-19	GULBARGA	110	BHALKI-BHALKI SUGUR_IPP	BHALKI_110	20:00	20:30	0:30	LINE FAULT
422	12-Jul-19	GULBARGA	110	BHALKI-MGSSK_IPP	BHALKI_110	20:30	21:30	1:00	LINE FAULT
423	12-Jul-19	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	19:45	19:52	0:07	LINE FAULT
424	12-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	22:10	23:05	0:55	LINE CLEAR AVAILED
425	12-Jul-19	GULBARGA	110	SEDAM-VICAT SAGAR	SEDAM_220	20:10	20:35	0:25	LINE FAULT
426	12-Jul-19	GULBARGA	110	SEDAM-VASAVADATTA	SEDAM_220	20:10	20:40	0:30	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
427	12-Jul-19	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	6:30	7:05	0:35	LINE CLEAR AVAILED
428	12-Jul-19	GULBARGA	110	KUSTAGI-BEVOOR	BEVOOR_110	6:30	7:05	0:35	LINE CLEAR AVAILED
429	12-Jul-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110	6:30	7:05	0:35	LINE CLEAR AVAILED
430	12-Jul-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANDAL_110	6:30	7:05	0:35	LINE CLEAR AVAILED
431	12-Jul-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	6:30	7:05	0:35	LINE CLEAR AVAILED
432	12-Jul-19	GULBARGA	110	HV2	KUSTAGI_220	6:40	7:05	0:25	LINE CLEAR AVAILED
433	12-Jul-19	GULBARGA	66	HV2	CHORNOOR_66	9:00	9:47	0:47	LINE CLEAR AVAILED
434	12-Jul-19	GULBARGA	66	HV1 & HV2	CJHALLI_66	6:25	6:50	0:25	TRANSFORMER FAULT
435	12-Jul-19	GULBARGA	66	HV1 & HV2	KOTTUR_66	12:15	12:55	0:40	LINE CLEAR AVAILED
436	12-Jul-19	GULBARGA	66	HV2	ITTAGI_220	11:25	11:30	0:05	TRANSFORMER FAULT
437	12-Jul-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	21:50	21:51	0:01	LOAD CURTAILMENT
438	12-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	7:56	7:56	LINE CLEAR AVAILED
439	12-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:47	23:59	1:12	LINE CLEAR AVAILED
440	12-Jul-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	0:00	9:44	9:44	NFBC ISSUED
441	12-Jul-19	HASSAN	110	HV1	KEMAR_220	11:45	13:08	1:23	TRANSFORMER FAULT
442	12-Jul-19	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	0:00	9:56	9:56	LINE CLEAR AVAILED
443	12-Jul-19	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	11:26	14:29	3:03	NFBC ISSUED
444	12-Jul-19	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	14:23	14:33	0:10	HAND TRIPPED
445	12-Jul-19	HASSAN	110	HV1	HALADY_110	6:27	6:38	0:11	LOAD CURTAILMENT
446	12-Jul-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	10:12	11:35	1:23	LINE CLEAR AVAILED
447	12-Jul-19	HASSAN	110	HV1	BIRUR_110	6:27	6:37	0:10	LOAD CURTAILMENT
448	12-Jul-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	11:19	13:17	1:58	LINE CLEAR AVAILED
449	12-Jul-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	14:11	14:29	0:18	HAND TRIPPED
450	12-Jul-19	HASSAN	110	HV1	KADUR_220	12:03	12:18	0:15	TRANSFORMER FAULT
451	12-Jul-19	HASSAN	110	KADUR-TNGL	KADUR_220	6:45	6:48	0:03	LOAD CURTAILMENT
452	12-Jul-19	HASSAN	110	HV2	KARAYA_110	10:41	11:48	1:07	LINE CLEAR AVAILED
453	12-Jul-19	HASSAN	110	HV3	KONAJE_110	11:05	12:30	1:25	LINE CLEAR AVAILED
454	12-Jul-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	16:24	23:59	7:35	LINE CLEAR AVAILED
455	12-Jul-19	HASSAN	66	GANGUR-HASSAN	GANGUR_66	9:25	17:26	8:01	MAIN SUPPLY FAILURE
456	12-Jul-19	HASSAN	66	HV1	GANGUR_66	9:25	17:26	8:01	MAIN SUPPLY FAILURE
457	12-Jul-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	22:09	22:15	0:06	LINE FAULT
458	12-Jul-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	6:57	7:49	0:52	LOAD CURTAILMENT
459	12-Jul-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	6:26	6:40	0:14	LOAD CURTAILMENT
460	12-Jul-19	HASSAN	66	HV2	BASAVAGHATTA_66	6:26	6:41	0:15	LOAD CURTAILMENT
461	12-Jul-19	MYSORE	66	HV2	ADDIHALLI_66	6:26	6:33	0:07	LOAD CURTAILMENT
462	12-Jul-19	MYSORE	66	HV1	BGNAGARA_66	6:26	6:30	0:03	LOAD CURTAILMENT
463	12-Jul-19	MYSORE	66	HV1	BGNAGARA_66	16:52	18:01	1:09	LINE CLEAR AVAILED
464	12-Jul-19	MYSORE	66	HV2	BGNAGARA_66	11:50	16:03	4:12	LINE CLEAR AVAILED
465	12-Jul-19	MYSORE	66	HV2	BOOKANAKERE_66	6:26	6:38	0:11	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
466	12-Jul-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66, RAMAPURA_MYS_66	9:48	11:38	1:49	LINE CLEAR AVAILED
467	12-Jul-19	MYSORE	66	CR NAGARA-CHANDAKVADI	CHANDAKAVADI_66	7:01	7:05	0:03	HAND TRIPPED
468	12-Jul-19	MYSORE	66	CR NAGARA-PANNYADAHUNDI	KARYA_66, HEMMARGALA_66, PANDYADAHUNDI_66	7:01	7:08	0:07	HAND TRIPPED
469	12-Jul-19	MYSORE	66	HV2	DODDARAYAPET_66	6:26	6:35	0:08	LOAD CURTAILMENT
470	12-Jul-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	10:50	13:56	3:05	LINE CLEAR AVAILED
471	12-Jul-19	MYSORE	66	HV2	ELAVALA_66	6:26	6:42	0:15	LOAD CURTAILMENT
472	12-Jul-19	MYSORE	66	HV1	GVGUDI_66	13:17	14:44	1:27	LINE CLEAR AVAILED
473	12-Jul-19	MYSORE	66	HV2	GVGUDI_66	14:44	15:45	1:00	LINE CLEAR AVAILED
474	12-Jul-19	MYSORE	66	HV1	KUSHALANAGARA_66	6:26	6:42	0:15	LOAD CURTAILMENT
475	12-Jul-19	MYSORE	66	KUSHALNAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66, KANAGAL_66	6:49	7:01	0:12	HAND TRIPPED
476	12-Jul-19	MYSORE	66	HV1	TARIPURA_66	11:59	14:06	2:06	TRANSFORMER FAULT
477	12-Jul-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	12:20	18:38	6:18	LINE CLEAR AVAILED
478	12-Jul-19	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	7:37	8:08	0:30	LOAD CURTAILMENT
479	12-Jul-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	6:42	7:33	0:50	LOAD CURTAILMENT
480	12-Jul-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	7:37	8:00	0:23	LOAD CURTAILMENT
481	12-Jul-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	6:42	7:32	0:50	LOAD CURTAILMENT
482	12-Jul-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	22:17	22:46	0:29	LOAD CURTAILMENT
483	12-Jul-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	6:36	6:49	0:12	LOAD CURTAILMENT
484	12-Jul-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	11:25	21:36	10:11	LINE FAULT
485	12-Jul-19	TUMKUR	66	TR-1	HIRIYUR_66	20:01	20:18	0:17	TRANSFORMER FAULT
486	12-Jul-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	11:36	11:51	0:15	HAND TRIPPED
487	12-Jul-19	TUMKUR	66	TR-1	RANGANATHAPURA_66	10:36	11:14	0:38	LINE CLEAR AVAILED
488	12-Jul-19	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:27	13:39	0:11	LINE CLEAR AVAILED
489	12-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:16	17:50	7:34	LINE FAULT
490	12-Jul-19	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	21:42	22:19	0:36	LOAD CURTAILMENT
491	12-Jul-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	21:41	22:18	0:37	LOAD CURTAILMENT
492	13-Jul-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	6:48	7:06	0:18	LOAD CURTAILMENT
493	13-Jul-19	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	20:24	23:59	3:35	LOAD CURTAILMENT
494	13-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:25	7:25	LINE CLEAR AVAILED
495	13-Jul-19	BAGALKOT	110	110/11KV,HV-4	BAILHONGAL_110	10:12	17:23	7:11	TRANSFORMER FAULT
496	13-Jul-19	BAGALKOT	110	CHIKKODI220-CHIKKODI110	CHIKKODI_110	15:54	18:08	2:14	LINE CLEAR AVAILED
497	13-Jul-19	BAGALKOT	110	GHATAPRABHA-KABBUR(NAGARMUNVALLI)	KABBUR(NAGAR MUNVALLI)_110	6:59	7:04	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
498	13-Jul-19	BAGALKOT	110	110/33VKV,HV-2	HUNAGUND_110& K.SANAGAM_33,AMINAGAD&KARADI	6:02	6:09	0:07	TRANSFORMER FAULT
499	13-Jul-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	0:00	17:55	17:55	LINE CLEAR AVAILED
500	13-Jul-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	18:29	23:59	5:30	LINE FAULT
501	13-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	0:00	10:41	10:41	LINE CLEAR AVAILED
502	13-Jul-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	10:51	12:34	1:43	LINE CLEAR AVAILED
503	13-Jul-19	BAGALKOT	110	110/11KV,HV2	MUNDARGI_110	9:07	12:59	3:52	LINE CLEAR AVAILED
504	13-Jul-19	BAGALKOT	110	110/33KV,HV3	MUNDARGI_110, SINGATALUR_33	12:59	16:27	3:28	LINE CLEAR AVAILED
505	13-Jul-19	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	6:33	7:16	0:42	LOAD CURTAILMENT
506	13-Jul-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	2:39	2:47	0:07	LINE FAULT
507	13-Jul-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	21:37	21:48	0:10	LINE FAULT
508	13-Jul-19	BENGALURU	220	HV1	DB PURA 220	13:22	13:25	0:03	LOAD CHANGEOVER
509	13-Jul-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	13:22	13:27	0:05	LOAD CHANGEOVER
510	13-Jul-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	13:22	13:27	0:05	LOAD CHANGEOVER
511	13-Jul-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	13:22	13:27	0:05	LOAD CHANGEOVER
512	13-Jul-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:22	13:27	0:05	LOAD CHANGEOVER
513	13-Jul-19	BENGALURU	220	HV1	DB PURA 220	14:23	14:31	0:08	LOAD CHANGEOVER
514	13-Jul-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	14:22	14:34	0:12	LOAD CHANGEOVER
515	13-Jul-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	14:22	14:34	0:12	LOAD CHANGEOVER
516	13-Jul-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	14:22	14:34	0:12	LOAD CHANGEOVER
517	13-Jul-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:22	14:34	0:12	LOAD CHANGEOVER
518	13-Jul-19	BENGALURU	66	HV1	GOWRBIDANUR 220	17:50	18:05	0:15	TRANSFORMER FAULT
519	13-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220	MITTEMARI 220	20:35	23:59	3:24	LINE FAULT
520	13-Jul-19	BENGALURU	66	HV2	HOSUR RAMAPURA	20:00	20:10	0:10	TRANSFORMER FAULT
521	13-Jul-19	BENGALURU	66	HV2	KODIHALLI KANAKAPURA	10:10	11:10	1:00	LINE CLEAR AVAILED
522	13-Jul-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR	6:46	6:49	0:03	LINE FAULT
523	13-Jul-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	6:32	7:16	0:43	LOAD CURTAILMENT
524	13-Jul-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:19	13:25	0:06	LINE FAULT
525	13-Jul-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	12:00	14:25	2:25	LINE FAULT
526	13-Jul-19	BENGALURU	66	KEMBODI - KOLAR 220	KEMBODI	12:00	14:25	2:25	LINE FAULT
527	13-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:08	5:21	0:12	LINE FAULT
528	13-Jul-19	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	12:47	15:15	2:28	LINE CLEAR AVAILED
529	13-Jul-19	BENGALURU	66	HV2	HEJJALA	11:49	11:55	0:05	TRANSFORMER FAULT
530	13-Jul-19	BENGALURU	66	HV2	ISRO LAYOUT	14:24	14:45	0:20	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
531	13-Jul-19	GULBARGA	220	HV2	KUSTAGI_220	11:42	11:52	0:10	TRANSFORMER FAULT
532	13-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	0:00	17:50	17:50	LINE CLEAR AVAILED
533	13-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	0:00	17:50	17:50	LINE CLEAR AVAILED
534	13-Jul-19	GULBARGA	110	HV3	BETAGERA_110	10:45	12:20	1:35	TRANSFORMER FAULT
535	13-Jul-19	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALLI_110, BISIHALLI_110,JANAKI_IPP,BASAI_IPP	6:35	6:40	0:05	LINE FAULT
536	13-Jul-19	GULBARGA	110	HALBARGA-ACMSLR_IPP	HALBARGA_220	11:25	11:31	0:06	LINE FAULT
537	13-Jul-19	GULBARGA	110	HV2	HANUMANAL_110	7:10	9:10	2:00	LINE CLEAR AVAILED
538	13-Jul-19	GULBARGA	110	HV2	KAMPLI_110	13:10	14:36	1:26	LINE CLEAR AVAILED
539	13-Jul-19	GULBARGA	110	HV1,HV2,HV3,HV4	KUSTAGI_220	11:42	12:09	0:27	TRANSFORMER FAULT
540	13-Jul-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	21:05	21:30	0:25	LINE FAULT
541	13-Jul-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	22:36	22:45	0:09	LINE FAULT
542	13-Jul-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	11:41	11:55	0:14	LINE FAULT
543	13-Jul-19	GULBARGA	66	HV2	CHORNOOR_66	12:20	12:45	0:25	LINE CLEAR AVAILED
544	13-Jul-19	GULBARGA	66	ITTAGI-CLNMAX-2	ITTAGI_220	14:30	14:38	0:08	LINE CLEAR AVAILED
545	13-Jul-19	GULBARGA	66	ITTAGI-SUZLON1,2	ITTAGI_220	15:27	15:50	0:23	LINE CLEAR AVAILED
546	13-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:37	23:59	0:22	HAND TRIPPED
547	13-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	9:39	9:39	LINE CLEAR AVAILED
548	13-Jul-19	HASSAN	220	HASSAN22-Shomoga	HASSAN_220	11:23	18:33	7:10	NFBC ISSUED
549	13-Jul-19	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	11:00	18:51	7:51	LINE CLEAR AVAILED
550	13-Jul-19	HASSAN	110	HV2	KULASHEKARA_110	10:30	11:43	1:13	LINE CLEAR AVAILED
551	13-Jul-19	HASSAN	110	HV4	MANIPAL_110	10:41	10:43	0:02	HAND TRIPPED
552	13-Jul-19	HASSAN	110	HV4	MANIPAL_110	12:20	12:23	0:03	HAND TRIPPED
553	13-Jul-19	HASSAN	66	HV2	HNPURA_66	12:13	16:56	4:43	LINE CLEAR AVAILED
554	13-Jul-19	HASSAN	66	HV2	SHANTHIGRAMMA_66	15:15	15:22	0:07	LINE CLEAR AVAILED
555	13-Jul-19	MYSORE	66	KUNTHUR-DR PETE	MUGUR_66, SANTHEMARAHALI_66, THAYURU_66, TNARASIPURA_66	12:16	12:24	0:08	LINE FAULT
556	13-Jul-19	MYSORE	66	HV5	SFCSHIVA_66	9:34	23:59	14:25	LINE CLEAR AVAILED
557	13-Jul-19	MYSORE	66	HV1	TARIPURA_66	10:41	10:59	0:17	LINE CLEAR AVAILED
558	13-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	11:01	11:05	0:04	TRANSFORMER FAULT
559	13-Jul-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	6:12	6:18	0:05	HAND TRIPPED
560	13-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:31	15:21	4:50	LINE FAULT
561	13-Jul-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	GULIGENAHALLI_66,SIRA_66	6:38	7:40	1:01	LOAD CURTAILMENT
562	13-Jul-19	TUMKUR	66	MADHUGIRI-SIRA-2	KALLAMBELLA_66, BUKKAPATNA_66	6:38	7:40	1:01	LOAD CURTAILMENT
563	13-Jul-19	TUMKUR	66	MADHUGIRI-SIRA-2	KALLAMBELLA_66, BUKKAPATNA_66	8:04	8:17	0:13	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
564	14-Jul-19	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	0:00	12:09	12:09	LINE CLEAR AVAILED
565	14-Jul-19	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT_220	19:09	23:59	4:50	LOAD CURTAILMENT
566	14-Jul-19	BAGALKOT	110	110/11KV,HV2	YELLAPHARATTI_110	9:50	10:07	0:17	HAND TRIPPED
567	14-Jul-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	0:00	13:50	13:50	LINE CLEAR AVAILED
568	14-Jul-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:25	15:22	3:57	LINE FAULT
569	14-Jul-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	11:49	12:25	0:36	LINE FAULT
570	14-Jul-19	BAGALKOT	110	MKHUBLI220-BEDI	BEDI_110	14:39	17:09	2:30	LINE CLEAR AVAILED
571	14-Jul-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	18:50	23:59	5:09	LINE CLEAR AVAILED
572	14-Jul-19	BENGALURU	66	HV1	BAIRAKUR	10:45	10:56	0:11	LINE CLEAR AVAILED
573	14-Jul-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:21	15:27	0:05	LINE FAULT
574	14-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220	MITTEMARI 220	0:00	9:10	9:10	LINE FAULT
575	14-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:46	12:07	0:21	LOAD CHANGEOVER
576	14-Jul-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:46	12:09	0:23	LOAD CHANGEOVER
577	14-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	11:46	12:08	0:22	LOAD CHANGEOVER
578	14-Jul-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	11:46	12:06	0:20	LOAD CHANGEOVER
579	14-Jul-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:46	12:10	0:24	LOAD CHANGEOVER
580	14-Jul-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:46	12:04	0:18	LOAD CHANGEOVER
581	14-Jul-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:18	13:32	0:14	LOAD CHANGEOVER
582	14-Jul-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:18	13:32	0:14	LOAD CHANGEOVER
583	14-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	13:18	13:32	0:14	LOAD CHANGEOVER
584	14-Jul-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	13:18	13:32	0:14	LOAD CHANGEOVER
585	14-Jul-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:18	13:32	0:14	LOAD CHANGEOVER
586	14-Jul-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:18	13:32	0:14	LOAD CHANGEOVER
587	14-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220	MITTEMARI 220	18:02	19:02	1:00	LINE FAULT
588	14-Jul-19	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	10:18	11:06	0:48	LINE CLEAR AVAILED
589	14-Jul-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	17:25	17:32	0:07	LOAD CHANGEOVER
590	14-Jul-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:50	23:59	23:09	LINE CLEAR AVAILED
591	14-Jul-19	GULBARGA	220	SEDAM-SHAHPUR	SHAHPUR_220	17:57	23:59	6:02	LINE FAULT
592	14-Jul-19	GULBARGA	110	HALBARGA-ACMSLR_IPP	HALBARGA_220	11:30	11:35	0:05	LINE FAULT
593	14-Jul-19	GULBARGA	110	SINDHANOOR220-PGLRWIND_IPP	SIDHANOOR_220	21:15	21:35	0:20	LINE FAULT
594	14-Jul-19	GULBARGA	110	HV2	RAICHUR_220	21:20	22:21	1:01	TRANSFORMER FAULT
595	14-Jul-19	GULBARGA	110	HV2	KOLHAR_110	17:15	17:25	0:10	TRANSFORMER FAULT
596	14-Jul-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:35	5:45	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
597	14-Jul-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	20:51	21:02	0:11	LINE FAULT
598	14-Jul-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	23:18	23:23	0:05	LINE FAULT
599	14-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:01	7:01	LINE CLEAR AVAILED
600	14-Jul-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:24	13:17	0:53	LINE FAULT
601	14-Jul-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	12:24	13:17	0:53	LINE FAULT
602	14-Jul-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:22	10:46	0:24	LINE FAULT
603	14-Jul-19	HASSAN	110	HV1	NANDIKUR_110	3:10	3:36	0:26	TRANSFORMER FAULT
604	14-Jul-19	HASSAN	110	HV1	NANDIKUR_110	22:31	23:22	0:51	TRANSFORMER FAULT
605	14-Jul-19	HASSAN	66	HV1	RAMPURA_66	13:22	13:27	0:05	LINE CLEAR AVAILED
606	14-Jul-19	HASSAN	66	HV2	RAMPURA_66	12:07	12:45	0:38	LINE CLEAR AVAILED
607	14-Jul-19	MYSORE	66	HV2	BGNAGARA_66	11:35	13:58	2:23	LINE CLEAR AVAILED
608	14-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	10:53	11:07	0:14	TRANSFORMER FAULT
609	15-Jul-19	BAGALKOT	220	PONDA1&2-AMBEWADI	AMBEWADI_220	0:00	16:41	16:41	LINE CLEAR AVAILED
610	15-Jul-19	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT_220	0:00	8:10	8:10	LINE CLEAR AVAILED
611	15-Jul-19	BAGALKOT	110	110/11KV,HV2	ANANDANAGAR_110	0:17	0:26	0:09	TRANSFORMER FAULT
612	15-Jul-19	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	13:40	13:50	0:10	HAND TRIPPED
613	15-Jul-19	BAGALKOT	110	GHATAPRABHA-SHIRAGAON	SHIRAGAON_110	5:45	5:52	0:07	LINE FAULT
614	15-Jul-19	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	12:46	13:41	0:55	LINE CLEAR AVAILED
615	15-Jul-19	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33	15:52	15:55	0:03	HAND TRIPPED
616	15-Jul-19	BAGALKOT	220	220/110HV1,LV1	VAJRAMATTI_220	15:12	17:41	2:29	LINE CLEAR AVAILED
617	15-Jul-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEBENNUR	RENEBENNUR_220	11:32	16:54	5:22	LINE CLEAR AVAILED
618	15-Jul-19	BAGALKOT	220	GUTTUR-RANEBENNUR	RENEBENNUR_220	0:00	11:32	11:32	LINE CLEAR AVAILED
619	15-Jul-19	BAGALKOT	220	GUTTUR-RANEBENNUR	RENEBENNUR_220	16:40	23:59	7:19	LINE CLEAR AVAILED
620	15-Jul-19	BAGALKOT	110	110/11KV,HV2	YELPARHATTI_110	11:48	13:00	1:12	LINE CLEAR AVAILED
621	15-Jul-19	BAGALKOT	110	RANEBENNUR-RATTIHAL(TUMMINAKATTI)	RATTIHAL_110	16:40	16:53	0:13	MAIN SUPPLY FAILURE
622	15-Jul-19	BAGALKOT	110	RANEBENNUR-GUTTAL	GUTTAL_110	16:10	16:54	0:44	HAND TRIPPED
623	15-Jul-19	BAGALKOT	110	RANEBUNNUR-HIREKERUR	HIREKERUR_110	16:10	16:25	0:15	HAND TRIPPED
624	15-Jul-19	BAGALKOT	110	RANEBUNNUR-HONNATTI	HONNATTI_110	16:10	16:54	0:44	HAND TRIPPED
625	15-Jul-19	BAGALKOT	110	110/11KV,HV2	PG HUNASHYAL_110	17:12	17:29	0:17	LINE CLEAR AVAILED
626	15-Jul-19	BAGALKOT	110	220/110,LV1	MK HUBLI_220	0:00	7:05	7:05	LINE CLEAR AVAILED
627	15-Jul-19	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	9:20	9:25	0:04	LOAD CHANGEVER
628	15-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	12:14	12:32	0:17	LOAD CHANGEVER
629	15-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	18:25	18:31	0:06	LOAD CHANGEVER
630	15-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	12:15	12:32	0:16	LOAD CHANGEVER
631	15-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	18:25	18:32	0:06	LOAD CHANGEVER
632	15-Jul-19	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NAGNATHPURA 220	15:30	18:30	3:00	LINE CLEAR AVAILED
633	15-Jul-19	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	10:51	11:18	0:26	LINE FAULT
634	15-Jul-19	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	11:20	18:33	7:13	LINE FAULT
635	15-Jul-19	BENGALURU	66	ADUGODI - HSR LAYOUT 1	AMARJYOTHI	15:30	15:36	0:06	LOAD CHANGEVER
636	15-Jul-19	BENGALURU	66	HV2	KADUGODI	12:45	13:08	0:23	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
637	15-Jul-19	BENGALURU	66	HV2	HEJJALA	10:30	10:45	0:14	TRANSFORMER FAULT
638	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	10:51	11:45	0:53	MAIN SUPPLY FAILURE
639	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	10:51	11:45	0:54	MAIN SUPPLY FAILURE
640	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	10:51	11:45	0:54	MAIN SUPPLY FAILURE
641	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	KORAMANGALA, K & C VALLEY, NAL (EHT)	10:51	11:45	0:54	MAIN SUPPLY FAILURE
642	15-Jul-19	BENGALURU	220	HV1	HSR LAYOUT 220	11:13	11:43	0:30	TRANSFORMER FAULT
643	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	11:54	12:23	0:29	MAIN SUPPLY FAILURE
644	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	11:54	12:23	0:29	MAIN SUPPLY FAILURE
645	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	15:13	15:15	0:02	LOAD CHANGEOVER
646	15-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	15:30	18:32	3:02	MAIN SUPPLY FAILURE
647	15-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S2, BIOCON(EHT)	15:30	18:32	3:02	MAIN SUPPLY FAILURE
648	15-Jul-19	BENGALURU	220	HV1	NAGNATHPURA 220	15:30	18:31	3:01	MAIN SUPPLY FAILURE
649	15-Jul-19	BENGALURU	220	HV2	NAGNATHPURA 220	15:30	18:31	3:01	MAIN SUPPLY FAILURE
650	15-Jul-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	18:58	19:06	0:08	LOAD CHANGEOVER
651	15-Jul-19	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NAGNATHPURA 220	15:30	18:31	3:01	LINE CLEAR AVAILED
652	15-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	18:48	18:52	0:04	LOAD CHANGEOVER
653	15-Jul-19	BENGALURU	66	SADALI - CHINTAMANI 220	SADALI, JULUPALYA	11:00	11:01	0:01	LOAD CHANGEOVER
654	15-Jul-19	BENGALURU	66	JULUPALYA - MITTEMARI 220	SADALI, JULUPALYA	17:35	17:36	0:01	LOAD CHANGEOVER
655	15-Jul-19	BENGALURU	66	KEMBODI - KOLAR 220	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI, KEMBODI	17:02	17:18	0:15	LINE CLEAR AVAILED
656	15-Jul-19	GULBARGA	400	BTPS-RTPS	BTPS_400	4:06	12:57	8:51	LINE FAULT
657	15-Jul-19	GULBARGA	220	SEDAM-SHAHPUR	SHAHPUR_220	0:00	15:30	15:30	LINE CLEAR AVAILED
658	15-Jul-19	GULBARGA	220	ITTAGGI-NEELANGUNDA	NEELANGUNDA_220	14:25	16:46	2:21	LINE CLEAR AVAILED
659	15-Jul-19	GULBARGA	220	ITTAGGI-BMM ISPAT	BMM ISPAT_IPP	11:20	14:05	2:45	LINE CLEAR AVAILED
660	15-Jul-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:00	15:53	15:53	LINE CLEAR AVAILED
661	15-Jul-19	GULBARGA	220	SEDAM-SHAHPUR	SHAHPUR_220	0:00	15:30	15:30	LINE FAULT
662	15-Jul-19	GULBARGA	110	HV3	BEVOOR_110	8:20	8:30	0:10	TRANSFORMER FAULT
663	15-Jul-19	GULBARGA	110	HV3	BEVOOR_110	12:07	12:09	0:02	TRANSFORMER FAULT
664	15-Jul-19	GULBARGA	110	HV1	HANUMANAL_110	7:35	8:15	0:40	LINE CLEAR AVAILED
665	15-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	4:59	5:17	0:18	LINE FAULT
666	15-Jul-19	GULBARGA	110	HALBARGA1&2-KOLHAR	KOLHAR_110	10:20	12:30	2:10	LINE CLEAR AVAILED
667	15-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	10:25	12:20	1:55	LINE CLEAR AVAILED
668	15-Jul-19	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110	4:30	5:00	0:30	LINE FAULT
669	15-Jul-19	GULBARGA	110	SHAHAPUR-WARDHASLR_IPP	SHAHAPUR_220	15:58	16:15	0:17	LINE FAULT
670	15-Jul-19	GULBARGA	66	ITTAGGI-CLN MAX1,2	ITTAGI_220	11:15	11:22	0:07	LINE CLEAR AVAILED
671	15-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:01	6:47	4:46	LINE CLEAR AVAILED
672	15-Jul-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	11:13	16:15	5:02	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
673	15-Jul-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	20:27	21:06	0:39	LINE CLEAR AVAILED
674	15-Jul-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:14	16:14	5:00	LINE CLEAR AVAILED
675	15-Jul-19	HASSAN	220	VARAH1-KEMAR3	varahi_gen	9:16	9:25	0:09	LINE FAULT
676	15-Jul-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	20:27	21:06	0:39	LINE CLEAR AVAILED
677	15-Jul-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	3:59	4:09	0:10	LINE FAULT
678	15-Jul-19	HASSAN	110	HV1	KITTADA	11:22	12:16	0:54	LINE CLEAR AVAILED
679	15-Jul-19	HASSAN	110	HV2	PUTUR110	9:43	11:28	1:45	LINE CLEAR AVAILED
680	15-Jul-19	HASSAN	66	HASSN220-BELUR	HASSAN_220	13:36	13:45	0:09	LINE FAULT
681	15-Jul-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:22	12:32	1:10	LINE CLEAR AVAILED
682	15-Jul-19	HASSAN	66	HNPR2-HNPR2	MOSALEHOSAHALLY_66	11:24	12:44	1:20	MAIN SUPPLY FAILURE
683	15-Jul-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	11:24	12:44	1:20	MAIN SUPPLY FAILURE
684	15-Jul-19	MYSORE	66	HV3	KRPET_66	12:50	13:17	0:27	LINE CLEAR AVAILED
685	15-Jul-19	MYSORE	66	SFC SIVA-MEGHALAPURA	CHIDRAVALLI_66, THUMBLA_66	10:55	11:05	0:10	LINE FAULT
686	15-Jul-19	MYSORE	66	HV1	THALAKADU_66	16:15	16:30	0:15	LINE CLEAR AVAILED
687	15-Jul-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	17:31	18:19	0:48	LINE FAULT
688	15-Jul-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	17:31	18:30	0:59	LINE FAULT
689	15-Jul-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:14	10:20	0:06	HAND TRIPPED
690	15-Jul-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:13	10:20	0:06	HAND TRIPPED
691	15-Jul-19	TUMKUR	66	TR-2	HOSADURGA_66	7:20	7:31	0:10	TRANSFORMER FAULT
692	15-Jul-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	17:03	19:20	2:17	LINE FAULT
693	15-Jul-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	10:22	18:06	7:43	LINE FAULT
694	15-Jul-19	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	18:47	22:34	3:47	LINE CLEAR AVAILED
695	15-Jul-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:55	16:58	8:03	LINE FAULT
696	15-Jul-19	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	GULIGENAHALLI_66,SIRA_66	13:02	13:04	0:01	LINE CLEAR AVAILED
697	15-Jul-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	12:52	12:57	0:05	HAND TRIPPED