

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 26.02.2019 to 04.03.2019

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	26-Feb-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	19:11	19:16	0:05	LOAD CURTAILMENT
2	26-Feb-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	20:02	20:30	0:28	LOAD CURTAILMENT
3	26-Feb-19	BAGALKOT	110	110/11KV,HV2	AINAPU_110	19:11	19:14	0:03	LOAD CURTAILMENT
4	26-Feb-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	19:02	19:16	0:14	LOAD CURTAILMENT
5	26-Feb-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	20:02	20:15	0:13	LOAD CURTAILMENT
6	26-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	0:00	1:23	1:23	LINE CLEAR AVAILED
7	26-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	0:00	1:25	1:25	LINE CLEAR AVAILED
8	26-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	1:49	12:33	10:44	LINE FAULT
9	26-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	1:49	1:50	0:01	LINE FAULT
10	26-Feb-19	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	1:49	1:51	0:02	LINE FAULT
11	26-Feb-19	BAGALKOT	110	BAGALKOT220-KATARKI	KATARKI_110	1:49	1:50	0:01	LINE FAULT
12	26-Feb-19	BAGALKOT	220	220/110KV,HV1&LVI	BIDNAL_220	10:51	17:39	6:48	LINE CLEAR AVAILED
13	26-Feb-19	BAGALKOT	110	HUBLI2-BIDNAL	BIDNAL_220	0:00	10:51	10:51	LINE CLEAR AVAILED
14	26-Feb-19	BAGALKOT	110	HUBLI2-BIDNAL	BIDNAL_220	17:41	23:59	6:18	LINE CLEAR AVAILED
15	26-Feb-19	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	DAMBAL_110	9:50	14:13	4:23	LINE CLEAR AVAILED
16	26-Feb-19	BAGALKOT	110	GADAG1-DAMBAL	DAMBAL_110	9:45	14:24	4:39	LINE CLEAR AVAILED
17	26-Feb-19	BAGALKOT	110	DAMBAL-EISL	DAMBAL_110	9:20	14:43	5:23	LINE CLEAR AVAILED
18	26-Feb-19	BAGALKOT	110	110/11KV.HV1	DAMBAL_110	9:25	14:49	5:24	LINE CLEAR AVAILED
19	26-Feb-19	BAGALKOT	110	110/33KV.HV2	DAMBAL_110,WATER SUPPLY_33	9:25	14:50	5:25	LINE CLEAR AVAILED
20	26-Feb-19	BAGALKOT	110	GADAG-DAMBAL 2	SMABAPUR ROAD_110	9:34	14:09	4:35	NFBC ISSUED
21	26-Feb-19	BAGALKOT	110	220/110KV,LV2	GADAG_220	11:46	12:07	0:21	TRANSFORMER FAULT
22	26-Feb-19	BAGALKOT	110	110/11KV,HV-4	GAJENDRAGAD_110	19:10	19:25	0:15	LOAD CURTAILMENT
23	26-Feb-19	BAGALKOT	110	110/11KV,HV-4	GAJENDRAGAD_110	20:02	20:25	0:23	LOAD CURTAILMENT
24	26-Feb-19	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	2:31	2:50	0:19	LINE FAULT
25	26-Feb-19	BAGALKOT	110	11/33KV,HV-1	HANAGALL_110 & PALA_33, BOMMANAHALLI_33	19:05	19:11	0:06	TRANSFORMER FAULT
26	26-Feb-19	BAGALKOT	110	11/33KV,HV-1	HANAGALL_110 & PALA_33, BOMMANAHALLI_33	20:02	20:09	0:07	LOAD CURTAILMENT
27	26-Feb-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110	4:14	4:55	0:41	TRANSFORMER FAULT
28	26-Feb-19	BAGALKOT	110	KUDACHI220-YELLAPARHATTI	YELLAPARHATTI_110	10:58	14:51	3:53	LINE CLEAR AVAILED
29	26-Feb-19	BAGALKOT	110	110/11KV,HV1	YELLAPARHATTI_110	10:58	14:51	3:53	LINE CLEAR AVAILED
30	26-Feb-19	BAGALKOT	110	110/11KV,HV2	YELLAPARHATTI_110	10:58	14:51	3:53	LINE CLEAR AVAILED
31	26-Feb-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	16:26	20:10	3:44	LINE CLEAR AVAILED
32	26-Feb-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	18:04	18:44	0:40	LINE CLEAR AVAILED
33	26-Feb-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	17:06	18:02	0:56	LINE CLEAR AVAILED
34	26-Feb-19	BAGALKOT	110	110/11KV,HV3	SOUDATTI_110	10:35	12:06	1:31	LINE CLEAR AVAILED
35	26-Feb-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	17:54	19:16	1:22	LINE FAULT
36	26-Feb-19	BAGALKOT	110	110/11KV,HV1	NAVALGUND_110	10:25	13:39	3:14	LINE CLEAR AVAILED
37	26-Feb-19	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	10:25	15:41	5:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
38	26-Feb-19	BAGALKOT	110	BIO DHARWAD-NAVALGUND	NAVALGUND_110	13:39	15:42	2:03	LINE CLEAR AVAILED
39	26-Feb-19	BAGALKOT	110	KONNUR-NAVALGUND	NAVALGUND_110	10:25	13:39	3:14	LINE CLEAR AVAILED
40	26-Feb-19	BAGALKOT	110	110/11KV,HV1	NANADI_110	13:20	17:03	3:43	LINE CLEAR AVAILED
41	26-Feb-19	BAGALKOT	110	110/11KV,HV2	NANADI_110	10:10	17:06	6:56	LINE CLEAR AVAILED
42	26-Feb-19	BAGALKOT	110	DAMBAL-MUNDARGI	MUNDARGI_110	14:49	14:55	0:06	LINE CLEAR AVAILED
43	26-Feb-19	BAGALKOT	110	VIJAYA NAGAR SUGARS-MUNDARGI	MUNDARGI_110	14:49	14:55	0:06	LINE CLEAR AVAILED
44	26-Feb-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	21:52	22:01	0:09	TRANSFORMER FAULT
45	26-Feb-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_110	17:50	18:00	0:10	TRANSFORMER FAULT
46	26-Feb-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	MAHALINGAPUR_110	17:56	18:04	0:08	HAND TRIPPED
47	26-Feb-19	BAGALKOT	110	MACHE-ASHOK IRON PLANT	MACHE_110	17:17	23:05	5:48	LINE CLEAR AVAILED
48	26-Feb-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	19:11	19:23	0:12	LOAD CURTAILMENT
49	26-Feb-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	20:02	20:15	0:13	LOAD CURTAILMENT
50	26-Feb-19	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	19:10	19:15	0:05	LOAD CURTAILMENT
51	26-Feb-19	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	20:02	20:10	0:08	LOAD CURTAILMENT
52	26-Feb-19	BAGALKOT	110	110/11KV, HV1	KALGHATAGI_110	22:26	22:49	0:23	TRANSFORMER FAULT
53	26-Feb-19	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66, AREMALLAPUR_33	19:10	19:28	0:18	LOAD CURTAILMENT
54	26-Feb-19	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66, AREMALLAPUR_33	20:01	20:42	0:41	LOAD CURTAILMENT
55	26-Feb-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	10:06	16:56	6:50	LINE CLEAR AVAILED
56	26-Feb-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	17:06	18:37	1:31	LINE CLEAR AVAILED
57	26-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110, KOLIGUDDA_33	19:12	19:19	0:07	LOAD CURTAILMENT
58	26-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110, KOLIGUDDA_33	20:02	20:15	0:13	LOAD CURTAILMENT
59	26-Feb-19	BENGALORE	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:24	11:28	0:04	LOAD CHANGEOVER
60	26-Feb-19	BENGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	22:20	22:25	0:05	LOAD CHANGEOVER
61	26-Feb-19	BENGALORE	66	HV3	ELECTRONIC CITY	9:36	22:06	12:30	TRANSFORMER FAULT
62	26-Feb-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	12:02	12:16	0:13	LINE FAULT
63	26-Feb-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	12:48	12:53	0:05	LINE FAULT
64	26-Feb-19	BENGALORE	66	HV2	KADUBISANAHALLI	12:46	13:56	1:10	TRANSFORMER FAULT
65	26-Feb-19	BENGALORE	66	HV2	MEI LAYOUT	9:23	9:29	0:06	LINE CLEAR AVAILED
66	26-Feb-19	BENGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	12:19	12:36	0:17	LINE FAULT
67	26-Feb-19	BENGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	12:27	12:32	0:05	LINE FAULT
68	26-Feb-19	BENGALORE	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	5:40	5:45	0:05	LOAD CHANGEOVER
69	26-Feb-19	BENGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	6:07	6:13	0:06	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
70	26-Feb-19	BENGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	6:05	6:15	0:10	LOAD CHANGEOVER
71	26-Feb-19	BENGALORE	66	DALASANUR - MALLASANDRA	DALASNUR, YELDUR	4:58	5:14	0:16	LINE FAULT
72	26-Feb-19	BENGALORE	66	HV1	D PALYA	11:34	11:38	0:03	LINE CLEAR AVAILED
73	26-Feb-19	BENGALORE	66	HV2	HONNIGANAHALLI	1:36	1:38	0:02	TRANSFORMER FAULT
74	26-Feb-19	BENGALORE	66	HV2	HONNIGANAHALLI	1:38	1:55	0:16	TRANSFORMER FAULT
75	26-Feb-19	BENGALORE	66	HV1	HONNIGANAHALLI	7:45	14:50	7:05	TRANSFORMER FAULT
76	26-Feb-19	BENGALORE	66	HV1	HONNIGANAHALLI	18:20	18:25	0:05	LINE CLEAR AVAILED
77	26-Feb-19	BENGALORE	66	HV3	BANGARPET	14:55	17:00	2:05	LINE CLEAR AVAILED
78	26-Feb-19	BENGALORE	66	HV1	BANGARPET	12:13	14:05	1:52	LINE CLEAR AVAILED
79	26-Feb-19	BENGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:40	11:50	1:10	LOAD CURTAILMENT
80	26-Feb-19	BENGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	10:40	11:50	1:10	LOAD CURTAILMENT
81	26-Feb-19	BENGALORE	66	HV2	SUGUTUR	13:20	13:29	0:08	LINE CLEAR AVAILED
82	26-Feb-19	BENGALORE	66	HV2	TEMAGONDALU	17:37	19:15	1:37	LINE CLEAR AVAILED
83	26-Feb-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:01	9:20	0:19	LINE FAULT
84	26-Feb-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:24	22:35	0:11	LINE FAULT
85	26-Feb-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	23:10	23:22	0:12	LINE FAULT
86	26-Feb-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	23:58	23:59	0:01	LINE FAULT
87	26-Feb-19	GULBARGA	220	SHAHPUR-RTPS1	SHAHPUR_220	8:50	11:55	3:05	LINE CLEAR AVAILED
88	26-Feb-19	GULBARGA	220	HV2	KUSTAGI_220	13:02	13:38	0:36	TRANSFORMER FAULT
89	26-Feb-19	GULBARGA	220	LINGAPUR-JVSL-1	JVSWL_220	11:48	18:51	7:03	LINE CLEAR AVAILED
90	26-Feb-19	GULBARGA	220	LINGASUGUR-BAGEWADI2(IDLE LINE)	LINGASUGUR_220	11:02	18:18	7:16	NFBC ISSUED
91	26-Feb-19	GULBARGA	220	HV2	KUSTAGI_220	13:05	13:36	0:31	TRANSFORMER FAULT
92	26-Feb-19	GULBARGA	110	BETAGERA-KSHVCMNT	BETAGERA_110	16:25	16:36	0:11	LINE FAULT
93	26-Feb-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	4:07	4:14	0:07	LINE FAULT
94	26-Feb-19	GULBARGA	110	KUSHTAGI-ILKAL1,2	ILKAL_110	13:02	13:55	0:53	LINE FAULT
95	26-Feb-19	GULBARGA	110	HV2	SRERAMANAGAR_110	20:25	20:50	0:25	TRANSFORMER FAULT
96	26-Feb-19	GULBARGA	110	HV4	YELBURGA_110	19:10	19:30	0:20	LOAD CURTAILMENT
97	26-Feb-19	GULBARGA	110	HV2	YADGIR_110	19:10	19:15	0:05	LOAD CURTAILMENT
98	26-Feb-19	GULBARGA	110	HV1,HV2	YADGIR_110	19:20	19:45	0:25	LOAD CURTAILMENT
99	26-Feb-19	GULBARGA	110	HV1,HV2	YADGIR_110	20:05	20:35	0:30	LOAD CURTAILMENT
100	26-Feb-19	GULBARGA	110	HV2	RAJESHWAR_110	19:20	19:30	0:10	LOAD CURTAILMENT
101	26-Feb-19	GULBARGA	110	HV1	RAJESHWAR_110	19:20	19:40	0:20	LOAD CURTAILMENT
102	26-Feb-19	GULBARGA	110	HV2	RAJESHWAR_110	20:05	20:15	0:10	LOAD CURTAILMENT
103	26-Feb-19	GULBARGA	110	HV1	RAJESHWAR_110	20:05	20:25	0:20	LOAD CURTAILMENT
104	26-Feb-19	GULBARGA	110	HV1	RAICHUR_220	15:45	23:59	8:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
105	26-Feb-19	GULBARGA	110	HV1	KURKUNTA_110	19:05	19:45	0:40	TRANSFORMER FAULT
106	26-Feb-19	GULBARGA	110	HV1	KURKUNTA_110	19:57	23:59	4:02	TRANSFORMER FAULT
107	26-Feb-19	GULBARGA	110	HV2	KOLHAR_110	19:25	19:30	0:05	LOAD CURTAILMENT
108	26-Feb-19	GULBARGA	110	HV2	KOLHAR_110	20:00	20:15	0:15	LOAD CURTAILMENT
109	26-Feb-19	GULBARGA	110	HV1	KEMBHAVI_110	19:20	19:25	0:05	LOAD CURTAILMENT
110	26-Feb-19	GULBARGA	110	HV2	HATTI_110	19:20	19:25	0:05	LOAD CURTAILMENT
111	26-Feb-19	GULBARGA	110	HV2	HATTI_110	20:00	20:05	0:05	LOAD CURTAILMENT
112	26-Feb-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	13:05	13:57	0:52	LINE FAULT
113	26-Feb-19	GULBARGA	110	HV1	ALAND_110	12:15	13:40	1:25	LINE CLEAR AVAILED
114	26-Feb-19	GULBARGA	110	HV2	ALAND_110	12:15	17:00	4:45	LINE CLEAR AVAILED
115	26-Feb-19	GULBARGA	110	HV2	ALAND_110	19:20	19:50	0:30	LOAD CURTAILMENT
116	26-Feb-19	GULBARGA	66	HV1	SOVENAHALLI_66	10:30	12:00	1:30	LINE CLEAR AVAILED
117	26-Feb-19	GULBARGA	66	HV1	SOVENAHALLI_66	19:20	19:25	0:05	LOAD CURTAILMENT
118	26-Feb-19	GULBARGA	66	HV1	SOVENAHALLI_66	20:00	20:05	0:05	LOAD CURTAILMENT
119	26-Feb-19	HASSAN	220	HASSN22-CHIKMANGLUR	HASSN_220	17:27	23:59	6:32	LINE FAULT
120	26-Feb-19	HASSAN	220	HV1	KEMAR_220	10:39	19:19	8:40	LINE CLEAR AVAILED
121	26-Feb-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	4:11	11:42	7:31	LINE FAULT
122	26-Feb-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	9:41	16:10	6:29	NFBC ISSUED
123	26-Feb-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	9:40	14:00	4:20	NFBC ISSUED
124	26-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATI_110	13:13	13:30	0:17	LINE CLEAR AVAILED
125	26-Feb-19	HASSAN	110	HV1	BIRUR_110	10:06	20:01	9:55	MAIN SUPPLY FAILURE
126	26-Feb-19	HASSAN	110	HV2	BIRUR_110	19:15	19:20	0:05	MAIN SUPPLY FAILURE
127	26-Feb-19	HASSAN	110	HV1	HALADY_110	19:14	19:26	0:12	MAIN SUPPLY FAILURE
128	26-Feb-19	HASSAN	110	HV1	HALADY_110	10:01	20:44	10:43	MAIN SUPPLY FAILURE
129	26-Feb-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:20	16:15	5:55	LINE CLEAR AVAILED
130	26-Feb-19	HASSAN	110	HV1	KUNDAPURA_110	10:13	16:40	6:27	LOAD CURTAILMENT
131	26-Feb-19	HASSAN	110	HV2	KUNDAPURA_110	10:13	16:40	6:27	LOAD CURTAILMENT
132	26-Feb-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:40	14:04	4:24	LINE CLEAR AVAILED
133	26-Feb-19	HASSAN	110	MANNIPAL-HIRIYADKA	MANIPAL_110	9:40	14:04	4:24	LINE CLEAR AVAILED
134	26-Feb-19	HASSAN	110	HV1	MANIPAL_110	9:40	14:04	4:24	LINE CLEAR AVAILED
135	26-Feb-19	HASSAN	110	HV3	MANIPAL_110	9:40	14:04	4:24	LINE CLEAR AVAILED
136	26-Feb-19	HASSAN	110	HV4	MANIPAL_110	9:40	14:04	4:24	LINE CLEAR AVAILED
137	26-Feb-19	HASSAN	110	KMANIPAL-EMAR1	MANIPAL_110	9:40	16:10	6:30	LINE CLEAR AVAILED
138	26-Feb-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	9:40	14:04	4:24	LINE CLEAR AVAILED
139	26-Feb-19	HASSAN	110	MOODAB-KEMAR	MOODABDRE_110	16:04	18:45	2:41	LINE CLEAR AVAILED
140	26-Feb-19	HASSAN	110	HV1	NAVUNDA_110	10:13	16:40	6:27	LOAD CURTAILMENT
141	26-Feb-19	HASSAN	110	HV2	NAVUNDA_110	16:12	16:31	0:19	LOAD CURTAILMENT
142	26-Feb-19	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	16:09	16:12	0:03	LOAD CURTAILMENT
143	26-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:59	18:52	6:53	LINE CLEAR AVAILED
144	26-Feb-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:45	18:50	11:05	LOAD CURTAILMENT
145	26-Feb-19	HASSAN	66	HV2	BELUR_66	0:55	1:05	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
146	26-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMANGLUR_66	7:41	18:48	11:07	LINE CLEAR AVAILED
147	26-Feb-19	HASSAN	66	HV1	HARIHARPURA_66	17:45	17:55	0:10	LOAD CURTAILMENT
148	26-Feb-19	HASSAN	66	HNPR2-CRP	HNPURA_220	17:45	17:50	0:05	LINE FAULT
149	26-Feb-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	0:00	1:35	1:35	LINE FAULT
150	26-Feb-19	MYSORE	66	HV1	BOOKANAKERE_66	17:02	17:39	0:37	LINE CLEAR AVAILED
151	26-Feb-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	13:54	23:59	10:04	LINE FAULT
152	26-Feb-19	MYSORE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 THUMLA_66	15:26	15:36	0:10	LINE FAULT
153	26-Feb-19	MYSORE	66	HV1	HUNSUR_66	10:00	17:48	7:48	LINE CLEAR AVAILED
154	26-Feb-19	MYSORE	66	HV2	HUNSUR_66	10:00	17:48	7:48	LINE CLEAR AVAILED
155	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	9:34	9:39	0:05	TRANSFORMER FAULT
156	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	12:49	12:58	0:09	TRANSFORMER FAULT
157	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	13:00	13:07	0:06	TRANSFORMER FAULT
158	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	13:58	13:59	0:01	TRANSFORMER FAULT
159	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	14:51	14:53	0:01	TRANSFORMER FAULT
160	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	15:30	15:34	0:04	TRANSFORMER FAULT
161	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	15:35	15:37	0:01	TRANSFORMER FAULT
162	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	15:37	15:41	0:03	TRANSFORMER FAULT
163	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	16:09	16:18	0:08	TRANSFORMER FAULT
164	26-Feb-19	MYSORE	66	HV1	KADAKOLA_220	21:33	21:38	0:05	TRANSFORMER FAULT
165	26-Feb-19	MYSORE	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66, HAMPAPURA_66 KOPPA_66, BESAGARAHALLI_66, DUNDANAHALLI_66	2:23	2:34	0:11	LINE FAULT
166	26-Feb-19	MYSORE	66	HV2	NAGAMANGALA_66	12:10	13:43	1:32	LINE CLEAR AVAILED
167	26-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	20:20	23:59	3:39	LINE CLEAR AVAILED
168	26-Feb-19	MYSORE	66	HV2	TUBINAKERE_220	13:16	13:19	0:02	LOAD CHANGEOVER
169	26-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	17:06	18:37	1:30	LINE CLEAR AVAILED
170	26-Feb-19	TUMKUR	110	TR-1	TURUVEKERE_110	2:00	2:13	0:12	HAND TRIPPED
171	26-Feb-19	TUMKUR	110	TR-1	TURUVEKERE_110	13:16	14:35	1:19	LINE CLEAR AVAILED
172	26-Feb-19	TUMKUR	110	TR-1	GUBBI_110	8:10	8:14	0:03	TRANSFORMER FAULT
173	26-Feb-19	TUMKUR	110	TR-1	GUBBI_110	22:00	22:06	0:05	TRANSFORMER FAULT
174	26-Feb-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHLI)	CHANNAGIRI_66	8:05	8:19	0:14	HAND TRIPPED
175	26-Feb-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	11:50	12:01	0:10	LINE FAULT
176	26-Feb-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	12:02	15:56	3:54	LINE CLEAR AVAILED
177	26-Feb-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:46	15:04	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
178	26-Feb-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	0:53	1:07	0:13	LINE FAULT
179	26-Feb-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	9:40	9:43	0:03	LINE FAULT
180	26-Feb-19	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	3:20	3:36	0:15	HAND TRIPPED
181	26-Feb-19	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	12:44	13:20	0:36	HAND TRIPPED
182	26-Feb-19	TUMKUR	66	TR-2	HULIYURDURGA_66	3:35	4:10	0:35	HAND TRIPPED
183	26-Feb-19	TUMKUR	66	TR-1	KATTIGE_66	6:07	6:14	0:06	TRANSFORMER FAULT
184	26-Feb-19	TUMKUR	66	TR-1	KATTIGE_66	16:58	17:09	0:10	TRANSFORMER FAULT
185	26-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:02	0:07	0:04	HAND TRIPPED
186	26-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:35	12:43	0:08	HAND TRIPPED
187	26-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:02	22:46	1:43	LINE FAULT
188	26-Feb-19	TUMKUR	66	TR-1	LINGADAHALLY_66	21:06	21:11	0:05	TRANSFORMER FAULT
189	26-Feb-19	TUMKUR	66	TR-1	LINGADAHALLY_66	21:42	21:49	0:07	TRANSFORMER FAULT
190	26-Feb-19	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	14:10	15:57	1:46	LINE CLEAR AVAILED
191	26-Feb-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	18:04	18:08	0:03	TRANSFORMER FAULT
192	26-Feb-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	12:02	15:57	3:54	LINE CLEAR AVAILED
193	26-Feb-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	11:43	15:57	4:14	MAIN SUPPLY FAILURE
194	27-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	10:40	17:44	7:04	LINE CLEAR AVAILED
195	27-Feb-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	10:40	14:10	3:30	LINE CLEAR AVAILED
196	27-Feb-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	0:00	10:19	10:19	LINE CLEAR AVAILED
197	27-Feb-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	14:56	23:59	9:03	LINE CLEAR AVAILED
198	27-Feb-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	8:05	8:19	0:14	TRANSFORMER FAULT
199	27-Feb-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	8:39	8:45	0:06	TRANSFORMER FAULT
200	27-Feb-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	10:25	12:21	1:56	LINE CLEAR AVAILED
201	27-Feb-19	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	4:15	4:36	0:21	LINE FAULT
202	27-Feb-19	BAGALKOT	110	HUBLI 220-P H COMPOUND	P H COMPOUND_110	8:18	23:59	15:41	LINE CLEAR AVAILED
203	27-Feb-19	BAGALKOT	110	BIDNAL220-P H COMPOUND	P H COMPOUND_110	0:00	7:58	7:58	NFBC ISSUED
204	27-Feb-19	BAGALKOT	110	110/11KV,HV1	NANADI_110	11:23	11:36	0:13	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
205	27-Feb-19	BAGALKOT	110	220/110KV, LV3	MAHALINGAPUR_220, ITNAL_110, HIDIKAL_110	12:44	13:00	0:16	TRANSFORMER FAULT
206	27-Feb-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	12:50	13:10	0:20	LINE CLEAR AVAILED
207	27-Feb-19	BENGALORE	66	AKKURMOLE - TK HALLI	AKKURMOLE, IGGALURU	18:51	19:01	0:09	LINE FAULT
208	27-Feb-19	BENGALORE	66	HV1	CHAKAVELU	12:27	12:34	0:07	TRANSFORMER FAULT
209	27-Feb-19	BENGALORE	66	DALASNUR - SRINIVASPURA	YELDUR	15:07	15:45	0:38	LINE CLEAR AVAILED
210	27-Feb-19	BENGALORE	66	HV1	D CROSS	8:24	8:30	0:06	TRANSFORMER FAULT
211	27-Feb-19	BENGALORE	66	HV1	GOWRIBIDANUR 220	22:58	23:05	0:07	TRANSFORMER FAULT
212	27-Feb-19	BENGALORE	66	KEMBODI - KOLAR 220	KEMBODI, MUDIYANUR, H GOLLAHALLI, NANGALI, BAIRAKUR	6:08	11:49	5:41	LINE FAULT
213	27-Feb-19	BENGALORE	66	SRINIVASPURA - DALASNUR	YELDUR	16:17	16:29	0:11	LOAD CHANGEOVER
214	27-Feb-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	0:00	0:15	0:15	LINE FAULT
215	27-Feb-19	BENGALORE	66	KAMASAMUDRA - KGF	KAMASAMUDRA	0:00	1:55	1:55	MAIN SUPPLY FAILURE
216	27-Feb-19	BENGALORE	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSUR RAMANPURA	10:35	10:45	0:10	LINE CLEAR AVAILED
217	27-Feb-19	BENGALORE	66	HV1	DOMMASANDRA	22:35	23:23	0:47	TRANSFORMER FAULT
218	27-Feb-19	BENGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	22:35	23:17	0:41	LINE FAULT
219	27-Feb-19	BENGALORE	66	HV1	TELECOM LAYOUT	14:02	14:08	0:05	LINE CLEAR AVAILED
220	27-Feb-19	BENGALORE	66	HV2	TELECOM LAYOUT	13:27	13:55	0:28	LINE CLEAR AVAILED
221	27-Feb-19	BENGALORE	66	HV2	TAVAREKERE	14:37	14:54	0:17	LINE CLEAR AVAILED
222	27-Feb-19	BENGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	4:56	5:40	0:43	LINE FAULT
223	27-Feb-19	BENGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	14:05	14:10	0:05	LOAD CHANGEOVER
224	27-Feb-19	BENGALORE	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	8:49	9:55	1:06	LINE FAULT
225	27-Feb-19	BENGALORE	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	9:55	16:45	6:50	LINE FAULT
226	27-Feb-19	BENGALORE	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220, HSR LAYOUT 220	13:12	16:24	3:11	LINE CLEAR AVAILED
227	27-Feb-19	BENGALORE	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI, GLOBAL TECH PARK, GLOBAL TECH PARK(EHT)	8:49	10:28	1:39	MAIN SUPPLY FAILURE
228	27-Feb-19	BENGALORE	66	HSR LAYOUT 220 - ST JOHNS WOOD	ST JOHNS WOOD	8:49	10:43	1:54	MAIN SUPPLY FAILURE
229	27-Feb-19	BENGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS, CESSNO, CESSNO (EHT)	8:49	10:28	1:39	MAIN SUPPLY FAILURE
230	27-Feb-19	BENGALORE	66	HV1	HSR LAYOUT 220	8:49	10:09	1:20	MAIN SUPPLY FAILURE
231	27-Feb-19	BENGALORE	66	HV2	HSR LAYOUT 220	8:49	10:09	1:20	MAIN SUPPLY FAILURE
232	27-Feb-19	BENGALORE	66	HV3	HSR LAYOUT 220	8:49	10:09	1:20	MAIN SUPPLY FAILURE
233	27-Feb-19	BENGALORE	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	13:24	16:57	3:33	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
234	27-Feb-19	BENGALORE	66	HSR LAYOUT 220 - ST JOHNS WOOD	ST JOHNS WOOD	13:14	13:29	0:15	LOAD CHANGEOVER
235	27-Feb-19	BENGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS, CESSNO, CESSNO (EHT)	13:15	17:05	3:50	MAIN SUPPLY FAILURE
236	27-Feb-19	BENGALORE	66	HV1	HSR LAYOUT 220	13:14	13:22	0:08	LOAD CHANGEOVER
237	27-Feb-19	BENGALORE	66	HV2	HSR LAYOUT 220	13:14	13:22	0:08	LOAD CHANGEOVER
238	27-Feb-19	BENGALORE	66	HV3	HSR LAYOUT 220	13:14	13:22	0:08	LOAD CHANGEOVER
239	27-Feb-19	BENGALORE	66	JAYADEVA - NIMHANS 220	JAYADEVA	13:17	13:19	0:02	LOAD CHANGEOVER
240	27-Feb-19	BENGALORE	66	JAYADEVA - SARAKKI 1 & 2	JAYADEVA	15:06	15:24	0:18	LOAD CHANGEOVER
241	27-Feb-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:10	10:16	0:06	LINE FAULT
242	27-Feb-19	BENGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 1	ELECTRONIC CITY PH 2 SEC 1	13:12	16:31	3:18	MAIN SUPPLY FAILURE
243	27-Feb-19	BENGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2	ELECTRONIC CITY PH 2 SEC 2, BIOCON (EHT), TECH MAHINDRA (EHT)	13:12	16:31	3:19	MAIN SUPPLY FAILURE
244	27-Feb-19	BENGALORE	66	HV1	NAGANATHPURA 220	13:12	16:31	3:18	MAIN SUPPLY FAILURE
245	27-Feb-19	BENGALORE	66	HV2	NAGANATHPURA 220	13:12	16:29	3:16	MAIN SUPPLY FAILURE
246	27-Feb-19	BENGALORE	66	HV3	NAGANATHPURA 220	13:12	16:29	3:16	MAIN SUPPLY FAILURE
247	27-Feb-19	BENGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	11:20	11:25	0:05	LOAD CHANGEOVER
248	27-Feb-19	BENGALORE	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	17:05	17:10	0:05	LOAD CHANGEOVER
249	27-Feb-19	BENGALORE	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDAMADU	14:02	14:30	0:28	LINE FAULT
250	27-Feb-19	BENGALORE	66	HANUMANTHNAGARA - YEDUMADU	HANUMANTHNAGARA	14:02	14:36	0:34	MAIN SUPPLY FAILURE
251	27-Feb-19	BENGALORE	66	HV2	RMV	10:20	10:26	0:06	LINE CLEAR AVAILED
252	27-Feb-19	BENGALORE	66	HV3	ADUGODI	13:17	13:31	0:14	LOAD CHANGEOVER
253	27-Feb-19	BENGALORE	66	HV3	ADUGODI	17:18	17:19	0:01	LOAD CHANGEOVER
254	27-Feb-19	BENGALORE	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	13:23	13:30	0:07	LINE CLEAR AVAILED
255	27-Feb-19	BENGALORE	66	ADUGODI - HAL 2	K&C VALLY, NAL (EHT)	13:23	13:34	0:11	LINE CLEAR AVAILED
256	27-Feb-19	GULBARGA	220	LINGAPUR-JVSL1_IPP	JVSL1_IPP	9:04	17:44	8:40	NFBC ISSUED
257	27-Feb-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KAMALAPUR_110, METRI_110,KURUGOD_110,KUDITINI_110	11:31	11:38	0:07	LINE FAULT
258	27-Feb-19	GULBARGA	110	GURGUNTA-KHEL_IPP	GURGUNTA_110	8:15	12:42	4:27	LINE CLEAR AVAILED
259	27-Feb-19	GULBARGA	110	GURGUNTA-LJVL_IPP	GURGUNTA_110	8:25	12:28	4:03	LINE CLEAR AVAILED
260	27-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR_IPP	KOLHAR_110	11:44	11:49	0:05	LINE FAULT
261	27-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR_IPP	KOLHAR_110	11:30	11:37	0:07	LINE FAULT
262	27-Feb-19	GULBARGA	110	HV1	MASKI_110	10:58	12:01	1:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
263	27-Feb-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	11:10	11:19	0:09	LINE CLEAR AVAILED
264	27-Feb-19	GULBARGA	110	HV1	SIRWAR_110	15:01	15:04	0:03	TRANSFORMER FAULT
265	27-Feb-19	GULBARGA	110	HV1	KURKUNTA_110	0:00	17:46	17:46	TRANSFORMER FAULT
266	27-Feb-19	GULBARGA	110	HV1	HANUMASAGAR_110	10:28	10:50	0:22	TRANSFORMER FAULT
267	27-Feb-19	GULBARGA	110	GURUMITKAL-GAMESHAWIND_IPP	GAMESHAWIND_IPP	10:09	18:34	8:25	LINE CLEAR AVAILED
268	27-Feb-19	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	14:36	14:40	0:04	LINE CLEAR AVAILED
269	27-Feb-19	HASSAN	220	HASSN22-CHIKMANGLUR	HASSAN_220	0:00	14:10	14:10	LINE FAULT
270	27-Feb-19	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	12:25	13:33	1:08	LINE CLEAR AVAILED
271	27-Feb-19	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	10:25	14:50	4:25	LINE CLEAR AVAILED
272	27-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:10	10:45	0:35	LINE FAULT
273	27-Feb-19	HASSAN	110	ANAVATI-TILUVALLI	ANAVATTI_110	10:10	10:45	0:35	LINE FAULT
274	27-Feb-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	10:45	14:15	3:30	LINE CLEAR AVAILED
275	27-Feb-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	11:31	11:37	0:06	LOAD CURTAILMENT
276	27-Feb-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:28	11:40	0:12	LOAD CURTAILMENT
277	27-Feb-19	HASSAN	110	KADUR-YGTI	KADUR_220	9:48	10:48	1:00	LOAD CURTAILMENT
278	27-Feb-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	11:27	11:37	0:10	LINE FAULT
279	27-Feb-19	HASSAN	110	HV2	KULASHEKARA_110	9:09	14:00	4:51	LINE CLEAR AVAILED
280	27-Feb-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:10	12:34	2:24	LINE CLEAR AVAILED
281	27-Feb-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	14:20	14:35	0:15	LINE FAULT
282	27-Feb-19	HASSAN	66	HV2	BELUR_66	14:15	14:23	0:08	TRANSFORMER FAULT
283	27-Feb-19	HASSAN	66	HV2	BELUR_66	15:31	15:45	0:14	TRANSFORMER FAULT
284	27-Feb-19	HASSAN	66	HV2	MATTANAVILE_66	16:20	16:28	0:08	TRANSFORMER FAULT
285	27-Feb-19	MYSORE	66	HV2	BGNAGARA_66	10:30	11:37	1:07	LINE CLEAR AVAILED
286	27-Feb-19	MYSORE	66	HV1	KADAKOLA_220	9:44	23:59	14:14	TRANSFORMER FAULT
287	27-Feb-19	MYSORE	66	HV1	KADAKOLA_220	10:09	10:14	0:04	TRANSFORMER FAULT
288	27-Feb-19	MYSORE	66	HV1	KADAKOLA_220	21:08	21:15	0:06	TRANSFORMER FAULT
289	27-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 HURA_66, HULLAHALLI_66, DOORA_66	7:33	9:12	1:39	LINE CLEAR AVAILED
290	27-Feb-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 HURA_66, HULLAHALLI_66, DOORA_66	7:33	9:13	1:40	LINE CLEAR AVAILED
291	27-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 HURA_66, HULLAHALLI_66, DOORA_66	16:12	17:25	1:13	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
292	27-Feb-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66 HURA_66, HULLAHALLI_66, DOORA_66	16:12	17:25	1:13	LINE CLEAR AVAILED
293	27-Feb-19	MYSORE	66	HV3	KUSHALNAGARA_220	9:50	10:01	0:10	TRANSFORMER FAULT
294	27-Feb-19	MYSORE	66	HV1	RAVANDUR_66	9:31	10:25	0:53	LINE CLEAR AVAILED
295	27-Feb-19	MYSORE	66	SANTHE SARGURU-B MATTGERE	B MATKERE_66	7:35	17:39	10:04	LINE CLEAR AVAILED
296	27-Feb-19	MYSORE	66	HV1	SANTHESARAGUR_66	7:35	17:51	10:16	LINE CLEAR AVAILED
297	27-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	7:35	17:43	10:08	LINE CLEAR AVAILED
298	27-Feb-19	MYSORE	66	MUGUR-THAYUR	CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66	3:15	3:20	0:05	LINE FAULT
299	27-Feb-19	MYSORE	66	TN PURA-SFC	THUMLA_66 CHIDRAVALLI_66	13:10	13:15	0:05	LINE FAULT
300	27-Feb-19	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:40	12:09	0:29	HAND TRIPPED
301	27-Feb-19	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	11:11	12:02	0:50	HAND TRIPPED
302	27-Feb-19	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRS MG_220	12:09	12:52	0:42	HAND TRIPPED
303	27-Feb-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	15:10	19:54	4:44	LINE CLEAR AVAILED
304	27-Feb-19	TUMKUR	110	TR-1	MAYASANDRA_110	9:11	10:56	1:45	TRANSFORMER FAULT
305	27-Feb-19	TUMKUR	66	BELADADARA-KORATAGERE(ANTHRASANAHALLI)	BELADARA_66	11:02	11:07	0:04	HAND TRIPPED
306	27-Feb-19	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	10:59	11:02	0:03	HAND TRIPPED
307	27-Feb-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	14:23	14:25	0:01	HAND TRIPPED
308	27-Feb-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:28	15:32	0:03	TRANSFORMER FAULT
309	27-Feb-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:48	14:00	0:11	LINE FAULT
310	27-Feb-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:27	15:32	0:05	HAND TRIPPED
311	27-Feb-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:10	15:26	0:16	HAND TRIPPED
312	27-Feb-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:09	12:16	0:06	LINE FAULT
313	27-Feb-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	7:57	11:05	3:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
314	27-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:01	14:10	0:09	HAND TRIPPED
315	27-Feb-19	TUMKUR	66	TR-1	LINGADAHALLY_66	19:00	19:10	0:09	TRANSFORMER FAULT
316	27-Feb-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	21:59	23:00	1:00	LINE CLEAR AVAILED
317	27-Feb-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI 2	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	22:00	23:00	1:00	LINE CLEAR AVAILED
318	27-Feb-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	10:18	11:53	1:34	LINE FAULT
319	27-Feb-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	12:13	13:43	1:30	LINE FAULT
320	27-Feb-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	16:27	18:22	1:55	LINE FAULT
321	28-Feb-19	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	9:24	15:12	5:48	LINE CLEAR AVAILED
322	28-Feb-19	BAGALKOT	220	BAGALKOT220-ALMATTI1	BAGALKOT_220	11:37	18:45	7:08	LINE CLEAR AVAILED
323	28-Feb-19	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	13:45	14:47	1:02	LINE FAULT
324	28-Feb-19	BAGALKOT	110	GHATAPRABHA220-P G HUNSYAL	P G HUNSYAL_110	6:49	7:08	0:19	LINE FAULT
325	28-Feb-19	BAGALKOT	110	110/11KV,HV2	GOKAK_110	13:31	13:38	0:07	TRANSFORMER FAULT
326	28-Feb-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA 33KV,BOMMANAHALLI 33KV	16:53	18:50	1:57	LINE CLEAR AVAILED
327	28-Feb-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110,BELAGALPET 33KV,LAXMIPUR 33KV	16:53	18:50	1:57	LINE CLEAR AVAILED
328	28-Feb-19	BAGALKOT	220	220/110KV,HV1&2,LV1&2	KUDUCHI_220,UGAR KHUD_110,AINAPUR_110,KUDUCHI_110,YELLAPARAHATTI_110,TERDAL_110	1:10	1:19	0:09	TRANSFORMER FAULT
329	28-Feb-19	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	15:18	16:19	1:01	LINE CLEAR AVAILED
330	28-Feb-19	BAGALKOT	110	KHUDUCHI220-AINAPUR	AINAPUR_110	1:17	1:33	0:16	LINE FAULT
331	28-Feb-19	BAGALKOT	110	110/11KV,HV2	PG HUNSYAL_110	7:45	9:22	1:37	LINE CLEAR AVAILED
332	28-Feb-19	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	2:40	15:36	12:56	LINE FAULT
333	28-Feb-19	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	11:42	13:35	1:53	LINE CLEAR AVAILED
334	28-Feb-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YELLAPUR_33	13:49	14:02	0:13	LINE CLEAR AVAILED
335	28-Feb-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	5:41	9:56	4:15	LINE FAULT
336	28-Feb-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	18:51	18:55	0:04	HAND TRIPPED
337	28-Feb-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	1:24	1:25	0:01	MAIN SUPPLY FAILURE
338	28-Feb-19	BENGALORE	66	HV2	ELECTRONIC CITY	19:43	21:20	1:37	TRANSFORMER FAULT
339	28-Feb-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:08	10:14	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
340	28-Feb-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	11:46	11:48	0:02	LINE FAULT
341	28-Feb-19	BENGALORE	66	SANKALGERE - ADANI SOLAR(IPP)	SANKALGERE	10:08	10:14	0:05	LINE FAULT
342	28-Feb-19	BENGALORE	66	HV2	SIR MV LAYOUT	13:45	14:45	1:00	LINE CLEAR AVAILED
343	28-Feb-19	BENGALORE	66	HV1	SIR MV LAYOUT	15:30	15:45	0:15	LINE CLEAR AVAILED
344	28-Feb-19	BENGALORE	66	HV1	SIR MV LAYOUT	16:45	17:35	0:50	LINE CLEAR AVAILED
345	28-Feb-19	BENGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	19:28	19:45	0:17	LINE FAULT
346	28-Feb-19	BENGALORE	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDAMADU	13:05	14:20	1:15	LINE CLEAR AVAILED
347	28-Feb-19	BENGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:56	12:44	0:48	LINE CLEAR AVAILED
348	28-Feb-19	GULBARGA	220	LINGAPUR-JVSL1_IPP	JVSL1_IPP	8:55	18:18	9:23	NFBC ISSUED
349	28-Feb-19	GULBARGA	220	RAICHUR-JURALLA1	JURALA_IPP	0:50	1:47	0:57	LINE FAULT
350	28-Feb-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	KHEL_IPP	3:45	23:59	20:14	LINE FAULT
351	28-Feb-19	GULBARGA	110	GURUGUNTA-LINGASUGUR	GURGUNTA_110	2:35	2:45	0:10	LINE FAULT
352	28-Feb-19	GULBARGA	110	GURUGUNTA-LINGASUGUR	GURGUNTA_110	3:45	3:55	0:10	LINE FAULT
353	28-Feb-19	GULBARGA	110	GURUMITKAL-GAMESHAWIND_IPP	GAMESHAWIND_IPP	11:02	18:18	7:16	LINE CLEAR AVAILED
354	28-Feb-19	GULBARGA	110	HV2	HAGARIBOMMANAHALLI_66	9:45	9:50	0:05	TRANSFORMER FAULT
355	28-Feb-19	GULBARGA	110	HV2	RAICHUR_220	1:21	1:25	0:04	TRANSFORMER FAULT
356	28-Feb-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	11:29	11:31	0:02	LINE FAULT
357	28-Feb-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	13:29	23:59	10:30	LINE FAULT
358	28-Feb-19	HASSAN	220	HV1	PUTTUR_220	10:22	12:44	2:22	LINE CLEAR AVAILED
359	28-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	13:30	23:59	10:29	LINE FAULT
360	28-Feb-19	HASSAN	110	HV3	MRSMG_220	11:26	14:49	3:23	LINE CLEAR AVAILED
361	28-Feb-19	HASSAN	110	LV1	PUTTUR_220	10:22	12:44	2:22	LINE CLEAR AVAILED
362	28-Feb-19	HASSAN	110	HV1	PUTTUR_110	10:05	13:05	3:00	LINE CLEAR AVAILED
363	28-Feb-19	HASSAN	110	HV2	PUTTUR_110	10:05	13:05	3:00	LINE CLEAR AVAILED
364	28-Feb-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	17:45	18:00	0:15	LINE FAULT
365	28-Feb-19	HASSAN	110	HV3	BANTWAL_110	10:07	14:33	4:26	LINE CLEAR AVAILED
366	28-Feb-19	HASSAN	110	HV1	HOSANGADI_110	8:08	18:31	10:23	LINE CLEAR AVAILED
367	28-Feb-19	HASSAN	110	HV1	MANIPAL_110	2:03	3:12	1:09	TRANSFORMER FAULT
368	28-Feb-19	HASSAN	110	HV1	SAGARA_110	7:26	8:03	0:37	TRANSFORMER FAULT
369	28-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	13:21	13:28	0:07	TRANSFORMER FAULT
370	28-Feb-19	HASSAN	66	HV1	MALLAPURA_66	0:15	0:18	0:03	TRANSFORMER FAULT
371	28-Feb-19	HASSAN	66	LV3	MRSMG_220	11:26	14:49	3:23	LINE CLEAR AVAILED
372	28-Feb-19	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	11:26	12:57	1:31	LINE FAULT
373	28-Feb-19	MYSORE	66	DEVNUR(N'GUD)-PANYADAHUNDI	SUTTUR_66 HEMMARGALA_66	9:14	9:22	0:08	HAND TRIPPED
374	28-Feb-19	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66 HEMMARGALA_66	9:14	23:59	14:44	LINE CLEAR AVAILED
375	28-Feb-19	MYSORE	66	HV1	ELAVALA_66	12:46	13:13	0:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
376	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	0:05	0:11	0:05	TRANSFORMER FAULT
377	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	0:15	0:20	0:05	TRANSFORMER FAULT
378	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	10:14	10:22	0:07	TRANSFORMER FAULT
379	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	10:46	10:51	0:05	TRANSFORMER FAULT
380	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	11:24	11:31	0:06	TRANSFORMER FAULT
381	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	14:48	14:50	0:01	TRANSFORMER FAULT
382	28-Feb-19	MYSORE	66	HV1	KADAKOLA_220	15:25	15:28	0:02	TRANSFORMER FAULT
383	28-Feb-19	MYSORE	66	MIRLE-KR NAGARA	MIRLE_66	12:47	13:01	0:14	HAND TRIPPED
384	28-Feb-19	MYSORE	66	HV1	MADHUVANAHALLI_220	9:02	9:07	0:05	TRANSFORMER FAULT
385	28-Feb-19	MYSORE	66	HV1	PGPALYA_66	17:14	19:07	1:53	LINE CLEAR AVAILED
386	28-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	0:15	9:14	8:59	LINE CLEAR AVAILED
387	28-Feb-19	MYSORE	66	HV2	YELANDUR_66	13:46	14:01	0:15	HAND TRIPPED
388	28-Feb-19	MYSORE	66	HV1	YELANDUR_66	13:45	13:50	0:05	HAND TRIPPED
389	28-Feb-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	0:28	14:12	13:43	LINE FAULT
390	28-Feb-19	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMG_220	12:35	13:06	0:31	HAND TRIPPED
391	28-Feb-19	TUMKUR	110	TR-1	GUBBI_110	20:00	20:05	0:04	TRANSFORMER FAULT
392	28-Feb-19	TUMKUR	110	HUNSEGHATTA_11-KBCROSS_66	HUNSEGHATTA_110,	15:36	16:57	1:20	LINE CLEAR AVAILED
393	28-Feb-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:10	13:20	0:09	HAND TRIPPED
394	28-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	9:25	14:46	5:21	LINE CLEAR AVAILED
395	28-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	10:29	10:35	0:06	TRANSFORMER FAULT
396	28-Feb-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66, SUZLON2_IPP_66	12:31	18:31	6:00	LINE CLEAR AVAILED
397	28-Feb-19	TUMKUR	66	TR-1	CHITRADURGA_66	8:45	10:40	1:55	LINE CLEAR AVAILED
398	28-Feb-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	6:45	7:31	0:45	LINE FAULT
399	28-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:17	17:35	9:17	LINE CLEAR AVAILED
400	28-Feb-19	TUMKUR	66	HANAGAL- B G KERE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	7:39	12:29	4:49	LINE CLEAR AVAILED
401	28-Feb-19	TUMKUR	66	TR-1	HARAPPANAHALLI_66	10:49	12:24	1:34	LINE CLEAR AVAILED
402	28-Feb-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	12:24	16:37	4:12	LINE CLEAR AVAILED
403	28-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	19:19	19:48	0:29	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
404	28-Feb-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:08	8:18	0:10	LINE FAULT
405	28-Feb-19	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	11:00	11:10	0:10	HAND TRIPPED
406	28-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:28	12:30	0:02	LINE FAULT
407	28-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:06	18:09	0:03	LINE FAULT
408	28-Feb-19	TUMKUR	66	NAGALAMADIKE- RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	14:39	14:42	0:02	LINE CLEAR AVAILED
409	28-Feb-19	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	7:36	12:28	4:51	LINE CLEAR AVAILED
410	28-Feb-19	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	WELSPUN_IPP_SOLAR_66	10:47	12:36	1:48	LINE CLEAR AVAILED
411	28-Feb-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	7:35	12:30	4:54	LINE CLEAR AVAILED
412	28-Feb-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	0:30	0:47	0:16	LINE FAULT
413	28-Feb-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	2:34	2:54	0:19	LINE FAULT
414	28-Feb-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	12:42	14:30	1:48	LINE CLEAR AVAILED
415	28-Feb-19	TUMKUR	66	TAVAREKERE (H)- PATTNAYAKANAHALLI	PATTANAYAKANAHALLI_66	12:55	16:28	3:33	LINE CLEAR AVAILED
416	28-Feb-19	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	9:35	15:15	5:40	LINE CLEAR AVAILED
417	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- HOLAVINHALLI	HOLAVINAHALLY_66	0:12	0:34	0:21	LOAD CURTAILMENT
418	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- HOLAVINHALLI	HOLAVINAHALLY_66	2:33	4:00	1:26	LOAD CURTAILMENT
419	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- SIRA 2	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	5:39	6:36	0:56	LOAD CURTAILMENT
420	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	16:47	16:52	0:04	LOAD CURTAILMENT
421	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI2	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	4:36	5:39	1:02	LOAD CURTAILMENT
422	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI2	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	16:53	18:04	1:10	LOAD CURTAILMENT
423	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI2	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	1:18	2:30	1:12	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
424	28-Feb-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	0:18	1:18	0:59	LOAD CURTAILMENT
425	1-Mar-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	9:56	10:01	0:05	TRANSFORMER FAULT
426	1-Mar-19	BAGALKOT	110	GOPANAKOPPA-MRITYUNJAY NAGAR 1&2	MRITYUNJAY NAGAR_110	10:47	23:59	13:12	LINE CLEAR AVAILED
427	1-Mar-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	19:36	19:43	0:07	LINE CLEAR AVAILED
428	1-Mar-19	BAGALKOT	110	RANEBENNUR220-GUTTAL	GUTTAL_110	8:07	10:20	2:13	LINE CLEAR AVAILED
429	1-Mar-19	BAGALKOT	110	220/110,LV3	MAHALINGAPUR_220,HIDIKAL_110,IT NAL_110	9:56	10:10	0:14	TRANSFORMER FAULT
430	1-Mar-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	MAHALINGAPUR_220	10:04	10:18	0:14	LINE FAULT
431	1-Mar-19	BAGALKOT	110	220/110,LV3	MAHALINGAPUR_220,HIDIKAL_110,IT NAL_110	10:48	10:55	0:07	TRANSFORMER FAULT
432	1-Mar-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	MAHALINGAPUR_220	10:56	11:07	0:11	LINE FAULT
433	1-Mar-19	BAGALKOT	110	110/11KV,HV1	KALGATAGI_110	8:49	9:45	0:56	LINE CLEAR AVAILED
434	1-Mar-19	BAGALKOT	110	110/11KV,HV2	KALGATAGI_110	9:56	11:28	1:32	LINE CLEAR AVAILED
435	1-Mar-19	BENGALORE	66	HV2	ISRO LAYOUT	0:27	1:22	0:54	TRANSFORMER FAULT
436	1-Mar-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	13:32	13:49	0:16	LINE FAULT
437	1-Mar-19	BENGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2	ELECTRONIC CITY PH 2 SEC 2, BIOCON (EHT), TECH MAHINDRA (EHT)	7:42	8:25	0:43	LINE FAULT
438	1-Mar-19	BENGALORE	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	10:59	11:05	0:06	LOAD CHANGEOVER
439	1-Mar-19	BENGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	16:20	16:24	0:04	LOAD CHANGEOVER
440	1-Mar-19	BENGALORE	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	14:09	14:12	0:02	LOAD CHANGEOVER
441	1-Mar-19	BENGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS, CESSNO, CESSNO(EHT)	15:13	15:22	0:09	LINE CLEAR AVAILED
442	1-Mar-19	BENGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	14:14	14:26	0:12	MAIN SUPPLY FAILURE
443	1-Mar-19	BENGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:14	14:26	0:12	MAIN SUPPLY FAILURE
444	1-Mar-19	BENGALORE	66	HV1	VIKAS TECH PARK 220	14:14	14:26	0:12	MAIN SUPPLY FAILURE
445	1-Mar-19	BENGALORE	66	HV2	VIKAS TECH PARK 220	14:14	14:26	0:12	MAIN SUPPLY FAILURE
446	1-Mar-19	BENGALORE	220	HV1	DB PURA 220	15:09	15:21	0:12	TRANSFORMER FAULT
447	1-Mar-19	BENGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	15:09	15:30	0:21	MAIN SUPPLY FAILURE
448	1-Mar-19	BENGALORE	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	15:09	15:30	0:21	MAIN SUPPLY FAILURE
449	1-Mar-19	BENGALORE	66	DB PURA 220 - D CROSS	D CROSS	15:09	15:30	0:21	MAIN SUPPLY FAILURE
450	1-Mar-19	BENGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT)	14:04	14:09	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
451	1-Mar-19	BENGALORE	220	KOLAR 220 - MALUR 1	MALUR 220	12:12	12:45	0:33	LINE FAULT
452	1-Mar-19	BENGALORE	220	KOLAR 220 - MALUR 1	MALUR 220	12:47	13:44	0:57	LINE FAULT
453	1-Mar-19	BENGALORE	220	KOLAR 220 - MALUR 1	MALUR 220	13:58	14:45	0:47	LINE FAULT
454	1-Mar-19	BENGALORE	220	KOLAR 220 - MALUR 1	MALUR 220	15:06	15:45	0:39	LINE FAULT
455	1-Mar-19	BENGALORE	66	MALLASANDRA - DALASNUR	DALASNUR	14:04	14:14	0:09	LINE FAULT
456	1-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:12	12:50	0:38	MAIN SUPPLY FAILURE
457	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:12	12:50	0:38	MAIN SUPPLY FAILURE
458	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:12	12:50	0:38	MAIN SUPPLY FAILURE
459	1-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	12:12	12:50	0:38	MAIN SUPPLY FAILURE
460	1-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	12:12	12:50	0:38	MAIN SUPPLY FAILURE
461	1-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:47	13:50	1:03	MAIN SUPPLY FAILURE
462	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:47	13:50	1:03	MAIN SUPPLY FAILURE
463	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:47	13:50	1:03	MAIN SUPPLY FAILURE
464	1-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	12:47	13:50	1:03	MAIN SUPPLY FAILURE
465	1-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	12:47	13:50	1:03	MAIN SUPPLY FAILURE
466	1-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:58	14:50	0:52	MAIN SUPPLY FAILURE
467	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:58	14:50	0:52	MAIN SUPPLY FAILURE
468	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:58	14:50	0:52	MAIN SUPPLY FAILURE
469	1-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	13:58	14:50	0:52	MAIN SUPPLY FAILURE
470	1-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	13:58	14:50	0:52	MAIN SUPPLY FAILURE
471	1-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:06	16:22	1:16	MAIN SUPPLY FAILURE
472	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:06	16:22	1:16	MAIN SUPPLY FAILURE
473	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:06	16:22	1:16	MAIN SUPPLY FAILURE
474	1-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A	15:06	16:43	1:37	MAIN SUPPLY FAILURE
475	1-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI	15:06	16:43	1:37	MAIN SUPPLY FAILURE
476	1-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	15:06	16:30	1:24	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
477	1-Mar-19	BENGALORE	220	HV2	MALUR 220	15:06	16:13	1:07	MAIN SUPPLY FAILURE
478	1-Mar-19	BENGALORE	220	MALUR 220 - KOLAR 1	MALUR 220	15:06	16:19	1:13	MAIN SUPPLY FAILURE
479	1-Mar-19	BENGALORE	220	HV1	MALUR 220	15:06	16:20	1:14	MAIN SUPPLY FAILURE
480	1-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:27	16:43	0:16	LINE FAULT
481	1-Mar-19	BENGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:14	14:26	0:12	LINE FAULT
482	1-Mar-19	BENGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:14	14:26	0:12	MAIN SUPPLY FAILURE
483	1-Mar-19	BENGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:14	14:26	0:12	MAIN SUPPLY FAILURE
484	1-Mar-19	BENGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:27	13:31	0:03	LINE FAULT
485	1-Mar-19	BENGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:49	14:00	0:11	LINE FAULT
486	1-Mar-19	BENGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	23:15	23:59	0:44	LINE FAULT
487	01-Mar-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	KHEL_IPP	0:00	10:21	10:21	LINE FAULT
488	01-Mar-19	GULBARGA	110	HV1, HV2	HALBURGA_220	14:38	14:45	0:07	TRANSFORMER FAULT
489	01-Mar-19	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110, JANAWADA_110	14:38	14:55	0:17	LINE FAULT
490	01-Mar-19	GULBARGA	110	HV2	KAMPLI_GLB_110	12:27	12:36	0:09	TRANSFORMER FAULT
491	01-Mar-19	GULBARGA	110	KOLHAR-HALBURGA1, JANAWADA	KOLHAR_110, JANAWADA_110	14:38	14:55	0:17	LINE FAULT
492	01-Mar-19	GULBARGA	220	RAICHUR-JURALA2	JURALA2_220	20:02	21:07	1:05	LINE FAULT
493	1-Mar-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	12:54	16:30	3:36	LINE CLEAR AVAILED
494	1-Mar-19	HASSAN	220	HNPURA21-HNPUR21	GOPALAPURA_220	6:20	6:50	0:30	LINE FAULT
495	1-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	12:52	15:34	2:42	LINE FAULT
496	1-Mar-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:52	15:34	2:42	LINE FAULT
497	1-Mar-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	16:13	16:55	0:42	LINE CLEAR AVAILED
498	1-Mar-19	HASSAN	110	HV1	SHIRALKOPPA_220	16:13	17:03	0:50	LINE CLEAR AVAILED
499	1-Mar-19	HASSAN	110	LV1	SHIRALKOPPA_220	16:13	16:56	0:43	LINE CLEAR AVAILED
500	1-Mar-19	HASSAN	110	HV1	AJJAMPURA_110	0:00	0:25	0:25	TRANSFORMER FAULT
501	1-Mar-19	HASSAN	110	HV1	AJJAMPURA_110	0:30	1:00	0:30	TRANSFORMER FAULT
502	1-Mar-19	HASSAN	110	HV1	BAIKAMPADI_110	11:46	14:58	3:12	LINE CLEAR AVAILED
503	1-Mar-19	HASSAN	110	HV1	HOSANGADI_110	17:33	19:15	1:42	LINE CLEAR AVAILED
504	1-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	8:51	9:40	0:49	HAND TRIPPED
505	1-Mar-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	6:20	6:31	0:11	LINE FAULT
506	1-Mar-19	MYSORE	66	HV2	BGNAGARA_66	12:45	13:43	0:57	LINE CLEAR AVAILED
507	1-Mar-19	MYSORE	66	HV2	BGNAGARA_66	13:51	23:59	10:07	LINE CLEAR AVAILED
508	1-Mar-19	MYSORE	220	MADHUVANAHALLI -HV2	MALAVALLI_66 HADLI_66	10:09	10:32	0:23	LINE FAULT
509	1-Mar-19	MYSORE	66	HV1	PGPALYA_66	7:20	8:20	1:00	LINE CLEAR AVAILED
510	1-Mar-19	MYSORE	66	HV1	SANTHEBACHALLI_66	16:50	17:05	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
511	1-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	9:07	13:35	4:27	LINE CLEAR AVAILED
512	01-Mar-19	TUMKUR	220	NITTUR 220kV- HASSAN	NITTUR_220	12:56	16:28	3:32	LINE CLEAR AVAILED
513	01-Mar-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	16:35	18:30	1:55	LINE CLEAR AVAILED
514	01-Mar-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:06	16:09	0:03	TRANSFORMER FAULT
515	01-Mar-19	TUMKUR	110	TR-1	GUBBI_110	0:08	0:19	0:10	TRANSFORMER FAULT
516	01-Mar-19	TUMKUR	110	TR-1	GUBBI_110	16:07	16:43	0:36	LINE CLEAR AVAILED
517	01-Mar-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	13:20	15:23	2:02	LINE CLEAR AVAILED
518	01-Mar-19	TUMKUR	66	TR2	CHANNAGIRI_66	8:35	8:41	0:05	TRANSFORMER FAULT
519	01-Mar-19	TUMKUR	66	TR2	CHANNAGIRI_66	13:26	13:37	0:11	TRANSFORMER FAULT
520	01-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:00	15:08	2:08	LINE CLEAR AVAILED
521	01-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:53	16:13	0:20	HAND TRIPPED
522	01-Mar-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	14:20	14:31	0:10	LINE CLEAR AVAILED
523	01-Mar-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	22:24	22:26	0:01	HAND TRIPPED
524	01-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	21:49	21:57	0:08	LINE FAULT
525	01-Mar-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS1_EHT_66	14:52	14:54	0:02	LINE FAULT
526	01-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:04	9:10	0:05	HAND TRIPPED
527	01-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	21:08	22:32	1:24	LINE FAULT
528	01-Mar-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	10:52	10:58	0:06	HAND TRIPPED
529	01-Mar-19	TUMKUR	66	HIREHALLI - MELEKOTE	HIREHALLY_66	12:29	15:48	3:18	LINE FAULT
530	2-Mar-19	BAGALKOT	110	110/33KV,HV3	GHATAPRABHA_110	18:15	18:16	0:01	LINE CLEAR AVAILED
531	2-Mar-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	18:15	18:26	0:11	LINE CLEAR AVAILED
532	2-Mar-19	BAGALKOT	110	GHATAPRABHA 110-HIDIKAL DAM	HIDIKAL DAM_110	13:15	20:37	7:22	NFBC ISSUED
533	2-Mar-19	BAGALKOT	110	SPV SOLAR-MUKARTHAL	MUKARTHAL_110	8:03	8:19	0:16	LINE FAULT
534	2-Mar-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	19:26	19:36	0:10	TRANSFORMER FAULT
535	2-Mar-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	14:10	16:19	2:09	LINE FAULT
536	2-Mar-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	4:18	4:33	0:15	TRANSFORMER FAULT
537	2-Mar-19	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	11:15	11:26	0:11	LINE CLEAR AVAILED
538	2-Mar-19	BAGALKOT	110	110/11KV, HV1	TILUVALI_110	9:40	12:25	2:45	LINE CLEAR AVAILED
539	2-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:10	14:00	1:50	LINE CLEAR AVAILED
540	2-Mar-19	BAGALKOT	220	VAJRAMATTI220-KAVATAGI LIS	VAJRAMATTI_220	15:02	15:25	0:23	LINE CLEAR AVAILED
541	2-Mar-19	BAGALKOT	110	110/11KV,HV-2	SATTI_110	17:56	18:14	0:18	TRANSFORMER FAULT
542	2-Mar-19	BAGALKOT	110	SATTI-RABAKAVI	RABAKAVI_110	14:50	14:57	0:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
543	2-Mar-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	0:00	17:33	17:33	LINE CLEAR AVAILED
544	2-Mar-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	22:18	23:59	1:41	LINE CLEAR AVAILED
545	2-Mar-19	BAGALKOT	110	DS SHIVAKUMAR SUGARS-HIREBEVANUR	HIREBEVANUR_110	16:35	18:50	2:15	LINE CLEAR AVAILED
546	2-Mar-19	BENGALORE	400	HV2	NELAMANGALA 400	13:54	14:03	0:09	TRANSFORMER FAULT
547	2-Mar-19	BENGALORE	66	HV1	RANGANDODDI	13:11	14:15	1:03	LINE CLEAR AVAILED
548	2-Mar-19	BENGALORE	66	HV1	RANGANDODDI	9:00	9:21	0:21	LINE CLEAR AVAILED
549	2-Mar-19	BENGALORE	66	HV1	RANGANDODDI	2:14	2:23	0:08	TRANSFORMER FAULT
550	2-Mar-19	BENGALORE	66	HV1	RANGANDODDI	2:23	3:06	0:43	TRANSFORMER FAULT
551	2-Mar-19	BENGALORE	66	HV2	NALLIMARADANAHALLI	7:41	14:57	7:16	LINE CLEAR AVAILED
552	2-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:03	9:08	0:05	LINE FAULT
553	2-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:26	10:30	0:04	LINE FAULT
554	2-Mar-19	BENGALORE	66	HULLENAHALLI - KUDUR	KUDUR	16:25	17:55	1:30	LINE CLEAR AVAILED
555	2-Mar-19	BENGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	12:00	12:05	0:05	LOAD CHANGEOVER
556	2-Mar-19	BENGALORE	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	9:35	9:40	0:05	LOAD CHANGEOVER
557	2-Mar-19	BENGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:55	13:59	0:04	LINE CLEAR AVAILED
558	2-Mar-19	BENGALORE	66	HV2	AKKURMOLE	18:33	18:40	0:06	TRANSFORMER FAULT
559	2-Mar-19	BENGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	0:00	1:30	1:30	LINE FAULT
560	2-Mar-19	BENGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	22:45	23:59	1:14	LINE CLEAR AVAILED
561	2-Mar-19	BENGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	10:09	10:25	0:16	LINE FAULT
562	2-Mar-19	BENGALORE	66	HV2	KHB	15:46	15:50	0:03	LINE CLEAR AVAILED
563	2-Mar-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	2:45	2:56	0:11	LINE FAULT
564	2-Mar-19	BENGALORE	66	HV1	ITI	11:00	11:25	0:25	LINE CLEAR AVAILED
565	2-Mar-19	BENGALORE	66	HV2	ITI	11:30	12:15	0:45	LINE CLEAR AVAILED
566	2-Mar-19	BENGALORE	66	HV1	IISC	0:08	1:11	1:03	TRANSFORMER FAULT
567	2-Mar-19	BENGALORE	66	HV1	IISC	13:47	14:12	0:25	TRANSFORMER FAULT
568	2-Mar-19	BENGALORE	66	HV3	HEBBAL 220	14:35	15:39	1:04	LINE CLEAR AVAILED
569	2-Mar-19	BENGALORE	66	HV1	ELECTRONIC CITY	11:42	12:05	0:22	LINE CLEAR AVAILED
570	2-Mar-19	BENGALORE	66	HV2	ELECTRONIC CITY	18:26	19:09	0:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
571	02-Mar-19	GULBARGA	220	RAICHUR-JURALA2	JURALA2	20:02	21:07	1:05	LINE FAULT
572	02-Mar-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BT PS_WATERWORKS	4:02	4:14	0:12	LINE FAULT
573	02-Mar-19	GULBARGA	110	PD HALLI-CLEANSOLAR_IPP	PD_HALLI_110	3:21	3:47	0:26	LINE FAULT
574	02-Mar-19	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	12:09	17:17	5:08	LINE CLEAR AVAILED
575	02-Mar-19	GULBARGA	110	MASKI-RNWSLR_IPP	RNWSLR_IPP	18:55	23:59	5:04	LINE CLEAR AVAILED
576	02-Mar-19	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	4:13	4:23	0:10	LINE FAULT
577	02-Mar-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:25	4:57	0:32	LINE FAULT
578	02-Mar-19	GULBARGA	110	SHKNGR-CHICKSUGUR	SHAKTINAGAR_110	9:13	11:18	2:05	MAIN SUPPLY FAILURE
579	2-Mar-19	HASSAN	220	HASSV22-Shomoga	HASSAN_220	5:19	21:55	16:36	LINE FAULT
580	2-Mar-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	17:48	22:03	4:15	LINE CLEAR AVAILED
581	2-Mar-19	HASSAN	220	HV1	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
582	2-Mar-19	HASSAN	220	HV2	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
583	2-Mar-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	20:35	20:40	0:05	LOAD CURTAILMENT
584	2-Mar-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	18:26	18:37	0:11	LINE CLEAR AVAILED
585	2-Mar-19	HASSAN	110	HV2	BAIKAMPADI_110	9:59	12:18	2:19	LINE CLEAR AVAILED
586	2-Mar-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:10	14:05	2:55	LINE CLEAR AVAILED
587	2-Mar-19	HASSAN	110	HV1	MANIPAL_110	9:41	10:10	0:29	LINE CLEAR AVAILED
588	2-Mar-19	HASSAN	110	SAGARA-IDLE	SAGARA_110	17:52	18:15	0:23	HAND TRIPPED
589	2-Mar-19	HASSAN	110	HV1	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
590	2-Mar-19	HASSAN	110	LV1	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
591	2-Mar-19	HASSAN	110	LV2	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
592	2-Mar-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
593	2-Mar-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
594	2-Mar-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	20:33	20:39	0:06	LOAD CURTAILMENT
595	2-Mar-19	HASSAN	110	SHRLKP-SHR220	SORABA_110	17:50	17:55	0:05	LINE CLEAR AVAILED
596	2-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:30	19:39	12:09	LOAD CURTAILMENT
597	2-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:26	19:38	12:12	LOAD CURTAILMENT
598	2-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	9:52	10:05	0:13	LINE FAULT
599	2-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:24	19:37	12:13	LINE CLEAR AVAILED
600	2-Mar-19	HASSAN	66	HV1	HASSAN_66	9:08	15:44	6:36	LINE CLEAR AVAILED
601	2-Mar-19	HASSAN	66	HV1	HASSAN_66	15:49	16:34	0:45	LINE CLEAR AVAILED
602	2-Mar-19	HASSAN	66	HV1	HASSAN_66	16:40	17:03	0:23	LINE CLEAR AVAILED
603	2-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	12:20	12:51	0:31	LINE CLEAR AVAILED
604	2-Mar-19	HASSAN	66	HV1	MALLAPURA_66	3:19	3:28	0:09	TRANSFORMER FAULT
605	2-Mar-19	MYSORE	66	HV2	HUNSUR_66	16:05	17:14	1:09	LINE CLEAR AVAILED
606	2-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	9:01	9:19	0:18	HAND TRIPPED
607	2-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	9:01	9:19	0:18	HAND TRIPPED
608	2-Mar-19	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66 MADDUR_66	9:01	20:20	11:19	LINE CLEAR AVAILED
609	2-Mar-19	MYSORE	66	KIADB MANDYA-MY SUGAR	KIADBMANDYA_66 MADDUR_66	8:22	20:20	11:57	LINE CLEAR AVAILED
610	2-Mar-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	11:36	19:27	7:51	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
611	2-Mar-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	BHERYA_66 BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	6:24	6:34	0:10	LINE FAULT
612	2-Mar-19	MYSORE	66	MADDUR-K HONNALAGERE	MADDUR_66	19:47	20:17	0:29	HAND TRIPPED
613	2-Mar-19	MYSORE	66	HV1	TARIPURA_66	11:20	11:26	0:06	TRANSFORMER FAULT
614	02-Mar-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:47	23:53	1:06	LINE CLEAR AVAIED
615	02-Mar-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	10:34	10:38	0:03	LINE CLEAR AVAIED
616	02-Mar-19	TUMKUR	66	HANAGAL- B G KERE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	10:34	10:38	0:04	LINE CLEAR AVAIED
617	02-Mar-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	10:34	10:38	0:04	LINE CLEAR AVAIED
618	02-Mar-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	10:12	16:20	6:07	LINE CLEAR AVAIED
619	02-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:23	17:49	9:26	LINE CLEAR AVAIED
620	02-Mar-19	TUMKUR	66	TR-1	HIRIYUR_66	11:28	11:36	0:07	LINE CLEAR AVAIED
621	02-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	1:16	1:23	0:07	LINE FAULT
622	02-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:42	10:53	0:11	LINE FAULT
623	02-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:10	0:56	0:46	MAIN SUPPLY FAILURE
624	02-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:20	9:21	0:01	MAIN SUPPLY FAILURE
625	02-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	13:51	16:19	2:27	LINE FAULT
626	02-Mar-19	TUMKUR	66	TR-2	SHYLAPURA_66	9:10	9:13	0:02	TRANSFORMER FAULT
627	02-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:27	10:38	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
628	02-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:01	9:14	0:13	LINE FAULT
629	3-Mar-19	BAGALKOT	220	ATHANI-RAVI URJA 1	ATANI_220	1:05	2:50	1:45	LINE FAULT
630	3-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:05	23:59	5:54	LINE CLEAR AVAILED
631	3-Mar-19	BAGALKOT	110	220/110KV, LV-2	BELGAUM_220	18:01	18:40	0:39	HAND TRIPPED
632	3-Mar-19	BAGALKOT	110	220/110KV, LV-2	GADAG_220	9:09	18:47	9:38	LINE CLEAR AVAILED
633	3-Mar-19	BAGALKOT	110	110/11KV, HV2	MUNAVALLI_110	20:39	20:49	0:10	TRANSFORMER FAULT
634	3-Mar-19	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	15:31	20:40	5:09	LINE CLEAR AVAILED
635	3-Mar-19	BAGALKOT	110	110/11KV, HV3	YARGATTI_110	11:20	15:25	4:05	LINE CLEAR AVAILED
636	3-Mar-19	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	11:03	11:22	0:19	TRANSFORMER FAULT
637	3-Mar-19	BAGALKOT	110	110/11KV, HV2	TILUVALI_110	9:20	11:45	2:25	LINE CLEAR AVAILED
638	3-Mar-19	BAGALKOT	110	110/11KV, HV1	SATTI_110	13:21	13:32	0:11	TRANSFORMER FAULT
639	3-Mar-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	8:18	18:44	10:26	LINE CLEAR AVAILED
640	3-Mar-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	8:19	18:45	10:26	LINE CLEAR AVAILED
641	3-Mar-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	8:23	18:42	10:19	LINE CLEAR AVAILED
642	3-Mar-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	8:23	18:57	10:34	LINE CLEAR AVAILED
643	3-Mar-19	BAGALKOT	110	110/33KV, HV3	RANEENNUR_220,KUPPELUR_33,R S NAGAR_33	12:20	17:40	5:20	LINE CLEAR AVAILED
644	3-Mar-19	BENGALORE	66	HV1	SURYANAGAR	0:29	0:32	0:03	TRANSFORMER FAULT
645	3-Mar-19	BENGALORE	66	HV1	SURYANAGAR	2:23	2:48	0:24	TRANSFORMER FAULT
646	3-Mar-19	BENGALORE	220	MALUR 220 - HOODY 220	MALUR 220	10:18	10:42	0:24	LOAD CHANGEOVER
647	3-Mar-19	BENGALORE	220	MALUR 220 - KOLAR 1	MALUR 220	15:59	16:15	0:16	LOAD CHANGEOVER
648	3-Mar-19	BENGALORE	66	HV2	SUGUTUR	9:35	10:20	0:45	TRANSFORMER FAULT
649	3-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:18	10:42	0:24	MAIN SUPPLY FAILURE
650	3-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:18	10:42	0:24	MAIN SUPPLY FAILURE
651	3-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:18	10:42	0:24	MAIN SUPPLY FAILURE
652	3-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	10:18	10:42	0:24	MAIN SUPPLY FAILURE
653	3-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	10:18	10:42	0:24	MAIN SUPPLY FAILURE
654	3-Mar-19	BENGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	13:24	13:35	0:11	LOAD CHANGEOVER
655	3-Mar-19	BENGALORE	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	16:00	16:06	0:06	LOAD CHANGEOVER
656	3-Mar-19	BENGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:11	18:20	0:09	LINE FAULT
657	3-Mar-19	BENGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:37	10:40	0:03	MAIN SUPPLY FAILURE
658	3-Mar-19	BENGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:37	10:42	0:05	MAIN SUPPLY FAILURE
659	3-Mar-19	BENGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:37	10:40	0:03	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
660	3-Mar-19	BENGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:14	11:20	0:06	MAIN SUPPLY FAILURE
661	3-Mar-19	BENGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:14	11:25	0:11	MAIN SUPPLY FAILURE
662	3-Mar-19	BENGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:14	11:22	0:08	MAIN SUPPLY FAILURE
663	3-Mar-19	BENGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI, NARASAPURA	11:55	13:10	1:15	LOAD CURTAILMENT
664	3-Mar-19	BENGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	12:35	13:50	1:15	LOAD CURTAILMENT
665	3-Mar-19	BENGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:50	12:30	0:40	LOAD CURTAILMENT
666	3-Mar-19	BENGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:21	10:50	0:28	LOAD CURTAILMENT
667	3-Mar-19	BENGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:41	14:25	2:44	LINE CLEAR AVAIED
668	3-Mar-19	BENGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	7:13	7:32	0:19	LINE FAULT
669	3-Mar-19	BENGALORE	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	19:05	19:35	0:30	LOAD CHANGEOVER
670	3-Mar-19	BENGALORE	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	14:50	16:15	1:24	LINE CLEAR AVAIED
671	3-Mar-19	BENGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	12:18	16:11	3:52	LINE FAULT
672	3-Mar-19	BENGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	11:55	12:03	0:08	LINE FAULT
673	3-Mar-19	BENGALORE	66	HV1	CHAKAVELU	7:46	8:25	0:38	LINE CLEAR AVAIED
674	3-Mar-19	BENGALORE	66	HV1	ANEKAL	11:00	11:10	0:10	LINE CLEAR AVAIED
675	3-Mar-19	BENGALORE	66	HV1	ANEKAL	12:10	12:15	0:04	LINE CLEAR AVAIED
676	3-Mar-19	BENGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:50	11:25	0:35	LINE CLEAR AVAIED
677	3-Mar-19	BENGALORE	66	HV1	BRINDAVANA	11:00	16:02	5:02	LINE CLEAR AVAIED
678	3-Mar-19	BENGALORE	66	HV3	BRINDAVANA	11:00	16:02	5:02	LINE CLEAR AVAIED
679	3-Mar-19	BENGALORE	66	HV1	C STATION	8:17	8:46	0:29	LINE CLEAR AVAIED
680	3-Mar-19	BENGALORE	66	HV2	C STATION	8:17	8:46	0:29	LINE CLEAR AVAIED
681	3-Mar-19	BENGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	8:45	8:50	0:05	LOAD CHANGEOVER
682	3-Mar-19	BENGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	12:15	12:19	0:04	LOAD CHANGEOVER
683	3-Mar-19	BENGALORE	66	ELECTRONIC CITY PH 2 SEC 2 - NAGANATHAPURA 220	BIOCON (EHT), ELECTRONIC CITY PH 2 SEC 2, TECH MAHINDRA (EHT)	14:35	14:48	0:13	LOAD CHANGEOVER
684	3-Mar-19	BENGALORE	66	ELECTRONIC CITY PH 2 SEC 2 - ELECTRONIC CITY	BIOCON (EHT), ELECTRONIC CITY PH 2 SEC 2, TECH MAHINDRA (EHT)	20:30	20:40	0:10	LOAD CHANGEOVER
685	3-Mar-19	BENGALORE	66	SOLADEVANAHALLI - YELAHANKA 220	SOLADEVANAHALLI	10:15	10:24	0:09	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
686	3-Mar-19	BENGALORE	66	SOLADEVANAHALLI- SRS PEENYA 220	SOLADEVANAHALLI	13:30	13:36	0:06	LOAD CHANGEOVER
687	3-Mar-19	BENGALORE	66	HV2	TAVAREKERE	12:35	12:54	0:18	TRANSFORMER FAULT
688	3-Mar-19	BENGALORE	66	HV2	TAVAREKERE	14:31	14:36	0:05	TRANSFORMER FAULT
689	3-Mar-19	BENGALORE	66	VR DODDI - TK HALLI 220	VR DODDI	18:25	19:05	0:40	LINE FAULT
690	3-Mar-19	BENGALORE	66	HV1	YARANDANAHALLI 220	9:00	10:23	1:23	LINE CLEAR AVAILED
691	3-Mar-19	BENGALORE	66	HV2	YARANDANAHALLI 220	8:45	8:50	0:05	LOAD CHANGEOVER
692	3-Mar-19	BENGALORE	66	HV3	YARANDANAHALLI 220	8:45	8:50	0:05	LOAD CHANGEOVER
693	3-Mar-19	BENGALORE	66	HV2	YARANDANAHALLI 220	10:53	13:10	2:17	LINE CLEAR AVAILED
694	3-Mar-19	BENGALORE	66	HV1	YARANDANAHALLI 220	17:50	17:55	0:05	LOAD CHANGEOVER
695	3-Mar-19	BENGALORE	66	HV2	YARANDANAHALLI 220	17:40	17:45	0:05	LOAD CHANGEOVER
696	3-Mar-19	BENGALORE	66	HV3	YARANDANAHALLI 220	17:40	17:45	0:05	LOAD CHANGEOVER
697	3-Mar-19	BENGALORE	66	HV1	VIJAYANAGARA	0:13	0:20	0:07	LOAD CHANGEOVER
698	3-Mar-19	BENGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	9:57	10:12	0:15	LOAD CHANGEOVER
699	3-Mar-19	BENGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	VIKAS TECH PARK 220	16:38	16:57	0:19	LOAD CHANGEOVER
700	03-Mar-19	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	0:00	1:36	1:36	LINE FAULT
701	03-Mar-19	GULBARGA	110	MASKI-RNWSLR_IPP	RNWSLR_IPP	0:00	3:07	3:07	LINE CLEAR AVAILED
702	03-Mar-19	GULBARGA	110	HV3	BEVOOR_110	9:29	9:44	0:15	TRANSFORMER FAULT
703	03-Mar-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	5:05	5:14	0:09	LINE FAULT
704	03-Mar-19	GULBARGA	110	MALLAT-ALKOD	ALKOD	21:50	22:00	0:10	LINE FAULT
705	3-Mar-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:07	23:59	12:52	LINE CLEAR AVAILED
706	3-Mar-19	HASSAN	220	GERSOPPA-TALGUPA1	gerusoppa_gen	10:55	16:49	5:54	NFBC ISSUED
707	3-Mar-19	HASSAN	220	GERSOPPA-TALGUPA2	gerusoppa_gen	10:50	14:40	3:50	NFBC ISSUED
708	3-Mar-19	HASSAN	220	HV1	KEMAR_220	10:03	20:01	9:58	LINE CLEAR AVAILED
709	3-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	10:55	23:59	13:04	LINE CLEAR AVAILED
710	3-Mar-19	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	8:19	18:47	10:28	LINE CLEAR AVAILED
711	3-Mar-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	8:19	18:53	10:34	LINE CLEAR AVAILED
712	3-Mar-19	HASSAN	110	HV2	BAIKAMPADI_110	8:32	8:48	0:16	LINE CLEAR AVAILED
713	3-Mar-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:46	20:40	9:54	LINE CLEAR AVAILED
714	3-Mar-19	HASSAN	110	HV1	SHIKARIPURA_110	10:10	17:45	7:35	LINE CLEAR AVAILED
715	3-Mar-19	HASSAN	110	HV2	SHIKARIPURA_110	10:15	17:55	7:40	LINE CLEAR AVAILED
716	3-Mar-19	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	1:04	23:59	22:55	LINE CLEAR AVAILED
717	3-Mar-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	16:04	16:15	0:11	LOAD CURTAILMENT
718	3-Mar-19	HASSAN	66	HV1	GENDEHALLI_66	16:04	16:15	0:11	LOAD CURTAILMENT
719	3-Mar-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	16:04	16:15	0:11	LOAD CURTAILMENT
720	3-Mar-19	HASSAN	66	MRSSHM-BD-2	MRSMG_220	1:04	23:59	22:55	LINE CLEAR AVAILED
721	3-Mar-19	HASSAN	66	RAMNAT-KUSHALNAGARA	RAMNATHPURA_66	6:43	7:23	0:40	LINE FAULT
722	3-Mar-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	6:43	7:16	0:33	LINE FAULT
723	3-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	0:32	0:41	0:09	HAND TRIPPED
724	3-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	0:32	0:42	0:09	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
725	3-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	11:30	11:50	0:20	HAND TRIPPED
726	3-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	11:30	11:50	0:20	HAND TRIPPED
727	3-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	6:05	15:20	9:14	LINE CLEAR AVAIED
728	3-Mar-19	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66	0:30	0:40	0:10	LINE FAULT
729	3-Mar-19	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66	11:30	11:48	0:18	LINE FAULT
730	3-Mar-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	7:39	7:47	0:07	LINE FAULT
731	3-Mar-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	8:07	10:15	2:07	LINE CLEAR AVAIED
732	3-Mar-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	MALAVALLI_66 HADLI_66	6:38	6:49	0:10	LINE FAULT
733	03-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	6:25	12:03	5:38	LINE CLEAR AVAIED
734	03-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	6:16	12:04	5:48	LINE CLEAR AVAIED
735	03-Mar-19	TUMKUR	110	TR-1	KALLUR_110	19:40	19:50	0:10	LINE CLEAR AVAIED
736	03-Mar-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	14:54	19:40	4:45	LINE FAULT
737	03-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:00	12:08	2:07	LINE FAULT
738	03-Mar-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	6:17	6:40	0:22	LINE FAULT
739	03-Mar-19	TUMKUR	66	TR-1	CHITRADURGA_66	10:12	12:57	2:45	LINE CLEAR AVAIED
740	03-Mar-19	TUMKUR	66	TR-1	KATTIGE_66	22:04	22:11	0:07	TRANSFORMER FAULT
741	03-Mar-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	15:28	15:31	0:03	TRANSFORMER FAULT
742	03-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	8:08	8:26	0:17	LINE FAULT
743	03-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	9:13	9:30	0:16	LINE FAULT
744	03-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	9:58	10:14	0:16	LINE FAULT
745	03-Mar-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:09	9:20	0:11	LINE FAULT
746	03-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:18	10:20	0:01	HAND TRIPPED
747	4-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	11:57	12:02	0:05	TRANSFORMER FAULT
748	4-Mar-19	BAGALKOT	110	BAGEWADI-ACHANUR	MUDEDEBIHAL_110	11:46	11:49	0:03	HAND TRIPPED
749	4-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	7:22	7:22	LINE CLEAR AVAIED
750	4-Mar-19	BAGALKOT	110	DAMBAL-GADAD 1	DAMBAL_110	6:26	8:24	1:58	LINE FAULT
751	4-Mar-19	BAGALKOT	220	220/110KV,HV1,LV1 &HV2,LV2	KUDUCHI_220,UGA KHUD_110,MORAB_110,AINAPUR_110,KUDUCHI_110,TERDAL_110&YELLA PARHATTI_110	23:45	23:49	0:04	TRANSFORMER FAULT
752	4-Mar-19	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	23:51	23:52	0:01	LINE FAULT
753	4-Mar-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	23:52	23:53	0:01	LINE FAULT
754	4-Mar-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	19:21	19:30	0:09	TRANSFORMER FAULT
755	4-Mar-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	23:38	23:50	0:12	TRANSFORMER FAULT
756	4-Mar-19	BAGALKOT	110	110/11KV, HV1	TERDAL_110	14:11	14:28	0:17	TRANSFORMER FAULT
757	4-Mar-19	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	11:27	11:43	0:16	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
758	4-Mar-19	BAGALKOT	110	110/11KV,HV-2	SHIRGOAN_110	11:56	12:23	0:27	LINE CLEAR AVAILED
759	4-Mar-19	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	11:00	11:32	0:32	LINE CLEAR AVAILED
760	4-Mar-19	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	6:26	6:40	0:14	LINE FAULT
761	4-Mar-19	BAGALKOT	110	MUNDARGI-DAMBAL	DAMBAL_110	6:26	8:25	1:59	LINE FAULT
762	4-Mar-19	BAGALKOT	110	NARENDRA220-MRUTHYUNJAY NAGAR1&2	MRUTHYUNJAY NAGAR_110	7:50	7:57	0:07	LINE FAULT
763	4-Mar-19	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	7:59	8:00	0:01	TRANSFORMER FAULT
764	4-Mar-19	BENGALORE	66	HV2	HONNIGANAHALLI	12:58	13:04	0:06	TRANSFORMER FAULT
765	4-Mar-19	BENGALORE	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	12:10	13:50	1:40	LINE CLEAR AVAILED
766	4-Mar-19	BENGALORE	66	HV3	YARANADANAHALLI 220	12:35	12:41	0:06	LINE CLEAR AVAILED
767	4-Mar-19	BENGALORE	66	HV1	VIJAYANAGARA	9:30	10:15	0:45	LOAD CHANGEOVER
768	4-Mar-19	BENGALORE	66	HV1	VIJAYANAGARA	8:21	8:30	0:09	LOAD CHANGEOVER
769	4-Mar-19	BENGALORE	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	17:09	17:20	0:11	LINE FAULT
770	04-Mar-19	GULBARGA	110	KAMPLI-SINDHANOOR	KAMPLI_GLB_110	12:40	16:05	3:25	LINE CLEAR AVAILED
771	04-Mar-19	GULBARGA	110	HV3	KAMPLI_GLB_110	12:22	23:59	11:37	LINE CLEAR AVAILED
772	04-Mar-19	GULBARGA	110	MALLAT-BYAGAWAT2	BYAGAWAT_110	15:00	15:10	0:10	LINE FAULT
773	04-Mar-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	16:00	16:05	0:05	LINE FAULT
774	4-Mar-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:33	15:58	4:25	NFBC ISSUED
775	4-Mar-19	HASSAN	110	SHRLKP-SHR220	SORABA_110	11:35	13:05	1:30	LINE CLEAR AVAILED
776	4-Mar-19	HASSAN	66	HV1	ALDUR_66	22:38	22:50	0:12	TRANSFORMER FAULT
777	4-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	12:17	12:43	0:26	LINE FAULT
778	4-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:13	10:47	0:34	LINE FAULT
779	4-Mar-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	7:58	8:05	0:07	LOAD CURTAILMENT
780	4-Mar-19	HASSAN	66	HV1	GENDEHALLI_66	7:58	8:05	0:07	LOAD CURTAILMENT
781	4-Mar-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	7:58	8:05	0:07	LOAD CURTAILMENT
782	4-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:32	13:37	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
783	4-Mar-19	MYSORE	220	HV2	CRNAGAR_220 CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66 , CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALI_66	12:19	12:32	0:13	TRANSFORMER FAULT
784	4-Mar-19	MYSORE	220	HV2	CRNAGAR_220 CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66 , CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALI_66	16:36	23:59	7:23	TRANSFORMER FAULT
785	4-Mar-19	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	12:20	12:30	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
786	4-Mar-19	MYSORE	66	JAKKANAHALLI-NAGAMANGALA	BOGADHI MANDYA_66 GUDDENAHALLI_66 G MALLIGERE_66 NAGAMANGALA_66	18:04	18:11	0:07	LINE FAULT
787	4-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	11:35	11:39	0:04	TRANSFORMER FAULT
788	4-Mar-19	MYSORE	66	HV3	KUSHALNAGARA_220	16:38	16:51	0:12	TRANSFORMER FAULT
789	4-Mar-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	BHERYA_66 MIRLE_66 KRNAGARA_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	12:53	13:18	0:25	LINE FAULT
790	4-Mar-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 RAVANDUR_66 KITTUR_66	12:53	13:15	0:22	LINE FAULT
791	4-Mar-19	MYSORE	220	HV1	MADHUVANAHALLI_220 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66	12:20	21:45	9:25	TRANSFORMER FAULT
792	4-Mar-19	MYSORE	220	HV2	MADHUVANAHALLI_220 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66	12:20	12:55	0:35	TRANSFORMER FAULT
793	4-Mar-19	MYSORE	220	HV2	MADHUVANAHALLI_220 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66	16:36	17:01	0:25	TRANSFORMER FAULT
794	4-Mar-19	MYSORE	66	MUGUR-KUNTHUR	MUGUR_66, CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66	7:15	7:20	0:05	LINE FAULT
795	4-Mar-19	MYSORE	66	MUGUR-THAYUR	MUGUR_66,	18:55	19:05	0:10	LINE FAULT
796	4-Mar-19	MYSORE	66	HV2	NAGAMANGALA_66	11:10	11:15	0:05	TRANSFORMER FAULT
797	4-Mar-19	MYSORE	66	HV2	NAGAMANGALA_66	11:25	11:35	0:10	TRANSFORMER FAULT
798	4-Mar-19	MYSORE	66	PGPALYA-MADHUVANAHALLI	PGPALYA_66	12:46	16:18	3:31	LINE CLEAR AVAILED
799	4-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	12:03	23:59	11:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
800	04-Mar-19	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	12:18	12:43	0:24	LINE FAULT
801	04-Mar-19	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	12:18	12:42	0:23	LINE FAULT
802	04-Mar-19	TUMKUR	220	TR-1	HONNALLI_220	12:19	12:43	0:24	HAND TRIPPED
803	04-Mar-19	TUMKUR	220	TR-1(HV SIDE)	THALLAKK_220	6:31	6:42	0:11	TRANSFORMER FAULT
804	04-Mar-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	6:31	8:15	1:44	LINE FAULT
805	04-Mar-19	TUMKUR	66	TR-1 (LV SIDE)	THALLAKK_220	6:31	6:43	0:11	TRANSFORMER FAULT
806	04-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:56	11:32	3:36	LINE FAULT
807	04-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	12:48	14:07	1:19	LINE FAULT
808	04-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:13	17:34	9:20	LINE CLEAR AVAILED
809	04-Mar-19	TUMKUR	66	TR-1	HANAGAL_66	15:47	18:36	2:48	TRANSFORMER FAULT
810	04-Mar-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	21:07	22:12	1:05	LINE FAULT
811	04-Mar-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	21:28	21:53	0:24	HAND TRIPPED
812	04-Mar-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	21:28	21:53	0:24	HAND TRIPPED
813	04-Mar-19	TUMKUR	66	TR-1 & TR-2	HONNALLI_220	12:19	12:47	0:27	MAIN SUPPLY FAILURE
814	04-Mar-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:19	12:47	0:28	MAIN SUPPLY FAILURE
815	04-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:19	12:47	0:28	MAIN SUPPLY FAILURE
816	04-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:07	6:18	0:11	LINE FAULT
817	04-Mar-19	TUMKUR	66	TR-1 & TR-2 (LV SIDE)	HONNALLI_220	12:19	12:46	0:27	MAIN SUPPLY FAILURE
818	04-Mar-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	12:19	12:48	0:29	MAIN SUPPLY FAILURE
819	04-Mar-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	10:08	10:38	0:29	LINE FAULT
820	04-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:19	8:21	0:01	MAIN SUPPLY FAILURE
821	04-Mar-19	TUMKUR	66	TR-1	KUNIGAL_66	11:54	12:08	0:13	TRANSFORMER FAULT
822	04-Mar-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	6:25	6:31	0:05	LINE FAULT
823	04-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	4:05	4:07	0:01	LINE FAULT
824	04-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	11:45	13:50	2:05	LINE FAULT
825	04-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:56	8:15	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
826	04-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:50	13:06	0:16	LINE FAULT
827	04-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:25	13:38	0:13	LINE FAULT
828	04-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	22:23	22:34	0:10	LINE FAULT