

400/220/110/66 kV TRANSMISSION OUTAGES FROM :05.10.21 to 11.10.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	5-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	5-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
3	5-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
4	5-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
5	5-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
6	5-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
7	5-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
8	5-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
9	5-Oct-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
10	5-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
11	5-Oct-2021	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	11:32 (01.10.2021)	3:51 (05.10.2021)	88:19HRS	TRANSFORMER CHARGED
12	5-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
13	5-Oct-2021	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	19:39 (04.10.2021)	12:12 (05.10.2021)	16:33HRS	TRANSFORMER CHARGED
14	5-Oct-2021	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	12:11	12:17	0:06	LINE CLEAR AVAILED
15	5-Oct-2021	BAGALKOT	110	BETAGERI- NAREGAL	NAREGAL_110	11:50	18:07	6:17	LINE CLEAR AVAILED
16	5-Oct-2021	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	9:43	19:10	9:27	LINE CLEAR AVAILED
17	5-Oct-2021	BAGALKOT	110	DAMBAL-SUZLON (L2)	DAMBAL_110	9:43	19:13	9:30	LINE CLEAR AVAILED
18	5-Oct-2021	BAGALKOT	110	DAMBAL-SUZLON (L3)	DAMBAL_110	9:43	19:13	9:30	LINE CLEAR AVAILED
19	5-Oct-2021	BAGALKOT	110	DAMBAL-GADAG2(L4)	DAMBAL_110	9:56	10:05	0:09	LINE CLEAR AVAILED
20	5-Oct-2021	BAGALKOT	110	DAMBAL-MUNDARAGI	DAMBAL_110	9:43	18:47	9:04	LINE CLEAR AVAILED
21	5-Oct-2021	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	11:09	18:35	7:26	LINE CLEAR AVAILED
22	5-Oct-2021	BAGALKOT	110	GHATAPRABHA220-KABBUR	KABBUR_110	4:12	4:38	0:26	LINE FAULT
23	5-Oct-2021	BAGALKOT	110	HIREBEVANUR-RODAGI(INDI-LACHYAN)	RODAGI_110	2:56	11:11	8:15	LINE FAULT
24	5-Oct-2021	BAGALKOT	110	KUMATA- SIRSI 1	KUMATA_110	17:56	19:51	1:55	LINE CLEAR AVAILED
25	5-Oct-2021	BAGALKOT	220	BIDNAL-NAGIJAR 2	BIDNAL_220	11:50	14:28	2:38	LINE FAULT
26	5-Oct-2021	BAGALKOT	220	BIJAPUR-INDI 2	BIJAPUR_220	11:40	17:46	6:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
27	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	10:37	13:00	2:23	LINE CLEAR AVAILED
28	5-Oct-2021	BAGALKOT	110	TODALBAGI- MAMDAPUR(B)	TODALBAGI_110	13:11	14:20	1:09	LINE CLEAR AVAILED
29	5-Oct-2021	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	10:45	12:37	1:52	LINE CLEAR AVAILED
30	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	SUARNASOUDA_110	9:46	10:12	0:26	TRANSFORMER FAULT
31	5-Oct-2021	BAGALKOT	110	SIRSI- KUMTA1&2	SIRSI_110	18:08	19:41	1:33	LINE CLEAR AVAILED
32	5-Oct-2021	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIDDAPUR_110	18:08	18:59	0:51	LINE FAULT
33	5-Oct-2021	BAGALKOT	110	SAMPAPUR ROAD- DAMBAL	DAMBAL_110	9:57	19:05	9:08	LINE CLEAR AVAILED
34	5-Oct-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	11:39	18:25	6:46	LINE CLEAR AVAILED
35	5-Oct-2021	BAGALKOT	110	RON- GAMESHA	RON_110	11:39	11:51	0:12	HAND TRIPPED
36	5-Oct-2021	BAGALKOT	110	RON- NAREGAL	RON_110	11:20	18:20	7:00	LINE CLEAR AVAILED
37	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	8:55	9:07	0:12	TRANSFORMER FAULT
38	5-Oct-2021	BAGALKOT	110	NAREGAL- RON	NAREGAL_110	11:23	18:21	6:58	LINE CLEAR AVAILED
39	5-Oct-2021	BAGALKOT	110	NAREGAL- BETAGERI	NAREGAL_110	11:50	18:00	6:10	LINE CLEAR AVAILED
40	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	15:09	16:28	1:19	LINE CLEAR AVAILED
41	5-Oct-2021	BAGALKOT	110	MUNDARGI- VIJAYNAGAR SUGARS	MUNDARGI_110	9:45	18:58	9:13	LINE CLEAR AVAILED
42	5-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:28	18:17	6:49	LINE FAULT
43	5-Oct-2021	BAGALKOT	220	MUGALKOD- GHATAPRABHA1	MUGALKOD_220	10:40	10:53	0:13	LINE FAULT
44	5-Oct-2021	BAGALKOT	220	MUGALKOD- CHIKKODI1	MUGALKOD_220	10:40	10:55	0:15	LINE FAULT
45	5-Oct-2021	BAGALKOT	220	220/110KV, HV1	MUGALKOD_220	10:40	11:05	0:25	TRANSFORMER FAULT
46	5-Oct-2021	BAGALKOT	220	220/110KV, HV2	MUGALKOD_220	10:40	11:06	0:26	TRANSFORMER FAULT
47	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_220	10:40	11:11	0:31	TRANSFORMER FAULT
48	5-Oct-2021	BAGALKOT	110	MUGALKOD- ITANAL1	MUGALKOD_220	10:40	11:08	0:28	LINE FAULT
49	5-Oct-2021	BAGALKOT	110	MUGALKOD- ITANAL2	MUGALKOD_220	10:40	11:10	0:30	LINE FAULT
50	5-Oct-2021	BAGALKOT	110	MUGALKOD- RAIBAG1&2	MUGALKOD_220	10:40	11:07	0:27	LINE FAULT
51	5-Oct-2021	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	15:34	17:34	2:00	LINE CLEAR AVAILED
52	5-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
53	5-Oct-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
54	5-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
55	5-Oct-2021	BAGALKOT	110	110/11KV, HV2	KATKOL_110	12:10	14:00	1:50	LINE CLEAR AVAILED
56	5-Oct-2021	BAGALKOT	110	110/33KV, HV2	SADALAGA_110	16:25 (05.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
57	5-Oct-2021	BAGALKOT	110	MKHUBLI220- BAILHONGAL	BAILHONGAL_110	5:16	6:10	0:54	LINE FAULT
58	5-Oct-2021	BAGALKOT	220	GUTTUR- RANEBENNUR	RANEBENNUR_220	20:15 (05.10.2021)			LINE OPEN:LINE FAULT
59	5-Oct-2021	BAGALKOT	110	VAJRAMATTI- SHIRGUPPI	SHIRGUPPI_110	1:45	1:50	0:05	LINE FAULT
60	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	15:10	16:30	1:20	LINE CLEAR AVAILED
61	5-Oct-2021	BAGALKOT	220	INDI- BIJAPUR2	INDI_220	11:38	17:50	6:12	LINE CLEAR AVAILED
62	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	SINGATALUR_110	9:45	18:50	9:05	LINE CLEAR AVAILED
63	5-Oct-2021	BAGALKOT	110	110/11KV, HV2	SINGATALUR_110	9:45	18:50	9:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
64	5-Oct-2021	BAGALKOT	110	GADAG220- DAMBAL	DAMBAL_110	9:45	18:37	8:52	LINE CLEAR AVAILED
65	5-Oct-2021	BAGALKOT	110	110/11KV, HV1	DAMBAL_110	9:45	18:45	9:00	LINE CLEAR AVAILED
66	5-Oct-2021	BAGALKOT	110	110/11KV, HV2	DAMBAL_110	9:45	18:55	9:10	LINE CLEAR AVAILED
67	5-Oct-2021	BAGALKOT	110	110/33KV, HV3	DAMBAL_110	9:45	19:10	9:25	LINE CLEAR AVAILED
68	5-Oct-2021	BAGALKOT	110	MUNDARGI- DAMBAL1	MUNDARGI_110	9:45	18:45	9:00	LINE CLEAR AVAILED
69	5-Oct-2021	BAGALKOT	110	MUNDARGI- DAMBAL2	MUNDARGI_110	9:45	18:45	9:00	LINE CLEAR AVAILED
70	5-Oct-2021	BAGALKOT	110	MUNDARGI- SINGATALUR	SINGATALUR_110	9:45	18:45	9:00	LINE CLEAR AVAILED
71	5-Oct-2021	BENGALURU	66	HV1	BTM 4TH PHASE	10:15	16:25	6:10	LINE CLEAR AVAILED
72	5-Oct-2021	BENGALURU	66	HV2	BTM 4TH PHASE	10:15	16:25	6:10	LINE CLEAR AVAILED
73	5-Oct-2021	BENGALURU	220	HV2	SUBRAMANYAPURA 220	15:54	15:56	0:02	LINE CLEAR AVAILED
74	5-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	15:54	15:59	0:05	LINE CLEAR AVAILED
75	5-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	15:54	15:59	0:05	LINE CLEAR AVAILED
76	5-Oct-2021	BENGALURU	66	IISc - NRS 220	IISc	7:19	7:22	0:03	LOAD CHANGE OVER
77	5-Oct-2021	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	NO STATION AFFECTED	13:16	13:50	0:34	LINE FAULT
78	5-Oct-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	9:03	9:10	0:07	LINE FAULT
79	5-Oct-2021	BENGALURU	66	HV1	CHINTAMANI 66	13:29	13:49	0:20	TRANSFORMER FAULT
80	5-Oct-2021	BENGALURU	66	HV1	CHINTAMANI 66	13:49	13:57	0:07	TRANSFORMER FAULT
81	5-Oct-2021	BENGALURU	66	HV1	DODDABELAVANGALA	11:35	13:27	1:52	LINE CLEAR AVAILED
82	5-Oct-2021	BENGALURU	66	HV1	MELUR	14:02	14:29	0:26	TRANSFORMER FAULT
83	5-Oct-2021	BENGALURU	66	HV1	MELUR	15:05	15:11	0:05	TRANSFORMER FAULT
84	5-Oct-2021	BENGALURU	66	HV1	SM MANGALA	13:11	13:27	0:16	LINE CLEAR AVAILED
85	5-Oct-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	11:15	15:42	4:27	MAIN SUPPLY FAILURE
86	5-Oct-2021	BENGALURU	66	T G HALLI - ANCHEPALYA 220	T G HALLI	11:15	15:42	4:27	MAIN SUPPLY FAILURE
87	5-Oct-2021	BENGALURU	66	G KODIHALLI - SRINIVASAPURA	SRINIVASAPURA, YELDUR	9:05	9:30	0:25	LINE FAULT
88	5-Oct-2021	BENGALURU	66	HV1	SURYANAGAR	8:42	9:00	0:18	LINE CLEAR AVAILED
89	5-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:35(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
90	5-Oct-2021	GULBARGA	220	ITTAGI-NEELAGUNDA	ITTAGI_220	14:14(04.10.2021)	01:45(05.10.2021)	11:31HRS	LINE CHARGED
91	5-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
92	5-Oct-2021	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	23:07(04.10.2021)	8:31(05.10.2021)	09:24HRS	LINE CHARGED
93	5-Oct-2021	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	12:00	12:48	0:48	NFBC ISSUED
94	5-Oct-2021	GULBARGA	220	KAPNOOR-SHAHAPUR	SHAHAPUR_220	20:54	21:25	0:31	LINE FAULT
95	5-Oct-2021	GULBARGA	220	KAPNOOR-SHAHAPUR	SHAHAPUR_220	23:02	23:34	0:32	NFBC ISSUED
96	5-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:23(04.10.2021)	07:03(05.10.2021)	07:40HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
97	5-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:18	21:54	0:36	LINE FAULT
98	5-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
99	5-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
100	5-Oct-2021	GULBARGA	110	GULBARGAWEST-KAPNOOR	GULBARGAWEST_110	7:00(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
101	5-Oct-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:30(4.10.2021)	00:59(5.10.2021)	1:29hrs	LINE CHARGED
102	5-Oct-2021	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	9:03	9:10	0:07	LOAD CURTAILMENT
103	5-Oct-2021	GULBARGA	110	NALWAR-SHAHABAD1	NALAWAR_110,JEWARGI_110	4:25	4:45	0:20	MAIN SUPPLY FAILURE
104	5-Oct-2021	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABBUR_110, GOOGLE_110	21:10	21:20	0:10	MAIN SUPPLY FAILURE
105	5-Oct-2021	GULBARGA	110	TEKKALKOTE-RENEWSOLAR IPP,SHAHISOLAR IPP	TEKKALKOTE_110	6:10	6:15	0:00	LINE CLEAR AVAILED
106	5-Oct-2021	GULBARGA	110	TEKKALKOTE-RENEWSOLAR_IPP	TEKKALKOTE_110	20:53(04.10.2021)	6:05(5.10.2021)	9:12HRS	LINE CHARGED
107	5-Oct-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KURUGOD_110,SHATHAVA HANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_IPP,MATRI_110,RBNS FACTORY	6:08	6:21	0:13	LINE FAULT
108	5-Oct-2021	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	6:38	19:19	12:41	NFBC ISSUED
109	5-Oct-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	8:09	19:42	11:33	NFBC ISSUED
110	5-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	22:19	22:27	0:08	LINE FAULT
111	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SINDHANOOR_110	20:06	20:12	0:06	LINE FAULT
112	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	0:20	0:30	0:10	LINE FAULT
113	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	0:35	11:50	11:15	LINE FAULT
114	5-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,DEODURGA_110, GABBUR_110	18:48	18:56	0:08	LINE FAULT
115	5-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GOOGLE_110,DEODURGA_110, GABBUR_110	18:48	18:56	0:08	LINE FAULT
116	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	19:17	19:25	0:08	LINE FAULT
117	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	19:48	19:55	0:07	LINE FAULT
118	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SINDHANOOR_110	22:21	22:27	0:06	LINE FAULT
119	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SINDHANOOR_110	22:53	23:04	0:11	LINE FAULT
120	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	23:31	23:50	0:19	LINE FAULT
121	5-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	23:02	23:07	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
122	5-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	4:23	9:48	5:25	LINE FAULT
123	5-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	5:02	5:06	0:04	LINE FAULT
124	5-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	15:50	16:10	0:20	LINE FAULT
125	5-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:50(05.10.2021)			LINE OPEN:LINE FAULT
126	5-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	22:43	22:50	0:07	LINE FAULT
127	5-Oct-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	GANDHINAGAR_110,THURVIHAL_110	18:40	19:05	0:25	LINE FAULT
128	5-Oct-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	GANDHINAGAR_110,THURVIHAL_110	22:01	22:11	0:10	LINE FAULT
129	5-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	18:40(05.10.2021)			LINE OPEN:LINE FAULT
130	5-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	22:20	22:30	0:10	LINE FAULT
131	5-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	23:20	23:30	0:10	LINE FAULT
132	5-Oct-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	8:44	9:02	0:18	LINE FAULT
133	5-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	1:09	1:17	0:08	LINE FAULT
134	5-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	4:40	4:50	0:10	LINE FAULT
135	5-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	5:28	5:44	0:16	LINE FAULT
136	5-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	1:52	2:00	0:08	LINE FAULT
137	5-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	7:26	7:35	0:09	LINE FAULT
138	5-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	19:24	19:40	0:16	LINE FAULT
139	5-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	19:49	20:04	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
140	5-Oct-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:06	4:15	0:09	LINE FAULT
141	5-Oct-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	5:50	6:03	0:13	LINE FAULT
142	5-Oct-2021	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	5:50	6:04	0:14	LINE FAULT
143	5-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	3:30	3:40	0:10	LINE FAULT
144	5-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:56	12:08	0:12	LINE FAULT
145	5-Oct-2021	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	21:27	21:57	0:30	LINE FAULT
146	5-Oct-2021	GULBARGA	110	NALWAR-SHAHABAD(JEWARGI)	NALWAR_110	4:25	5:20	0:55	LINE FAULT
147	5-Oct-2021	GULBARGA	110	BAYYAPURA-MUDAGAL	BAYYAPURA_110	6:15	6:20	0:05	MAIN SUPPLY FAILURE
148	5-Oct-2021	GULBARGA	110	JEEWARGI-SHAHAPUR	JEEWARGI_110	4:20	4:45	0:25	LINE FAULT
149	5-Oct-2021	GULBARGA	110	JEEWARGI-SHAHAPUR	JEEWARGI_110	16:00	16:15	0:15	LINE FAULT
150	5-Oct-2021	GULBARGA	110	HV1	MANVI_110	12:12	13:20	1:08	LINE CLEAR AVAILED
151	5-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	18:10(05.10.2021)			MAIN SUPPLY FAILURE
152	5-Oct-2021	GULBARGA	110	HV1	HUMNABAD_220	13:01	14:52	1:51	TRANSFORMER FAULT
153	5-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	4:25	4:30	0:05	LINE FAULT
154	5-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRSHWAR_110	1:45	1:55	0:10	LINE FAULT
155	5-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRSHWAR_110	3:15	3:30	0:15	LINE FAULT
156	5-Oct-2021	GULBARGA	110	HUNSAGI-KEMBHAVI	HUNSAGI_110	21:20	21:35	0:15	MAIN SUPPLY FAILURE
157	5-Oct-2021	GULBARGA	110	SINDANOOR-BENNUR	BENNUR_110	18:40	23:59	5:19	MAIN SUPPLY FAILURE
158	5-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	18:50	18:55	0:05	MAIN SUPPLY FAILURE
159	5-Oct-2021	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
160	5-Oct-2021	GULBARGA	66	HV2	HALAVAGALU_66	8:30	8:35	0:05	TRANSFORMER FAULT
161	5-Oct-2021	GULBARGA	66	HV3	KUDLIGI_220	10:50	11:10	0:20	TRANSFORMER FAULT
162	5-Oct-2021	GULBARGA	66	ITTAGI-HIREHADGALI 2	HIREHADGALI_66,GIRIYAPUR_66,MAGLA_66,SOVENAHALLI_66,TB IPP	6:08	6:15	0:07	LINE FAULT
163	5-Oct-2021	HASSAN	110	LV3	MRSMSG_220	9:01 (4.10.2021)	18:16 (5.10.2021)	33:14 hrs	TRANSFORMER CHARGED
164	5-Oct-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	13:05 (4.10.2021)	13:55 (5.10.2021)	24:49 hrs	LINE CHARGED
165	5-Oct-2021	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	9:01(4.10.2021)	13:55 (5.10.2021)	28:53 hrs	LINE CHARGED
166	5-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
167	5-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
168	5-Oct-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	13:05 (4.10.2021)			LINE OPEN:LINE FAULT
169	5-Oct-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:01(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
170	5-Oct-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:20 (4.10.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
171	5-Oct-2021	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	9:26(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
172	5-Oct-2021	HASSAN	66	LV1	MRSMSG_220	9:39(4.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
173	5-Oct-2021	HASSAN	110	LPH-JLT4	lph_gen	9:25(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
174	5-Oct-2021	HASSAN	110	JOG-JLT4	mghejog_gen	9:25(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
175	5-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	18:35 (5.10.2021)			LINE OPEN:LINE CLEAR AVAILED
176	5-Oct-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:28	14:30	1:02	LINE CLEAR AVAILED
177	5-Oct-2021	HASSAN	220	TALAGU-ST1	TALAGUPPA_400	11:06	12:32	1:26	LINE CLEAR AVAILED
178	5-Oct-2021	HASSAN	220	TALAGU-ST2	TALAGUPPA_400	14:01	17:47	3:46	LINE FAULT
179	5-Oct-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:43	13:04	1:21	LINE CLEAR AVAILED
180	5-Oct-2021	HASSAN	220	HGUNJE-KMR	HEGGUNJE_220	15:28	16:39	1:11	MAIN SUPPLY FAILURE
181	5-Oct-2021	HASSAN	110	HGUNJE-HIRIYADKA	HEGGUNJE_220	15:13	15:54	0:41	MAIN SUPPLY FAILURE
182	5-Oct-2021	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	15:04	16:02	0:58	LINE FAULT
183	5-Oct-2021	HASSAN	110	HGUNJE-HIRIYADKA	HEGGUNJE_220	17:03	17:09	0:06	HAND TRIPPED
184	5-Oct-2021	HASSAN	220	HV1	KAVOOR_220	9:27	12:57	3:30	LINE CLEAR AVAILED
185	5-Oct-2021	HASSAN	220	KAVOOR-EMAR3	KAVOOR_220	15:10	15:55	0:45	MAIN SUPPLY FAILURE
186	5-Oct-2021	HASSAN	220	KAVOOR-BJPE1	KAVOOR_220	15:10	15:55	0:45	MAIN SUPPLY FAILURE
187	5-Oct-2021	HASSAN	220	KAVOOR-BJPE2	KAVOOR_220	10:10	13:15	3:05	LINE CLEAR AVAILED
188	5-Oct-2021	HASSAN	220	KAVOOR-BJPE2	KAVOOR_220	15:10	15:55	0:45	MAIN SUPPLY FAILURE
189	5-Oct-2021	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	15:10	15:55	0:45	MAIN SUPPLY FAILURE
190	5-Oct-2021	HASSAN	110	LV1	KAVOOR_220	9:28	12:59	3:31	LINE CLEAR AVAILED
191	5-Oct-2021	HASSAN	110	LV1	KAVOOR_220	14:25	17:27	3:02	TRANSFORMER FAULT
192	5-Oct-2021	HASSAN	220	HV1	KEMAR_220	15:29	16:00	0:31	MAIN SUPPLY FAILURE
193	5-Oct-2021	HASSAN	220	HV2	KEMAR_220	15:28	16:01	0:33	MAIN SUPPLY FAILURE
194	5-Oct-2021	HASSAN	220	HV3	KEMAR_220	15:29	16:00	0:31	MAIN SUPPLY FAILURE
195	5-Oct-2021	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	15:38	16:15	0:37	MAIN SUPPLY FAILURE
196	5-Oct-2021	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	15:13	16:16	1:03	MAIN SUPPLY FAILURE
197	5-Oct-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	15:13	15:57	0:44	MAIN SUPPLY FAILURE
198	5-Oct-2021	HASSAN	220	KEMAR-KMR KVR	KEMAR_220	15:13	15:56	0:43	MAIN SUPPLY FAILURE
199	5-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:13	16:32	1:19	LINE FAULT
200	5-Oct-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	15:13	16:33	1:20	MAIN SUPPLY FAILURE
201	5-Oct-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	15:13	16:39	1:26	MAIN SUPPLY FAILURE
202	5-Oct-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:13	16:37	1:24	MAIN SUPPLY FAILURE
203	5-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:30	16:06	0:36	MAIN SUPPLY FAILURE
204	5-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:16	18:35	0:19	LINE FAULT
205	5-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:58	23:59	5:01	LINE CLEAR AVAILED
206	5-Oct-2021	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	15:13	16:03	0:50	MAIN SUPPLY FAILURE
207	5-Oct-2021	HASSAN	110	HV1	KEMAR_220	11:03	17:28	6:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
208	5-Oct-2021	HASSAN	110	HV2	KEMAR_220	11:03	17:28	6:25	LINE CLEAR AVAILED
209	5-Oct-2021	HASSAN	110	LV1	KEMAR_220	15:29	16:00	0:31	MAIN SUPPLY FAILURE
210	5-Oct-2021	HASSAN	110	LV2	KEMAR_220	15:13	16:01	0:48	MAIN SUPPLY FAILURE
211	5-Oct-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	15:13	16:07	0:54	MAIN SUPPLY FAILURE
212	5-Oct-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	15:13	16:19	1:06	MAIN SUPPLY FAILURE
213	5-Oct-2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	15:13	16:11	0:58	MAIN SUPPLY FAILURE
214	5-Oct-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	15:13	16:13	1:00	MAIN SUPPLY FAILURE
215	5-Oct-2021	HASSAN	220	KEMAR-MSEZ	KEMAR_220	15:13	15:59	0:46	MAIN SUPPLY FAILURE
216	5-Oct-2021	HASSAN	220	HV3	MRSMSG_220	10:24	16:17	5:53	LINE CLEAR AVAILED
217	5-Oct-2021	HASSAN	220	MRSSHM-SHARVTY4	MRSMSG_220	12:31	12:51	0:20	LINE FAULT
218	5-Oct-2021	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:11	13:14	3:03	NFBC ISSUED
219	5-Oct-2021	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	15:13	16:03	0:50	HAND TRIPPED
220	5-Oct-2021	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	15:13	16:03	0:50	HAND TRIPPED
221	5-Oct-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	15:13	16:02	0:49	HAND TRIPPED
222	5-Oct-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	15:13	16:16	1:03	LINE CLEAR AVAILED
223	5-Oct-2021	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	15:13	16:17	1:04	MAIN SUPPLY FAILURE
224	5-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:31	12:51	0:20	LINE FAULT
225	5-Oct-2021	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	14:01	17:47	3:46	LINE FAULT
226	5-Oct-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	15:13	15:47	0:34	MAIN SUPPLY FAILURE
227	5-Oct-2021	HASSAN	220	UPCL-KEMAR2	upcl_gen	15:13	15:50	0:37	MAIN SUPPLY FAILURE
228	5-Oct-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:13	16:37	1:24	LINE FAULT
229	5-Oct-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:13	16:38	1:25	LINE FAULT
230	5-Oct-2021	HASSAN	220	VARAHI-HEGUNJE	varahi_gen	15:04	15:50	0:46	LINE FAULT
231	5-Oct-2021	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	15:04	16:02	0:58	MAIN SUPPLY FAILURE
232	5-Oct-2021	HASSAN	110	HV2	ANAVATTI_110	15:45	16:02	0:17	TRANSFORMER FAULT
233	5-Oct-2021	HASSAN	110	HV2	BAIKAMPADI_110	10:00	10:10	0:10	HAND TRIPPED
234	5-Oct-2021	HASSAN	110	HV4	BAIKAMPADI_110	15:14	16:05	0:51	MAIN SUPPLY FAILURE
235	5-Oct-2021	HASSAN	110	BAIKAM-KAVOOR	BAIKAMPADI_110	15:14	16:05	0:51	MAIN SUPPLY FAILURE
236	5-Oct-2021	HASSAN	110	HV2	BHADRAVATHI_110	19:05	20:09	1:04	TRANSFORMER FAULT
237	5-Oct-2021	HASSAN	110	HV1	BELAGUMBA_110	14:05	14:54	0:49	LINE CLEAR AVAILED
238	5-Oct-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	15:13	16:39	1:26	MAIN SUPPLY FAILURE
239	5-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	15:13	16:37	1:24	MAIN SUPPLY FAILURE
240	5-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	18:16	18:35	0:19	LINE FAULT
241	5-Oct-2021	HASSAN	110	HIRIRYA-HALADY	HIRIYADKA_110	15:14	16:13	0:59	MAIN SUPPLY FAILURE
242	5-Oct-2021	HASSAN	110	HIRIRYA-HALADY	HIRIYADKA_110	17:05	17:09	0:04	MAIN SUPPLY FAILURE
243	5-Oct-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	15:14	16:15	1:01	MAIN SUPPLY FAILURE
244	5-Oct-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:05	17:12	0:07	MAIN SUPPLY FAILURE
245	5-Oct-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	15:14	16:25	1:11	MAIN SUPPLY FAILURE
246	5-Oct-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	17:05	17:14	0:09	MAIN SUPPLY FAILURE
247	5-Oct-2021	HASSAN	110	HV2	HOSANGADI_110	15:04	16:06	1:02	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
248	5-Oct-2021	HASSAN	110	JOG-NK2	mghejog_gen	17:47	18:05	0:18	LINE FAULT
249	5-Oct-2021	HASSAN	110	JOG-NK1	mghejog_gen	17:47	18:05	0:18	LINE FAULT
250	5-Oct-2021	HASSAN	110	JOG110-LPH	JOG_110	9:20	18:45	9:25	LINE CLEAR AVAILED
251	5-Oct-2021	HASSAN	110	KARKALA-L1	KARKALA_110	15:13	16:07	0:54	MAIN SUPPLY FAILURE
252	5-Oct-2021	HASSAN	110	HV2	KONAJE_110	15:13	16:07	0:54	MAIN SUPPLY FAILURE
253	5-Oct-2021	HASSAN	110	HV2	KONAJE_110	19:52	20:17	0:25	MAIN SUPPLY FAILURE
254	5-Oct-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:13	16:36	1:23	MAIN SUPPLY FAILURE
255	5-Oct-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:53	20:26	0:33	MAIN SUPPLY FAILURE
256	5-Oct-2021	HASSAN	110	LPH-MGHE 2	lph_gen	9:20	18:45	9:25	LINE CLEAR AVAILED
257	5-Oct-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL-110	15:15	16:19	1:04	MAIN SUPPLY FAILURE
258	5-Oct-2021	HASSAN	110	HV4	MANIPAL-110	9:50	19:50	10:00	LINE CLEAR AVAILED
259	5-Oct-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:15	16:15	1:00	MAIN SUPPLY FAILURE
260	5-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:15	16:15	1:00	MAIN SUPPLY FAILURE
261	5-Oct-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	15:15	16:20	1:05	MAIN SUPPLY FAILURE
262	5-Oct-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	15:15	16:13	0:58	MAIN SUPPLY FAILURE
263	5-Oct-2021	HASSAN	110	HV1	NAVUNDA_110	10:05	13:05	3:00	LINE CLEAR AVAILED
264	5-Oct-2021	HASSAN	110	HV2	NAVUNDA_110	11:45	12:09	0:24	LINE CLEAR AVAILED
265	5-Oct-2021	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_110	15:15	16:05	0:50	MAIN SUPPLY FAILURE
266	5-Oct-2021	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_110	15:15	16:06	0:51	MAIN SUPPLY FAILURE
267	5-Oct-2021	HASSAN	110	PUTTUR-SLTR	PUTTUR_110	15:16	16:00	0:44	MAIN SUPPLY FAILURE
268	5-Oct-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_110	15:15	16:01	0:46	MAIN SUPPLY FAILURE
269	5-Oct-2021	HASSAN	110	SALATHUR-BNTWAL	SALATHUR_110	15:12	16:03	0:51	MAIN SUPPLY FAILURE
270	5-Oct-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	19:51	20:28	0:37	MAIN SUPPLY FAILURE
271	5-Oct-2021	HASSAN	110	SAATHU-BNTWAL	SALATHUR_110	19:51	20:28	0:37	MAIN SUPPLY FAILURE
272	5-Oct-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	15:12	16:03	0:51	MAIN SUPPLY FAILURE
273	5-Oct-2021	HASSAN	110	HV	VITTALA_110	20:10	20:30	0:20	HAND TRIPPED
274	5-Oct-2021	HASSAN	110	HV2	VITTALA_110	20:10	20:30	0:20	HAND TRIPPED
275	5-Oct-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	15:14	16:04	0:50	MAIN SUPPLY FAILURE
276	5-Oct-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	19:52	20:29	0:37	MAIN SUPPLY FAILURE
277	5-Oct-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	23:43	23:57	0:14	NFBC ISSUED
278	5-Oct-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:42	18:15	0:33	MAIN SUPPLY FAILURE
279	5-Oct-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	17:40	18:08	0:28	LINE FAULT
280	5-Oct-2021	HASSAN	66	HV3	BALEHONNUR_66	10:53	16:06	5:13	LINE CLEAR AVAILED
281	5-Oct-2021	HASSAN	66	HV1	KANDLI_66	11:35	11:45	0:10	LINE CLEAR AVAILED
282	5-Oct-2021	HASSAN	66	HV2	KANDLI_66	11:35	12:05	0:30	LINE CLEAR AVAILED
283	5-Oct-2021	HASSAN	66	HV1	RAMPURA_66	11:10	13:30	2:20	LINE CLEAR AVAILED
284	5-Oct-2021	HASSAN	66	HV1	RAMPURA_66	14:32	16:26	1:54	LINE CLEAR AVAILED
285	5-Oct-2021	HASSAN	66	HV1	TAVARECHATNAHALLI_66	12:35	16:15	3:40	LINE CLEAR AVAILED
286	5-Oct-2021	HASSAN	66	HV1	TAVARECHATNAHALLI_66	17:00	17:50	0:50	HAND TRIPPED
287	5-Oct-2021	MYSURU	66	BANNIMANTAPA-FTS	NO STATIONS EFFECTED	9:38	18:08	22:44	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
288	5-Oct-2021	MYSURU	66	BANNIMANTAPA-VIJAYANAGARA	BANNIMANTAP_66	10:01	16:38	6:37	NFBC ISSUED
289	5-Oct-2021	MYSURU	66	HV1	BYLUKUPPE_66	10:55	13:06	2:10	LINE CLEAR AVAILED
290	5-Oct-2021	MYSURU	66	HV2	FTS_66	10:45	18:31	7:46	LINE CLEAR AVAILED
291	5-Oct-2021	MYSURU	66	G UKKADA-SR PATNA	NO STATIONS EFFECTED	5:50	18:49	12:59	LINE CLEAR AVAILED
292	5-Oct-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	9:29	15:26	5:57	LOAD CHANGE OVER
293	5-Oct-2021	MYSURU	220	HV1	KADAKOLA_220	9:43	12:42	2:58	LINE CLEAR AVAILED
294	5-Oct-2021	MYSURU	220	HV2	KADAKOLA_220	12:43	15:11	2:28	LINE CLEAR AVAILED
295	5-Oct-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	11:37	11:42	0:05	LINE FAULT
296	5-Oct-2021	MYSURU	66	HV1	KUSHALANAGARA_66	11:28	13:24	1:56	LINE CLEAR AVAILED
298	5-Oct-2021	MYSURU	66	KUSHALANAGARA-MERCERA-1	MADIKERI_66	19:08	19:34	0:25	LINE FAULT
299	5-Oct-2021	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	SUNTIKOPPA_66	19:05	19:37	0:31	LINE FAULT
300	5-Oct-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	9:38	15:23	5:45	LOAD CHANGE OVER
301	5-Oct-2021	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	12:11	17:11	4:59	LINE CLEAR AVAILED
302	5-Oct-2021	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	9:34	15:30	5:55	LINE CLEAR AVAILED
304	5-Oct-2021	MYSURU	66	HV1	TUBINAKERE_66	10:53	14:57	4:04	LINE CLEAR AVAILED
305	5-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42			LINE OPEN:LINE CLEAR AVAILED
307	5-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
308	5-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
309	5-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
310	5-Oct-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	6:14	6:27	0:12	LINE FAULT
311	5-Oct-2021	TUMKUR	66	ANTHRASANA HALLI 220kV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	22:20	22:26	0:05	HAND TRIPPED
312	5-Oct-2021	TUMKUR	66	TR-1	BRAMASANDRA_66	15:00	16:17	1:17	LINE CLEAR AVAILED
313	5-Oct-2021	TUMKUR	66	TR-2	HOLALKERE_66	15:49	15:52	0:03	MAIN SUPPLY FAILURE
314	5-Oct-2021	TUMKUR	66	TR-2	HOLALKERE_66	18:51	19:15	0:23	MAIN SUPPLY FAILURE
315	5-Oct-2021	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	18:51	19:16	0:25	LINE FAULT
316	5-Oct-2021	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66,DEVARABELKERE_66	9:18	9:28	0:09	LINE FAULT
317	5-Oct-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:21	14:24	0:03	HAND TRIPPED
318	5-Oct-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:46	15:56	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
319	5-Oct-2021	TUMKUR	66	KUKKAWADA-LINGADAHALLI(HONNALLI)	KUKKAWADA_66	13:24	14:45	1:21	LINE CLEAR AVAILED
320	5-Oct-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	12:52	13:24	0:31	LINE CLEAR AVAILED
321	5-Oct-2021	TUMKUR	66	TR-1	KUNIGAL_66	23:34	23:56	0:21	TRANSFORMER FAULT
322	5-Oct-2021	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	4:53	5:10	0:16	LINE FAULT
323	5-Oct-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	6:14	6:27	0:12	LINE FAULT
324	5-Oct-2021	TUMKUR	66	TR-2	THIMMASANDRA_66	11:29	16:13	4:44	LINE CLEAR AVAILED
325	6-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
326	6-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
327	6-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
328	6-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
329	6-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
330	6-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
331	6-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
332	6-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
333	6-Oct-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
334	6-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
335	6-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
336	6-Oct-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS&KPR SUGARS	ALMEL_110	7:21	7:22	0:01	HAND TRIPPED
337	6-Oct-2021	BAGALKOT	110	BELGAUM220-HUKKERI	HUKKERI_110	18:45	19:09	0:24	LOAD CURTAILMENT
338	6-Oct-2021	BAGALKOT	110	110/33KV,HV3	BYADAGI_110 & KAGINELE &SHIDENUR_33	22:50	23:20	0:30	TRANSFORMER FAULT
339	6-Oct-2021	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	16:50	18:35	1:45	LINE FAULT
340	6-Oct-2021	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	22:48	23:01	0:13	LINE FAULT
341	6-Oct-2021	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	ANKALAGI_110	6:25	6:36	0:11	LINE FAULT
342	6-Oct-2021	BAGALKOT	110	HUKKERI-HATARAGI	HATARAGI_110	18:25	19:30	1:05	LINE CLEAR AVAILED
343	6-Oct-2021	BAGALKOT	110	KARAWAR220-ARGA	ARGA_110	18:03 (06.10.2021)			LINE OPEN:LINE FAULT
344	6-Oct-2021	BAGALKOT	110	KUDACHI-AINAPUR(KUDACHI)	AINAPUR_110	1:49	2:43	0:54	LINE FAULT
345	6-Oct-2021	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 & ALNAVAR_33	17:10	18:04	0:54	TRANSFORMER FAULT
346	6-Oct-2021	BAGALKOT	220	BIDNAL-NAGIJAR 2	BIDNAL_220	16:40	17:45	1:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
347	6-Oct-2021	BAGALKOT	110	ZALKI- CHADCHAN	CHADCHAN_110	12:03	12:29	0:26	HAND TRIPPED
348	6-Oct-2021	BAGALKOT	110	110/11KV, HV1	ZALKI_110	12:03	12:29	0:26	TRANSFORMER FAULT
349	6-Oct-2021	BAGALKOT	110	SAVANUR-SHIGGOAN	SHIGGOAN_110	5:57	6:20	0:23	LINE FAULT
350	6-Oct-2021	BAGALKOT	110	SHIGGOAN- MUNDAGOD	SHIGGOAN_110	5:57	9:06	3:09	LINE FAULT
351	6-Oct-2021	BAGALKOT	110	SADALAGA- VPPL	SADALAGA_110	5:57	6:31	0:34	LINE FAULT
352	6-Oct-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	5:57	6:05	0:08	LINE FAULT
353	6-Oct-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	12:55	14:03	1:08	LINE CLEAR AVAILED
354	6-Oct-2021	BAGALKOT	110	110/11KV, HV2	MORATAGI_110	15:20	16:50	1:30	LINE CLEAR AVAILED
355	6-Oct-2021	BAGALKOT	110	MAMADAPUR(B)- BABLESHWAR	BABLESHWAR_110	18:44	19:25	0:41	HAND TRIPPED
356	6-Oct-2021	BAGALKOT	220	NARENDRA- HAVERI2	NARENDRA_220	16:50	18:35	1:45	LINE FAULT
357	6-Oct-2021	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	18:52	20:10	1:18	LINE FAULT
358	6-Oct-2021	BAGALKOT	110	CHIKKODI220- ANKALI	ANKALI_110	2:45	3:00	0:15	LINE FAULT
359	6-Oct-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	5:33	6:03	0:30	LINE FAULT
360	6-Oct-2021	BAGALKOT	110	CHIKKODI220- ANKALI	ANKALI_110	8:22	8:29	0:07	LINE FAULT
361	6-Oct-2021	BAGALKOT	110	CHIKKODI220- ANKALI	ANKALI_110	8:51	8:58	0:07	LINE FAULT
362	6-Oct-2021	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_110	10:28	12:45	2:17	NFBC ISSUED
363	6-Oct-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	12:55	13:55	1:00	LINE CLEAR AVAILED
364	6-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	15:38	18:03	2:25	LINE FAULT
365	6-Oct-2021	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	17:34 (06.10.2021)			LINE OPEN:LINE FAULT
366	6-Oct-2021	BAGALKOT	220	HUBLI- NAGJHARI2	HUBLI_220	17:34 (06.10.2021)			LINE OPEN:LINE FAULT
367	6-Oct-2021	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	17:40	18:06	0:26	LINE FAULT
368	6-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
369	6-Oct-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
370	6-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
371	6-Oct-2021	BAGALKOT	110	110/33KV, HV2	SADALAGA_110	16:25 (05.10.2021)	13:45 (06.10.2021)	21:20hrs	TRANSFORMER CHARGED
372	6-Oct-2021	BAGALKOT	220	GUTTUR- RANEBENNUR	RANEBENNUR_220	20:15 (05.10.2021)	14:50 (06.10.2021)	18:35hrs	LINE CHARGED
373	6-Oct-2021	BAGALKOT	110	INDI220- DEVAR HIPARGI	DEVAR HIPARGI_110, ATHARGA_110, HIREBENNUR_110	2:13	2:20	0:07	LINE FAULT
374	6-Oct-2021	BAGALKOT	110	INDI220- DEVAR HIPARGI	DEVAR HIPARGI_110, ATHARGA_110, HIREBENNUR_110	6:05	6:10	0:05	LINE FAULT
375	6-Oct-2021	BAGALKOT	110	INDI220- ZALKI2	ZALKI_110	8:54	9:04	0:10	LINE FAULT
376	6-Oct-2021	BAGALKOT	110	INDI220- ZALKI2	ZALKI_110	12:03	12:21	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
377	6-Oct-2021	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	2:25	3:00	0:35	LINE FAULT
378	6-Oct-2021	BAGALKOT	110	PG HUNSHYAL- NAGNUR	NAGANUR_110	5:00	5:05	0:05	LINE FAULT
379	6-Oct-2021	BAGALKOT	110	NAGNUR- MUDALGI	MUDALGI_110	5:00	5:15	0:15	MAIN SUPPLY FAILURE
380	6-Oct-2021	BAGALKOT	110	110/11KV, HV1	NAGANUR_110	5:00	5:05	0:05	MAIN SUPPLY FAILURE
381	6-Oct-2021	BAGALKOT	110	110/11KV, HV2	NAGANUR_110	5:00	5:05	0:05	MAIN SUPPLY FAILURE
382	6-Oct-2021	BAGALKOT	110	JAMBAGI-MUDHOL	110KV-MUDHOL	6:04	6:18	0:14	MAIN SUPPLY FAILURE
383	6-Oct-2021	BAGALKOT	110	JAMBAGI-MUDHOL	JAMBAGI_110	6:05	6:20	0:15	LINE FAULT
384	6-Oct-2021	BAGALKOT	110	110/11KV,HV1	MANTUR_110	20:15	20:20	0:05	TRANSFORMER FAULT
385	6-Oct-2021	BAGALKOT	110	110/11KV,HV2	MANTUR_110	9:00	9:10	0:10	TRANSFORMER FAULT
386	6-Oct-2021	BAGALKOT	110	110/33KV,HV3	LAKAMANAHALLI_110	17:10	18:02	0:52	TRANSFORMER FAULT
387	6-Oct-2021	BAGALKOT	110	110/33KV,HV5	BELUR_110	17:12	17:49	0:37	TRANSFORMER FAULT
388	6-Oct-2021	BAGALKOT	110	GADAG-DAMBAL	DAMBAL_110	12:30	14:25	1:55	LINE CLEAR AVAILED
389	6-Oct-2021	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	11:25	15:20	3:55	LINE CLEAR AVAILED
390	6-Oct-2021	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	7:20	7:54	0:34	LINE CLEAR AVAILED
391	6-Oct-2021	BAGALKOT	110	CHIKKODI220- RAIBAG2	RAIBAG_110	10:02	20:26	10:24	LINE CLEAR AVAILED
392	6-Oct-2021	BENGALURU	66	HV2	EXORA	11:00	11:08	0:08	TRANSFORMER FAULT
393	6-Oct-2021	BENGALURU	220	HV2	NRS 220	8:06	15:27	7:21	TRANSFORMER FAULT
394	6-Oct-2021	BENGALURU	66	HV2	NRS 220	8:22	8:35	0:13	LOAD CHANGEVER
395	6-Oct-2021	BENGALURU	66	HV2	NRS 220	16:17	16:22	0:05	LOAD CHANGEVER
396	6-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	ANDERSONPETE, KYSAMBALLI, DODDAKARI	6:24	9:32	3:08	LINE FAULT
397	6-Oct-2021	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	3:14	3:28	0:14	LINE FAULT
398	6-Oct-2021	BENGALURU	66	HV1	TK HALLI 220	10:47	10:52	0:05	TRANSFORMER FAULT
399	6-Oct-2021	BENGALURU	66	HV1	TK HALLI 220	14:56	15:00	0:04	TRANSFORMER FAULT
400	6-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	3:24	3:34	0:09	LINE FAULT
401	6-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	4:57	5:13	0:15	LINE FAULT
402	6-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	4:57	5:13	0:15	LINE FAULT
403	6-Oct-2021	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	18:36	19:19	0:43	LOAD CURTAILMENT
404	6-Oct-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	19:05	19:24	0:19	LOAD CURTAILMENT
405	6-Oct-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENNIGADALE, CHELUR, CHAKAVELU	3:39	3:45	0:05	LINE FAULT
406	6-Oct-2021	BENGALURU	66	HV2	SARIAPURA 220	3:50	8:01	4:10	TRANSFORMER FAULT
407	6-Oct-2021	BENGALURU	66	MAASTI - MALUR 220	MAASTHI, DEVANGONDHI, LAKKUR	1:15	1:45	0:30	LINE CLEAR AVAILED
408	6-Oct-2021	BENGALURU	66	HV2	MAASTHI	1:15	3:15	2:00	LINE CLEAR AVAILED
409	6-Oct-2021	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	3:25	3:40	0:15	LINE FAULT
410	6-Oct-2021	BENGALURU	66	SADLI - DIBURALLI	DIBURALLI	3:25	3:40	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
411	6-Oct-2021	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	3:40	3:45	0:05	LINE FAULT
412	6-Oct-2021	BENGALURU	66	SADLI - DIBURALLI	DIBURALLI	3:40	12:15	8:35	LINE FAULT
413	6-Oct-2021	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	4:55	5:10	0:15	LINE FAULT
414	6-Oct-2021	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	10:00	10:05	0:05	LINE CLEAR AVAILED
415	6-Oct-2021	BENGALURU	66	HV2	DIBURALLI	19:45	20:25	0:40	TRANSFORMER FAULT
416	6-Oct-2021	BENGALURU	66	HV1	DIBURALLI	19:45	20:30	0:45	TRANSFORMER FAULT
417	6-Oct-2021	BENGALURU	66	HV2	DIBURALLI	20:35	20:40	0:05	TRANSFORMER FAULT
418	6-Oct-2021	BENGALURU	66	HV2	DIBURALLI	20:50	20:55	0:05	TRANSFORMER FAULT
419	6-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:35(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
420	6-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
421	6-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	4:40	4:55	0:15	LINE FAULT
422	6-Oct-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	5:51	6:01	0:10	TRANSFORMER FAULT
423	6-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	23:51(06.10.2021)			LINE OPEN:LINE FAULT
424	6-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	3:12	6:36	3:24	LINE FAULT
425	6-Oct-2021	GULBARGA	220	LV1 & LV2	ITTAGI_220	18:04	18:10	0:06	TRANSFORMER FAULT
426	6-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	18:10(05.10.2021)	7:10(06.10.2021)	13:00HRS	MAIN SUPPLY FAILURE
427	6-Oct-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KURUGOD_110,SHATHAVA HANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_IPP,MATRI_110,RBNS FACTORY	6:08	6:21	0:13	LINE FAULT
428	6-Oct-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	3:19	3:30	0:11	LINE FAULT
429	6-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	5:32	5:39	0:07	LINE FAULT
430	6-Oct-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	6:47	6:53	0:06	LINE FAULT
431	6-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	6:48	6:54	0:06	LINE FAULT
432	6-Oct-2021	GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP,KARE POWER_IPP	4:40	4:58	0:18	LINE FAULT
433	6-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	0:25	7:30	7:05	LINE FAULT
434	6-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	3:40	3:50	0:10	LINE FAULT
435	6-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	8:45	8:50	0:05	LINE FAULT
436	6-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	18:35(06.10.2021)			LINE OPEN:LINE FAULT
437	6-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,DEODURGA_110,GABBUR_110	16:55	17:15	0:20	LINE FAULT
438	6-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:50(05.10.2021)	10:53(06.10.2021)	19:06HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
439	6-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	18:44	18:48	0:04	LINE FAULT
440	6-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	18:40(05.10.2021)	07:25(06. 10.2021)	12:45HRS	LINE CHARGED
441	6-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_ 110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	0:39	0:49	0:10	LINE FAULT
442	6-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_ 110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	1:40	1:50	0:10	LINE FAULT
443	6-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	5:50	7:25	1:35	LINE CLEAR AVAILED
444	6-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_11 0,SDAIDHAPUR_110,SANATHI_I PP,CORE GREEN SUGAR_IPP	19:08	19:19	0:11	LINE FAULT
445	6-Oct-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:40	19:46	0:06	LINE FAULT
446	6-Oct-2021	GULBARGA	110	SHAHAPUR-WARDA SOLAR_IPP	SHAHAPUR_220	22:47	23:14	0:27	LINE FAULT
447	6-Oct-2021	GULBARGA	110	ITTAGI-CLAEN MAX SOLAR-1_IPP	ITTAGI_220	18:04	19:57	1:53	LINE FAULT
448	6-Oct-2021	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	4:55	5:05	0:10	LINE FAULT
449	6-Oct-2021	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	5:57	6:45	0:48	LINE FAULT
450	6-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	22:35	22:40	0:05	LINE FAULT
451	6-Oct-2021	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	0:50	11:05	10:15	LINE CLEAR AVAILED
452	6-Oct-2021	GULBARGA	110	HV1	KUDITINI_110	15:16	15:40	0:24	TRANSFORMER FAULT
453	6-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_11 0	18:50	18:55	0:05	LINE FAULT
454	6-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_11 0	19:10	19:50	0:40	MAIN SUPPLY FAILURE
455	6-Oct-2021	GULBARGA	110	HV1	DEODURGA_110	11:30	12:35	1:05	LINE CLEAR AVAILED
456	6-Oct-2021	GULBARGA	110	HV2	DEODURGA_110	16:50	17:15	0:25	TRANSFORMER FAULT
457	6-Oct-2021	GULBARGA	110	SIRIGERICROSS-SINDHNOOR	SIRIGERICROSS_110	19:15	19:30	0:15	MAIN SUPPLY FAILURE
458	6-Oct-2021	GULBARGA	110	HV2	SIRIGERICROSS_110	18:15	19:00	0:45	TRANSFORMER FAULT
459	6-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRSHWAR_110	21:15	21:25	0:10	LINE FAULT
460	6-Oct-2021	GULBARGA	110	MANGALUR-BEVOOR	MANGALUR_110	4:00	4:30	0:30	MAIN SUPPLY FAILURE
461	6-Oct-2021	GULBARGA	110	MANGALUR-BEVOOR	MANGALUR_110	5:00	8:20	3:20	MAIN SUPPLY FAILURE
462	6-Oct-2021	GULBARGA	110	SINDANOOR-BENNUR	BENNUR_110	0:00	7:50	7:50	MAIN SUPPLY FAILURE
463	6-Oct-2021	GULBARGA	110	HV2	BISLAHALLI_110	17:17	17:26	0:09	LINE CLEAR AVAILED
464	6-Oct-2021	GULBARGA	110	HV1	HALKUNDI_110	15:25	16:45	1:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
465	6-Oct-2021	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
466	6-Oct-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:20 (4.10.2021)	16:57 (6.10.2021)	55:36 hrs	LINE CHARGED
467	6-Oct-2021	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	9:20 (4.10.2021)	16:07(6.10.2021)	54:46 hrs	LINE CHARGED
468	6-Oct-2021	HASSAN	66	LV1	MRSMSG_220	9:39(4.10.2021)	14:35(06.10.2021)	52:55 hrs	LINE CHARGED
469	6-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	18:35(05.10.2021)	11:23(06.10.2021)	16:47 hrs	LINE CHARGED
470	6-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
471	6-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
472	6-Oct-2021	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	13:05 (4.10.2021)			LINE OPEN:LINE FAULT
473	6-Oct-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:01(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
474	6-Oct-2021	HASSAN	110	JOG-JLT4	mghejog_gen	9:25(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
475	6-Oct-2021	HASSAN	110	LPH-JLT4	lph_gen	9:25(05.10.2021)			LINE OPEN:LINE CLEAR AVAILED
476	6-Oct-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	4:48 (6.10.2021)			LINE OPEN:LINE FAULT
477	6-Oct-2021	HASSAN	110	HV2	BHADRAVATHI_110	13:20(06.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
478	6-Oct-2021	HASSAN	110	HV2	KAVOOR_220	15:00	17:03	2:03	LINE CLEAR AVAILED
479	6-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:35	18:58	0:23	LINE FAULT
480	6-Oct-2021	HASSAN	110	LV3	MRSMSG_220	8:19	14:33	6:14	LINE CLEAR AVAILED
481	6-Oct-2021	HASSAN	220	SHTAVTY-TALAGUPPA1	sharavathy_gen	11:06	12:32	1:26	LINE CLEAR AVAILED
482	6-Oct-2021	HASSAN	66	CRPTNA-MATTANAVILE	CHANNARAYAPATNA_66	9:16	9:40	0:24	LINE FAULT
483	6-Oct-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:20	15:40	0:20	LINE FAULT
484	6-Oct-2021	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	15:15	17:55	2:40	NFBC ISSUED
485	6-Oct-2021	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	9:16	9:40	0:24	MAIN SUPPLY FAILURE
486	6-Oct-2021	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66	4:53	5:04	22:44	LINE FAULT
487	6-Oct-2021	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66	6:27	6:36	0:09	LINE FAULT
488	6-Oct-2021	MYSURU	66	SFC SHIVA-PGL	NO STATIONS EFFECTED	3:15	3:21	0:06	LINE FAULT
489	6-Oct-2021	MYSURU	66	VAJMANGALA-KADKOLA 2	NO STATIONS EFFECTED	6:27	18:31	12:04	LINE FAULT
490	6-Oct-2021	MYSURU	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	10:12	18:49	8:37	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
491	6-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42			LINE OPEN:LINE CLEAR AVAILED
492	6-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
493	6-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
494	6-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
495	6-Oct-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	20:13	21:51	1:37	MAIN SUPPLY FAILURE
496	6-Oct-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	20:02	20:13	0:10	MAIN SUPPLY FAILURE
497	6-Oct-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	21:25	21:31	0:06	LINE FAULT
498	6-Oct-2021	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	13:50	13:54	0:04	LINE FAULT
499	6-Oct-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:45	10:54	0:09	LINE FAULT
500	6-Oct-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:22	17:32	0:09	LINE FAULT
501	6-Oct-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:33	17:44	0:10	LINE FAULT
502	6-Oct-2021	TUMKUR	66	TR-2	HOSAKERE_66	18:59	20:21	1:22	MAIN SUPPLY FAILURE
503	6-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:02	12:03	0:00	LINE FAULT
504	6-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:18	12:22	0:03	LINE FAULT
505	6-Oct-2021	TUMKUR	66	TR-1	PAVAGADA_66	10:17	10:27	0:10	MAIN SUPPLY FAILURE
506	6-Oct-2021	TUMKUR	66	TR-1	PAVAGADA_66	20:54	22:38	1:43	MAIN SUPPLY FAILURE
507	6-Oct-2021	TUMKUR	66	TR-2	PAVAGADA_66	21:25	22:20	0:55	MAIN SUPPLY FAILURE
508	6-Oct-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	14:18	14:58	0:39	LINE FAULT
509	6-Oct-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	14:18	14:58	0:39	LINE FAULT
510	6-Oct-2021	TUMKUR	66	SOKKE 66-JAGLUR66	SOKKE_66	22:31	22:36	0:04	HAND TRIPPED
1	7-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	7-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
3	7-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
4	7-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
5	7-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
6	7-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
7	7-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
8	7-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
9	7-Oct-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
10	7-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
11	7-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
12	7-Oct-2021	BAGALKOT	110	KARAWAR220-ARGA	ARGA_110	18:03 (06.10.2021)	10:48 (7.10.2021)	16:45HRS	LINE CHARGED
13	7-Oct-2021	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	17:34 (06.10.2021)	16:03 (7.10.2021)	22:29HRS	LINE CHARGED
14	7-Oct-2021	BAGALKOT	220	HUBLI- NAGJHARI2	HUBLI_220	17:34 (06.10.2021)	16:03 (07.10.2021)	22:29HRS	LINE CHARGED
15	7-Oct-2021	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	7:52	7:57	0:05	HAND TRIPPED
16	7-Oct-2021	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	16:37	16:45	0:08	HAND TRIPPED
17	7-Oct-2021	BAGALKOT	110	110/11KV,HV1&HV2	ANAND NAGAR_110	9:59	17:22	7:23	LINE CLEAR AVAILED
18	7-Oct-2021	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	21:16	22:07	0:51	HAND TRIPPED
19	7-Oct-2021	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	21:17	22:09	0:52	HAND TRIPPED
20	7-Oct-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI((RAMPUR)	NIDAGUNDI_110	18:49	20:40	1:51	LOAD CURTAILMENT
21	7-Oct-2021	BAGALKOT	220	BIJAPUR-NANDYAL1(BAGEWADI1)	BIJAPUR_220	11:27	14:56	3:29	LINE CLEAR AVAILED
22	7-Oct-2021	BAGALKOT	220	BIJAPUR-NANDYAL2(BAGEWADI2)	BIJAPUR_220	14:47	15:18	0:31	LINE CLEAR AVAILED
23	7-Oct-2021	BAGALKOT	220	BIJAPUR-VAISHALI 1	BIJAPUR_220	14:56	16:25	1:29	LINE CLEAR AVAILED
24	7-Oct-2021	BAGALKOT	220	BIJAPUR-VAISHALI 2	BIJAPUR_220	16:27 (7.10.2021)			LINE OPEN:LINE CLEAR AVAILED
25	7-Oct-2021	BAGALKOT	220	BIJAPUR-VAISHALI 2	BIJAPUR_220	14:49	14:58	0:09	LINE CLEAR AVAILED
26	7-Oct-2021	BAGALKOT	220	BIJAPUR-INDI 1&2	BIJAPUR_220	14:54	14:57	0:03	LINE CLEAR AVAILED
27	7-Oct-2021	BAGALKOT	110	BIJAPUR220-BIJAPUR	BIJAPUR_110	10:57	11:03	0:06	LINE FAULT
28	7-Oct-2021	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	18:15	20:05	1:50	LINE CLEAR AVAILED
29	7-Oct-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRGAD_110	18:25	18:30	0:05	LOAD CURTAILMENT
30	7-Oct-2021	BAGALKOT	110	110/11KV,HV1	HANAGAL_110	18:20	18:43	0:23	LOAD CURTAILMENT
31	7-Oct-2021	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	14:17	14:44	0:27	LINE FAULT
32	7-Oct-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	18:48	19:42	0:54	HAND TRIPPED
33	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	8:10	8:21	0:11	TRANSFORMER FAULT
34	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:25	18:34	0:09	LOAD CURTAILMENT
35	7-Oct-2021	BAGALKOT	110	TARIHAL- IDLE (KIADB GAMANGATTI)	TARIHAL_110	12:15	13:40	1:25	LINE CLEAR AVAILED
36	7-Oct-2021	BAGALKOT	110	TAKKALAKI- WARADA SOLAR	TAKKALAKI_110	14:49	14:58	0:09	HAND TRIPPED
37	7-Oct-2021	BAGALKOT	110	TAKKALAKI- KN SOLAR	TAKKALAKI_110	14:49	14:58	0:09	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
38	7-Oct-2021	BAGALKOT	110	SHIRAHATTI- LAXMESHWAR	LAXMESHWAR_110	20:39	21:02	0:23	LINE FAULT
39	7-Oct-2021	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110, KALABILAGI_33	18:25	18:52	0:27	LOAD CURTAILMENT
40	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	18:47	20:20	1:33	TRANSFORMER FAULT
41	7-Oct-2021	BAGALKOT	110	RANEENNUR220- AREMALLAPUR (HONNATTI)	HONNATTI_110	7:29	7:39	0:10	LINE FAULT
42	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	MUNDUGNUR_110	18:20	18:37	0:17	LOAD CURTAILMENT
43	7-Oct-2021	BAGALKOT	110	LAXMESHWAR- BELLATTI	BELLATTI_110	20:39	21:52	1:13	LINE FAULT
44	7-Oct-2021	BAGALKOT	110	110/33KV, HV1	LAXMESHWAR_110, SSM_33, MMCL_33	18:25	18:32	0:07	LOAD CURTAILMENT
45	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	KULGERI CROSS_110	13:12	14:25	1:13	LINE CLEAR AVAILED
46	7-Oct-2021	BAGALKOT	110	110/11KV, HV2	KULGERI CROSS_110	13:12	14:25	1:13	LINE CLEAR AVAILED
47	7-Oct-2021	BAGALKOT	110	KUDAL SANGAM- HUNGUND	KUDALSANGAM_110	6:20	6:46	0:26	LINE FAULT
48	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	KUDALSANGAM_110	18:20	18:42	0:22	LOAD CURTAILMENT
49	7-Oct-2021	BAGALKOT	220	KUDACHI- CHIKKODI1	KUDACHI_220	3:22	4:27	1:05	LINE FAULT
50	7-Oct-2021	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	3:22	15:14	11:52	LINE FAULT
51	7-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, KUDACHI_110, AINAPUR_110, UGARKHUD_110, YELPARHATTI_110, TERDAL_110	3:22	4:19	0:57	TRANSFORMER FAULT
52	7-Oct-2021	BAGALKOT	220	220/110KV, HV2&LV2	KUDACHI_220, KUDACHI_110, AINAPUR_110, UGARKHUD_110, YELPARHATTI_110, TERDAL_110	3:22	4:22	1:00	TRANSFORMER FAULT
53	7-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
54	7-Oct-2021	BAGALKOT	110	KERUR- KONNUR (KULGERI CROSS)	KERUR_110	19:40	19:47	0:07	HAND TRIPPED
55	7-Oct-2021	BAGALKOT	110	KIRUVATTI- UMMACHAGI	UMMACHAGI_110	8:59	18:25	9:26	NFBC ISSUED
56	7-Oct-2021	BAGALKOT	110	HUNGUND- KUDAL SANGAM	HUNGUND_110	6:20	6:30	0:10	LINE FAULT
57	7-Oct-2021	BAGALKOT	110	BELGAUM220- HUDLI	HUDLI_110	18:59	20:11	1:12	LINE CLEAR AVAILED
58	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	6:39	6:52	0:13	TRANSFORMER FAULT
59	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	16:27	17:21	0:54	LINE CLEAR AVAILED
60	7-Oct-2021	BAGALKOT	110	110/33KV, HV3	HIDIKAL_110, KOLIGUDDA_33, ALAGAWAD_33	18:20	18:34	0:14	LOAD CURTAILMENT
61	7-Oct-2021	BAGALKOT	110	CHIKKODI220- ANKALI	ANKALI_110	3:25	3:50	0:25	LINE FAULT
62	7-Oct-2021	BAGALKOT	110	CHIKKODI220- ANKALI	ANKALI_110	10:35	12:05	1:30	LINE CLEAR AVAILED
63	7-Oct-2021	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	16:36	16:57	0:21	LINE FAULT
64	7-Oct-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	9:48	15:51	6:03	LINE CLEAR AVAILED
65	7-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	9:49	15:52	6:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
66	7-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	HUBLI_220	11:36	17:19	5:43	TRANSFORMER FAULT
67	7-Oct-2021	BAGALKOT	220	220/110KV, HV2&LV2	HUBLI_220	11:36	13:54	2:18	TRANSFORMER FAULT
68	7-Oct-2021	BAGALKOT	110	HUBLI220- ANAND NAGAR	ANAND NAGAR_110	10:10	18:27	8:17	LINE CLEAR AVAILED
69	7-Oct-2021	BAGALKOT	110	HUBLI- TARIHAL1&2	TARIHAL_110	11:36	12:05	0:29	HAND TRIPPED
70	7-Oct-2021	BAGALKOT	110	HUBLI- PH COMPOUND	PH COMPOUND_110	11:36	12:05	0:29	HAND TRIPPED
71	7-Oct-2021	BAGALKOT	110	110/11KV, HV1&HV2	HUBLI_220	11:36	12:05	0:29	HAND TRIPPED
72	7-Oct-2021	BAGALKOT	110	BAGALKOT220-KATARKI (NEERABUDIHAI)	NEERABUDIHAI_110	5:58	6:07	0:09	LINE FAULT
73	7-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
74	7-Oct-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
75	7-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
76	7-Oct-2021	BAGALKOT	110	BAGALKOT220- RAMDURGA	RAMDURGA_110	18:40	21:03	2:23	LINE FAULT
77	7-Oct-2021	BAGALKOT	110	110/33KV, HV2	KONNUR_110	18:50	19:40	0:50	MAIN SUPPLY FAILURE
78	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	18:50	19:40	0:50	MAIN SUPPLY FAILURE
79	7-Oct-2021	BAGALKOT	110	BIDNAL220- NARAGUND	NARAGUND_110	18:50	19:40	0:50	MAIN SUPPLY FAILURE
80	7-Oct-2021	BAGALKOT	110	BIDNAL220- KONNUR	KONNUR_110	18:50	19:40	0:50	MAIN SUPPLY FAILURE
81	7-Oct-2021	BAGALKOT	110	110/11KV, HV1&HV2	SINGATALUR_110	18:10	18:15	0:05	MAIN SUPPLY FAILURE
82	7-Oct-2021	BAGALKOT	110	110/11KV, HV1	BELLATTI_110	20:40	21:55	1:15	MAIN SUPPLY FAILURE
83	7-Oct-2021	BAGALKOT	110	110/11KV, HV2	BELLATTI_110	20:40	21:55	1:15	MAIN SUPPLY FAILURE
84	7-Oct-2021	BAGALKOT	110	110/33KV, HV2	BELLATTI_110	20:40	21:55	1:15	MAIN SUPPLY FAILURE
85	7-Oct-2021	BAGALKOT	110	MUNDARAGI-SINGATALUR	MUNDARAGI_110	18:10	18:15	0:05	LINE FAULT
86	7-Oct-2021	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	9:15	18:25	9:10	LINE CLEAR AVAILED
87	7-Oct-2021	BAGALKOT	220	SAVALSANG WIND-INDI	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE
88	7-Oct-2021	BAGALKOT	220	INDI-BIJAPUR1	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE
89	7-Oct-2021	BAGALKOT	220	INDI-BIJAPUR2	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE
90	7-Oct-2021	BAGALKOT	110	INDI-DEVAR HIPPARAGI	DEVARAHIPPARAGI_110 ,ATHARGA_110, HIREMASLI_110	14:47	14:57	0:10	MAIN SUPPLY FAILURE
91	7-Oct-2021	BAGALKOT	110	INDI220-INDI	INDI_110	14:47	14:57	0:10	MAIN SUPPLY FAILURE
92	7-Oct-2021	BAGALKOT	110	INDI-LACHYAN	LACHYAN_110HIREBEVANUR_1 10, RODAGI_110	14:47	14:57	0:10	MAIN SUPPLY FAILURE
93	7-Oct-2021	BAGALKOT	110	INDI-ZALKI1&2	ZALKI_110, INCHIGERI_110,CHADCHAN_11 0	14:47	14:57	0:10	MAIN SUPPLY FAILURE
94	7-Oct-2021	BAGALKOT	110	110/11KV,HV1	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE
95	7-Oct-2021	BAGALKOT	110	110/11KV,HV2	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE
96	7-Oct-2021	BAGALKOT	220	220/110KV,HV1	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE
97	7-Oct-2021	BAGALKOT	220	220/110KV,HV2	INDI_220	14:47	14:57	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
98	7-Oct-2021	BAGALKOT	110	INDI-DEVAR HIPPARAGI	DEVARAHIPPARAGI_110 ,ATHARGA_110, HIREMASLI_110	20:47	20:52	0:05	LINE FAULT
99	7-Oct-2021	BAGALKOT	110	INDI-LACHYAN	LACHYAN_110,HIREBEVANUR_1 10, RODAGI_110	20:47	20:52	0:05	LINE FAULT
100	7-Oct-2021	BAGALKOT	110	INDI-ZALKI2	ZALKI_110, INCHIGERI_110,CHADCHAN_11 0	20:47	20:52	0:05	LINE FAULT
101	7-Oct-2021	BAGALKOT	110	CHIKKODI220-SHANKESHWAR	SHANKESHWAR_110	16:35	16:55	0:20	MAIN SUPPLY FAILURE
102	7-Oct-2021	BAGALKOT	110	SHANKESHWAR-HUKKERI	HUKKERI_110	16:35	17:00	0:25	MAIN SUPPLY FAILURE
103	7-Oct-2021	BAGALKOT	220	ATHANI- KUDACHI	ATHANI_220	3:20	15:21	12:01	LINE FAULT
104	7-Oct-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	11:00	11:45	0:45	LINE CLEAR AVAILED
105	7-Oct-2021	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	10:15	10:45	0:30	LOAD CHANGEOVER
106	7-Oct-2021	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	19:12	19:17	0:05	LOAD CHANGEOVER
107	7-Oct-2021	BENGALURU	66	BMTC- NIMHANS 220	BMTC	11:10	11:13	0:03	LOAD CHANGEOVER
108	7-Oct-2021	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	11:20	16:28	5:08	LINE CLEAR AVAILED
109	7-Oct-2021	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	14:35	16:40	2:05	LINE CLEAR AVAILED
110	7-Oct-2021	BENGALURU	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	10:00	12:45	2:45	LINE CLEAR AVAILED
111	7-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	1:02	1:19	0:17	LINE FAULT
112	7-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	10:29	10:33	0:04	LINE FAULT
113	7-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	15:47	15:52	0:05	LINE FAULT
114	7-Oct-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	1:02	1:20	0:18	LINE FAULT
115	7-Oct-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	10:29	10:34	0:05	LINE FAULT
116	7-Oct-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	15:47	15:52	0:05	LINE FAULT
117	7-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - PEENYA 2	SAHAKARNAGAR	9:21	9:39	0:18	LINE FAULT
118	7-Oct-2021	BENGALURU	66	HV1	V R DODDI	23:16	23:23	0:07	TRANSFORMER FAULT
119	7-Oct-2021	BENGALURU	66	HV1	V R DODDI	23:43	23:49	0:06	TRANSFORMER FAULT
120	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS	15:13	16:22	1:09	MAIN SUPPLY FAILURE
121	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	15:13	18:15	3:02	MAIN SUPPLY FAILURE
122	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	15:13	18:15	3:02	MAIN SUPPLY FAILURE
123	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	15:13	18:15	3:02	MAIN SUPPLY FAILURE
124	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	15:13	16:35	1:22	MAIN SUPPLY FAILURE
125	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	15:13	16:20	1:07	MAIN SUPPLY FAILURE
126	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	15:13	18:15	3:02	MAIN SUPPLY FAILURE
127	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	15:13	16:30	1:17	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
128	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	15:13	18:15	3:02	MAIN SUPPLY FAILURE
129	7-Oct-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	15:13	16:45	1:32	MAIN SUPPLY FAILURE
130	7-Oct-2021	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	15:13	18:12	2:59	LINE FAULT
131	7-Oct-2021	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	15:13	18:15	3:02	LINE CLEAR AVAILED
132	7-Oct-2021	BENGALURU	220	HV1	CHINTAMANI 220	15:13	18:15	3:02	MAIN SUPPLY FAILURE
133	7-Oct-2021	BENGALURU	220	HV2	CHINTAMANI 220	15:13	18:15	3:02	MAIN SUPPLY FAILURE
134	7-Oct-2021	BENGALURU	66	T GOLAHALLI 220 - NANGLI	BAIRAKURU, NANGALI	13:40	13:42	0:02	LOAD CHANGEOVER
135	7-Oct-2021	BENGALURU	66	T GOLAHALLI 220 - NANGLI	BAIRAKURU, NANGALI	14:38	14:40	0:02	LOAD CHANGEOVER
136	7-Oct-2021	BENGALURU	66	T GOLAHALLI 220 - THYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:50	14:40	0:50	LINE CLEAR AVAILED
137	7-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:27	19:30	1:03	LOAD CURTAILMENT
138	7-Oct-2021	BENGALURU	66	KOLAR 220 - THAYLUR	NO STATION AFFECTED	11:00	11:10	0:10	LINE FAULT
139	7-Oct-2021	BENGALURU	66	MELUR - VIJAYAPURA	MELUR	21:25	21:40	0:15	LOAD CHANGEOVER
140	7-Oct-2021	BENGALURU	66	HV2	ANEKAL	11:16	11:48	0:32	LINE CLEAR AVAILED
141	7-Oct-2021	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	22:12	22:21	0:08	LINE FAULT
142	7-Oct-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	12:40	15:45	3:05	LINE CLEAR AVAILED
143	7-Oct-2021	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	18:31	19:25	0:54	LOAD CURTAILMENT
144	7-Oct-2021	BENGALURU	66	MALLASANDRA - DALSANUR	DALSANUR, YELDUR, SRINIVASPURA	18:20	19:25	1:05	LOAD CURTAILMENT
145	7-Oct-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:36	19:25	0:48	LOAD CURTAILMENT
146	7-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	22:12	22:19	0:06	LINE FAULT
147	7-Oct-2021	BENGALURU	66	TEKAL - MALUR 220	TEKAL, TORALAKKI, BOODIKOTE, KAMASAMUDRA	12:31	12:45	0:13	LINE CLEAR AVAILED
148	7-Oct-2021	BENGALURU	66	HV2	THIMMAMPALLI	22:38	22:47	0:09	TRANSFORMER FAULT
149	7-Oct-2021	BENGALURU	66	HV1	VIDYANAGAR	10:38	11:58	1:19	LINE CLEAR AVAILED
150	7-Oct-2021	BENGALURU	66	HV1	SM MANGALA	11:15	18:45	7:30	LINE CLEAR AVAILED
151	7-Oct-2021	BENGALURU	66	CHINTAMANI 66 - SM MANGALA	CHINTAMANI 66	19:40	19:45	0:05	LOAD CHANGEOVER
152	7-Oct-2021	BENGALURU	66	SIDDLAGHATTA - MELUR	SIDLAGHATTA	19:15	19:20	0:05	LOAD CHANGEOVER
153	7-Oct-2021	BENGALURU	66	TALAGWARA - KYALANUR	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:30	18:35	0:05	LOAD CHANGEOVER
154	7-Oct-2021	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	8:35	13:43	5:08	LINE CLEAR AVAILED
155	7-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:35(05.10.2021)	6:57(07.10.2021)	53:22HRS	LINE CHARGED
156	7-Oct-2021	GULBARGA	400	BTPSG-RTPS	BTPSG_400	3:39	13:32	0:10	LINE FAULT
157	7-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
158	7-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	23:51(06.10.2021)	00:01(07.10.2021)	0:10	LINE CHARGED
159	7-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	3:58	11:37	7:39	LINE CLEAR AVAILED
160	7-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	0:52	6:03	5:11	LINE FAULT
161	7-Oct-2021	GULBARGA	220	HV1	SEDAM_220	23:55(07.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
162	7-Oct-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:05			LINE OPEN:LINE FAULT
163	7-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
164	7-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
165	7-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	4:28	4:36	0:08	LINE FAULT
166	7-Oct-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAO N_110,DIGGI_110	3:32	3:40	0:08	LINE FAULT
167	7-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	18:35(06.10.2021)	07:30(07.10.2021)	12:55HRS	LINE CHARGED
168	7-Oct-2021	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	6:52	7:05	0:13	LINE FAULT
169	7-Oct-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	18:12	18:23	0:11	LINE FAULT
170	7-Oct-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	18:12	18:24	0:12	LINE FAULT
171	7-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110, SDAIDHAPUR_110,SANATHI_I PP,CORE GREEN SUGAR_IPP	20:54	21:07	0:13	LINE FAULT
172	7-Oct-2021	GULBARGA	110	HV1	ADAVI AMARESHWAR_110	7:35	7:55	0:20	LINE CLEAR AVAILED
173	7-Oct-2021	GULBARGA	110	HV1,HV2	MYLAR_66	7:02	7:36	0:34	LINE CLEAR AVAILED
174	7-Oct-2021	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	4:53	4:58	0:05	LINE FAULT
175	7-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRSHWAR_110	5:00	5:10	0:10	LINE FAULT
176	7-Oct-2021	GULBARGA	110	HV2	HATTI_110	7:16	7:20	0:04	TRANSFORMER FAULT
177	7-Oct-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA_110	0:45	0:54	0:09	LINE FAULT
178	7-Oct-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA_110	0:45	0:54	0:09	LINE FAULT
179	7-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:19	22:25	0:06	LINE FAULT
180	7-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	21:05	21:11	0:06	LINE FAULT
181	7-Oct-2021	GULBARGA	110	BELLARY NORTH-BISILAHALLI	BISILAHALLI_110	11:01	11:23	0:22	MAIN SUPPLY FAILURE
182	7-Oct-2021	GULBARGA	110	HV3	CHIDRI_110	18:25	18:32	0:07	TRANSFORMER FAULT
183	7-Oct-2021	GULBARGA	110	BELLARY SOUTH-HALAKUNDI	HALAKUNDI_110	11:10	11:25	0:15	MAIN SUPPLY FAILURE
184	7-Oct-2021	GULBARGA	110	VADAVATTI-YAPALDINI	YAPALDINI_110	2:25	2:30	0:05	MAIN SUPPLY FAILURE
185	7-Oct-2021	GULBARGA	110	HV2	HATTI_110	7:16	7:20	0:04	TRANSFORMER FAULT
186	7-Oct-2021	GULBARGA	110	HUNSAGI-KEMBHAVI	KEMBHAVI_110	20:20	20:40	0:20	MAIN SUPPLY FAILURE
187	7-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRSHWAR_110	5:00	5:10	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
188	7-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	11:48	11:58	0:10	LINE FAULT
189	7-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	20:32	20:42	0:10	LINE FAULT
190	7-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	22:57	23:07	0:10	LINE FAULT
191	7-Oct-2021	GULBARGA	110	HUMNABAD-HUMNABAD1	MANEKAHALLI_110	6:06	6:14	0:08	LINE FAULT
192	7-Oct-2021	GULBARGA	110	HV1	HUMNABAD_220	10:58	11:02	0:04	TRANSFORMER FAULT
193	7-Oct-2021	GULBARGA	110	HV4	YELBURGA_110	18:25	19:45	1:20	LOAD CURTAILMENT
194	7-Oct-2021	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	12:10	13:10	1:00	LINE CLEAR AVAILED
195	7-Oct-2021	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	4:02	4:11	0:09	LINE FAULT
196	7-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:01	5:03	0:02	LINE FAULT
197	7-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:58	12:05	0:07	LINE FAULT
198	7-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	23:55(07.10.2021)			LINE OPEN:LINE FAULT
199	7-Oct-2021	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
200	7-Oct-2021	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	0:15	0:21	0:06	LINE FAULT
201	7-Oct-2021	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	0:33	2:03	1:30	LINE FAULT
202	7-Oct-2021	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66	0:21	0:30	0:09	LINE FAULT
203	7-Oct-2021	GULBARGA	66	HV2	BENNEHALLI_66	1:10	6:00	4:50	TRANSFORMER FAULT
204	7-Oct-2021	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	6:00	6:30	0:30	LINE FAULT
205	7-Oct-2021	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	18:35	19:00	0:25	LINE FAULT
206	7-Oct-2021	GULBARGA	66	KUDLIGI-CHORNOOR	CHORNOOR_66	18:40	19:10	0:30	LINE FAULT
207	7-Oct-2021	GULBARGA	66	MUNIRABAD-MSD LINE	HANSI_66	19:44(07.10.2021)			LINE OPEN:LINE FAULT
208	7-Oct-2021	GULBARGA	66	MUNIRABAD-TIE LINE_IPP	MUNIRABAD_220	19:50	20:05	0:15	LINE FAULT
209	7-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
210	7-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
211	7-Oct-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	13:05 (4.10.2021)			LINE OPEN:LINE FAULT
212	7-Oct-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:01(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
213	7-Oct-2021	HASSAN	110	HV2	BHADRAVATHI_110	13:20(06.10.2021)	12:55(07.10.2021)	23:35hrs	TRANSFORMER CHARGED
214	7-Oct-2021	HASSAN	400	TALAGU-NELAMANG2	TALAGUPP_400	4:48 (6.10.2021)	18:25 (7.10.2021)	37:37hrs	LINE CHARGED
215	7-Oct-2021	HASSAN	110	JOG-JLT4	mghejog_gen	9:25(05.10.2021)	18:56 (7.10.2021)	57:31hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
216	7-Oct-2021	HASSAN	110	LPH-JLT4	lph_gen	9:25(05.10.2021)	18:56 (7.10.2021)	57:31hrs	LINE CHARGED
217	7-Oct-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	8:40 (7.10.2021)			LINE OPEN:LINE CLEAR AVAILED
218	7-Oct-2021	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	15:28	17:58	2:30	LINE CLEAR AVAILED
219	7-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	12:19	14:59	2:40	LINE FAULT
220	7-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:25	13:44	0:19	LINE FAULT
221	7-Oct-2021	HASSAN	110	LV3	MRSMSG_220	8:47	18:39	9:52	LINE CLEAR AVAILED
222	7-Oct-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	15:28	17:58	2:30	NFBC ISSUED
223	7-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	13:25	13:44	0:19	LINE FAULT
224	7-Oct-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	12:19	14:59	2:40	LINE FAULT
225	7-Oct-2021	HASSAN	110	HV2	HALADY_110	3:50	4:05	0:15	HAND TRIPPED
226	7-Oct-2021	HASSAN	110	HV2	HALADY_110	9:53	16:23	6:30	LINE CLEAR AVAILED
227	7-Oct-2021	HASSAN	110	HV1	JOG_110	9:19	18:03	8:44	LINE CLEAR AVAILED
228	7-Oct-2021	HASSAN	110	HV2	JOG_110	9:19	18:04	8:45	LINE CLEAR AVAILED
229	7-Oct-2021	HASSAN	110	HV2	KADUR_220	11:32	12:59	1:27	TRANSFORMER FAULT
230	7-Oct-2021	HASSAN	110	HV1	KARAYA_110	8:57	9:15	0:18	HAND TRIPPED
231	7-Oct-2021	HASSAN	110	HV2	KARAYA_110	8:57	9:15	0:18	HAND TRIPPED
232	7-Oct-2021	HASSAN	110	LPH-LST3	lph_gen	9:32	15:29	5:57	LINE CLEAR AVAILED
233	7-Oct-2021	HASSAN	110	LPH-LST4	lph_gen	15:31	18:40	3:09	LINE CLEAR AVAILED
234	7-Oct-2021	HASSAN	110	SAGARA-LST4	SAGARA_110	15:32	18:40	3:08	MAIN SUPPLY FAILURE
235	7-Oct-2021	MYSURU	66	ADDIHALLI-BG NAGARA	HARADANAHALLI(JAK)_66 BGNAGARA_66 VADERALLI_66 ADICHUNCHANAGIRI_66	14:22	15:34	22:44	LINE CLEAR AVAILED
236	7-Oct-2021	MYSURU	66	JAKKANAHALLI-NAGAMANGALA	GUDDENAHALLI_66 G MALLIGERE_66 BOGADHI_66	13:35	15:35	2:00	LINE CLEAR AVAILED
237	7-Oct-2021	MYSURU	66	NAGAMANGALA-TUBINKERE	NAGAMANGALA_66	13:02	13:30	0:27	LINE FAULT
238	7-Oct-2021	MYSURU	66	NAGAMANGALA-TUBINKERE	NAGAMANGALA_66	13:45	18:31	4:46	NFBC ISSUED
239	7-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	HARADANAHALLI(JAK)_66 BGNAGARA_66 VADERALLI_66 ADICHUNCHANAGIRI_66 NAGAMANGALA_66 ADDIHALLI_66 HARIYALDAMMATemple_66 SANTHEBACHALLI_66	11:09	18:49	7:39	LINE FAULT
240	7-Oct-2021	MYSURU	66	COWDALLI-MARTHALLI	RAMAPURA_MYS MARTAHALLI_66	22:49	22:52	0:03	LINE FAULT
241	7-Oct-2021	MYSURU	66	HALAGUR-TK HALLI	HALAGUR_66	4:42	5:19	0:37	HAND TRIPPED
242	7-Oct-2021	MYSURU	66	HV1	HANAGODU_66	14:54	15:51	0:56	LINE CLEAR AVAILED
243	7-Oct-2021	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	PGPALYA_66 LOKKANAHALLI_66	21:39	21:48	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
244	7-Oct-2021	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALI_66BGPURA_66	6:40	6:57	0:17	LINE FAULT
245	7-Oct-2021	MYSURU	66	HV2	PONNAMPET_66	10:20	10:31	0:10	TRANSFORMER FAULT
246	7-Oct-2021	MYSURU	66	HV1	SANIVARASANTHE_66	10:43	10:49	0:06	LINE CLEAR AVAILED
247	7-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42			LINE OPEN:LINE CLEAR AVAILED
248	7-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
249	7-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
250	7-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
251	7-Oct-2021	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA220 2	MADHUGIRI 220kV	23:43	23:50	0:07	LINE FAULT
252	7-Oct-2021	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI 220kV	23:10	23:56	0:45	TRANSFORMER FAULT
253	7-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI 220kV	23:10	23:57	0:47	TRANSFORMER FAULT
254	7-Oct-2021	TUMKUR	220	TR-2(HV SIDE)	KIADB V N PURA_220	10:30	16:03	5:33	LINE CLEAR AVAILED
255	7-Oct-2021	TUMKUR	110	TR-1	TURUVEKERE_110	11:20	17:35	6:15	LINE CLEAR AVAILED
256	7-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	19:25	19:58	0:33	LOAD CURTAILMENT
257	7-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA	KOLALA_66, URDIGERE_66	19:25	19:58	0:33	LOAD CURTAILMENT
258	7-Oct-2021	TUMKUR	66	TR-2	BENKIKERE_66	14:06	14:14	0:07	HAND TRIPPED
259	7-Oct-2021	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	6:11	19:18	13:07	LINE CLEAR AVAILED
260	7-Oct-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2_IPP_66	MEGMICON 2_IPP_66	1:17	2:02	0:44	HAND TRIPPED
261	7-Oct-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	6:12	6:16	0:03	LINE FAULT
262	7-Oct-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:03	6:13	0:09	LINE FAULT
263	7-Oct-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	13:42	14:01	0:19	LINE FAULT
264	7-Oct-2021	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	13:50	16:49	2:59	MAIN SUPPLY FAILURE
265	7-Oct-2021	TUMKUR	66	TR-2	HOSAKERE_66	7:40	8:21	0:40	TRANSFORMER FAULT
266	7-Oct-2021	TUMKUR	66	TR-2	HOSAKERE_66	10:59	11:07	0:08	TRANSFORMER FAULT
267	7-Oct-2021	TUMKUR	66	TR-2	HOSAKERE_66	14:05	14:15	0:09	TRANSFORMER FAULT
268	7-Oct-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	12:40	17:39	4:58	LINE CLEAR AVAILED
269	7-Oct-2021	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	13:50	16:49	2:59	MAIN SUPPLY FAILURE
270	7-Oct-2021	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	13:59	14:34	0:35	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
271	7-Oct-2021	TUMKUR	66	PAVAGADA220-MADHUGIRI 2	PAVAGADA_66	23:10	23:59	0:49	LINE FAULT
272	7-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	9:16	9:20	0:04	LINE FAULT
273	7-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:45	10:58	0:12	HAND TRIPPED
274	7-Oct-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	8:49	9:07	0:17	LINE FAULT
275	7-Oct-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	10:23	10:35	0:12	LINE FAULT
276	7-Oct-2021	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	6:14	6:41	0:27	MAIN SUPPLY FAILURE
277	7-Oct-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	6:14	6:35	0:21	MAIN SUPPLY FAILURE
278	7-Oct-2021	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	6:14	6:35	0:21	MAIN SUPPLY FAILURE
1	8-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	8-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
3	8-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
4	8-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
5	8-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
6	8-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
7	8-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
8	8-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
9	8-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
10	8-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
11	8-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
12	8-Oct-2021	BAGALKOT	220	BIJAPUR-VAISHALI 2	BIJAPUR_220	16:27 (7.10.2021)	14:03 (08.10.2021)	21:36HRS	LINE CHARGED
13	8-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
14	8-Oct-2021	BAGALKOT	110	HAVERI220- TILUVALLI (HANGAL)	HANGAL_110	11:37	11:40	0:04	LINE FAULT
15	8-Oct-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	10:56	15:43	4:47	LINE CLEAR AVAILED
16	8-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	10:57	15:40	4:43	LINE CLEAR AVAILED
17	8-Oct-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	20:00	20:06	0:06	TRANSFORMER FAULT
18	8-Oct-2021	BAGALKOT	110	HIDIKAL DAM-ANAKALGI	ANKALAGI_110	6:20	6:28	0:08	LINE FAULT
19	8-Oct-2021	BAGALKOT	110	VAJRAMATTI-JAMBAGI KD	JAMBAGI KD_110	13:16	13:31	0:15	LINE FAULT
20	8-Oct-2021	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	9:20	12:18	2:58	TRANSFORMER FAULT
21	8-Oct-2021	BAGALKOT	110	110/33KV, HV3	MANGASULI_33, SHEDBAL_33 STATION NOT AFFECTED UGARKHUD_110	6:10	6:41	0:31	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
22	8-Oct-2021	BAGALKOT	110	NARAGUND-BPCL WIND	BPCL WIND_110 STATION NOT AFFECTED NARAGUND_110	8:09	8:50	0:41	LINE FAULT
23	8-Oct-2021	BAGALKOT	110	MUNDARGI-VIJAYASUGARS	VIJAYASUGARS_110 STATION NOT AFFECTED MUNDARGI_110	9:20	21:15	11:55	LINE CLEAR AVAILED
24	8-Oct-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGOD_110	13:55	14:11	0:16	LINE CLEAR AVAILED
25	8-Oct-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KULIGOD_110	13:17	15:08	1:51	LINE CLEAR AVAILED
26	8-Oct-2021	BAGALKOT	110	KULIGOD-GAMESH WIND	GAMESH WIND_110 KULIGOD_110	14:35	15:08	0:33	HAND TRIPPED
27	8-Oct-2021	BAGALKOT	110	KERUR-KULAGERI CROSS(KONNUR)	STATION NOT AFFECTED KERUR_110	16:20	17:26	1:06	LINE CLEAR AVAILED
28	8-Oct-2021	BAGALKOT	220	BIJAPUR-BAGEWADI 1	STATION NOT AFFECTED BIJAPUR_220	12:24	15:17	2:53	LINE CLEAR AVAILED
29	8-Oct-2021	BAGALKOT	220	BIJAPUR-INDI 1	STATION NOT AFFECTED BIJAPUR_220	11:35	13:45	2:10	LINE CLEAR AVAILED
30	8-Oct-2021	BAGALKOT	220	BIJAPUR-VAISHALI 1	STATION NOT AFFECTED BIJAPUR_220	13:32	14:01	0:29	HAND TRIPPED
31	8-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
32	8-Oct-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
33	8-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
34	8-Oct-2021	BAGALKOT	220	INDI- BIJAPUR1	INDI_220	11:30	13:48	2:18	LINE CLEAR AVAILED
35	8-Oct-2021	BAGALKOT	110	110/11KV, HV1	HIDIKAL_110	14:50	15:15	0:25	LINE CLEAR AVAILED
36	8-Oct-2021	BAGALKOT	110	HAVERI220- TILUVALLI (HANGAL)	HANGAL_110	11:37	11:40	0:04	LINE FAULT
37	8-Oct-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	11:29	12:40	1:11	LINE CLEAR AVAILED
38	8-Oct-2021	BAGALKOT	110	KD JAMBAGI-MUDHOL	KD JAMBAGI_110	12:45	12:55	0:10	LINE FAULT
39	8-Oct-2021	BAGALKOT	110	MUDHOL- KD JAMBAGI	MUDHOL_110	12:45	12:55	0:10	MAIN SUPPLY FAILURE
40	8-Oct-2021	BAGALKOT	110	MANTUR - SHIROL	MANTUR_110	18:40	18:55	0:15	HAND TRIPPED
41	8-Oct-2021	BAGALKOT	110	110/11KV, HV2	DEVARGENNUR_110	12:08	12:22	0:14	TRANSFORMER FAULT
42	8-Oct-2021	BAGALKOT	110	110/11KV, HV2	DEVARGENNUR_110	14:04	14:14	0:10	TRANSFORMER FAULT
43	8-Oct-2021	BENGALURU	66	HV3	ELECTRONIC CITY	18:25	18:33	0:08	TRANSFORMER FAULT
44	8-Oct-2021	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI	10:40	15:46	5:06	LINE CLEAR AVAILED
45	8-Oct-2021	BENGALURU	66	EXORA - CESSNA	EXORA	10:05	14:08	4:03	LINE CLEAR AVAILED
46	8-Oct-2021	BENGALURU	66	CESSNA - SHOBHA CITY	CESSNA	10:30	14:05	3:35	LINE CLEAR AVAILED
47	8-Oct-2021	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	7:21	7:29	0:08	LINE FAULT
48	8-Oct-2021	BENGALURU	66	HV1	BANASAWADI	9:47	9:50	0:03	LOAD CHANGEOVER
49	8-Oct-2021	BENGALURU	66	HV3	BANASAWADI	9:47	9:50	0:03	LOAD CHANGEOVER
50	8-Oct-2021	BENGALURU	66	RAJANUKUNTE - D B PURA 220	RAJANUKUNTE	19:40	19:50	0:10	LOAD CHANGEOVER
51	8-Oct-2021	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	17:20	17:28	0:08	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
52	8-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:11	18:33	0:22	LINE FAULT
53	8-Oct-2021	BENGALURU	66	HV1	V R DODDI	0:50	1:30	0:40	TRANSFORMER FAULT
54	8-Oct-2021	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	18:25	18:33	0:08	LINE FAULT
55	8-Oct-2021	BENGALURU	66	KADUGODI -EPIP 220	KADUGODI, ARMY WELFARE, KONDASPURA	16:36	16:45	0:09	LINE CLEAR AVAIED
56	8-Oct-2021	BENGALURU	66	KADUGODI -EPIP 220	KADUGODI, ARMY WELFARE, KONDASPURA	16:52	16:55	0:03	LINE FAULT
57	8-Oct-2021	BENGALURU	66	HV1	KADUGODI	17:40	17:50	0:10	LINE CLEAR AVAIED
58	8-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	BAIRAKURU, NANGLI	2:09	3:44	1:35	LINE FAULT
59	8-Oct-2021	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 220 1	T GOLLAHALLI	2:09	9:15	7:06	LINE FAULT
60	8-Oct-2021	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 220 2	T GOLLAHALLI	2:09	3:25	1:16	LINE FAULT
61	8-Oct-2021	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 220 2	T GOLLAHALLI	8:50	9:06	0:16	LINE FAULT
62	8-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	BAIRAKURU, NANGLI	8:50	9:10	0:20	LINE CLEAR AVAIED
63	8-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	8:50	9:10	0:20	LINE CLEAR AVAIED
64	8-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - THAYALUR	THAYALUR, TAMAKA, N G HULKUR, MALLANAYAKANAHALLI	8:50	9:10	0:20	LINE CLEAR AVAIED
65	8-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	8:50	9:10	0:20	LINE CLEAR AVAIED
66	8-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	8:50	9:10	0:20	LINE CLEAR AVAIED
67	8-Oct-2021	BENGALURU	220	HV1	YELAHANKA 220	12:51	18:42	5:50	TRANSFORMER FAULT
68	8-Oct-2021	BENGALURU	220	LV1	YELAHANKA 220	12:51	18:55	6:03	TRANSFORMER FAULT
69	8-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	12:51	14:00	1:09	MAIN SUPPLY FAILURE
70	8-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	12:51	13:18	0:27	MAIN SUPPLY FAILURE
71	8-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE4/DG4	SAHAKARINAGAR, ESCORTS(EHT)YHT(8), PLATINUM CITY	12:51	13:15	0:24	MAIN SUPPLY FAILURE
72	8-Oct-2021	BENGALURU	66	HV1	YELAHANKA 220	12:51	13:11	0:20	MAIN SUPPLY FAILURE
73	8-Oct-2021	BENGALURU	66	HV2	YELAHANKA 220	12:51	13:11	0:20	MAIN SUPPLY FAILURE
74	8-Oct-2021	BENGALURU	66	WELCASTE STEEL - ABBIGERE	WELCASTE STEEL	16:44	16:49	0:05	LOAD CHANGEOVER
75	8-Oct-2021	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	18:20	18:30	0:10	LOAD CURTAILMENT
76	8-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:20	19:15	0:55	LOAD CURTAILMENT
77	8-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:15	20:00	0:45	LOAD CURTAILMENT
78	8-Oct-2021	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	18:55	19:25	0:30	LOAD CURTAILMENT
79	8-Oct-2021	BENGALURU	66	KONDASPURA - KADUGODI	KONDASPURA, ARMY WELFARE	10:40	10:50	0:10	MAIN SUPPLY FAILURE
80	8-Oct-2021	BENGALURU	66	HV1	KONDASPURA	16:10	16:30	0:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
81	8-Oct-2021	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA, ARMY WELFARE	16:20	16:30	0:10	LOAD CHANGEOVER
82	8-Oct-2021	BENGALURU	66	KONDASPURA - KADUGODI	KONDASPURA, ARMY WELFARE	16:36	16:51	0:15	MAIN SUPPLY FAILURE
83	8-Oct-2021	BENGALURU	66	KONDASPURA - KADUGODI	KONDASPURA, ARMY WELFARE	16:55	17:25	0:30	MAIN SUPPLY FAILURE
84	8-Oct-2021	BENGALURU	66	HV2	SARIAPURA 220	11:43	12:25	0:41	LINE CLEAR AVAILED
85	8-Oct-2021	BENGALURU	66	HV2	BAIRAKURU	2:09	3:51	1:41	TRANSFORMER FAULT
86	8-Oct-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	0:57	1:00	0:03	LINE FAULT
87	8-Oct-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	NO STATION AFFECTED	6:51	7:01	0:10	LINE FAULT
88	8-Oct-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:30	19:00	0:29	LOAD CURTAILMENT
89	8-Oct-2021	BENGALURU	66	HBR LAYOUT - KADUGODI	HBR LAYOUT	10:26	10:49	0:23	MAIN SUPPLY FAILURE
90	8-Oct-2021	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT	16:39	16:42	0:03	LOAD CHANGEOVER
91	8-Oct-2021	BENGALURU	66	HONNIGANAHALLI - T K HALLI 220	HONNIGANAHALLI, DODALAHALLI	8:20	8:30	0:10	LOAD CHANGEOVER
92	8-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:29	7:17	6:48	LINE CLEAR AVAILED
93	8-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:45(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
94	8-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
95	8-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
96	8-Oct-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	1:06	1:17	0:11	TRANSFORMER FAULT
97	8-Oct-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	15:30	21:03	5:33	LINE CLEAR AVAILED
98	8-Oct-2021	GULBARGA	220	HV1	SEDAM_220	23:55(07.10.2021)	00:20(08.10.2021)	00:25 HRS	TRANSFORMER CHARGED
99	8-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	10:21	10:47	0:26	LINE FAULT
100	8-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	11:25	16:41	5:16	LINE CLEAR AVAILED
101	8-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:01	6:09	5:08	LINE FAULT
102	8-Oct-2021	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	10:40	10:56	0:16	MAIN SUPPLY FAILURE
103	8-Oct-2021	GULBARGA	220	HV2	KUSTAGI_220	17:08	17:30	0:22	LINE CLEAR AVAILED
104	8-Oct-2021	GULBARGA	220	KUSTAGI-LINGAPUR (IDLE LINE)	KUSTAGI_220	10:37			LINE OPEN:LINE CLEAR AVAILED
105	8-Oct-2021	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA1_220	15:51	17:52	2:01	LINE FAULT
106	8-Oct-2021	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	8:15	18:45	10:30	NFBC ISSUED
107	8-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
108	8-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
109	8-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSS K_IPP,BHALKI SUGAR_IPP	5:50	5:55	0:05	LINE FAULT
110	8-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	23:55(07.10.2021)	00:15 (08.10.20 21)	0:20HRS	LINE CHARGED
111	8-Oct-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:05(07.10.2021)	12:18 (08.10.20 21)	15:13HRS	LINE CHARGED
112	8-Oct-2021	GULBARGA	110	ALIPUR-BELLARY SOUTH2	BELLARY SOUTH_110,HALKUNDI_110	18:30	18:42	0:12	LINE CLEAR AVAILED
113	8-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR_110	0:52	0:58	0:06	LINE FAULT
114	8-Oct-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,YERAGERA_11 0,VADAVATI_110,YAPALADINNI 110	1:10	1:15	0:05	LINE FAULT
115	8-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR_110	2:43	2:49	0:06	LINE FAULT
116	8-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_ 110,MANVI_110	3:49	3:56	0:07	LINE FAULT
117	8-Oct-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,YERAGERA_11 0,VADAVATI_110,YAPALADINNI 110	4:49	4:55	0:06	LINE FAULT
118	8-Oct-2021	GULBARGA	110	HV1	RAICHUR_220	8:53	8:58	0:05	TRANSFORMER FAULT
119	8-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR_110	20:16	20:22	0:06	LINE FAULT
120	8-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	20:18	20:23	0:05	LINE FAULT
121	8-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHAWAR_110	3:36	4:54	1:18	LINE FAULT
122	8-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHAWAR_110	5:16	5:20	0:04	LINE FAULT
123	8-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	5:32	5:44	0:12	LINE FAULT
124	8-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	23:01	23:08	0:07	LINE FAULT
125	8-Oct-2021	GULBARGA	110	HATTI-LINGSUGUR	HATTI_110	10:38	10:57	0:19	MAIN SUPPLY FAILURE
126	8-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	12:45	13:45	1:00	MAIN SUPPLY FAILURE
127	8-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	22:05	22:15	0:10	MAIN SUPPLY FAILURE
128	8-Oct-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	10:40	11:00	0:10	MAIN SUPPLY FAILURE
129	8-Oct-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	16:10	17:25	0:10	MAIN SUPPLY FAILURE
130	8-Oct-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNSAG I_110	12:43	13:35	0:52	LINE CLEAR AVAILED
131	8-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
132	8-Oct-2021	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110,KUKUNOOR_11 0	18:10	19:15	1:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
133	8-Oct-2021	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGON NAGAR_110, HANUMNAL_110	18:20	18:35	0:15	LINE FAULT
134	8-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	0:55	0:58	0:03	LINE FAULT
135	8-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	0:35	0:46	0:11	LINE FAULT
136	8-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	3:30	8:54	5:24	LINE FAULT
137	8-Oct-2021	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	4:28	4:32	0:04	LINE FAULT
138	8-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	10:45	13:50	3:05	LINE FAULT
139	8-Oct-2021	GULBARGA	110	ALIPUR-BELLARYSOUTH	BELLARYSOUTH_110	18:29	18:43	0:14	MAIN SUPPLY FAILURE
140	8-Oct-2021	GULBARGA	110	BELLAYOUTH-HALAKUNDI	BELLARYSOUTH_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
141	8-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	12:50	12:55	0:05	MAIN SUPPLY FAILURE
142	8-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	2:45	2:55	0:10	MAIN SUPPLY FAILURE
143	8-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	20:15	20:20	0:05	MAIN SUPPLY FAILURE
144	8-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	4:00	4:20	0:20	MAIN SUPPLY FAILURE
145	8-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	4:30	4:35	0:05	MAIN SUPPLY FAILURE
146	8-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	11:15	13:00	1:45	MAIN SUPPLY FAILURE
147	8-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	5:15	6:15	1:00	MAIN SUPPLY FAILURE
148	8-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	19:00	19:20	0:20	MAIN SUPPLY FAILURE
149	8-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	23:20	23:25	0:05	MAIN SUPPLY FAILURE
150	8-Oct-2021	GULBARGA	110	VADAVATTI-YAPALDINI	YAPALDINI_110	1:10	1:15	0:05	MAIN SUPPLY FAILURE
151	8-Oct-2021	GULBARGA	110	VADAVATTI-YAPALDINI	YAPALDINI_110	4:50	4:55	0:05	MAIN SUPPLY FAILURE
152	8-Oct-2021	GULBARGA	66	MUNIRABAD-MSD LINE	HANSI_66	19:44(07.10.2021)	02:20(08.10.2021)	06:36HRS	LINE CHARGED
153	8-Oct-2021	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)	20:20(08.10.2021)	203:50 HRS	TRANSFORMER CHARGED
154	8-Oct-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	17:27	17:35	0:08	LINE CLEAR AVAILED
155	8-Oct-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	13:05 (4.10.2021)			LINE OPEN:LINE FAULT
156	8-Oct-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	8:40 (7.10.2021)	18:31 (8.10.2021)	34:03 hrs	LINE CHARGED
157	8-Oct-2021	HASSAN	110	HV1	KEMAR_220	11:12	17:47	6:35	LINE CLEAR AVAILED
158	8-Oct-2021	HASSAN	220	HV1	SHIRALKOPPA_220	11:32	17:32	6:00	LINE CLEAR AVAILED
159	8-Oct-2021	HASSAN	110	LV1	SHIRALKOPPA_220	11:32	17:32	6:00	LINE CLEAR AVAILED
160	8-Oct-2021	HASSAN	110	HV4	BAIKAMPADY_110	13:14	14:33	1:19	LINE CLEAR AVAILED
161	8-Oct-2021	HASSAN	110	HV1	BANAVARA_110	18:40	18:50	0:10	HAND TRIPPED
162	8-Oct-2021	HASSAN	110	HV2	KADUR_220	17:55	19:35	1:40	TRANSFORMER FAULT
163	8-Oct-2021	HASSAN	110	LPH-LST4	lph_gen	9:15	13:50	4:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
164	8-Oct-2021	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	9:20	13:52	4:32	NFBC ISSUED
165	8-Oct-2021	HASSAN	110	LV3	MRSMSG_220	8:14	17:41	9:27	LINE CLEAR AVAILED
166	8-Oct-2021	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	12:49	20:15	7:26	LINE FAULT
167	8-Oct-2021	HASSAN	110	SAGARA-LST4	SAGARA_110	9:15	13:30	4:15	NFBC ISSUED
168	8-Oct-2021	HASSAN	110	SORABA-SAGARA	SORABA_110	11:00	11:10	0:10	LOAD CHANGEOVER
169	8-Oct-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:06	18:46	0:40	HAND TRIPPED
170	8-Oct-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	13:13	13:25	0:12	LINE CLEAR AVAILED
171	8-Oct-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	18:04	18:42	0:38	MAIN SUPPLY FAILURE
172	8-Oct-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	18:00	18:40	0:40	NFBC ISSUED
173	8-Oct-2021	MYSURU	66	HV1	BILIKERE_66	10:59	11:11	22:44	TRANSFORMER FAULT
174	8-Oct-2021	MYSURU	66	HV2	BILIKERE_66	10:59	11:11	0:11	TRANSFORMER FAULT
175	8-Oct-2021	MYSURU	66	HV2	BOOKANAKERE_66	12:48	18:31	5:43	LINE CLEAR AVAILED
176	8-Oct-2021	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66	1:52	18:49	16:56	LINE FAULT
177	8-Oct-2021	MYSURU	220	CR NAGARA-MADHUVANALLI2	NO STATIONS EFFECTED	17:30	17:39	0:09	LINE FAULT
178	8-Oct-2021	MYSURU	66	HV1	DEVANORNGUDU_66	15:17	16:16	0:58	LINE CLEAR AVAILED
179	8-Oct-2021	MYSURU	66	HV2	DEVANORNGUDU_66	15:17	16:16	0:58	LINE CLEAR AVAILED
180	8-Oct-2021	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	13:03	13:55	0:51	LINE CLEAR AVAILED
181	8-Oct-2021	MYSURU	66	HV1	DUNDANAHALLI_66	13:54	14:04	0:09	HAND TRIPPED
182	8-Oct-2021	MYSURU	66	HV2	DUNDANAHALLI_66	13:54	14:04	0:09	HAND TRIPPED
183	8-Oct-2021	MYSURU	66	HV2	HONNALLY_MYS_66	14:49	15:29	0:39	LINE CLEAR AVAILED
184	8-Oct-2021	MYSURU	66	HV2	KIKKERI_66	12:45	16:43	3:58	LINE CLEAR AVAILED
185	8-Oct-2021	MYSURU	66	HV2	KMDODDI_66	7:36	8:05	0:28	LINE CLEAR AVAILED
186	8-Oct-2021	MYSURU	66	KR PETE-SANTEBACHALLI	SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	10:46	10:52	0:05	LINE FAULT
187	8-Oct-2021	MYSURU	66	MADHUVANALLI-KUNTUR	NO STATIONS EFFECTED	18:18	18:27	0:09	LINE FAULT
188	8-Oct-2021	MYSURU	66	VAJMANGALA-KADKOLA1	AYRALLI_66 MARADIHUNDI_66	1:00	1:06	0:06	LINE FAULT
189	8-Oct-2021	MYSURU	66	VAJMANGALA-KADKOLA1	AYRALLI_66 MARADIHUNDI_66	18:19	18:24	0:05	LINE FAULT
190	8-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08			LINE OPEN:LINE CLEAR AVAILED
191	8-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42			LINE OPEN:LINE CLEAR AVAILED
192	8-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
193	8-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
194	8-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
195	8-Oct-2021	TUMKUR	220	ANCHEPALYA 66KV-ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	11:24	16:03	4:38	LINE CLEAR AVAILED
196	8-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	11:10	12:44	1:33	LINE CLEAR AVAILED
197	8-Oct-2021	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	15:22	16:24	1:01	LINE CLEAR AVAILED
198	8-Oct-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINA KERE_66,ANKASANDRA_66	0:28	0:39	0:10	LINE FAULT
199	8-Oct-2021	TUMKUR	66	TR-2	BADAVANAHALLI_66	13:36	13:58	0:22	HAND TRIPPED
200	8-Oct-2021	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	11:10	12:46	1:35	LINE CLEAR AVAILED
201	8-Oct-2021	TUMKUR	66	GULIGENAHALLI- MADHUGIRI-1	GULIGENAHALLI_66	6:42	9:12	2:29	LINE CLEAR AVAILED
202	8-Oct-2021	TUMKUR	66	GULIGENAHALLI- SIRA2	GULIGENAHALLI_66	12:38	12:45	0:06	HAND TRIPPED
203	8-Oct-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	6:16	6:17	0:00	HAND TRIPPED
204	8-Oct-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:28	18:30	0:02	HAND TRIPPED
205	8-Oct-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	5:51	6:16	0:25	LINE FAULT
206	8-Oct-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	11:27	11:33	0:05	LINE FAULT
207	8-Oct-2021	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	1:52	3:03	1:10	LINE CLEAR AVAILED
208	8-Oct-2021	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	17:03	18:38	1:35	LINE CLEAR AVAILED
209	8-Oct-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	1:52	3:09	1:16	LINE CLEAR AVAILED
210	8-Oct-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	16:13	18:55	2:42	LINE CLEAR AVAILED
211	8-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	2:48	2:53	0:04	LINE FAULT
212	8-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:28	18:48	0:20	LINE FAULT
213	9-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
214	9-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
215	9-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
216	9-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
217	9-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
218	9-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
219	9-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
220	9-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
221	9-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
222	9-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
223	9-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
224	9-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
225	9-Oct-2021	BAGALKOT	110	AMBEWADI- SUPA1	AMBEWADI_220	6:34	8:22	1:48	LINE FAULT
226	9-Oct-2021	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	10:33	12:44	2:11	LINE CLEAR AVAILED
227	9-Oct-2021	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	23:44 (09.10.2021)			LOAD CURTAILMENT
228	9-Oct-2021	BAGALKOT	110	ALABAL-SPR SUGARS	ALABAL_110	20:42	21:01	0:19	LINE FAULT
229	9-Oct-2021	BAGALKOT	110	ALABAL-RFE SOLAR	ALABAL_110	20:42	20:59	0:17	LINE FAULT
230	9-Oct-2021	BAGALKOT	110	MAHALINGPUR-BANAHATTI	BANAHATTI_110	3:21	11:11	7:50	LINE FAULT
231	9-Oct-2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 &AMINAGAD_33 &KARADI_33	15:00	15:08	0:08	TRANSFORMER FAULT
232	9-Oct-2021	BAGALKOT	110	MAHALINGPUR-JAMAKHANDI	JAMAKHANDI_110	4:07	4:20	0:13	HAND TRIPPED
233	9-Oct-2021	BAGALKOT	110	UMMACHAGI-SIRSI	STATION NOT AFFECTED UMMACHAGI_110	0:00	15:52	15:52	NFBC ISSUED
234	9-Oct-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	13:45	13:48	0:03	TRANSFORMER FAULT
235	9-Oct-2021	BAGALKOT	66	66/11KV,HV2	STATION NOT AFFECTED HARIHAR HOSPET_66	17:10	18:30	1:20	LINE CLEAR AVAILED
236	9-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
237	9-Oct-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)	15:33 (09.10.2021)	702:27HRS	LINE CHARGED
238	9-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
239	9-Oct-2021	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110, HIREBENNUR_110, RODAGI_110	10:00	18:50	8:50	LINE CLEAR AVAILED
240	9-Oct-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	11:52	15:43	3:51	LINE CLEAR AVAILED
241	9-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:53	15:46	3:53	LINE CLEAR AVAILED
242	9-Oct-2021	BAGALKOT	110	110/11KV, HV1	ITANAL_110	18:15	18:30	0:15	TRANSFORMER FAULT
243	9-Oct-2021	BAGALKOT	110	110/11KV, HV1	ITANAL_110	20:50	20:55	0:05	TRANSFORMER FAULT
244	9-Oct-2021	BAGALKOT	110	110/11KV, HV1	SHIROL_110	17:00	17:05	0:05	TRANSFORMER FAULT
245	9-Oct-2021	BAGALKOT	110	AMBEWADI- GANESHGUDI	GANESHGUDI_110	6:28	8:30	2:02	MAIN SUPPLY FAILURE
246	9-Oct-2021	BAGALKOT	110	110/11KV, HV2	GANESHGUDI_110	8:30	18:53	10:23	LINE CLEAR AVAILED
247	9-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 66 - ISCON	SUBRAMANYAPURA 66	10:08	16:20	6:12	LINE CLEAR AVAILED
248	9-Oct-2021	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	10:55	13:48	2:53	LINE CLEAR AVAILED
249	9-Oct-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	7:45	8:20	0:35	LOAD CHANGEVER
250	9-Oct-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	7:45	8:20	0:35	LOAD CHANGEVER
251	9-Oct-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	7:45	8:20	0:35	LOAD CHANGEVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
252	9-Oct-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	7:45	8:23	0:38	LOAD CHANGEOVER
253	9-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	21:11	22:15	1:04	LINE FAULT
254	9-Oct-2021	BENGALURU	66	ANEKAL - YARANDANAHALLI 2	ANEKAL, SAMANDURU	7:45	8:45	1:00	MAIN SUPPLY FAILURE
255	9-Oct-2021	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL, SAMANDURU	20:20	20:30	0:10	LOAD CHANGEOVER
256	9-Oct-2021	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	18:24	18:34	0:10	LOAD CURTAILMENT
257	9-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:21	19:21	1:00	LOAD CURTAILMENT
258	9-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:19	19:41	0:22	LOAD CURTAILMENT
259	9-Oct-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	18:21	18:29	0:08	LOAD CURTAILMENT
260	9-Oct-2021	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	7:45	8:43	0:58	MAIN SUPPLY FAILURE
261	9-Oct-2021	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	20:20	20:30	0:10	LOAD CHANGEOVER
262	9-Oct-2021	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	8:07	8:09	0:02	LOAD CHANGEOVER
263	9-Oct-2021	BENGALURU	66	HV1	GANJIGUNTE	11:45	11:50	0:05	TRANSFORMER FAULT
264	9-Oct-2021	BENGALURU	66	HV2	ATTIBELE	8:20	18:45	10:25	LINE CLEAR AVAILED
265	9-Oct-2021	BENGALURU	66	HV1	HOSKOTE 220	9:23	9:33	0:10	TRANSFORMER FAULT
266	9-Oct-2021	BENGALURU	66	HV1	SM MANGALA	14:33	14:39	0:06	TRANSFORMER FAULT
267	9-Oct-2021	BENGALURU	220	MYLASANDRA 400 - JIGANI 220	JIGANI 220	7:58	8:43	0:45	LINE CLEAR AVAILED
268	9-Oct-2021	BENGALURU	66	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	3:52	4:16	0:24	LINE FAULT
269	9-Oct-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	9:31	11:28	1:57	LINE FAULT
270	9-Oct-2021	BENGALURU	220	HV1	JIGANI 220	7:58	11:20	3:22	MAIN SUPPLY FAILURE
271	9-Oct-2021	BENGALURU	220	HV2	JIGANI 220	7:58	11:20	3:22	MAIN SUPPLY FAILURE
272	9-Oct-2021	BENGALURU	66	HV1	JIGANI 220	7:58	8:43	0:45	MAIN SUPPLY FAILURE
273	9-Oct-2021	BENGALURU	66	HV2	JIGANI 220	7:58	8:43	0:45	MAIN SUPPLY FAILURE
274	9-Oct-2021	BENGALURU	220	JIGANI 220 - YARANDANAHALLI 220	JIGANI 220	10:35	10:45	0:10	LOAD CHANGEOVER
275	9-Oct-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	7:58	8:40	0:42	MAIN SUPPLY FAILURE
276	9-Oct-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	10:35	10:45	0:10	MAIN SUPPLY FAILURE
277	9-Oct-2021	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	11:17	11:25	0:08	LOAD CHANGEOVER
278	9-Oct-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI LINK ROAD, JIGANI 66	7:58	8:15	0:17	MAIN SUPPLY FAILURE
279	9-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:45(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
280	9-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
281	9-Oct-2021	GULBARGA	220	KUSTAGI-LINGAPUR	KUSTAGI_220	10:37(08.10.2021)	15:54(09.10.2021)	29:17 HRS	LINE CHARGED
282	9-Oct-2021	GULBARGA	220	MALLAT-RTPS	MALLT_220	2:20	7:06	4:46	LINE FAULT
283	9-Oct-2021	GULBARGA	220	HV1	RAICHUR_220	2:00	20:16	18:16	TRANSFORMER FAULT
284	9-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	3:45	7:53	4:08	LINE CLEAR AVAILED
285	9-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	3:52	7:51	3:59	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
286	9-Oct-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	0:38	0:48	0:10	TRANSFORMER FAULT
287	9-Oct-2021	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	12:07	15:54	3:47	LINE CLEAR AVAILED
288	9-Oct-2021	GULBARGA	220	LINGAPUR-SINDHANOOR	LINGAPUR_220	9:42	15:56	6:14	LINE CLEAR AVAILED
289	9-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	0:38	7:05	6:27	LINE FAULT
290	9-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:45(09.10.2021)			LINE OPEN:LINE FAULT
291	9-Oct-2021	GULBARGA	220	SHAHAPUR_RTPS2	SHAHAPUR_220	23:45(09.10.2021)			LINE OPEN:LINE FAULT
292	9-Oct-2021	GULBARGA	220	HV2	KUSTAGI_220	18:05	18:55	0:50	LINE CLEAR AVAILED
293	9-Oct-2021	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	2:56	12:49	9:53	LINE FAULT
294	9-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE 110	5:08	5:16	0:08	LINE FAULT
295	9-Oct-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KURUGOD_110,SHATHAVA HANA_IPP,AGARWAL_IPP,SUZL ON_IPP,KAMALAPUR_IPP,MATR I 110,RBNS FACTORY	21:09	21:17	0:08	LINE FAULT
296	9-Oct-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KURUGOD_110,SHATHAVA HANA_IPP,AGARWAL_IPP,SUZL ON_IPP,KAMALAPUR_IPP,MATR I 110,RBNS FACTORY	21:29	21:39	0:10	LINE FAULT
297	9-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	3:16	3:29	0:13	LINE FAULT
298	9-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	6:25	6:35	0:10	LINE FAULT
299	9-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSS K_IPP,BHALKI SUGAR_IPP	12:47	13:40	0:53	LINE CLEAR AVAILED
300	9-Oct-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANWADA_110,N SSK SUGAR FACTORY	3:09	6:50	3:41	LINE FAULT
301	9-Oct-2021	GULBARGA	110	HV1	RAICHUR_220	0:46	0:51	0:05	TRANSFORMER FAULT
302	9-Oct-2021	GULBARGA	110	HV1	RAICHUR_220	1:05	1:55	0:50	TRANSFORMER FAULT
303	9-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
304	9-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
305	9-Oct-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA 110	2:00	2:39	0:39	LINE FAULT
306	9-Oct-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA 110	2:00	2:39	0:39	LINE FAULT
307	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR 110	4:14	4:19	0:05	LINE FAULT
308	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR 110	4:32	4:39	0:07	LINE FAULT
309	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR 110	5:18	7:00	1:42	LINE FAULT
310	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR 110	11:14	12:50	1:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
311	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR_110	12:51	13:17	0:26	LINE FAULT
312	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR_110	19:03	19:21	0:18	LINE FAULT
313	9-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	19:18	19:32	0:14	LINE FAULT
314	9-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:55	22:12	0:17	LINE FAULT
315	9-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR_110	23:20	23:27	0:07	LINE FAULT
316	9-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_ 110,MANVI_110	21:18	21:27	0:09	LINE FAULT
317	9-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	9:30	18:07	8:37	LINE FAULT
318	9-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALAKAMDI NNI_110	19:14	19:24	0:10	LINE FAULT
319	9-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	5:48	6:02	0:14	LINE FAULT
320	9-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	22:34	22:44	0:10	LINE FAULT
321	9-Oct-2021	GULBARGA	110	HV2	HATTI_110	5:03	5:06	0:03	TRANSFORMER FAULT
322	9-Oct-2021	GULBARGA	110	HV2	HATTI_110	5:19	5:23	0:04	TRANSFORMER FAULT
323	9-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	3:10	3:15	0:05	LINE FAULT
324	9-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	6:15	6:30	0:15	LINE FAULT
325	9-Oct-2021	GULBARGA	110	MASKI-SINDHANNNOOR	MASKI_110	20:43	20:48	0:05	LINE FAULT
326	9-Oct-2021	GULBARGA	110	JANAWADA-SANTAPUR	SANTHAPUR_110	17:50	22:05	4:15	LOAD CURTAILMENT
327	9-Oct-2021	GULBARGA	110	SREEERAMANAGAR-VALKAMDINNI	VALKAMDINNI_110	10:40	18:12	7:32	NFBC ISSUED
328	9-Oct-2021	GULBARGA	110	SHAKTINAGAR-RAICHUR BIO MASS_IPP	SHAKTINAGAR_110	3:02	4:20	1:18	LINE FAULT
329	9-Oct-2021	GULBARGA	110	SHAKTINAGAR-RAICHUR BIO MASS_IPP	SHAKTINAGAR_110	13:01	13:30	0:29	LINE FAULT
330	9-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR 2 (IDLE LINE)	DEODURGA_110	4:44	4:55	0:11	LINE FAULT
331	9-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR 2 (IDLE LINE)	DEODURGA_110	4:44	4:55	0:11	LINE FAULT
332	9-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_11 0,SDAIDHAPUR_110,SANATHI_I PP,CORE GREEN SUGAR_IPP	18:55	19:06	0:11	LINE FAULT
333	9-Oct-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:03	23:20	0:17	LINE FAULT
334	9-Oct-2021	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSS K_IPP,BHALKI SUGAR_IPP	3:07	3:35	0:28	LINE FAULT
335	9-Oct-2021	GULBARGA	110	BELLAYASOUTH-HALAKUNDI	BELLARYSOUTH_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
336	9-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	5:15	6:15	1:00	MAIN SUPPLY FAILURE
337	9-Oct-2021	GULBARGA	110	HV1	GABBUR_110	11:00	11:03	0:03	TRANSFORMER FAULT
338	9-Oct-2021	GULBARGA	110	GABBUR-DEODURGA	GABBUR_110	12:20	13:00	0:40	LINE CLEAR AVAILED
339	9-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	11:15	11:50	0:35	MAIN SUPPLY FAILURE
340	9-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	19:05	19:20	0:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
341	9-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	23:20	23:50	0:30	MAIN SUPPLY FAILURE
342	9-Oct-2021	GULBARGA	110	HV1	HALAKUNDI_110	11:55	12:10	0:15	TRANSFORMER FAULT
343	9-Oct-2021	GULBARGA	110	MALLAT-GALAG	GALAG_110	5:45	6:00	0:15	MAIN SUPPLY FAILURE
344	9-Oct-2021	GULBARGA	110	MALIYABAD-YERGERA	YERGERA_110	1:11	1:16	0:05	MAIN SUPPLY FAILURE
345	9-Oct-2021	GULBARGA	110	MALIYABAD-YERGERA	YERGERA_110	4:53	4:58	0:05	MAIN SUPPLY FAILURE
346	9-Oct-2021	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	3:05	3:35	0:30	MAIN SUPPLY FAILURE
347	9-Oct-2021	GULBARGA	66	HV1	HALAVAGALU_66	12:05	13:50	1:45	LINE CLEAR AVAILED
348	9-Oct-2021	GULBARGA	66	HV3	HALAVAGALU_66	13:20	13:50	0:30	LINE CLEAR AVAILED
349	9-Oct-2021	GULBARGA	66	HV1,HV3	HALAVAGALU_66	16:00	16:15	0:15	LINE CLEAR AVAILED
350	9-Oct-2021	GULBARGA	66	HV1,HV3	HALAVAGALU_66	17:15	18:15	1:00	LINE CLEAR AVAILED
351	9-Oct-2021	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	11:20	15:00	3:40	LINE CLEAR AVAILED
352	9-Oct-2021	HASSAN	66	MRSSHM-BD1	MRSMSG_220	9:01(4.10.2021)	10:32(09.10.2021)	121:30 hrs	LINE CHARGED
353	9-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
354	9-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
355	9-Oct-2021	HASSAN	110	HV2	ANAVATTI_110	10:00	10:20	0:20	TRANSFORMER FAULT
356	9-Oct-2021	HASSAN	110	HV2	ANAVATTI_110	11:20	11:35	0:15	TRANSFORMER FAULT
357	9-Oct-2021	HASSAN	110	HV1	JAVAGAL_110	7:06	8:35	1:29	LINE CLEAR AVAILED
358	9-Oct-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	12:50	14:12	1:22	LINE FAULT
359	9-Oct-2021	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	11:16	11:29	0:13	LINE FAULT
360	9-Oct-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:25	10:45	0:20	LOAD CHANGEOVER
361	9-Oct-2021	HASSAN	66	HV1	HOLEHONNUR_66	11:05	14:20	3:15	MAIN SUPPLY FAILURE
362	9-Oct-2021	HASSAN	66	HV2	HOLEHONNUR_66	11:05	14:20	3:15	MAIN SUPPLY FAILURE
363	9-Oct-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	4:42	5:02	0:20	LINE FAULT
364	9-Oct-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	11:15	13:40	2:25	NFBC ISSUED
365	9-Oct-2021	HASSAN	66	TAVAREC-MRS	TAVARECHATNAHALLI_66	12:50	14:10	1:20	MAIN SUPPLY FAILURE
366	9-Oct-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:56	19:14	5:18	LINE FAULT
367	9-Oct-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	16:30	19:15	2:45	LINE CLEAR AVAILED
368	9-Oct-2021	HASSAN	66	HV1	MALLAPURA_66	10:55	14:50	3:55	MAIN SUPPLY FAILURE
369	9-Oct-2021	HASSAN	66	HV2	MALLAPURA_66	10:55	14:50	3:55	MAIN SUPPLY FAILURE
370	9-Oct-2021	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	10:55	14:50	3:55	MAIN SUPPLY FAILURE
371	9-Oct-2021	MYSURU	66	DR PETE-KUNTUR	SANTHEMARAHALI_66 THAYURU_66 MUGUR_66 JANNUR_66 TNARASIPURA_66	13:38	13:44	22:44	LINE FAULT
372	9-Oct-2021	MYSURU	66	HV1	GUNDULPET_66	11:21	11:35	0:13	TRANSFORMER FAULT
373	9-Oct-2021	MYSURU	66	HANNUR-KOTHUNUR	NO STATIONS EFFECTED	10:27	10:35	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
374	9-Oct-2021	MYSURU	66	KR PETE-SANTEBACHALLI	SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	15:42	18:31	2:49	LINE FAULT
375	9-Oct-2021	MYSURU	66	KUNTUR-DR PETE	NO STATIONS EFFECTED	13:38	18:49	5:11	LINE FAULT
376	9-Oct-2021	MYSURU	66	MADHUVANALLI-KUNTUR	NO STATIONS EFFECTED	12:11	12:17	0:06	LINE FAULT
377	9-Oct-2021	MYSURU	66	HV1	MADHUVANAHALLI_66	8:16	8:28	0:12	TRANSFORMER FAULT
378	9-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08			LINE OPEN:LINE CLEAR AVAILED
379	9-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42			LINE OPEN:LINE CLEAR AVAILED
380	9-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
381	9-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
382	9-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
383	9-Oct-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	16:37	18:33	1:56	LINE CLEAR AVAILED
384	9-Oct-2021	TUMKUR	220	TR-1	CHITRADURGA_220	10:05	16:07	6:01	LINE CLEAR AVAILED
385	9-Oct-2021	TUMKUR	220	TR-2	CHITRADURGA_220	10:05	16:07	6:01	LINE CLEAR AVAILED
386	9-Oct-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	16:38	18:32	1:54	LINE CLEAR AVAILED
387	9-Oct-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	13:04	13:14	0:09	LINE FAULT
388	9-Oct-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	10:49	10:54	0:05	LINE FAULT
389	9-Oct-2021	TUMKUR	66	BHARAMAGIRI-MATHOD66	BHARAMAGIRI_66	13:14	13:23	0:08	LINE FAULT
390	9-Oct-2021	TUMKUR	66	TR-2	CHANNAGIRI_66	11:57	13:05	1:07	LINE CLEAR AVAILED
391	9-Oct-2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	10:06	16:29	6:23	LINE CLEAR AVAILED
392	9-Oct-2021	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	10:54	13:41	2:47	MAIN SUPPLY FAILURE
393	9-Oct-2021	TUMKUR	66	TR-1	SAVALANGA_66	10:54	13:51	2:56	MAIN SUPPLY FAILURE
394	9-Oct-2021	TUMKUR	66	TR-1	CHITRADURGA_66	16:32	16:33	0:00	MAIN SUPPLY FAILURE
395	9-Oct-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1 IPP_66	MEGMICON 1_IPP_66	16:32	16:52	0:20	MAIN SUPPLY FAILURE
396	9-Oct-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2_IPP_66	MEGMICON 2_IPP_66	16:32	16:52	0:20	MAIN SUPPLY FAILURE
397	9-Oct-2021	TUMKUR	66	TR-2	HALURAMESHWAR_66	12:29	12:38	0:09	TRANSFORMER FAULT
398	10-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
399	10-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
400	10-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
401	10-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
402	10-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
403	10-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
404	10-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
405	10-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
406	10-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
407	10-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
408	10-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
409	10-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
410	10-Oct-2021	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	23:44 (09.10.2021)	3:53 (10.10.2021)	0:15HRS	LINE CHARGED
411	10-Oct-2021	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	3:13	3:51	0:38	LOAD CURTAILMENT
412	10-Oct-2021	BAGALKOT	220	BIDNAL- HUBLI1	BIDNAL_220	3:18	3:43	0:25	LOAD CURTAILMENT
413	10-Oct-2021	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	18:26	21:06	2:40	LINE CLEAR AVAILED
414	10-Oct-2021	BAGALKOT	110	GHATAPRABHA220- PG HUNSHYAL	PG HUNSHYAL_110	1:04	1:20	0:16	LINE FAULT
415	10-Oct-2021	BAGALKOT	110	GHATAPRABHA220- PG HUNSHYAL	PG HUNSHYAL_110	3:03	3:13	0:08	LINE FAULT
416	10-Oct-2021	BAGALKOT	110	GHATAPRABHA220- KABBUR	KABBUR_110,NAGAR MUNAVALLI_110	5:15	5:25	0:10	LINE FAULT
417	10-Oct-2021	BAGALKOT	110	GHATAPRABHA220- PG HUNSHYAL	PG HUNSHYAL_110	21:20	21:32	0:12	LINE FAULT
418	10-Oct-2021	BAGALKOT	110	110/11KV,HV2	BIJAPUR KIADB_110	8:29	9:06	0:37	HAND TRIPPED
419	10-Oct-2021	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110 &KABBUR_33	3:30	3:42	0:12	TRANSFORMER FAULT
420	10-Oct-2021	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110	18:54	19:11	0:17	LINE FAULT
421	10-Oct-2021	BAGALKOT	110	HUKKERI- VS SUGARS	HUKKERI_110	8:54	12:25	3:31	LINE CLEAR AVAILED
422	10-Oct-2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 &AMINAGAD_33 &KARADI_34	9:23	9:44	0:21	HAND TRIPPED
423	10-Oct-2021	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	7:01	7:36	0:35	LINE FAULT
424	10-Oct-2021	BAGALKOT	110	ITANAL-BPCL	ITANAL_110	19:57	20:03	0:06	LINE FAULT
425	10-Oct-2021	BAGALKOT	110	ITANAL-KABBUR	KABBUR_110	21:22	21:30	0:08	LINE FAULT
426	10-Oct-2021	BAGALKOT	110	ITANAL-BPCL	HIDIKAL_110	21:22	21:29	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
427	10-Oct-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	6:56	8:04	1:08	TRANSFORMER FAULT
428	10-Oct-2021	BAGALKOT	110	MALGHAN(B)-BASAVESHWAR SUGARS	BASAVESHWAR SUGARS_110 STATION NOT AFFECTED MALGHAN(B)_110	15:26	16:42	1:16	LINE CLEAR AVAILED
429	10-Oct-2021	BAGALKOT	110	CHIKKODI220- ANKALI	ANKALI_110	5:15	5:31	0:16	LINE FAULT
430	10-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
431	10-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
432	10-Oct-2021	BAGALKOT	110	110/11KV, HV1	HIDIKAL_110	12:50	13:20	0:30	LINE CLEAR AVAILED
433	10-Oct-2021	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	12:50	13:20	0:30	LINE CLEAR AVAILED
434	10-Oct-2021	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	12:00	12:10	0:10	LINE CLEAR AVAILED
435	10-Oct-2021	BAGALKOT	110	PG HUNSHYAL- NAGANUR	NAGNUR_110	1:05	1:20	0:15	MAIN SUPPLY FAILURE
436	10-Oct-2021	BAGALKOT	110	NAGNUR- MUDALGI	MUDALGI_110	1:05	1:20	0:15	MAIN SUPPLY FAILURE
437	10-Oct-2021	BAGALKOT	110	110/11KV, HV1	NAGNUR_110	1:05	1:20	0:15	MAIN SUPPLY FAILURE
438	10-Oct-2021	BAGALKOT	110	110/11KV, HV2	NAGNUR_110	1:05	1:20	0:15	MAIN SUPPLY FAILURE
439	10-Oct-2021	BAGALKOT	110	PG HUNSHYAL- NAGANUR	NAGNUR_110	3:00	3:15	0:15	MAIN SUPPLY FAILURE
440	10-Oct-2021	BAGALKOT	110	NAGNUR- MUDALGI	MUDALGI_110	3:00	3:15	0:15	MAIN SUPPLY FAILURE
441	10-Oct-2021	BAGALKOT	110	110/11KV, HV1	NAGNUR_110	3:00	3:15	0:15	MAIN SUPPLY FAILURE
442	10-Oct-2021	BAGALKOT	110	110/11KV, HV2	NAGNUR_110	3:00	3:15	0:15	MAIN SUPPLY FAILURE
443	10-Oct-2021	BAGALKOT	110	PG HUNSHYAL- NAGANUR	NAGNUR_110	21:20	21:35	0:15	MAIN SUPPLY FAILURE
444	10-Oct-2021	BAGALKOT	110	NAGNUR- MUDALGI	MUDALGI_110	21:20	21:35	0:15	MAIN SUPPLY FAILURE
445	10-Oct-2021	BAGALKOT	110	110/11KV, HV1	NAGNUR_110	21:20	21:35	0:15	MAIN SUPPLY FAILURE
446	10-Oct-2021	BAGALKOT	110	110/11KV, HV2	NAGNUR_110	21:20	21:35	0:15	MAIN SUPPLY FAILURE
447	10-Oct-2021	BAGALKOT	220	HUBLI- BIDNAL1	HUBLI_220	3:17	3:43	0:26	LOAD CURTAILMENT
448	10-Oct-2021	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	23:42 (9.10.2021)	3:45 (10.10.2021)	4:03HRS	HAND TRIPPED
449	10-Oct-2021	BAGALKOT	220	HUBLI- NAGJHARI2	HUBLI_220	23:42 (9.10.2021)	3:46 (10.10.2021)	4:04HRS	HAND TRIPPED
450	10-Oct-2021	BAGALKOT	110	ALNAVAR- HALIYAL	HALIYAL_110	18:02	19:12	1:10	LINE FAULT
451	10-Oct-2021	BAGALKOT	110	110/11KV, HV1	GANESHGUDI_110	10:53	17:41	6:48	LINE CLEAR AVAILED
452	10-Oct-2021	BENGALURU	66	GOKULA - SRS PEENYA 220 1	GOKULA, BEL (EHT), HMT (EHT)	13:17	13:44	0:27	LINE FAULT
453	10-Oct-2021	BENGALURU	66	GOKULA - SRS PEENYA 220 2	GOKULA, BEL (EHT), HMT (EHT)	13:17	13:44	0:27	LINE FAULT
454	10-Oct-2021	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	14:48	14:53	0:05	LOAD CHANGEOVER
455	10-Oct-2021	BENGALURU	66	HV2	KHODAYS 220	10:37	10:41	0:04	LINE CLEAR AVAILED
456	10-Oct-2021	BENGALURU	66	KODIGEHALLI - TAVAREKERE	TAVAREKERE	10:55	12:22	1:27	LINE CLEAR AVAILED
457	10-Oct-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	13:17	13:33	0:16	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
458	10-Oct-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	15:25	15:29	0:04	LOAD CHANGEOVER
459	10-Oct-2021	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	12:50	13:15	0:25	MAIN SUPPLY FAILURE
460	10-Oct-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	13:20	13:35	0:15	MAIN SUPPLY FAILURE
461	10-Oct-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	15:25	15:28	0:03	LOAD CHANGEOVER
462	10-Oct-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, BEL (EHT), HMT (EHT),	13:17	13:44	0:27	LINE FAULT
463	10-Oct-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, BEL (EHT), HMT (EHT),	13:17	13:44	0:27	LINE FAULT
464	10-Oct-2021	BENGALURU	66	HV1	TK HALLI 220	17:48	17:51	0:03	TRANSFORMER FAULT
465	10-Oct-2021	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATION AFFECTED	16:09	17:08	0:59	LINE FAULT
466	10-Oct-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	19:01	19:37	0:36	LOAD CHANGEOVER
467	10-Oct-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	19:01	19:37	0:36	LOAD CHANGEOVER
468	10-Oct-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	19:01	19:37	0:36	LOAD CHANGEOVER
469	10-Oct-2021	BENGALURU	66	HV2	JIGANI 220	10:52	11:04	0:12	LINE CLEAR AVAILED
470	10-Oct-2021	BENGALURU	66	HV2	JIGANI 220	17:05	17:15	0:10	LINE CLEAR AVAILED
471	10-Oct-2021	BENGALURU	66	ANEKAL - YARANDANAHALLI 1	ANEKAL, SAMANDURU	14:16	14:24	0:08	MAIN SUPPLY FAILURE
472	10-Oct-2021	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL, SAMANDURU	16:06	16:14	0:08	LOAD CHANGEOVER
473	10-Oct-2021	BENGALURU	66	ANEKAL - SURYANAGAR	ANEKAL, SAMANDURU	19:03	19:54	0:51	MAIN SUPPLY FAILURE
474	10-Oct-2021	BENGALURU	66	ANEKAL - YARANDANAHALLI 220	ANEKAL, SAMANDURU	20:00	20:04	0:04	LOAD CHANGEOVER
475	10-Oct-2021	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	14:18	14:28	0:10	MAIN SUPPLY FAILURE
476	10-Oct-2021	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	16:07	16:11	0:04	LOAD CHANGEOVER
477	10-Oct-2021	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	19:03	19:52	0:49	MAIN SUPPLY FAILURE
478	10-Oct-2021	BENGALURU	220	JIGANI 220 - YARANDANAHALLI 220	JIGANI 220	19:19	19:38	0:19	LOAD CHANGEOVER
479	10-Oct-2021	BENGALURU	220	HV1	JIGANI 220	19:19	19:40	0:21	MAIN SUPPLY FAILURE
480	10-Oct-2021	BENGALURU	66	BAGMANE WTC - HOODY 1	BAGMANE WTC	11:10	11:15	0:05	LOAD CHANGEOVER
481	10-Oct-2021	BENGALURU	66	HV3	NELEMANGALA 66	18:57	20:34	1:36	TRANSFORMER FAULT
482	10-Oct-2021	BENGALURU	66	HV1	DABUSPET 220	9:32	9:37	0:05	LINE CLEAR AVAILED
483	10-Oct-2021	BENGALURU	66	HV1	CHAKAVELU	12:40	12:56	0:16	TRANSFORMER FAULT
484	10-Oct-2021	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	11:13	13:58	2:44	LINE CLEAR AVAILED
485	10-Oct-2021	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	18:17	18:43	0:26	LINE FAULT
486	10-Oct-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS, YENNIGADALE, CHELUR, CHAKAVELU	4:50	4:57	0:07	LINE FAULT
487	10-Oct-2021	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	12:40	12:56	0:16	LINE FAULT
488	10-Oct-2021	BENGALURU	220	HV2	JIGANI 220	19:19	19:40	0:21	MAIN SUPPLY FAILURE
489	10-Oct-2021	BENGALURU	66	HV1	JIGANI 220	19:19	19:40	0:21	MAIN SUPPLY FAILURE
490	10-Oct-2021	BENGALURU	66	HV2	JIGANI 220	19:19	19:51	0:32	MAIN SUPPLY FAILURE
491	10-Oct-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	19:19	19:40	0:21	MAIN SUPPLY FAILURE
492	10-Oct-2021	BENGALURU	66	JIAGNI 66 - JIGANI 220	JIGANI 66	19:20	19:40	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
493	10-Oct-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	19:19	19:40	0:21	MAIN SUPPLY FAILURE
494	10-Oct-2021	BENGALURU	66	HV2	JIGANI LINK ROAD	12:30	14:53	2:23	LINE CLEAR AVAILED
495	10-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:45(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
496	10-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
497	10-Oct-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	5:53	6:03	0:10	TRANSFORMER FAULT
498	10-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	22:03	22:49	0:46	LINE CLEAR AVAILED
499	10-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:45(09.10.2021)	7:13(10.10.2021)	9:28 HRS	LINE CHARGED
500	10-Oct-2021	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	23:45(09.10.2021)	00:49(10.10.2021)	1:04 HRS	LINE CHARGED
501	10-Oct-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	3:32	3:43	0:11	LINE FAULT
502	10-Oct-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	5:16	15:38	10:22	LINE FAULT
503	10-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:11	21:25	0:14	LINE FAULT
504	10-Oct-2021	GULBARGA	220	HV1	KUSTAGI_220	0:06	6:56	6:50	TRANSFORMER FAULT
505	10-Oct-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	8:26	8:46	0:20	LINE FAULT
506	10-Oct-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	9:22	9:27	0:05	LINE FAULT
507	10-Oct-2021	GULBARGA	220	HV1	HUMNABAD_220	17:55	18:47	0:52	TRANSFORMER FAULT
508	10-Oct-2021	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	17:55	18:45	0:50	LINE FAULT
509	10-Oct-2021	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	17:55	19:03	1:08	LINE FAULT
510	10-Oct-2021	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	17:55			LINE OPEN:LINE FAULT
511	10-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
512	10-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
513	10-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALAKAMD NNI 110	4:45	5:05	0:20	LINE FAULT
514	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR 110	0:05	0:21	0:16	LINE FAULT
515	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GOOGLE_110,DEODURGA_110, GABBUR 110	0:28	0:48	0:20	LINE FAULT
516	10-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_ 110,MANVI 110	0:49	0:58	0:09	LINE FAULT
517	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,DEODURGA_110, GABBUR 110	1:37	2:00	0:23	LINE FAULT
518	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GOOGLE_110,DEODURGA_110, GABBUR 110	2:57	16:20	13:23	LINE FAULT
519	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,DEODURGA_110, GABBUR 110	0:17	11:22	11:05	LINE FAULT
520	10-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	2:32	7:55	5:23	LINE FAULT
521	10-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALAKAMD NNI 110	2:53	3:00	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
522	10-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALAKAMDINNI_110	3:35	4:00	0:25	LINE FAULT
523	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110	20:40	20:50	0:10	LINE FAULT
524	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:10	21:15	0:05	LINE FAULT
525	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	21:20	21:26	0:06	LINE FAULT
526	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	21:50	21:56	0:06	LINE FAULT
527	10-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:17	22:58	0:41	LINE FAULT
528	10-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:47	22:58	0:11	LINE FAULT
529	10-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	5:15	7:55	2:40	LINE FAULT
530	10-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	7:35	8:10	0:35	LINE CLEAR AVAILED
531	10-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHWAR_110	2:57	3:07	0:10	LINE FAULT
532	10-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	3:19	3:29	0:10	LINE FAULT
533	10-Oct-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	4:14	4:24	0:10	LINE FAULT
534	10-Oct-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	4:27	4:37	0:10	LINE FAULT
535	10-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHWAR_110	5:55	6:08	0:13	LINE FAULT
536	10-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	19:50	19:58	0:08	LINE FAULT
537	10-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	20:27	20:35	0:08	LINE FAULT
538	10-Oct-2021	GULBARGA	110	YELBURGA-PARAM POOJA_IPP	YELBURGA_110	19:38	21:44	2:06	LINE CLEAR AVAILED
539	10-Oct-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	5:15	7:43	2:28	LINE FAULT
540	10-Oct-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	23:25	23:50	0:25	MAIN SUPPLY FAILURE
541	10-Oct-2021	GULBARGA	110	MASKI-SINDHNNOOR	MASKI_110	4:12	4:28	0:16	LINE FAULT
542	10-Oct-2021	GULBARGA	110	MASKI-SINDHNNOOR	MASKI_110	4:44	4:55	0:11	LINE FAULT
543	10-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	0:20	0:25	0:05	LINE FAULT
544	10-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	4:35	4:40	0:05	LINE FAULT
545	10-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	1:45	1:50	0:05	MAIN SUPPLY FAILURE
546	10-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	2:40	2:45	0:05	MAIN SUPPLY FAILURE
547	10-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	3:10	3:15	0:05	MAIN SUPPLY FAILURE
548	10-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:15	4:40	0:25	MAIN SUPPLY FAILURE
549	10-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	5:30	5:45	0:15	MAIN SUPPLY FAILURE
550	10-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	19:30	19:45	0:15	MAIN SUPPLY FAILURE
551	10-Oct-2021	GULBARGA	110	JANAWADA-SANTAPUR	SANTHAPUR_110	17:56	18:02	0:06	LINE FAULT
552	10-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	3:02	3:16	0:14	MAIN SUPPLY FAILURE
553	10-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	5:56	6:10	0:14	MAIN SUPPLY FAILURE
554	10-Oct-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNSAGI_110	1:45	1:51	0:06	LINE FAULT
555	10-Oct-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNSAGI_110	2:37	2:43	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
556	10-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	3:53	7:58	4:05	LINE CLEAR AVAILED
557	10-Oct-2021	GULBARGA	110	SHAHAPUR-YADGIR (IDLE LINE)	YADGIR_110	3:58	4:07	0:09	LINE FAULT
558	10-Oct-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNSAG I_110	4:16	4:30	0:14	LINE FAULT
559	10-Oct-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNSAG I_110	19:18	19:44	0:26	LINE FAULT
560	10-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR 2	DEODURGA_110	19:43	20:05	0:22	LINE FAULT
561	10-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR 1	DEODURGA_110	19:43	20:05	0:22	LINE FAULT
562	10-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_11 0,SDAIDHAPUR_110,SANATHI_I PP,CORE GREEN SUGAR_IPP	21:35	21:44	0:09	LINE FAULT
563	10-Oct-2021	GULBARGA	110	BELLAYSOUTH-HALAKUNDI	BELLARYSOUTH_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
564	10-Oct-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	12:00	16:25	4:25	NFBC ISSUED
565	10-Oct-2021	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	17:55	18:00	0:05	MAIN SUPPLY FAILURE
566	10-Oct-2021	GULBARGA	110	HV1	MATAMARI_110	14:40	15:15	0:35	LINE CLEAR AVAILED
567	10-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	22:10	22:15	0:05	MAIN SUPPLY FAILURE
568	10-Oct-2021	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	22:45	23:00	0:15	MAIN SUPPLY FAILURE
569	10-Oct-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	4:10	4:20	0:10	MAIN SUPPLY FAILURE
570	10-Oct-2021	GULBARGA	66	HV1	KOTTUR_66	13:20	13:25	0:05	LINE CLEAR AVAILED
571	10-Oct-2021	GULBARGA	66	HV1	KOTTUR_66	15:40	15:50	0:10	LINE CLEAR AVAILED
572	10-Oct-2021	GULBARGA	66	HV1	HALAVAGALU_66	9:20	10:50	1:30	LINE CLEAR AVAILED
573	10-Oct-2021	GULBARGA	66	KUDLIGI-BANAVEKAL	BANAVEKAL_66	7:00	7:10	0:10	LINE FAULT
574	10-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
575	10-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
576	10-Oct-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	19:38(10.10.2021)			LINE OPEN:LINE FAULT
577	10-Oct-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:03	14:11	4:08	LINE CLEAR AVAILED
578	10-Oct-2021	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	10:24	14:08	3:44	NFBC ISSUED
579	10-Oct-2021	HASSAN	110	HV1	HOSUR_110	10:20	14:10	3:50	LINE CLEAR AVAILED
580	10-Oct-2021	HASSAN	110	HV1	JADE_110	10:07	13:13	3:06	LINE CLEAR AVAILED
581	10-Oct-2021	HASSAN	110	HV2	JADE_110	10:07	13:14	3:07	LINE CLEAR AVAILED
582	10-Oct-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	12:15	12:39	0:24	LINE FAULT
583	10-Oct-2021	HASSAN	110	HV1	KAVOOR_220	19:16	19:26	0:10	TRANSFORMER FAULT
584	10-Oct-2021	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	10:02	18:39	8:37	LINE CLEAR AVAILED
585	10-Oct-2021	HASSAN	110	HV1	KITTADAHALLI_110	10:02	18:39	8:37	LINE CLEAR AVAILED
586	10-Oct-2021	HASSAN	110	HV2	KITTADAHALLI_110	10:02	18:39	8:37	LINE CLEAR AVAILED
587	10-Oct-2021	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	10:17	18:01	7:44	LINE FAULT
588	10-Oct-2021	HASSAN	110	HV2	BRAHMAVARA_110	15:42	16:15	0:33	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
589	10-Oct-2021	MYSURU	66	HV2	BOOKANAKERE_66	15:52	16:02	22:44	TRANSFORMER FAULT
590	10-Oct-2021	MYSURU	66	CR NAGARA-PANYADAHUNDI	HEMMARGALA_66 KARYA_66 PANDYADAHUNDI_66	20:17	23:06	2:49	LINE FAULT
591	10-Oct-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	16:37	18:49	2:12	LINE FAULT
592	10-Oct-2021	MYSURU	66	HV1	MANDGERE_66	12:40	13:00	0:20	LINE CLEAR AVAILED
593	10-Oct-2021	MYSURU	220	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	16:11	17:08	0:57	LINE FAULT
594	10-Oct-2021	MYSURU	66	HV1	HANNUR_66	19:07	18:31	0:25	LINE CLEAR AVAILED
595	10-Oct-2021	MYSURU	66	HV1	CHIKKA_MANDYA_66	22:33:11 (10/10/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
596	10-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
597	10-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50			LINE OPEN:LINE CLEAR AVAILED
598	10-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
599	10-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
600	10-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
601	10-Oct-2021	TUMKUR	220	TR-2	HIRIYUR_220	6:15	6:23	0:08	TRANSFORMER FAULT
602	10-Oct-2021	TUMKUR	66	ANTHRASANAHALLI 220kV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE 66,BELADARA_66	11:38	16:46	5:08	LINE CLEAR AVAILED
603	10-Oct-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	14:09	14:25	0:16	TRANSFORMER FAULT
604	10-Oct-2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:11	17:24	0:13	LINE FAULT
605	10-Oct-2021	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	9:28	9:31	0:03	LINE FAULT
606	10-Oct-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	9:26	11:41	2:15	LINE CLEAR AVAILED
607	10-Oct-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA 66	18:35	19:19	0:43	LINE FAULT
608	10-Oct-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	14:40	16:20	1:39	LINE CLEAR AVAILED
609	10-Oct-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON1_IPP_66	ENERCON1_IPP_66	6:20	6:35	0:14	HAND TRIPPED
610	10-Oct-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:04	17:14	0:09	LINE FAULT
611	10-Oct-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	17:57	18:07	0:09	LINE FAULT
612	10-Oct-2021	TUMKUR	66	TR-1	MATHOD_66	6:16	6:42	0:26	TRANSFORMER FAULT
613	10-Oct-2021	TUMKUR	66	PD KOTE66-AZURE POWER_IPP_66	AZURE POWER_IPP_66	23:41	23:59	0:17	HAND TRIPPED
614	10-Oct-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR_IPP_66	CLEAR SOLAR_IPP_66	23:41	23:59	0:18	HAND TRIPPED
615	10-Oct-2021	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	23:35	23:43	0:08	LINE FAULT
616	10-Oct-2021	TUMKUR	66	TR-1	PD KOTE_66	9:56	10:00	0:04	HAND TRIPPED
617	10-Oct-2021	TUMKUR	66	TR-1	MADADKERE_66	7:01	7:05	0:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	11-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	11-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
3	11-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
4	11-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
5	11-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
6	11-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
7	11-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
8	11-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)	13:45 (11.10.2021)	699:22HRS	TRANSFORMER CHARGED
9	11-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
10	11-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
11	11-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
12	11-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
13	11-Oct-2021	BAGALKOT	110	ANKLAGI-HIDIKAL	ANKALAGI_110	4:49	5:07	0:18	LINE FAULT
14	11-Oct-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	9:25	14:45	5:20	LINE CLEAR AVAILED
15	11-Oct-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	15:25 (11.10.2021)			LINE OPEN:LINE FAULT
16	11-Oct-2021	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	12:52	17:00	4:08	LINE CLEAR AVAILED
17	11-Oct-2021	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	14:46	15:45	0:59	LINE CLEAR AVAILED
18	11-Oct-2021	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA 2	GHATAPRABHA_110	17:17	17:42	0:25	LINE FAULT
19	11-Oct-2021	BAGALKOT	110	110/11KV,HV1	HOSA HONNATTI_110	18:26	18:50	0:24	TRANSFORMER FAULT
20	11-Oct-2021	BAGALKOT	110	ILKAL-AVAADA SOLAR	ILKAL_110	6:35	6:55	0:20	LINE FAULT
21	11-Oct-2021	BAGALKOT	110	KUSHTAGI 2-ILKAL	ILKAL_110	6:35	6:43	0:08	LINE FAULT
22	11-Oct-2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	16:11	18:05	1:54	LINE CLEAR AVAILED
23	11-Oct-2021	BAGALKOT	110	KIRUVATTI-UMACHAGI	UMACHAGI_110	12:18	13:39	1:21	LINE CLEAR AVAILED
24	11-Oct-2021	BAGALKOT	110	110/11KV,HV2	PG HUNASYAL_110	11:01	12:51	1:50	LINE CLEAR AVAILED
25	11-Oct-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YADAWAD_110	15:21	15:59	0:38	LINE CLEAR AVAILED
26	11-Oct-2021	BAGALKOT	110	TADASINAKOPPA-GAMANAGATTI(KUD DHARWAD)	GAMANAGATTI_110	13:48	13:50	0:02	HAND TRIPPED
27	11-Oct-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SADALGA_110	13:32	14:54	1:22	LINE CLEAR AVAILED
28	11-Oct-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	13:35	13:44	0:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
29	11-Oct-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	7:33	7:43	0:10	LINE CLEAR AVAILED
30	11-Oct-2021	BAGALKOT	220	AMBEWADI - NARENDRA2	AMBEWADI_220	0:28	6:28	6:00	LOAD CURTAILMENT
31	11-Oct-2021	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	12:35	17:21	4:46	LINE CLEAR AVAILED
32	11-Oct-2021	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:18	18:20	5:02	LINE CLEAR AVAILED
33	11-Oct-2021	BAGALKOT	110	HUBLI- TARIHAL1	HUBLI_220	9:07	15:49	6:42	LINE FAULT
34	11-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)	13:28 (11.09.2021)	42:00HRS	LINE CHARGED
35	11-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
36	11-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	AMBEWADI_220	10:22	11:38	1:16	LINE CLEAR AVAILED
37	11-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	AMBEWADI_220	11:42	13:36	1:54	TRANSFORMER FAULT
38	11-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	AMBEWADI_220	16:03	16:25	0:22	LINE CLEAR AVAILED
39	11-Oct-2021	BAGALKOT	110	110/11KV, HV1	GANESHGUDI_110	10:49	16:13	5:24	LINE CLEAR AVAILED
40	11-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	13:36 (11.09.2021)	18:24(11.10.21)	5:06 hrs	LINE OPEN:LINE FAULT
41	11-Oct-2021	BAGALKOT	110	110/11KV, HV1	KUD DHARWAD_110	15:45	16:25	0:40	LINE CLEAR AVAILED
42	11-Oct-2021	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:28	18:24	4:56	LINE FAULT
43	11-Oct-2021	BAGALKOT	220	ATHANI- MAHALINGAPUR	ATHANI_220	16:18	16:59	0:41	LINE FAULT
44	11-Oct-2021	BAGALKOT	110	CHIKKODI- RAIBAG1	RAIBAG_110	5:15	10:10	4:55	LINE FAULT
45	11-Oct-2021	BAGALKOT	110	SOUDATTI- RAMDURGA1	RAMDURGA_110	5:30	6:16	0:46	LINE FAULT
46	11-Oct-2021	BAGALKOT	110	SOUDATTI- RAMDURGA2	RAMDURGA_110	5:30	6:16	0:46	LINE FAULT
47	11-Oct-2021	BAGALKOT	110	110/11KV, HV1	NAVALAGI_110	16:15	16:45	0:30	MAIN SUPPLY FAILURE
48	11-Oct-2021	BAGALKOT	110	110/11KV, HV2	NAVALAGI_110	16:15	16:45	0:30	MAIN SUPPLY FAILURE
49	11-Oct-2021	BAGALKOT	110	NAVALAGI- BANAHATTI	BANAHATTI_110	16:15	16:45	0:30	MAIN SUPPLY FAILURE
50	11-Oct-2021	BAGALKOT	110	NAVALAGI- JAMKHANDI	JAMKHANDI_110	16:15	16:45	0:30	MAIN SUPPLY FAILURE
51	11-Oct-2021	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:23	12:11	1:48	LINE FAULT
52	11-Oct-2021	BENGALURU	66	RAJANUKUNTE - D B PURA 220	RAJANUKUNTE	20:40	21:15	0:35	LOAD CHANGE OVER
53	11-Oct-2021	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	15:16	15:20	0:04	LOAD CHANGE OVER
54	11-Oct-2021	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	15:26	15:30	0:04	LOAD CHANGE OVER
55	11-Oct-2021	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 220 1	T GOLLAHALLI	0:05	11:32	11:27	MAIN SUPPLY FAILURE
56	11-Oct-2021	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 220 2	T GOLLAHALLI	0:05	11:32	11:27	MAIN SUPPLY FAILURE
57	11-Oct-2021	BENGALURU	220	HV1	T GOLLAHALLI	0:05	11:32	11:27	TRANSFORMER FAULT
58	11-Oct-2021	BENGALURU	220	HV2	T GOLLAHALLI	0:05	11:32	11:27	TRANSFORMER FAULT
59	11-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	BAIRAKURU, NANGLI	0:05	11:35	11:30	LINE CLEAR AVAILED
60	11-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	0:05	11:35	11:30	LINE CLEAR AVAILED
61	11-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - THAYALUR	THAYALUR, TAMAKA, N G HULKUR, MALLANAYAKANAHALLI	0:05	11:35	11:30	LINE CLEAR AVAILED
62	11-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	0:05	11:35	11:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
63	11-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	0:05	11:35	11:30	LINE CLEAR AVAILED
64	11-Oct-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	5:48	7:41	1:53	LINE FAULT
65	11-Oct-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	5:48	6:40	0:52	TRANSFORMER FAULT
66	11-Oct-2021	BENGALURU	66	HV1	ANEKAL	15:03	15:40	0:37	TRANSFORMER FAULT
67	11-Oct-2021	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	12:55	13:05	0:10	LINE CLEAR AVAILED
68	11-Oct-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	20:39	20:45	0:06	LINE FAULT
69	11-Oct-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	20:45	23:49	3:04	LINE FAULT
70	11-Oct-2021	BENGALURU	220	LV1	JIGANI 220	7:42	9:02	1:20	LINE CLEAR AVAILED
71	11-Oct-2021	BENGALURU	220	LV2	JIGANI 220	7:42	9:02	1:20	LINE CLEAR AVAILED
72	11-Oct-2021	BENGALURU	66	HV1	JIGANI 220	7:42	9:02	1:20	LINE CLEAR AVAILED
73	11-Oct-2021	BENGALURU	66	HV2	JIGANI 220	7:42	9:02	1:20	LINE CLEAR AVAILED
74	11-Oct-2021	BENGALURU	66	HV1	JIGANI 220	9:32	10:15	0:43	LINE CLEAR AVAILED
75	11-Oct-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	7:42	9:02	1:20	MAIN SUPPLY FAILURE
76	11-Oct-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	7:42	9:02	1:20	MAIN SUPPLY FAILURE
77	11-Oct-2021	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	MELUR	13:22	13:31	0:09	LINE FAULT
78	11-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	6:24	6:45	0:20	MAIN SUPPLY FAILURE
79	11-Oct-2021	BENGALURU	66	HV2	THAYALUR	12:00	12:05	0:05	LINE CLEAR AVAILED
80	11-Oct-2021	BENGALURU	220	HV1	YELAHANKA 220	6:24	6:45	0:20	TRANSFORMER FAULT
81	11-Oct-2021	BENGALURU	66	HV1	YELAHANKA 220	6:24	6:34	0:09	MAIN SUPPLY FAILURE
82	11-Oct-2021	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	MELUR	13:22	13:31	0:09	LINE FAULT
83	11-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	6:24	6:45	0:20	MAIN SUPPLY FAILURE
84	11-Oct-2021	BENGALURU	66	HV2	THAYALUR	12:00	12:05	0:05	LINE CLEAR AVAILED
85	11-Oct-2021	BENGALURU	220	HV1	YELAHANKA 220	6:24	6:45	0:20	TRANSFORMER FAULT
86	11-Oct-2021	BENGALURU	66	HV1	YELAHANKA 220	6:24	6:34	0:09	MAIN SUPPLY FAILURE
87	11-Oct-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL	ANEKAL, SURYANAGARA	7:28	7:33	1:09	MAIN SUPPLY FAILURE
88	11-Oct-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	23:49(11/10/2021)			LINE OPEN:LINE FAULT
89	11-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:45(08.10.2021)	7:30(11.10.2021)	56:45HRS	LINE CHARGED
90	11-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:59(11.10.2021)			LINE OPEN:LINE CLEAR AVAILED
91	11-Oct-2021	GULBARGA	400	BTPSG-GUTTUR	HIRIYUR_400	13:09	13:49	0:40	LINE FAULT
92	11-Oct-2021	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	14:38	14:48	0:10	LINE CLEAR AVAILED
93	11-Oct-2021	GULBARGA	220	MALLAT-RTPS	MALLT_220	20:02	20:25	0:23	LINE FAULT
94	11-Oct-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	3:49	4:16	0:27	LINE FAULT
95	11-Oct-2021	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	22:34(11.10.2021)			LINE OPEN:LINE CLEAR AVAILED
96	11-Oct-2021	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	17:55(10.10.2021)	11:02(11.10.2021)	17:07 HRS	LINE CHARGED
97	11-Oct-2021	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	14:42	18:00	3:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
98	11-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
99	11-Oct-2021	GULBARGA	220	BTPSG-LINGAPUR	BTPSG_400	16:10	18:06	1:56	LINE FAULT
100	11-Oct-2021	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	8:09	8:11	7:32	LINE CLEAR AVAILED
101	11-Oct-2021	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	13:18	14:52	7:32	LINE CLEAR AVAILED
102	11-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	5:40			LINE OPEN:LINE FAULT
103	11-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	10:10	20:05	9:55	LINE FAULT
104	11-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARAGI_110	10:10	10:50	0:40	LINE FAULT
105	11-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:43	3:48	0:05	LINE FAULT
106	11-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	5:48	5:53	0:05	LINE FAULT
107	11-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARAGI_110	10:50	10:55	0:05	LINE CLEAR AVAILED
108	11-Oct-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	5:48	9:58	4:10	LINE FAULT
109	11-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:57	7:30	0:33	LINE CLEAR AVAILED
110	11-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110	4:05	4:13	0:08	LINE FAULT
111	11-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	5:10	5:16	0:06	LINE FAULT
112	11-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	5:10	5:30	0:20	LINE FAULT
113	11-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:50	22:00	0:10	LINE FAULT
114	11-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:00	21:05	0:05	LINE FAULT
115	11-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:15(11.10.2021)			LINE OPEN:LINE FAULT
116	11-Oct-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	5:29	5:57	0:28	LINE FAULT
117	11-Oct-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	5:48	5:58	0:10	LINE FAULT
118	11-Oct-2021	GULBARGA	110	HV3	VALKAMDINI_110	10:00	10:05	0:05	TRANSFORMER FAULT
119	11-Oct-2021	GULBARGA	110	BELLAYSOUTH-HALAKUNDI	BELLARYSOUTH_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
120	11-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSS K IPP,BHALKI SUGAR IPP	5:32	5:01	5:27	LINE FAULT
121	11-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSS K IPP,BHALKI SUGAR IPP	5:32	7:26	7:32	LINE FAULT
122	11-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	4:14	4:22	0:08	LINE FAULT
123	11-Oct-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:10	23:18	0:08	LINE FAULT
124	11-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	11:27	11:37	0:10	LINE FAULT
125	11-Oct-2021	GULBARGA	110	STAR METALLIC -MUNIRABAD	MUNIRABAD_220	16:11	16:25	0:14	LINE FAULT
126	11-Oct-2021	GULBARGA	110	YELBURGA-KUKUNOOR	KUKUNOOR_110	14:45	15:08	0:23	LINE FAULT
127	11-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	4:31	4:38	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
128	11-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	18:10	18:18	0:08	LINE FAULT
129	11-Oct-2021	GULBARGA	110	SEDAM-VICAT SAGAR	SEDAM_220	3:00	3:21	0:21	LINE FAULT
130	11-Oct-2021	GULBARGA	110	SEDAM-VICAT SAGAR	SEDAM_220	3:55	4:10	0:15	LINE FAULT
131	11-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:58	12:14	0:16	LINE FAULT
132	11-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	19:22	19:35	0:13	LINE FAULT
133	11-Oct-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:53	19:58	0:05	LINE FAULT
134	11-Oct-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:58	22:02	0:04	LINE FAULT
135	11-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
136	11-Oct-2021	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	6:28	6:39	0:11	LINE FAULT
137	11-Oct-2021	GULBARGA	110	KUSTAGI-ILKAL2	ILKAL_110	6:28	9:55	3:27	LINE FAULT
138	11-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	11:25	11:40	0:15	MAIN SUPPLY FAILURE
139	11-Oct-2021	GULBARGA	110	HV3	VALKAMDINI_110	1:05	1:15	0:10	TRANSFORMER FAULT
140	11-Oct-2021	GULBARGA	110	RAJESHWAR-SASTHAPUR	RAJESHWAR_110	14:15	14:40	0:25	LINE CLEAR AVAILED
141	11-Oct-2021	GULBARGA	110	HV3	KEREHALLI_110	10:42	10:57	0:15	TRANSFORMER FAULT
142	11-Oct-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	19:30(11/10/2021)			MAIN SUPPLY FAILURE
143	11-Oct-2021	GULBARGA	66	HV2	BENNEHALLI_66	20:10	20:23	0:13	TRANSFORMER FAULT
144	11-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
145	11-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
146	11-Oct-2021	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	12:42	16:34	3:52	LINE CLEAR AVAILED
147	11-Oct-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:42	16:34	3:52	NFBC ISSUED
148	11-Oct-2021	HASSAN	110	HV3	ALKOLA_110	16:01	18:30	2:29	TRANSFORMER FAULT
149	11-Oct-2021	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	19:38(10.10.2021)	1:07(11.1 0.2021)	5:29HRS	LINE CHARGED
150	11-Oct-2021	HASSAN	110	HV1	JAVAGAL_110	11:02	13:00	1:58	LINE CLEAR AVAILED
151	11-Oct-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	15:27	15:46	0:19	LINE FAULT
152	11-Oct-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:27	15:34	0:07	LINE FAULT
153	11-Oct-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	14:17	14:24	0:07	LINE FAULT
154	11-Oct-2021	HASSAN	66	HV2	SALAGAME_66	14:50	15:08	0:18	TRANSFORMER FAULT
155	11-Oct-2021	HASSAN	66	HV1	YESLUR_66	12:55	14:23	1:28	MAIN SUPPLY FAILURE
156	11-Oct-2021	MYSURU	66	BOOKANAKERE-CHINKURALI	CHINAKURALI_66 BANANGADI_66 PANDAVAPURA_66	15:58	16:02	22:44	LINE FAULT
157	11-Oct-2021	MYSURU	66	CR NAGARA-PANYADAHUNDI	NO STATIONS EFFECTED	12:30	13:34	1:04	LINE CLEAR AVAILED
158	11-Oct-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	17:32	18:03	0:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
159	11-Oct-2021	MYSURU	66	HV1	HANNUR_66	9:34	18:31	8:57	LINE CLEAR AVAILED
160	11-Oct-2021	MYSURU	66	JAKKANAHALLI-NAGMANGALA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI_66 NAGAMANGALA_66	16:58	18:49	1:51	LINE FAULT
161	11-Oct-2021	MYSURU	66	KR PETE 220-BOOKANAKERE	SHEELUNERE_66 GANJIGERE_66 CHINAKURALI_66 BANANGADI_66 PANDAVAPURA_66	15:44	15:52	0:08	LINE FAULT
162	11-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	15:35	15:54	0:18	LINE FAULT
163	11-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_67	16:07	16:14	0:06	LINE FAULT
164	11-Oct-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	6:23	6:27	0:04	LINE FAULT
165	11-Oct-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	13:11	13:17	0:05	LINE FAULT
166	11-Oct-2021	MYSURU	66	HV1	MANDGERE_66	12:40	13:00	0:20:00	LINE CLEAR AVAILED
167	11-Oct-2021	MYSURU	66	MEGALAPURA-HEBBANI	CHIDRAVALLI_66 GARGESHWARI_66 BGPURA_66 THUMBLA_66 VYASRAJPURA_66	13:35	17:23	3:47	LINE FAULT
168	11-Oct-2021	MYSURU	66	HV2	PONNAMPET_66	17:27	17:35	0:08	TRANSFORMER FAULT
169	11-Oct-2021	MYSURU	66	SHANIVARSANTHE-YESSLUR	YESSLUR_66 HETHUR_66	12:52	13:43	0:50:45	LINE CLEAR AVAILED
170	11-Oct-2021	MYSURU	66	HV1	SHANIVARSANTHE_66	14:18	15:23	1:04:54	LINE CLEAR AVAILED
172	11-Oct-2021	MYSURU	66	HV1	CHIKKA_MANDYA_66	22:33:11 (10/10/2021)	8:04:00 (11.10.2021)	9:30HRS	LINE CHARGED
173	11-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
174	11-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50			LINE OPEN:LINE CLEAR AVAILED
175	11-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
176	11-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
177	11-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
178	11-Oct-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	12:47	15:32	2:45	LINE FAULT
179	11-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	12:47	16:53	4:05	LINE CLEAR AVAILED
180	11-Oct-2021	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	5:32	12:29	6:56	LINE CLEAR AVAILED
181	11-Oct-2021	TUMKUR	220	TR-2	KDBVNP	11:37	16:37	4:59	LINE CLEAR AVAILED
182	11-Oct-2021	TUMKUR	220	TR-2	PAVAGADA_220	11:17	13:20	2:03	LINE CLEAR AVAILED
183	11-Oct-2021	TUMKUR	110	TR-1	MAYASANDRA_110	18:03	18:35	0:31	TRANSFORMER FAULT
184	11-Oct-2021	TUMKUR	110	TR-1	KALLUR_110	11:11	17:08	5:57	LINE CLEAR AVAILED
186	11-Oct-2021	TUMKUR	66	TR-2	BHARAMAGIRI_66	18:42	18:47	0:04	TRANSFORMER FAULT
187	11-Oct-2021	TUMKUR	66	TR-1	BUKKAPATNA_66	12:15	12:51	0:35	LINE CLEAR AVAILED
188	11-Oct-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP 66	6:21	6:56	0:35	LINE FAULT
189	11-Oct-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP 66	7:53	8:04	0:11	LINE FAULT
190	11-Oct-2021	TUMKUR	66	TR-1	CHITRAHALLI_66	18:35	18:41	0:06	TRANSFORMER FAULT
191	11-Oct-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_6 6,KADAJJI 66	12:55	13:31	0:35	HAND TRIPPED
192	11-Oct-2021	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	12:55	13:31	0:35	HAND TRIPPED
193	11-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	16:46	16:56	0:09	LINE FAULT
194	11-Oct-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	14:08	14:20	0:11	MAIN SUPPLY FAILURE
195	11-Oct-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	18:09	18:32	0:22	MAIN SUPPLY FAILURE
196	11-Oct-2021	TUMKUR	66	TR-1	HIRIYUR_66	16:59	17:54	0:54	LINE CLEAR AVAILED
197	11-Oct-2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:35	11:41	0:06	LINE FAULT
198	11-Oct-2021	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI 66	13:36	13:47	0:11	LINE FAULT
199	11-Oct-2021	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI 66	14:27	14:33	0:06	LINE FAULT
200	11-Oct-2021	TUMKUR	66	HIRIYUR220kV-P R PURA	P R PURA_66	14:00	14:13	0:13	LINE FAULT
201	11-Oct-2021	TUMKUR	66	HIRIYUR220kV-P R PURA	P R PURA_66	18:08	18:15	0:07	LINE FAULT
202	11-Oct-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI 66	9:42	9:52	0:10	LINE FAULT
203	11-Oct-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI 66	11:13	11:24	0:11	LINE FAULT
204	11-Oct-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	11:48	11:58	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
205	11-Oct-2021	TUMKUR	66	TR-2(LV-2)	KDBVNP	11:37	16:37	5:00	LINE CLEAR AVAILED
206	11-Oct-2021	TUMKUR	66	PDKOTE-AZURE SOLAR	PDKOTE_66	14:02	14:25	0:22	MAIN SUPPLY FAILURE
207	11-Oct-2021	TUMKUR	66	PDKOTE-AZURE SOLAR	PDKOTE_66	18:05	18:37	0:31	MAIN SUPPLY FAILURE
208	11-Oct-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	14:03	14:25	0:22	MAIN SUPPLY FAILURE
209	11-Oct-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	18:05	18:34	0:29	MAIN SUPPLY FAILURE
210	11-Oct-2021	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	18:04	18:20	0:15	MAIN SUPPLY FAILURE
211	11-Oct-2021	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	14:03	14:25	0:22	MAIN SUPPLY FAILURE
212	11-Oct-2021	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	18:05	18:39	0:33	MAIN SUPPLY FAILURE
213	11-Oct-2021	TUMKUR	66	TR-2	PAVAGADA_220	11:09	13:21	2:11	LINE CLEAR AVAILED
214	11-Oct-2021	TUMKUR	66	TR-1	PURUVARA_66	13:36	13:45	0:09	LINE CLEAR AVAILED
215	11-Oct-2021	TUMKUR	66	TR-2	RAMAPURA_66	13:10	13:30	0:20	LINE CLEAR AVAILED
216	11-Oct-2021	TUMKUR	66	TR-1	RAMAPURA_66	13:35	14:10	0:35	LINE CLEAR AVAILED
217	11-Oct-2021	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	22:01	23:23	1:22	LINE FAULT
218	11-Oct-2021	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	22:01	23:23	1:21	LINE FAULT