

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 25.06.2019 TO 01.07.2019**

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	25-Jun-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	12:03	12:29	0:26	LINE FAULT
2	25-Jun-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	15:08	17:42	2:34	TRANSFORMER FAULT
3	25-Jun-19	BAGALKOT	110	BETAGERI-NAREGALL	NAREGALL_110	5:56	6:12	0:16	LINE FAULT
4	25-Jun-19	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	15:17	16:44	1:27	LINE CLEAR AVAILED
5	25-Jun-19	BAGALKOT	110	RON 1-GAJENDRAGAD	GAJENDRAGAD_110	5:30	13:17	7:47	MAIN SUPPLY FAILURE
6	25-Jun-19	BAGALKOT	110	RON 2-GAJENDRAGAD	GAJENDRAGAD_110	5:30	6:38	1:08	MAIN SUPPLY FAILURE
7	25-Jun-19	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	14:49	16:05	1:16	LINE CLEAR AVAILED
8	25-Jun-19	BAGALKOT	110	110/11KV,HV2	GOPANAKOPPA_110	16:04	16:10	0:06	HAND TRIPPED
9	25-Jun-19	BAGALKOT	110	110/11KV,HV4	GOPANAKOPPA_110	15:36	15:46	0:10	HAND TRIPPED
10	25-Jun-19	BAGALKOT	110	110/33KV,HV2	GULEDGUDD_110&33KV-SIRIU&KAMATAGI	10:59	11:06	0:07	TRANSFORMER FAULT
11	25-Jun-19	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	17:51	18:06	0:15	TRANSFORMER FAULT
12	25-Jun-19	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110	18:04	19:23	1:19	LINE FAULT
13	25-Jun-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	11:29	13:34	2:05	LINE CLEAR AVAILED
14	25-Jun-19	BAGALKOT	110	HIREHAL_110	HIREHAL-MFR SLR	6:27	6:37	0:10	MAIN SUPPLY FAILURE
15	25-Jun-19	BAGALKOT	110	HIREHAL_110	HIREHAL-BADAMI(IDLE)	6:26	6:29	0:03	MAIN SUPPLY FAILURE
16	25-Jun-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33	19:32	19:42	0:10	TRANSFORMER FAULT
17	25-Jun-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	18:04	18:13	0:09	LINE FAULT
18	25-Jun-19	BAGALKOT	110	RON-GAJENDRAGAD1	RON_110	5:30	13:16	7:46	LINE FAULT
19	25-Jun-19	BAGALKOT	110	RON-NAREGAL	RON_110	5:30	6:17	0:47	LINE FAULT
20	25-Jun-19	BAGALKOT	220	220/110KV HV2&LV2	MAHALINGAPUR_220	0:00	11:59	11:59	TRANSFORMER FAULT
21	25-Jun-19	BAGALKOT	110	KUDACHI220-TERDAL(MORAB)	MORAB_110	19:59	20:23	0:24	LINE FAULT
22	25-Jun-19	BAGALKOT	220	220/110KV HV2&LV2	MAHALINGAPUR_220	10:35	17:47	7:12	TRANSFORMER FAULT
23	25-Jun-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	10:55	23:59	13:04	LINE CLEAR AVAILED
24	25-Jun-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	17:51	18:12	0:21	LINE FAULT
25	25-Jun-19	BAGALKOT	110	MAHALINGAPUR-JAMKHANDI	JAMKHANDI_110	11:56	12:09	0:13	HAND TRIPPED
26	25-Jun-19	BAGALKOT	110	110/33KV, HV2	JAMKHANDI_110, HIPPARGI_33, MADARKANDI_33	15:00	21:40	6:40	TRANSFORMER FAULT
27	25-Jun-19	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	12:35	12:52	0:17	LINE CLEAR AVAILED
28	25-Jun-19	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	18:01	18:50	0:49	MAIN SUPPLY FAILURE
29	25-Jun-19	BENGALURU	220	HV1	VRISHBHAVATHI 220	18:01	18:28	0:27	MAIN SUPPLY FAILURE
30	25-Jun-19	BENGALURU	220	HV2	VRISHBHAVATHI 220	18:01	18:28	0:27	MAIN SUPPLY FAILURE
31	25-Jun-19	BENGALURU	66	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	18:01	18:28	0:27	MAIN SUPPLY FAILURE
32	25-Jun-19	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	18:38	18:44	0:06	LOAD CHANGEOVER
33	25-Jun-19	BENGALURU	66	SIR MV LAYOUT - VRISHBHAVATHI 220	SIR MV LAYOUT, KENGERI SATELLITE TOWN	18:01	19:18	1:17	MAIN SUPPLY FAILURE

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
34	25-Jun-19	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	SIR MV LAYOUT, KENGERI SATELLITE TOWN	22:20	22:23	0:03	LOAD CHANGEOVER
35	25-Jun-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	KORAMANGALA, K & C VALLEY, NAL (EHT)	16:32	17:40	1:08	LINE FAULT
36	25-Jun-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	18:01	18:32	0:31	MAIN SUPPLY FAILURE
37	25-Jun-19	BENGALURU	66	HV2	KUNDANA	17:05	17:35	0:29	LINE CLEAR AVAILED
38	25-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:22	5:35	0:13	LINE FAULT
39	25-Jun-19	GULBARGA	220	HV1	KUSTAGI_220	19:48	20:40	0:52	TRANSFORMER FAULT
40	25-Jun-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	16:42	23:59	7:17	LINE CLEAR AVAILED
41	25-Jun-19	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADALAPURA_110	2:10	2:20	0:10	LINE FAULT
42	25-Jun-19	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	5:25	5:30	0:05	LINE FAULT
43	25-Jun-19	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110	11:05	11:43	0:38	NFBC ISSUED
44	25-Jun-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:59	11:53	0:54	HAND TRIPPED
45	25-Jun-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	5:25	5:30	0:05	LINE FAULT
46	25-Jun-19	GULBARGA	110	HV2	SHORAPUR_110	13:35	13:53	0:18	TRANSFORMER FAULT
47	25-Jun-19	GULBARGA	110	KUSTAGI-ILKAL1	KUSTAGI_220	19:48	20:50	1:02	LINE FAULT
48	25-Jun-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	23:22	23:32	0:10	LINE FAULT
49	25-Jun-19	GULBARGA	110	SHAHAPUR-SHAHABAD	SHAHPUR_110,NALWAR_110, GOOGLE_110	12:20	18:00	5:40	LINE CLEAR AVAILED
50	25-Jun-19	HASSAN	400	TALAGUPPA_400	TALAGU-HSN400#1	10:34	14:27	3:53	LINE CLEAR AVAILED
51	25-Jun-19	HASSAN	220	sharavathy_gen	SHRAVTY-SHIRALKOPPA	10:05	11:54	1:49	LINE CLEAR AVAILED
52	25-Jun-19	HASSAN	220	sharavathy_gen	SHRAVTY-SHIRALKOPPA	12:01	12:26	0:25	LINE CLEAR AVAILED
53	25-Jun-19	HASSAN	220	sharavathy_gen	SHRAVTY-SHIRALKOPPA	15:46	16:09	0:23	LINE CLEAR AVAILED
54	25-Jun-19	HASSAN	220	SHIRALKOPPA_220	HV2	10:05	12:24	2:19	LINE CLEAR AVAILED
55	25-Jun-19	HASSAN	220	SHIRALKOPPA_220	HV2	15:45	16:10	0:25	HAND TRIPPED
56	25-Jun-19	HASSAN	220	SHIRALKOPPA_220	HV3	16:16	16:23	0:07	HAND TRIPPED
57	25-Jun-19	HASSAN	220	SHIRALKOPPA_220	SHRLKP-SGS	10:05	12:24	2:19	LINE CLEAR AVAILED
58	25-Jun-19	HASSAN	220	SHIRALKOPPA_220	SHRLKP-SGS	15:45	16:10	0:25	HAND TRIPPED
59	25-Jun-19	HASSAN	220	SHIRALKOPPA_220	SHRLKP-SGS	16:16	16:23	0:07	HAND TRIPPED
60	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-BARANG	10:05	12:24	2:19	LINE CLEAR AVAILED
61	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-BARANG	15:45	16:10	0:25	HAND TRIPPED
62	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-BARANG	16:16	16:23	0:07	HAND TRIPPED
63	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	LV2	10:05	12:24	2:19	LINE CLEAR AVAILED
64	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	LV2	15:45	16:10	0:25	HAND TRIPPED
65	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	LV3	16:16	16:23	0:07	HAND TRIPPED
66	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-SHIKARIPURA	10:05	12:24	2:19	LINE CLEAR AVAILED
67	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-SHIKARIPURA	15:45	16:10	0:25	HAND TRIPPED
68	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-SHIKARIPURA	16:16	16:23	0:07	HAND TRIPPED
69	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-SHIRALKOPPA	10:05	12:24	2:19	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
70	25-Jun-19	HASSAN	110	SHIRALKOPPA_220	SHRLKP-SHIRALKOPPA	15:45	16:10	0:25	HAND TRIPPED
71	25-Jun-19	HASSAN	110	ANAVATTI_110	ANAVATI-BARNGI	10:05	12:25	2:20	MAIN SUPPLY FAILURE
72	25-Jun-19	HASSAN	110	HALADY_110	HV1	11:03	17:11	6:08	LINE CLEAR AVAILED
73	25-Jun-19	HASSAN	110	HALADY_110	HV2	14:51	15:45	0:54	LINE CLEAR AVAILED
74	25-Jun-19	HASSAN	110	KALLUSADARAHALLY_110	HV1	11:32	15:43	4:11	LINE CLEAR AVAILED
75	25-Jun-19	HASSAN	110	SORABA_110	SORABA-SHR220	10:00	13:20	3:20	MAIN SUPPLY FAILURE
76	25-Jun-19	HASSAN	66	BALLUPETE_66	BALLUPE-SAKLESH PURA	10:29	11:48	1:19	NFBC ISSUED
77	25-Jun-19	HASSAN	66	BYACHANAHALLI_66	BYACHAN-HNPURA	7:35	7:50	0:15	MAIN SUPPLY FAILURE
78	25-Jun-19	HASSAN	66	BYACHANAHALLI_66	HV1	8:12	8:16	0:04	LINE FAULT
79	25-Jun-19	HASSAN	66	BYACHANAHALLI_66	HV1	12:40	13:07	0:27	LINE CLEAR AVAILED
80	25-Jun-19	HASSAN	66	KANDLI_66	KANDLI-SAKLESHPUR	10:14	12:18	2:04	LINE CLEAR AVAILED
81	25-Jun-19	HASSAN	66	RAMNATHPURA_66	RAMNAT-BNDSTHL	7:32	7:46	0:14	LINE FAULT
82	25-Jun-19	HASSAN	66	RAMNATHPURA_66	RAMNAT-KATTEPURA_MINIH	6:56	9:20	2:24	NFBC ISSUED
83	25-Jun-19	HASSAN	66	RAMESHWARNAGAR_66	HV2	11:25	13:11	1:46	LINE CLEAR AVAILED
84	25-Jun-19	HASSAN	66	SAKLESH PURA_66	SAKALE-HASSAN	10:12	11:51	1:39	LINE CLEAR AVAILED
85	25-Jun-19	HASSAN	66	SAKLESH PURA_66	SAKALE-IPCL1	11:51	17:29	5:38	LINE CLEAR AVAILED
86	25-Jun-19	HASSAN	66	SAKLESH PURA_66	SAKALE-IPCL2	11:51	15:46	3:55	LINE CLEAR AVAILED
87	25-Jun-19	MYSORE	66	HV1	BOGADHI_66	11:48	13:55	2:06	LINE CLEAR AVAILED
88	25-Jun-19	MYSORE	66	CHINAKURLI-BOOKANAKERE	CHINAKURALI_66	13:14	13:49	0:34	LINE FAULT
89	25-Jun-19	MYSORE	66	CHINAKURLI-PANDAVAPURA	BANANGADI_66	13:14	13:49	0:34	LINE FAULT
90	25-Jun-19	MYSORE	66	COWDALLI-MARTALLI	MARTAHALLI_66, RAMAPURA_MYS_66	10:07	10:14	0:07	LINE FAULT
91	25-Jun-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:15	12:21	1:06	LINE CLEAR AVAILED
92	25-Jun-19	MYSORE	66	HALAGURU-TK HALLI	HALAGUR_66	9:48	15:46	5:57	LINE CLEAR AVAILED
93	25-Jun-19	MYSORE	66	HALAGURU-HONAGANAHALLI	HALAGUR_66	9:48	15:46	5:57	LINE CLEAR AVAILED
94	25-Jun-19	MYSORE	66	HV2	HAMPAPURA_66	11:05	11:09	0:04	TRANSFORMER FAULT
95	25-Jun-19	MYSORE	66	HV1	HUNSUR_66	18:10	19:10	1:00	LINE CLEAR AVAILED
96	25-Jun-19	MYSORE	66	HV1	SANTHESARAGUR_66	7:12	7:17	0:05	TRANSFORMER FAULT
97	25-Jun-19	MYSORE	66	HV2	SANTHEBACHALLI_66	12:05	14:15	2:10	LINE CLEAR AVAILED
98	25-Jun-19	MYSORE	66	HV1	SRIRANGAPATNA_66	13:52	13:56	0:03	TRANSFORMER FAULT
99	25-Jun-19	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	14:13	16:31	2:18	LINE FAULT
100	25-Jun-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA	MRSMSG_220	14:03	14:14	0:11	LINE FAULT
101	25-Jun-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	14:07	14:18	0:10	HAND TRIPPED
102	25-Jun-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	14:07	14:19	0:11	HAND TRIPPED
103	25-Jun-19	TUMKUR	110	TR-1	HALKURKE_110	10:59	11:51	0:51	LINE CLEAR AVAILED
104	25-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	12:31	15:00	2:29	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
105	25-Jun-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:50	17:00	0:09	TRANSFORMER FAULT
106	26-Jun-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR	VAJRAMATTI_220	0:00	17:15	17:15	NFBC ISSUED
107	26-Jun-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	0:00	10:07	10:07	LINE CLEAR AVAILED
108	26-Jun-19	BAGALKOT	110	110/11KV, HV2	GOKAK_110	5:07	5:15	0:08	TRANSFORMER FAULT
109	26-Jun-19	BAGALKOT	110	GHATAPRABHA-HIDIKALDAM	HIDIKAL DAM_110	5:05	17:05	12:00	LINE FAULT
110	26-Jun-19	BAGALKOT	110	110/11KV, HV4	GHATAPRABHA_110	5:05	5:42	0:37	TRANSFORMER FAULT
111	26-Jun-19	BAGALKOT	110	GADAG110-BETAGERI	BETAGERI_110, NAREGAL_110, RON_110, GAJENDRGAD_110	12:37	13:15	0:38	LINE FAULT
112	26-Jun-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	6:19	6:41	0:22	LINE FAULT
113	26-Jun-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	0:00	18:02	18:02	LINE CLEAR AVAILED
114	26-Jun-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	10:44	13:20	2:36	NFBC ISSUED
115	26-Jun-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	0:00	18:02	18:02	LINE CLEAR AVAILED
116	26-Jun-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	5:42	5:43	0:00	LOAD CHANGEOVER
117	26-Jun-19	BENGALURU	66	ELECTRONIC CITY P2 S2 - BIOCON (EHT)	BIOCON (EHT)	19:36	19:41	0:05	MAIN SUPPLY FAILURE
118	26-Jun-19	BENGALURU	66	ELECTRONIC CITY P2 S2 - NAGNATHPURA 220	ELECTRONIC CITY P2 S2, BIOCON (EHT)	18:36	19:36	0:59	LINE FAULT
119	26-Jun-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	18:36	19:32	0:56	LINE FAULT
120	26-Jun-19	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	17:23	17:35	0:11	LINE FAULT
121	26-Jun-19	BENGALURU	66	HV2	RMV	11:18	11:20	0:01	LINE CLEAR AVAILED
122	26-Jun-19	BENGALURU	66	HV1	BIDADI 220	18:29	19:30	1:01	TRANSFORMER FAULT
123	26-Jun-19	BENGALURU	66	HV2	HEJJALA	15:22	15:26	0:04	TRANSFORMER FAULT
124	26-Jun-19	BENGALURU	66	HV1	SHOBHA APARTMENT	22:18	23:59	1:40	LINE CLEAR AVAILED
125	26-Jun-19	BENGALURU	66	HV1	TK HALLI 220	3:40	4:07	0:26	TRANSFORMER FAULT
126	26-Jun-19	BENGALURU	66	REMCO - NRS	REMCO	2:49	2:54	0:05	LOAD CHANGEOVER
127	26-Jun-19	BENGALURU	66	NANDINI LOAYOUT - NRS 220	NANDINI LAYOUT	17:18	17:25	0:07	LOAD CHANGEOVER
128	26-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	7:41	7:43	0:01	LOAD CHANGEOVER
129	26-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	8:45	8:47	0:02	LOAD CHANGEOVER
130	26-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	7:41	7:43	0:01	LOAD CHANGEOVER
131	26-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	7:41	7:43	0:01	LOAD CHANGEOVER
132	26-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	8:45	8:47	0:02	LOAD CHANGEOVER
133	26-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	8:45	8:47	0:02	LOAD CHANGEOVER
134	26-Jun-19	BENGALURU	66	HV1	D CROSS	12:58	13:26	0:28	TRANSFORMER FAULT
135	26-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	11:24	13:36	2:12	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
136	26-Jun-19	BENGALURU	66	HV1	SURYANAGAR	13:39	13:47	0:08	LINE CLEAR AVAILED
137	26-Jun-19	GULBARGA	110	HV3	HATTI_110	12:12	12:21	0:09	TRANSFORMER FAULT
138	26-Jun-19	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110, JANAWADA_110, NSSKSUGARS_IPP	0:00	11:48	11:48	LINE CLEAR AVAILED
139	26-Jun-19	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110, JANAWADA_110, NSSKSUGARS_IPP	11:48	12:14	0:26	LINE CLEAR AVAILED
140	26-Jun-19	GULBARGA	110	LADHA-BHALKI	LADHA_110,MGSSK_IPP, BHALKISUGARS_IPP	15:40	16:00	0:20	LINE CLEAR AVAILED
141	26-Jun-19	GULBARGA	110	HV2	SHORAPUR_110	22:11	22:22	0:11	TRANSFORMER FAULT
142	26-Jun-19	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	21:49	21:59	0:10	LINE CLEAR AVAILED
143	26-Jun-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP, RENEWSOLAR2_IPP	ITTAGI_220	11:23	11:30	0:07	LINE CLEAR AVAILED
144	26-Jun-19	HASSAN	400	TALAGUPPA_400	TALAGU-NELAMANGALA#2	3:05	7:36	4:31	LINE CLEAR AVAILED
145	26-Jun-19	HASSAN	220	KEMAR_220	KEMAR-Varahi2	11:01	13:48	2:47	LINE CLEAR AVAILED
146	26-Jun-19	HASSAN	220	KEMAR_220	KEMAR-Varahi3	9:25	10:57	1:32	LINE CLEAR AVAILED
147	26-Jun-19	HASSAN	220	varahi_gen	VARAHI-KEMAR2	11:01	13:47	2:46	NFBC ISSUED
148	26-Jun-19	HASSAN	220	varahi_gen	VARAHI-KEMAR3	9:24	10:58	1:34	NFBC ISSUED
149	26-Jun-19	HASSAN	110	ALKOLA_110	HV3	7:17	8:38	1:21	LINE FAULT
150	26-Jun-19	HASSAN	110	HALADY_110	HV2	21:23	21:36	0:13	LINE FAULT
151	26-Jun-19	HASSAN	110	NANDIKUR_110	NANDIKU-ISTR	14:53	15:05	0:12	LINE CLEAR AVAILED
152	26-Jun-19	HASSAN	110	NANDIKUR_110	NANDIKU-KEMAR1	14:53	15:05	0:12	LINE CLEAR AVAILED
153	26-Jun-19	HASSAN	110	NANDIKUR_110	NANDIKU-KEMAR2	14:53	15:05	0:12	LINE CLEAR AVAILED
154	26-Jun-19	HASSAN	110	NANDIKUR_110	NANDIKU-NDKR-SUZLON	10:56	15:06	4:10	LINE CLEAR AVAILED
155	26-Jun-19	HASSAN	66	bhadra_gen	BHADRA-LINGADAHALLI	10:22	12:14	1:52	LINE CLEAR AVAILED
156	26-Jun-19	HASSAN	66	BYACHANAHALLI_66	BYACHAN-HNPURA	10:26	18:19	7:53	LINE CLEAR AVAILED
157	26-Jun-19	HASSAN	66	BYACHANAHALLI_66	HV1	10:26	18:20	7:54	LINE CLEAR AVAILED
158	26-Jun-19	HASSAN	66	GENDEHALLI_66	GENDEHA-MUDIGERE	10:17	13:56	3:39	LINE CLEAR AVAILED
159	26-Jun-19	HASSAN	66	KANDLI_66	KANDLI-SAKLESHPUR	11:54	13:56	2:02	LINE CLEAR AVAILED
160	26-Jun-19	HASSAN	66	RAMNATHPURA_66	RAMNAT-BNDSTHL	10:42	11:35	0:53	NFBC ISSUED
161	26-Jun-19	HASSAN	66	RAMNATHPURA_66	RAMNAT-BNDSTHL	18:10	18:21	0:11	NFBC ISSUED
162	26-Jun-19	HASSAN	66	SAKLESHPURA_66	SAKALE-IPCL1	10:06	15:43	5:37	LINE CLEAR AVAILED
163	26-Jun-19	HASSAN	66	SAKLESHPURA_66	SAKALE-IPCL2	10:06	15:43	5:37	LINE CLEAR AVAILED
164	26-Jun-19	HASSAN	66	SAKLESHPURA_66	SAKALE-IPCL2	18:51	19:05	0:14	LINE FAULT
165	26-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	10:55	11:02	0:07	TRANSFORMER FAULT
166	26-Jun-19	MYSORE	66	HV1	MALAVALLI_66	9:45	17:15	7:30	LINE CLEAR AVAILED
167	26-Jun-19	MYSORE	66	HV2	MALAVALLI_66	9:45	17:15	7:30	LINE CLEAR AVAILED
168	26-Jun-19	MYSORE	66	HV1	SUNTIKOPPA_66	12:28	12:45	0:17	LINE CLEAR AVAILED
169	26-Jun-19	MYSORE	66	HV1	SUTTUR_66	13:10	15:01	1:51	LINE CLEAR AVAILED
170	26-Jun-19	MYSORE	66	HV2	SUTTUR_66	12:20	14:03	1:43	LINE CLEAR AVAILED
171	26-Jun-19	TUMKUR	66	TR-2	BELLAVI_66	9:32	14:30	4:58	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
172	26-Jun-19	TUMKUR	66	TR-2	CHANNAGIRI_66	16:22	16:38	0:15	HAND TRIPPED
173	26-Jun-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	16:58	17:18	0:20	LINE FAULT
174	26-Jun-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA_220	16:57	17:12	0:14	LINE FAULT
175	26-Jun-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA_220	17:16	17:18	0:02	HAND TRIPPED
176	26-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	15:21	16:28	1:06	LINE CLEAR AVAILED
177	26-Jun-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	20:43	20:49	0:06	LINE FAULT
178	26-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:48	11:00	0:11	HAND TRIPPED
179	26-Jun-19	TUMKUR	66	TR-1	KUNIGAL_66	11:52	14:34	2:42	LINE CLEAR AVAILED
180	26-Jun-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:59	17:15	6:16	LINE FAULT
181	26-Jun-19	TUMKUR	66	SANIKERE- CHALLAKERE	SANIKERE_66	12:27	15:15	2:48	LINE FAULT
182	27-Jun-19	BAGALKOT	110	ATHANI220-BALLIGERI(TAUSHI)	BALLIGERI(TAUSHI)_110	5:36	6:00	0:24	LINE FAULT
183	27-Jun-19	BAGALKOT	110	110/11KV,HV1	BANAHATTI_110	0:00	18:44	18:44	LINE CLEAR AVAILED
184	27-Jun-19	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	3:22	23:59	20:37	LINE FAULT
185	27-Jun-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	9:56	18:45	8:49	LINE CLEAR AVAILED
186	27-Jun-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	18:30	18:57	0:27	LINE CLEAR AVAILED
187	27-Jun-19	BAGALKOT	220	NAGAJHARI1-AMBEWADI	AMBEWADI_220	11:05	14:39	3:34	LINE CLEAR AVAILED
188	27-Jun-19	BAGALKOT	220	NAGAJHARI2-AMBEWADI	AMBEWADI_220	11:05	14:40	3:35	LINE CLEAR AVAILED
189	27-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	14:19	15:25	1:06	LINE CLEAR AVAILED
190	27-Jun-19	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	5:36	9:16	3:40	TRANSFORMER FAULT
191	27-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	SOUDATTI_220	9:16	23:59	14:43	LINE CLEAR AVAILED
192	27-Jun-19	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD_110	13:07	15:45	2:38	LINE CLEAR AVAILED
193	27-Jun-19	BAGALKOT	110	110/11KV, HV1	UGARKHUD_110	12:26	15:09	2:43	LINE CLEAR AVAILED
194	27-Jun-19	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	10:20	14:15	3:55	LINE CLEAR AVAILED
195	27-Jun-19	BAGALKOT	110	SOUDATTI220-RAMDURG2	RAMDURG_110	10:25	14:16	3:51	LINE CLEAR AVAILED
196	27-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1	NARENDRA_220	11:34	13:32	1:58	LINE CLEAR AVAILED
197	27-Jun-19	BAGALKOT	220	220/110KV,HV2&LV2	NARENDRA_220	13:41	15:39	1:58	LINE CLEAR AVAILED
198	27-Jun-19	BAGALKOT	110	ATHANI220-BALLIGERI(TAUSHI)	BALLIGERI(TAUSHI)_110	5:36	6:00	0:24	LINE FAULT
199	27-Jun-19	BAGALKOT	110	110/11KV,HV1	BANAHATTI_110	0:00	18:44	18:44	LINE CLEAR AVAILED
200	27-Jun-19	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	3:22	23:59	20:37	LINE FAULT
201	27-Jun-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	9:56	18:45	8:49	LINE CLEAR AVAILED
202	27-Jun-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	18:30	18:57	0:27	LINE CLEAR AVAILED
203	27-Jun-19	BAGALKOT	220	NAGAJHARI1-AMBEWADI	AMBEWADI_220	11:05	14:39	3:34	LINE CLEAR AVAILED
204	27-Jun-19	BAGALKOT	220	NAGAJHARI2-AMBEWADI	AMBEWADI_220	11:05	14:40	3:35	LINE CLEAR AVAILED
205	27-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	14:19	15:25	1:06	LINE CLEAR AVAILED
206	27-Jun-19	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	5:36	9:16	3:40	TRANSFORMER FAULT
207	27-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	SOUDATTI_220	9:16	23:59	14:43	LINE CLEAR AVAILED
208	27-Jun-19	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD_110	13:07	15:45	2:38	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
209	27-Jun-19	BAGALKOT	110	110/11KV, HV1	UGARKHUD_110	12:26	15:09	2:43	LINE CLEAR AVAILED
210	27-Jun-19	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	10:20	14:15	3:55	LINE CLEAR AVAILED
211	27-Jun-19	BAGALKOT	110	SOUDATTI220-RAMDURG2	RAMDURG_110	10:25	14:16	3:51	LINE CLEAR AVAILED
212	27-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1	NARENDRA_220	11:34	13:32	1:58	LINE CLEAR AVAILED
213	27-Jun-19	BAGALKOT	220	220/110KV,HV2&LV2	NARENDRA_220	13:41	15:39	1:58	LINE CLEAR AVAILED
214	27-Jun-19	BENGALURU	66	HV1	D CROSS	9:59	10:09	0:09	TRANSFORMER FAULT
215	27-Jun-19	BENGALURU	66	CHIKKABALLAPURA I/A - CHIKKABALLAPURA URBAN	CHIKKABALLAPURA URBAN	13:30	13:51	0:20	LINE CLEAR AVAILED
216	27-Jun-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	16:25	16:35	0:10	LINE FAULT
217	27-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:01	9:06	0:05	LINE FAULT
218	27-Jun-19	BENGALURU	66	HV2	SARJAPURA 220	11:00	11:36	0:36	LINE CLEAR AVAILED
219	27-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:50	14:00	0:10	LINE CLEAR AVAILED
220	27-Jun-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	12:54	13:48	0:53	TRANSFORMER FAULT
221	27-Jun-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	7:25	7:50	0:25	TRANSFORMER FAULT
222	27-Jun-19	BENGALURU	66	HV3	BANASHANKARI	11:54	13:14	1:20	LINE CLEAR AVAILED
223	27-Jun-19	BENGALURU	66	HV2	EPIP 220	12:47	13:23	0:35	LINE CLEAR AVAILED
224	27-Jun-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	5:45	6:35	0:49	LINE FAULT
225	27-Jun-19	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	13:04	16:33	3:29	LINE FAULT
226	27-Jun-19	BENGALURU	66	HOODY 220 - HAL 1 & 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	12:14	15:08	2:53	LINE CLEAR AVAILED
227	27-Jun-19	BENGALURU	66	HV3	HSR LAYOUT 220	15:17	16:10	0:53	LINE CLEAR AVAILED
228	27-Jun-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	10:32	10:37	0:05	LOAD CHANGEVER
229	27-Jun-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	13:46	13:49	0:03	LOAD CHANGEVER
230	27-Jun-19	BENGALURU	66	REMCO - SUBRAMANYAPURA	REMCO	13:40	13:45	0:05	LOAD CHANGEVER
231	27-Jun-19	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	10:35	10:40	0:05	LOAD CHANGEVER
232	27-Jun-19	BENGALURU	66	HV2	DODDABELAVANGALA	13:27	17:10	3:42	LINE CLEAR AVAILED
233	27-Jun-19	BENGALURU	66	HV1	DODDABELAVANGALA	15:50	16:00	0:10	LINE CLEAR AVAILED
234	27-Jun-19	BENGALURU	66	HV1	SHOBHA APARTMENTS	0:42	1:00	0:18	LINE CLEAR AVAILED
235	27-Jun-19	GULBARGA	220	ITTAGI-ESPLSLR_IPP	ITTAGI_220	19:33	20:13	0:40	LINE FAULT
236	27-Jun-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	12:25	20:05	7:40	LINE CLEAR AVAILED
237	27-Jun-19	GULBARGA	110	BYAGWAT-ACMESLR	BYAGAWAT_110	13:30	13:49	0:19	LINE CLEAR AVAILED
238	27-Jun-19	GULBARGA	110	BYAGWAT-ACMESLR	BYAGAWAT_110	14:28	14:54	0:26	LINE CLEAR AVAILED
239	27-Jun-19	GULBARGA	110	HV2	HANUMASAGAR_110	7:00	10:43	3:43	LINE CLEAR AVAILED
240	27-Jun-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	5:10	5:20	0:10	LINE FAULT
241	27-Jun-19	GULBARGA	110	HV3	KUSTAGI_220	11:25	13:29	2:04	LINE CLEAR AVAILED
242	27-Jun-19	GULBARGA	110	HV3	KUSTAGI_220	15:13	16:00	0:47	LINE CLEAR AVAILED
243	27-Jun-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	12:43	12:49	0:06	LINE CLEAR AVAILED
244	27-Jun-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	19:08	20:19	1:11	LINE CLEAR AVAILED
245	27-Jun-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	19:12	20:19	1:07	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
246	27-Jun-19	GULBARGA	66	HV1	ITTAGI_220	15:19	15:23	0:04	TRANSFORMER FAULT
247	27-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:38	7:06	5:28	LOAD CURTAILMENT
248	27-Jun-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	1:44	6:26	4:42	LINE CLEAR AVAILED
249	27-Jun-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:04	13:57	1:53	NFBC ISSUED
250	27-Jun-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	12:03	13:56	1:53	LINE CLEAR AVAILED
251	27-Jun-19	HASSAN	220	KADUR-DABUSET	KADUR_220	10:31	12:39	2:08	NFBC ISSUED
252	27-Jun-19	HASSAN	110	HV1	HALADY_110	11:10	11:37	0:27	LINE CLEAR AVAILED
253	27-Jun-19	HASSAN	110	HV1	HIRIYADKA_110	11:05	11:35	0:30	LINE CLEAR AVAILED
254	27-Jun-19	HASSAN	110	JOG11-AMBTR2	JOG_110	9:15	11:39	2:24	LINE CLEAR AVAILED
255	27-Jun-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	5:57	6:25	0:28	LINE FAULT
256	27-Jun-19	HASSAN	110	BANTWL-SALATTUR	BANTWAL_110	10:08	13:19	3:11	LINE CLEAR AVAILED
257	27-Jun-19	HASSAN	66	HV1	BASAVAGATTA_66	15:09	16:46	1:37	LINE CLEAR AVAILED
258	27-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	6:33	6:43	0:10	TRANSFORMER FAULT
259	27-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:59	15:08	5:09	LINE CLEAR AVAILED
260	27-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:59	15:08	5:09	LINE CLEAR AVAILED
261	27-Jun-19	HASSAN	66	HV2	SINGAPURA_66	18:20	18:36	0:16	TRANSFORMER FAULT
262	27-Jun-19	MYSORE	66	HV2	BGNAGARA_66	10:10	17:23	7:12	LINE CLEAR AVAILED
263	27-Jun-19	MYSORE	66	HV1	BGNAGARA_66	10:10	17:23	7:12	LINE CLEAR AVAILED
264	27-Jun-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66	10:23	14:07	3:43	NFBC ISSUED
265	27-Jun-19	MYSORE	66	HV1	HANNUR_66	17:53	18:07	0:14	LINE CLEAR AVAILED
266	27-Jun-19	MYSORE	66	HV1	HONNALLY_MYS_66	14:27	16:19	1:52	LINE CLEAR AVAILED
267	27-Jun-19	MYSORE	66	HV1	HUNSUR_66	12:04	12:11	0:07	TRANSFORMER FAULT
268	27-Jun-19	MYSORE	66	HV2	KIKKERI_66	15:17	15:51	0:34	LINE CLEAR AVAILED
269	27-Jun-19	MYSORE	66	HV1	MIRLE_66	14:08	15:17	1:09	LINE CLEAR AVAILED
270	27-Jun-19	MYSORE	66	HV1	SANTHESARAGUR_66	7:04	7:10	0:05	TRANSFORMER FAULT
271	27-Jun-19	MYSORE	66	HV1	SFCSHIVA_66	9:22	12:50	3:27	LINE CLEAR AVAILED
272	27-Jun-19	MYSORE	66	HV2	SFCSHIVA_66	9:22	12:50	3:27	LINE CLEAR AVAILED
273	27-Jun-19	MYSORE	66	HV3	SFCSHIVA_66	9:23	12:48	3:25	LINE CLEAR AVAILED
274	27-Jun-19	MYSORE	66	HV4	SFCSHIVA_66	9:23	12:51	3:28	LINE CLEAR AVAILED
275	27-Jun-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	10:21	10:30	0:08	LINE FAULT
276	27-Jun-19	MYSORE	220	HV2	VAJAMANGALA_220	21:21	23:59	2:37	LINE CLEAR AVAILED
277	27-Jun-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	20:54	21:00	0:06	HAND TRIPPED
278	27-Jun-19	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	14:19	15:02	0:42	LINE CLEAR AVAILED
279	27-Jun-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	15:02	15:30	0:27	LINE CLEAR AVAILED
280	27-Jun-19	TUMKUR	220	TR-3(HV SIDE)	ANTHRASANAHALLI_220	16:28	17:09	0:41	LINE CLEAR AVAILED



Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
281	27-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	14:18	15:30	1:12	LINE CLEAR AVAILED
282	27-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	14:18	15:31	1:12	LINE CLEAR AVAILED
283	27-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	16:28	17:09	0:41	LINE CLEAR AVAILED
284	27-Jun-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	14:19	15:02	0:42	LINE CLEAR AVAILED
285	27-Jun-19	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	15:02	15:30	0:27	LINE CLEAR AVAILED
286	27-Jun-19	TUMKUR	66	TR-3(LV SIDE)	ANTHRASANAHALLI_220	16:28	17:09	0:41	LINE CLEAR AVAILED
287	27-Jun-19	TUMKUR	66	TR-1	BADAVANAHALLI_66	11:44	12:12	0:27	LINE CLEAR AVAILED
288	27-Jun-19	TUMKUR	66	TR-1	BRAHMASANDRA_66	16:05	17:09	1:04	MAIN SUPPLY FAILURE
289	27-Jun-19	TUMKUR	66	TR-2	BRAHMASANDRA_66	16:04	17:09	1:04	MAIN SUPPLY FAILURE
290	27-Jun-19	TUMKUR	66	TR-2	CHANNAGIRI_66	11:18	11:23	0:05	TRANSFORMER FAULT
291	27-Jun-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	22:38	22:49	0:11	LINE FAULT
292	27-Jun-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	17:51	18:44	0:53	LINE FAULT
293	27-Jun-19	TUMKUR	66	TR-2	IDHALLY_66	14:14	14:39	0:25	LINE CLEAR AVAILED
294	27-Jun-19	TUMKUR	66	TR-2	KUKKAWADA_66	10:12	13:38	3:26	LINE CLEAR AVAILED
295	27-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:51	12:11	0:19	HAND TRIPPED
296	27-Jun-19	TUMKUR	66	TR-2	KUNIGAL_66	11:58	12:04	0:06	TRANSFORMER FAULT
297	28-Jun-19	BAGALKOT	110	110/11KV, HV2	AKSHAY COLONY_110	6:06	17:29	11:23	TRANSFORMER FAULT
298	28-Jun-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	11:10	23:55	12:45	LINE CLEAR AVAILED
299	28-Jun-19	BAGALKOT	110	110/11KV, HV1	AMBEWADI_220	13:00	15:38	2:38	TRANSFORMER FAULT
300	28-Jun-19	BAGALKOT	110	110/11KV, HV1	AMBEWADI_220	19:30	20:12	0:42	LINE CLEAR AVAILED
301	28-Jun-19	BAGALKOT	110	110/11KV, HV1	BABLESHWAR_110	11:08	11:34	0:26	LINE CLEAR AVAILED
302	28-Jun-19	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	16:18	17:10	0:52	LINE CLEAR AVAILED
303	28-Jun-19	BAGALKOT	220	LINGASUGUR1-BAGEWADI	BAGEWADI_220	11:10	17:15	6:05	LINE CLEAR AVAILED
304	28-Jun-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	11:08	13:04	1:56	LINE CLEAR AVAILED
305	28-Jun-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110,WIND1&2_33	16:48	19:18	2:30	TRANSFORMER FAULT
306	28-Jun-19	BAGALKOT	110	110/33KV, HV3	GAJENDRAGAD_110, WIND3&4_33	8:45	18:45	10:00	LINE CLEAR AVAILED
307	28-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	18:06	23:59	5:53	LINE CLEAR AVAILED
308	28-Jun-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	0:27	7:38	7:11	LINE CLEAR AVAILED
309	28-Jun-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	13:09	13:13	0:04	HAND TRIPPED
310	28-Jun-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	13:09	13:13	0:04	HAND TRIPPED
311	28-Jun-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	12:47	16:26	3:39	LINE FAULT
312	28-Jun-19	BAGALKOT	110	220/110KV,LV1	SIRSI_220	12:45	13:10	0:25	TRANSFORMER FAULT
313	28-Jun-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	13:13	13:21	0:08	LINE CLEAR AVAILED
314	28-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	21:34	21:37	0:03	LINE FAULT
315	28-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	20:55	21:05	0:10	LINE FAULT
316	28-Jun-19	BAGALKOT	110	MUNDARGI-VIJAY SUGARS	MUNDARGI_110	9:20	15:23	6:03	LINE CLEAR AVAILED
317	28-Jun-19	BAGALKOT	110	MATRIX WIND-MUKARTHAL	MUKARTHAL_110	13:06	13:11	0:05	LINE CLEAR AVAILED
318	28-Jun-19	BAGALKOT	110	110/33KV,HV3	MUDEDEBIHAL_110,NALATWAD_33KV	16:42	16:46	0:04	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
319	28-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	0:00	21:40	21:40	LINE CLEAR AVAILED
320	28-Jun-19	BAGALKOT	110	B.BAGEWADI-ACHANUR	ACHANUR_110	17:26	23:59	6:33	LINE CLEAR AVAILED
321	28-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	13:01	14:35	1:34	LINE CLEAR AVAILED
322	28-Jun-19	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110,BATAKURKI_33KV,RSSKN_33KV	15:50	16:33	0:43	TRANSFORMER FAULT
323	28-Jun-19	BAGALKOT	110	110/11KV, HV2	AKSHAY COLONY_110	6:06	17:29	11:23	TRANSFORMER FAULT
324	28-Jun-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	11:10	23:55	12:45	LINE CLEAR AVAILED
325	28-Jun-19	BAGALKOT	110	110/11KV, HV1	AMBEWADI_220	13:00	15:38	2:38	TRANSFORMER FAULT
326	28-Jun-19	BAGALKOT	110	110/11KV, HV1	AMBEWADI_220	19:30	20:12	0:42	LINE CLEAR AVAILED
327	28-Jun-19	BAGALKOT	110	110/11KV, HV1	BABLESHWAR_110	11:08	11:34	0:26	LINE CLEAR AVAILED
328	28-Jun-19	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	16:18	17:10	0:52	LINE CLEAR AVAILED
329	28-Jun-19	BAGALKOT	220	LINGASUGUR1-BAGEWADI	BAGEWADI_220	11:10	17:15	6:05	LINE CLEAR AVAILED
330	28-Jun-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	11:08	13:04	1:56	LINE CLEAR AVAILED
331	28-Jun-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110,WIND1&2_33	16:48	19:18	2:30	TRANSFORMER FAULT
332	28-Jun-19	BAGALKOT	110	110/33KV, HV3	GAJENDRAGAD_110, WIND3&4_33	8:45	18:45	10:00	LINE CLEAR AVAILED
333	28-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	18:06	23:59	5:53	LINE CLEAR AVAILED
334	28-Jun-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	0:27	7:38	7:11	LINE CLEAR AVAILED
335	28-Jun-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	13:09	13:13	0:04	HAND TRIPPED
336	28-Jun-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	13:09	13:13	0:04	HAND TRIPPED
337	28-Jun-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	12:47	16:26	3:39	LINE FAULT
338	28-Jun-19	BAGALKOT	110	220/110KV,LV1	SIRSI_220	12:45	13:10	0:25	TRANSFORMER FAULT
339	28-Jun-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	13:13	13:21	0:08	LINE CLEAR AVAILED
340	28-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	21:34	21:37	0:03	LINE FAULT
341	28-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	20:55	21:05	0:10	LINE FAULT
342	28-Jun-19	BAGALKOT	110	MUNDARGI-VIJAY SUGARS	MUNDARGI_110	9:20	15:23	6:03	LINE CLEAR AVAILED
343	28-Jun-19	BAGALKOT	110	MATRIX WIND-MUKARTHAL	MUKARTHAL_110	13:06	13:11	0:05	LINE CLEAR AVAILED
344	28-Jun-19	BAGALKOT	110	110/33KV,HV3	MUDEBIHAL_110,NALATWAD_33KV	16:42	16:46	0:04	TRANSFORMER FAULT
345	28-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	0:00	21:40	21:40	LINE CLEAR AVAILED
346	28-Jun-19	BAGALKOT	110	B.BAGEWADI-ACHANUR	ACHANUR_110	17:26	23:59	6:33	LINE CLEAR AVAILED
347	28-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	13:01	14:35	1:34	LINE CLEAR AVAILED
348	28-Jun-19	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110,BATAKURKI_33KV,RSSKN_33KV	15:50	16:33	0:43	TRANSFORMER FAULT
349	28-Jun-19	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	14:00	14:45	0:44	LINE FAULT
350	28-Jun-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	13:35	13:37	0:01	LOAD CHANGEOVER
351	28-Jun-19	BENGALURU	220	HV1	NRS 220	5:56	6:45	0:49	TRANSFORMER FAULT
352	28-Jun-19	BENGALURU	220	LV1	NRS 220	5:56	6:45	0:49	TRANSFORMER FAULT
353	28-Jun-19	BENGALURU	220	HV2	NRS 220	5:56	6:24	0:28	TRANSFORMER FAULT
354	28-Jun-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	5:56	6:26	0:30	MAIN SUPPLY FAILURE
355	28-Jun-19	BENGALURU	66	HV4	NRS 220	5:56	6:26	0:30	MAIN SUPPLY FAILURE
356	28-Jun-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	5:56	6:48	0:52	MAIN SUPPLY FAILURE

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
357	28-Jun-19	BENGALURU	66	NRS 220 - MYSORE ROAD 2	VIJAYANAGARA	5:56	6:14	0:18	MAIN SUPPLY FAILURE
358	28-Jun-19	BENGALURU	220	HV1	NRS 220	6:49	6:55	0:06	TRANSFORMER FAULT
359	28-Jun-19	BENGALURU	220	HV2	NRS 220	6:49	6:55	0:06	TRANSFORMER FAULT
360	28-Jun-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	6:49	6:54	0:05	MAIN SUPPLY FAILURE
361	28-Jun-19	BENGALURU	66	HV3	NRS 220	5:56	6:57	1:01	MAIN SUPPLY FAILURE
362	28-Jun-19	BENGALURU	66	HV1	NRS 220	6:49	6:57	0:08	MAIN SUPPLY FAILURE
363	28-Jun-19	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	5:56	7:02	1:06	MAIN SUPPLY FAILURE
364	28-Jun-19	BENGALURU	66	HV2	VIJAYANAGARA	13:00	13:50	0:50	LINE CLEAR AVAILED
365	28-Jun-19	BENGALURU	66	HV2	VIJAYANAGARA	17:17	18:36	1:18	LINE CLEAR AVAILED
366	28-Jun-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	9:58	10:14	0:16	LINE FAULT
367	28-Jun-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:58	10:18	0:20	MAIN SUPPLY FAILURE
368	28-Jun-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	9:58	10:18	0:19	MAIN SUPPLY FAILURE
369	28-Jun-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1 & 2	SURYANAGAR, ANEKAL	9:58	10:20	0:21	MAIN SUPPLY FAILURE
370	28-Jun-19	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	14:00	14:45	0:44	LINE FAULT
371	28-Jun-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	13:02	13:08	0:06	LOAD CHANGEOVER
372	28-Jun-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:31	12:00	0:29	LOAD CHANGEOVER
373	28-Jun-19	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	13:30	13:36	0:05	LOAD CHANGEOVER
374	28-Jun-19	BENGALURU	220	HV2	YERANDANAHALLI 220	9:58	10:17	0:18	MAIN SUPPLY FAILURE
375	28-Jun-19	BENGALURU	220	HV3	YERANDANAHALLI 220	9:58	10:17	0:19	MAIN SUPPLY FAILURE
376	28-Jun-19	BENGALURU	66	HV2	YERANDANAHALLI 220	10:16	10:18	0:02	MAIN SUPPLY FAILURE
377	28-Jun-19	BENGALURU	66	HV2	REMCO	14:00	14:45	0:45	TRANSFORMER FAULT
378	28-Jun-19	BENGALURU	66	HV1	REMCO	14:00	14:50	0:49	TRANSFORMER FAULT
379	28-Jun-19	BENGALURU	66	HV1	RR NAGAR	14:41	14:45	0:04	LOAD CHANGEOVER
380	28-Jun-19	BENGALURU	66	HV2	RR NAGAR	14:41	14:45	0:04	LOAD CHANGEOVER
381	28-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	9:00	15:55	6:55	LINE CLEAR AVAILED
382	28-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	11:44	11:52	0:08	LINE CLEAR AVAILED
383	28-Jun-19	BENGALURU	66	HV1	HOSKOTE 220	13:25	14:28	1:02	LINE CLEAR AVAILED
384	28-Jun-19	BENGALURU	66	HV2	SARJAPURA 220	13:13	13:18	0:05	TRANSFORMER FAULT
385	28-Jun-19	BENGALURU	66	HV1	SURYANAGAR	10:30	11:15	0:45	LINE CLEAR AVAILED
386	28-Jun-19	BENGALURU	66	HV2	YEDUMADU	13:12	13:23	0:10	LINE CLEAR AVAILED
387	28-Jun-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	9:58	10:18	0:20	MAIN SUPPLY FAILURE
388	28-Jun-19	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	12:30	17:20	4:50	NFBC ISSUED
389	28-Jun-19	GULBARGA	220	SEDAM-CHITAPUR	CHITAPUR_110,RAJASHREE CEMENTS,KORWAR TEMPLE	17:55	18:05	0:10	LINE CLEAR AVAILED
390	28-Jun-19	GULBARGA	110	HV2	YELBURGA_110	14:23	14:37	0:14	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
391	28-Jun-19	GULBARGA	110	HV2	HATTI_110	8:35	17:45	9:10	LINE CLEAR AVAILED
392	28-Jun-19	GULBARGA	110	HV2	HATTI_110	17:57	18:10	0:13	HAND TRIPPED
393	28-Jun-19	GULBARGA	110	HV2	MADIYAL_110	15:53	16:01	0:08	LINE CLEAR AVAILED
394	28-Jun-19	GULBARGA	110	HV3	MADIYAL_110	15:00	15:49	0:49	LINE CLEAR AVAILED
395	28-Jun-19	GULBARGA	110	HV3	MADIYAL_110	13:39	14:45	1:06	LINE CLEAR AVAILED
396	28-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:07	6:37	6:30	LINE CLEAR AVAILED
397	28-Jun-19	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	12:14	14:16	2:02	LINE CLEAR AVAILED
398	28-Jun-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	8:33	15:22	6:49	LINE CLEAR AVAILED
399	28-Jun-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:36	15:15	5:39	LINE CLEAR AVAILED
400	28-Jun-19	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	12:13	14:15	2:02	LINE CLEAR AVAILED
401	28-Jun-19	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:37	10:04	0:27	LINE FAULT
402	28-Jun-19	HASSAN	220	HV2	PUTTUR_220	11:42	16:01	4:19	LINE CLEAR AVAILED
403	28-Jun-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	11:28	14:00	2:32	LINE CLEAR AVAILED
404	28-Jun-19	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	14:10	16:00	1:50	LINE CLEAR AVAILED
405	28-Jun-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:35	15:16	5:41	NFBC ISSUED
406	28-Jun-19	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	16:08	19:13	3:05	LINE FAULT
407	28-Jun-19	HASSAN	110	LV2	PUTTUR_220	11:42	16:02	4:20	LINE CLEAR AVAILED
408	28-Jun-19	HASSAN	110	SHIVAPU-BIRUR	SHIVPURA_110	10:01	13:16	3:15	LINE CLEAR AVAILED
409	28-Jun-19	HASSAN	110	HV1	SHIVPURA_110	10:01	13:58	3:57	LINE CLEAR AVAILED
410	28-Jun-19	HASSAN	110	SHIVPU-NERLEKERE	SHIVPURA_110	10:01	13:13	3:12	LINE CLEAR AVAILED
411	28-Jun-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	16:09	16:25	0:16	HAND TRIPPED
412	28-Jun-19	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	9:37	10:07	0:30	LINE FAULT
413	28-Jun-19	HASSAN	66	GEDEHA-MUDIGERE	GENDEHALLI_66	10:42	13:41	2:59	LINE CLEAR AVAILED
414	28-Jun-19	HASSAN	66	HV1	HANGARANAHALLY_66	11:19	11:42	0:23	LINE CLEAR AVAILED
415	28-Jun-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	16:17	16:30	0:13	LINE FAULT
416	28-Jun-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:49	12:06	0:17	LINE FAULT
417	28-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	11:33	16:15	4:42	LINE CLEAR AVAILED
418	28-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	11:33	16:15	4:42	LINE CLEAR AVAILED
419	28-Jun-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:18	6:24	0:06	LINE FAULT
420	28-Jun-19	MYSORE	66	DODDARAYAPETE-KUNTHUR	SANTHEMARAHALLI_66 MUGUR_66 TNARASIPURA_66 THAYURU_66	8:21	8:34	0:12	LINE FAULT
421	28-Jun-19	MYSORE	66	HALAGUR-HONGANAHALLI	HALAGUR_66	16:17	16:40	0:23	HAND TRIPPED
422	28-Jun-19	MYSORE	66	JYOTHINAGARA-DKMAIDANA	DKMAIDANA_66	10:10	16:39	6:28	NFBC ISSUED
423	28-Jun-19	MYSORE	66	KADAKOLA-DKMAIDANA	DKMAIDANA_66	10:02	16:01	5:59	NFBC ISSUED
424	28-Jun-19	MYSORE	66	HV1	VIJAYANAGRAMYS_66	13:49	14:06	0:17	HAND TRIPPED
425	28-Jun-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	2:04	8:58	6:54	LINE CLEAR AVAILED
426	28-Jun-19	TUMKUR	110	TR-1	TURUVEKERE_110	15:01	15:09	0:08	TRANSFORMER FAULT
427	28-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:11	11:37	1:25	LINE CLEAR AVAILED
428	28-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	7:06	14:26	7:19	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
429	28-Jun-19	TUMKUR	66	TR-2	HIREHALLY_66	10:26	10:29	0:02	TRANSFORMER FAULT
430	28-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:58	11:05	0:06	HAND TRIPPED
431	28-Jun-19	TUMKUR	66	TR-2	HULIYURDURGA_66	11:24	11:38	0:13	TRANSFORMER FAULT
432	28-Jun-19	TUMKUR	66	TR-1	KUNIGAL_66	14:03	14:10	0:07	TRANSFORMER FAULT
433	28-Jun-19	TUMKUR	66	TR-1	LINGADAHALLY_66	11:20	19:40	8:19	LINE CLEAR AVAILED
434	28-Jun-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	10:41	19:36	8:55	LINE CLEAR AVAILED
435	28-Jun-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	5:29	11:18	5:49	LINE FAULT
436	28-Jun-19	TUMKUR	66	NEELAGUNDA 220KV-HARAPPANAHALLI	HARAPPANAHALLI_66	10:22	18:07	7:45	LINE CLEAR AVAILED
437	28-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:23	12:00	0:36	HAND TRIPPED
438	28-Jun-19	TUMKUR	66	TR-2	SANIKERE_66	9:06	13:37	4:31	LINE CLEAR AVAILED
439	28-Jun-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	17:51	17:52	0:01	LINE FAULT
440	29-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	20:32	20:50	0:18	LINE FAULT
441	29-Jun-19	BAGALKOT	110	110/11KV,HV2	BABLESHWARA_110	16:40	17:17	0:37	LINE CLEAR AVAILED
442	29-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	0:01	7:47	7:46	LINE CLEAR AVAILED
443	29-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	18:03	23:58	5:55	LINE CLEAR AVAILED
444	29-Jun-19	BAGALKOT	110	110/11KV,HV1	HIREHAL_110	11:11	14:21	3:10	LINE CLEAR AVAILED
445	29-Jun-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	20:56	21:54	0:58	LINE FAULT
446	29-Jun-19	BAGALKOT	220	SOUDATTI-MAHALIINGAPUR	SOUDATTI_220	20:56	21:54	0:58	LINE FAULT
447	29-Jun-19	BAGALKOT	220	MMCL-SOUDATTI	SOUDATTI_220	21:15	22:10	0:55	LINE FAULT
448	29-Jun-19	BAGALKOT	220	220/11KV.HV1,LV1,HV2,LV2	SOUDATTI_220,SOUDATTI_110,YARAGATTI_110,RAMDURGA_110,UDIKERI_110,MUNAVALLI_110	20:56	21:56	1:00	TRANSFORMER FAULT
449	29-Jun-19	BAGALKOT	110	110/11KV,HV1,LV1	SOUDATTI_220	20:56	21:56	1:00	HAND TRIPPED
450	29-Jun-19	BAGALKOT	110	SOUDATTI220-SOUDATTI1&2	SOUDATTI_110	21:14	22:01	0:47	HAND TRIPPED
451	29-Jun-19	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	21:15	22:01	0:46	HAND TRIPPED
452	29-Jun-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1&2	RAMDURGA_110	21:15	22:07	0:52	HAND TRIPPED
453	29-Jun-19	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	21:15	22:08	0:53	HAND TRIPPED
454	29-Jun-19	BAGALKOT	110	110/33KV, HV1	SOUDATTI_110, SUZLON_33, CHULKI_33, UDIKERI_33	11:46	12:24	0:38	TRANSFORMER FAULT
455	29-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1	SIRSI_220	23:49	23:59	0:10	TRANSFORMER FAULT
456	29-Jun-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	11:11	11:51	0:40	LINE CLEAR AVAILED
457	29-Jun-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	10:11	10:39	0:28	LINE FAULT
458	29-Jun-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	10:11	23:59	13:48	LINE FAULT
459	29-Jun-19	BAGALKOT	110	110/33KV, HV3	SINDAGI_110, KALKERI_33, ALMAL_33	14:05	17:12	3:07	TRANSFORMER FAULT
460	29-Jun-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	15:09	15:49	0:40	LINE CLEAR AVAILED
461	29-Jun-19	BENGALURU	66	HV2	NALLIMARADANAHALLI	15:15	16:15	1:00	LINE CLEAR AVAILED
462	29-Jun-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	12:41	12:49	0:08	LOAD CHANGEOVER
463	29-Jun-19	BENGALURU	220	MALUR 220 - HOODY 220	MALUR 220	21:12	21:22	0:10	LOAD CHANGEOVER
464	29-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:41	13:00	0:19	MAIN SUPPLY FAILURE

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
465	29-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	12:41	13:00	0:19	MAIN SUPPLY FAILURE
466	29-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	12:41	13:00	0:19	MAIN SUPPLY FAILURE
467	29-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:41	13:00	0:19	MAIN SUPPLY FAILURE
468	29-Jun-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:41	13:00	0:19	MAIN SUPPLY FAILURE
469	29-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	21:12	21:22	0:10	MAIN SUPPLY FAILURE
470	29-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:12	21:22	0:10	MAIN SUPPLY FAILURE
471	29-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	21:12	21:22	0:10	MAIN SUPPLY FAILURE
472	29-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	21:12	21:22	0:10	MAIN SUPPLY FAILURE
473	29-Jun-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:12	21:22	0:10	MAIN SUPPLY FAILURE
474	29-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	6:25	6:30	0:05	LINE FAULT
475	29-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:12	15:52	0:40	LINE CLEAR AVAILED
476	29-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	20:10	20:18	0:08	LINE FAULT
477	29-Jun-19	BENGALURU	66	HV2	MAASTHI	6:47	6:52	0:04	TRANSFORMER FAULT
478	29-Jun-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	17:48	17:55	0:07	LINE FAULT
479	29-Jun-19	BENGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI, HALAGUR	7:20	8:05	0:45	LINE FAULT
480	29-Jun-19	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI, HALAGUR	16:40	16:55	0:15	LOAD CHANGEOVER
481	29-Jun-19	BENGALURU	66	HV2	DODDABELAVAGALA	13:50	14:00	0:09	TRANSFORMER FAULT
482	29-Jun-19	BENGALURU	66	HV1	KIADB DB PURA 220	18:02	18:13	0:10	TRANSFORMER FAULT
483	29-Jun-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	12:00	12:00	0:00	LOAD CHANGEOVER
484	29-Jun-19	BENGALURU	66	HV2	EPIP 220	1:17	3:54	2:37	TRANSFORMER FAULT
485	29-Jun-19	BENGALURU	66	HV1	KORMANGALA	13:01	15:18	2:17	LINE CLEAR AVAILED
486	29-Jun-19	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	14:52	15:00	0:07	LINE CLEAR AVAILED
487	29-Jun-19	BENGALURU	66	HV1	TELECOM LAYOUT	11:49	11:52	0:02	LINE CLEAR AVAILED
488	29-Jun-19	GULBARGA	220	MALLAT-RTPS1	MALLAT_220	11:28	13:00	1:32	LINE CLEAR AVAILED
489	29-Jun-19	GULBARGA	110	HV3	HANUMASAGAR_110	10:20	10:50	0:30	LINE CLEAR AVAILED
490	29-Jun-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	2:22	2:32	0:10	LINE FAULT
491	29-Jun-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	3:33	4:03	0:30	LINE FAULT
492	29-Jun-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	4:48	14:04	9:16	LINE FAULT
493	29-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	10:50	14:23	3:33	LINE CLEAR AVAILED
494	29-Jun-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	15:05	17:19	2:14	LINE CLEAR AVAILED
495	29-Jun-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	15:05	17:19	2:14	LINE CLEAR AVAILED
496	29-Jun-19	GULBARGA	110	HV2	MALLAT_220	10:56	13:00	2:04	TRANSFORMER FAULT
497	29-Jun-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	14:05	14:15	0:10	LINE FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
498	29-Jun-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	13:41	23:59	10:18	LINE CLEAR AVAILED
499	29-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:23	6:59	6:36	LINE CLEAR AVAILED
500	29-Jun-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	15:52	16:30	0:38	LINE CLEAR AVAILED
501	29-Jun-19	HASSAN	110	BANTAWA-SALATTUR	BANTWAL_110	10:26	14:40	4:14	LINE CLEAR AVAILED
502	29-Jun-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:52	11:43	0:51	LINE CLEAR AVAILED
503	29-Jun-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:43	13:08	1:25	LINE CLEAR AVAILED
504	29-Jun-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	10:50	11:43	0:53	NFBC ISSUED
505	29-Jun-19	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	11:43	13:03	1:20	NFBC ISSUED
506	29-Jun-19	HASSAN	110	HV2	SORABA-110	12:00	12:20	0:20	LINE CLEAR AVAILED
507	29-Jun-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	3:20	3:31	0:11	LINE FAULT
508	29-Jun-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	13:36	14:56	1:20	NFBC ISSUED
509	29-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	7:36	7:41	0:05	TRANSFORMER FAULT
510	29-Jun-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	13:31	15:26	1:55	LINE CLEAR AVAILED
511	29-Jun-19	HASSAN	66	HV2	SINGAPURA_66	15:00	15:19	0:19	TRANSFORMER FAULT
512	29-Jun-19	MYSORE	66	HV2	BASARALU_66	10:32	11:25	0:52	LINE CLEAR AVAILED
513	29-Jun-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	5:45	5:50	0:04	LINE FAULT
514	29-Jun-19	MYSORE	66	HV1	SANTHESARAGUR_66	14:39	14:41	0:02	TRANSFORMER FAULT
515	29-Jun-19	MYSORE	66	HV1	SALIGRAMA_66	21:10	21:15	0:05	TRANSFORMER FAULT
516	29-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	11:15	23:59	12:43	LINE CLEAR AVAILED
517	29-Jun-19	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	15:43	15:52	0:08	LINE FAULT
518	29-Jun-19	TUMKUR	66	TR-2	BELLAVI_66	12:46	12:57	0:10	TRANSFORMER FAULT
519	29-Jun-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	9:07	9:50	0:42	LINE FAULT
520	29-Jun-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66	9:06	9:49	0:43	LINE FAULT
521	29-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	12:27	13:17	0:49	TRANSFORMER FAULT
522	29-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	15:40	16:00	0:20	TRANSFORMER FAULT
523	29-Jun-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	5:10	5:41	0:30	LINE FAULT
524	29-Jun-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	18:29	18:46	0:16	LINE CLEAR AVAILED
525	29-Jun-19	TUMKUR	66	TR-2	LINGADAHALLY_66	17:48	18:17	0:28	HAND TRIPPED
526	29-Jun-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	13:00	13:10	0:09	TRANSFORMER FAULT
527	29-Jun-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:55	16:45	6:49	LINE FAULT
528	30-Jun-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	3:16	14:36	11:20	LINE FAULT
529	30-Jun-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	14:05	23:59	9:54	LINE FAULT
530	30-Jun-19	BAGALKOT	110	ANKALAGI-HIDIKAL	HIDIKAL_110	7:06	11:41	4:35	LINE FAULT
531	30-Jun-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	10:51	23:59	13:08	LINE CLEAR AVAILED
532	30-Jun-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	18:06	22:35	4:29	LINE CLEAR AVAILED
533	30-Jun-19	BAGALKOT	110	BYDAGI-SUZALON	BYADAGI_110	4:30	4:46	0:16	LINE FAULT
534	30-Jun-19	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	10:23	11:43	1:20	TRANSFORMER FAULT
535	30-Jun-19	BAGALKOT	110	KARAWAR-BINAGA(SOLARIS)	BINAGA_110	0:53	15:17	14:24	LINE FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
536	30-Jun-19	BAGALKOT	110	KARAWAR220-KUMATA(ARAGA)	KUMATA_110	10:50	15:20	4:30	LINE CLEAR AVAILED
537	30-Jun-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:08	23:59	23:51	LINE CLEAR AVAILED
538	30-Jun-19	BAGALKOT	110	110/33KV, HV3	GHATAPRABHA_110&33KV-RIDDI-SIDDI&GOKAK MILL	9:21	10:40	1:19	TRANSFORMER FAULT
539	30-Jun-19	BAGALKOT	110	110/11KV, HV1&2	HATTARAGI_110	11:45	12:03	0:18	HAND TRIPPED
540	30-Jun-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	22:20	23:59	1:39	LINE CLEAR AVAILED
541	30-Jun-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	4:13	23:59	19:46	LINE FAULT
542	30-Jun-19	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	0:00	9:07	9:07	LINE CLEAR AVAILED
543	30-Jun-19	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	7:31	8:08	0:37	TRANSFORMER FAULT
544	30-Jun-19	BAGALKOT	110	110/33KV, HV3	RON_110, MUSIGERI_33	10:57	13:14	2:17	LINE CLEAR AVAILED
545	30-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	12:52	14:48	1:55	LINE FAULT
546	30-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 2	BAGHMANE WORLD TECH PARK	14:20	14:45	0:25	LINE CLEAR AVAILED
547	30-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 1	BAGHMANE WORLD TECH PARK	14:20	14:45	0:25	LINE CLEAR AVAILED
548	30-Jun-19	BENGALURU	66	HV2	DODDABELAVANGALA	6:25	6:39	0:14	TRANSFORMER FAULT
549	30-Jun-19	BENGALURU	66	DB PURA 220 - DODDABELAVANGALA	DODDABELAVANGALA	6:25	6:38	0:12	LINE FAULT
550	30-Jun-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	6:50	7:11	0:21	TRANSFORMER FAULT
551	30-Jun-19	BENGALURU	66	HV2	GOWRIBIDANUR 220	18:45	18:55	0:10	TRANSFORMER FAULT
552	30-Jun-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	16:03	16:10	0:06	TRANSFORMER FAULT
553	30-Jun-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	16:15	16:31	0:16	TRANSFORMER FAULT
554	30-Jun-19	BENGALURU	220	HV2	A STATION 220	0:16	0:25	0:09	TRANSFORMER FAULT
555	30-Jun-19	BENGALURU	220	LV2	A STATION 220	0:16	0:25	0:09	TRANSFORMER FAULT
556	30-Jun-19	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	0:16	23:59	23:43	LINE FAULT
557	30-Jun-19	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	0:16	0:26	0:10	MAIN SUPPLY FAILURE
558	30-Jun-19	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 66	0:16	0:25	0:09	MAIN SUPPLY FAILURE
559	30-Jun-19	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	0:16	0:25	0:09	MAIN SUPPLY FAILURE
560	30-Jun-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	15:31	16:00	0:28	LINE FAULT
561	30-Jun-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	8:55	9:42	0:46	LINE FAULT
562	30-Jun-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	9:58	10:31	0:33	LINE CLEAR AVAILED
563	30-Jun-19	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	8:55	9:40	0:44	LINE FAULT
564	30-Jun-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	8:55	10:33	1:37	LINE FAULT
565	30-Jun-19	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	8:55	10:13	1:17	LINE FAULT
566	30-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	9:30	9:50	0:20	TRANSFORMER FAULT
567	30-Jun-19	GULBARGA	110	HV1	ITTAGI_220	8:20	8:38	0:18	TRANSFORMER FAULT
568	30-Jun-19	GULBARGA	110	HV1	ITTAGI_220	8:40	9:10	0:30	LINE CLEAR AVAILED
569	30-Jun-19	GULBARGA	110	HV1	ITTAGI_220	9:15	13:15	4:00	LINE CLEAR AVAILED



Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
570	30-Jun-19	GULBARGA	110	HV1	ITTAGI_220	13:25	13:40	0:15	LINE CLEAR AVAILED
571	30-Jun-19	GULBARGA	110	HV1	ITTAGI_220	11:25	12:05	0:40	LINE CLEAR AVAILED
572	30-Jun-19	GULBARGA	110	LV1	ITTAGI_220	11:25	12:05	0:40	TRANSFORMER FAULT
573	30-Jun-19	GULBARGA	110	HV1	ITTAGI_220	12:10	16:25	4:15	LINE CLEAR AVAILED
574	30-Jun-19	GULBARGA	110	HV3	KOLHAR_110	5:20	5:30	0:10	TRANSFORMER FAULT
575	30-Jun-19	GULBARGA	110	HV3	KOLHAR_110	5:30	5:45	0:15	TRANSFORMER FAULT
576	30-Jun-19	GULBARGA	110	HV3	KOLHAR_110	6:00	9:50	3:50	LINE CLEAR AVAILED
577	30-Jun-19	GULBARGA	110	HV3	KOLHAR_110	13:15	13:20	0:05	TRANSFORMER FAULT
578	30-Jun-19	GULBARGA	110	HV3	KOLHAR_110	13:20	21:25	8:05	LINE CLEAR AVAILED
579	30-Jun-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	20:10	20:16	0:06	LINE FAULT
580	30-Jun-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:05	5:10	0:05	LINE FAULT
581	30-Jun-19	GULBARGA	110	HV2	HATTI_110	4:00	4:05	0:05	TRANSFORMER FAULT
582	30-Jun-19	GULBARGA	110	HV2	HATTI_110	7:40	7:50	0:10	TRANSFORMER FAULT
583	30-Jun-19	GULBARGA	110	HV1	BETAGERA_110	10:25	10:45	0:20	LINE CLEAR AVAILED
584	30-Jun-19	GULBARGA	110	HV2	BETAGERA_110	10:25	15:10	4:45	LINE CLEAR AVAILED
585	30-Jun-19	GULBARGA	110	HV1	BETAGERA_110	11:10	15:10	4:00	LINE CLEAR AVAILED
586	30-Jun-19	GULBARGA	110	HV3	YADAGIR_110	17:09	20:04	2:55	TRANSFORMER FAULT
587	30-Jun-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	4:42	4:48	0:06	LINE FAULT
588	30-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	12:40	12:46	0:06	LINE FAULT
589	30-Jun-19	GULBARGA	110	HV3	GULBARGA SOUTH_110	18:30	18:55	0:25	LINE CLEAR AVAILED
590	30-Jun-19	GULBARGA	110	HV2	GULBARGA SOUTH_110	9:45	20:10	10:25	LINE CLEAR AVAILED
591	30-Jun-19	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	22:05	22:10	0:05	LINE FAULT
592	30-Jun-19	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	10:39	10:51	0:12	LINE CLEAR AVAILED
593	30-Jun-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	14:12	23:59	9:47	LINE CLEAR AVAILED
594	30-Jun-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	14:14	23:59	9:45	LINE CLEAR AVAILED
595	30-Jun-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:12	22:15	12:03	LINE FAULT
596	30-Jun-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	4:20	10:20	6:00	LINE FAULT
597	30-Jun-19	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	4:23	10:19	5:56	LINE FAULT
598	30-Jun-19	HASSAN	220	KADUR-SHARAVATHY1	MRSMSG_220	22:15	22:34	0:19	LINE FAULT
599	30-Jun-19	HASSAN	220	KADUR-SHARAVATHY1	MRSMSG_220	22:34	23:59	1:25	LINE FAULT
600	30-Jun-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:12	23:59	13:47	LINE FAULT
601	30-Jun-19	HASSAN	110	HV2	ESSUR_110	8:04	8:10	0:06	TRANSFORMER FAULT
602	30-Jun-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	14:23	14:54	0:31	LINE FAULT
603	30-Jun-19	MYSORE	66	HV2	GUNDULPET_66	18:01	22:49	4:48	TRANSFORMER FAULT
604	30-Jun-19	MYSORE	66	MEGHALAPURA-SFC	CHIDRAVALLI_66 THUMBLA_66	8:05	10:15	2:10	LINE CLEAR AVAILED
605	30-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	13:38	23:59	10:20	LINE CLEAR AVAILED
606	30-Jun-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	5:15	6:23	1:07	LINE FAULT
607	30-Jun-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:53	13:12	0:19	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
608	30-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	9:50	11:12	1:22	LINE FAULT
609	30-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	9:49	11:12	1:22	LINE FAULT
610	30-Jun-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	18:04	18:15	0:11	TRANSFORMER FAULT
611	30-Jun-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	9:15	10:54	1:38	LINE CLEAR AVAILED
612	30-Jun-19	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	MELKOTE_66	8:58	11:49	2:51	LINE CLEAR AVAILED
613	30-Jun-19	TUMKUR	66	TR-2	HULIYURDURGA_66	13:53	14:09	0:15	TRANSFORMER FAULT
614	30-Jun-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:28	6:29	0:01	LINE FAULT
615	30-Jun-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	14:17	14:24	0:07	LINE CLEAR AVAILED
616	30-Jun-19	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	16:04	20:07	4:03	LINE CLEAR AVAILED
617	30-Jun-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66, HARAPPANAHALLI_66, HALUVAGALU_66, TELAGI_66	23:39	23:49	0:10	LINE FAULT
618	30-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:55	12:40	0:45	HAND TRIPPED
619	30-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:29	16:54	7:24	LINE FAULT
620	30-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	9:45	9:49	0:04	LINE FAULT
621	01-Jul-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWAD_220	12:50	19:56	7:06	LINE CLEAR AVAILED
622	01-Jul-19	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWAD_220	0:00	19:34	19:34	LINE CLEAR AVAILED
623	01-Jul-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	12:54	13:11	0:17	LINE CLEAR AVAILED
624	01-Jul-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	0:00	16:02	16:02	LINE CLEAR AVAILED
625	01-Jul-19	BAGALKOT	110	ENERGON-BIJAPUR	BIJAPUR_220	0:02	0:10	0:08	LINE FAULT
626	01-Jul-19	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	0:00	18:04	18:04	LINE CLEAR AVAILED
627	01-Jul-19	BAGALKOT	110	220/110KV, LV2	BELGAUM_220	2:23	3:25	1:02	LINE CLEAR AVAILED
628	01-Jul-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	9:05	15:51	6:46	LINE CLEAR AVAILED
629	01-Jul-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	17:01	23:59	6:58	LINE CLEAR AVAILED
630	01-Jul-19	BAGALKOT	220	GUTTUR 1-HAVERI	HAVERI_220	14:36	19:23	4:47	LINE CLEAR AVAILED
631	01-Jul-19	BAGALKOT	220	220/110KV, HV1&LV1	KARWAR_220	10:35	11:00	0:25	LINE CLEAR AVAILED
632	01-Jul-19	BAGALKOT	110	MAREGUDDI-MUNDUGANUR	MUNDUGANUR_110	6:10	6:24	0:14	MAIN SUPPLY FAILURE
633	01-Jul-19	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	2:34	2:43	0:09	LINE FAULT
634	01-Jul-19	BAGALKOT	110	SIRISI220-UMMACHAGI	UMMACHAGI_110	15:52	15:58	0:06	LINE FAULT
635	01-Jul-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	0:00	14:25	14:25	LINE CLEAR AVAILED
636	01-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:18	17:03	5:45	LINE CLEAR AVAILED
637	01-Jul-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	0:00	13:57	13:57	LINE CLEAR AVAILED
638	01-Jul-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	16:03	17:07	1:04	LINE CLEAR AVAILED
639	01-Jul-19	BAGALKOT	110	110/33KV, HV3	SINDAGI_110, KALKERI_33, ALMAL_33	8:06	10:24	2:18	TRANSFORMER FAULT
640	01-Jul-19	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	10:18	15:22	5:04	LINE CLEAR AVAILED
641	01-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDARGI_110	9:49	10:06	0:17	LINE CLEAR AVAILED
642	01-Jul-19	BAGALKOT	110	220/110KV, LV1	MKHUBLI_220	3:24	6:06	2:42	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
643	01-Jul-19	BENGALURU	66	HV2	SARJAPURA 220	10:15	10:30	0:14	TRANSFORMER FAULT
644	01-Jul-19	BENGALURU	66	HV2	THIMAMPALLI	11:55	12:20	0:25	TRANSFORMER FAULT
645	01-Jul-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	19:00	19:55	0:55	LINE CLEAR AVAILED
646	01-Jul-19	BENGALURU	66	HV1	D CROSS	5:35	6:00	0:24	TRANSFORMER FAULT
647	01-Jul-19	BENGALURU	66	HV1	D CROSS	12:37	13:12	0:34	LINE CLEAR AVAILED
648	01-Jul-19	BENGALURU	66	HV1	D CROSS	11:25	12:05	0:40	LOAD CHANGEOVER
649	01-Jul-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	10:02	10:11	0:09	LINE FAULT
650	01-Jul-19	BENGALURU	66	HV2	MAASTHI	22:06	22:14	0:08	TRANSFORMER FAULT
651	01-Jul-19	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	8:57	11:03	2:06	LINE FAULT
652	01-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	8:57	11:04	2:07	MAIN SUPPLY FAILURE
653	01-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	8:57	11:04	2:07	MAIN SUPPLY FAILURE
654	01-Jul-19	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	0:00	23:59	23:59	LINE FAULT
655	01-Jul-19	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	9:20	9:25	0:04	MAIN SUPPLY FAILURE
656	01-Jul-19	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	9:20	9:25	0:04	MAIN SUPPLY FAILURE
657	01-Jul-19	BENGALURU	220	HOODY 220 - HSR LAYOUT 220	HSR LAYOUT	8:57	11:03	2:06	LINE FAULT
658	01-Jul-19	BENGALURU	66	HV2	HOODY 220	9:20	10:20	1:00	MAIN SUPPLY FAILURE
659	01-Jul-19	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NAGNATHPURA 220	4:43	5:21	0:37	LINE FAULT
660	01-Jul-19	BENGALURU	220	NIMHANS 220 - HSR LAYOUT 220	NIMHANS 220	9:20	15:22	6:01	LINE FAULT
661	01-Jul-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	9:24	10:33	1:08	MAIN SUPPLY FAILURE
662	01-Jul-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	9:24	10:33	1:08	MAIN SUPPLY FAILURE
663	01-Jul-19	BENGALURU	220	HOODY 400 - HAL 1	HAL 220, EDC 220	9:42	12:25	2:42	MAIN SUPPLY FAILURE
664	01-Jul-19	BENGALURU	220	HOODY 400 - HAL 2	HAL 220, EDC 220	9:41	10:30	0:48	MAIN SUPPLY FAILURE
665	01-Jul-19	BENGALURU	66	POTTERY ROAD - HBR LAYOUT	POTTERY ROAD	10:45	10:48	0:02	LOAD CHANGEOVER
666	01-Jul-19	BENGALURU	220	NAGNATHPURA 220 - SOMANAHALLI 220	NAGNATHPURA 220	4:44	5:21	0:37	LINE FAULT
667	01-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	4:44	5:23	0:39	MAIN SUPPLY FAILURE
668	01-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	9:20	11:00	1:39	MAIN SUPPLY FAILURE
669	01-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	4:44	5:25	0:41	MAIN SUPPLY FAILURE
670	01-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	9:20	10:59	1:38	MAIN SUPPLY FAILURE
671	01-Jul-19	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	13:51	13:54	0:03	LOAD CHANGEOVER
672	01-Jul-19	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	9:25	9:56	0:30	LINE FAULT
673	01-Jul-19	BENGALURU	66	HOODY 220 - BMRCL (EHT)	BMRCL (EHT)	9:27	9:36	0:08	MAIN SUPPLY FAILURE

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
674	01-Jul-19	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	9:27	11:00	1:32	MAIN SUPPLY FAILURE
675	01-Jul-19	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	9:26	10:44	1:18	MAIN SUPPLY FAILURE
676	01-Jul-19	BENGALURU	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	9:26	10:56	1:30	MAIN SUPPLY FAILURE
677	01-Jul-19	BENGALURU	220	HAL 220 - HOODY 2	HAL 220, EDC 220	9:23	12:25	3:02	MAIN SUPPLY FAILURE
678	01-Jul-19	BENGALURU	66	HOODY 220 - HP (EHT)	HP (EHT)	9:27	10:42	1:14	MAIN SUPPLY FAILURE
679	01-Jul-19	BENGALURU	220	HAL 220 - HOODY 1	HAL 220, EDC 220	9:23	13:37	4:13	MAIN SUPPLY FAILURE
680	01-Jul-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	9:26	10:42	1:15	MAIN SUPPLY FAILURE
681	01-Jul-19	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	9:21	10:36	1:15	MAIN SUPPLY FAILURE
682	01-Jul-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	9:20	10:38	1:18	MAIN SUPPLY FAILURE
683	01-Jul-19	BENGALURU	66	HAL 220 - HOODY 1	HAL 220, EDC 220	9:20	10:39	1:19	MAIN SUPPLY FAILURE
684	01-Jul-19	BENGALURU	220	HV1	NIMHANS 220	9:20	10:58	1:37	MAIN SUPPLY FAILURE
685	01-Jul-19	BENGALURU	220	HV2	NIMHANS 220	9:20	13:56	4:35	MAIN SUPPLY FAILURE
686	01-Jul-19	BENGALURU	400	HV1	HOODY 400	9:20	10:06	0:45	TRANSFORMER FAULT
687	01-Jul-19	BENGALURU	400	HV3	HOODY 400	9:20	10:24	1:03	TRANSFORMER FAULT
688	01-Jul-19	BENGALURU	66	HV1	SOUTH CITY	14:13	14:28	0:15	LINE CLEAR AVAILED
689	01-Jul-19	BENGALURU	66	HV1	NAGNATHPURA 220	4:44	5:25	0:41	MAIN SUPPLY FAILURE
690	01-Jul-19	BENGALURU	66	HV1	NAGNATHPURA 220	9:20	10:56	1:35	MAIN SUPPLY FAILURE
691	01-Jul-19	BENGALURU	66	HV2	NAGNATHPURA 220	4:44	5:23	0:39	MAIN SUPPLY FAILURE
692	01-Jul-19	BENGALURU	66	HV2	NAGNATHPURA 220	9:20	10:56	1:35	MAIN SUPPLY FAILURE
693	01-Jul-19	BENGALURU	66	HV1	HOODY 220	9:20	10:18	0:58	TRANSFORMER FAULT
694	01-Jul-19	BENGALURU	220	HV4	HOODY 220	9:20	10:21	1:01	TRANSFORMER FAULT
695	01-Jul-19	BENGALURU	220	A STATION 220 - EDC 220	A STATION 220	9:20	9:25	0:04	LINE FAULT
696	01-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	5:53	6:01	0:08	LINE FAULT
697	01-Jul-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:35	5:42	0:07	LINE FAULT
698	01-Jul-19	GULBARGA	110	GURGUNTA-LJVL_IPP	LJVL_IPP	11:55	17:01	5:06	LINE CLEAR AVAILED
699	01-Jul-19	GULBARGA	110	GURGUNTA-KHEL_IPP	KHEL_IPP	11:55	17:01	5:06	LINE CLEAR AVAILED
700	01-Jul-19	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110	23:45	23:50	0:05	LINE FAULT
701	01-Jul-19	GULBARGA	110	GURUGUTA-KHEL_IPP	GURUGUNTA_110	23:45	23:59	0:14	LINE FAULT
702	01-Jul-19	GULBARGA	110	GURUGUTA-LJVL_IPP	GURUGUNTA_110	23:45	23:59	0:14	LINE FAULT
703	01-Jul-19	GULBARGA	110	HV3	YADGIR_110	23:16	23:29	0:13	TRANSFORMER FAULT
704	01-Jul-19	GULBARGA	110	HV1	RAICHUR_110	18:03	18:12	0:09	TRANSFORMER FAULT
705	01-Jul-19	GULBARGA	110	HV3	BEVOOR_110	18:39	18:47	0:08	LINE CLEAR AVAILED
706	01-Jul-19	GULBARGA	66	KOTTUR-SUZLON1_IPP	KOTTUR_66	15:42	16:07	0:25	LINE CLEAR AVAILED
707	01-Jul-19	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	9:35	9:54	0:19	LINE CLEAR AVAILED
708	01-Jul-19	GULBARGA	66	ITTAGI-RNWSLR2	ITTAGI_220	13:03	13:14	0:11	LINE CLEAR AVAILED
709	01-Jul-19	GULBARGA	66	ITTAGI-CLNMAX2	ITTAGI_220	13:03	13:34	0:31	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
710	01-Jul-19	GULBARGA	66	ITTAGI-KUDILIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANVEKAL_66,CHORNOOR_66	17:05	17:50	0:45	LINE FAULT
711	01-Jul-19	GULBARGA	66	ITTAGI-KUDILIGI1	KOGALI_66,KUDILIGI_66	17:09	17:50	0:41	LINE CLEAR AVAILED
712	01-Jul-19	GULBARGA	66	ITTAGI-HIREHADAGALLI	HIREHADAGALLI_66	2:45	7:15	4:30	LINE FAULT
713	01-Jul-19	HASSAN	400	TALAGU-HSN400#1	TALAGUGIPPA_400	0:00	8:31	8:31	LINE CLEAR AVAILED
714	01-Jul-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	9:07	9:07	LINE CLEAR AVAILED
715	01-Jul-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	0:00	9:02	9:02	LINE CLEAR AVAILED
716	01-Jul-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	9:52	18:25	8:33	NFBC ISSUED
717	01-Jul-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	9:51	18:25	8:34	LINE CLEAR AVAILED
718	01-Jul-19	HASSAN	110	HV1	BIRUR_110	15:18	17:16	1:58	LINE CLEAR AVAILED
719	01-Jul-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	6:53	8:09	1:16	NFBC ISSUED
720	01-Jul-19	HASSAN	66	HV2	BELUR_66	11:18	11:34	0:16	HAND TRIPPED
721	01-Jul-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	17:05	17:18	0:13	LINE FAULT
722	01-Jul-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	6:50	8:29	1:39	NFBC ISSUED
723	01-Jul-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	15:12	16:02	0:50	LINE CLEAR AVAILED
724	01-Jul-19	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	6:50	8:10	1:20	LINE CLEAR AVAILED
725	01-Jul-19	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	6:50	8:10	1:20	LINE CLEAR AVAILED
726	01-Jul-19	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	12:01	12:30	0:29	LINE CLEAR AVAILED
727	01-Jul-19	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	12:37	13:57	1:20	LINE CLEAR AVAILED
728	01-Jul-19	HASSAN	66	HV1	SIGEBAGI_66	16:02	17:26	1:24	LINE CLEAR AVAILED
729	01-Jul-19	MYSORE	66	HV1	CHUNCHUNKATTE_66	3:10	3:15	0:04	TRANSFORMER FAULT
730	01-Jul-19	MYSORE	66	HV1	HONNALLY_MYS_66	11:24	12:20	0:55	LINE CLEAR AVAILED
731	01-Jul-19	MYSORE	66	HV1	HUNSUR_66	12:32	13:21	0:49	LINE CLEAR AVAILED
732	01-Jul-19	MYSORE	66	HV1	K_HONNALGERE_66	21:13	21:27	0:13	HAND TRIPPED
733	01-Jul-19	MYSORE	66	HV2	K_HONNALGERE_66	21:13	21:27	0:13	HAND TRIPPED
734	01-Jul-19	MYSORE	66	KIADB MANDYA-THUMBKERE	TUMBKERE_66	21:25	21:27	0:01	HAND TRIPPED
735	01-Jul-19	MYSORE	66	KIADB MANDYA-TK HALLY	KIADBMANDYA_66 , MADDUR_66, SOMANAHALLI_66	21:10	21:27	0:17	LINE FAULT
736	01-Jul-19	MYSORE	66	HV2	KMDODDI_66	21:16	21:28	0:12	TRANSFORMER FAULT
737	01-Jul-19	MYSORE	66	HV1	TUBINAKERE_220	13:30	14:47	1:17	LINE CLEAR AVAILED
738	01-Jul-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	16:45	19:43	2:57	LINE FAULT
739	01-Jul-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:23	15:44	4:20	LINE CLEAR AVAILED
740	01-Jul-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	16:52	19:32	2:40	LINE CLEAR AVAILED
741	01-Jul-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	11:23	15:46	4:23	LINE CLEAR AVAILED
742	01-Jul-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	14:37	18:55	4:18	LINE CLEAR AVAILED
743	01-Jul-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	21:50	22:38	0:47	LINE FAULT
744	01-Jul-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	15:52	16:01	0:08	LINE FAULT
745	01-Jul-19	TUMKUR	110	TR-1	TALKERE_110	3:15	4:00	0:44	TRANSFORMER FAULT
746	01-Jul-19	TUMKUR	110	TR-1	KADABA_110	12:28	14:26	1:58	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
747	01-Jul-19	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	15:18	15:23	0:05	HAND TRIPPED
748	01-Jul-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	14:40	16:00	1:19	LINE CLEAR AVAILED
749	01-Jul-19	TUMKUR	66	CHITRADURGA 220kv- SUZLON 1	SUZLON1_IPP_66,	14:46	17:00	2:13	LINE CLEAR AVAILED
750	01-Jul-19	TUMKUR	66	CHITRADURGA 220kv- SUZLON2	SUZLON1_IPP_66, 66	14:48	16:44	1:56	LINE CLEAR AVAILED
751	01-Jul-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	14:40	15:21	0:40	HAND TRIPPED
752	01-Jul-19	TUMKUR	66	TR-2	HULIYURDURGA_66	14:17	14:25	0:07	TRANSFORMER FAULT