

### 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM: 23.03.2021 TO 29.03.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	23-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
2	23-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
3	23-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
4	23-Mar-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
5	23-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
6	23-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
7	23-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
8	23-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
9	23-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
10	23-Mar-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
11	23-Mar-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
12	23-Mar-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
13	23-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
14	23-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
15	23-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT
16	23-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL 110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
17	23-Mar-2021	BAGALKOT	110	SIRSI-JOG1 (SIDDAPUR1)	STATION NOT AFFECTED SIRSI 110	12:02 (16.03.2021)	12:30 (22.03.2021)	144:28HRS	LINE CHARGED
18	23-Mar-2021	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI 110	11:59 (17.03.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
19	23-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD 110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
20	23-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON 110	14:56 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
21	23-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON 110	14:56 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
22	23-Mar-2021	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI 110	19:11 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
23	23-Mar-2021	BAGALKOT	110	KARAWAR-ARGA	STATION NOT AFFECTED ARGA 110	17:05 (22.03.2021)	10:14 (23.03.2021)	17:09HRS	LINE CHARGED
24	23-Mar-2021	BAGALKOT	110	110/11KV,HV2	AINAPUR 110	18:48	18:55	0:07	LOAD CURTAILMENT
25	23-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI 220	08:51	17:11	8:20	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
26	23-Mar-2021	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWADA_110	07:30	07:39	0:09	LINE FAULT
27	23-Mar-2021	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	HALIYAL_110	07:31	07:41	0:10	HAND TRIPPED
28	23-Mar-2021	BAGALKOT	110	ARGA-ANKOLA	STATION NOT AFFECTED ANKOLA_110	11:33	14:46	3:13	LINE CLEAR AVOIDED
29	23-Mar-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	15:01	18:00	2:59	LINE CLEAR AVOIDED
30	23-Mar-2021	BAGALKOT	220	BAGEWADI- NANDIHAL1(BIJAPUR)	STATION NOT AFFECTED BAGEWADI_220	10:54	14:28	3:34	LINE CLEAR AVOIDED
31	23-Mar-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2	STATION NOT AFFECTED BAGEWADI_220	14:30	16:05	1:35	LINE CLEAR AVOIDED
32	23-Mar-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	02:28	2:52	0:24	HAND TRIPPED
33	23-Mar-2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	15:49	0:00	8:11	LINE FAULT
34	23-Mar-2021	BAGALKOT	220	HAVERI220-GUTTUR2	STATION NOT AFFECTED HAVERI_220	05:42	13:49	8:07	LINE FAULT
35	23-Mar-2021	BAGALKOT	220	HAVERI220-GUTTUR1	STATION NOT AFFECTED HAVERI_220	10:56	13:09	2:13	LINE CLEAR AVOIDED
36	23-Mar-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	18:48	18:58	0:10	LOAD CURTAILMENT
37	23-Mar-2021	BAGALKOT	110	110/33KV,HV1	HANAGALL_110 & PALA,BASAPUR_33	18:49	19:06	0:17	TRANSFORMER FAULT
38	23-Mar-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110 & KOLIGUDD_33	18:48	18:54	0:06	LOAD CURTAILMENT
39	23-Mar-2021	BAGALKOT	110	HUKKERI -VISWHANATH SUGARS	HUKKERI_110	11:02	15:53	4:51	LINE CLEAR AVOIDED
40	23-Mar-2021	BAGALKOT	110	KADANAKOPPA-KAVALWAD	KAVALWAD_110	7:30	7:50	0:20	LINE FAULT
41	23-Mar-2021	BAGALKOT	110	KARAWAR-SOLARIS	STATION NOT AFFECTED KARAWAR_220	8:12	10:24	2:12	LINE CLEAR AVOIDED
42	23-Mar-2021	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED HUBLI_220	10:59	13:19	2:20	LINE CLEAR AVOIDED
43	23-Mar-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED HUBLI_220	10:45	13:19	2:34	LINE CLEAR AVOIDED
44	23-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UCHAGOAN_110	08:19	09:19	1:00	LINE CLEAR AVOIDED
45	23-Mar-2021	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110, KALABILAGI_33, HIREPADSALAGI LIS_33	18:48	18:59	0:11	LOAD CURTAILMENT
46	23-Mar-2021	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	07:37	09:10	1:33	LINE CLEAR AVOIDED
47	23-Mar-2021	BAGALKOT	110	MAMDAPUR(B)- SHIRBUR	SHIRBUR_110	15:08	16:53	1:45	LINE CLEAR AVOIDED
48	23-Mar-2021	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	10:45	10:50	0:05	TRANSFORMER FAULT
49	23-Mar-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	08:50	17:15	8:25	LINE CLEAR AVOIDED
50	23-Mar-2021	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	07:34	08:02	0:28	HAND TRIPPED
51	23-Mar-2021	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	10:25	11:31	1:06	LINE CLEAR AVOIDED
52	23-Mar-2021	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	16:18	19:55	3:37	LINE CLEAR AVOIDED
53	23-Mar-2021	BENGALURU	66	HV1	GOLF LINK	10:12	10:15	00:03	LINE CLEAR AVOIDED
54	23-Mar-2021	BENGALURU	66	HV2	GOLF LINK	11:51	11:54	00:03	LINE CLEAR AVOIDED
55	23-Mar-2021	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	10:50	11:40	00:50	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
56	23-Mar-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	09:11	09:17	00:06	LINE FAULT
57	23-Mar-2021	BENGALURU	66	HV2	PADMANABHANAGARA	08:38	08:44	00:06	LINE CLEAR AVAILED
58	23-Mar-2021	BENGALURU	66	HV2	T K HALLI 220	11:03	11:07	00:04	LINE CLEAR AVAILED
59	23-Mar-2021	BENGALURU	66	HV1	T K HALLI 220	14:38	14:45	00:07	LINE CLEAR AVAILED
60	23-Mar-2021	BENGALURU	66	HV1	T K HALLI 220	19:31	19:33	00:02	TRANSFORMER FAULT
61	23-Mar-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	03:10	03:18	00:08	LINE FAULT
62	23-Mar-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	16:15	16:35	00:20	LINE FAULT
63	23-Mar-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	16:35	18:10	01:35	LINE FAULT
64	23-Mar-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	18:10	18:45	00:35	LINE CLEAR AVAILED
65	23-Mar-2021	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	GUNDLU KOTTUR, VIDHURASHWATHA	18:45	18:50	00:05	LINE FAULT
66	23-Mar-2021	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	GUNDLU KOTTUR, VIDHURASHWATHA	18:55	19:00	00:05	LINE FAULT
67	23-Mar-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	19:00	20:15	01:15	LINE FAULT
68	23-Mar-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:05	17:10	00:05	LOAD CHANGE OVER
69	23-Mar-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:41	19:10	00:29	LOAD CURTAILMENT
70	23-Mar-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:42	19:12	00:30	LOAD CURTAILMENT
71	23-Mar-2021	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:34	19:10	00:36	LOAD CURTAILMENT
72	23-Mar-2021	BENGALURU	66	HV1	MAASTHI	13:40	14:38	00:58	LINE CLEAR AVAILED
73	23-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	00:06	00:11	00:05	LINE FAULT
74	23-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	02:23	02:31	00:08	LINE FAULT
75	23-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	15:38	15:46	00:08	LINE FAULT
76	23-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:41	19:13	00:32	LOAD CURTAILMENT
77	23-Mar-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	MANCHENAHALLI, THONDEBHAVI	09:05	11:40	02:35	LINE CLEAR AVAILED
78	23-Mar-2021	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	09:22	11:05	01:43	LINE CLEAR AVAILED
79	23-Mar-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	MANCHENAHALLI, THONDEBHAVI	12:35	12:43	00:08	LINE FAULT
80	23-Mar-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	19:04	19:09	00:05	LINE FAULT
81	23-Mar-2021	BENGALURU	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA, MELUR	04:05	04:10	00:05	LINE FAULT
82	23-Mar-2021	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	19:04	19:12	00:08	LINE FAULT
83	23-Mar-2021	BENGALURU	66	HV1	THAYLUR	00:17	01:30	01:13	TRANSFORMER FAULT
84	23-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
85	23-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 .03 2021)			LINE OPEN,LINE FAULT
86	23-Mar-2021	GULBARGA	110	HV1	KEREHALLI_110	12:45	12:50	00:05	TRANSFORMER FAULT
87	23-Mar-2021	GULBARGA	110	HV2	MANVI_110	10:35	10:44	00:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
88	23-Mar-2021	GULBARGA	110	HV2	MANVI_110	12:54	13:05	00:11	TRANSFORMER FAULT
89	23-Mar-2021	GULBARGA	110	HV2	MANVI_110	10:58	11:07	00:09	TRANSFORMER FAULT
90	23-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:05	12:52	00:47	NFBC ISSUED
91	23-Mar-2021	GULBARGA	110	SEDAM- ULTRATECHCEMENTS IPP	SEDAM_220	08:52	17:11	08:19	LINE CLEAR AVOIDED
92	23-Mar-2021	GULBARGA	110	HV1	KURUKUNTA_110	18:48	19:05	00:17	LOAD CURTAILMENT
93	23-Mar-2021	GULBARGA	110	HV1	LADHA_110	18:48	19:05	00:17	TRANSFORMER FAULT
94	23-Mar-2021	GULBARGA	110	MAHAGOAN-KAPNOOR	MAHAGOAN_110	20:20	21:10	00:50	MAIN SUPPLY FAILURE
95	23-Mar-2021	GULBARGA	110	HV2	MAHAGOAN_110	16:40	17:10	00:30	LINE CLEAR AVOIDED
96	23-Mar-2021	GULBARGA	110	HV1	MANTHAL_110	18:48	19:00	00:12	LOAD CURTAILMENT
97	23-Mar-2021	GULBARGA	110	MARAGUTTI-KAPNOOR	MARAGUTTI_110	20:17	21:10	00:53	MAIN SUPPLY FAILURE
98	23-Mar-2021	GULBARGA	110	HV2	MANVI_110	10:58	11:08	00:10	TRANSFORMER FAULT
99	23-Mar-2021	GULBARGA	110	HV2	MANVI_110	12:51	13:05	00:14	TRANSFORMER FAULT
100	23-Mar-2021	GULBARGA	110	SANKLAPUR-MUNIRABAD	SANKLAPUR_110	17:42	17:51	00:09	MAIN SUPPLY FAILURE
101	23-Mar-2021	GULBARGA	110	HV1	SIRWAR_110	18:45	18:55	00:10	LOAD CURTAILMENT
102	23-Mar-2021	GULBARGA	110	HV1	TEKKALKOTE_110	18:45	18:55	00:10	LOAD CURTAILMENT
103	23-Mar-2021	GULBARGA	110	HV1	VENKATAGIRI_110	18:45	18:47	00:02	LOAD CURTAILMENT
104	23-Mar-2021	GULBARGA	110	HV2	HATTI_110	16:20	16:30	04:50	TRANSFORMER FAULT
105	23-Mar-2021	GULBARGA	110	HV2	JEEWARGI_110	18:45	18:55	05:50	LOAD CURTAILMENT
106	23-Mar-2021	GULBARGA	110	HUMNABAD-MAHAGAON	MAHAGOAN_110	20:17	20:34	06:50	LINE CLEAR AVOIDED
107	23-Mar-2021	GULBARGA	110	HUMNABAD-MAHAGAON	MAHAGOAN_110	20:35	21:05	07:50	LINE CLEAR AVOIDED
108	23-Mar-2021	GULBARGA	66	KOTTUR-BENNEHALLI,SUZLON	KOTTUR_66	11:55	15:45	03:50	LINE CLEAR AVOIDED
109	23-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
110	23-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
111	23-Mar-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:51(22.3.21)	2:27(23.3.21)	12:26hrs	LINE CHARGED
112	23-Mar-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	22:17(22.3.2021)	2:07(23.3.2021)	3:50hrs	LINE CHARGED
113	23-Mar-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	08:46	16:41	07:55	NFBC ISSUED
114	23-Mar-2021	HASSAN	220	ARSK2-SHMG	ARASIKERE_200	13:45	15:43	01:58	LINE FAULT
115	23-Mar-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	13:14	16:14	03:00	LINE FAULT
116	23-Mar-2021	HASSAN	220	HV1	KEMAR_220	11:35	13:30	01:55	LINE CLEAR AVOIDED
117	23-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:40	13:37	01:57	LINE CLEAR AVOIDED
118	23-Mar-2021	HASSAN	110	LV1	KEMAR_220	11:35	13:30	01:55	LINE CLEAR AVOIDED
119	23-Mar-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:22	11:33	01:11	LINE CLEAR AVOIDED
120	23-Mar-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:33	13:32	01:59	LINE CLEAR AVOIDED
121	23-Mar-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	11:33	13:32	01:59	LINE CLEAR AVOIDED
122	23-Mar-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:09	17:09	02:00	LINE FAULT
123	23-Mar-2021	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:45	15:39	01:54	LINE FAULT
124	23-Mar-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:14	16:14	03:00	LINE FAULT
125	23-Mar-2021	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	12:32	14:45	02:13	NFBC ISSUED
126	23-Mar-2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	12:32	14:45	02:13	NFBC ISSUED
127	23-Mar-2021	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	08:46	16:41	07:55	LINE CLEAR AVOIDED
128	23-Mar-2021	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	13:14	16:14	03:00	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
129	23-Mar-2021	HASSAN	220	VARAHI-KEMAR3	varahi_gen	11:40	13:37	01:57	LINE CLEAR AVAILED
130	23-Mar-2021	HASSAN	110	ARSK2-ARSKR	ARASIKERE_200	13:45	15:50	02:05	LINE CLEAR AVAILED
131	23-Mar-2021	HASSAN	110	ARSK2-GANDASI	ARASIKERE_200	13:45	15:50	02:05	LINE CLEAR AVAILED
132	23-Mar-2021	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_200	13:45	15:51	02:06	LINE CLEAR AVAILED
133	23-Mar-2021	HASSAN	110	BANTWA-AMR	BANTWAL_110	11:18	11:25	00:07	HAND TRIPPED
134	23-Mar-2021	HASSAN	110	HV1	GANDASI_110	17:52	17:53	00:01	MAIN SUPPLY FAILURE
135	23-Mar-2021	HASSAN	110	HV2	GANDASI_110	18:47	18:55	00:08	LOAD CURTAILMENT
136	23-Mar-2021	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	11:30	12:52	01:22	LINE CLEAR AVAILED
137	23-Mar-2021	HASSAN	110	HV1	JAVAGAL_110	18:48	18:53	00:05	LOAD CURTAILMENT
138	23-Mar-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	14:13	14:17	00:04	LINE FAULT
139	23-Mar-2021	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	11:18	11:23	00:05	HAND TRIPPED
140	23-Mar-2021	HASSAN	110	HV2	KONAJE_110	15:47	16:02	00:15	LINE CLEAR AVAILED
141	23-Mar-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	11:28	13:34	02:06	LINE CLEAR AVAILED
142	23-Mar-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:22	13:04	02:42	LINE CLEAR AVAILED
143	23-Mar-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	13:08	13:34	00:26	LINE CLEAR AVAILED
144	23-Mar-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	07:42	13:20	05:38	LINE CLEAR AVAILED
145	23-Mar-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	07:42	13:20	05:38	LINE CLEAR AVAILED
146	23-Mar-2021	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	17:06	17:35	00:29	LINE CLEAR AVAILED
147	23-Mar-2021	HASSAN	66	BALLUPE-SAKLESHPUR	BALLUPETE_66	10:46	14:04	03:18	NFBC ISSUED
148	23-Mar-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	14:16	14:56	00:40	MAIN SUPPLY FAILURE
149	23-Mar-2021	HASSAN	66	HV1	MAGGE_66	14:17	14:56	00:39	MAIN SUPPLY FAILURE
150	23-Mar-2021	HASSAN	66	HV2	MAGGE_66	14:17	14:56	00:39	MAIN SUPPLY FAILURE
151	23-Mar-2021	HASSAN	66	HV2	RAMPURA_66	02:04	02:14	00:10	TRANSFORMER FAULT
152	23-Mar-2021	HASSAN	66	HV2	RAMPURA_66	12:47	13:05	00:18	TRANSFORMER FAULT
153	23-Mar-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPUR_66	14:16	14:55	00:39	NFBC ISSUED
154	23-Mar-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUR_66	13:42	19:30	05:48	LINE CLEAR AVAILED
155	23-Mar-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUR_66	13:42	19:31	05:49	LINE CLEAR AVAILED
156	23-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:27	19:11	08:44	LINE CLEAR AVAILED
157	23-Mar-2021	HASSAN	66	HV1	CHANNARAYAPATNA_66	18:00	19:55	01:55	LINE CLEAR AVAILED
158	23-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:27	19:04	08:37	LINE CLEAR AVAILED
159	23-Mar-2021	MYSURU	66	HV2	AKKIHEBBAL_66	9:02	9:11	0:09	TRANSFORMER FAULT
160	23-Mar-2021	MYSURU	66	HV2	AKKIHEBBAL_66	12:13	12:45	0:31	LINE CLEAR AVAILED
161	23-Mar-2021	MYSURU	66	HV2	AKKIHEBBAL_66	18:44	18:58	0:13	LOAD CURTAILMENT
162	23-Mar-2021	MYSURU	66	HV1	BESAGARAHALLI_66	18:44	18:47	0:03	LOAD CURTAILMENT
163	23-Mar-2021	MYSURU	66	HV2	BOOKANAKERE_66	18:44	18:57	0:13	LOAD CURTAILMENT
164	23-Mar-2021	MYSURU	66	HV2	CHINAKURALI_66	18:47	18:57	0:09	LOAD CURTAILMENT
165	23-Mar-2021	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	5:42	6:04	0:22	LINE FAULT
166	23-Mar-2021	MYSURU	66	HV1	DATTAGALLY_66	10:26	14:06	3:40	LINE CLEAR AVAILED
167	23-Mar-2021	MYSURU	66	HV2	DATTAGALLY_66	14:37	16:58	2:20	LINE CLEAR AVAILED
168	23-Mar-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	13:03	13:10	0:06	TRANSFORMER FAULT
169	23-Mar-2021	MYSURU	66	GV GUDI-BILIKERE	GVGUDI_66	18:55	19:45	0:49	LINE FAULT
170	23-Mar-2021	MYSURU	66	HV1	GVGUDI_66	18:45 (23/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
171	23-Mar-2021	MYSURU	66	HV1	HANAGODU_66	18:44	18:59	0:15	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
172	23-Mar-2021	MYSURU	66	HV2	HANNUR_66	18:48	18:53	0:05	LOAD CURTAILMENT
173	23-Mar-2021	MYSURU	66	HV1	HOOTAGALLY_220	10:56 (23/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
174	23-Mar-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATION EFFECTED	6:03	6:11	0:08	LINE FAULT
175	23-Mar-2021	MYSURU	66	HV1	JAKKANAHALLY_66	12:31	15:57	3:26	LINE CLEAR AVAILED
176	23-Mar-2021	MYSURU	66	KIADB MANDYA-TUMBEGERE	TUMBEKERE_66	7:24	17:32	10:08	LINE CLEAR AVAILED
177	23-Mar-2021	MYSURU	66	HV2	KIRUGAVALU_66	18:48	19:13	0:25	LOAD CURTAILMENT
178	23-Mar-2021	MYSURU	66	HV2	KOLLEGALA_66	13:18	13:24	0:06	TRANSFORMER FAULT
179	23-Mar-2021	MYSURU	66	HV2	KOLLEGALA_66	13:33	13:41	0:07	TRANSFORMER FAULT
180	23-Mar-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	19:07	19:14	0:06	HAND TRIPPED
181	23-Mar-2021	MYSURU	66	HV1	KRPET_66	18:48	18:53	0:05	LOAD CURTAILMENT
182	23-Mar-2021	MYSURU	66	PERIYAPATNA-HUNSUR	NO STATION EFFECTED	6:35	19:10	12:35	LINE CLEAR AVAILED
183	23-Mar-2021	MYSURU	66	TUBINKERE-G UKKADE	NO STATION EFFECTED	13:13	13:39	0:25	HAND TRIPPED
184	23-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI, HARADANAHALLI, BG NAGARA, AC GIRI, VADERALLI, KESALGERE & BASARALU	16:41	16:48	0:06	LINE FAULT
185	23-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI, HARADANAHALLI, BG NAGARA, AC GIRI, VADERALLI, KESALGERE & BASARALU	17:37	17:45	0:08	LINE FAULT
186	23-Mar-2021	MYSURU	66	HV1	YELANDUR_66	18:44	18:50	0:05	LOAD CURTAILMENT
187	23-Mar-2021	MYSURU	220	BEGUR 220KV-CR NAGARA	NO STATION EFFECTED	16:12	17:41	1:29	NFBC ISSUED
188	23-Mar-2021	MYSURU	66	HOOTAGALLI-BARC 2	NO STATION EFFECTED	16:47 (22/03/2021)	17:48 (23/03/2021)	25:00 HRS	LINE CHARGED
189	23-Mar-2021	MYSURU	66	HV2	HOOTAGALLY_220	9:53 (22/03/2021)	10:53 (23/03/2021)	24:59 HRS	TRANSFORMER CHARGED
190	23-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
191	23-Mar-2021	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	15:49	16:16	0:26	MAIN SUPPLY FAILURE
192	23-Mar-2021	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	13:08	15:49	2:41	LINE FAULT
193	23-Mar-2021	TUMKUR	110	HONNAVALI 110-ADAN SOLAR_IPP_66	ADAN SOLAR_IPP_110	18:00	18:14	0:14	LINE FAULT
194	23-Mar-2021	TUMKUR	110	TR-1	SAMPIGE_110	13:45	15:05	1:19	LINE CLEAR AVAILED
195	23-Mar-2021	TUMKUR	110	TR-1	NITTUR_220	15:49	16:09	0:19	TRANSFORMER FAULT
196	23-Mar-2021	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	18:35	19:33	0:58	LOAD CURTAILMENT
197	23-Mar-2021	TUMKUR	66	ANCHEPALYA 220- HEBBUR	HEBBUR-66, HONNENAHALLI-66, THIMMASANDRA-66	18:58	19:33	0:34	LOAD CURTAILMENT
198	23-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	18:46	19:26	0:40	LOAD CURTAILMENT
199	23-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	9:12	9:19	0:07	LOAD CURTAILMENT
200	23-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	12:49	18:03	5:13	LINE CLEAR AVAILED
201	23-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	18:47	18:56	0:09	LOAD CURTAILMENT
202	23-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	18:46	19:06	0:20	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
203	23-Mar-2021	TUMKUR	66	ANTHRASANAHALI 220KV-TUMKUR	TUMKUR_66	12:13	13:09	0:55	LINE FAULT
204	23-Mar-2021	TUMKUR	66	BENNEHALI-SUZLON	SUZLON1_IPP_66	12:17	15:52	3:34	LINE CLEAR AVAILED
205	23-Mar-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	8:33	8:42	0:08	LINE CLEAR AVAILED
206	23-Mar-2021	TUMKUR	66	CHITRADURGA 220kv-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITRAHALI_66	14:21	14:46	0:24	LINE FAULT
207	23-Mar-2021	TUMKUR	66	CHITRADURGA 66kv-PANDARAHALLI 2	CHITRADURGA_66	14:21	14:47	0:25	LINE FAULT
208	23-Mar-2021	TUMKUR	66	CHIKKATOTTLUKERE-ANTHRASANAHALI	CHIKKATOTTLUKERE_66	18:50	19:10	0:20	MAIN SUPPLY FAILURE
209	23-Mar-2021	TUMKUR	66	TR-1	CHIKKATOTTLUKERE_66	10:23	18:33	8:09	LINE CLEAR AVAILED
210	23-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:59	11:10	0:11	LINE FAULT
211	23-Mar-2021	TUMKUR	66	TR-2	HALURAMESHWARA_66	11:21	12:03	0:42	LINE CLEAR AVAILED
212	23-Mar-2021	TUMKUR	66	TR-2	HALURAMESHWARA_66	12:06	12:27	0:20	LINE CLEAR AVAILED
213	23-Mar-2021	TUMKUR	66	TR-2	HARIYABBE_66	7:52	8:00	0:07	LINE CLEAR AVAILED
214	23-Mar-2021	TUMKUR	66	TR-3	HARIYABBE_66	12:53	13:00	0:06	LINE CLEAR AVAILED
215	24-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
216	24-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
217	24-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
218	24-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
219	24-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
220	24-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
221	24-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
222	24-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
223	24-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
224	24-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
225	24-Mar-2021	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
226	24-Mar-2021	BAGALKOT	220	VAJRAMATTI-MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
227	24-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
228	24-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
229	24-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
230	24-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
231	24-Mar-2021	BAGALKOT	110	110/11KV,HV4(HV3)	STATION NOT AFFECTED MK HUBLI_110	11:59 (17.03.2021)	16:23 (24.03.2021)	172:24hrs	TRANSFORMER CHARGED
232	24-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
233	24-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)	14:18 (24.03.2021)	119:22hrs	LINE CHARGED
234	24-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	14:56 (19.03.2021)	14:21 (24.03.2021)	119:25hrs	LINE CHARGED
235	24-Mar-2021	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
236	24-Mar-2021	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	16:35	16:50	0:15	LINE CLEAR AVOIDED
237	24-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	08:40	16:58	8:18	LINE CLEAR AVOIDED
238	24-Mar-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	16:57	17:01	0:04	LINE FAULT
239	24-Mar-2021	BAGALKOT	110	ANKOLA-ARGA(L1)	ANKOLA_110	09:56	10:01	0:05	HAND TRIPPED
240	24-Mar-2021	BAGALKOT	110	110/11KV,HV1	BABLESHWAR_110	18:09	18:24	0:15	HAND TRIPPED
241	24-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	00:09	00:19	0:10	LINE FAULT
242	24-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	12:37	16:56	4:19	LINE CLEAR AVOIDED
243	24-Mar-2021	BAGALKOT	110	BELGAUM- UCHAGOAN(HUKKERI)	UCHAGOAN_110	17:36	18:04	0:28	LINE FAULT
244	24-Mar-2021	BAGALKOT	110	110/11KV,HV2	GANESHGUDI_110	12:28	13:01	0:33	HAND TRIPPED
245	24-Mar-2021	BAGALKOT	110	UMMACHAGI- SIRSI	UMMACHAGI_110	09:06	09:11	0:05	LINE FAULT
246	24-Mar-2021	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIRSI_110	09:08	09:14	0:06	HAND TRIPPED
247	24-Mar-2021	BAGALKOT	110	110/11KV, HV2	RATTIHALLI_110	11:29	11:38	0:09	TRANSFORMER FAULT
248	24-Mar-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	08:41	16:58	8:17	LINE CLEAR AVOIDED
249	24-Mar-2021	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33	10:15	11:11	0:56	LINE CLEAR AVOIDED
250	24-Mar-2021	BAGALKOT	110	KARWAR220- ARGA	STATION NOT AFFECTED ARGA_110	07:27	09:50	2:23	LINE CLEAR AVOIDED
251	24-Mar-2021	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	22:09	22:14	0:05	TRANSFORMER FAULT
252	24-Mar-2021	BAGALKOT	110	110/11KV, HV1	HIDIKAL DAM_110	13:38	14:04	0:26	LINE CLEAR AVOIDED
253	24-Mar-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110, RUSTUMPUR_33, BELGAUM W/S_33	14:06	14:40	0:34	LINE CLEAR AVOIDED
254	24-Mar-2021	BAGALKOT	110	110/33KV, HV4	HIDIKAL_110	8:13 (24.03.2021)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
255	24-Mar-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110, KOLIGUDDA_33, ALAGAWADI_33	08:14	09:23	1:09	LINE CLEAR AVOIDED
256	24-Mar-2021	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	06:03	06:10	00:06	LINE FAULT
257	24-Mar-2021	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	07:05	07:13	00:08	LINE FAULT
258	24-Mar-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	22:37	23:37	01:00	LINE FAULT
259	24-Mar-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	23:19	23:39	00:20	LINE CLEAR AVOIDED
260	24-Mar-2021	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	07:20	08:10	00:49	LINE FAULT
261	24-Mar-2021	BENGALURU	66	HV2	CHAKAVELU	16:25	16:32	00:06	TRANSFORMER FAULT
262	24-Mar-2021	BENGALURU	66	HV1	HOSKOTE 66	17:00	17:50	00:50	TRANSFORMER FAULT
263	24-Mar-2021	BENGALURU	66	HV1	EPIP 220	20:57	21:04	00:07	TRANSFORMER FAULT
264	24-Mar-2021	BENGALURU	66	HV3	EPIP 220	15:26	15:37	00:11	LINE CLEAR AVOIDED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
265	24-Mar-2021	BENGALURU	66	HV1	SOUTH CITY	10:35	10:41	00:06	LINE CLEAR AVAILED
266	24-Mar-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	05:51	06:15	00:24	LINE FAULT
267	24-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
268	24-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN,LINE FAULT
269	24-Mar-2021	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	23:52 (24-03-2021)			LINE OPEN,LINE FAULT
270	24-Mar-2021	GULBARGA	220	ALIPUR-BTPS	ALLIPUR_220	10:48	12:36	01:48	LINE CLEAR AVAILED
271	24-Mar-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	GOOGLE_110	10:35(24.03.2021)			LINE CLEAR AVAILED
272	24-Mar-2021	GULBARGA	110	SEDAM- ULTRATECHCEMENTS IPP	SEDAM_220	08:38	16:57	08:19	LINE CLEAR AVAILED
273	24-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	09:26	17:51	08:25	LINE CLEAR AVAILED
274	24-Mar-2021	GULBARGA	110	HV2	MANVI_110	09:01	09:06	00:05	TRANSFORMER FAULT
275	24-Mar-2021	GULBARGA	110	HV2	MANVI_110	11:43	11:50	00:07	TRANSFORMER FAULT
276	24-Mar-2021	GULBARGA	110	HV1	CHORNOOR_110	09:00	09:25	00:25	LINE CLEAR AVAILED
277	24-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	17:05	19:24	02:19	LINE CLEAR AVAILED
278	24-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	17:10	19:28	02:18	NFBC ISSUED
279	24-Mar-2021	GULBARGA	110	HV3	KOLHAR_110	19:00	19:30	00:30	TRANSFORMER FAULT
280	24-Mar-2021	GULBARGA	110	SHAHPUR-NALWAR	NALWAR_110	18:10	18:50	00:40	NFBC ISSUED
281	24-Mar-2021	GULBARGA	110	GABUR-RAICHUR	GABUR_110,DEODURGA_110	16:59	19:42	02:43	MAIN SUPPLY FAILURE
282	24-Mar-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	23:24	23:28	00:04	LINE FAULT
283	24-Mar-2021	GULBARGA	110	HV2	JEWARGI_110	18:15	18:25	00:10	TRANSFORMER FAULT
284	24-Mar-2021	GULBARGA	110	HV1	SANKLAPUR_110	08:30	08:40	00:10	TRANSFORMER FAULT
285	24-Mar-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	17:45	19:45	02:00	LINE CLEAR AVAILED
286	24-Mar-2021	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110	12:18	14:28	02:10	LINE CLEAR AVAILED
287	24-Mar-2021	GULBARGA	110	HALBARGA-ACME SOLAR	HALBARGA_220	19:02	20:18	01:16	LINE CLEAR AVAILED
288	24-Mar-2021	GULBARGA	66	ITTAGI-TAMBRAHALI	TAMBRAHALI_66KV	06:40	06:50	00:10	MAIN SUPPLY FAILURE
289	24-Mar-2021	GULBARGA	66	HV2	TAMBRAHALI_66KV	00:45	00:50	00:05	TRANSFORMER FAULT
290	24-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
291	24-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
292	24-Mar-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	8:41(24.03.2021)			LINE OPEN, LINE CLEAR AVAILED
293	24-Mar-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	8:41(24.03.2021)			LINE OPEN, LINE CLEAR AVAILED
294	24-Mar-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	13:31	14:00	00:29	LINE CLEAR AVAILED
295	24-Mar-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:42	18:00	03:18	LINE FAULT
296	24-Mar-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	11:06	13:21	02:15	LINE FAULT
297	24-Mar-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:15	13:47	00:32	HAND TRIPPED
298	24-Mar-2021	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	13:31	14:42	01:11	LINE CLEAR AVAILED
299	24-Mar-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	14:41	18:01	03:20	LINE FAULT
300	24-Mar-2021	HASSAN	110	HV2	ARASIKERE_110	13:39	14:26	00:47	LINE CLEAR AVAILED
301	24-Mar-2021	HASSAN	110	BARANGI-ANVATTI	BARANGI_110	18:47	18:58	00:11	LINE FAULT
302	24-Mar-2021	HASSAN	110	BARANGI-ANVATTI	BARANGI_110	19:09	20:39	01:30	LINE FAULT
303	24-Mar-2021	HASSAN	110	HV1	ESSUR_110	16:47	17:34	00:47	LINE CLEAR AVAILED
304	24-Mar-2021	HASSAN	110	HV1	GANDSI_110	13:12	13:20	00:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
305	24-Mar-2021	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	15:57	17:04	01:07	LINE CLEAR AVAILED
306	24-Mar-2021	HASSAN	110	HV1	KALLUSADARAHALLY_110	15:41	16:38	00:57	LINE CLEAR AVAILED
307	24-Mar-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	07:53	18:15	10:22	LINE CLEAR AVAILED
308	24-Mar-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	07:53	18:15	10:22	LINE CLEAR AVAILED
309	24-Mar-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:24	13:27	00:03	LINE FAULT
310	24-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:32	18:40	08:08	LINE CLEAR AVAILED
311	24-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:32	18:39	08:07	LINE CLEAR AVAILED
312	24-Mar-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	07:58	09:58	02:00	LINE CLEAR AVAILED
313	24-Mar-2021	HASSAN	66	MALALI-CRPATNA	MALALI_66	07:45	10:05	02:20	LINE CLEAR AVAILED
314	24-Mar-2021	HASSAN	66	MALALI-HASSAN	MALALI_66	07:45	10:05	02:20	LINE CLEAR AVAILED
315	24-Mar-2021	HASSAN	66	HV1	MALALI_66	07:45	12:45	05:00	LINE CLEAR AVAILED
316	24-Mar-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	12:46	12:55	00:09	LINE FAULT
317	24-Mar-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	14:57	15:05	00:08	LINE FAULT
318	24-Mar-2021	HASSAN	66	HV2	RAMPURA_66	15:19	16:31	01:12	LINE CLEAR AVAILED
319	24-Mar-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	13:49	17:42	03:53	LINE CLEAR AVAILED
320	24-Mar-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	13:49	17:42	03:53	LINE CLEAR AVAILED
321	24-Mar-2021	HASSAN	66	HV2	SALAGAME_66	17:54	18:22	00:28	TRANSFORMER FAULT
322	24-Mar-2021	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	08:13	11:28	03:15	NFBC ISSUED
323	24-Mar-2021	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	08:13	10:05	01:52	NFBC ISSUED
324	24-Mar-2021	HASSAN	66	HV2	UDAYAPURA_66	13:42	13:44	00:02	TRANSFORMER FAULT
325	24-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:30	18:35	08:05	LINE CLEAR AVAILED
326	24-Mar-2021	HASSAN	66	HV1	CHANNARAYAPATNA_66	16:38	20:20	03:42	LINE CLEAR AVAILED
327	24-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:31	18:32	08:01	LINE CLEAR AVAILED
328	24-Mar-2021	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	21:14	21:32	0:18	LINE CLEAR AVAILED
329	24-Mar-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	7:13	7:20	0:06	HAND TRIPPED
330	24-Mar-2021	MYSURU	66	HV1	HONNALLY_MYS_66	11:05	11:18	0:12	LINE CLEAR AVAILED
331	24-Mar-2021	MYSURU	66	HV2	HONNALLY_MYS_66	11:20	13:15	1:55	LINE CLEAR AVAILED
332	24-Mar-2021	MYSURU	66	HOOTAGALLI-BARC 1	NO STATION EFFECTED	9:55	17:55	8:00	LINE CLEAR AVAILED
333	24-Mar-2021	MYSURU	66	HV2	KIKKERI_66	16:20	17:26	1:06	LINE CLEAR AVAILED
334	24-Mar-2021	MYSURU	66	HV2	KIKKERI_66	17:33	17:35	0:01	HAND TRIPPED
335	24-Mar-2021	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66 KOLLEGALA_66 CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	7:15	7:20	0:05	MAIN SUPPLY FAILURE
336	24-Mar-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	KOLLEGALA_66 CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	5:33 (24/03/2021)			LINE OPEN,LINE FAULT
337	24-Mar-2021	MYSURU	66	HV3	KRPET_66	9:03	9:08	0:05	TRANSFORMER FAULT
338	24-Mar-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE 1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	1:46	1:55	0:09	LINE FAULT
339	24-Mar-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE 2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	1:46	1:59	0:13	LINE FAULT
340	24-Mar-2021	MYSURU	66	HV1	MANDGERE_66	16:15	16:50	0:35	LINE CLEAR AVAILED
341	24-Mar-2021	MYSURU	66	PERIYAPATNA-HUNSUR	NO STATION EFFECTED	15:20	18:49	3:29	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
342	24-Mar-2021	MYSURU	66	SHANIVARSANTHE-MALIPATNA	SANIVARASANTHE_66	10:10	11:15	1:05	LINE CLEAR AVAILED
343	24-Mar-2021	MYSURU	66	SHANIVARSANTHE-YESSLUR	SANIVARASANTHE_66	10:10	11:15	1:05	LINE CLEAR AVAILED
344	24-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	13:13	14:59	1:45	LINE CLEAR AVAILED
345	24-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	15:12	15:40	0:28	HAND TRIPPED
346	24-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	15:50	19:00	3:10	LINE CLEAR AVAILED
347	24-Mar-2021	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	7:16	7:20	0:04	LINE FAULT
348	24-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	7:19	7:25	0:05	LINE FAULT
349	24-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:05	10:10	0:05	LINE FAULT
350	24-Mar-2021	MYSURU	66	HV1	GVGUDI_66	18:45 (23/03/2021)	21:35 (24/03/2021)	26:50 HRS	TRANSFORMER CHARGED
351	24-Mar-2021	MYSURU	66	HV1	HOOTAGALLY_220	10:56 (23/03/2021)	17:20 (24/03/2021)	30:24 HRS	TRANSFORMER CHARGED
352	24-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
353	24-Mar-2021	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	17:03	17:34	0:30	TRANSFORMER FAULT
354	24-Mar-2021	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	11:59	18:22	6:23	LINE CLEAR AVAILED
355	24-Mar-2021	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	10:40	15:29	4:48	LOAD CURTAILMENT
356	24-Mar-2021	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	12:20	12:59	0:39	LOAD CURTAILMENT
357	24-Mar-2021	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	11:40	12:13	0:33	LOAD CURTAILMENT
358	24-Mar-2021	TUMKUR	110	TR-1	SHEYKERE_110	14:40	14:50	0:09	TRANSFORMER FAULT
359	24-Mar-2021	TUMKUR	66	ANCHEPALYA 220kV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	10:40	10:59	0:18	HAND TRIPPED
360	24-Mar-2021	TUMKUR	66	ANCHEPALYA 220-ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	10:06	10:11	0:05	HAND TRIPPED
361	24-Mar-2021	TUMKUR	66	ANCHEPALYA 220-ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	22:07	22:09	0:01	HAND TRIPPED
362	24-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	9:17	9:21	0:04	LOAD CURTAILMENT
363	24-Mar-2021	TUMKUR	66	TR-1	CHITRADURGA_66	8:40	8:46	0:05	HAND TRIPPED
364	24-Mar-2021	TUMKUR	66	TR-2	CHITRADURGA_66	8:35	8:47	0:12	HAND TRIPPED
365	24-Mar-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	7:52	8:03	0:10	TRANSFORMER FAULT
366	24-Mar-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	16:02	16:05	0:03	TRANSFORMER FAULT
367	24-Mar-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	17:55	18:01	0:06	TRANSFORMER FAULT
368	24-Mar-2021	TUMKUR	66	HARIYABBE- PD KOTE	HARIYABBE_66	17:44	17:50	0:06	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
369	24-Mar-2021	TUMKUR	66	TR-2	HIRIYUR_66	12:39	12:53	0:14	TRANSFORMER FAULT
370	24-Mar-2021	TUMKUR	66	TR-2	HOLALKERE_66	14:59	15:04	0:04	TRANSFORMER FAULT
371	24-Mar-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:13	18:28	0:15	LINE FAULT
372	24-Mar-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:31	19:44	0:13	MAIN SUPPLY FAILURE
373	24-Mar-2021	TUMKUR	66	TR-1	HONNALI_66	9:19	11:13	1:54	LINE CLEAR AVAILED
374	24-Mar-2021	TUMKUR	66	TR-1	MAYAKONDA_66	17:55	19:04	1:09	TRANSFORMER FAULT
375	24-Mar-2021	TUMKUR	66	TR-2	MELKOTE_66	9:24	9:26	0:01	TRANSFORMER FAULT
376	24-Mar-2021	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	17:07	17:13	0:06	LINE FAULT
377	24-Mar-2021	TUMKUR	66	TR-1	SOKKE_66	8:15	8:35	0:19	TRANSFORMER FAULT
378	24-Mar-2021	TUMKUR	66	TR-1	SOKKE_66	11:37	12:36	0:58	LINE CLEAR AVAILED
379	24-Mar-2021	TUMKUR	66	TR-1	TUMKUR_66	18:05	18:45	0:39	LINE CLEAR AVAILED
380	24-Mar-2021	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	9:21	10:21	0:59	LOAD CURTAILMENT
381	24-Mar-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	17:35	18:06	0:31	HAND TRIPPED
382	24-Mar-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	17:05	18:00	0:54	LINE FAULT
383	24-Mar-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:08	17:48	0:40	LINE FAULT
384	24-Mar-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	21:02	21:23	0:20	LINE FAULT
385	25-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
386	25-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
387	25-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
388	25-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
389	25-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
390	25-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
391	25-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
392	25-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
393	25-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
394	25-Mar-2021	BAGALKOT	220	MAAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
395	25-Mar-2021	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
396	25-Mar-2021	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
397	25-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
398	25-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
399	25-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
400	25-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
401	25-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVALIED
402	25-Mar-2021	BAGALKOT	110	TUMMINAKATTI (HIREKERUR) -RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)			LINE OPEN, LINE CLEAR AVALIED
403	25-Mar-2021	BAGALKOT	110	110/33KV, HV4	HIDIKAL_110	8:13 (24.03.2021)			TRANSFORMER OPEN, LINE CLEAR AVALIED
404	25-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA1&2	AMBEWADI_220	08:28	18:32	10:04	LINE CLEAR AVALIED
405	25-Mar-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	12:09	12:17	0:08	HAND TRIPPED
406	25-Mar-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	17:03	17:08	0:05	HAND TRIPPED
407	25-Mar-2021	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	19:34	20:13	0:39	LINE CLEAR AVALIED
408	25-Mar-2021	BAGALKOT	110	110/11KV,HV1&2	BABALESHWAR_110	05:38	08:45	3:07	LINE CLEAR AVALIED
409	25-Mar-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	08:12	08:20	0:08	LINE FAULT
410	25-Mar-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	17:22	17:33	0:11	LINE FAULT
411	25-Mar-2021	BAGALKOT	220	BAGEWADI-ADPH2	BAGEWADI_220	10:50	18:20	7:30	NFBC ISSUED
412	25-Mar-2021	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	08:15	8:56	0:41	LINE FAULT
413	25-Mar-2021	BAGALKOT	220	BAGEWADI- NANDIHAL1(BIJAPUR1)	BAGEWADI_220	08:13	8:27	0:14	LINE FAULT
414	25-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	5:35	8:24	2:49	LINE CLEAR AVALIED
415	25-Mar-2021	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	5:44	8:05	2:21	LINE CLEAR AVALIED
416	25-Mar-2021	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	8:13	8:23	0:10	LINE FAULT
417	25-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	17:06	17:21	0:15	LINE CLEAR AVALIED
418	25-Mar-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	11:25	11:29	0:04	TRANSFORMER FAULT
419	25-Mar-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	12:23	12:27	0:04	TRANSFORMER FAULT
420	25-Mar-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	13:14	13:16	0:02	TRANSFORMER FAULT
421	25-Mar-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	13:45	13:50	0:05	TRANSFORMER FAULT
422	25-Mar-2021	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	04:13	04:23	0:10	TRANSFORMER FAULT
423	25-Mar-2021	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	07:46	09:10	1:24	LINE CLEAR AVALIED
424	25-Mar-2021	BAGALKOT	110	110/11KV, HV1	NAVALGUND_110	18:04	21:31	3:27	TRANSFORMER FAULT
425	25-Mar-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	11:09	11:46	0:37	LINE CLEAR AVALIED
426	25-Mar-2021	BAGALKOT	110	MANALISUGARS- MALGHAN(S)	MALGHAN(S)_110	06:26	06:28	0:02	LINE FAULT
427	25-Mar-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	08:27	18:31	10:04	LINE CLEAR AVALIED
428	25-Mar-2021	BAGALKOT	110	MAMADAPUR(B)- BELGAUM SUGARS	MAMADAPUR(B)_110	17:08	17:22	0:14	LINE FAULT
429	25-Mar-2021	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	12:08	17:06	4:58	LINE CLEAR AVALIED
430	25-Mar-2021	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	18:04	20:28	2:24	LINE FAULT
431	25-Mar-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA(AMBEWADI)	STATION NOT AFFECTED KADANKOPPA_110	12:07	17:05	4:58	LINE CLEAR AVALIED
432	25-Mar-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA(AMBEWADI)	STATION NOT AFFECTED KADANKOPPA_110	18:04	20:29	2:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
433	25-Mar-2021	BAGALKOT	110	110/11KV, HV2	GOKAK_110	11:30	17:50	6:20	LINE CLEAR AVAILED
434	25-Mar-2021	BAGALKOT	110	MAHALINGAPUR- DAVLESHWAR	STATION NOT AFFECTED DAVLESHWAR_110	14:59	18:10	3:11	LINE CLEAR AVAILED
435	25-Mar-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	09:14	17:40	8:26	LINE CLEAR AVAILED
436	25-Mar-2021	BAGALKOT	220	BIDNAL- TADAS2 (HIREBENDIGERI2)	STATION NOT AFFECTED BIDNAL_220	10:07	16:40	6:33	LINE CLEAR AVAILED
437	25-Mar-2021	BAGALKOT	220	BIDNAL- TADAS1 (HIREBENDIGERI1)	STATION NOT AFFECTED BIDNAL_220	14:28	15:25	0:57	LINE CLEAR AVAILED
438	25-Mar-2021	BAGALKOT	110	RAIBAG- CHIKKODI1&2	RAIBAG_110	12:05	12:16	0:11	HAND TRIPPED
439	25-Mar-2021	BAGALKOT	110	THORVI(BJCTY)- TIKOTA (TAKKALKI)	TAKKALKI_110	5:45	7:41	1:56	LINE CLEAR AVAILED
440	25-Mar-2021	BENGALURU	66	HV2	GANJIGUNTE	14:13	14:19	0:05	TRANSFORMER FAULT
441	25-Mar-2021	BENGALURU	66	HV1	HOSKOTE 66	9:35	10:15	0:39	LINE CLEAR AVAILED
442	25-Mar-2021	BENGALURU	66	HV1	HOSKOTE 66	11:29	12:10	0:40	LINE CLEAR AVAILED
443	25-Mar-2021	BENGALURU	66	HV1	KAMASAMUDRA	11:12	11:20	0:07	LINE CLEAR AVAILED
444	25-Mar-2021	BENGALURU	66	HV1	MAASTHI	8:50	8:59	0:09	LINE CLEAR AVAILED
445	25-Mar-2021	BENGALURU	66	HV2	MAASTHI	13:39	14:00	0:20	LINE CLEAR AVAILED
446	25-Mar-2021	BENGALURU	66	HV1	VOLVO	11:45	13:10	1:25	LINE CLEAR AVAILED
447	25-Mar-2021	BENGALURU	66	HV1	VOLVO	13:25	13:35	0:10	TRANSFORMER FAULT
448	25-Mar-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	16:59	17:05	0:06	LINE FAULT
449	25-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:03	14:18	0:15	LINE FAULT
450	25-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:03	14:21	0:17	LINE FAULT
451	25-Mar-2021	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	14:10	14:38	0:28	LINE CLEAR AVAILED
452	25-Mar-2021	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	14:10	14:39	0:29	LINE CLEAR AVAILED
453	25-Mar-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	14:10	14:35	0:25	LINE CLEAR AVAILED
454	25-Mar-2021	BENGALURU	66	KAMASAMUDRA - KGF	KAMASAMUDRA	11:12	11:20	0:07	LINE CLEAR AVAILED
455	25-Mar-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	7:21	7:46	0:24	LOAD CURTAILMENT
456	25-Mar-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	7:22	7:47	0:24	LOAD CURTAILMENT
457	25-Mar-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	19:01	19:27	0:26	LINE FAULT
458	25-Mar-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:23	16:43	0:20	LINE CLEAR AVAILED
459	25-Mar-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:39	17:46	0:07	LINE FAULT
460	25-Mar-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:04	11:16	0:12	LINE FAULT
461	25-Mar-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:23	16:44	0:21	LINE CLEAR AVAILED
462	25-Mar-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:39	17:46	0:07	LINE FAULT
463	25-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:42	11:51	0:08	LINE FAULT
464	25-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:56	16:03	0:07	LINE FAULT
465	25-Mar-2021	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	10:34	10:40	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
466	25-Mar-2021	BENGALURU	66	YELAHANKA 220 - LINE5	KHB	3:40	5:02	1:22	LINE FAULT
467	25-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	0:01	0:03	0:02	LINE FAULT
468	25-Mar-2021	BENGALURU	66	HV2	AUSTIN TOWN	12:30	12:36	0:06	LOAD CHANGE OVER
469	25-Mar-2021	BENGALURU	66	HV2	AUSTIN TOWN	14:12	14:17	0:05	LOAD CHANGE OVER
470	25-Mar-2021	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	16:30	16:45	0:15	LOAD CHANGE OVER
471	25-Mar-2021	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	17:40	17:47	0:07	LOAD CHANGE OVER
472	25-Mar-2021	BENGALURU	220	HV1	HAL 220	15:28	17:40	2:12	TRANSFORMER FAULT
473	25-Mar-2021	BENGALURU	66	HV1	HAL 220	15:28	16:28	1:00	LINE CLEAR AVAILED
474	25-Mar-2021	BENGALURU	66	HV1	HAL 220	15:28	16:28	1:00	LINE CLEAR AVAILED
475	25-Mar-2021	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	15:29	16:04	0:35	MAIN SUPPLY FAILURE
476	25-Mar-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	17:04	17:50	0:46	LOAD CHANGE OVER
477	25-Mar-2021	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	8:16	8:25	0:09	TRANSFORMER FAULT
478	25-Mar-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	17:09	17:12	0:03	LINE CLEAR AVAILED
479	25-Mar-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	1:34	1:38	0:04	LINE FAULT
480	25-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	9:38	11:50	2:12	LINE CLEAR AVAILED
481	25-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	15:12	16:50	1:38	LINE CLEAR AVAILED
482	25-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	17:50	18:20	0:30	LINE CLEAR AVAILED
483	25-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
484	25-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN,LINE FAULT
485	25-Mar-2021	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	23:52 (24-03-2021)	0:5 (25-3-2021)	0:13HRS	LINE CHARGED
486	25-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
487	25-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN,LINE FAULT
488	25-Mar-2021	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	19:59	20:19	00:20	LINE FAULT
489	25-Mar-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	GOOGLE_110	10:35(24.03.2021)	13:53(25.03.2021)	27:18HRS	LINE CHARGED
490	25-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	10:05(25.03.21)			LINE OPEN, LINE CLEAR AVAILED
491	25-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHPUR_110 IDLE LINE	10:05(25.03.21)			LINE OPEN, LINE CLEAR AVAILED
492	25-Mar-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)			NFBC ISSUED
493	25-Mar-2021	GULBARGA	110	HV3	HATTI_110	03:53	04:09	00:16	TRANSFORMER FAULT
494	25-Mar-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	08:05	08:30	00:25	MAIN SUPPLY FAILURE
495	25-Mar-2021	GULBARGA	110	SEDAM- ULTRATECHCEMENTS IPP	SEDAM_220	08:38	17:11	08:33	LINE CLEAR AVAILED
496	25-Mar-2021	GULBARGA	110	ITTAGI-HANASI	HANASI_110	14:00	14:40	00:40	MAIN SUPPLY FAILURE
497	25-Mar-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	09:47	10:10	00:23	LINE CLEAR AVAILED
498	25-Mar-2021	GULBARGA	110	KEREHALLI-MUNIRABAD	KEREHALLI_110	09:00	16:50	07:50	LINE CLEAR AVAILED
499	25-Mar-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	05:40	05:50	00:10	LINE FAULT
500	25-Mar-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	21:10	21:15	00:05	LINE FAULT
501	25-Mar-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHA THINAGAR_110,SURAN IPP	21:04	21:22	00:18	LINE FAULT
502	25-Mar-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHA THINAGAR_110,SURAN IPP	21:04	21:23	00:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
503	25-Mar-2021	GULBARGA	110	SINDHANOOR110-RAICHUR2	VALKAMDINNI_110	00:10	0,15625	03:35	LINE FAULT
504	25-Mar-2021	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOOR_220	02:20	02:35	00:15	LINE FAULT
505	25-Mar-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	08:20	08:40	00:20	MAIN SUPPLY FAILURE
506	25-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
507	25-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
508	25-Mar-2021	HASSAN	220	SHRAVITY-TALAGUPPA2	sharavathy_gen	8:41(24.3.2021)	16:42(25.3.2021)	32:01hrs	LINE CHARGED
509	25-Mar-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	8:41(24.3.2021)	16:42(25.3.2021)	32:01hrs	LINE CHARGED
510	25-Mar-2021	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:13	11:30	00:17	NFBC ISSUED
511	25-Mar-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:01	15:17	01:16	LINE FAULT
512	25-Mar-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	15:28	15:34	00:06	HAND TRIPPED
513	25-Mar-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	16:41	21:24	04:43	LINE FAULT
514	25-Mar-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	21:51	21:55	00:04	HAND TRIPPED
515	25-Mar-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:45	14:33	00:48	MAIN SUPPLY FAILURE
516	25-Mar-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:45	14:29	00:44	MAIN SUPPLY FAILURE
517	25-Mar-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:01	14:37	00:36	MAIN SUPPLY FAILURE
518	25-Mar-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:45	14:27	00:42	MAIN SUPPLY FAILURE
519	25-Mar-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:45	14:26	00:41	MAIN SUPPLY FAILURE
520	25-Mar-2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	19:04	22:10	03:06	MAIN SUPPLY FAILURE
521	25-Mar-2021	HASSAN	110	BARANG-ANVATTI	BARANGI_110	12:50	13:15	00:25	MAIN SUPPLY FAILURE
522	25-Mar-2021	HASSAN	110	HV1	KONDENALU_110	15:20	16:40	01:20	LINE CLEAR AVAILED
523	25-Mar-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	07:46	17:16	09:30	LINE CLEAR AVAILED
524	25-Mar-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	07:46	17:16	09:30	LINE CLEAR AVAILED
525	25-Mar-2021	HASSAN	110	HV2	NERALAKERE_110	00:03	00:17	00:14	TRANSFORMER FAULT
526	25-Mar-2021	HASSAN	110	HV2	SORABA_110	14:00	14:40	00:40	MAIN SUPPLY FAILURE
527	25-Mar-2021	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	08:20	08:28	00:08	LINE FAULT
528	25-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:26	16:43	06:17	LINE CLEAR AVAILED
529	25-Mar-2021	HASSAN	66	KIADB-RAMESWARNAGAR	KIADB_66	10:14	17:24	07:10	NFBC ISSUED
530	25-Mar-2021	HASSAN	66	HV1	MALLAPURA_66	13:58	14:10	00:12	LINE CLEAR AVAILED
531	25-Mar-2021	MYSURU	66	HV1	BANNUR_66	11:08	11:20	0:12	TRANSFORMER FAULT
532	25-Mar-2021	MYSURU	66	HV1	CHUNCHUNKATTE_66	18:00	18:16	0:15	TRANSFORMER FAULT
533	25-Mar-2021	MYSURU	66	CR NAGARA-KABBALLI	NO STATION EFFECTED	23:34	23:41	0:06	LINE FAULT
534	25-Mar-2021	MYSURU	66	HV2	FTS_66	6:15	12:40	6:25	LINE CLEAR AVAILED
535	25-Mar-2021	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATION EFFECTED	22:26 (25/03/2021)			LINE OPEN, LINE CLEAR AVAILED
536	25-Mar-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE 66 HDKOTE 66	7:37	7:46	0:09	LINE FAULT
537	25-Mar-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE 66 HDKOTE 66	23:14	23:19	0:04	LINE FAULT
538	25-Mar-2021	MYSURU	66	HV2	K_HONNALGERE_66	1:35	1:40	0:05	MAIN SUPPLY FAILURE
539	25-Mar-2021	MYSURU	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	8:22	17:45	9:22	LINE CLEAR AVAILED
540	25-Mar-2021	MYSURU	66	HV2	KOLLEGALA_66	9:36	10:05	0:28	HAND TRIPPED
541	25-Mar-2021	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	6:55	7:00	0:04	LINE FAULT
542	25-Mar-2021	MYSURU	66	MALAVALLI-KK HALLI-SHIMSHA	MALAVALLI_66 HADLI_66	9:53	12:24	2:31	NFBC ISSUED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
543	25-Mar-2021	MYSURU	66	MALAVALLI-KK HALLI-SHIMSHA	MALAVALLI_66 HADLI_66	15:21	16:41	1:20	NFBC ISSUED
544	25-Mar-2021	MYSURU	66	HV3	PONNAMPET_66	18:50	18:57	0:07	TRANSFORMER FAULT
545	25-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	9:53 (25/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
546	25-Mar-2021	MYSURU	66	TUBINKERE-G UKKADE	GARUDANAUKADDA_66 SRIRANGAPATNA_66	10:16	10:21	0:05	HAND TRIPPED
547	25-Mar-2021	MYSURU	66	TUBINKERE-G UKKADE	GARUDANAUKADDA_66 SRIRANGAPATNA_66	22:18	22:21	0:03	HAND TRIPPED
548	25-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	7:29	7:35	0:05	LINE FAULT
549	25-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	7:45	7:52	0:07	LINE FAULT
550	25-Mar-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN,LINE FAULT
551	25-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
552	25-Mar-2021	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	7:22	8:16	0:53	LOAD CURTAILMENT
553	25-Mar-2021	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	7:16	8:12	0:55	LOAD CURTAILMENT
554	25-Mar-2021	TUMKUR	66	ANCHEPALYA 220kv-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:09	11:24	0:15	LOAD CURTAILMENT
555	25-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	7:22	8:16	0:53	LOAD CURTAILMENT
556	25-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	10:36	10:49	0:12	HAND TRIPPED
557	25-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220kv-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	12:57	13:26	0:29	LINE FAULT
558	25-Mar-2021	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	13:09	13:27	0:17	MAIN SUPPLY FAILURE
559	25-Mar-2021	TUMKUR	66	BELADADARA-KORATAGERE	BELADARA_66	13:09	13:34	0:24	MAIN SUPPLY FAILURE
560	25-Mar-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	19:51	19:58	0:06	LINE CLEAR AVAILED
561	25-Mar-2021	TUMKUR	66	TR-1	CHITRADURGA_66	18:07	18:14	0:07	HAND TRIPPED
562	25-Mar-2021	TUMKUR	66	TR-1	CHITRADURGA_66	18:26	18:32	0:05	HAND TRIPPED
563	25-Mar-2021	TUMKUR	66	TR-3	HARIYABBE_66	10:28	10:36	0:07	TRANSFORMER FAULT
564	25-Mar-2021	TUMKUR	66	TR-3	HARIYABBE_66	10:52	11:02	0:10	TRANSFORMER FAULT
565	25-Mar-2021	TUMKUR	66	TR-3	HARIYABBE_66	11:06	11:17	0:11	TRANSFORMER FAULT
566	25-Mar-2021	TUMKUR	66	TR-3	HARIYABBE_66	11:54	11:57	0:03	TRANSFORMER FAULT
567	25-Mar-2021	TUMKUR	66	TR-1	HOLALKERE_66	22:02	22:19	0:17	TRANSFORMER FAULT
568	25-Mar-2021	TUMKUR	66	TR-2	HOLALKERE_66	12:48	12:50	0:02	TRANSFORMER FAULT
569	25-Mar-2021	TUMKUR	66	TR-3	HOLALKERE_66	18:27	18:30	0:03	TRANSFORMER FAULT
570	25-Mar-2021	TUMKUR	66	TR-1	HONNALI_66	12:16	17:41	5:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
571	25-Mar-2021	TUMKUR	66	TR-2	HONNALI_66	16:42	17:41	0:59	LINE CLEAR AVAILED
572	25-Mar-2021	TUMKUR	66	TR-3	HONNALI_66	12:16	17:41	5:24	LINE CLEAR AVAILED
573	25-Mar-2021	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	17:07	19:42	2:34	LINE CLEAR AVAILED
574	25-Mar-2021	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	11:20	17:15	5:55	LINE CLEAR AVAILED
575	25-Mar-2021	TUMKUR	66	TR-2	KORATAGERE_66	16:43	17:56	1:13	LINE CLEAR AVAILED
576	25-Mar-2021	TUMKUR	66	TR-2	KORATAGERE_66	18:41	19:11	0:29	LINE CLEAR AVAILED
577	25-Mar-2021	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	10:35	10:43	0:07	LOAD CURTAILMENT
578	25-Mar-2021	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	13:45	14:47	1:02	LOAD CHANGE OVER
579	25-Mar-2021	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	16:05	16:43	0:38	MAIN SUPPLY FAILURE
580	25-Mar-2021	TUMKUR	66	TR-1	MAYAKONDA_66	9:06	9:16	0:10	TRANSFORMER FAULT
581	25-Mar-2021	TUMKUR	66	TR-2	MELEKOTE_66	9:18	9:20	0:01	TRANSFORMER FAULT
582	25-Mar-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	11:18	11:19	0:01	TRANSFORMER FAULT
583	26-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
584	26-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGANUR_110	22:15	22:30	0:15	LOAD CURTAILMENT
585	26-Mar-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED MAHALINGAPUR_220	13:05	13:49	0:44	HAND TRIPPED
586	26-Mar-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	22:18	22:30	0:12	LOAD CURTAILMENT
587	26-Mar-2021	BAGALKOT	110	110/11KV,HV1	BYADAGI_110	08:56	9:11	0:15	TRANSFORMER FAULT
588	26-Mar-2021	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	22:18	22:24	0:06	TRANSFORMER FAULT
589	26-Mar-2021	BAGALKOT	110	110/11KV,HV1	AMBEWADI_220	2:09	2:16	0:07	TRANSFORMER FAULT
590	26-Mar-2021	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	22:18	22:45	0:27	LOAD CURTAILMENT
591	26-Mar-2021	BAGALKOT	110	110/11KV,HV2	GOKAK_110	11:33	19:05	7:32	LINE CLEAR AVAILED
592	26-Mar-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	22:18	22:21	0:03	LOAD CURTAILMENT
593	26-Mar-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	22:22	22:43	0:21	LOAD CURTAILMENT
594	26-Mar-2021	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	22:47	23:13	0:26	TRANSFORMER FAULT
595	26-Mar-2021	BAGALKOT	110	110/33KV, HV1 (HV2)	KALABILAGI_33, HIREPADASLAGI LIS_33, TUNGLE LIS_33 STATION NOT AFFECTED SAVALAGI_110	22:19	22:30	0:11	LOAD CURTAILMENT
596	26-Mar-2021	BAGALKOT	110	110/33KV, HV4	HIDIKAL_110	8:13 (24.03.2021)	18:06 (26.03.2021)	57:53 hrs	TRANSFORMER CHARGED
597	26-Mar-2021	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33	22:19	22:27	0:08	LOAD CURTAILMENT
598	26-Mar-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,MYTRA SOLAR_33,KOLIGUDDA_33,ALAGA WADI_33	22:19	22:23	0:04	LOAD CURTAILMENT
599	26-Mar-2021	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	HALIYAL_110	13:06	13:12	0:06	LINE FAULT
600	26-Mar-2021	BAGALKOT	110	ANKOLA-ARGA	STATION NOT AFFECTED ANKOLA_110	13:02	13:53	0:51	LINE CLEAR AVAILED
601	26-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
602	26-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVAILED
603	26-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
604	26-Mar-2021	BAGALKOT	110	HIREHAL-RON	HIREHAL_110,RON_110	10:00	10:14	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
605	26-Mar-2021	BAGALKOT	110	HUBLI220-TARIHAL	STATION NOT AFFECTED HUBLI_220	9:46	14:00	4:14	LINE CLEAR AVAILED
606	26-Mar-2021	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATION NOT AFFECTED KADANKOPPA_110	8:44	11:27	2:43	LINE CLEAR AVAILED
607	26-Mar-2021	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATION NOT AFFECTED KADANKOPPA_110	13:06	14:44	1:38	LINE FAULT
608	26-Mar-2021	BAGALKOT	110	KARWAR-ARGA(KUMTA)	STATION NOT AFFECTED KARWAR_220	13:11	15:33	2:22	LINE CLEAR AVAILED
609	26-Mar-2021	BAGALKOT	110	KARWAR-SOLARIS(BINAGA)	STATION NOT AFFECTED KARWAR_220,BINAGA_110	13:13	15:34	2:21	LINE CLEAR AVAILED
610	26-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
611	26-Mar-2021	BAGALKOT	110	MAHALINGAPUR220- RABAKAVI	RABAKAVI_110	16:22	17:15	0:53	HAND TRIPPED
612	26-Mar-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	18:03	18:04	0:01	HAND TRIPPED
613	26-Mar-2021	BAGALKOT	110	MFR SOLAR-HIREHAL	HIREHAL_110	10:14	10:15	0:01	HAND TRIPPED
614	26-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
615	26-Mar-2021	BAGALKOT	110	RAIBAG-CHIKKODI220 1	RAIBAG_110	15:23	16:57	1:34	NFBC ISSUED
616	26-Mar-2021	BAGALKOT	110	RAIBAG-CHIKKODI220 2	RAIBAG_110	15:23	16:57	1:34	NFBC ISSUED
617	26-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVAILED
618	26-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
619	26-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
620	26-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN,LINE FAULT
621	26-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN, LINE CLEAR AVAILED
622	26-Mar-2021	BAGALKOT	110	RON-GAMESH IPP	RON_110, GAMESH IPP_110	10:29	10:36	0:07	HAND TRIPPED
623	26-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
624	26-Mar-2021	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	13:06	13:22	0:16	LINE FAULT
625	26-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
626	26-Mar-2021	BAGALKOT	110	TARIHAL-HUBLI220	STATION NOT AFFECTED TARIHAL_110	9:19	14:00	4:41	NFBC ISSUED
627	26-Mar-2021	BAGALKOT	110	TUMMINAKATTI (HIREKERUR) -RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)			LINE OPEN, LINE CLEAR AVAILED
628	26-Mar-2021	BAGALKOT	110	TUMMINAKATTI (HIREKERUR) -RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	19:11 (19.03.2021)	8:40 (27.03.2021)	181:29 hrs	LINE CHARGED
629	26-Mar-2021	BAGALKOT	220	220/110,HV1,LV1	KARWAR_220	13:24	14:26	1:02	LINE CLEAR AVAILED
630	26-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	8:02	17:15	9:13	LINE CLEAR AVAILED
631	26-Mar-2021	BAGALKOT	220	AMBEWADI- XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	13:22	17:20	3:58	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
632	26-Mar-2021	BAGALKOT	220	ATHANI220-RAVI URJA1	STATION NOT AFFECTED ATHANI 220	11:10	19:40	8:30	LINE CLEAR AVAILED
633	26-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM 220	10:45 (26.03.2021)			LOAD CURTAILMENT
634	26-Mar-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI 220	12:29	12:55	0:26	LINE FAULT
635	26-Mar-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI 220	17:51	18:07	0:16	LINE CLEAR AVAILED
636	26-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
637	26-Mar-2021	BAGALKOT	220	MAAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
638	26-Mar-2021	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDARA 220	8:02	17:15	9:13	LINE CLEAR AVAILED
639	26-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT
640	26-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
641	26-Mar-2021	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
642	26-Mar-2021	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
643	26-Mar-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	12:10	12:30	00:20	LINE CLEAR AVAILED
644	26-Mar-2021	BENGALURU	66	BIDADI 220 - COCOCOLA(EHT)	COCOCOLA(EHT)	12:10	12:30	00:20	LINE CLEAR AVAILED
645	26-Mar-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	12:10	12:30	00:20	LINE CLEAR AVAILED
646	26-Mar-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPAHALLI	12:10	12:30	00:20	LINE CLEAR AVAILED
647	26-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	07:03	07:07	00:04	LOAD CURTAILMENT
648	26-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	07:03	07:07	00:04	LOAD CURTAILMENT
649	26-Mar-2021	BENGALURU	66	HV1	BIDADI 220	12:10	12:30	00:20	LINE CLEAR AVAILED
650	26-Mar-2021	BENGALURU	66	HV1	DALASNUR	13:42	14:00	00:17	LINE CLEAR AVAILED
651	26-Mar-2021	BENGALURU	66	HV2	BIDADI 220	12:10	12:30	00:20	LINE CLEAR AVAILED
652	26-Mar-2021	BENGALURU	66	HV2	DEVARABISANAHALLI	09:59	10:05	00:06	LINE CLEAR AVAILED
653	26-Mar-2021	BENGALURU	66	HV2	DALASNUR	13:42	14:00	00:17	LINE CLEAR AVAILED
654	26-Mar-2021	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	08:30	11:12	02:42	LINE FAULT
655	26-Mar-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	14:10	14:21	00:11	LINE FAULT
656	26-Mar-2021	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:20	22:39	00:19	LOAD CURTAILMENT
657	26-Mar-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	07:29	07:40	00:11	LINE FAULT
658	26-Mar-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	22:40	23:00	00:20	LOAD CURTAILMENT
659	26-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	00:08	00:14	00:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
660	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	15:12	15:22	00:09	MAIN SUPPLY FAILURE
661	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	21:59	22:10	00:11	MAIN SUPPLY FAILURE
662	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	15:10	15:20	00:10	MAIN SUPPLY FAILURE
663	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	21:59	22:10	00:11	MAIN SUPPLY FAILURE
664	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	15:10	15:21	00:10	MAIN SUPPLY FAILURE
665	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	21:59	22:09	00:10	MAIN SUPPLY FAILURE
666	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	15:10	15:20	00:10	MAIN SUPPLY FAILURE
667	26-Mar-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	21:59	22:08	00:09	MAIN SUPPLY FAILURE
668	26-Mar-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	16:43	16:45	00:02	LINE CLEAR AVAILED
669	26-Mar-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	17:16	17:30	00:14	LINE FAULT
670	26-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	07:05	07:40	00:35	LINE FAULT
671	26-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	07:39	08:11	00:32	LOAD CURTAILMENT
672	26-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN, LINE FAULT
673	26-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN, LINE FAULT
674	26-Mar-2021	BENGALURU	220	HV1	BIDADI 220	12:10	12:30	00:20	LINE CLEAR AVAILED
675	26-Mar-2021	BENGALURU	220	HV2	BIDADI 220	12:10	12:30	00:20	LINE CLEAR AVAILED
676	26-Mar-2021	BENGALURU	220	HV2	MITTEMARI 220	15:06	15:19	00:13	MAIN SUPPLY FAILURE
677	26-Mar-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	15:06	15:18	00:12	MAIN SUPPLY FAILURE
678	26-Mar-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	21:59	22:09	00:10	MAIN SUPPLY FAILURE
679	26-Mar-2021	GULBARGA	110	HV1	CHITAGUPPA_110	09:05	09:45	00:40	LINE CLEAR AVAILED
680	26-Mar-2021	GULBARGA	110	HV1	CHINCHOLI_110	22:21	22:31	00:10	LOAD CURTAILMENT
681	26-Mar-2021	GULBARGA	110	HV1	SANKLAPUR_110	12:18	12:35	00:17	LINE CLEAR AVAILED
682	26-Mar-2021	GULBARGA	110	HV1	SINDHANOOR_110	10:30	12:35	02:05	LINE CLEAR AVAILED
683	26-Mar-2021	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	15:24	15:30	00:06	HAND TRIPPED
684	26-Mar-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110, CHICKSUGUR_110, SHA THINAGAR_110, SURAN IPP	15:30	16:03	00:33	LINE FAULT
685	26-Mar-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	13:11	14:19	01:08	LINE CLEAR AVAILED
686	26-Mar-2021	GULBARGA	110	SEDAM- ULTRATECHCEMENTS IPP	SEDAM_220	08:36	17:02	08:26	LINE CLEAR AVAILED
687	26-Mar-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)			NFBC ISSUED
688	26-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	10:05(25.03.2021)			LINE OPEN, LINE CLEAR AVAILED
689	26-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHPUR_110 IDLE LINE	10:05(25.03.2021)			LINE OPEN, LINE CLEAR AVAILED
690	26-Mar-2021	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	01:05	01:15	00:10	LINE FAULT
691	26-Mar-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110, SRERAMNAGAR_1 10, GANGAVATHI_110, VENKATAGI RI_110	00:20	00:30	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
692	26-Mar-2021	GULBARGA	220	LINGAPUR-HALWARTY1	LINGAPUR_220	08:50	12:28	03:38	LINE CLEAR AVAILED
693	26-Mar-2021	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	14:46	16:15	01:29	LINE CLEAR AVAILED
694	26-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:09	12:50	02:41	LINE CLEAR AVAILED
695	26-Mar-2021	HASSAN	66	BELUR66-HASSAN	BELUR_66	11:39	13:44	02:05	LOAD CURTAILMENT
696	26-Mar-2021	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	12:32	13:50	01:18	LOAD CURTAILMENT
697	26-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:00	12:54	02:54	LINE CLEAR AVAILED
698	26-Mar-2021	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	10:24	10:40	00:16	LINE FAULT
699	26-Mar-2021	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	13:52	18:50	04:58	LINE CLEAR AVAILED
700	26-Mar-2021	HASSAN	66	HV1	SALAGAME_66	23:54(25.02.2021)	2:06(26.02.2021)	2:11 hrs	TRANSFORMER CHARGED
701	26-Mar-2021	HASSAN	66	HV1	ALDUR_66	15:10	15:40	00:30	LINE CLEAR AVAILED
702	26-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:37	12:57	02:20	LINE CLEAR AVAILED
703	26-Mar-2021	HASSAN	66	HV1	GANGUR_66	11:20	11:55	00:35	LINE CLEAR AVAILED
704	26-Mar-2021	HASSAN	66	HV1	SALAGAME_66	19:48	20:12	00:24	LOAD CURTAILMENT
705	26-Mar-2021	HASSAN	66	HV1	SINGAPURA_66	10:26	10:42	00:16	LOAD CURTAILMENT
706	26-Mar-2021	HASSAN	66	HV2	SALAGAME_66	23:54(25.02.2021)	2:06(26.02.2021)	2:11 hrs	TRANSFORMER CHARGED
707	26-Mar-2021	HASSAN	66	HV2	SALAGAME_66	17:58	20:12	02:14	LOAD CURTAILMENT
708	26-Mar-2021	HASSAN	66	HV2	SINGAPURA_66	10:26	10:42	00:16	LOAD CURTAILMENT
709	26-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
710	26-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
711	26-Mar-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	08:57	16:09	07:12	LINE CLEAR AVAILED
712	26-Mar-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	08:52	16:09	07:17	LINE CLEAR AVAILED
713	26-Mar-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	23:59(25.02.2021)	2:05(26.02.2021)	2:05 hrs	LINE CHARGED
714	26-Mar-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	15:41	18:02	02:21	LOAD CURTAILMENT
715	26-Mar-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	19:50	20:17	00:27	LOAD CURTAILMENT
716	26-Mar-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	23:54(25.02.2021)	20:11(26.02.2021)	20:16 hrs	LINE CHARGED
717	26-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:01	12:55	02:54	LINE CLEAR AVAILED
718	26-Mar-2021	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	01:12	20:07	18:55	LINE CLEAR AVAILED
719	26-Mar-2021	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	11:00	13:10	02:10	LINE CLEAR AVAILED
720	26-Mar-2021	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	09:15	14:16	05:01	LINE CLEAR AVAILED
721	26-Mar-2021	HASSAN	110	HV1	ESSUR_110	22:29	22:45	00:16	LINE CLEAR AVAILED
722	26-Mar-2021	HASSAN	110	HV2	ESSUR_110	12:45 (25.02.2021)	23:25(26.02.2021)	34:39 hrs	TRANSFORMER CHARGED
723	26-Mar-2021	HASSAN	110	HV2	KARAYA_110	19:35 (25.02.2021)	16:09 (26.02.2021)	20:33 hrs	TRANSFORMER CHARGED
724	26-Mar-2021	HASSAN	110	HV2	HALADY_110	09:30	09:35	00:05	TRANSFORMER FAULT
725	26-Mar-2021	HASSAN	110	KADUR-TNGL	KADUR_220	11:14	12:34	01:20	LINE CLEAR AVAILED
726	26-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:26(26.02.2021)			LINE OPEN, LINE CLEAR AVAILED
727	26-Mar-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	10:23	14:23	04:00	LINE FAULT
728	26-Mar-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:05 (26.02.2021)			LINE OPEN, LINE CLEAR AVAILED
729	26-Mar-2021	MYSURU	66	BETTADAPURA-KUSHALNAGARA	BETTADHAPURA_66	19:25	20:10	0:45	HAND TRIPPED
730	26-Mar-2021	MYSURU	66	DATAGALLI-RK NAGARA	DATTAGALLY_66	9:00	15:52	6:52	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
731	26-Mar-2021	MYSURU	66	DR PETE-KUNTHUR	KUNTHUR_66 JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	8:02	8:11	0:09	LINE FAULT
732	26-Mar-2021	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATION EFFECTED	22:26 (25/03/2021)	11:35 (26/03/2021)	13:08 HRS	LINE CHARGED
733	26-Mar-2021	MYSURU	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66	10:10	19:13	9:02	NFBC ISSUED
734	26-Mar-2021	MYSURU	66	HV1	ADDIHALLI_66	8:35	11:19	2:44	LINE CLEAR AVAILED
735	26-Mar-2021	MYSURU	66	HV1	BGNAGARA_66	22:16	22:20	0:03	LOAD CURTAILMENT
736	26-Mar-2021	MYSURU	66	HV1	BGNAGARA_66	22:15	22:38	0:22	LOAD CURTAILMENT
737	26-Mar-2021	MYSURU	66	HV1	BILIKERE_66	22:16	22:23	0:06	LOAD CURTAILMENT
738	26-Mar-2021	MYSURU	66	HV1	HANAGODU_66	22:25	22:27	0:02	LOAD CURTAILMENT
739	26-Mar-2021	MYSURU	66	HV1	HANGLA_66	14:30	14:40	0:10	TRANSFORMER FAULT
740	26-Mar-2021	MYSURU	66	HV1	HEBBAL_66	6:51	7:20	0:28	LINE CLEAR AVAILED
741	26-Mar-2021	MYSURU	66	HV1	HOOTAGALLY_220	11:17	11:26	0:09	HAND TRIPPED
742	26-Mar-2021	MYSURU	66	HV1	KRPET_66	22:21	22:29	0:07	LOAD CURTAILMENT
743	26-Mar-2021	MYSURU	66	HV1	KUSHALNAGARA_66	22:15	22:35	0:19	LOAD CURTAILMENT
744	26-Mar-2021	MYSURU	66	HV1	RAMAPURA_MYS_66	22:20	22:30	0:10	LOAD CURTAILMENT
745	26-Mar-2021	MYSURU	66	HV1	SANIVARASANTHE_66	15:29	15:40	0:10	LINE CLEAR AVAILED
746	26-Mar-2021	MYSURU	66	HV2	ADDIHALLI_66	22:15	22:30	0:14	LOAD CURTAILMENT
747	26-Mar-2021	MYSURU	66	HV2	AKKIHEBBAL_66	22:25	22:29	0:04	LOAD CURTAILMENT
748	26-Mar-2021	MYSURU	66	HV2	BOOKANAKERE_66	22:20	22:29	0:09	LOAD CURTAILMENT
749	26-Mar-2021	MYSURU	66	HV2	CHINAKURALI_66	22:20	22:31	0:11	LOAD CURTAILMENT
750	26-Mar-2021	MYSURU	66	HV2	HOOTAGALLY_220	11:17	11:26	0:09	HAND TRIPPED
751	26-Mar-2021	MYSURU	66	HV2	KIRUGAVALU_66	22:22	22:43	0:21	LOAD CURTAILMENT
752	26-Mar-2021	MYSURU	66	HV2	KMDODDI_66	22:18	22:29	0:11	LOAD CURTAILMENT
753	26-Mar-2021	MYSURU	66	HV2	BETTADHAPURA_66	19:25 (26/03/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
754	26-Mar-2021	MYSURU	66	HV2	MALAVALLI_66	22:21	22:26	0:05	LOAD CURTAILMENT
755	26-Mar-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	22:20	22:35	0:15	LOAD CURTAILMENT
756	26-Mar-2021	MYSURU	66	HV2	THALAKADU_66	22:20	22:30	0:10	LOAD CURTAILMENT
757	26-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	16:10	23:01	6:51	LINE CLEAR AVAILED
758	26-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	9:53 (25/03/2021)	5:25 (26/03/2021)	19:31 HRS	TRANSFORMER CHARGED
759	26-Mar-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	6:40	6:49	0:09	LINE FAULT
760	26-Mar-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	22:01	22:08	0:07	LINE FAULT
761	26-Mar-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	7:02	11:31	4:28	LINE CLEAR AVAILED
762	26-Mar-2021	MYSURU	66	KADAKOLA-SARGUR 2	CHANDAKAVADI_66 DOORA_66 HURA_66 HULLAHALLI_66	7:02	10:07	3:05	LINE CLEAR AVAILED
763	26-Mar-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN,LINE FAULT
764	26-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
765	26-Mar-2021	MYSURU	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66	19:25	19:30	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
766	26-Mar-2021	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	7:04	7:07	0:02	LINE FAULT
767	26-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	12:25	12:34	0:09	LINE FAULT
768	26-Mar-2021	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	3:15	3:25	0:10	LINE FAULT
769	26-Mar-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	14:58	15:16	0:18	LOAD CURTAILMENT
770	26-Mar-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	22:25	23:02	0:36	LOAD CURTAILMENT
771	26-Mar-2021	TUMKUR	66	ANCHEPALYA 220- HEBBUR	HEBBUR-66, HONNENAHALLI-66, THIMMASANDRA-66	22:21	23:02	0:41	LOAD CURTAILMENT
772	26-Mar-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,	21:46	21:59	0:13	LOAD CURTAILMENT
773	26-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	14:08	14:43	0:34	LINE FAULT
774	26-Mar-2021	TUMKUR	66	BALENAHALLI- FEFCWIND IPP_66	FEFCWIND_IPP_66	10:09	15:10	5:01	LINE CLEAR AVAILED
775	26-Mar-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:14	14:33	0:18	LINE CLEAR AVAILED
776	26-Mar-2021	TUMKUR	66	BEVINAHALLI- JAVAGONDANAHALLI	BEVINAHALLI_66	14:09	14:14	0:05	LINE CLEAR AVAILED
777	26-Mar-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	6:38	7:06	0:27	LOAD CURTAILMENT
778	26-Mar-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66,CHI TRAHALLI_66	6:38	6:42	0:04	LOAD CURTAILMENT
779	26-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:30	13:12	1:41	LINE CLEAR AVAILED
780	26-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:38	13:17	1:38	MAIN SUPPLY FAILURE
781	26-Mar-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:50	15:55	0:04	LINE FAULT
782	26-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:09	6:17	0:08	LINE FAULT
783	26-Mar-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	15:04	16:39	1:35	LINE CLEAR AVAILED
784	26-Mar-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	16:04	16:15	0:10	HAND TRIPPED
785	26-Mar-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	6:50	7:02	0:12	LOAD CURTAILMENT
786	26-Mar-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	7:18	7:28	0:10	LINE FAULT
787	26-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	5:09	7:20	2:10	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
788	26-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP 66	TATA SOLAR_IPP_66	7:36	7:40	0:04	LINE FAULT
789	26-Mar-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	11:04	11:48	0:44	LINE CLEAR AVAILED
790	26-Mar-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	16:02	16:14	0:12	LINE FAULT
791	26-Mar-2021	TUMKUR	66	TR-1	GULIGENAHALLI_66	20:03	20:11	0:07	TRANSFORMER FAULT
792	26-Mar-2021	TUMKUR	66	TR-1	HARIHAR_66	11:48	13:18	1:29	MAIN SUPPLY FAILURE
793	26-Mar-2021	TUMKUR	66	TR-1	HDPURA_66	16:54	16:57	0:02	TRANSFORMER FAULT
794	26-Mar-2021	TUMKUR	66	TR-1	HOLALKERE_66	14:13	16:15	2:01	LINE CLEAR AVAILED
795	26-Mar-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	0:36	0:38	0:01	TRANSFORMER FAULT
796	26-Mar-2021	TUMKUR	66	TR-2	AVAREGERE_66	12:43	14:03	1:20	LINE CLEAR AVAILED
797	26-Mar-2021	TUMKUR	66	TR-2	BENNEHALLI_66	17:30	17:54	0:24	LINE CLEAR AVAILED
798	26-Mar-2021	TUMKUR	66	TR-2	CHITRADURGA_66	14:21	16:46	2:25	LINE CLEAR AVAILED
799	26-Mar-2021	TUMKUR	66	TR-2	HARIHAR_66	11:38	13:18	1:40	MAIN SUPPLY FAILURE
800	26-Mar-2021	TUMKUR	66	TR-2	HOLALKERE_66	9:48	9:54	0:06	TRANSFORMER FAULT
801	26-Mar-2021	TUMKUR	66	TR-2	KORA_66	16:33	16:49	0:15	LINE CLEAR AVAILED
802	26-Mar-2021	TUMKUR	66	TR-2	MATHOD_66	12:01	12:08	0:07	TRANSFORMER FAULT
803	26-Mar-2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	14:27	14:38	0:10	TRANSFORMER FAULT
804	26-Mar-2021	TUMKUR	66	TR-2	PALLAGATTE_66	7:03	7:10	0:06	TRANSFORMER FAULT
805	26-Mar-2021	TUMKUR	66	TR-2	SHYLAPURA_66	13:25	13:38	0:12	TRANSFORMER FAULT
806	26-Mar-2021	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	0:20	1:37	1:17	MAIN SUPPLY FAILURE
807	26-Mar-2021	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	2:14	8:08	5:54	LINE FAULT
808	26-Mar-2021	TUMKUR	110	HONNAVALI 110-TIPTUR	HALKURKE_110,KEREKODI_110,H UNSEGHATTA 110	9:24	9:36	0:11	HAND TRIPPED
809	26-Mar-2021	TUMKUR	110	TR-1	SHETYKERE_110	13:24	13:32	0:07	TRANSFORMER FAULT
810	26-Mar-2021	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 1	ANCHEPALYA_220	7:10	9:46	2:36	LINE CLEAR AVAILED
811	26-Mar-2021	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	10:41	17:32	6:51	LOAD CURTAILMENT
812	27-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
813	27-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	7:20	7:29	0:09	LINE CLEAR AVAILED
814	27-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUDDEBIHAL_110	9:20	9:26	0:06	TRANSFORMER FAULT
815	27-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUDDEBIHAL_110	10:32	10:36	0:04	TRANSFORMER FAULT
816	27-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUDDEBIHAL_110	12:09	12:18	0:09	TRANSFORMER FAULT
817	27-Mar-2021	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	01:15	08:46	7:31	TRANSFORMER FAULT
818	27-Mar-2021	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	8:59	10:00	1:01	LINE CLEAR AVAILED
819	27-Mar-2021	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	16:26	16:30	0:04	LINE CLEAR AVAILED
820	27-Mar-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,MYTRA SOLAR_33,KOLIGUDDA_33	13:32	14:19	0:47	LINE CLEAR AVAILED
821	27-Mar-2021	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI_33	12:43	14:22	1:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
822	27-Mar-2021	BAGALKOT	110	110/3KV, HV4	HALASANGI_33, NIVARGI_33, DULAKHED_33 STATION NOT AFFECTED ZALKI_110	10:56	11:08	0:12	TRANSFORMER FAULT
823	27-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
824	27-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
825	27-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
826	27-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
827	27-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
828	27-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
829	27-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
830	27-Mar-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
831	27-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN, LINE FAULT
832	27-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
833	27-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
834	27-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
835	27-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	7:57	15:23	7:26	LINE CLEAR AVOIDED
836	27-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:45 (26.03.2021)			LOAD CURTAILMENT
837	27-Mar-2021	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
838	27-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
839	27-Mar-2021	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
840	27-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA1	STATION NOT AFFECTED HAVERI_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
841	27-Mar-2021	BAGALKOT	220	MAAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
842	27-Mar-2021	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	7:54	15:24	7:30	LINE CLEAR AVOIDED
843	27-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
844	27-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
845	27-Mar-2021	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
846	27-Mar-2021	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
847	27-Mar-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	11:41	11:46	00:05	LOAD CHANGE OVER
848	27-Mar-2021	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	16:19	16:42	00:23	LINE FAULT
849	27-Mar-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	06:40	07:21	00:40	LINE FAULT
850	27-Mar-2021	BENGALURU	66	HV1	ALLIMARADANAHALLI	07:15	08:34	01:19	LINE CLEAR AVAILED
851	27-Mar-2021	BENGALURU	66	HV1	EPID 220	11:09	11:12	00:03	TRANSFORMER FAULT
852	27-Mar-2021	BENGALURU	66	HV1	HUKUNDA	11:39	11:44	00:04	TRANSFORMER FAULT
853	27-Mar-2021	BENGALURU	66	HV2	MANCHENAHALLI	10:38	10:50	00:11	LINE CLEAR AVAILED
854	27-Mar-2021	BENGALURU	66	HV2	THIMMAMPALLI	10:35	11:40	01:05	LINE CLEAR AVAILED
855	27-Mar-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE	09:29	09:36	00:07	LINE FAULT
856	27-Mar-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	09:16	10:18	01:02	LINE FAULT
857	27-Mar-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	09:16	10:27	01:11	LINE FAULT
858	27-Mar-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:03	09:10	00:07	LINE FAULT
859	27-Mar-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	09:03	09:10	00:07	LINE FAULT
860	27-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:36	10:42	00:05	LINE FAULT
861	27-Mar-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	17:25	17:30	00:05	LOAD CHANGE OVER
862	27-Mar-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	18:20	18:24	00:04	LOAD CHANGE OVER
863	27-Mar-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	07:29	07:34	00:05	LOAD CHANGE OVER
864	27-Mar-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	07:29	07:34	00:05	LOAD CHANGE OVER
865	27-Mar-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	07:29	07:34	00:05	LOAD CHANGE OVER
866	27-Mar-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	07:29	07:34	00:05	LOAD CHANGE OVER
867	27-Mar-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	14:57	15:00	00:03	LOAD CHANGE OVER
868	27-Mar-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	10:22	10:25	00:03	LOAD CHANGE OVER
869	27-Mar-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	14:40	14:44	00:04	LOAD CHANGE OVER
870	27-Mar-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	18:15	18:20	00:05	LOAD CHANGE OVER
871	27-Mar-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:17	12:02	00:44	MAIN SUPPLY FAILURE
872	27-Mar-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:17	11:45	00:27	MAIN SUPPLY FAILURE
873	27-Mar-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:56	18:08	00:12	LOAD CHANGE OVER
874	27-Mar-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:17	11:53	00:35	MAIN SUPPLY FAILURE
875	27-Mar-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:30	14:36	00:06	LOAD CHANGE OVER
876	27-Mar-2021	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	07:11	07:29	00:18	LINE FAULT
877	27-Mar-2021	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	17:47	18:05	00:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
878	27-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	15:54	18:19	02:25	LOAD CURTAILMENT
879	27-Mar-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	11:20	13:39	02:19	MAIN SUPPLY FAILURE
880	27-Mar-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	18:28	18:38	00:10	LOAD CHANGE OVER
881	27-Mar-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:20	13:39	02:19	MAIN SUPPLY FAILURE
882	27-Mar-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:28	18:38	00:10	LOAD CHANGE OVER
883	27-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN,LINE FAULT
884	27-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
885	27-Mar-2021	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	11:17	12:32	01:15	LINE FAULT
886	27-Mar-2021	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:35	13:02	00:26	LINE FAULT
887	27-Mar-2021	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:02	17:52	04:49	LINE FAULT
888	27-Mar-2021	BENGALURU	220	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	18:28	18:38	00:10	LOAD CHANGE OVER
889	27-Mar-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	11:20	13:20	02:00	MAIN SUPPLY FAILURE
890	27-Mar-2021	GULBARGA	110	HV1	GURUMITAKAL_110	02:00	02:14	00:14	TRANSFORMER FAULT
891	27-Mar-2021	GULBARGA	110	HV2	MANVI_110	04:02	04:09	00:07	TRANSFORMER FAULT
892	27-Mar-2021	GULBARGA	110	HV2	MANVI_110	11:57	12:08	00:11	TRANSFORMER FAULT
893	27-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	22:10	22:20	00:10	LINE FAULT
894	27-Mar-2021	GULBARGA	110	SEDAM- ULTRATECHCEMENTS IPP	SEDAM_220	08:11	17:18	09:07	LINE CLEAR AVAILED
895	27-Mar-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)			NFBC ISSUED
896	27-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	10:05(25.03.2021)	20:20(27.03.2021)	58:15HRS	LINE CHARGED
897	27-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHPUR_110 IDLE LINE	10:05(25.03.2021)			LINE OPEN, LINE CLEAR AVAILED
898	27-Mar-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	08:10	08:40	00:30	LINE CLEAR AVAILED
899	27-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:37	17:31	06:54	LINE CLEAR AVAILED
900	27-Mar-2021	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	13:35	13:44	00:09	LINE FAULT
901	27-Mar-2021	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	15:24	15:36	00:12	HAND TRIPPED
902	27-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	09:59	17:23	07:24	LINE CLEAR AVAILED
903	27-Mar-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	17:03	17:07	00:04	HAND TRIPPED
904	27-Mar-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	11:22	11:51	00:29	LINE FAULT
905	27-Mar-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:21	13:15	01:54	LINE CLEAR AVAILED
906	27-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:37	17:31	06:54	LINE CLEAR AVAILED
907	27-Mar-2021	HASSAN	66	HV1	HAGARE_66	11:13	12:55	01:42	LINE CLEAR AVAILED
908	27-Mar-2021	HASSAN	66	HV1	MALALI_66	11:24	11:55	00:31	LOAD CURTAILMENT
909	27-Mar-2021	HASSAN	66	HV1	SALAGAME_66	11:05	11:47	00:42	LOAD CURTAILMENT
910	27-Mar-2021	HASSAN	66	HV1	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
911	27-Mar-2021	HASSAN	66	HV2	SALAGAME_66	11:05	11:47	00:42	LOAD CURTAILMENT
912	27-Mar-2021	HASSAN	66	HV2	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
913	27-Mar-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
914	27-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
915	27-Mar-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	10:52	16:39	05:47	LINE CLEAR AVAILED
916	27-Mar-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	10:52	16:24	05:32	LINE CLEAR AVAILED
917	27-Mar-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:05	11:47	00:42	LOAD CURTAILMENT
918	27-Mar-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
919	27-Mar-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	11:05	11:46	00:41	LOAD CURTAILMENT
920	27-Mar-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
921	27-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:31	17:30	06:59	LINE CLEAR AVAILED
922	27-Mar-2021	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	14:15	14:22	00:07	HAND TRIPPED
923	27-Mar-2021	HASSAN	110	HV1	HALADY_110	09:20	09:29	00:09	HAND TRIPPED
924	27-Mar-2021	HASSAN	110	HV1	HALADY_110	10:28	11:42	01:14	LINE CLEAR AVAILED
925	27-Mar-2021	HASSAN	110	HV2	ESSUR_110	10:19	10:52	00:33	LINE CLEAR AVAILED
926	27-Mar-2021	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	10:31	15:09	04:38	NFBC ISSUED
927	27-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:26(26.02.2021)			LINE OPEN, LINE CLEAR AVAILED
928	27-Mar-2021	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	10:31	15:09	04:38	LINE CLEAR AVAILED
929	27-Mar-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	04:27	07:53	03:26	LINE FAULT
930	27-Mar-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:05 (26.02.2021)	15:39 (27.02.2021)	21:30 hrs	LINE CHARGED
931	27-Mar-2021	MYSURU	66	HOOTAGALLI-BARC-2	NO STATION EFFECTED	6:30	6:47	0:17	LINE FAULT
932	27-Mar-2021	MYSURU	66	HOOTAGALLI-BOGHADI	BOGADHI_66 KALAMANDIRA_66	14:46	14:59	0:13	LINE FAULT
933	27-Mar-2021	MYSURU	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	5:28	5:30	0:02	LINE FAULT
934	27-Mar-2021	MYSURU	66	HOOTAGALLI-ELWALA	NO STATION EFFECTED	12:39	13:23	0:43	LINE FAULT
935	27-Mar-2021	MYSURU	66	HOOTAGALLI-FTS1	FTS_66	13:09	13:20	0:11	LINE FAULT
936	27-Mar-2021	MYSURU	66	HOOTAGALLI-FTS1	FTS_66	14:30	14:37	0:06	LINE FAULT
937	27-Mar-2021	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATION EFFECTED	12:39	13:23	0:43	LINE FAULT
938	27-Mar-2021	MYSURU	66	HV1	ARAKERE_66	14:35	14:38	0:03	TRANSFORMER FAULT
939	27-Mar-2021	MYSURU	66	HV1	BETTADHAPURA_66	17:40	17:55	0:14	LINE CLEAR AVAILED
940	27-Mar-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	20:52	22:04	1:11	TRANSFORMER FAULT
941	27-Mar-2021	MYSURU	66	HV2	ADDIHALLI_66	7:30	11:13	3:43	LINE CLEAR AVAILED
942	27-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	17:36 (27/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
943	27-Mar-2021	MYSURU	66	KOLLEGALA- MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN,LINE FAULT
944	27-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
945	27-Mar-2021	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATION EFFECTED	5:57	6:03	0:05	LINE FAULT
946	27-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	7:28	7:34	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
947	27-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	14:35	14:40	0:04	LINE FAULT
948	27-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	15:10	15:16	0:05	LINE FAULT
949	27-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:41	16:43	0:02	HAND TRIPPED
950	27-Mar-2021	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66	17:51	18:02	0:10	LINE FAULT
951	27-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:28	19:04	12:35	LINE CLEAR AVAILED
952	27-Mar-2021	TUMKUR	66	ANTHRASANAHALI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	13:27	14:16	0:49	LINE FAULT
953	27-Mar-2021	TUMKUR	66	ANTHRASANAHALI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	16:16	18:19	2:02	LINE FAULT
954	27-Mar-2021	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:33	6:50	0:17	LINE FAULT
955	27-Mar-2021	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_66	13:58	14:10	0:11	LINE FAULT
956	27-Mar-2021	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	20:23	20:34	0:10	LINE FAULT
957	27-Mar-2021	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:20	10:38	0:18	LINE FAULT
958	27-Mar-2021	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66 , BASAVAPATNA_66	8:51	9:03	0:11	LINE FAULT
959	27-Mar-2021	TUMKUR	66	KALAMARANAHALI- PR PURA	KALAMARANAHALI_66	13:50	13:54	0:04	LINE FAULT
960	27-Mar-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:26	10:44	0:18	HAND TRIPPED
961	27-Mar-2021	TUMKUR	66	TR-1	GOWRASAMUDRA_66	16:25	16:48	0:22	HAND TRIPPED
962	27-Mar-2021	TUMKUR	66	TR-1	KUNDUR_66	19:07	19:23	0:16	TRANSFORMER FAULT
963	27-Mar-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	0:04	0:09	0:04	TRANSFORMER FAULT
964	27-Mar-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	0:34	0:39	0:04	TRANSFORMER FAULT
965	27-Mar-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	9:57	10:04	0:06	TRANSFORMER FAULT
966	27-Mar-2021	TUMKUR	66	TR-1	MAYAKONDA_66	16:08	19:36	3:27	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
967	27-Mar-2021	TUMKUR	66	TR-2	CHITRADURGA_66	12:43	14:07	1:24	LINE CLEAR AVAILED
968	27-Mar-2021	TUMKUR	66	TR-2	KORA_66	5:08	11:01	5:52	LINE CLEAR AVAILED
969	27-Mar-2021	TUMKUR	66	TR-3	HOLALKERE_66	15:40	16:35	0:55	LINE CLEAR AVAILED
970	27-Mar-2021	TUMKUR	110	TR-1	DODDAGUNI_110	15:20	17:17	1:57	LINE CLEAR AVAILED
971	27-Mar-2021	TUMKUR	110	TR-1	SHETYKERE_110	10:21	10:31	0:10	TRANSFORMER FAULT
972	27-Mar-2021	TUMKUR	110	TR-1	SHETYKERE_110	14:22	14:28	0:05	TRANSFORMER FAULT
973	27-Mar-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:49	17:02	4:12	LINE FAULT
974	27-Mar-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:50	17:02	4:11	LINE FAULT
975	28-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
976	28-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL_110	11:13	11:28	0:15	TRANSFORMER FAULT
977	28-Mar-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED SADALAGA_110	16:29	16:38	0:09	HAND TRIPPED
978	28-Mar-2021	BAGALKOT	110	110/11KV,HV1	GADAG_110	1:53	2:31	0:38	HAND TRIPPED
979	28-Mar-2021	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	18:00	18:41	0:41	LINE CLEAR AVAILED
980	28-Mar-2021	BAGALKOT	110	110/11KV,HV2	KALGATAGI_110	21:00	21:06	0:06	TRANSFORMER FAULT
981	28-Mar-2021	BAGALKOT	110	110/33KV,HV2	ATHANI_110,JAMBAGI_33,MURGU NDI_33	07:02	07:28	0:26	LINE CLEAR AVAILED
982	28-Mar-2021	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,BOMMANAHALLI_ 33,AKKIALURU_33,BELAGALPETE_ 33,LAXMIPURA_33	7:57	8:06	0:09	TRANSFORMER FAULT
983	28-Mar-2021	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,BOMMANAHALLI_ 33,AKKIALURU_33,BELAGALPETE_ 33,LAXMIPURA_33	9:40	9:46	0:06	TRANSFORMER FAULT
984	28-Mar-2021	BAGALKOT	110	110/33KV,HV3	LAXMESHVAR_110,SSM_33,MMC L_33	8:27	8:53	0:26	TRANSFORMER FAULT
985	28-Mar-2021	BAGALKOT	110	110/33KV,HV3,HV4	GADAG_110,LAKKUNDI_110,HULIK OTI_33,KAPPADA GUDDA_33,MALLASAMUDRA_33, NAGAVI_110,TDPL1&2_33,PIONEE R_33	2:10	2:31	0:21	HAND TRIPPED
986	28-Mar-2021	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_3 3	8:14	8:19	0:05	TRANSFORMER FAULT
987	28-Mar-2021	BAGALKOT	110	110/3KV, HV4	HALASANGI_33, NIVARGI_33, DULAKHED_33 STATION NOT AFFECTED ZALKI_110	09:25	09:30	0:05	TRANSFORMER FAULT
988	28-Mar-2021	BAGALKOT	110	220/110KV,LV1,LV2	HAVERI_220,HANAGAL_110,SAVA NUR_110,BYADAGI_110,BASAVAN AKATTI_110,GM SUGARS_110,TILUVALI_110,KNNL_ 110	13:17	14:01	0:44	LINE CLEAR AVAILED
989	28-Mar-2021	BAGALKOT	110	BAGEWADI-MUDEBEHAL	MUDEBEHAL_110	0:02	7:40	7:38	LINE FAULT
990	28-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
991	28-Mar-2021	BAGALKOT	110	GADAG-DAMBAL1(SAMBAPUR ROAD)	STATION NOT AFFECTED GADAG_220	17:26	17:36	0:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
992	28-Mar-2021	BAGALKOT	110	GADAG-DAMBAL2	STATION NOT AFFECTED GADAG_220	17:20	17:25	0:05	LINE CLEAR AVAILED
993	28-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVAILED
994	28-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
995	28-Mar-2021	BAGALKOT	110	HUKKERI-KOTAWAGI LIS	HUKKERI_110,KOTAWAGI LIS_110	9:53	15:16	5:23	LINE FAULT
996	28-Mar-2021	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	4:43	5:16	0:33	LINE FAULT
997	28-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
998	28-Mar-2021	BAGALKOT	110	MALAGHAN(S)-MANALI SUGARS	MANALI SUGARS_110 STATION NOT AFFECTED MALAGHAN(S)_110	11:40	12:47	1:07	LINE FAULT
999	28-Mar-2021	BAGALKOT	110	MUDEDEBIHAL-BAGEWADI220	MUDEDEBIHAL_110	1:07	7:55	6:48	NFBC ISSUED
1000	28-Mar-2021	BAGALKOT	110	MUDEDEBIHAL-BALAJI SUGARS	MUDEDEBIHAL_110 BALAJI SUGARS_110	0:00	8:10	8:10	LINE FAULT
1001	28-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
1002	28-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1003	28-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1004	28-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
1005	28-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN,LINE FAULT
1006	28-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1007	28-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1008	28-Mar-2021	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	18:03 (28.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1009	28-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1010	28-Mar-2021	BAGALKOT	110	UMMACHAGI(SIRSI220)- KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:24	18:03	1:39	LINE FAULT
1011	28-Mar-2021	BAGALKOT	110	UMMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	16:23	17:56	1:33	LINE FAULT
1012	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-BILAGI	BILAGI_110	22:01	22:05	0:04	HAND TRIPPED
1013	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-JK CEMENT	JK CEMENT_110 STATION NOT AFFECTED VAJJRAMATTI_220	22:05	22:07	0:02	HAND TRIPPED
1014	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-KATARKI	KATARKI_110	16:17	16:19	0:02	HAND TRIPPED
1015	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-LOKAPUR	LOKAPUR_110	15:34	15:50	0:16	HAND TRIPPED
1016	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-LOKAPUR	LOKAPUR_110	15:50	15:55	0:05	HAND TRIPPED
1017	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-MANTUR1	MANTUR_110	15:32	15:34	0:02	HAND TRIPPED
1018	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-MANTUR2	MANTUR_110	15:33	15:36	0:03	HAND TRIPPED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1019	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-MELLIGERI	MELLIGERI_110	15:38	15:41	0:03	HAND TRIPPED
1020	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-MUDHOL (MANTUR)	MUDHOL_110	22:05	22:07	0:02	HAND TRIPPED
1021	28-Mar-2021	BAGALKOT	110	VAJJRAMATTI220-VAJJRAMATTI	VAJJRAMATTI_110	15:39	15:42	0:03	HAND TRIPPED
1022	28-Mar-2021	BAGALKOT	220	220/110KV,HV2	STATION NOT AFFECTED GADAG_220	15:31	17:33	2:02	LINE CLEAR AVOIDED
1023	28-Mar-2021	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	17:23 (28.03.2021)			LINE OPEN,LINE FAULT
1024	28-Mar-2021	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	9:13	9:44	0:31	LINE FAULT
1025	28-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	18:21	18:23	0:02	LOAD CURTAILMENT
1026	28-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:45 (26.03.2021)	18:23 (28.03.2021)	55:38 hrs	LINE CHARGED
1027	28-Mar-2021	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1028	28-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
1029	28-Mar-2021	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1030	28-Mar-2021	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	13:17	14:01	0:44	LINE CLEAR AVOIDED
1031	28-Mar-2021	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	13:17	14:01	0:44	LINE CLEAR AVOIDED
1032	28-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA1	STATION NOT AFFECTED HAVERI_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1033	28-Mar-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	16:04 (28.03.2021)			LINE OPEN,LINE FAULT
1034	28-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1035	28-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
1036	28-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1037	28-Mar-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	16:04 (28.03.2021)			LINE OPEN,LINE FAULT
1038	28-Mar-2021	BAGALKOT	220	VAJJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJJRAMATTI_220	15:59	16:02	0:03	HAND TRIPPED
1039	28-Mar-2021	BAGALKOT	220	VAJJRAMATTI-BAGALKOT2	STATION NOT AFFECTED VAJJRAMATTI_220	16:03	16:04	0:01	HAND TRIPPED
1040	28-Mar-2021	BAGALKOT	220	VAJJRAMATTI-KAVATAGI LIS	KAVATAGI LIS_220 STATION NOT AFFECTED VAJJRAMATTI_220	16:26	16:28	0:02	HAND TRIPPED
1041	28-Mar-2021	BAGALKOT	220	VAJJRAMATTI-MAAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
1042	28-Mar-2021	BAGALKOT	220	VAJJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1043	28-Mar-2021	BENGALURU	66	AGALAKOTE - KEMPAHALI	AGALAKOTE, MATHIKERE	18:15	18:28	00:13	MAIN SUPPLY FAILURE
1044	28-Mar-2021	BENGALURU	66	AGALAKOTE - MATHIKERE	MATHIKERE	18:15	18:42	00:27	MAIN SUPPLY FAILURE
1045	28-Mar-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:43	13:52	00:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1046	28-Mar-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	14:01	14:15	00:14	LINE FAULT
1047	28-Mar-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	12:01	12:11	00:09	LINE FAULT
1048	28-Mar-2021	BENGALURU	66	ELECTRONIC CITY - ELCTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	21:36	22:02	00:26	MAIN SUPPLY FAILURE
1049	28-Mar-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGANATHPURA 220	ELECTRONIC CITY P2 S1	21:36	22:30	00:54	LINE FAULT
1050	28-Mar-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	13:45	13:55	00:10	LINE CLEAR AVAILED
1051	28-Mar-2021	BENGALURU	66	HV1	DALASNUR	07:45	07:50	00:04	LINE CLEAR AVAILED
1052	28-Mar-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	22:10	22:15	00:05	LINE CLEAR AVAILED
1053	28-Mar-2021	BENGALURU	66	HV2	TEMAGONDALU	13:21	13:48	00:26	TRANSFORMER FAULT
1054	28-Mar-2021	BENGALURU	66	HV2	TEMAGONDALU	14:11	14:35	00:23	TRANSFORMER FAULT
1055	28-Mar-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	11:57	12:03	00:06	LINE CLEAR AVAILED
1056	28-Mar-2021	BENGALURU	66	HV3	JIGANI LINK ROAD	12:35	12:40	00:05	LINE CLEAR AVAILED
1057	28-Mar-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	06:22	06:28	00:06	LINE FAULT
1058	28-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:33	13:43	00:09	LINE FAULT
1059	28-Mar-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	14:41	18:08	03:27	LOAD CURTAILMENT
1060	28-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)	20:28(28/03/2021)	534:37HRS	LINE CHARGED
1061	28-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
1062	28-Mar-2021	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	10:34	10:46	00:12	LINE FAULT
1063	28-Mar-2021	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	MAGADI 220	18:10	19:17	01:07	LINE FAULT
1064	28-Mar-2021	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66	16:30	16:45	00:15	MAIN SUPPLY FAILURE
1065	28-Mar-2021	GULBARGA	110	ALIPUR-MUNIRABAD	MUNIRABAD_110	23:40	23:54	00:14	LINE FAULT
1066	28-Mar-2021	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA	19:15	19:20	00:05	MAIN SUPPLY FAILURE
1067	28-Mar-2021	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA	22:50	22:55	00:05	MAIN SUPPLY FAILURE
1068	28-Mar-2021	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110,HIREGONNA GAR_110,HANUMANAL_110	11:20	11:35	00:15	MAIN SUPPLY FAILURE
1069	28-Mar-2021	GULBARGA	110	HV1	NIRNA_110	13:35	13:40	00:05	TRANSFORMER FAULT
1070	28-Mar-2021	GULBARGA	110	HV1	CHICKSUGUR_110	10:28	15:30	05:02	TRANSFORMER FAULT
1071	28-Mar-2021	GULBARGA	110	HV2	KAMPLI_GLB_110	08:51	08:59	00:08	TRANSFORMER FAULT
1072	28-Mar-2021	GULBARGA	110	HV2	MANVI_110	01:02	01:12	00:10	TRANSFORMER FAULT
1073	28-Mar-2021	GULBARGA	110	HV2	MANVI_110	08:40	08:50	00:10	TRANSFORMER FAULT
1074	28-Mar-2021	GULBARGA	110	KAMPLI-MUNIRABAD	KAMPLI_GLB_110	09:30	09:40	00:10	MAIN SUPPLY FAILURE
1075	28-Mar-2021	GULBARGA	110	KAMPLI-MUNIRABAD	KAMPLI_GLB_110	09:50	10:01	00:11	MAIN SUPPLY FAILURE
1076	28-Mar-2021	GULBARGA	110	KAMPLI-MUNIRABAD	KAMPLI_GLB_110	10:15	10:25	00:10	MAIN SUPPLY FAILURE
1077	28-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	22:49	22:54	00:05	LINE FAULT
1078	28-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	23:14	23:21	00:07	LINE FAULT
1079	28-Mar-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)			NFBC ISSUED
1080	28-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHPUR_110 IDLE LINE	10:05(25.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1081	28-Mar-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	04:38	04:49	00:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1082	28-Mar-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	18:44	18:52	00:08	LINE FAULT
1083	28-Mar-2021	GULBARGA	400	BTPS-JSWVL	BTPS_400	12:37(28.03.21)			LINE CLEAR AVAILED
1084	28-Mar-2021	GULBARGA	400	JVSL-BTPS	JVSL_400	13:30	20:30	07:00	NFBC ISSUED
1085	28-Mar-2021	GULBARGA	400	JVSL-GUTTUR	JVSL_400	14:20	23:30	09:10	NFBC ISSUED
1086	28-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:06	13:48	03:42	LINE CLEAR AVAILED
1087	28-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	09:59	14:08	04:09	LINE CLEAR AVAILED
1088	28-Mar-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	15:10	15:33	00:23	LINE FAULT
1089	28-Mar-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	08:44	08:48	00:04	HAND TRIPPED
1090	28-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:06	14:10	04:04	LINE CLEAR AVAILED
1091	28-Mar-2021	HASSAN	66	HV1	BALEHONNUR_66	19:36	20:10	00:34	TRANSFORMER FAULT
1092	28-Mar-2021	HASSAN	66	HV1	BALEHONNUR_66	20:18	20:46	00:28	TRANSFORMER FAULT
1093	28-Mar-2021	HASSAN	66	HV1	HANGARANAHALY_66	18:05	18:37	00:32	HAND TRIPPED
1094	28-Mar-2021	HASSAN	66	HV3	BALEHONNUR_66	20:18(28.02.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1095	28-Mar-2021	HASSAN	66	HV3	BALEHONNUR_66	19:36	20:18	00:42	TRANSFORMER FAULT
1096	28-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1097	28-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1098	28-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:02	14:11	04:09	LINE CLEAR AVAILED
1099	28-Mar-2021	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	09:13	15:15	06:02	LINE CLEAR AVAILED
1100	28-Mar-2021	HASSAN	110	HV2	KONAJE_110	13:14	13:21	00:07	TRANSFORMER FAULT
1101	28-Mar-2021	HASSAN	110	HV2	KONAJE_110	19:51	19:54	00:03	TRANSFORMER FAULT
1102	28-Mar-2021	HASSAN	110	HV2	KUNDAPURA_110	10:26	11:01	00:35	LINE CLEAR AVAILED
1103	28-Mar-2021	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	08:25	15:21	06:56	LINE CLEAR AVAILED
1104	28-Mar-2021	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	08:25	15:21	06:56	LINE CLEAR AVAILED
1105	28-Mar-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:17	11:27	00:10	LOAD CURTAILMENT
1106	28-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:26(26.02.2021)	14:31(28.02.2021)	52:04 hrs	LINE CHARGED
1107	28-Mar-2021	MYSURU	66	BOOKANAKERE-CHINKURALI	CHINAKURALI_66 BANANGADI_66	16:02	16:17	0:14	LINE FAULT
1108	28-Mar-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	13:20	17:55	4:35	LINE CLEAR AVAILED
1109	28-Mar-2021	MYSURU	66	HV2	SATHEGALA_66	18:27	18:44	0:16	TRANSFORMER FAULT
1110	28-Mar-2021	MYSURU	66	HV3	PONNAMPET_66	18:39	18:46	0:06	TRANSFORMER FAULT
1111	28-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	17:36 (27/03/2021)	7:15 (28/03/2021)	13:39 HRS	TRANSFORMER CHARGED
1112	28-Mar-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN,LINE FAULT
1113	28-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
1114	28-Mar-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	18:34	18:39	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1115	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	7:13	7:19	0:06	LINE FAULT
1116	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:47	10:52	0:05	LINE FAULT
1117	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:15	11:22	0:06	LINE FAULT
1118	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:41	11:51	0:10	LINE FAULT
1119	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	13:11	13:20	0:09	LINE FAULT
1120	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	14:38	14:48	0:10	LINE FAULT
1121	28-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	21:49	21:55	0:05	LINE FAULT
1122	28-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:12	18:26	12:14	LINE CLEAR AVAILED
1123	28-Mar-2021	TUMKUR	66	ANTHRASANAHALI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	11:59	13:22	1:22	LINE FAULT
1124	28-Mar-2021	TUMKUR	66	CHITRADURGA 66KV-PANDARAHALLI 2	CHITRADURGA_66	13:37	13:58	0:20	HAND TRIPPED
1125	28-Mar-2021	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	17:12	17:20	0:07	LINE FAULT
1126	28-Mar-2021	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	17:34	17:43	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1127	28-Mar-2021	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	18:10	18:51	0:40	LINE FAULT
1128	28-Mar-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	6:14	6:32	0:17	HAND TRIPPED
1129	28-Mar-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	6:34	6:38	0:04	HAND TRIPPED
1130	28-Mar-2021	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66 ,SASALUHALLA_66	18:12	18:42	0:29	MAIN SUPPLY FAILURE
1131	28-Mar-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	18:12	18:42	0:29	MAIN SUPPLY FAILURE
1132	28-Mar-2021	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	13:27	13:29	0:01	MAIN SUPPLY FAILURE
1133	28-Mar-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:15	13:25	0:10	MAIN SUPPLY FAILURE
1134	28-Mar-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66 , BASAVAPATNA_66	14:03	14:13	0:10	LINE FAULT
1135	28-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	8:44	8:46	0:02	LINE FAULT
1136	28-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	8:59	9:03	0:03	LINE FAULT
1137	28-Mar-2021	TUMKUR	66	TR-1	GULIGENAHALLI_66	21:03	21:05	0:01	TRANSFORMER FAULT
1138	28-Mar-2021	TUMKUR	66	TR-1	GULIGENAHALLI_66	10:02	10:21	0:19	TRANSFORMER FAULT
1139	28-Mar-2021	TUMKUR	66	TR-1	HDPURA_66	15:06	15:08	0:01	TRANSFORMER FAULT
1140	28-Mar-2021	TUMKUR	66	TR-1	HDPURA_66	16:04	16:06	0:02	TRANSFORMER FAULT
1141	28-Mar-2021	TUMKUR	66	TR-1	HDPURA_66	16:05	18:55	2:50	TRANSFORMER FAULT
1142	28-Mar-2021	TUMKUR	66	TR-2	BENNEHALLI_66	1:22	1:33	0:11	TRANSFORMER FAULT
1143	28-Mar-2021	TUMKUR	66	TR-2	HOLALKERE_66	23:35	23:37	0:01	TRANSFORMER FAULT
1144	28-Mar-2021	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	8:32	8:43	0:10	TRANSFORMER FAULT
1145	28-Mar-2021	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG	UCHCHANGIDURGA_66	16:05	17:27	1:21	LINE FAULT
1146	28-Mar-2021	TUMKUR	110	TR-2	BANDIHALLI_110	17:14	17:39	0:24	HAND TRIPPED
1147	28-Mar-2021	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	13:13	13:53	0:40	LINE FAULT
1148	28-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	16:28	16:52	0:23	LINE FAULT
1149	28-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	13:49	19:15	5:26	LINE FAULT
1150	28-Mar-2021	TUMKUR	220	DAVANGERE SRS- HONNALLI	HONNALLI_220	13:49	14:20	0:31	HAND TRIPPED
1151	29-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
1152	29-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
1153	29-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
1154	29-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
1155	29-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
1156	29-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
1157	29-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)	11:32 (29.03.2021)	1989:00HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1158	29-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1159	29-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1160	29-Mar-2021	BAGALKOT	220	MAAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1161	29-Mar-2021	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1162	29-Mar-2021	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
1163	29-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1164	29-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1165	29-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
1166	29-Mar-2021	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1167	29-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1168	29-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN,LINE FAULT
1169	29-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1170	29-Mar-2021	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1171	29-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA1	STATION NOT AFFECTED HAVERI_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1172	29-Mar-2021	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	10:56 (27.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1173	29-Mar-2021	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	18:03 (28.03.2021)	17:36 (29.03.2021)	23:33hrs	LINE CHARGED
1174	29-Mar-2021	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	17:23 (28.03.2021)	12:44 (29.03.2021)	19:21hrs	LINE CHARGED
1175	29-Mar-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	16:04 (28.03.2021)	13:47 (29.03.2021)	21:43hrs	LINE CHARGED
1176	29-Mar-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	16:04 (28.03.2021)	13:45 (29.03.2021)	21:41hrs	LINE CHARGED
1177	29-Mar-2021	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	03:26	03:46	0:20	LINE FAULT
1178	29-Mar-2021	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	AMBEWADI_220	15:10	16:27	1:17	LINE CLEAR AVAILED
1179	29-Mar-2021	BAGALKOT	110	BANAHATTI- JAMAKHANDI(NAVALAGI)	NAVALAGI_110	21:20	21:40	0:20	LINE FAULT
1180	29-Mar-2021	BAGALKOT	110	DAMBAL-MUNDARGI 1	MUNDARAGI_110	08:31	09:40	1:09	LINE FAULT
1181	29-Mar-2021	BAGALKOT	110	DAMBAL-MUNDARGI 2(GADAG)	MUNDARAGI_110	08:31	09:51	1:20	LINE FAULT
1182	29-Mar-2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	17:06	18:44	1:38	LINE FAULT
1183	29-Mar-2021	BAGALKOT	110	GADAG-DAMBAL	STATION NOT AFFECTED GADAG_220	08:31	08:47	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1184	29-Mar-2021	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA 220	04:28	4:36	0:08	LINE FAULT
1185	29-Mar-2021	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,KAMATAGI_3 3,SHIRUR 33	14:26	15:18	0:52	TRANSFORMER FAULT
1186	29-Mar-2021	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	9:05	9:14	0:09	TRANSFORMER FAULT
1187	29-Mar-2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMEENAGAD_33, KARADI 33,MYTRA SOLAR 33	13:07	13:13	0:06	TRANSFORMER FAULT
1188	29-Mar-2021	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI 110	21:28	22:26	0:58	HAND TRIPPED
1189	29-Mar-2021	BAGALKOT	110	110/33KV,HV2	MUDEDEBIHAL_110,DAVALAGI_33, NALATWADA 33	11:52	12:03	0:11	TRANSFORMER FAULT
1190	29-Mar-2021	BAGALKOT	110	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI 220	17:52	20:10	2:18	LINE FAULT
1191	29-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI 110	19:52	20:07	0:15	LINE CLEAR AVAILED
1192	29-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI 110	21:27	22:11	0:44	LINE CLEAR AVAILED
1193	29-Mar-2021	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED MAHALINGAPUR 220	18:10 (28.03.2021)	00:50 (29.03.2021)	6:40hrs	TRANSFORMER CHARGED
1194	29-Mar-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED SADALAGA 110	09:01	09:11	0:10	HAND TRIPPED
1195	29-Mar-2021	BAGALKOT	110	HUBLI220-PH COMPOUND	STATION NOT AFFECTED HUBLI 220	11:38	12:08	0:30	HAND TRIPPED
1196	29-Mar-2021	BAGALKOT	110	RATHIHALLI-HIREKERUR	STATION NOT AFFECTED RATHIHALLI 110	13:20	13:26	0:06	LINE FAULT
1197	29-Mar-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RAIBAG 110	07:18	07:32	0:14	TRANSFORMER FAULT
1198	29-Mar-2021	BAGALKOT	110	PH COMPOUND-HUBLI220	STATION NOT AFFECTED PH COMPOUND 110	11:34	16:08	4:34	LINE CLEAR AVAILED
1199	29-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	16:11 (29.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1200	29-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTHAL 110	11:09	11:56	0:47	HAND TRIPPED
1201	29-Mar-2021	BENGALURU	66	HV1	ALLIMARADANAHALLI	08:56	09:24	00:28	TRANSFORMER FAULT
1202	29-Mar-2021	BENGALURU	66	HV2	BRIGADE METROPOLIS	16:15	16:20	00:05	LINE CLEAR AVAILED
1203	29-Mar-2021	BENGALURU	66	HV2	CHANDRA LAYOUT	11:04	11:06	00:02	LINE CLEAR AVAILED
1204	29-Mar-2021	BENGALURU	66	HV1	ELECTRONIC CITY	19:27	21:21	01:54	TRANSFORMER FAULT
1205	29-Mar-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	18:05	18:15	00:10	LOAD CHANGE OVER
1206	29-Mar-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	06:04	06:42	00:38	MAIN SUPPLY FAILURE
1207	29-Mar-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	10:00	10:03	00:03	LOAD CHANGE OVER
1208	29-Mar-2021	BENGALURU	66	ITI 220 - DRDO(EHT)	DRDO(EHT)	06:05	07:56	01:51	LINE FAULT
1209	29-Mar-2021	BENGALURU	66	HV2	ITI 220	10:53	12:05	01:12	LINE CLEAR AVAILED
1210	29-Mar-2021	BENGALURU	66	HV2	TELECOM LAYOUT	11:18	11:36	00:18	TRANSFORMER FAULT
1211	29-Mar-2021	BENGALURU	66	HV1	HUKUNDA	16:48	16:52	00:04	TRANSFORMER FAULT
1212	29-Mar-2021	BENGALURU	66	HV1	HUKUNDA	21:45	21:47	00:02	TRANSFORMER FAULT
1213	29-Mar-2021	BENGALURU	66	HV2	JIGANI LINK ROAD	13:30	13:37	00:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1214	29-Mar-2021	BENGALURU	66	HV1	MITTEMARI 220	11:00	11:04	00:04	TRANSFORMER FAULT
1215	29-Mar-2021	BENGALURU	66	HV1	MITTEMARI 220	12:00	12:05	00:04	TRANSFORMER FAULT
1216	29-Mar-2021	BENGALURU	66	HV1	MITTEMARI 220	14:19	15:37	01:18	LINE CLEAR AVAILED
1217	29-Mar-2021	BENGALURU	66	HV1	SOMENAHALLI	10:15	11:22	01:07	LINE CLEAR AVAILED
1218	29-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	11:28	11:41	00:12	LINE FAULT
1219	29-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:28	11:39	00:10	LINE FAULT
1220	29-Mar-2021	BENGALURU	66	GUNDLU KOTTUR	GUNDLU KOTTUR - GOWRIBIDANUR 220	17:02	18:06	01:03	LINE CLEAR AVAILED
1221	29-Mar-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	15:11	15:24	00:12	LINE FAULT
1222	29-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	00:05	00:17	00:12	LINE FAULT
1223	29-Mar-2021	BENGALURU	66	HV2	SRINIVASAPURA	13:06	13:19	0:13	TRANSFORMER FAULT
1224	29-Mar-2021	BENGALURU	66	SRINIVASAPURA - CHINTAMANI	SRINIVASAPURA	13:06	13:19	0:13	LINE FAULT
1225	29-Mar-2021	BENGALURU	66	VIDYANAGAR - BIAL BEGUR 220	VIDYANAGAR, HENNUR CROSS	06:04	06:24	00:20	LINE FAULT
1226	29-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
1227	29-Mar-2021	BENGALURU	220	KIADB DB PURA 220 - DB PURA 220	NO STATION AFFECTED	13:05 (29-03-2021)			LINE OPEN,LINE FAULT
1228	29-Mar-2021	GULBARGA	400	BTPS-JSWVL	BTPS_400	12:37(28.03.2021)			LINE CLEAR AVAILED
1229	29-Mar-2021	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	12:45	13:07	00:22	LINE FAULT
1230	29-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	00:03	00:10	00:07	LINE FAULT
1231	29-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	00:20	00:25	00:05	LINE FAULT
1232	29-Mar-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	05:00	05:09	00:09	LINE FAULT
1233	29-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHPUR_110 IDLE LINE	10:05(25.03.2021)	10:45(29.03.2021)	96:40HRS	LINE CHARGED
1234	29-Mar-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)			NFBC ISSUED
1235	29-Mar-2021	GULBARGA	110	HV3	HANUMASAGAR_110	15:20	16:15	00:55	TRANSFORMER FAULT
1236	29-Mar-2021	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	06:15	06:25	00:10	LINE FAULT
1237	29-Mar-2021	GULBARGA	110	HV3(IDLE)	CHINCHOLI_110	06:15	06:45	00:30	TRANSFORMER FAULT
1238	29-Mar-2021	GULBARGA	110	HV1	CHICKSUGUR_110	08:15	13:48	05:33	LINE CLEAR AVAILED
1239	29-Mar-2021	GULBARGA	110	GABUR-RAICHUR	GABUR_110	00:05	00:21	00:16	MAIN SUPPLY FAILURE
1240	29-Mar-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	09:01	09:05	00:04	LINE FAULT
1241	29-Mar-2021	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	19:20	19:35	00:15	LINE FAULT
1242	29-Mar-2021	GULBARGA	110	ALIPUR-TORANGALLU	TORANGALLU_110	19:20	19:40	00:20	LINE FAULT
1243	29-Mar-2021	GULBARGA	110	HV3	HATTI_110	19:40	20:13	00:33	TRANSFORMER FAULT
1244	29-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1245	29-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1246	29-Mar-2021	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	13:45 (28.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1247	29-Mar-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	17:23 (29.03.2021)			LINE OPEN,LINE FAULT
1248	29-Mar-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	18:55 (28.03.2021)	0:33 (29.03.2021)	5:37 hrs	LINE CHARGED
1249	29-Mar-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	18:55 (28.03.2021)	0:33 (29.03.2021)	5:37 hrs	LINE CHARGED
1250	29-Mar-2021	HASSAN	220	HV1	GOPALAPURA_220	10:23(28.03.2021)	7:00 (29.03.2021)	20:36 hrs	TRANSFORMER CHARGED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1251	29-Mar-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	09:03	18:18	09:15	LINE FAULT
1252	29-Mar-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:23	18:10	04:47	LINE FAULT
1253	29-Mar-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:23	18:10	04:47	LINE FAULT
1254	29-Mar-2021	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	07:21	12:16	04:55	LINE CLEAR AVAILED
1255	29-Mar-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	20:52	22:00	01:08	LINE CLEAR AVAILED
1256	29-Mar-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	20:52	22:28	01:36	LINE CLEAR AVAILED
1257	29-Mar-2021	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	07:21	12:23	05:02	LINE CLEAR AVAILED
1258	29-Mar-2021	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	21:04	21:59	00:55	LINE FAULT
1259	29-Mar-2021	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	21:12	22:08	00:56	LINE FAULT
1260	29-Mar-2021	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	21:27	22:00	00:33	LINE FAULT
1261	29-Mar-2021	HASSAN	110	HV1	KONAJE_110	10:40	10:45	00:05	HAND TRIPPED
1262	29-Mar-2021	HASSAN	110	HV1	KONAJE_110	14:24	14:27	00:03	MAIN SUPPLY FAILURE
1263	29-Mar-2021	HASSAN	110	HV2	KONAJE_110	10:39	10:46	00:07	HAND TRIPPED
1264	29-Mar-2021	HASSAN	110	HV2	KONAJE_110	14:27	14:28	00:01	MAIN SUPPLY FAILURE
1265	29-Mar-2021	HASSAN	110	HV3	KONAJE_110	10:39	10:45	00:06	HAND TRIPPED
1266	29-Mar-2021	HASSAN	110	HV3	KONAJE_110	14:22	14:28	00:06	MAIN SUPPLY FAILURE
1267	29-Mar-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	21:07	22:07	01:00	LINE FAULT
1268	29-Mar-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	08:01	18:30	10:29	LINE CLEAR AVAILED
1269	29-Mar-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	08:01	18:30	10:29	LINE CLEAR AVAILED
1270	29-Mar-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:52	14:20	03:28	NFBC ISSUED
1271	29-Mar-2021	HASSAN	110	HV1	SORABA_110	16:22	18:31	02:09	LINE CLEAR AVAILED
1272	29-Mar-2021	HASSAN	66	HV2	BAGUR_66	10:33	10:52	00:19	TRANSFORMER FAULT
1273	29-Mar-2021	HASSAN	66	HV2	BELUR_66	16:29	16:40	00:11	TRANSFORMER FAULT
1274	29-Mar-2021	HASSAN	66	HV1	HANBALU_66	14:42	16:30	01:48	LINE CLEAR AVAILED
1275	29-Mar-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:00	17:57	00:57	LINE CLEAR AVAILED
1276	29-Mar-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	17:00	17:57	00:57	LINE CLEAR AVAILED
1277	29-Mar-2021	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	13:13	13:33	00:20	LINE CLEAR AVAILED
1278	29-Mar-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	17:00	17:56	00:56	MAIN SUPPLY FAILURE
1279	29-Mar-2021	MYSURU	66	HV1	BILIKERE_66	13:15	14:40	1:24	LINE CLEAR AVAILED
1280	29-Mar-2021	MYSURU	66	G UKKADA -SR PATNA	SRIRANGAPATNA_66	12:54	13:01	0:06	LINE FAULT
1281	29-Mar-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	19:54	19:59	0:04	LINE FAULT
1282	29-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:26	18:50	12:23	LINE CLEAR AVAILED
1283	29-Mar-2021	MYSURU	66	HV1	K_HONNALGERE_66	20:20	20:30	0:10	TRANSFORMER FAULT
1284	29-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	7:13	13:05	5:52	LINE CLEAR AVAILED
1285	29-Mar-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	1:37	1:42	0:05	LINE FAULT
1286	29-Mar-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	7:50	11:52	4:02	LINE CLEAR AVAILED
1287	29-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:31	10:38	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1288	29-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALI_66	11:36	11:41	0:04	LINE FAULT
1289	29-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALI_66	12:43	12:48	0:05	LINE FAULT
1290	29-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALI_66	15:58	16:05	0:07	LINE FAULT
1291	29-Mar-2021	MYSURU	220	HV1	BEGUR_220	8:06	8:22	0:16	TRANSFORMER FAULT
1292	29-Mar-2021	MYSURU	66	220 BEGUR-BEGUR-1	NO STATION EFFECTED	14:14	14:38	0:24	NFBC ISSUED
1293	29-Mar-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN,LINE FAULT
1294	29-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
1295	29-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	11:43:52 PM(29.03.2021)			LINE OPEN,LINE FAULT
1296	29-Mar-2021	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66	11:43:53 PM(29.03.2021)			MAIN SUPPLY FAILURE
1297	29-Mar-2021	TUMKUR	66	TR-2	SASALUHALLA_66	10:18:48 AM(29.03.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1298	29-Mar-2021	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	12:34	13:02	0:28	LINE CLEAR AVAILED
1299	29-Mar-2021	TUMKUR	220	HONNALLI 220kv- SHIMOGA 220kv	HONNALLI_220	9:34	12:02	2:27	LINE CLEAR AVAILED
1300	29-Mar-2021	TUMKUR	220	TR-2	MADHUGIRI_220	15:49	15:51	0:02	TRANSFORMER FAULT
1301	29-Mar-2021	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	11:14	16:58	5:43	LOAD CURTAILMENT
1302	29-Mar-2021	TUMKUR	110	TR-1	BIDARE_110	1:03	1:07	0:04	TRANSFORMER FAULT
1303	29-Mar-2021	TUMKUR	110	TR-1	SAMPIGE_110	12:35	12:42	0:06	TRANSFORMER FAULT
1304	29-Mar-2021	TUMKUR	110	TR-1	SHETYKERE_110	14:45	14:49	0:03	TRANSFORMER FAULT
1305	29-Mar-2021	TUMKUR	66	TR-2	BENNEHALLI_66	20:50	21:06	0:16	TRANSFORMER FAULT
1306	29-Mar-2021	TUMKUR	66	TR-2	BENNEHALLI_66	23:01	23:06	0:05	TRANSFORMER FAULT
1307	29-Mar-2021	TUMKUR	66	TR-2	BENNEHALLI_66	23:38	23:43	0:05	TRANSFORMER FAULT
1308	29-Mar-2021	TUMKUR	66	TR-1	CHANNAGIRI_66(LINGADHALLI)	12:22	12:27	0:05	TRANSFORMER FAULT
1309	29-Mar-2021	TUMKUR	66	TR-1	CHANNAGIRI_66(LINGADHALLI)	18:06	18:10	5:37	TRANSFORMER FAULT
1310	29-Mar-2021	TUMKUR	66	TR-1	CHITRADURGA_66	8:52	9:10	3:35	LINE CLEAR AVAILED
1311	29-Mar-2021	TUMKUR	66	TR-2	CHITRADURGA_66	8:52	9:10	9:18	LINE CLEAR AVAILED
1312	29-Mar-2021	TUMKUR	66	TR-2	DAVANAGERE_66	14:15	16:26	2:10	LINE CLEAR AVAILED
1313	29-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:50	6:27	1:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1314	29-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:32	12:38	0:06	LINE FAULT
1315	29-Mar-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:56	17:07	0:10	LINE FAULT
1316	29-Mar-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	4:52	5:11	0:18	MAIN SUPPLY FAILURE
1317	29-Mar-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	5:11	5:13	0:01	HAND TRIPPED
1318	29-Mar-2021	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:20	9:34	0:14	LINE FAULT
1319	29-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	9:08	9:18	0:10	LINE FAULT
1320	29-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	9:26	9:33	0:06	LINE FAULT
1321	29-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	9:35	9:38	0:03	LINE FAULT
1322	29-Mar-2021	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	10:09	10:11	0:02	LINE FAULT
1323	29-Mar-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:55	9:07	0:12	LINE FAULT
1324	29-Mar-2021	TUMKUR	66	TR-1	LINGDHALLI_66(SHIMOGA)	11:28	11:31	0:02	TRANSFORMER FAULT
1325	29-Mar-2021	TUMKUR	66	TR-1	LINGDHALLI_66(SHIMOGA)	12:51	12:56	0:05	TRANSFORMER FAULT
1326	29-Mar-2021	TUMKUR	66	TR-1	LINGDHALLI_66(SHIMOGA)	13:10	13:12	0:02	TRANSFORMER FAULT
1327	29-Mar-2021	TUMKUR	66	TR-1	LINGDHALLI_66(SHIMOGA)	17:05	17:59	0:54	MAIN SUPPLY FAILURE
1328	29-Mar-2021	TUMKUR	66	TR-2	LINGDHALLI_66(SHIMOGA)	17:03	17:59	0:55	MAIN SUPPLY FAILURE
1329	29-Mar-2021	TUMKUR	66	TR-2	LINGDHALLI_66(SHIMOGA)	18:07	18:08	0:01	MAIN SUPPLY FAILURE
1330	29-Mar-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	7:49	8:53	1:03	LINE CLEAR AVAILED
1331	29-Mar-2021	TUMKUR	66	TR-1	SASALUHALLA_66	17:27	17:30	0:03	TRANSFORMER FAULT
1332	29-Mar-2021	TUMKUR	66	TR-1	SOKKE_66	20:58	21:07	0:08	TRANSFORMER FAULT