

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 06.08.2019 TO 12.08.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	6-Aug-19	BAGALKOT	110	110/11KV,HV-2	AMBEWADI_220	8:48	8:50	0:02	TRANSFORMER FAULT
2	6-Aug-19	BAGALKOT	110	ANKOLA-KUMATA2	KUMATA_110	9:25	9:30	0:05	HAND TRIPPED
3	6-Aug-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	14:56	15:25	0:29	HAND TRIPPED
4	6-Aug-19	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	6:59	7:20	0:21	LOAD CURTAILMENT
5	6-Aug-19	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	13:21	23:59	10:38	LINE CLEAR AVAILED
6	6-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	13:10	23:59	10:49	LINE CLEAR AVAILED
7	6-Aug-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	6:58	7:54	0:56	LINE FAULT
8	6-Aug-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	7:20	7:48	0:28	HAND TRIPPED
9	6-Aug-19	BAGALKOT	110	110/11KV, HV2	TODALBAGI_110	11:35	12:05	0:30	LINE CLEAR AVAILED
10	6-Aug-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	9:34	23:59	14:25	LINE FAULT
11	6-Aug-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	10:37	23:59	13:22	LINE FAULT
12	6-Aug-19	BAGALKOT	110	SIRISI220-KAVALWADA	KAVALWADA_110	9:01	23:59	14:58	LINE FAULT
13	6-Aug-19	BAGALKOT	110	110/11KV, HV4	HUBLI_220	13:28	22:19	8:51	TRANSFORMER FAULT
14	6-Aug-19	BAGALKOT	110	110/11KV, HV1	SIRSI_110	7:11	7:30	0:19	TRANSFORMER FAULT
15	6-Aug-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	8:45	9:00	0:15	LINE FAULT
16	6-Aug-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	9:43	9:50	0:07	TRANSFORMER FAULT
17	6-Aug-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	11:39	11:45	0:06	TRANSFORMER FAULT
18	6-Aug-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	7:57	19:55	11:58	LINE FAULT
19	6-Aug-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:28	6:55	6:27	LINE CLEAR AVAILED
20	6-Aug-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	13:32	19:11	5:39	LINE CLEAR AVAILED
21	6-Aug-19	BAGALKOT	110	SIRISI-KUMTA1	KUMTA_110	14:25	15:02	0:37	LINE FAULT
22	6-Aug-19	BAGALKOT	110	SIRISI-KUMTA1	KUMTA_110	15:06	15:08	0:02	HAND TRIPPED
23	6-Aug-19	BENGALURU	66	HV2	CHANDAPURA	11:45	12:05	0:19	LINE CLEAR AVAILED
24	6-Aug-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	15:20	15:30	0:10	TRANSFORMER FAULT
25	6-Aug-19	BENGALURU	66	HV2	HOSKOTE 66	2:35	2:44	0:09	TRANSFORMER FAULT
26	6-Aug-19	BENGALURU	66	HV1	VIJAYAPURA	15:20	15:50	0:30	LINE CLEAR AVAILED
27	6-Aug-19	BENGALURU	66	HV3	YERANDANAHALLI 220	21:00	21:10	0:10	TRANSFORMER FAULT
28	6-Aug-19	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	0:07	1:45	1:38	LINE FAULT
29	6-Aug-19	BENGALURU	66	GOKULA - HMT(EHT)	HMT(EHT)	15:18	15:40	0:22	LOAD CHANGEOVER
30	6-Aug-19	BENGALURU	66	ADUGODI - JAYADEVA	ADUGODI, BOSCH(EHT)	23:48	23:57	0:09	LINE CLEAR AVAILED
31	6-Aug-19	GULBARGA	220	MALLAT-RTPS	MALLAT_220	9:10	16:50	7:40	LINE CLEAR AVAILED
32	6-Aug-19	GULBARGA	220	SINDHANOOR-LINGASUGUR, LINGAPUR	SIDHANOOR_220	15:30	15:40	0:10	LINE FAULT
33	6-Aug-19	GULBARGA	220	RTPS-LINGSUGUR3	LINGASUGUR_220	0:00	17:00	17:00	LINE FAULT
34	6-Aug-19	GULBARGA	110	SINDANOOR-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	2:45	2:55	0:10	LINE FAULT
35	6-Aug-19	GULBARGA	110	SINDANOOR-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	2:45	2:55	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
36	6-Aug-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS WATER WORKS	15:03	15:10	0:07	LINE FAULT
37	6-Aug-19	GULBARGA	110	HUMNABAD-MARAGUTTI	MARAGUTTI_110,MAHAGOAN_110	6:12	6:24	0:12	LINE FAULT
38	6-Aug-19	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66	6:13	6:25	0:12	LINE CLEAR AVAILED
39	6-Aug-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	9:19	9:31	0:12	LINE CLEAR AVAILED
40	6-Aug-19	GULBARGA	66	ITTAGI-CLEANMAX1	ITTAGI_220	9:30	9:41	0:11	LINE CLEAR AVAILED
41	6-Aug-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	11:31	11:39	0:08	LINE CLEAR AVAILED
42	6-Aug-19	GULBARGA	66	HANSI-KUDLIGI	HANASI_66	15:15	16:05	0:50	LINE FAULT
43	6-Aug-19	GULBARGA	66	HV1	HANASI_66	15:15	16:15	1:00	TRANSFORMER FAULT
44	6-Aug-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:01	12:08	2:07	LINE CLEAR AVAILED
45	6-Aug-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	0:00	12:22	12:22	LINE CLEAR AVAILED
46	6-Aug-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	18:00	18:12	0:12	LINE FAULT
47	6-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	7:11	9:35	2:24	NFBC ISSUED
48	6-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	12:15	17:35	5:20	NFBC ISSUED
49	6-Aug-19	HASSAN	220	HV1	MRSMSG_220	2:35	10:47	8:12	LINE CLEAR AVAILED
50	6-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	1:59	23:59	22:00	LINE FAULT
51	6-Aug-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	1:47	6:26	4:39	MAIN SUPPLY FAILURE
52	6-Aug-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	16:04	19:34	3:30	LINE FAULT
53	6-Aug-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:56	17:06	6:10	LINE CLEAR AVAILED
54	6-Aug-19	HASSAN	220	VARAH1-KEMAR2	varahi_gen	10:02	12:08	2:06	NFBC ISSUED
55	6-Aug-19	HASSAN	220	VARAH1-KEMAR2	varahi_gen	18:01	18:13	0:12	LINE FAULT
56	6-Aug-19	HASSAN	220	VARAH1-KEMAR3	varahi_gen	0:00	12:22	12:22	LINE FAULT
57	6-Aug-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	1:47	6:27	4:40	MAIN SUPPLY FAILURE
58	6-Aug-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	16:05	19:34	3:29	LINE FAULT
59	6-Aug-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	18:19	19:25	1:06	LINE CLEAR AVAILED
60	6-Aug-19	HASSAN	110	HV4	MRSMSG_220	2:24	2:49	0:25	TRANSFORMER FAULT
61	6-Aug-19	HASSAN	110	HV4	MRSMSG_220	4:59	12:41	7:42	TRANSFORMER FAULT
62	6-Aug-19	HASSAN	110	LV1	MRSMSG_220	2:02	10:48	8:46	LINE CLEAR AVAILED
63	6-Aug-19	HASSAN	110	SS2	MRSMSG_220	4:45	5:29	0:44	LINE FAULT
64	6-Aug-19	HASSAN	110	HV1	AJJAMPURA_110	13:55	15:15	1:20	LINE CLEAR AVAILED
65	6-Aug-19	HASSAN	110	HV2	ANANDAPURA_110	20:39	21:11	0:32	LINE CLEAR AVAILED
66	6-Aug-19	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	20:38	21:22	0:44	LINE FAULT
67	6-Aug-19	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	4:45	5:39	0:54	LINE FAULT
68	6-Aug-19	HASSAN	110	HV3	BANTWAL_110	11:06	12:12	1:06	LINE CLEAR AVAILED
69	6-Aug-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	18:20	19:25	1:05	NFBC ISSUED
70	6-Aug-19	HASSAN	110	HV1	JAVAGAL-110	11:18	15:42	4:24	LINE CLEAR AVAILED
71	6-Aug-19	HASSAN	110	HV1	JOG_110	11:19	12:37	1:18	LINE CLEAR AVAILED
72	6-Aug-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:45	13:45	2:00	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
73	6-Aug-19	HASSAN	110	HV1	MANIPAL_110	11:12	12:42	1:30	LINE CLEAR AVAILED
74	6-Aug-19	HASSAN	110	HV2	MANIPAL_110	9:54	11:11	1:17	LINE CLEAR AVAILED
75	6-Aug-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	11:31	11:47	0:16	LINE FAULT
76	6-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:01	11:35	0:34	LINE CLEAR AVAILED
77	6-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	17:35	18:00	0:25	LINE CLEAR AVAILED
78	6-Aug-19	MYSORE	66	HV2	ADDIHALLI_66	10:59	11:48	0:48	LINE CLEAR AVAILED
79	6-Aug-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	10:26	11:19	0:53	LINE CLEAR AVAILED
80	6-Aug-19	MYSORE	66	HV1	HANAGODU_66	14:51	15:49	0:58	TRANSFORMER FAULT
81	6-Aug-19	MYSORE	66	HV1	K_HONNALGERE_66	14:10	14:25	0:15	HAND TRIPPED
82	6-Aug-19	MYSORE	66	HV2	K_HONNALGERE_66	14:10	14:26	0:15	HAND TRIPPED
83	6-Aug-19	MYSORE	66	HV2	KMDODDI_66	11:48	13:28	1:39	LINE CLEAR AVAILED
84	6-Aug-19	MYSORE	66	HV1	KMDODDI_66	13:15	16:06	2:51	LINE CLEAR AVAILED
85	6-Aug-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	16:24	18:27	2:02	LINE FAULT
86	6-Aug-19	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	7:40	13:33	5:52	LINE FAULT
87	6-Aug-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	16:24	18:08	1:43	LINE FAULT
88	6-Aug-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	16:24	18:27	2:03	LINE FAULT
89	6-Aug-19	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	16:24	18:08	1:44	LINE FAULT
90	6-Aug-19	TUMKUR	110	TR-1	KADEHALLI_110	12:49	13:58	1:08	LINE CLEAR AVAILED
91	6-Aug-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	12:44	13:06	0:22	LINE CLEAR AVAILED
92	6-Aug-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	7:12	7:18	0:06	TRANSFORMER FAULT
93	6-Aug-19	TUMKUR	66	TR-1	BAGUR_66	18:00	18:04	0:03	TRANSFORMER FAULT
94	6-Aug-19	TUMKUR	66	TR-1	CHANNAGIRI_66	5:14	5:28	0:13	TRANSFORMER FAULT
95	6-Aug-19	TUMKUR	66	TR-2	CHANNAGIRI_66	12:42	13:40	0:58	LINE CLEAR AVAILED
96	6-Aug-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	9:04	9:16	0:12	LINE FAULT
97	6-Aug-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	22:52	22:55	0:03	LINE FAULT
98	6-Aug-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	16:58	18:27	1:29	LINE CLEAR AVAILED
99	6-Aug-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	16:58	17:38	0:39	HAND TRIPPED
100	6-Aug-19	TUMKUR	66	TR-2	DAVANAGERE_66	8:22	8:25	0:02	TRANSFORMER FAULT
101	6-Aug-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:06	10:33	0:27	LINE FAULT
102	6-Aug-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	19:33	19:40	0:07	LINE FAULT
103	6-Aug-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	16:01	18:14	2:13	LINE CLEAR AVAILED
104	6-Aug-19	TUMKUR	66	TR-1	HIEMALLANAHOLE_66	19:05	22:59	3:53	MAIN SUPPLY FAILURE
105	6-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:32	13:48	3:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
106	6-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:32	13:35	3:03	LINE CLEAR AVAILED
107	6-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	8:36	13:35	4:58	LINE CLEAR AVAILED
108	6-Aug-19	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	14:15	14:45	0:30	LINE CLEAR AVAILED
109	6-Aug-19	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	14:04	14:54	0:50	LINE CLEAR AVAILED
110	6-Aug-19	TUMKUR	66	TR-1 & TR-2	HULIYURDURGA_66	13:54	14:45	0:51	LINE CLEAR AVAILED
111	6-Aug-19	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	11:08	18:42	7:33	LINE CLEAR AVAILED
112	6-Aug-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:00	12:16	0:16	LINE FAULT
113	6-Aug-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	13:14	17:53	4:39	MAIN SUPPLY FAILURE
114	6-Aug-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	13:14	13:19	0:05	MAIN SUPPLY FAILURE
115	6-Aug-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	18:33	22:54	4:21	LINE CLEAR AVAILED
116	6-Aug-19	TUMKUR	66	NEELAGUNDA 220KV-HULUVAGALU	HALUVAGALU_66	14:44	22:44	8:00	LINE FAULT
117	6-Aug-19	TUMKUR	66	TR-2	RANGANATHAPURA_66	9:17	9:24	0:07	LINE CLEAR AVAILED
118	7-Aug-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	17:32	23:59	6:27	LINE CLEAR AVAILED
119	7-Aug-19	BAGALKOT	110	GHATAPRABHA-PG HUNASYAAL	PG HUNASYAL_110	22:07	22:27	0:20	LINE FAULT
120	7-Aug-19	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	13:08	14:10	1:02	LINE CLEAR AVAILED
121	7-Aug-19	BAGALKOT	220	AMBEWDI-NARENDRA1	AMBEWADI_220	17:20	17:54	0:34	LINE FAULT
122	7-Aug-19	BAGALKOT	220	AMBEWDI-NARENDRA2	AMBEWADI_220	17:20	23:59	6:39	LINE FAULT
123	7-Aug-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	4:25	15:23	10:58	LINE FAULT
124	7-Aug-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	10:15	16:12	5:57	LINE CLEAR AVAILED
125	7-Aug-19	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	6:19	6:31	0:12	LINE FAULT
126	7-Aug-19	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	7:30	10:42	3:12	TRANSFORMER FAULT
127	7-Aug-19	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	17:21	17:54	0:33	LINE FAULT
128	7-Aug-19	BAGALKOT	220	NARENDRA-HAVERI1	NARENDRA_220	16:20	17:05	0:45	LINE FAULT
129	7-Aug-19	BAGALKOT	110	KULIGOD-MUDALAGI -GOKAK	KULIGOD_110	22:06	23:59	1:53	LINE FAULT
130	7-Aug-19	BENGALURU	66	HV2	KADUGODI	12:04	12:22	0:18	LINE CLEAR AVAILED
131	7-Aug-19	BENGALURU	66	HV1	KEMPANAHALLI	0:04	0:14	0:10	TRANSFORMER FAULT
132	7-Aug-19	BENGALURU	66	HV2	NALLIMARDANAHALLI	14:40	15:25	0:44	LINE CLEAR AVAILED
133	7-Aug-19	BENGALURU	66	HV2	SIDDLAGHATTA	11:55	12:00	0:05	LINE CLEAR AVAILED
134	7-Aug-19	BENGALURU	66	HV2	SIDDLAGHATTA	18:00	18:09	0:09	LINE CLEAR AVAILED
135	7-Aug-19	BENGALURU	220	HV2	YELAHANKA 220	9:05	9:22	0:17	TRANSFORMER FAULT
136	7-Aug-19	BENGALURU	66	YELAHANKA 220 - LINE 3	ESCORTS (EHT)	9:05	9:22	0:17	MAIN SUPPLY FAILURE
137	7-Aug-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	9:05	9:30	0:24	LINE FAULT
138	7-Aug-19	BENGALURU	66	YELAHANKA 220 - LINE 5	KHB	9:05	9:22	0:17	MAIN SUPPLY FAILURE
139	7-Aug-19	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	11:55	12:00	0:05	LOAD CHANGEVER
140	7-Aug-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	15:29	16:06	0:37	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
141	7-Aug-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	15:29	16:06	0:37	LINE CLEAR AVAILED
142	7-Aug-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	15:29	16:06	0:37	LINE CLEAR AVAILED
143	7-Aug-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:29	16:06	0:37	LINE CLEAR AVAILED
144	7-Aug-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1 & 2	TUBUGERE, CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:29	16:06	0:37	LINE CLEAR AVAILED
145	7-Aug-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	15:29	16:06	0:37	LINE CLEAR AVAILED
146	7-Aug-19	BENGALURU	66	JULUPALYA - MITTEMARI 220	JULUPALYA	18:03	18:15	0:12	LOAD CHANGEOVER
147	7-Aug-19	BENGALURU	66	SOMENAHALL - MITTEMARI 220	SOMENAHALLI	18:02	18:25	0:23	LOAD CHANGEOVER
148	7-Aug-19	GULBARGA	110	SINDHNOOR-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	3:07	3:19	0:12	LINE FAULT
149	7-Aug-19	GULBARGA	110	SINDHNOOR-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	3:47	3:58	0:11	LINE FAULT
150	7-Aug-19	GULBARGA	110	ITTAGI-SUZLON1	ITTAGI_220	1:15	2:44	1:29	LINE FAULT
151	7-Aug-19	GULBARGA	110	ITTAGI-SUZLON2	ITTAGI_220	1:25	2:44	1:19	LINE FAULT
152	7-Aug-19	GULBARGA	110	ITTAGI-RNWSLR2	ITTAGI_220	10:55	11:18	0:23	LINE CLEAR AVAILED
153	7-Aug-19	GULBARGA	110	ITTAGI-CLEANMAX2	ITTAGI_220	11:02	11:16	0:14	LINE CLEAR AVAILED
154	7-Aug-19	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	0:00	13:21	13:21	LINE FAULT
155	7-Aug-19	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	8:30	13:22	4:52	NFBC ISSUED
156	7-Aug-19	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	13:30	23:59	10:29	LINE CLEAR AVAILED
157	7-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	19:30	19:30	LINE CLEAR AVAILED
158	7-Aug-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	3:23	23:59	20:36	LINE CLEAR AVAILED
159	7-Aug-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	3:27	3:52	0:25	HAND TRIPPED
160	7-Aug-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	3:27	3:52	0:25	HAND TRIPPED
161	7-Aug-19	HASSAN	220	HV1	HASSAN_220	21:01	21:09	0:08	TRANSFORMER FAULT
162	7-Aug-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	12:04	12:28	0:24	LINE FAULT
163	7-Aug-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	19:10	19:49	0:39	LINE FAULT
164	7-Aug-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	21:25	23:59	2:34	LINE FAULT
165	7-Aug-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	7:42	13:35	5:53	LINE FAULT
166	7-Aug-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	18:36	23:59	5:23	LINE FAULT
167	7-Aug-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	17:10	22:50	5:40	LINE FAULT
168	7-Aug-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	18:52	19:20	0:28	LINE FAULT
169	7-Aug-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	19:20	23:59	4:39	LINE FAULT
170	7-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	1:18	6:32	5:14	MAIN SUPPLY FAILURE
171	7-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:26	13:28	0:02	LINE FAULT
172	7-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	9:47	13:28	3:41	LINE CLEAR AVAILED
173	7-Aug-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:04	12:27	0:23	LINE FAULT
174	7-Aug-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	19:10	19:48	0:38	LINE FAULT
175	7-Aug-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	21:25	23:59	2:34	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
176	7-Aug-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	9:47	13:28	3:41	LINE CLEAR AVAILED
177	7-Aug-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	7:40	18:35	10:55	LINE FAULT
178	7-Aug-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	20:25	23:59	3:34	LINE FAULT
179	7-Aug-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	7:45	13:16	5:31	LINE FAULT
180	7-Aug-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:46	18:28	3:42	LINE FAULT
181	7-Aug-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	18:28	20:25	1:57	LINE FAULT
182	7-Aug-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	7:42	13:35	5:53	LINE FAULT
183	7-Aug-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	18:38	23:59	5:21	LINE FAULT
184	7-Aug-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	17:10	22:54	5:44	LINE FAULT
185	7-Aug-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	18:52	23:59	5:07	LINE FAULT
186	7-Aug-19	HASSAN	110	MRSSHM-SS1	MRSMSG_220	15:06	15:52	0:46	LINE FAULT
187	7-Aug-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	15:15	15:16	0:01	LOAD CURTAILMENT
188	7-Aug-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:46	15:25	0:39	LOAD CURTAILMENT
189	7-Aug-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	7:45	8:00	0:15	LOAD CURTAILMENT
190	7-Aug-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	15:15	15:17	0:02	LOAD CURTAILMENT
191	7-Aug-19	HASSAN	110	HV2	HALADY_110	10:24	12:03	1:39	LINE CLEAR AVAILED
192	7-Aug-19	HASSAN	110	HV2	HALADY_110	19:40	19:51	0:11	TRANSFORMER FAULT
193	7-Aug-19	HASSAN	110	ALKOLA-LPH	ALKOLA_110	15:06	15:28	0:22	LINE FAULT
194	7-Aug-19	HASSAN	110	ALKOLA-MRS	ALKOLA_110	15:06	15:53	0:47	LINE FAULT
195	7-Aug-19	HASSAN	110	HV1	BAIKAMPADI_110	17:57	18:18	0:21	LOAD CURTAILMENT
196	7-Aug-19	HASSAN	110	HV2	BAIKAMPADI_110	17:57	18:18	0:21	LOAD CURTAILMENT
197	7-Aug-19	HASSAN	110	HV3	BAIKAMPADI_110	17:57	18:18	0:21	LOAD CURTAILMENT
198	7-Aug-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	18:52	19:27	0:35	LOAD CURTAILMENT
199	7-Aug-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	18:53	19:14	0:21	LINE FAULT
200	7-Aug-19	HASSAN	110	HV2	KARAYA_110	11:56	13:20	1:24	LINE CLEAR AVAILED
201	7-Aug-19	HASSAN	110	HV2	KARAYA_110	13:53	14:26	0:33	LINE CLEAR AVAILED
202	7-Aug-19	HASSAN	110	HV1	KAVOOR_220	9:17	12:34	3:17	LINE CLEAR AVAILED
203	7-Aug-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	17:56	18:15	0:19	LINE FAULT
204	7-Aug-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	15:06	15:27	0:21	LINE FAULT
205	7-Aug-19	HASSAN	110	HV2	SAGARA_110	13:05	13:19	0:14	LINE CLEAR AVAILED
206	7-Aug-19	HASSAN	110	HV1	SAGARA_110	16:25	16:55	0:30	LINE CLEAR AVAILED
207	7-Aug-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	21:08	21:11	0:03	HAND TRIPPED
208	7-Aug-19	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	21:08	21:12	0:04	HAND TRIPPED
209	7-Aug-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	21:08	21:12	0:04	HAND TRIPPED
210	7-Aug-19	HASSAN	66	LV1	HASSAN_220	21:01	21:10	0:09	TRANSFORMER FAULT
211	7-Aug-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	21:08	21:12	0:04	HAND TRIPPED
212	7-Aug-19	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	21:08	21:12	0:04	HAND TRIPPED
213	7-Aug-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	21:08	21:53	0:45	HAND TRIPPED
214	7-Aug-19	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	11:00	12:40	1:40	LINE CLEAR AVAILED
215	7-Aug-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	8:26	8:32	0:06	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
216	7-Aug-19	HASSAN	66	HV1	DODDAKADANUR_66	11:12	11:50	0:38	LOAD CURTAILMENT
217	7-Aug-19	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	6:50	6:55	0:05	LINE FAULT
218	7-Aug-19	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	7:05	7:40	0:35	LINE FAULT
219	7-Aug-19	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	12:55	13:10	0:15	LINE CLEAR AVAILED
220	7-Aug-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	11:08	11:46	0:38	LINE FAULT
221	7-Aug-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	14:05	14:54	0:49	TRANSFORMER FAULT
222	7-Aug-19	HASSAN	66	RAAMNAT-BNDSTHL	RAMNATHPURA_66	12:42	13:36	0:54	LINE CLEAR AVAILED
223	7-Aug-19	HASSAN	66	HV2	RAMNATHPURA_66	12:42	13:13	0:31	LINE CLEAR AVAILED
224	7-Aug-19	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:42	13:34	0:52	LINE CLEAR AVAILED
225	7-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	0:22	0:32	0:10	LINE FAULT
226	7-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	0:56	1:06	0:10	LINE FAULT
227	7-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	1:54	2:06	0:12	LINE FAULT
228	7-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	2:30	11:10	8:40	LINE FAULT
229	7-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	11:30	16:55	5:25	LINE FAULT
230	7-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	16:55	23:59	7:04	LINE FAULT
231	7-Aug-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	21:55	22:25	0:30	HAND TRIPPED
232	7-Aug-19	HASSAN	66	SAKALE-HASSAN2	SAKLESHPURA_66	17:20	17:40	0:20	LINE FAULT
233	7-Aug-19	HASSAN	66	SAKALE-HASSAN2	SAKLESHPURA_66	19:30	23:30	4:00	LINE FAULT
234	7-Aug-19	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	11:00	12:40	1:40	LOAD CURTAILMENT
235	7-Aug-19	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	11:00	12:40	1:40	LINE CLEAR AVAILED
236	7-Aug-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	11:49	12:15	0:26	LINE CLEAR AVAILED
237	7-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	17:27	19:02	1:35	LINE CLEAR AVAILED
238	7-Aug-19	MYSORE	66	HV1	BILIKERE_66	11:12	12:00	0:48	LINE CLEAR AVAILED
239	7-Aug-19	MYSORE	66	HV2	BILIKERE_66	12:18	12:31	0:12	LINE CLEAR AVAILED
240	7-Aug-19	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	6:34	6:43	0:09	LINE FAULT
241	7-Aug-19	MYSORE	66	CR NAGARA-CHANDAKVADI	CHANDAKAVADI_66	12:41	12:45	0:04	HAND TRIPPED
242	7-Aug-19	MYSORE	66	DEVNUR(MYS)-FTS	FTS_66	4:37	10:17	5:39	LINE CLEAR AVAILED
243	7-Aug-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66	14:45	14:56	0:11	HAND TRIPPED
244	7-Aug-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66	14:57	15:02	0:04	LINE FAULT
245	7-Aug-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66	22:18	22:19	0:01	LINE FAULT
246	7-Aug-19	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	13:45	13:47	0:02	HAND TRIPPED
247	7-Aug-19	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	13:50	13:55	0:05	HAND TRIPPED
248	7-Aug-19	MYSORE	66	HV1	HOOTAGALLY_220	13:33	13:40	0:07	HAND TRIPPED
249	7-Aug-19	MYSORE	66	HV2	HOOTAGALLY_220	13:34	13:41	0:07	HAND TRIPPED
250	7-Aug-19	MYSORE	66	HV1	HUNSUR_66	12:56	13:25	0:29	LINE CLEAR AVAILED
251	7-Aug-19	MYSORE	66	HV1	PANDAVAPURA_66	6:36	6:41	0:04	HAND TRIPPED
252	7-Aug-19	MYSORE	66	HV2	SANTHEMARAHALI_66	17:06	17:13	0:07	HAND TRIPPED
253	7-Aug-19	TUMKUR	110	TR-1	TURUVEKERE_110	17:31	17:50	0:18	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
254	7-Aug-19	TUMKUR	66	CHITRADURGA 220KV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	0:09	2:35	2:26	LINE FAULT
255	7-Aug-19	TUMKUR	66	TR-2	HIREHALLY_66	11:31	13:33	2:02	LINE CLEAR AVAILED
256	7-Aug-19	TUMKUR	66	TR-1	HIRIYUR_66	16:14	16:20	0:05	TRANSFORMER FAULT
257	7-Aug-19	TUMKUR	66	TR-1	HONNALI_66	11:21	16:14	4:53	TRANSFORMER FAULT
258	7-Aug-19	TUMKUR	66	TR-1	PANDARAHALLI_66	18:14	18:24	0:10	TRANSFORMER FAULT
259	7-Aug-19	TUMKUR	66	TR-1	PANDARAHALLI_66	19:06	19:09	0:02	TRANSFORMER FAULT
260	7-Aug-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	21:55	23:34	1:39	LINE CLEAR AVAILED
261	7-Aug-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	21:55	23:34	1:39	LINE CLEAR AVAILED
262	7-Aug-19	TUMKUR	66	TR-1	SAVANUR_110	15:17	16:11	0:53	MAIN SUPPLY FAILURE
263	8-Aug-19	BAGALKOT	110	110/11KV,HV2	AKSHAY COLONY_110	3:32	10:15	6:43	TRANSFORMER FAULT
264	8-Aug-19	BAGALKOT	110	SUPA1 -AMBEWADI	AMBEWADI_220	2:43	4:23	1:40	LINE CLEAR AVAILED
265	8-Aug-19	BAGALKOT	110	SUPA2 -AMBEWADI	AMBEWADI_220	2:43	4:29	1:46	LINE CLEAR AVAILED
266	8-Aug-19	BAGALKOT	110	SUPA1 -AMBEWADI	AMBEWADI_220	9:33	16:03	6:30	LINE CLEAR AVAILED
267	8-Aug-19	BAGALKOT	110	SUPA2 -AMBEWADI	AMBEWADI_220	9:33	18:27	8:54	LINE CLEAR AVAILED
268	8-Aug-19	BAGALKOT	220	PONDA 1-AMBEWADI	AMBEWADI_220	2:43	23:59	21:16	LINE CLEAR AVAILED
269	8-Aug-19	BAGALKOT	110	110/11KV,HV1	ANANDANAGAR	4:55	5:06	0:11	TRANSFORMER FAULT
270	8-Aug-19	BAGALKOT	110	110/11KV,HV1	ANANDANAGAR	9:43	9:51	0:08	TRANSFORMER FAULT
271	8-Aug-19	BAGALKOT	110	110/11KV,HV1	BELUR_110	3:15	4:41	1:26	TRANSFORMER FAULT
272	8-Aug-19	BAGALKOT	220	220/110KV,HV1&LV1	BIDNAL_220	2:55	11:07	8:12	LINE CLEAR AVAILED
273	8-Aug-19	BAGALKOT	110	220/110KV,LV1	BIDNAL_220,PH COMPOUND_110,GADAG ROAD_110,ANNIGERI_110,NAVALAGUND_110	2:55	12:34	9:39	LINE CLEAR AVAILED
274	8-Aug-19	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	2:58	3:46	0:48	HAND TRIPPED
275	8-Aug-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	2:58	3:25	0:27	HAND TRIPPED
276	8-Aug-19	BAGALKOT	220	NAGJHARI -BIDNAL	BIDNAL_220	2:58	3:17	0:19	HAND TRIPPED
277	8-Aug-19	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	2:58	3:21	0:23	HAND TRIPPED
278	8-Aug-19	BAGALKOT	220	BIDNAL-HUBLI 2	BIDNAL_220	2:58	3:27	0:29	HAND TRIPPED
279	8-Aug-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI 2	BIDNAL_220	3:01	5:05	2:04	LINE CLEAR AVAILED
280	8-Aug-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI 1	BIDNAL_220	3:01	23:59	20:58	LINE CLEAR AVAILED
281	8-Aug-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	0:00	3:10	3:10	LINE CLEAR AVAILED
282	8-Aug-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	5:02	14:27	9:25	LINE CLEAR AVAILED
283	8-Aug-19	BAGALKOT	220	HARTI1&2-BIDNAL	BIDNAL_220	5:07	23:59	18:52	LINE CLEAR AVAILED
284	8-Aug-19	BAGALKOT	110	BIDNAL 220-HUBLI 2	BIDNAL_220	0:00	4:11	4:11	LINE CLEAR AVAILED
285	8-Aug-19	BAGALKOT	110	BIDNAL 220-HUBLI 2	BIDNAL_220	12:34	23:59	11:25	LINE CLEAR AVAILED
286	8-Aug-19	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	3:01	4:12	1:11	LINE CLEAR AVAILED
287	8-Aug-19	BAGALKOT	110	110/11KV,HV2	BIDNAL_220	3:01	4:37	1:36	LINE CLEAR AVAILED
288	8-Aug-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_220	3:01	13:08	10:07	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
289	8-Aug-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	3:01	13:26	10:25	LINE CLEAR AVAILED
290	8-Aug-19	BAGALKOT	110	BIDNAL 220-GADAG ROAD	GADAG ROAD_110	3:01	13:24	10:23	LINE CLEAR AVAILED
291	8-Aug-19	BAGALKOT	110	BIDNAL 220-P H COMPOUND	P H COMPOUND_110	3:01	13:27	10:26	LINE CLEAR AVAILED
292	8-Aug-19	BAGALKOT	220	BELGAUM-NARENDRA 1(KANABARGI 1)	BELGAUM_220	0:00	4:55	4:55	LINE CLEAR AVAILED
293	8-Aug-19	BAGALKOT	220	BELGAUM-NARENDRA 2(KANABARGI 2)	BELGAUM_220	1:25	9:13	7:48	LINE FAULT
294	8-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	1:25	5:45	4:20	LINE FAULT
295	8-Aug-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	0:15	7:50	7:35	LINE CLEAR AVAILED
296	8-Aug-19	BAGALKOT	220	220/110KV,HV1&LV1	BELGAUM_220,UCHAGAON_110,VA DAGAON_110,ANKALAGI_110	2:05	5:05	3:00	LINE CLEAR AVAILED
297	8-Aug-19	BAGALKOT	220	220/110KV,HV2	BELGAUM_220	2:05	5:50	3:45	LINE CLEAR AVAILED
298	8-Aug-19	BAGALKOT	110	BELGAUM 220-UCHAGAON	UCHAGAON_110	1:25	5:10	3:45	LINE CLEAR AVAILED
299	8-Aug-19	BAGALKOT	110	BELGAUM 220-VADAGAON	VADAGAON_110	1:25	5:15	3:50	LINE CLEAR AVAILED
300	8-Aug-19	BAGALKOT	110	BELGAUM 220-ANKALAGI	ANKALAGI_110	1:25	5:40	4:15	LINE CLEAR AVAILED
301	8-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	14:16	15:50	1:34	LINE FAULT
302	8-Aug-19	BAGALKOT	220	BELGAUM-NARENDRA 2(KANABARGI 2)	BELGAUM_220	14:16	17:52	3:36	LINE FAULT
303	8-Aug-19	BAGALKOT	220	BELGAUM-NARENDRA 1(KANABARGI 1)	BELGAUM_220	15:05	15:27	0:22	HAND TRIPPED
304	8-Aug-19	BAGALKOT	110	220/110KV,LV1	BELGAUM_220	15:25	15:30	0:05	HAND TRIPPED
305	8-Aug-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	15:25	16:13	0:48	HAND TRIPPED
306	8-Aug-19	BAGALKOT	220	220/110KV,HV2	BELGAUM_220	15:28	15:57	0:29	TRANSFORMER FAULT
307	8-Aug-19	BAGALKOT	110	MACHE-SUARNASOUDA	SUARNASOUDA_110	2:20	4:52	2:32	LINE CLEAR AVAILED
308	8-Aug-19	BAGALKOT	110	HUBLI220-TARIHAL1	TARIHAL_110	11:37	19:52	8:15	LINE CLEAR AVAILED
309	8-Aug-19	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	11:37	19:52	8:15	LINE CLEAR AVAILED
310	8-Aug-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:00	18:12	18:12	LINE CLEAR AVAILED
311	8-Aug-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	0:00	18:43	18:43	LINE CLEAR AVAILED
312	8-Aug-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	17:20	23:59	6:39	LINE CLEAR AVAILED
313	8-Aug-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	3:25	3:51	0:26	HAND TRIPPED
314	8-Aug-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	3:28	4:44	1:16	LINE CLEAR AVAILED
315	8-Aug-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	1:33	14:50	13:17	LINE FAULT
316	8-Aug-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	3:28	14:50	11:22	LINE CLEAR AVAILED
317	8-Aug-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	4:44	7:57	3:13	LINE CLEAR AVAILED
318	8-Aug-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	12:32	12:38	0:06	TRANSFORMER FAULT
319	8-Aug-19	BAGALKOT	110	110/11KV,HV2	RANRBENNUR_220	11:42	12:21	0:39	HAND TRIPPED
320	8-Aug-19	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	2:18	4:38	2:20	LINE CLEAR AVAILED
321	8-Aug-19	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	2:40	23:59	21:19	LINE FAULT
322	8-Aug-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	2:40	4:51	2:11	LINE FAULT
323	8-Aug-19	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	2:40	4:47	2:07	LINE FAULT
324	8-Aug-19	BAGALKOT	220	NARENDRA-HAVERI1	NARENDRA_220	2:14	17:34	15:20	LINE CLEAR AVAILED
325	8-Aug-19	BAGALKOT	220	220,110KV, HV1&LV1	NARENDRA_220, BELUR_110, KUD DHARWAD_110, MRUTHYUNJAY NAGAR_110	2:14	3:35	1:21	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
326	8-Aug-19	BAGALKOT	220	220,110KV, HV2&LV2	NARENDRA_220	2:14	5:02	2:48	LINE CLEAR AVAILED
327	8-Aug-19	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI_220	14:20	23:59	9:39	TRANSFORMER FAULT
328	8-Aug-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	2:18	4:12	1:54	LINE CLEAR AVAILED
329	8-Aug-19	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	2:45	23:59	21:14	LINE CLEAR AVAILED
330	8-Aug-19	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	2:43	4:12	1:29	LINE CLEAR AVAILED
331	8-Aug-19	BAGALKOT	220	220/110KV, HV1&LV1	HAVERI_220, SAVANUR_110, BYADAGI_110	3:51	4:12	0:21	TRANSFORMER FAULT
332	8-Aug-19	BAGALKOT	110	110/11KV, HV1&HV2	MUNAVALLY_110	8:27	23:59	15:32	LINE CLEAR AVAILED
333	8-Aug-19	BAGALKOT	110	110/33KV, HV3	MUNAVALLY_110	8:27	23:59	15:32	LINE CLEAR AVAILED
334	8-Aug-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	2:40	4:15	1:35	LINE CLEAR AVAILED
335	8-Aug-19	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	4:21	7:23	3:02	LINE CLEAR AVAILED
336	8-Aug-19	BAGALKOT	110	GADAG220-SHIRHATTI	SHIRHATTI_110	7:16	14:46	7:30	LINE CLEAR AVAILED
337	8-Aug-19	BAGALKOT	110	GADAG220-LAXMESHVAR	LAXMESHVAR_110, BELLATTI_110	12:41	14:40	1:59	LINE CLEAR AVAILED
338	8-Aug-19	BAGALKOT	110	BAGEWADI220-MAMDAPUR1&2	MAMDAPUR_110	7:16	8:37	1:21	LINE CLEAR AVAILED
339	8-Aug-19	BAGALKOT	110	BAGEWADI220-MAMDAPUR1&2	MAMDAPUR_110	8:36	10:30	1:54	LINE CLEAR AVAILED
340	8-Aug-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	8:23	11:10	2:47	LINE FAULT
341	8-Aug-19	BAGALKOT	110	BAGEWADI220-MUDEDEBIHAL	MUDEDEBIHAL_110	9:20	10:30	1:10	LINE CLEAR AVAILED
342	8-Aug-19	BAGALKOT	220	LINGASUR1-BAGEWADI	BAGEWADI_220	6:11	10:26	4:15	LINE FAULT
343	8-Aug-19	BAGALKOT	220	LINGASUR2-BAGEWADI	BAGEWADI_220	6:11	10:26	4:15	LINE FAULT
344	8-Aug-19	BAGALKOT	220	FORTUNEFIVE2-BAGEWADI	BAGEWADI_220	7:16	10:41	3:25	LINE CLEAR AVAILED
345	8-Aug-19	BAGALKOT	220	BAGEWADI-BIJAPUR1&2	BAGEWADI_220	9:00	12:31	3:31	LINE CLEAR AVAILED
346	8-Aug-19	BAGALKOT	220	ATRIYA1-BAGEWADI	BAGEWADI_220	9:12	10:53	1:41	LINE CLEAR AVAILED
347	8-Aug-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	9:17	11:23	2:06	LINE CLEAR AVAILED
348	8-Aug-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	5:51	15:55	10:04	LINE FAULT
349	8-Aug-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	12:19	16:00	3:41	NFBC ISSUED
350	8-Aug-19	GULBARGA	220	HV1	SIDHANOOR_220	9:24	9:50	0:26	TRANSFORMER FAULT
351	8-Aug-19	GULBARGA	220	LV1	SIDHANOOR_220	10:00	10:10	0:10	TRANSFORMER FAULT
352	8-Aug-19	GULBARGA	110	SIDHANOOR-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	9:24	9:51	0:27	LINE FAULT
353	8-Aug-19	GULBARGA	110	SIDHANOOR-MUNIRABAD2	BTPS_WATER WORKS,KAMPLI_GLB_110,MUKUND A_110	9:24	9:57	0:33	LINE FAULT
354	8-Aug-19	GULBARGA	110	SIDHANOOR-PGLRWIND_IPP	SIDHANOOR_220	9:24	9:59	0:35	LINE FAULT
355	8-Aug-19	GULBARGA	110	SIDHANOOR-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	10:00	10:15	0:15	LINE FAULT
356	8-Aug-19	GULBARGA	110	SIDHANOOR-MUNIRABAD2	BTPS_WATER WORKS,KAMPLI_GLB_110,MUKUND A_110	10:00	10:20	0:20	LINE FAULT
357	8-Aug-19	GULBARGA	110	SIDHANOOR-PGLRWIND_IPP	SIDHANOOR_220	10:00	10:30	0:30	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
358	8-Aug-19	GULBARGA	110	SIDHANOOR-RAICHUR2	MANVI_110,MADALAPUR_110	10:00	10:25	0:25	LINE FAULT
359	8-Aug-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	9:48	10:01	0:13	LINE CLEAR AVAILED
360	8-Aug-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	7:35	7:35	LINE CLEAR AVAILED
361	8-Aug-19	HASSAN	220	HV1	KAVOOR_220	9:33	10:31	0:58	LINE CLEAR AVAILED
362	8-Aug-19	HASSAN	220	HV2	KAVOOR_220	10:44	12:03	1:19	TRANSFORMER FAULT
363	8-Aug-19	HASSAN	220	HV3	KAVOOR_220	12:04	13:54	1:50	LINE CLEAR AVAILED
364	8-Aug-19	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:27	10:35	0:08	HAND TRIPPED
365	8-Aug-19	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	10:27	10:36	0:09	HAND TRIPPED
366	8-Aug-19	HASSAN	110	LV1	KAVOOR_220	9:33	10:32	0:59	LINE CLEAR AVAILED
367	8-Aug-19	HASSAN	110	LV2	KAVOOR_220	10:52	12:04	1:12	TRANSFORMER FAULT
368	8-Aug-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	3:16	3:43	0:27	LINE FAULT
369	8-Aug-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	0:00	17:27	17:27	LINE FAULT
370	8-Aug-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	0:00	13:50	13:50	LINE FAULT
371	8-Aug-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:29	18:33	4:04	LINE FAULT
372	8-Aug-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	8:10	14:19	6:09	LINE CLEAR AVAILED
373	8-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	16:42	17:25	0:43	LINE FAULT
374	8-Aug-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:05	17:27	6:22	NFBC ISSUED
375	8-Aug-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	3:27	3:52	0:25	LINE FAULT
376	8-Aug-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	16:42	17:26	0:44	LINE FAULT
377	8-Aug-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	0:00	15:51	15:51	LINE FAULT
378	8-Aug-19	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	17:49	17:50	0:01	LINE FAULT
379	8-Aug-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	0:00	15:52	15:52	LINE FAULT
380	8-Aug-19	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	3:39	11:33	7:54	LINE FAULT
381	8-Aug-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	0:00	13:49	13:49	LINE FAULT
382	8-Aug-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	14:29	18:51	4:22	LINE FAULT
383	8-Aug-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:52	14:51	2:59	LINE CLEAR AVAILED
384	8-Aug-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:54	18:52	3:58	LINE CLEAR AVAILED
385	8-Aug-19	HASSAN	110	HV2	ANANDAPURA_110	12:09	17:34	5:25	LINE CLEAR AVAILED
386	8-Aug-19	HASSAN	110	HV3	BAIKAMPADI_110	15:29	15:35	0:06	TRANSFORMER FAULT
387	8-Aug-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	3:28	8:09	4:41	LINE FAULT
388	8-Aug-19	HASSAN	110	HV1	HIRENALLUR_110	11:45	12:45	1:00	LINE CLEAR AVAILED
389	8-Aug-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	3:29	4:29	1:00	LINE FAULT
390	8-Aug-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	6:05	6:24	0:19	LINE FAULT
391	8-Aug-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	2:41	2:52	0:11	LINE FAULT
392	8-Aug-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	8:05	8:19	0:14	LINE FAULT
393	8-Aug-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	8:04	8:19	0:15	LOAD CURTAILMENT
394	8-Aug-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	5:35	11:00	5:25	LINE FAULT
395	8-Aug-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:00	11:10	0:10	HAND TRIPPED
396	8-Aug-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	14:15	14:25	0:10	LINE FAULT
397	8-Aug-19	HASSAN	66	SAKALAE-HANBAL	SAKLESHPURA_66	4:24	4:39	0:15	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
398	8-Aug-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	2:14	2:41	0:27	LINE FAULT
399	8-Aug-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	2:56	8:05	5:09	LINE CLEAR AVAILED
400	8-Aug-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:05	20:02	11:57	LINE CLEAR AVAILED
401	8-Aug-19	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPLU_66	16:50	17:56	1:06	LINE CLEAR AVAILED
402	8-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:42	23:59	13:17	LINE CLEAR AVAILED
403	8-Aug-19	MYSORE	66	HV1	HANAGODU_66	4:19	17:25	13:05	TRANSFORMER FAULT
404	8-Aug-19	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	9:58	10:05	0:07	LINE FAULT
405	8-Aug-19	MYSORE	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	6:18	6:37	0:18	LINE FAULT
406	8-Aug-19	MYSORE	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	7:06	7:14	0:08	LINE FAULT
407	8-Aug-19	MYSORE	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66, SUNTIKOPPA_66	10:26	11:29	1:03	LINE CLEAR AVAILED
408	8-Aug-19	MYSORE	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	6:43	6:50	0:07	LINE FAULT
409	8-Aug-19	MYSORE	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	7:06	7:15	0:08	LINE FAULT
410	8-Aug-19	MYSORE	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	7:15	11:29	4:14	LINE FAULT
411	8-Aug-19	MYSORE	220	HV2	MADHUVANAHALLI_220	13:16	15:26	2:10	LINE CLEAR AVAILED
412	8-Aug-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA1	BGPURA_66, CHANDALLI_66, KOLLEGALA_66, PARINAMIPURA_66, THALAKADU_66	13:31	13:41	0:09	LINE FAULT
413	8-Aug-19	MYSORE	66	HV2	MADIKERI_66	12:45	13:16	0:30	TRANSFORMER FAULT
414	8-Aug-19	MYSORE	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	6:18	6:49	0:30	LINE FAULT
415	8-Aug-19	MYSORE	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	7:08	7:25	0:16	HAND TRIPPED
416	8-Aug-19	MYSORE	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	10:29	11:30	1:01	NFBC ISSUED
417	8-Aug-19	MYSORE	66	HV2	NAGAMANGALA_66	15:20	15:41	0:20	HAND TRIPPED
418	8-Aug-19	TUMKUR	66	TR-2	BALENAHALLI_66	16:02	16:30	0:27	TRANSFORMER FAULT
419	8-Aug-19	TUMKUR	66	TR-1	CHANNAGIRI_66	1:49	1:58	0:09	TRANSFORMER FAULT
420	8-Aug-19	TUMKUR	66	TR-1	CHANNAGIRI_66	10:03	10:13	0:10	TRANSFORMER FAULT
421	8-Aug-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:51	10:22	0:30	LINE FAULT
422	8-Aug-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	13:11	13:54	0:43	LINE FAULT
423	8-Aug-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	5:19	5:24	0:05	LINE FAULT
424	8-Aug-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	13:11	13:55	0:43	HAND TRIPPED
425	8-Aug-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	13:15	14:12	0:57	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
426	8-Aug-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	1:57	4:51	2:54	LINE CLEAR AVAILED
427	8-Aug-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	6:48	6:55	0:06	TRANSFORMER FAULT
428	8-Aug-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	7:37	7:52	0:15	LINE FAULT
429	8-Aug-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	2:22	3:35	1:13	LINE CLEAR AVAILED
430	8-Aug-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	2:22	3:35	1:12	LINE CLEAR AVAILED
431	8-Aug-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:37	4:47	0:10	HAND TRIPPED
432	8-Aug-19	TUMKUR	66	TR-1	MADHUGIRI_220	2:23	7:09	4:45	LINE CLEAR AVAILED
433	8-Aug-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	7:51	7:59	0:08	TRANSFORMER FAULT
434	8-Aug-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	3:56	9:10	5:14	TRANSFORMER FAULT
435	8-Aug-19	TUMKUR	66	TR-1	PANDARAHALLI_66	11:36	12:40	1:03	LINE CLEAR AVAILED
436	8-Aug-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	16:10	16:34	0:23	LINE CLEAR AVAILED
437	8-Aug-19	TUMKUR	66	TR-1	YNHOSKOTE_66	19:47	19:52	0:05	TRANSFORMER FAULT
438	9-Aug-19	BAGALKOT	110	ATHANISUGARS-AINAPUR	AINAPUR_110	9:30	9:40	0:10	LINE FAULT
439	9-Aug-19	BAGALKOT	110	ATHANISUGARS-AINAPUR	AINAPUR_110	10:55	11:05	0:10	LINE FAULT
440	9-Aug-19	BAGALKOT	110	AINAPUR-AINAPUR LIS	AINAPUR_110	16:12	23:59	7:47	LINE CLEAR AVAILED
441	9-Aug-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	3:40	6:25	2:45	LINE CLEAR AVAILED
442	9-Aug-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	23:05	23:59	0:54	HAND TRIPPED
443	9-Aug-19	BAGALKOT	220	BELGAUM -NARENDRA 2	BELGAUM_220	12:50	23:59	11:09	LINE CLEAR AVAILED
444	9-Aug-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI 1	BIDNAL_220	0:00	17:48	17:48	LINE CLEAR AVAILED
445	9-Aug-19	BAGALKOT	220	220/110KV,HV1 & LV1	HAVERI_220	23:03	23:59	0:56	TRANSFORMER FAULT
446	9-Aug-19	BAGALKOT	220	KADRA 2-KARAWAR	KARAWAR_220	10:41	23:59	13:18	LINE FAULT
447	9-Aug-19	BAGALKOT	220	KUDACHI-CHIKKODI1(GHATAPRABHA)	KUDACHI_220	17:05	23:59	6:54	LINE CLEAR AVAILED
448	9-Aug-19	BAGALKOT	110	HUNAGUND-KUDALSANGAM	KUDALSANGAM_110	14:03	14:30	0:27	LINE FAULT
449	9-Aug-19	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	1:28	20:09	18:41	MAIN SUPPLY FAILURE
450	9-Aug-19	BAGALKOT	220	MK HUBLI-NARENDRA 2	MK HUBLI_220	23:33	23:59	0:26	HAND TRIPPED
451	9-Aug-19	BAGALKOT	110	110/11KV,HV1&2	MUNAVALLI_110	15:50	16:54	1:04	LINE CLEAR AVAILED
452	9-Aug-19	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	0:00	16:28	16:28	LINE CLEAR AVAILED
453	9-Aug-19	BAGALKOT	110	HUBLI220-TARIHAL1	TARIHAL_110	13:04	17:39	4:35	LINE CLEAR AVAILED
454	9-Aug-19	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	13:04	17:39	4:35	LINE CLEAR AVAILED
455	9-Aug-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	0:00	16:55	16:55	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
456	9-Aug-19	BAGALKOT	110	110/11KV,HV1	UTTUR_110	14:00	23:59	9:59	LINE CLEAR AVAILED
457	9-Aug-19	BAGALKOT	110	110/11KV,HV2	UTTUR_110	14:00	23:59	9:59	LINE CLEAR AVAILED
458	9-Aug-19	BAGALKOT	110	MAHALINGAPUR-UTTUR	UTTUR_110	20:43	23:59	3:16	LINE CLEAR AVAILED
459	9-Aug-19	BAGALKOT	110	110/33KV,HV1	UTTUR_110,YADVAD_33KV,VANTAG ODI_33KV	7:32	23:59	16:27	LINE CLEAR AVAILED
460	9-Aug-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR 2	VAJRAMATTI_220	15:27	23:59	8:32	LINE FAULT
461	9-Aug-19	BAGALKOT	110	VAJRAMATTI-JK CEMENT	VAJRAMATTI_220	11:23	17:28	6:05	LINE FAULT
462	9-Aug-19	BAGALKOT	110	110/11KV,HV1	YELLAPARHATTI_110	12:55	14:00	1:05	LINE CLEAR AVAILED
463	9-Aug-19	BAGALKOT	110	110/11KV,HV2	YELLAPARHATTI_110	12:55	14:00	1:05	LINE CLEAR AVAILED
464	9-Aug-19	BENGALURU	220	EPID 220 - HSR LAYOUT 220	HSR LAYOUT 220	4:04	4:39	0:35	LINE FAULT
465	9-Aug-19	BENGALURU	220	EPID 220 - HSR LAYOUT 220	HSR LAYOUT 220	4:39	5:18	0:39	LINE FAULT
466	9-Aug-19	BENGALURU	220	HSR LAYOUT 220 - EPID 220	HSR LAYOUT 220	4:04	5:18	1:14	LINE FAULT
467	9-Aug-19	BENGALURU	220	HV2	HSR LAYOUT 220	4:10	5:19	1:09	MAIN SUPPLY FAILURE
468	9-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	4:04	5:02	0:58	MAIN SUPPLY FAILURE
469	9-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	4:04	4:50	0:46	MAIN SUPPLY FAILURE
470	9-Aug-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	7:48	7:56	0:08	LOAD CHANGEVER
471	9-Aug-19	BENGALURU	66	HV1	BYADRAHALLI	18:12	18:22	0:10	TRANSFORMER FAULT
472	9-Aug-19	BENGALURU	66	HV2	NAGNATHPURA 220	4:55	5:42	0:47	TRANSFORMER FAULT
473	9-Aug-19	BENGALURU	66	HV2	NAGNATHPURA 220	15:11	15:15	0:03	LINE CLEAR AVAILED
474	9-Aug-19	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	11:25	11:45	0:20	LINE CLEAR AVAILED
475	9-Aug-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	15:34	15:45	0:11	LINE FAULT
476	9-Aug-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	15:34	15:45	0:11	LINE FAULT
477	9-Aug-19	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	0:00	17:50	17:50	LINE CLEAR AVAILED
478	9-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAB1	MAHAGOAN_110,MARGUTTI_110	12:58	13:03	0:05	LINE FAULT
479	9-Aug-19	GULBARGA	110	MASKI-RNWSLR	MASKI_110	14:03	14:07	0:04	LINE CLEAR AVAILED
480	9-Aug-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPUR_110	13:20	13:40	0:20	LINE FAULT
481	9-Aug-19	GULBARGA	110	YELBURGA-PARAMPOOJYA_IPP	YELBURGA_110	10:20	20:28	10:08	LINE FAULT
482	9-Aug-19	GULBARGA	110	YELBURGA-PARAMPOOJYA_IPP	YELBURGA_110	13:05	13:10	0:05	LINE FAULT
483	9-Aug-19	GULBARGA	110	HV1	SHAHAPUR_220	11:25	12:00	0:35	LINE CLEAR AVAILED
484	9-Aug-19	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:15	19:22	0:07	LINE CLEAR AVAILED
485	9-Aug-19	GULBARGA	110	SINDHANOOR-PGLRWIND_IPP	SIDHANOOR_220	22:58	23:12	0:14	LINE FAULT
486	9-Aug-19	GULBARGA	66	HV2	CHORNOOR_66	13:55	14:00	0:05	TRANSFORMER FAULT
487	9-Aug-19	GULBARGA	66	HV1	CHORNOOR_66	15:20	16:10	0:50	LINE CLEAR AVAILED
488	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	8:48	8:50	0:02	TRANSFORMER FAULT
489	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	10:05	10:10	0:05	TRANSFORMER FAULT
490	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	11:10	11:15	0:05	LINE CLEAR AVAILED
491	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	11:20	11:25	0:05	LINE CLEAR AVAILED
492	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	12:05	12:10	0:05	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
493	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	13:05	13:10	0:05	TRANSFORMER FAULT
494	9-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	17:45	17:50	0:05	TRANSFORMER FAULT
495	9-Aug-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	10:20	10:25	0:05	LINE CLEAR AVAILED
496	9-Aug-19	GULBARGA	66	ITTAGI-SUZLON1,2_IPP	ITTAGI_220	12:22	13:10	0:48	LINE CLEAR AVAILED
497	9-Aug-19	GULBARGA	66	HV1	CHORNOOR_66	7:20	7:25	0:05	TRANSFORMER FAULT
498	9-Aug-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:01	23:59	22:58	LINE FAULT
499	9-Aug-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	0:00	17:14	17:14	LINE FAULT
500	9-Aug-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:58	16:24	0:26	LINE FAULT
501	9-Aug-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:58	16:24	0:26	LINE FAULT
502	9-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	18:12	20:51	2:39	LINE CLEAR AVAILED
503	9-Aug-19	HASSAN	220	HV1	MRSMSG_220	8:14	8:31	0:17	HAND TRIPPED
504	9-Aug-19	HASSAN	220	HV1	MRSMSG_220	8:54	10:36	1:42	LINE CLEAR AVAILED
505	9-Aug-19	HASSAN	220	HV1	MRSMSG_220	10:43	11:40	0:57	HAND TRIPPED
506	9-Aug-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:23	11:55	2:32	LINE CLEAR AVAILED
507	9-Aug-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	12:40	17:39	4:59	LINE CLEAR AVAILED
508	9-Aug-19	HASSAN	110	LV1	MRSMSG_220	8:14	8:34	0:20	HAND TRIPPED
509	9-Aug-19	HASSAN	110	LV1	MRSMSG_220	8:53	10:36	1:43	LINE CLEAR AVAILED
510	9-Aug-19	HASSAN	110	LV1	MRSMSG_220	10:43	11:40	0:57	HAND TRIPPED
511	9-Aug-19	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	3:39	13:34	9:55	LINE FAULT
512	9-Aug-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	3:39	11:33	7:54	LINE FAULT
513	9-Aug-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	0:00	17:15	17:15	LINE FAULT
514	9-Aug-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:45	11:56	1:11	LINE CLEAR AVAILED
515	9-Aug-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:39	17:40	5:01	LINE CLEAR AVAILED
516	9-Aug-19	HASSAN	110	HV3	BAIKAMPADI_110	11:55	12:00	0:05	TRANSFORMER FAULT
517	9-Aug-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	21:41	22:27	0:46	LINE FAULT
518	9-Aug-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	11:18	11:48	0:30	HAND TRIPPED
519	9-Aug-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	15:09	15:44	0:35	HAND TRIPPED
520	9-Aug-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:59	16:26	0:27	LINE FAULT
521	9-Aug-19	HASSAN	110	HULICA-KVR	HULICAL_110	16:49	17:06	0:17	HAND TRIPPED
522	9-Aug-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	21:39	22:13	0:34	LINE FAULT
523	9-Aug-19	HASSAN	110	KAVOOR-AMR	KAVOOR_220	21:14	22:12	0:58	LINE FAULT
524	9-Aug-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	21:42	22:37	0:55	MAIN SUPPLY FAILURE
525	9-Aug-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	15:00	15:51	0:51	LINE FAULT
526	9-Aug-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	4:17	4:40	0:23	LINE FAULT
527	9-Aug-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	11:25	12:58	1:33	LINE CLEAR AVAILED
528	9-Aug-19	HASSAN	110	SALATHUR-NTMDNOR	SALATHUR_110	11:25	12:58	1:33	LINE CLEAR AVAILED
529	9-Aug-19	HASSAN	110	HV2	SORABA_110	16:12	17:00	0:48	LINE CLEAR AVAILED
530	9-Aug-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	18:09	18:13	0:04	HAND TRIPPED
531	9-Aug-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	17:04	18:13	1:09	LINE FAULT
532	9-Aug-19	HASSAN	66	HV1	BAGUR_66	12:36	14:23	1:47	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
533	9-Aug-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	5:12	9:12	4:00	MAIN SUPPLY FAILURE
534	9-Aug-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:14	15:47	0:33	LINE FAULT
535	9-Aug-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	20:24	20:55	0:31	LINE FAULT
536	9-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	19:09	19:25	0:16	LINE FAULT
537	9-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	8:53	19:25	10:32	LINE FAULT
538	9-Aug-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	5:36	5:58	0:22	LINE FAULT
539	9-Aug-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	5:59	10:54	4:55	LINE FAULT
540	9-Aug-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	14:25	19:27	5:02	LINE CLEAR AVAILED
541	9-Aug-19	HASSAN	66	HV2	SALAGAME_66	0:00	11:47	11:47	TRANSFORMER FAULT
542	9-Aug-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	17:55	18:00	0:05	HAND TRIPPED
543	9-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	17:55	18:00	0:05	HAND TRIPPED
544	9-Aug-19	HASSAN	66	HV1	MALLAPURA_66	15:56	18:44	2:48	LINE CLEAR AVAILED
545	9-Aug-19	MYSORE	66	HV2	HULLAHALLI_66	11:29	18:56	7:27	LINE CLEAR AVAILED
546	9-Aug-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 MADDUR_66 TUMBEKERE_66 SOMANAHALLI_66	12:58	13:01	0:03	LINE FAULT
547	9-Aug-19	MYSORE	66	HV1	SANTHESARAGUR_66	17:04	17:46	0:42	TRANSFORMER FAULT
548	9-Aug-19	TUMKUR	110	TR-1	TURUVEKERE_110	15:05	15:12	0:07	LINE CLEAR AVAILED
549	9-Aug-19	TUMKUR	110	TR-2	TURUVEKERE_110	15:05	15:12	0:07	LINE CLEAR AVAILED
550	9-Aug-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:09	5:10	0:01	LINE FAULT
551	9-Aug-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	4:30	4:55	0:25	LINE FAULT
552	9-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	8:45	8:47	0:01	HAND TRIPPED
553	9-Aug-19	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	1:28	1:44	0:16	LINE FAULT
554	9-Aug-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	5:08	5:11	0:03	LINE FAULT
555	9-Aug-19	TUMKUR	66	TR-2	TELADI_66	5:08	16:55	11:47	LINE CLEAR AVAILED
556	10-Aug-19	BAGALKOT	110	110/11KV, HV2	AKSHAY COLONY_110	10:36	12:12	1:36	LINE CLEAR AVAILED
557	10-Aug-19	BAGALKOT	110	110/11KV, HV1	AKSHAY COLONY_110	11:45	12:15	0:30	LINE CLEAR AVAILED
558	10-Aug-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	11:22	12:01	0:39	LINE FAULT
559	10-Aug-19	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	11:22	11:45	0:23	LINE FAULT
560	10-Aug-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	0:00	12:49	12:49	LINE CLEAR AVAILED
561	10-Aug-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	0:00	6:09	6:09	LINE CLEAR AVAILED
562	10-Aug-19	BAGALKOT	110	110/11KV, HV1	BIDNAL_220	20:02	23:59	3:57	LINE CLEAR AVAILED
563	10-Aug-19	BAGALKOT	110	KARAWAR -BINAGA(SOLAR)	BINAGA_110	11:04	11:08	0:04	HAND TRIPPED
564	10-Aug-19	BAGALKOT	110	KARAWAR -BINAGA(SOLAR)	BINAGA_110	19:27	19:33	0:06	HAND TRIPPED
565	10-Aug-19	BAGALKOT	110	110/11KV,HV4	HANAGAL_110	14:45	15:30	0:45	LINE CLEAR AVAILED
566	10-Aug-19	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	17:05	18:10	1:05	LINE CLEAR AVAILED
567	10-Aug-19	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33KV	16:32	16:49	0:17	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
568	10-Aug-19	BAGALKOT	66	66/33KV,HV3	HARIHAR-HOPSPET_66KV	11:11	23:59	12:48	TRANSFORMER FAULT
569	10-Aug-19	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	11:19	16:41	5:22	LINE CLEAR AVAILED
570	10-Aug-19	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	18:55	19:25	0:30	LINE CLEAR AVAILED
571	10-Aug-19	BAGALKOT	220	220/110KV,HV1	HAVERI_220	0:00	6:41	6:41	LINE CLEAR AVAILED
572	10-Aug-19	BAGALKOT	110	BELGAUM 220-KANABARAGI	KANABARAGI LAYOUT_110	11:07	11:28	0:21	LINE FAULT
573	10-Aug-19	BAGALKOT	220	KADRA 2-KARAWAR	KARAWAR_220	0:00	15:36	15:36	LINE CLEAR AVAILED
574	10-Aug-19	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	11:09	15:36	4:27	LINE CLEAR AVAILED
575	10-Aug-19	BAGALKOT	220	KADRA 2-KARAWAR	KARAWAR_220	15:40	19:23	3:43	LINE FAULT
576	10-Aug-19	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	16:21	19:23	3:02	LINE FAULT
577	10-Aug-19	BAGALKOT	220	220/110KV,HV1	KARAWAR_220	18:28	19:26	0:58	HAND TRIPPED
578	10-Aug-19	BAGALKOT	220	220/110KV,HV1	KARAWAR_220	15:40	19:30	3:50	TRANSFORMER FAULT
579	10-Aug-19	BAGALKOT	110	220/110KV,LV 1	KARAWAR_220	11:04	15:38	4:34	LINE CLEAR AVAILED
580	10-Aug-19	BAGALKOT	110	220/110KV,LV 1	KARAWAR_220	16:11	19:33	3:22	LINE CLEAR AVAILED
581	10-Aug-19	BAGALKOT	220	KUDACHI-CHIKKODI1(GHATAPRABHA)	KUDACHI_220	0:00	8:45	8:45	LINE CLEAR AVAILED
582	10-Aug-19	BAGALKOT	110	MUDALAGI-GOKAK TO KULIGOD	KULIGOD_110	4:20	5:06	0:46	LINE FAULT
583	10-Aug-19	BAGALKOT	110	MUDALAGI-GAMESH	KULIGOD_110	5:06	5:08	0:02	LINE FAULT
584	10-Aug-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	11:00	14:39	3:39	LINE CLEAR AVAILED
585	10-Aug-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:50	14:47	3:57	LINE CLEAR AVAILED
586	10-Aug-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	12:36	23:59	11:23	LINE CLEAR AVAILED
587	10-Aug-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	11:16	19:50	8:34	LINE FAULT
588	10-Aug-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	12:57	19:20	6:23	LINE CLEAR AVAILED
589	10-Aug-19	BAGALKOT	110	110/11KV,HV 1	TILUALLI_110	11:44	13:30	1:46	TRANSFORMER FAULT
590	10-Aug-19	BAGALKOT	110	110/11KV,HV1	UTTUR_110	0:00	8:53	8:53	LINE CLEAR AVAILED
591	10-Aug-19	BAGALKOT	110	110/11KV,HV2	UTTUR_110	0:00	11:40	11:40	LINE CLEAR AVAILED
592	10-Aug-19	BAGALKOT	110	MAHALINGAPUR-UTTUR	UTTUR_110	0:00	10:10	10:10	LINE CLEAR AVAILED
593	10-Aug-19	BAGALKOT	110	110/33KV,HV1	UTTUR_110,YADVAD_33KV,VANTAG ODI_33KV	0:00	11:10	11:10	LINE CLEAR AVAILED
594	10-Aug-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR 2	VAJRAMATTI_220	0:00	20:05	20:05	LINE CLEAR AVAILED
595	10-Aug-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	7:48	7:56	0:08	LOAD CHANGE OVER
596	10-Aug-19	BENGALURU	66	HV2	YERANDANAHALLI 220	19:17	19:26	0:09	LOAD CHANGE OVER
597	10-Aug-19	BENGALURU	66	HV2	YERANDANAHALLI 220	18:44	18:50	0:06	LOAD CHANGE OVER
598	10-Aug-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	9:01	9:08	0:07	LOAD CHANGE OVER
599	10-Aug-19	BENGALURU	66	HV1	KEMPANAHALLI	17:20	17:27	0:06	TRANSFORMER FAULT
600	10-Aug-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	22:25	22:50	0:25	LINE FAULT
601	10-Aug-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:11	13:06	0:55	LINE CLEAR AVAILED
602	10-Aug-19	GULBARGA	220	HV2	KUSTAGI_220	10:25	11:00	0:35	TRANSFORMER FAULT
603	10-Aug-19	GULBARGA	220	HV1	KUSTAGI_220	10:43	11:12	0:29	TRANSFORMER FAULT
604	10-Aug-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	2:23	23:59	21:36	LINE FAULT
605	10-Aug-19	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	2:23	3:45	1:22	LINE FAULT
606	10-Aug-19	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	2:23	3:24	1:01	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
607	10-Aug-19	GULBARGA	110	HV1	KOLHAR_110	12:10	12:35	0:25	LINE CLEAR AVAILED
608	10-Aug-19	GULBARGA	110	VALKAMDINNI-BYAGAWAT	BYAGAWAT_110	17:05	18:00	0:55	LINE CLEAR AVAILED
609	10-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:31	5:38	0:07	LINE FAULT
610	10-Aug-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPUR_110	17:20	23:59	6:39	LINE CLEAR AVAILED
611	10-Aug-19	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	10:50	14:33	3:43	LINE CLEAR AVAILED
612	10-Aug-19	HASSAN	220	HV1	KEMAR_220	4:26	8:17	3:51	TRANSFORMER FAULT
613	10-Aug-19	HASSAN	110	LV1	KEMAR_220	4:26	8:18	3:52	TRANSFORMER FAULT
614	10-Aug-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	4:26	12:12	7:46	LINE FAULT
615	10-Aug-19	HASSAN	110	HV2	HALADY_110	20:38	21:27	0:49	LINE CLEAR AVAILED
616	10-Aug-19	HASSAN	110	HV2	HALADY_110	21:38	23:59	2:21	LINE CLEAR AVAILED
617	10-Aug-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	2:24	23:59	21:35	LINE CLEAR AVAILED
618	10-Aug-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:44	14:55	4:11	LINE FAULT
619	10-Aug-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	3:11	3:34	0:23	LINE FAULT
620	10-Aug-19	HASSAN	110	NANDIKUR-KEMAR2	NANDIKUR_110	4:26	12:11	7:45	LINE FAULT
621	10-Aug-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	14:30	14:43	0:13	LINE FAULT
622	10-Aug-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	9:03	9:46	0:43	LINE CLEAR AVAILED
623	10-Aug-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	8:27	9:15	0:48	NFBC ISSUED
624	10-Aug-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	14:48	15:09	0:21	LINE FAULT
625	10-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:24	9:31	0:07	HAND TRIPPED
626	10-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:45	10:48	0:03	HAND TRIPPED
627	10-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	11:20	11:25	0:05	HAND TRIPPED
628	10-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	12:12	12:23	0:11	HAND TRIPPED
629	10-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	12:24	12:29	0:05	HAND TRIPPED
630	10-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	12:34	12:37	0:03	HAND TRIPPED
631	10-Aug-19	HASSAN	66	HV2	HALEBEEDU_66	11:56	21:59	10:03	TRANSFORMER FAULT
632	10-Aug-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	14:27	15:39	1:12	LINE CLEAR AVAILED
633	10-Aug-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	15:20	15:40	0:20	HAND TRIPPED
634	10-Aug-19	HASSAN	66	HV1	KANDLI_66	15:00	15:16	0:16	HAND TRIPPED
635	10-Aug-19	HASSAN	66	HV2	KANDLI_66	14:30	15:00	0:30	TRANSFORMER FAULT
636	10-Aug-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:08	12:19	0:11	HAND TRIPPED
637	10-Aug-19	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	14:25	15:40	1:15	LINE FAULT
638	10-Aug-19	MYSORE	66	HV2	BOMMALAPURA_66	10:30	11:09	0:38	TRANSFORMER FAULT
639	10-Aug-19	MYSORE	66	HV1	DKMAIDANA_66	12:06	12:59	0:53	TRANSFORMER FAULT
640	10-Aug-19	MYSORE	66	HV1	ELAVALA_66	12:30	12:51	0:20	TRANSFORMER FAULT
641	10-Aug-19	MYSORE	66	HV1	KRNAGARA_66	8:31	9:18	0:47	TRANSFORMER FAULT
642	10-Aug-19	MYSORE	66	NAGAMANGALA-JAKKANAHALLI	BOGADHI MANDYA_66 JAKKANAHALLY_66 GUDDENAHALLI_66 G MALLIGERE_66 NAGAMANGALA_66	11:15	11:20	0:05	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
643	10-Aug-19	MYSORE	66	NAGAMANGALA-JAKKANAHALLI	BOGADHI MANDYA_66 JAKKANAHALLY_66 GUDDENAHALLI_66 G MALLIGERE_66 NAGAMANGALA_66	13:23	13:37	0:14	HAND TRIPPED
644	10-Aug-19	MYSORE	66	HV1	RAVANDUR_66	2:25	2:37	0:12	TRANSFORMER FAULT
645	10-Aug-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	0:16	22:36	22:19	LINE CLEAR AVAILED
646	10-Aug-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	9:49	16:44	6:55	LINE CLEAR AVAILED
647	10-Aug-19	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	9:48	17:28	7:39	LINE CLEAR AVAILED
648	10-Aug-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:27	16:19	3:52	LINE CLEAR AVAILED
649	10-Aug-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	13:31	16:24	2:53	LINE CLEAR AVAILED
650	10-Aug-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	16:25	19:26	3:01	LINE FAULT
651	10-Aug-19	TUMKUR	66	TR-1	HARIHAR_66	17:36	19:09	1:32	TRANSFORMER FAULT
652	10-Aug-19	TUMKUR	66	TR-2	HARIHAR_66	11:23	18:57	7:33	LINE CLEAR AVAILED
653	10-Aug-19	TUMKUR	66	TR-2	HARIHAR_66	19:02	19:35	0:33	TRANSFORMER FAULT
654	10-Aug-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	15:49	18:32	2:43	LINE CLEAR AVAILED
655	10-Aug-19	TUMKUR	66	TR-1	KUNIGAL_66	16:19	16:34	0:15	TRANSFORMER FAULT
656	10-Aug-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	11:37	11:41	0:04	HAND TRIPPED
657	10-Aug-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	18:51	19:01	0:09	LINE FAULT
658	11-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	11:22	11:37	0:15	LINE FAULT
659	11-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	11:22	17:02	5:40	LINE FAULT
660	11-Aug-19	BAGALKOT	220	AMBEWADI-NAGJHARI 1	AMBEWADI_220	16:01	16:30	0:29	LINE FAULT
661	11-Aug-19	BAGALKOT	220	AMBEWADI-NAGJHARI 2	AMBEWADI_220	16:01	16:30	0:29	LINE FAULT
662	11-Aug-19	BAGALKOT	110	110/11KV,HV1	BABLESHWAR_110	11:10	12:15	1:05	LINE CLEAR AVAILED
663	11-Aug-19	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	12:30	13:06	0:36	LINE CLEAR AVAILED
664	11-Aug-19	BAGALKOT	110	110/11KV,HV1	BEDI_110	12:00	13:32	1:32	LINE CLEAR AVAILED
665	11-Aug-19	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	0:00	14:03	14:03	LINE CLEAR AVAILED
666	11-Aug-19	BAGALKOT	110	DAMBAL-MUNDARGI2	MUNDARGI_110	5:54	7:45	1:51	LINE FAULT
667	11-Aug-19	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	5:16	6:02	0:46	LINE FAULT
668	11-Aug-19	BAGALKOT	110	SVRG-TERDAL	TERDAL_110	9:24	23:59	14:35	LINE CLEAR AVAILED
669	11-Aug-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	13:27	14:42	1:15	NFBC ISSUED
670	11-Aug-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	16:01	19:45	3:44	LINE FAULT
671	11-Aug-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	13:51	23:59	10:08	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
672	11-Aug-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	13:52	23:59	10:07	LINE CLEAR AVAILED
673	11-Aug-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	16:20	18:29	2:09	LINE CLEAR AVAILED
674	11-Aug-19	BAGALKOT	110	VIJAY SUGARS-MUNDARGI	MUNDARGI_110	5:54	10:24	4:30	LINE FAULT
675	11-Aug-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	15:09	23:59	8:50	LINE CLEAR AVAILED
676	11-Aug-19	BAGALKOT	110	MFR SOLAR-HIREHAL	HIREHAL_110	10:22	17:53	7:31	LINE CLEAR AVAILED
677	11-Aug-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	17:10	17:21	0:11	TRANSFORMER FAULT
678	11-Aug-19	BAGALKOT	110	110/11KV,HV3	MUNAVALLI_110,MUNAVALLI_33.M ALLUR_33	17:05	17:21	0:16	TRANSFORMER FAULT
679	11-Aug-19	BAGALKOT	110	110/11KV,HV1	MUNAVALLI_110	17:10	17:21	0:11	TRANSFORMER FAULT
680	11-Aug-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	15:18	15:24	0:06	LOAD CHANGEOVER
681	11-Aug-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	9:30	9:37	0:07	LOAD CHANGEOVER
682	11-Aug-19	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 2	SARAKKI	9:35	9:42	0:07	LOAD CHANGEOVER
683	11-Aug-19	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	15:12	15:17	0:05	LOAD CHANGEOVER
684	11-Aug-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	11:15	11:20	0:05	LOAD CHANGEOVER
685	11-Aug-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	15:17	15:21	0:04	LOAD CHANGEOVER
686	11-Aug-19	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	9:26	15:27	6:00	LOAD CHANGEOVER
687	11-Aug-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	19:17	19:22	0:04	LOAD CHANGEOVER
688	11-Aug-19	BENGALURU	220	EPID 220 - HSR LAYOUT 220	HSR LAYOUT 220	16:39	19:07	2:28	LINE FAULT
689	11-Aug-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	13:41	13:48	0:07	MAIN SUPPLY FAILURE
690	11-Aug-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	13:40	13:48	0:08	MAIN SUPPLY FAILURE
691	11-Aug-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	14:53	15:03	0:10	MAIN SUPPLY FAILURE
692	11-Aug-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	14:53	15:03	0:10	MAIN SUPPLY FAILURE
693	11-Aug-19	BENGALURU	66	HV1	KHODAYS 220	13:41	13:47	0:06	MAIN SUPPLY FAILURE
694	11-Aug-19	BENGALURU	220	HV1	KHODAYS 220	13:42	13:46	0:04	MAIN SUPPLY FAILURE
695	11-Aug-19	BENGALURU	66	HV2	KHODAYS 220	13:41	13:47	0:05	MAIN SUPPLY FAILURE
696	11-Aug-19	BENGALURU	220	HV2	KHODAYS 220	13:42	13:46	0:04	MAIN SUPPLY FAILURE
697	11-Aug-19	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	13:41	13:47	0:06	MAIN SUPPLY FAILURE
698	11-Aug-19	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	14:54	15:02	0:08	MAIN SUPPLY FAILURE
699	11-Aug-19	BENGALURU	66	HV2	CHANDAPURA	11:58	12:20	0:21	TRANSFORMER FAULT
700	11-Aug-19	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	21:21	22:30	1:08	LINE CLEAR AVAILED
701	11-Aug-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	20:34	22:29	1:55	LINE FAULT
702	11-Aug-19	BENGALURU	66	HV1	DOMMASANDRA	16:01	16:20	0:18	TRANSFORMER FAULT
703	11-Aug-19	BENGALURU	66	HV1	DOMMASANDRA	16:45	17:38	0:53	LOAD CHANGEOVER
704	11-Aug-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	9:10	16:14	7:04	LINE CLEAR AVAILED
705	11-Aug-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	11:05	11:15	0:10	LINE FAULT
706	11-Aug-19	BENGALURU	66	HV2	DEVANAHALLI	15:12	15:26	0:13	TRANSFORMER FAULT
707	11-Aug-19	GULBARGA	220	KAPNOOR-SHAHBAD	KAPNOOR_220	5:50	6:20	0:30	LINE FAULT
708	11-Aug-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	0:00	14:25	14:25	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
709	11-Aug-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	2:24	3:41	1:17	LINE FAULT
710	11-Aug-19	GULBARGA	220	HV1,HV2	KUSTAGI_220	2:24	2:38	0:14	TRANSFORMER FAULT
711	11-Aug-19	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	13:05	14:35	1:30	NFBC ISSUED
712	11-Aug-19	GULBARGA	110	HV3	HATTI_110	2:25	2:45	0:20	TRANSFORMER FAULT
713	11-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	12:20	12:30	0:10	LINE FAULT
714	11-Aug-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	23:26	23:34	0:08	LINE CLEAR AVAILED
715	11-Aug-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	4:20	4:30	0:10	LINE FAULT
716	11-Aug-19	GULBARGA	66	HV1	KOTTUR_66	7:52	7:58	0:06	TRANSFORMER FAULT
717	11-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	12:45	13:50	1:05	LINE CLEAR AVAILED
718	11-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	13:55	23:59	10:04	LINE CLEAR AVAILED
719	11-Aug-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALLI_66	19:30	19:45	0:15	LINE FAULT
720	11-Aug-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	0:00	11:20	11:20	LINE CLEAR AVAILED
721	11-Aug-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	22:55	23:59	1:04	LINE CLEAR AVAILED
722	11-Aug-19	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	20:53	22:13	1:20	LINE FAULT
723	11-Aug-19	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	22:13	23:59	1:46	LINE FAULT
724	11-Aug-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	22:12	23:59	1:47	LINE FAULT
725	11-Aug-19	HASSAN	110	HV2	HALADY_110	0:00	10:06	10:06	LINE CLEAR AVAILED
726	11-Aug-19	HASSAN	110	HV2	HALADY_110	10:11	23:59	13:48	LINE CLEAR AVAILED
727	11-Aug-19	HASSAN	110	HV2	AJJAMPURA_110	16:40	17:23	0:43	HAND TRIPPED
728	11-Aug-19	HASSAN	110	HV1	BAIKAMPADI_110	10:00	11:44	1:44	LINE CLEAR AVAILED
729	11-Aug-19	HASSAN	110	HV2	BAIKAMPADI_110	10:00	11:44	1:44	LINE CLEAR AVAILED
730	11-Aug-19	HASSAN	110	HV3	BAIKAMPADI_110	14:19	14:25	0:06	TRANSFORMER FAULT
731	11-Aug-19	HASSAN	110	HV1	BARANGI_110	0:09	13:50	13:41	TRANSFORMER FAULT
732	11-Aug-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	19:25	19:35	0:10	TRANSFORMER FAULT
733	11-Aug-19	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	9:30	13:12	3:42	LINE CLEAR AVAILED
734	11-Aug-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	9:23	13:04	3:41	LINE CLEAR AVAILED
735	11-Aug-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	19:22	20:01	0:39	HAND TRIPPED
736	11-Aug-19	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	16:35	16:49	0:14	LINE FAULT
737	11-Aug-19	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	18:57	20:29	1:32	LINE CLEAR AVAILED
738	11-Aug-19	MYSORE	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	3:05	3:17	0:11	LINE FAULT
739	11-Aug-19	MYSORE	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	3:05	3:17	0:12	LINE FAULT
740	11-Aug-19	MYSORE	66	HV1	SANTHESARAGUR_66	18:56	19:03	0:06	TRANSFORMER FAULT
741	11-Aug-19	TUMKUR	66	TR-2	MALEBENNUR_66	14:04	20:43	6:38	TRANSFORMER FAULT
742	11-Aug-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	12:26	12:34	0:07	TRANSFORMER FAULT
743	12-Aug-19	BAGALKOT	220	DHONI 2-GADAG	GADAG_220	15:29	17:12	1:43	LINE CLEAR AVAILED
744	12-Aug-19	BAGALKOT	220	220/110KV,HV2&LV2	AMBEWADI_220	11:35	12:13	0:38	TRANSFORMER FAULT
745	12-Aug-19	BAGALKOT	220	HARTI 1-BIDNAL	BIDNAL_110	0:00	4:30	4:30	LINE CLEAR AVAILED
746	12-Aug-19	BAGALKOT	220	HARTI 2-BIDNAL	BIDNAL_110	0:00	4:35	4:35	LINE CLEAR AVAILED
747	12-Aug-19	BAGALKOT	220	220/110KV,HV2&LV2	CHIKKODI_220	10:48	12:13	1:25	TRANSFORMER FAULT
748	12-Aug-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA 2	GOPANAKOPPA_110	15:26	16:53	1:27	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
749	12-Aug-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	15:26	23:59	8:33	LINE FAULT
750	12-Aug-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTHI_33KV	13:41	13:42	0:01	LINE CLEAR AVAILED
751	12-Aug-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:35	14:59	2:24	NFBC ISSUED
752	12-Aug-19	BAGALKOT	110	JOG2-SIRSI	SIRSI-110	4:00	15:27	11:27	LINE FAULT
753	12-Aug-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	15:18	16:08	0:50	LINE CLEAR AVAILED
754	12-Aug-19	BAGALKOT	110	110/11KV,HV2	RON_110	18:02	18:10	0:08	TRANSFORMER FAULT
755	12-Aug-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:00	7:05	7:05	LINE CLEAR AVAILED
756	12-Aug-19	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	16:22	17:12	0:50	LINE CLEAR AVAILED
757	12-Aug-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	4:20	4:54	0:34	LINE FAULT
758	12-Aug-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	7:18	7:23	0:05	LOAD CHANGEVER
759	12-Aug-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	7:18	7:23	0:05	LOAD CHANGEVER
760	12-Aug-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	15:26	15:40	0:14	LOAD CHANGEVER
761	12-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	15:58	15:59	0:01	LOAD CHANGEVER
762	12-Aug-19	BENGALURU	66	HV1	NALLIMARADANAHALLI	22:20	22:30	0:10	TRANSFORMER FAULT
763	12-Aug-19	BENGALURU	66	HV2	T BEGUR	18:59	19:05	0:05	TRANSFORMER FAULT
764	12-Aug-19	GULBARGA	220	HV2	HUMNABAD_220	17:15	19:05	1:50	LINE CLEAR AVAILED
765	12-Aug-19	GULBARGA	110	KOLHAR-SHAHISLR	KOLHAR_110	6:05	6:10	0:05	LINE FAULT
766	12-Aug-19	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	18:43	18:45	0:02	LINE CLEAR AVAILED
767	12-Aug-19	GULBARGA	66	HV1	TAMBRAHALLI_66	7:40	8:30	0:50	LINE CLEAR AVAILED
768	12-Aug-19	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIRHADAGALLI_66	1:30	1:36	0:06	LINE FAULT
769	12-Aug-19	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66	10:45	10:55	0:10	LINE CLEAR AVAILED
770	12-Aug-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALLI_66	15:40	15:45	0:05	LINE FAULT
771	12-Aug-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:07	7:07	LINE CLEAR AVAILED
772	12-Aug-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:54	23:59	0:05	HAND TRIPPED
773	12-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	11:47	22:54	11:07	LINE CLEAR AVAILED
774	12-Aug-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	0:00	11:47	11:47	LINE CLEAR AVAILED
775	12-Aug-19	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	0:00	20:49	20:49	LINE FAULT
776	12-Aug-19	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	17:21	19:38	2:17	LINE CLEAR AVAILED
777	12-Aug-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	17:21	19:38	2:17	LINE CLEAR AVAILED
778	12-Aug-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	0:00	20:44	20:44	LINE FAULT
779	12-Aug-19	HASSAN	110	HV4	PUTTUR_110	11:13	12:40	1:27	TRANSFORMER FAULT
780	12-Aug-19	HASSAN	110	HV2	HALADY_110	0:00	13:03	13:03	LINE CLEAR AVAILED
781	12-Aug-19	HASSAN	110	HV2	HALADY_110	13:23	13:33	0:10	HAND TRIPPED
782	12-Aug-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	13:13	13:45	0:32	LINE CLEAR AVAILED
783	12-Aug-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:30	15:38	0:08	LINE FAULT
784	12-Aug-19	HASSAN	66	HV2	KANDLI_66	11:51	13:00	1:09	LINE CLEAR AVAILED
785	12-Aug-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	14:45	15:20	0:34	LINE CLEAR AVAILED
786	12-Aug-19	MYSORE	66	HV1	KABHALLY_66	11:00	12:10	1:10	LINE CLEAR AVAILED
787	12-Aug-19	MYSORE	66	KUSHALANAGARA-SOMWARPETE	SOMWARPETE_33	13:45	14:23	0:37	LINE FAULT
788	12-Aug-19	MYSORE	66	HV1	MADIKERI_66	11:12	14:32	3:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
789	12-Aug-19	MYSORE	66	HV2	SANTHESARAGUR_66	14:23	14:53	0:30	LINE CLEAR AVAILED
790	12-Aug-19	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	15:12	16:20	1:08	LINE CLEAR AVAILED
791	12-Aug-19	TUMKUR	110	TR-1	TURUVEKERE_110	19:06	19:17	0:10	TRANSFORMER FAULT
792	12-Aug-19	TUMKUR	110	TR-1	TURUVEKERE_110	23:31	23:37	0:05	TRANSFORMER FAULT
793	12-Aug-19	TUMKUR	66	TR-1	KORA_66	19:29	19:36	0:07	TRANSFORMER FAULT
794	12-Aug-19	TUMKUR	66	TR-2	MAVINAKATTE_66	12:04	12:22	0:17	LINE CLEAR AVAILED
795	12-Aug-19	TUMKUR	66	TR-1	TUMKUR_66	17:15	18:02	0:46	TRANSFORMER FAULT