

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 31.12.2019 TO 06.01.2020**

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	31-Dec-2019	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	7:15	7:26	0:11	LOAD CURTAILMENT
2	31-Dec-2019	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	0:00	14:12	14:12	LINE CLEAR AVAILED
3	31-Dec-2019	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	10:18	10:32	0:14	LINE FAULT
4	31-Dec-2019	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	10:51	18:32	7:41	LINE CLEAR AVAILED
5	31-Dec-2019	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	15:23	18:33	3:10	LINE CLEAR AVAILED
6	31-Dec-2019	BAGALKOT	110	BIDNAL-HUBLI2	BIDNAL_220	11:53	13:46	1:53	LINE CLEAR AVAILED
7	31-Dec-2019	BAGALKOT	220	BELGAUM-CHIKKODI1	BIELGAUM_220	11:18	12:07	0:49	LINE CLEAR AVAILED
8	31-Dec-2019	BAGALKOT	220	BELGAUM-CHIKKODI2	BIELGAUM_220	12:08	12:59	0:51	LINE CLEAR AVAILED
9	31-Dec-2019	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	13:03	14:28	1:25	LINE CLEAR AVAILED
10	31-Dec-2019	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	9:01	11:45	2:44	LINE CLEAR AVAILED
11	31-Dec-2019	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	7:15	8:18	1:03	LOAD CURTAILMENT
12	31-Dec-2019	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33,BASAPUR_33	7:15	7:23	0:08	LOAD CURTAILMENT
13	31-Dec-2019	BAGALKOT	110	110/33KV,HV2&HV3	HANGAL_110,BHOMANAHALLI_33,BEL AGALPETE_33,AKKIHALURU_33,LAXMI PURA_33	11:26	11:34	0:08	TRANSFORMER FAULT
14	31-Dec-2019	BAGALKOT	110	110/11KV,HV1	TODALBAGAI_110	7:41	7:47	0:06	LOAD CURTAILMENT
15	31-Dec-2019	BAGALKOT	220	NAGJARI3-HUBLI	HUBLI_220	16:03	16:23	0:20	LINE FAULT
16	31-Dec-2019	BAGALKOT	110	110/11KV,HV1	SOUDATTI_110	10:09	10:11	0:02	TRANSFORMER FAULT
17	31-Dec-2019	BAGALKOT	110	110/11KV,HV3	SOUDATTI_110,AMEENBAVI_33,JACK WELL_33	10:09	10:12	0:03	TRANSFORMER FAULT
18	31-Dec-2019	BAGALKOT	110	ENERCON1&2-SOUDATTI	SOUDATTI_110	10:09	10:30	0:21	LINE FAULT
19	31-Dec-2019	BAGALKOT	110	110/11KV,HV2	SAVALGI_110	7:15	7:29	0:14	LOAD CURTAILMENT
20	31-Dec-2019	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	7:14	7:27	0:13	LOAD CURTAILMENT
21	31-Dec-2019	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	7:41	7:43	0:02	LOAD CURTAILMENT
22	31-Dec-2019	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	10:43	16:33	5:50	LINE CLEAR AVAILED
23	31-Dec-2019	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	11:20	11:41	0:21	MAIN SUPPLY FAILURE
24	31-Dec-2019	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	11:52	12:24	0:32	MAIN SUPPLY FAILURE
25	31-Dec-2019	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	11:20	11:41	0:21	MAIN SUPPLY FAILURE
26	31-Dec-2019	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	11:52	12:49	0:57	MAIN SUPPLY FAILURE
27	31-Dec-2019	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	11:20	11:50	0:30	MAIN SUPPLY FAILURE
28	31-Dec-2019	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	11:51	12:05	0:14	MAIN SUPPLY FAILURE

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
29	31-Dec-2019	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:14	9:20	0:06	LINE FAULT
30	31-Dec-2019	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:22	9:40	0:17	LINE FAULT
31	31-Dec-2019	BENGALURU	66	CHANDRAPPA CIRCLE - KUMBLAGODU	CHANDRAPPA CIRCLE	14:53	16:13	1:19	LINE CLEAR AVAILED
32	31-Dec-2019	BENGALURU	66	HV1	SURYNAGAR	13:56	14:52	0:55	LINE CLEAR AVAILED
33	31-Dec-2019	BENGALURU	66	HV1	VIJAYANAGARA	11:20	11:30	0:10	LOAD CHANGE OVER
34	31-Dec-2019	BENGALURU	66	HV2	KADUGODI	13:04	13:32	0:27	LINE CLEAR AVAILED
35	31-Dec-2019	BENGALURU	66	HV1	DEVANAHALLI	18:25	18:36	0:11	LINE CLEAR AVAILED
36	31-Dec-2019	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	18:40	18:50	0:10	LOAD CHANGE OVER
37	31-Dec-2019	BENGALURU	66	BRINDAVANA - NELAKADRENAHALLI	NELAKADRENAHALLI	12:15	12:40	0:25	LOAD CHANGE OVER
38	31-Dec-2019	BENGALURU	66	HV1	CHANDAPURA	11:27	12:06	0:39	LINE CLEAR AVAILED
39	31-Dec-2019	BENGALURU	66	HV2	CHANDAPURA	12:06	12:58	0:52	LINE CLEAR AVAILED
40	31-Dec-2019	BENGALURU	66	HV2	SULIBELE	16:14	16:46	0:32	LINE CLEAR AVAILED
41	31-Dec-2019	BENGALURU	66	HV2	VIJAYAPURA	11:35	13:10	1:35	LINE CLEAR AVAILED
42	31-Dec-2019	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	9:01	11:14	2:13	LINE FAULT
43	31-Dec-2019	KALABURAGI	220	MALLAT-LINGASUGUR	LINGASUGUR_220	9:35	14:10	4:35	NFBC ISSUED
44	31-Dec-2019	KALABURAGI	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,KAMALAPUR_110,METRI_110,RBNSFACTORY	4:18	4:32	0:14	LINE FAULT
45	31-Dec-2019	KALABURAGI	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	3:00	3:11	0:11	LINE FAULT
46	31-Dec-2019	KALABURAGI	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	4:31	4:40	0:09	LINE FAULT
47	31-Dec-2019	KALABURAGI	110	HV3,HV4	YELBURGA_110	7:37	8:04	0:27	LOAD CURTAILMENT
48	31-Dec-2019	KALABURAGI	110	HUMNABAD220-HUMNABAD1	HUMNABAD_110	7:50	8:06	0:16	LINE FAULT
49	31-Dec-2019	KALABURAGI	110	HV3	LADHA_110	16:45	18:00	1:15	LINE CLEAR AVAILED
50	31-Dec-2019	KALABURAGI	110	SEDAM-KURKUNTA	KURKUNTA_110	16:24	17:14	0:50	LINE CLEAR AVAILED
51	31-Dec-2019	KALABURAGI	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	7:50	8:05	0:15	LINE FAULT
52	31-Dec-2019	KALABURAGI	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	4:30	4:40	0:10	LINE FAULT
53	31-Dec-2019	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	23:44	23:59	0:15	LINE FAULT
54	31-Dec-2019	HASSAN	220	KEMAR-KAVOOR3	KEMAR_220	23:44	23:59	0:15	LINE FAULT
55	31-Dec-2019	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	17:35	18:05	0:30	LINE CLEAR AVAILED
56	31-Dec-2019	HASSAN	110	BARANG-ANVATTI	BARANGI_110	17:35	18:05	0:30	LINE CLEAR AVAILED
57	31-Dec-2019	HASSAN	110	HV1	BRAHMAVARA_110	7:15	7:45	0:30	LOAD CURTAILMENT
58	31-Dec-2019	HASSAN	110	HV2	GANDASI_110	7:14	7:29	0:15	LOAD CURTAILMENT
59	31-Dec-2019	HASSAN	110	HV1	HALADY_110	7:15	7:37	0:22	LOAD CURTAILMENT
60	31-Dec-2019	HASSAN	110	HV1	JAVAGAL_110	7:14	7:24	0:10	LOAD CURTAILMENT
61	31-Dec-2019	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	7:23	8:06	0:43	LINE FAULT
62	31-Dec-2019	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	7:13	7:23	0:10	LINE FAULT
63	31-Dec-2019	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	7:23	12:03	4:40	LINE FAULT
64	31-Dec-2019	HASSAN	110	HV1	KEMAR_220	12:25	13:20	0:55	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
65	31-Dec-2019	HASSAN	110	SAGARA-JST1	SAGARA_110	11:19	14:24	3:05	LINE CLEAR AVAILED
66	31-Dec-2019	HASSAN	110	HV1	SHIVAPURA_110	11:57	14:11	2:14	LINE CLEAR AVAILED
67	31-Dec-2019	HASSAN	66	HV2	CHANNARAYAPATNA_66	7:14	7:35	0:21	LOAD CURTAILMENT
68	31-Dec-2019	HASSAN	66	HV1	MATTANAVILE_66	10:20	11:20	1:00	LINE CLEAR AVAILED
69	31-Dec-2019	HASSAN	66	HV2	MATTANAVILE_66	9:05	10:20	1:15	LINE CLEAR AVAILED
70	31-Dec-2019	HASSAN	66	MRSSHM-DVG2	MRSMG_220	16:16	16:24	0:08	LINE FAULT
71	31-Dec-2019	HASSAN	66	MRSSHM-DVG2	MRSMG_220	16:31	16:36	0:05	LINE FAULT
72	31-Dec-2019	HASSAN	66	HV2	RAMESHWARNAGARA_66	7:15	7:30	0:15	LOAD CURTAILMENT
73	31-Dec-2019	HASSAN	66	RMWNGR-KIADB	RAMESHWARNAGARA_66	11:30	11:40	0:10	MAIN SUPPLY FAILURE
74	31-Dec-2019	HASSAN	66	RMWNGR-KIADB	RAMESHWARNAGARA_66	12:20	12:30	0:10	MAIN SUPPLY FAILURE
75	31-Dec-2019	HASSAN	66	RMWNGR-KIADB	RAMESHWARNAGARA_66	14:15	14:25	0:10	MAIN SUPPLY FAILURE
76	31-Dec-2019	HASSAN	66	HV2	SALAGAME_66	7:40	7:56	0:16	LOAD CURTAILMENT
77	31-Dec-2019	HASSAN	66	HV2	UDAYAPURA_66	12:37	12:38	0:01	TRANSFORMER FAULT
78	31-Dec-2019	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	19:19	19:37	0:18	LINE FAULT
79	31-Dec-2019	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	10:34	15:43	5:08	LINE CLEAR AVAILED
80	31-Dec-2019	MYSORE	66	HV2	BILIKERE_66	12:05	12:16	0:11	TRANSFORMER FAULT
81	31-Dec-2019	MYSORE	66	HV2	BOOKANAKERE_66	7:14	7:24	0:09	LOAD CURTAILMENT
82	31-Dec-2019	MYSORE	66	HV1	CHINAKURALI_66	10:09	16:19	6:09	LINE CLEAR AVAILED
83	31-Dec-2019	MYSORE	66	HV2	CHINAKURALI_66	7:14	7:24	0:09	LOAD CURTAILMENT
84	31-Dec-2019	MYSORE	66	HV2	CHINAKURALI_66	10:09	13:47	3:37	LINE CLEAR AVAILED
85	31-Dec-2019	MYSORE	66	HV2	DEVANOORNGUDU_66	12:50	12:59	0:08	TRANSFORMER FAULT
86	31-Dec-2019	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:31	13:45	2:13	LINE CLEAR AVAILED
87	31-Dec-2019	MYSORE	66	HV2	ELAVALA_66	7:14	7:31	0:16	LOAD CURTAILMENT
88	31-Dec-2019	MYSORE	66	HV1	HANAGODU_66	7:14	7:38	0:23	LOAD CURTAILMENT
89	31-Dec-2019	MYSORE	66	HV2	HANNUR_66	7:14	7:44	0:29	LOAD CURTAILMENT
90	31-Dec-2019	MYSORE	66	HV2	KIRUGAVALU_66	7:15	7:46	0:31	LOAD CURTAILMENT
91	31-Dec-2019	MYSORE	66	HV1	KOPPA_66	10:02	17:52	7:50	LINE CLEAR AVAILED
92	31-Dec-2019	MYSORE	66	HV2	KOPPA_66	10:02	17:53	7:51	LINE CLEAR AVAILED
93	31-Dec-2019	MYSORE	66	HV1	MADDUR_66	7:14	7:28	0:14	LOAD CURTAILMENT
94	31-Dec-2019	MYSORE	66	MEGALAPURA-SFC	THUMBLA_66 CHIDRAVALLI_66	10:03	10:12	0:08	LINE FAULT
95	31-Dec-2019	MYSORE	66	HV1	PANDAVAPURA_66	7:15	7:47	0:32	LOAD CURTAILMENT
96	31-Dec-2019	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	11:32	12:06	0:33	LINE CLEAR AVAILED
97	31-Dec-2019	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	14:49	15:01	0:12	LINE FAULT
98	31-Dec-2019	TUMKUR	66	TR-2	BALENAHALLI_66	17:43	18:03	0:20	TRANSFORMER FAULT
99	31-Dec-2019	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	13:41	18:47	5:05	LINE CLEAR AVAILED
100	31-Dec-2019	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	10:41	10:47	0:05	MAIN SUPPLY FAILURE
101	31-Dec-2019	TUMKUR	66	TR-2	HALURAMESHWARA_66	10:04	12:55	2:51	LINE CLEAR AVAILED
102	31-Dec-2019	TUMKUR	66	TR-1	HANAGAL_66	11:54	14:08	2:14	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
103	31-Dec-2019	TUMKUR	66	TR-2	HARIYABBE_66	8:12	8:20	0:07	TRANSFORMER FAULT
104	31-Dec-2019	TUMKUR	66	TR-2	HIREHALLY_66	12:31	12:45	0:14	TRANSFORMER FAULT
105	31-Dec-2019	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	3:24	3:35	0:10	LINE FAULT
106	31-Dec-2019	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	13:43	18:22	4:39	LINE CLEAR AVAILED
107	31-Dec-2019	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	10:23	15:43	5:20	LINE CLEAR AVAILED
108	31-Dec-2019	TUMKUR	66	TR-2	LINGDHALLI_66	17:10	17:11	0:01	MAIN SUPPLY FAILURE
109	31-Dec-2019	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	11:32	12:06	0:34	LINE CLEAR AVAILED
110	31-Dec-2019	TUMKUR	66	TR-1	MYLANAHALLI_66	8:34	8:42	0:07	TRANSFORMER FAULT
111	31-Dec-2019	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	7:00	10:37	3:37	LINE FAULT
112	31-Dec-2019	TUMKUR	66	THALLAK 220kv- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	5:42	9:25	3:42	LINE CLEAR AVAILED
113	31-Dec-2019	TUMKUR	66	TR-1	PANDARAHALLI_66	7:41	7:46	0:04	TRANSFORMER FAULT
114	31-Dec-2019	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	11:27	12:09	0:41	LINE FAULT
115	31-Dec-2019	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	13:09	13:57	0:48	LINE FAULT
116	31-Dec-2019	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53	11:12	0:19	LINE FAULT
117	1-Jan-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	15:50	16:10	0:20	LINE CLEAR AVAILED
118	1-Jan-2020	BAGALKOT	110	110/11KV,HV2	RON_110	11:23	11:34	0:11	TRANSFORMER FAULT
119	1-Jan-2020	BAGALKOT	110	110/33KV,HV1	MAHALINGAPUR_220,DEMPO DIARY_33,JAGADAL_33	3:45	12:05	8:20	TRANSFORMER FAULT
120	1-Jan-2020	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	9:39	23:59	14:20	LINE CLEAR AVAILED
121	1-Jan-2020	BAGALKOT	220	SIRSI-HUBLI 2	SIRSI_220	9:40	17:14	7:34	LINE CLEAR AVAILED
122	1-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS(EHT)	16:17	16:27	0:10	LINE FAULT
123	1-Jan-2020	BENGALURU	66	HAROBELA - KODIHALLI	HUNASANAHALLI, BIJJAHALLI	16:55	17:10	0:15	LINE FAULT
124	1-Jan-2020	BENGALURU	66	HV2	KYALANUR	12:45	15:15	2:30	LINE CLEAR AVAILED
125	1-Jan-2020	BENGALURU	66	LAKSMIPURA - SOMAGAYAHALLI	SOMAGAYAHALLI	18:08	18:16	0:07	LINE FAULT
126	1-Jan-2020	BENGALURU	66	NELAMANGALA 66 - SRS PEENYA	NELAMANGALA 66	7:59	8:03	0:04	LOAD CHANGE OVER
127	1-Jan-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPETE	NELAMANGALA 66	9:09	9:24	0:15	LOAD CHANGE OVER
128	1-Jan-2020	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	10:40	11:08	0:28	LINE CLEAR AVAILED
129	1-Jan-2020	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	11:43	11:48	0:05	LOAD CHANGE OVER
130	1-Jan-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-1 - NAGANATHPURA	ELECTRONIC CITY PH-2 SEC-1	12:05	12:23	0:18	LOAD CHANGE OVER
131	1-Jan-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-1 - KEONIC CITY	ELECTRONIC CITY PH-2 SEC-1	16:07	16:48	0:41	LOAD CHANGE OVER
132	1-Jan-2020	BENGALURU	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	7:26	7:54	0:28	LINE CLEAR AVAILED
133	1-Jan-2020	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	9:06	9:12	0:06	LINE CLEAR AVAILED
134	1-Jan-2020	BENGALURU	220	SOMANAHALLI 220 - VRISHABHAVATHI 220	VRISHABHAVATHI 220	10:39	10:50	0:11	LINE FAULT
135	1-Jan-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	18:12	18:26	0:14	LINE FAULT

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
136	1-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	10:40	11:02	0:22	LINE CLEAR AVAILED
137	1-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO,VIJAYANAGARA	10:40	11:17	0:37	LINE CLEAR AVAILED
138	1-Jan-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	0:00	1:17	1:17	LINE FAULT
139	1-Jan-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	12:03	15:29	3:26	LINE CLEAR AVAILED
140	1-Jan-2020	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	15:35	16:25	0:50	LINE CLEAR AVAILED
141	1-Jan-2020	HASSAN	220	YALAGU-SGS2	TALAGUPPA_400	11:10	16:28	5:18	LINE CLEAR AVAILED
142	1-Jan-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:00	12:20	0:20	HAND TRIPPED
143	1-Jan-2020	HASSAN	110	HV2	KADUR_220	10:00	11:10	1:10	LINE CLEAR AVAILED
144	1-Jan-2020	HASSAN	220	KEMAR-KAVOOR3	KEMAR_220	0:00	1:17	1:17	LINE FAULT
145	1-Jan-2020	HASSAN	110	HV2	KEMAR_220	16:56	17:43	0:47	LINE CLEAR AVAILED
146	1-Jan-2020	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	11:59	12:20	0:21	MAIN SUPPLY FAILURE
147	1-Jan-2020	HASSAN	220	HV1	SHIRALKOPPA_220	12:00	23:59	11:59	LINE CLEAR AVAILED
148	1-Jan-2020	HASSAN	110	LV1	SHIRALKOPPA_220	11:58	23:59	12:01	LINE CLEAR AVAILED
149	1-Jan-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:33	11:40	0:07	HAND TRIPPED
150	1-Jan-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:54	12:17	0:23	HAND TRIPPED
151	1-Jan-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:43	12:16	1:33	LINE CLEAR AVAILED
152	1-Jan-2020	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	13:58	15:20	1:22	LINE CLEAR AVAILED
153	1-Jan-2020	HASSAN	66	HV2	SALAGAME_66	14:59	16:08	1:09	LINE CLEAR AVAILED
154	1-Jan-2020	KALABURAGI	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	0:29	0:41	0:12	LINE FAULT
155	1-Jan-2020	KALABURAGI	220	SHAHAPUR-RTPS2	SHAHAPUR_220	6:01	6:45	0:44	LINE FAULT
156	1-Jan-2020	KALABURAGI	110	HV2	HATTI_110	10:36	10:44	0:08	TRANSFORMER FAULT
157	1-Jan-2020	KALABURAGI	110	HV3	LADHA_110	8:40	8:55	0:15	LINE CLEAR AVAILED
158	1-Jan-2020	KALABURAGI	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	19:46	19:54	0:08	LINE FAULT
159	1-Jan-2020	KALABURAGI	110	SHAHAPUR-KBJNL	KBJNL_110	21:18	21:24	0:06	LINE FAULT
160	1-Jan-2020	KALABURAGI	110	HV3	LADHA_110	17:00	17:10	0:10	LINE CLEAR AVAILED
161	1-Jan-2020	KALABURAGI	110	MALLAT-ALKOD	ALKOD_110	21:02	21:07	0:05	LINE FAULT
162	1-Jan-2020	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	11:55	12:01	0:05	LINE FAULT
163	1-Jan-2020	MYSORE	66	HV1	DUNDANAHALLI_66	7:11	7:20	0:09	TRANSFORMER FAULT
164	1-Jan-2020	MYSORE	66	HOTAGALLI-DATTAGALLI	DATTAGALLY_66	13:12	16:37	3:24	LINE FAULT
165	1-Jan-2020	MYSORE	66	HV1	KIADBMANDYA_66	17:28	18:22	0:54	LINE CLEAR AVAILED
166	1-Jan-2020	MYSORE	66	HV1	KIADBMANDYA_66	14:01	14:06	0:04	TRANSFORMER FAULT
167	1-Jan-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	22:46	22:55	0:09	LINE FAULT
168	1-Jan-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	11:35	12:02	0:27	LINE CLEAR AVAILED
169	1-Jan-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	17:50	18:00	0:09	HAND TRIPPED
170	1-Jan-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	5:35	5:48	0:13	HAND TRIPPED
171	1-Jan-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	14:33	14:37	0:04	HAND TRIPPED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
172	1-Jan-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	16:23	16:29	0:06	HAND TRIPPED
173	1-Jan-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	18:04	18:12	0:08	HAND TRIPPED
174	1-Jan-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	8:22	8:31	0:08	TRANSFORMER FAULT
175	1-Jan-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	9:19	9:24	0:05	TRANSFORMER FAULT
176	1-Jan-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	18:26	18:29	0:02	TRANSFORMER FAULT
177	1-Jan-2020	TUMKUR	66	TR-2	CHELURU_66	14:55	15:35	0:39	LINE CLEAR AVAILED
178	1-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:33	9:48	0:14	LINE FAULT
179	1-Jan-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	13:50	13:59	0:09	TRANSFORMER FAULT
180	1-Jan-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:59	13:08	0:09	TRANSFORMER FAULT
181	1-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	13:58	14:08	0:10	LINE FAULT
182	1-Jan-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	12:40	14:38	1:58	LINE CLEAR AVAILED
183	1-Jan-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	12:40	13:27	0:46	LINE FAULT
184	1-Jan-2020	TUMKUR	66	TR-1	TUMKUR_66	7:33	8:01	0:28	HAND TRIPPED
185	1-Jan-2020	TUMKUR	66	TR-2	TUMKUR_66	7:33	8:01	0:28	HAND TRIPPED
186	2-Jan-2020	BAGALKOT	110	KN SOLAR-ATHARGA	ATHARGA_110	16:35	23:59	7:24	LINE FAULT
187	2-Jan-2020	BAGALKOT	110	MAMADAPUR-BABLESHWAR	BABLESHWAR_110	17:20	17:40	0:20	HAND TRIPPED
188	2-Jan-2020	BAGALKOT	110	MAMADAPUR-BABLESHWAR	BABLESHWAR_110	20:28	20:31	0:03	HAND TRIPPED
189	2-Jan-2020	BAGALKOT	110	110/11KV,HV1&HV2	BABLESHWAR_110	17:20	17:40	0:20	HAND TRIPPED
190	2-Jan-2020	BAGALKOT	110	110/11KV,HV1&HV2	BABLESHWAR_110	20:28	20:31	0:03	HAND TRIPPED
191	2-Jan-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:06	18:42	8:36	LINE CLEAR AVAILED
192	2-Jan-2020	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	10:28	18:26	7:58	LINE CLEAR AVAILED
193	2-Jan-2020	BAGALKOT	110	110/11KV,HV2	CHIKKODI_110,KERUR_33,KAROSHI_33	17:53	18:19	0:26	TRANSFORMER FAULT
194	2-Jan-2020	BAGALKOT	110	SHARAVATHI2-SIRSI	SIRSI_220	9:20	16:41	7:21	LINE CLEAR AVAILED
195	2-Jan-2020	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	21:46	22:28	0:42	TRANSFORMER FAULT
196	2-Jan-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	22:21	22:37	0:16	HAND TRIPPED
197	2-Jan-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	22:22	22:38	0:16	HAND TRIPPED
198	2-Jan-2020	BAGALKOT	110	MAHALINGAPUR-ITNAL	ITNAL_110	22:21	22:38	0:17	HAND TRIPPED
199	2-Jan-2020	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	13:33	23:59	10:26	LINE CLEAR AVAILED
200	2-Jan-2020	BAGALKOT	110	HUNGUND-JINDAL	JINDAL_110(EHT)	7:03	7:31	0:28	LINE FAULT
201	2-Jan-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:52	14:16	0:24	HAND TRIPPED
202	2-Jan-2020	BAGALKOT	220	NAGJHARI 1-HUBLI	HUBLI_220	14:37	15:23	0:46	LINE FAULT
203	2-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL(EHT)	16:25	16:45	0:20	LINE FAULT
204	2-Jan-2020	BENGALURU	220	HV2	T K HALLI 220	13:52	13:58	0:06	TRANSFORMER FAULT
205	2-Jan-2020	BENGALURU	66	T K HALLI 220 - MANDYA 1	K M DODDI, K K DODDI, KIADB MANDYA, MADDUR, MANDYA	13:52	14:08	0:16	MAIN SUPPLY FAILURE

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
206	2-Jan-2020	BENGALURU	66	T K HALLI 220 - MANDYA 2	K M DODDI, K K DODDI, KIADB MANDYA, MADDUR, MANDYA	13:52	14:08	0:16	MAIN SUPPLY FAILURE
207	2-Jan-2020	BENGALURU	66	T K HALLI 220 - SHIMSHA 1	T K HALLI 220	13:52	14:08	0:16	LINE FAULT
208	2-Jan-2020	BENGALURU	66	T K HALLI 220 - SHIMSHA 2	T K HALLI 220	13:52	14:08	0:16	LINE FAULT
209	2-Jan-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	17:37	20:43	3:06	LINE FAULT
210	2-Jan-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:15	16:40	7:25	LINE CLEAR AVAILED
211	2-Jan-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:48	16:08	0:20	MAIN SUPPLY FAILURE
212	2-Jan-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:48	16:13	0:25	MAIN SUPPLY FAILURE
213	2-Jan-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	15:49	16:16	0:27	MAIN SUPPLY FAILURE
214	2-Jan-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:47	16:07	0:20	LINE FAULT
215	2-Jan-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:47	16:12	0:25	LINE FAULT
216	2-Jan-2020	HASSAN	110	HV3	PUTTUR_110	18:44	18:59	0:15	TRANSFORMER FAULT
217	2-Jan-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	10:44	18:05	7:21	LINE CLEAR AVAILED
218	2-Jan-2020	HASSAN	66	HV2	HALEBEEDU_66	13:21	14:39	1:18	LINE CLEAR AVAILED
219	2-Jan-2020	HASSAN	66	HV1	KANDLI_66	11:17	13:13	1:56	LINE CLEAR AVAILED
220	2-Jan-2020	HASSAN	66	MATTANV-CRPATNA	MATTNAVILE_66	11:52	15:28	3:36	NFBC ISSUED
221	2-Jan-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	11:05	12:33	1:28	LINE CLEAR AVAILED
222	2-Jan-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:33	9:46	0:13	MAIN SUPPLY FAILURE
223	2-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	12:34	12:38	0:04	TRANSFORMER FAULT
224	2-Jan-2020	KALABURAGI	220	MALLAT-LINGASUGUR	MALLAT_220	5:40	8:00	2:20	LINE FAULT
225	2-Jan-2020	KALABURAGI	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	5:40	6:31	0:51	LINE FAULT
226	2-Jan-2020	KALABURAGI	220	SEDAM-RTPS1	SEDAM_220	4:22	10:53	6:31	LINE FAULT
227	2-Jan-2020	KALABURAGI	220	SEDAM-TANDOOR	KURKUNTA_110	13:48	17:30	3:42	LINE CLEAR AVAILED
228	2-Jan-2020	KALABURAGI	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	0:44	0:59	0:15	LINE FAULT
229	2-Jan-2020	KALABURAGI	110	GABUR-DEODURGA	DEODURGA_110	3:31	3:33	0:02	LINE FAULT
230	2-Jan-2020	KALABURAGI	110	HATTI-SOMANAMARDI IPP	HATTI_110	5:38	5:55	0:17	LINE FAULT
231	2-Jan-2020	KALABURAGI	110	HATTI-LINGASUGUR	HATTI_110	5:40	5:53	0:13	MAIN SUPPLY FAILURE
232	2-Jan-2020	KALABURAGI	110	SINDHANOOR-NIRLOOPI_IPP	SINDHANOOR_220	5:50	6:10	0:20	LINE FAULT
233	2-Jan-2020	KALABURAGI	110	HV3 & HV4	YELBURGA_110	10:35	15:05	4:30	LINE CLEAR AVAILED
234	2-Jan-2020	KALABURAGI	110	HV4	YELBURGA_110	14:02	19:25	5:23	LINE CLEAR AVAILED
235	2-Jan-2020	KALABURAGI	110	HV4	YELBURGA_110	18:05	18:20	0:15	TRANSFORMER FAULT
236	2-Jan-2020	KALABURAGI	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	21:13	21:28	0:15	LINE FAULT
237	2-Jan-2020	MYSORE	66	HV1	BASARALU_66	10:11	20:30	10:19	LINE CLEAR AVAILED
238	2-Jan-2020	MYSORE	66	HV2	BASARALU_66	11:07	16:56	5:48	LINE CLEAR AVAILED
239	2-Jan-2020	MYSORE	66	HV1	DUNDANAHALLI_66	6:03	6:10	0:06	TRANSFORMER FAULT
240	2-Jan-2020	MYSORE	66	HV1	DUNDANAHALLI_66	9:09	9:19	0:10	TRANSFORMER FAULT
241	2-Jan-2020	MYSORE	66	HV1	DUNDANAHALLI_66	9:38	9:47	0:08	TRANSFORMER FAULT

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
242	2-Jan-2020	MYSORE	66	KRPET 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	4:28	4:32	0:04	LINE FAULT
243	2-Jan-2020	MYSORE	66	HV1	MADDUR_66	13:50	14:06	0:16	HAND TRIPPED
244	2-Jan-2020	MYSORE	66	HV1	MADDUR_66	13:50	14:06	0:16	HAND TRIPPED
245	2-Jan-2020	MYSORE	66	HV1	SANIVARASANTHE_66	15:55	16:00	0:04	LINE CLEAR AVAILED
246	2-Jan-2020	MYSORE	66	SHANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	15:55	16:00	0:04	LINE CLEAR AVAILED
247	2-Jan-2020	MYSORE	66	SHANIVARSANTHE-YESSLUR	SANIVARASANTHE_66	15:55	16:00	0:04	LINE CLEAR AVAILED
248	2-Jan-2020	MYSORE	66	HV1	TARIPURA_66	12:13	14:00	1:47	LINE CLEAR AVAILED
249	2-Jan-2020	MYSORE	66	HV1	K_HONNALGERE_66	13:48	14:01	0:12	HAND TRIPPED
250	2-Jan-2020	MYSORE	66	HV2	K_HONNALGERE_66	13:48	14:01	0:12	HAND TRIPPED
251	2-Jan-2020	MYSORE	66	HV2	KMDODDI_66	14:00	14:06	0:06	HAND TRIPPED
252	2-Jan-2020	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	17:29	17:37	0:07	LINE FAULT
253	2-Jan-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	12:32	13:55	1:23	LINE CLEAR AVAILED
254	2-Jan-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:38	11:48	0:09	HAND TRIPPED
255	2-Jan-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	13:17	15:09	1:51	LINE CLEAR AVAILED
256	2-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	10:45	10:52	0:06	LINE CLEAR AVAILED
257	2-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	15:26	15:37	0:10	LINE CLEAR AVAILED
258	2-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	10:45	10:52	0:06	LINE CLEAR AVAILED
259	2-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	15:26	15:37	0:10	LINE CLEAR AVAILED
260	2-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	13:46	15:24	1:37	LINE CLEAR AVAILED
261	2-Jan-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	6:12	6:16	0:04	TRANSFORMER FAULT
262	2-Jan-2020	TUMKUR	66	DAVANGERE66-DAVANGERE SRS	DAVANAGERE_66	12:37	13:02	0:25	LINE FAULT
263	2-Jan-2020	TUMKUR	66	DAVANGERE66-DAVANGERE SRS	DAVANAGERE_66	15:09	15:28	0:18	LINE FAULT
264	2-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:10	15:25	0:15	LINE FAULT
265	2-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:18	22:30	0:12	LINE FAULT
266	2-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:14	10:21	0:06	HAND TRIPPED
267	2-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:02	12:09	0:07	HAND TRIPPED
268	2-Jan-2020	TUMKUR	66	TR-2	GUTTUR_66	11:15	11:23	0:07	TRANSFORMER FAULT
269	2-Jan-2020	TUMKUR	66	TR-1	HDPUA_66	15:06	15:11	0:04	TRANSFORMER FAULT
270	2-Jan-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	6:50	7:14	0:23	LINE FAULT



SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
271	2-Jan-2020	TUMKUR	66	TR-1	TYAVANAGI_66	7:29	7:57	0:28	LINE CLEAR AVAILED
272	2-Jan-2020	TUMKUR	66	TR-2	TUMKUR_66	14:20	14:23	0:02	TRANSFORMER FAULT
273	2-Jan-2020	TUMKUR	66	TR-2	SASALUHALLA_66	10:41	10:45	0:04	HAND TRIPPED
274	2-Jan-2020	TUMKUR	66	TR-1	KATTIGE_66	8:36	8:40	0:03	TRANSFORMER FAULT
275	3-Jan-2020	BAGALKOT	110	110/11KV,HV1	ANANDANAGAR_110	16:54	17:46	0:52	LINE CLEAR AVAILED
276	3-Jan-2020	BAGALKOT	110	KN SOLAR-ATHARGA	ATHARGA_110	0:00	6:56	6:56	LINE CLEAR AVAILED
277	3-Jan-2020	BAGALKOT	110	BAGLKOT220-GULEDAGUDDA	GULEDAGUDDA_110	7:24	7:31	0:07	LOAD CURTAILMENT
278	3-Jan-2020	BAGALKOT	110	RAIBAG 2-ITNAL	ITNAL_110	12:12	16:18	4:06	LINE CLEAR AVAILED
279	3-Jan-2020	BAGALKOT	110	HIDIKAL2(RAIBAG 1)-ITNAL	ITNAL_110	12:13	16:17	4:04	LINE CLEAR AVAILED
280	3-Jan-2020	BAGALKOT	110	JAMAKHANDI SUGARS-TODALBAGI	TODALBAGI_110	20:15	20:37	0:22	LINE FAULT
281	3-Jan-2020	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	MAHALINGAPUR_220	3:56	4:45	0:49	LINE FAULT
282	3-Jan-2020	BAGALKOT	110	220/110KV,LV1	HUBLI_220	9:40	23:59	14:19	LINE CLEAR AVAILED
283	3-Jan-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:21	17:12	6:51	LINE CLEAR AVAILED
284	3-Jan-2020	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	9:01	15:47	6:46	LINE CLEAR AVAILED
285	3-Jan-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	8:16	8:30	0:14	LINE FAULT
286	3-Jan-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:03	8:07	0:04	LINE FAULT
287	3-Jan-2020	BENGALURU	66	HV1	SIDDLAGHATTA	21:11	21:30	0:18	LINE CLEAR AVAILED
288	3-Jan-2020	BENGALURU	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	15:40	16:03	0:22	LINE FAULT
289	3-Jan-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, SOMANTHPURA, THIMAMPALLI	15:45	17:35	1:50	LINE FAULT
290	3-Jan-2020	BENGALURU	66	HV1	BANASHANKARI	11:55	12:00	0:05	LINE CLEAR AVAILED
291	3-Jan-2020	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	8:05	8:20	0:15	LINE CLEAR AVAILED
292	3-Jan-2020	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	10:05	11:05	1:00	MAIN SUPPLY FAILURE
293	3-Jan-2020	KALABURAGI	220	RTPS-SEDAM1	SEDAM_220	7:30	8:30	1:00	NFBC ISSUED
294	3-Jan-2020	KALABURAGI	220	SHAHPUR-SEDAM	SEDAM_220	3:30	3:54	0:24	LINE FAULT
295	3-Jan-2020	KALABURAGI	220	SHAHPUR-SEDAM	SEDAM_220	3:54	13:46	9:52	NFBC ISSUED
296	3-Jan-2020	KALABURAGI	220	SHAHPUR-SEDAM	SEDAM_220	15:15	18:00	2:45	LINE FAULT
297	3-Jan-2020	KALABURAGI	110	HV2	YELBURGA_110	6:20	6:30	0:10	TRANSFORMER FAULT
298	3-Jan-2020	KALABURAGI	110	HV4	YELBURGA_110	15:47	15:53	0:06	LINE CLEAR AVAILED
299	3-Jan-2020	KALABURAGI	110	RAICHUR-SHAHAPUR 2	GOOGLE_110	7:18	8:30	1:12	LOAD CURTAILMENT
300	3-Jan-2020	KALABURAGI	110	SEDAM-KURKUNTA	KURKUNTA_110	10:49	11:07	0:18	LINE FAULT
301	3-Jan-2020	HASSAN	220	HASSN22- SHANTHIGRAMA	HASSAN_220	15:29	17:35	2:06	LINE CLEAR AVAILED
302	3-Jan-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:30	18:19	7:49	LINE CLEAR AVAILED
303	3-Jan-2020	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMG_220	5:47	10:50	5:03	LINE FAULT
304	3-Jan-2020	HASSAN	110	HV3	PUTTUR_110	17:04	17:12	0:08	TRANSFORMER FAULT

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
305	3-Jan-2020	HASSAN	110	HV3	PUTTUR_110	18:48	18:53	0:05	TRANSFORMER FAULT
306	3-Jan-2020	HASSAN	110	HV2	AJJAMPURA_110	11:53	12:59	1:06	LINE CLEAR AVAILED
307	3-Jan-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:01	16:56	6:55	NFBC ISSUED
308	3-Jan-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:21	13:09	1:48	LINE CLEAR AVAILED
309	3-Jan-2020	MYSORE	66	HV1	BASARALU_66	12:24	13:16	0:52	LINE CLEAR AVAILED
310	3-Jan-2020	MYSORE	66	HV1	BASARALU_66	13:29	13:51	0:21	LINE CLEAR AVAILED
311	3-Jan-2020	MYSORE	66	HV2	ELAVALA_66	13:55	14:33	0:37	LINE CLEAR AVAILED
312	3-Jan-2020	MYSORE	66	HD KOTE-KADKOLA	HDKOTE_66 ANTHARSANTHE_66	8:50	9:05	0:15	LINE FAULT
313	3-Jan-2020	MYSORE	66	HD KOTE-KADKOLA	HDKOTE_66 ANTHARSANTHE_66	9:15	9:27	0:12	LINE FAULT
314	3-Jan-2020	MYSORE	66	HD KOTE-KADKOLA	HDKOTE_66 ANTHARSANTHE_66	10:32	10:43	0:10	LINE FAULT
315	3-Jan-2020	MYSORE	66	HOOTAGALLI-DATAGALLI	RKNAGARA_66 DATTAGALLY_66	13:29	23:59	10:29	LINE FAULT
316	3-Jan-2020	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 CHANDRAWADI_66 B MATKERE_66, SANTHESARAGUR_66	14:00	14:03	0:03	HAND TRIPPED
317	3-Jan-2020	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 CHANDRAWADI_66 B MATKERE_66, SANTHESARAGUR_66	16:24	16:49	0:24	HAND TRIPPED
318	3-Jan-2020	MYSORE	66	KADAKOLA-SARAGUR 1	HDKOTE_66 ANTHARSANTHE_66 HAMPAPURA(K)_66 JAIPUR_66	11:48	11:52	0:04	HAND TRIPPED
319	3-Jan-2020	MYSORE	66	KADAKOLA-SARAGUR 1	HDKOTE_66 ANTHARSANTHE_66 HAMPAPURA(K)_66 JAIPUR_66	16:27	16:28	0:01	HAND TRIPPED
320	3-Jan-2020	MYSORE	66	HV1	KIADBMANDYA_66	11:36	12:14	0:38	LINE CLEAR AVAILED
321	3-Jan-2020	MYSORE	66	PERIYAPATNA -PONNAMPETE	PONNAMPET_66 HANAGODU_66 VIRAJPET_66	6:00	6:10	0:10	LINE FAULT
322	3-Jan-2020	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	14:02	14:39	0:37	LINE CLEAR AVAILED
323	3-Jan-2020	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:33	14:38	4:05	LINE CLEAR AVAILED
324	3-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	7:15	7:27	0:11	LINE CLEAR AVAILED
325	3-Jan-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	11:02	11:15	0:13	LINE CLEAR AVAILED
326	3-Jan-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	16:24	16:52	0:27	LINE CLEAR AVAILED
327	3-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	9:49	10:11	0:22	LINE CLEAR AVAILED
328	3-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	7:15	7:28	0:12	LINE CLEAR AVAILED
329	3-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	9:49	10:11	0:22	LINE CLEAR AVAILED
330	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	11:06	12:06	0:59	HAND TRIPPED
331	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	9:06	10:06	1:00	LINE CLEAR AVAILED
332	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	10:06	11:06	1:00	LINE CLEAR AVAILED
333	3-Jan-2020	TUMKUR	66	TR-1	ANCHEPALYA_220	14:02	14:41	0:39	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
334	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	13:56	14:42	0:45	HAND TRIPPED
335	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	15:57	16:11	0:14	HAND TRIPPED
336	3-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:58	17:26	1:27	LINE FAULT
337	3-Jan-2020	TUMKUR	66	TR-3	AVAREGERE_66	20:07	20:08	0:01	TRANSFORMER FAULT
338	3-Jan-2020	TUMKUR	66	TR-1	BADAVANAHALLI_66	13:38	13:54	0:15	LINE CLEAR AVAILED
339	3-Jan-2020	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	17:12	17:29	0:17	MAIN SUPPLY FAILURE
340	3-Jan-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	7:09	7:25	0:15	LOAD CURTAILMENT
341	3-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	7:48	8:51	1:02	LOAD CURTAILMENT
342	3-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	7:09	7:27	0:17	LOAD CURTAILMENT
343	3-Jan-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	7:09	7:27	0:17	LINE FAULT
344	3-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:01	9:07	0:06	HAND TRIPPED
345	3-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:15	9:19	0:03	HAND TRIPPED
346	3-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:04	22:18	0:14	HAND TRIPPED
347	3-Jan-2020	TUMKUR	66	TR-1	HDPURA_66	11:34	12:11	0:36	LINE CLEAR AVAILED
348	3-Jan-2020	TUMKUR	66	TR-2	HIREHALLY_66	12:06	12:11	0:04	TRANSFORMER FAULT
349	3-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66, MALEBENNUR_66	7:07	7:17	0:10	LINE FAULT
350	3-Jan-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	13:59	15:20	1:21	LOAD CURTAILMENT
351	3-Jan-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	10:55	11:04	0:09	TRANSFORMER FAULT
352	3-Jan-2020	TUMKUR	66	YEDIYUR- BGNAGARA_66	BGNAGARA_66	13:57	16:40	2:42	LINE CLEAR AVAILED
353	3-Jan-2020	TUMKUR	66	TR-1	YEDIYUR_66	14:53	16:33	1:40	LINE CLEAR AVAILED
354	3-Jan-2020	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	5:51	15:21	9:29	LINE CLEAR AVAILED
355	3-Jan-2020	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	6:20	6:33	0:12	LINE CLEAR AVAILED
356	3-Jan-2020	TUMKUR	66	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:01	17:15	0:14	HAND TRIPPED
357	3-Jan-2020	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	14:02	14:39	0:37	LINE CLEAR AVAILED
358	3-Jan-2020	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:33	14:38	4:05	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
359	3-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	7:15	7:27	0:11	LINE CLEAR AVAILED
360	3-Jan-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	11:02	11:15	0:13	LINE CLEAR AVAILED
361	3-Jan-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	16:24	16:52	0:27	LINE CLEAR AVAILED
362	3-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	9:49	10:11	0:22	LINE CLEAR AVAILED
363	3-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	7:15	7:28	0:12	LINE CLEAR AVAILED
364	3-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	9:49	10:11	0:22	LINE CLEAR AVAILED
365	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	11:06	12:06	0:59	HAND TRIPPED
366	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	9:06	10:06	1:00	LINE CLEAR AVAILED
367	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	10:06	11:06	1:00	LINE CLEAR AVAILED
368	3-Jan-2020	TUMKUR	66	TR-1	ANCHEPALYA_220	14:02	14:41	0:39	LINE CLEAR AVAILED
369	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	13:56	14:42	0:45	HAND TRIPPED
370	3-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	15:57	16:11	0:14	HAND TRIPPED
371	3-Jan-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:58	17:26	1:27	LINE FAULT
372	3-Jan-2020	TUMKUR	66	TR-3	AVAREGERE_66	20:07	20:08	0:01	TRANSFORMER FAULT
373	3-Jan-2020	TUMKUR	66	TR-1	BADAVANAHALLI_66	13:38	13:54	0:15	LINE CLEAR AVAILED
374	3-Jan-2020	TUMKUR	66	CHELLUR-ANTHRASANAHALI	CHELURU_66	17:12	17:29	0:17	MAIN SUPPLY FAILURE
375	3-Jan-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	7:09	7:25	0:15	LOAD CURTAILMENT
376	3-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	7:48	8:51	1:02	LOAD CURTAILMENT
377	3-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	7:09	7:27	0:17	LOAD CURTAILMENT
378	3-Jan-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	7:09	7:27	0:17	LINE FAULT
379	3-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:01	9:07	0:06	HAND TRIPPED
380	3-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:04	22:18	0:14	HAND TRIPPED
381	3-Jan-2020	TUMKUR	66	TR-1	HDPURA_66	11:34	12:11	0:36	LINE CLEAR AVAILED
382	3-Jan-2020	TUMKUR	66	TR-2	HIREHALLY_66	12:06	12:11	0:04	TRANSFORMER FAULT
383	3-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	7:07	7:17	0:10	LINE FAULT
384	3-Jan-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	13:59	15:20	1:21	MAIN SUPPLY FAILURE
385	3-Jan-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	10:55	11:04	0:09	TRANSFORMER FAULT
386	3-Jan-2020	TUMKUR	66	YEDIYUR- BGNAGARA_66	BGNAGARA_66	13:57	16:40	2:42	LINE CLEAR AVAILED
387	3-Jan-2020	TUMKUR	66	TR-1	YEDIYUR_66	14:53	16:33	1:40	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
388	3-Jan-2020	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	5:51	15:21	9:29	LINE CLEAR AVOIDED
389	3-Jan-2020	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	6:20	6:33	0:12	LINE CLEAR AVOIDED
390	3-Jan-2020	TUMKUR	66	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:01	17:15	0:14	HAND TRIPPED
391	4-Jan-2020	BAGALKOT	110	110/11KV,HV-2	ANAND NAGAR_110	10:41	11:33	0:52	HAND TRIPPED
392	4-Jan-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	21:59	22:19	0:20	TRANSFORMER FAULT
393	4-Jan-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	22:35	23:10	0:35	LINE CLEAR AVOIDED
394	4-Jan-2020	BAGALKOT	110	110/11KV,HV4	KERUR_110	8:24	10:05	1:41	LINE CLEAR AVOIDED
395	4-Jan-2020	BAGALKOT	110	110/11KV,HV2	MRUTHYUNJAYANAGAR_110	11:58	12:05	0:07	TRANSFORMER FAULT
396	4-Jan-2020	BAGALKOT	110	110/11KV,HV1	MUNDAGANUR_110	6:51	7:01	0:10	LOAD CURTAILMENT
397	4-Jan-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	6:51	7:28	0:37	LOAD CURTAILMENT
398	4-Jan-2020	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	12:36	13:13	0:37	LINE CLEAR AVOIDED
399	4-Jan-2020	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	15:50	16:09	0:19	LINE CLEAR AVOIDED
400	4-Jan-2020	BAGALKOT	110	110/11KV, HV1	TIKOTA_110	8:04	8:12	0:08	TRANSFORMER FAULT
401	4-Jan-2020	BAGALKOT	110	110/11KV, HV1	TIKOTA_110	14:52	15:17	0:25	TRANSFORMER FAULT
402	4-Jan-2020	BAGALKOT	220	HUBLI-NARENDRA 1	HUBLI_220	11:05	16:59	5:54	LINE CLEAR AVOIDED
403	4-Jan-2020	BAGALKOT	110	220/110KV,LV1	HUBLI_220	0:00	13:19	13:19	LINE CLEAR AVOIDED
404	4-Jan-2020	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	10:00	14:25	4:25	LINE CLEAR AVOIDED
405	4-Jan-2020	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	7:36	15:39	8:03	LINE FAULT
406	4-Jan-2020	BAGALKOT	220	SHARAVATHI 2-SIRSI	SIRSI_220	12:43	14:24	1:41	LINE CLEAR AVOIDED
407	4-Jan-2020	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110,KANAGAL_33,HEB BAL_33	16:56	17:34	0:38	LINE CLEAR AVOIDED
408	4-Jan-2020	BAGALKOT	110	110/11KV, HV2	RON_110	11:13	12:28	1:15	LINE CLEAR AVOIDED
409	4-Jan-2020	BAGALKOT	110	RANEBENNUR220-BYADAGI(GUTTAL)	GUTTAL_110	10:51	16:28	5:37	LINE CLEAR AVOIDED
410	4-Jan-2020	BAGALKOT	66	110/33KV, HV4	HARIHAR HOSPET_110,VENKESH FACTORY_33	6:51	7:25	0:34	LOAD CURTAILMENT
411	4-Jan-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	11:20	11:25	0:05	LOAD CHANGE OVER
412	4-Jan-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	19:24	19:28	0:04	LOAD CHANGE OVER
413	4-Jan-2020	BENGALURU	66	HV2	TELECOM LAYOUT	13:36	13:49	0:13	TRANSFORMER FAULT
414	4-Jan-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	1:25	1:30	0:05	LINE FAULT
415	4-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	12:09	13:15	1:06	LINE CLEAR AVOIDED
416	4-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:20	14:28	1:08	LINE CLEAR AVOIDED
417	4-Jan-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSNUK	7:10	7:14	0:04	LOAD CURTAILMENT

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
418	4-Jan-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:10	7:14	0:04	LOAD CURTAILMENT
419	4-Jan-2020	BENGALURU	66	ELECTRONIC CITY P2 S2 - NAGNATHPURA 220	ELECTRONIC CITY P2 S2, BIOCON (EHT)	13:46	15:00	1:13	LINE FAULT
420	4-Jan-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	9:14	9:24	0:09	LINE FAULT
421	4-Jan-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	11:07	12:05	0:57	LINE FAULT
422	4-Jan-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, BEVOOR, SANKALGERE	16:36	16:49	0:13	LINE FAULT
423	4-Jan-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	7:03	8:05	1:01	LOAD CURTAILMENT
424	4-Jan-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:41	14:03	0:22	LINE FAULT
425	4-Jan-2020	KALABURAGI	220	LINGASUGUR-B.BAGEWADI1	LINGASUGUR_220	10:54	13:42	2:48	LINE CLEAR AVAILED
426	4-Jan-2020	KALABURAGI	110	HV2	DEODURGA_110	6:15	6:20	0:05	TRANSFORMER FAULT
427	4-Jan-2020	KALABURAGI	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110,SAIDAPUR_GLB_110,WADAGERA_110,NALWAR_110	3:47	3:59	0:12	LINE FAULT
428	4-Jan-2020	KALABURAGI	110	HV1	MAHAGOAN_110	6:50	7:15	0:25	LOAD CURTAILMENT
429	4-Jan-2020	KALABURAGI	110	HV1	PDHALLI_110	6:50	6:55	0:05	LOAD CURTAILMENT
430	4-Jan-2020	KALABURAGI	110	HV1	LINGASUGUR_220	15:20	15:25	0:05	TRANSFORMER FAULT
431	4-Jan-2020	KALABURAGI	110	HV2	LINGASUGUR_220	15:20	15:25	0:05	TRANSFORMER FAULT
432	4-Jan-2020	KALABURAGI	110	HV1	SIRWAR_110	6:50	6:55	0:05	LOAD CURTAILMENT
433	4-Jan-2020	KALABURAGI	110	HV1	TEKKALAKOTE_110	6:50	7:00	0:10	TRANSFORMER FAULT
434	4-Jan-2020	KALABURAGI	110	HV2	TEKKALAKOTE_110	9:30	9:45	0:15	TRANSFORMER FAULT
435	4-Jan-2020	KALABURAGI	110	HV2	YELBURGA_110	6:50	7:15	0:25	LOAD CURTAILMENT
436	4-Jan-2020	KALABURAGI	110	BEVOOR-KUSHTAGI	BEVOOR_110	15:50	16:35	0:45	LINE CLEAR AVAILED
437	4-Jan-2020	KALABURAGI	110	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,DHADESUGUR_110,TEKKALAKOTE_110	16:25	17:40	1:15	LINE CLEAR AVAILED
438	4-Jan-2020	KALABURAGI	110	HV2	TEKKALAKOTE_110	12:40	12:55	0:15	TRANSFORMER FAULT
439	4-Jan-2020	KALABURAGI	110	SHAKTINAGAR-RAICHURBIOMASS	SHAKTINAGAR_110	19:54	21:29	1:35	LINE FAULT
440	4-Jan-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	11:31	16:15	4:44	NFBC ISSUED
441	4-Jan-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	8:30	18:41	10:11	LINE CLEAR AVAILED
442	4-Jan-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	11:31	16:15	4:44	NFBC ISSUED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
443	4-Jan-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:30	15:53	2:23	LINE FAULT
444	4-Jan-2020	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	3:48	16:12	12:24	LINE FAULT
445	4-Jan-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	8:30	18:15	9:45	NFBC ISSUED
446	4-Jan-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	7:36	15:40	8:04	LINE FAULT
447	4-Jan-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	12:48	14:20	1:32	LINE CLEAR AVAILED
448	4-Jan-2020	HASSAN	110	HV2	ALKOLA_110	12:39	13:15	0:36	LINE CLEAR AVAILED
449	4-Jan-2020	HASSAN	110	HV2	ESSUR_110	10:14	12:32	2:18	LINE CLEAR AVAILED
450	4-Jan-2020	HASSAN	110	HV2	GANDASI_110	6:51	6:59	0:08	MAIN SUPPLY FAILURE
451	4-Jan-2020	HASSAN	110	HV1	JAVAGAL_110	6:51	7:04	0:13	MAIN SUPPLY FAILURE
452	4-Jan-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:46	10:55	0:09	HAND TRIPPED
453	4-Jan-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:28	13:47	2:19	LINE CLEAR AVAILED
454	4-Jan-2020	HASSAN	110	HV1	BRAHMAVARA_110	6:51	7:06	0:15	MAIN SUPPLY FAILURE
455	4-Jan-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	12:12	12:36	0:24	LOAD CURTAILMENT
456	4-Jan-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	12:11	12:34	0:23	LINE CLEAR AVAILED
457	4-Jan-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:39	13:00	0:21	LINE FAULT
458	4-Jan-2020	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	15:25	17:02	1:37	NFBC ISSUED
459	4-Jan-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	13:22	13:29	0:07	HAND TRIPPED
460	4-Jan-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	6:51	6:59	0:08	MAIN SUPPLY FAILURE
461	4-Jan-2020	MYSORE	66	HV2	BOMMALAPURA_66	17:31	18:56	1:24	LINE CLEAR AVAILED
462	4-Jan-2020	MYSORE	66	HV2	BOOKANAKERE_66	6:50	7:00	0:09	LOAD CURTAILMENT
463	4-Jan-2020	MYSORE	66	HV2	CHINAKURALI_66	6:50	6:56	0:06	LOAD CURTAILMENT
464	4-Jan-2020	MYSORE	66	HAMPAPURA-MANDYA	CHIKKA_MANDYA_66	16:21	18:19	1:57	LINE CLEAR AVAILED
465	4-Jan-2020	MYSORE	66	HV1	HANAGODU_66	6:50	7:51	1:00	LOAD CURTAILMENT
466	4-Jan-2020	MYSORE	66	HV2	HANNUR_66	6:50	7:15	0:24	LOAD CURTAILMENT
467	4-Jan-2020	MYSORE	66	KR PETE 220-MADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	6:31	6:44	0:13	LINE FAULT
468	4-Jan-2020	MYSORE	66	HV1	MALAVALLI_66	16:27	17:55	1:27	LINE CLEAR AVAILED
469	4-Jan-2020	MYSORE	66	HV2	MALAVALLI_66	16:27	17:55	1:27	LINE CLEAR AVAILED
470	4-Jan-2020	MYSORE	66	MEGLAPURA-SFC	THUMBLA_66,VYASRAJPURA_66,GAR GESHWARI_66,TNARASIPURA_66	0:55	1:02	0:06	LINE FAULT
471	4-Jan-2020	MYSORE	66	HV1	SATHEGALA_66	6:50	6:55	0:04	LOAD CURTAILMENT
472	4-Jan-2020	MYSORE	66	HV1	SATHEGALA_66	11:23	11:44	0:20	LINE CLEAR AVAILED
473	4-Jan-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	6:50	7:07	0:16	LOAD CURTAILMENT
474	4-Jan-2020	MYSORE	66	TUBINKERE-NAGAMGALA 1	BASARALU_66 BESAGARAHALLI_66, KOPPA_66	16:25	16:31	0:06	LINE FAULT

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
475	4-Jan-2020	MYSORE	66	HV2	VIRAJPET_66	17:37	17:51	0:13	LINE CLEAR AVAILED
476	4-Jan-2020	MYSORE	66	HV1	YELANDUR_66	6:50	6:54	0:04	LOAD CURTAILMENT
477	4-Jan-2020	TUMKUR	110	TR-1	SHETYKERE_110	22:35	22:51	0:15	LINE CLEAR AVAILED
478	4-Jan-2020	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	1:05	1:18	0:13	LINE FAULT
479	4-Jan-2020	TUMKUR	66	CHANNAGIRI-LINGDHILI	CHANNAGIRI_66	15:56	16:11	0:14	MAIN SUPPLY FAILURE
480	4-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	6:56	7:51	0:54	LOAD CURTAILMENT
481	4-Jan-2020	TUMKUR	66	TR-2	GUTTUR_66	11:03	12:51	1:48	LINE CLEAR AVAILED
482	4-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:36	11:45	0:09	HAND TRIPPED
483	4-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:36	16:17	1:41	LINE CLEAR AVAILED
484	4-Jan-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	11:10	12:58	1:47	LINE FAULT
485	4-Jan-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:12	16:15	3:02	LINE FAULT
486	4-Jan-2020	TUMKUR	66	HOSAKERE- MIDIGESHI	MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66	15:18	17:40	2:22	LINE CLEAR AVAILED
487	4-Jan-2020	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	15:17	18:06	2:48	LINE CLEAR AVAILED
488	4-Jan-2020	TUMKUR	66	TR-1	KATTIGE_66	12:01	12:06	0:04	TRANSFORMER FAULT
489	4-Jan-2020	TUMKUR	66	TR-1	KATTIGE_66	13:10	13:16	0:05	TRANSFORMER FAULT
490	4-Jan-2020	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	10:17	15:01	4:44	LINE CLEAR AVAILED
491	4-Jan-2020	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	10:11	15:03	4:51	LINE CLEAR AVAILED
492	4-Jan-2020	TUMKUR	66	TR-1	MADHUGIRI_66	10:11	15:02	4:50	LINE CLEAR AVAILED
493	4-Jan-2020	TUMKUR	66	TR-2	MADHUGIRI_66	10:11	15:01	4:49	LINE CLEAR AVAILED
494	4-Jan-2020	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	10:11	15:01	4:49	LINE CLEAR AVAILED
495	4-Jan-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	15:20	17:37	2:17	LINE CLEAR AVAILED
496	4-Jan-2020	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	15:26	17:41	2:14	LINE CLEAR AVAILED
497	4-Jan-2020	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	16:35	17:43	1:08	LINE CLEAR AVAILED
498	4-Jan-2020	TUMKUR	66	TR-2	SHYLAPURA_66	15:17	15:50	0:33	LINE CLEAR AVAILED
499	4-Jan-2020	TUMKUR	66	TR-1	SASALUHALLA_66	15:38	15:45	0:06	TRANSFORMER FAULT
500	4-Jan-2020	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	1:08	1:13	0:05	LINE FAULT
501	4-Jan-2020	TUMKUR	66	TR-1	TYAVANAGI_66	8:30	11:16	2:45	TRANSFORMER FAULT
502	5-Jan-2020	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	14:15	17:51	3:36	LINE FAULT
503	5-Jan-2020	BAGALKOT	110	ATHANI-KSSKN	ATHANI_220	6:30	6:59	0:29	LINE FAULT
504	5-Jan-2020	BAGALKOT	110	WIND MILL-CHIKKODI	CHIKKODI_110	10:45	17:45	7:00	LINE CLEAR AVAILED
505	5-Jan-2020	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	10:48	17:52	7:04	LINE CLEAR AVAILED
506	5-Jan-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	7:53	8:14	0:21	LINE FAULT



SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
507	5-Jan-2020	BAGALKOT	220	NARENDRA1&2-BELGAUM	BELGAUM_220	7:04	22:51	15:47	LINE CLEAR AVAILED
508	5-Jan-2020	BAGALKOT	110	110/11KV, HV1	TILUVALI_110	8:31	9:26	0:55	TRANSFORMER FAULT
509	5-Jan-2020	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMAWAD_33, IE_33	10:07	18:06	7:59	LINE CLEAR AVAILED
510	5-Jan-2020	BAGALKOT	110	110/11KV,HV2	TARIHAL_110	10:08	18:08	8:00	LINE CLEAR AVAILED
511	5-Jan-2020	BAGALKOT	110	TADASINKOPPA-TARIHAL	TARIHAL_110	9:13	19:53	10:40	NFBC ISSUED
512	5-Jan-2020	BAGALKOT	110	HUBLI2-TARIHAL	TARIHAL_110	17:11	18:08	0:57	LINE CLEAR AVAILED
513	5-Jan-2020	BAGALKOT	110	110/11KV, HV1	NAVALGUND_110	11:22	15:11	3:49	LINE CLEAR AVAILED
514	5-Jan-2020	BAGALKOT	66	110/33KV, HV3	HARIHAR HOSPET_110	4:34	23:59	19:25	TRANSFORMER FAULT
515	5-Jan-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	22:12	22:19	0:07	LINE FAULT
516	5-Jan-2020	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	KORMANGALA 220	9:58	10:18	0:20	LINE FAULT
517	5-Jan-2020	BENGALURU	220	KORMANGALA 220 - NIMHANS 220	KORMANGALA 220	10:38	10:42	0:04	LOAD CHANGE OVER
518	5-Jan-2020	BENGALURU	220	HV1	KORMANGALA 220	9:58	10:18	0:20	MAIN SUPPLY FAILURE
519	5-Jan-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	7:07	7:17	0:10	LOAD CURTAILMENT
520	5-Jan-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	15:46	16:12	0:25	LINE FAULT
521	5-Jan-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, BEVOOR, SANKALGERE	8:04	8:19	0:14	LINE FAULT
522	5-Jan-2020	KALABURAGI	110	SINDHANOOR220-PGLR_WIND_IPP	SIDHANOOR_220	16:55	17:34	0:39	LINE FAULT
523	5-Jan-2020	KALABURAGI	110	BHALKI-BKLISUGAR	BHALKI_110	8:06	8:19	0:13	LINE FAULT
524	5-Jan-2020	KALABURAGI	110	GABUR-BPSLR	GABUR_110	5:03	5:18	0:15	LINE FAULT
525	5-Jan-2020	KALABURAGI	110	MALLAT-BYAGWAT1	BYAGAWAT_110	1:20	1:25	0:05	LINE FAULT
526	5-Jan-2020	KALABURAGI	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110, SRERAMANAGAR_110, YERADONA_110, MALLAPURA_110	13:19	13:30	0:11	LINE CLEAR AVAILED
527	5-Jan-2020	KALABURAGI	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	6:17	6:24	0:07	LINE FAULT
528	5-Jan-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	2:12	5:12	3:00	LINE CLEAR AVAILED
529	5-Jan-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	10:41	15:43	5:02	NFBC ISSUED
530	5-Jan-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	10:41	15:43	5:02	NFBC ISSUED
531	5-Jan-2020	HASSAN	66	HV1	CHIKMAGALUR_66	18:54	19:05	0:11	HAND TRIPPED
532	5-Jan-2020	HASSAN	66	HV1	CHIKMAGALUR_66	20:26	20:57	0:31	LINE CLEAR AVAILED
533	5-Jan-2020	HASSAN	66	HV1	DODDAKADANUR_66	16:26	16:29	0:03	LOAD CURTAILMENT
534	5-Jan-2020	HASSAN	66	HV1	HNPUA_66	14:01	14:52	0:51	LINE CLEAR AVAILED
535	5-Jan-2020	HASSAN	66	HV2	HNPUA_66	14:01	14:53	0:52	LINE CLEAR AVAILED
536	5-Jan-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	6:35	6:48	0:13	LINE FAULT
537	5-Jan-2020	MYSORE	66	KADAKOLA-NANJANAGUDU 2	THANDYA_66	6:06	16:49	10:42	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
538	5-Jan-2020	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	13:50	14:01	0:10	LINE FAULT
539	5-Jan-2020	MYSORE	66	SINDUVALLIPURA-KADKOLA	NANJANGUDU_66	11:31	11:49	0:18	LINE FAULT
540	5-Jan-2020	MYSORE	66	MADDUR-K.HONALGERE	SOMANAHALLI_66	16:16	16:37	0:21	LINE FAULT
541	5-Jan-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:47	13:22	0:35	LINE FAULT
542	5-Jan-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:47	13:22	0:34	LINE FAULT
543	5-Jan-2020	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	14:05	18:13	4:07	LINE FAULT
544	5-Jan-2020	TUMKUR	110	TR-1	SHETYKERE_110	8:39	9:58	1:18	LINE CLEAR AVAILED
545	5-Jan-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	11:20	14:49	3:29	LINE CLEAR AVAILED
546	5-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	8:44	8:45	0:01	HAND TRIPPED
547	5-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	17:20	17:24	0:03	HAND TRIPPED
548	5-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	9:32	9:50	0:17	LINE FAULT
549	5-Jan-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	15:38	15:47	0:09	LINE FAULT
550	5-Jan-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	14:29	17:45	3:16	LINE CLEAR AVAILED
551	5-Jan-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	17:41	17:48	0:06	LINE FAULT
552	5-Jan-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	17:41	17:42	0:01	LINE FAULT
553	5-Jan-2020	TUMKUR	66	TR-2	HARIYABBE_66	17:41	17:51	0:10	TRANSFORMER FAULT
554	5-Jan-2020	TUMKUR	66	HIREHALLI - ANTHRASANAHALLI	HIREHALLY_66	17:30	17:50	0:20	HAND TRIPPED
555	5-Jan-2020	TUMKUR	66	HIREHALLI - MELEKOTE	MELKOTE_66	8:36	17:42	9:06	LINE CLEAR AVAILED
556	5-Jan-2020	TUMKUR	66	TR-3	HONNALI_66	9:45	12:46	3:01	LINE CLEAR AVAILED
557	5-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:26	16:35	0:09	LINE FAULT
558	5-Jan-2020	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:29	18:40	0:10	LINE FAULT
559	5-Jan-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	1:53	1:59	0:05	LINE CLEAR AVAILED
560	5-Jan-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	6:57	7:12	0:14	TRANSFORMER FAULT
561	5-Jan-2020	TUMKUR	66	TR-1	TUMKUR_66	10:31	17:47	7:16	LINE CLEAR AVAILED
562	6-Jan-20	BAGALKOT	66	110/33KV, HV4	HARIHAR HOSPET_66, VENKESH FACTORY_33	11:25	11:47	0:22	MAIN SUPPLY FAILURE
563	6-Jan-20	BAGALKOT	66	110/33KV, HV3	HARIHAR HOSPET_66	0:00	11:51	11:51	LINE CLEAR AVAILED
564	6-Jan-20	BAGALKOT	110	110/33KV, HV2	ANKALAGI_110, KANAGAL_33, NESARGI_33	11:14	18:44	7:30	LINE CLEAR AVAILED
565	6-Jan-20	BAGALKOT	110	110/11KV, HV1	BETAGERI_110	6:26	7:51	1:25	TRANSFORMER FAULT
566	6-Jan-20	BAGALKOT	110	BAGEWADI220-MAMADAPUR2	MAMADAPUR_110	13:33	15:25	1:52	LINE CLEAR AVAILED
567	6-Jan-20	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	12:16	13:32	1:16	LINE CLEAR AVAILED
568	6-Jan-20	BAGALKOT	110	110/11KV, HV1	BILAGI_110	9:07	15:06	5:59	LINE CLEAR AVAILED
569	6-Jan-20	BAGALKOT	110	GAJENDRAGA-RON1&2	RON_110	9:35	10:02	0:27	HAND TRIPPED
570	6-Jan-20	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	10:49	12:53	2:04	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
571	6-Jan-20	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	SIDDAPUR_110	14:12	14:27	0:15	LINE FAULT
572	6-Jan-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:53	14:43	1:50	LINE CLEAR AVAILED
573	6-Jan-20	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	16:58	17:06	0:08	LINE CLEAR AVAILED
574	6-Jan-20	BAGALKOT	220	220/110KV, HV3	HUBLI_220	10:06	17:34	7:28	LINE CLEAR AVAILED
575	6-Jan-20	BAGALKOT	110	220/110KV, LV3	HUBLI_220	10:03	23:59	13:56	LINE CLEAR AVAILED
576	6-Jan-20	BAGALKOT	110	GAMESHA-RON	RON_110	9:15	10:17	1:02	LINE CLEAR AVAILED
577	6-Jan-20	BAGALKOT	110	GAJENDRAGA1&2-RON	RON_110	14:13	16:05	1:52	LINE CLEAR AVAILED
578	6-Jan-20	BAGALKOT	110	NAREGAL-RON	RON_110	9:32	14:42	5:10	LINE CLEAR AVAILED
579	6-Jan-20	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	13:20	14:47	1:27	LINE CLEAR AVAILED
580	6-Jan-20	BAGALKOT	110	110/11KV, HV3	LOKAPUR_110	13:30	13:55	0:25	LINE CLEAR AVAILED
581	6-Jan-20	BAGALKOT	110	110/11KV,HV2	LAKMANHALLI_110	15:12	15:31	0:19	LINE CLEAR AVAILED
582	6-Jan-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:50	11:00	0:10	LINE FAULT
583	6-Jan-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:32	14:46	0:14	LINE FAULT
584	6-Jan-20	BENGALURU	66	HV1	SOLDEVANAHALLI	9:56	11:58	2:02	LINE CLEAR AVAILED
585	6-Jan-20	BENGALURU	66	HV2	SOLDEVANAHALLI	12:00	14:40	2:40	LINE CLEAR AVAILED
586	6-Jan-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:05	13:20	0:15	LINE CLEAR AVAILED
587	6-Jan-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	15:52	16:02	0:10	LINE FAULT
588	6-Jan-20	BENGALURU	220	HV2	HSR 220	21:07	21:47	0:39	TRANSFORMER FAULT
589	6-Jan-20	BENGALURU	220	HV2	HSR 220	21:50	23:59	2:09	TRANSFORMER FAULT
590	6-Jan-20	BENGALURU	220	HV2	HSR 220	0:00	1:34	1:34	TRANSFORMER FAULT
591	6-Jan-20	BENGALURU	66	HSR 220 - ADUGODI 2	ADUGODI, JAKKASANDRA BOSCH	21:07	21:41	0:34	LINE CLEAR AVAILED
592	6-Jan-20	BENGALURU	220	HOODY 400 - HSR 220	KORMANGALA 220	21:07	21:21	0:13	LINE FAULT
593	6-Jan-20	KALABURAGI	220	RAICHUR-RTPS1	RAICHUR_220	10:01	22:00	11:59	LINE CLEAR AVAILED
594	6-Jan-20	KALABURAGI	220	RAICHUR-RTPS2	RAICHUR_220	10:01	10:28	0:27	LINE CLEAR AVAILED
595	6-Jan-20	KALABURAGI	220	HV1	SIDHANOOR_220	11:55	17:05	5:10	LINE CLEAR AVAILED
596	6-Jan-20	KALABURAGI	110	LINGASUGUR-KPRL	KPRL_IPP	7:10	13:25	6:15	LINE CLEAR AVAILED
597	6-Jan-20	KALABURAGI	110	RAJESHWAR - WARADA	WARADA_IPP	19:40	22:55	3:15	LINE CLEAR AVAILED
598	6-Jan-20	KALABURAGI	110	SHAHAPUR-YADGIR	YADGIR_110	23:46	23:49	0:03	LINE FAULT
599	6-Jan-20	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:06	10:36	0:30	LINE CLEAR AVAILED
600	6-Jan-20	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:49	15:39	4:50	LINE CLEAR AVAILED
601	6-Jan-20	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	11:40	16:40	5:00	LINE CLEAR AVAILED
602	6-Jan-20	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	6:34	6:50	0:16	LINE FAULT
603	6-Jan-20	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	12:15	16:43	4:28	LINE CLEAR AVAILED
604	6-Jan-20	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	18:06	19:03	0:57	HAND TRIPPED
605	6-Jan-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	6:34	6:44	0:10	HAND TRIPPED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
606	6-Jan-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	11:49	12:22	0:33	HAND TRIPPED
607	6-Jan-20	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:49	12:15	0:26	HAND TRIPPED
608	6-Jan-20	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	11:49	19:45	7:56	LINE CLEAR AVAILED
609	6-Jan-20	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	10:43	12:28	1:45	LINE CLEAR AVAILED
610	6-Jan-20	HASSAN	66	HV1	DODDAKADANUR_66	10:43	12:37	1:54	LINE CLEAR AVAILED
611	6-Jan-20	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	10:43	12:37	1:54	LINE CLEAR AVAILED
612	6-Jan-20	HASSAN	66	HV1	HALLIMYSORE_66	10:45	12:37	1:52	MAIN SUPPLY FAILURE
613	6-Jan-20	HASSAN	66	HV1	HANGARANAHALLY_66	14:03	14:12	0:09	HAND TRIPPED
614	6-Jan-20	HASSAN	66	HV2	SALAGAME_66	13:40	15:11	1:31	LINE CLEAR AVAILED
615	6-Jan-20	HASSAN	66	HV2	SHRAVANABELAGOLA_66	12:53	13:28	0:35	LINE CLEAR AVAILED
616	6-Jan-20	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	11:40	11:45	0:05	HAND TRIPPED
617	6-Jan-20	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	18:10	18:15	0:05	HAND TRIPPED
618	6-Jan-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	11:40	11:45	0:05	HAND TRIPPED
619	6-Jan-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	18:10	18:15	0:05	HAND TRIPPED
620	6-Jan-20	HASSAN	66	HV2	UDAYAPURA_66	9:00	9:05	0:05	TRANSFORMER FAULT
621	6-Jan-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:45	11:51	0:06	HAND TRIPPED
622	6-Jan-20	HASSAN	66	UDAYAP-CRP	UDAYAPURA_66	11:20	11:35	0:15	HAND TRIPPED
623	6-Jan-20	MYSORE	66	HV1	ARAKERE_66	13:43	14:22	0:39	LINE CLEAR AVAILED
624	6-Jan-20	MYSORE	66	HV1	GAMANAHALLY_66	14:10	16:55	2:45	LINE CLEAR AVAILED
625	6-Jan-20	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66, SINDHUVALLI_66	14:52	15:12	0:19	LINE FAULT
626	6-Jan-20	MYSORE	66	GUNDLUPETE-BOMMLAPURA	BOMMALAPURA_66	14:52	15:11	0:18	LINE FAULT
627	6-Jan-20	MYSORE	66	JAKKANAHALLI-NAGAMANGALA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	7:19	7:28	0:08	LINE FAULT
628	6-Jan-20	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	8:27	8:31	0:04	LINE FAULT
629	6-Jan-20	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	11:06	11:38	0:32	LINE CLEAR AVAILED
630	6-Jan-20	MYSORE	66	HV1	THANDYA_66	12:56	12:58	0:02	TRANSFORMER FAULT
631	6-Jan-20	MYSORE	66	HV2	THANDYA_66	12:40	13:31	0:51	LINE CLEAR AVAILED
632	6-Jan-20	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	14:25	15:28	1:02	LINE CLEAR AVAILED
633	6-Jan-20	TUMKUR	110	TR-1	BIDARE_110	14:25	15:28	1:03	LINE CLEAR AVAILED
634	6-Jan-20	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	14:40	14:54	0:14	LINE CLEAR AVAILED
635	6-Jan-20	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:47	13:51	0:04	LINE CLEAR AVAILED
636	6-Jan-20	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:08	17:20	0:12	LINE CLEAR AVAILED

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
637	6-Jan-20	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:47	13:52	0:04	LINE CLEAR AVAILED
638	6-Jan-20	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	17:08	17:23	0:14	LINE CLEAR AVAILED
639	6-Jan-20	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	14:17	15:27	1:09	LINE CLEAR AVAILED
640	6-Jan-20	TUMKUR	66	TR-3	AVAREGERE_66	11:07	13:13	2:05	LINE CLEAR AVAILED
641	6-Jan-20	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	18:00	20:08	2:08	LINE CLEAR AVAILED
642	6-Jan-20	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:29	13:39	0:10	TRANSFORMER FAULT
643	6-Jan-20	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:24	12:40	1:16	LINE CLEAR AVAILED
644	6-Jan-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:03	11:24	0:20	HAND TRIPPED
645	6-Jan-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:14	13:33	0:18	HAND TRIPPED
646	6-Jan-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	1:10	1:16	0:05	HAND TRIPPED
647	6-Jan-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:04	11:29	0:25	HAND TRIPPED
648	6-Jan-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:14	13:32	0:18	HAND TRIPPED
649	6-Jan-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:03	11:35	0:32	HAND TRIPPED
650	6-Jan-20	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:04	11:24	0:20	HAND TRIPPED
651	6-Jan-20	TUMKUR	66	TR-1	DAVANGERE_SRS_220	13:14	13:32	0:18	HAND TRIPPED
652	6-Jan-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:04	11:31	0:27	HAND TRIPPED
653	6-Jan-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:14	13:33	0:18	HAND TRIPPED
654	6-Jan-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:03	11:34	0:30	HAND TRIPPED
655	6-Jan-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	6:13	6:21	0:07	LINE FAULT
656	6-Jan-20	TUMKUR	66	TR-1	SASALUHALLA_66	11:56	12:25	0:29	TRANSFORMER FAULT
657	6-Jan-20	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	14:01	14:05	0:04	MAIN SUPPLY FAILURE
658	6-Jan-20	TUMKUR	66	MYLANAHALLI-THALLAK	MYLANAHALLI_66	8:30	8:48	0:17	LINE CLEAR AVAILED
659	6-Jan-20	TUMKUR	66	TR-1	MYLANAHALLI_66	8:30	10:48	2:18	LINE CLEAR AVAILED
660	6-Jan-20	TUMKUR	66	TR-1	MYLANAHALLI_66	15:54	16:03	0:08	LINE CLEAR AVAILED
661	6-Jan-20	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	17:12	17:24	0:11	LOAD CURTAILMENT
662	6-Jan-20	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	17:12	17:20	0:08	LOAD CURTAILMENT
663	6-Jan-20	TUMKUR	66	TR-2	HIREHALLY_66	10:10	10:21	0:11	TRANSFORMER FAULT

SL No	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
664	6-Jan-20	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66	15:00	15:49	0:48	MAIN SUPPLY FAILURE
665	6-Jan-20	TUMKUR	66	TR-1	KATTIGE_66	15:00	15:49	0:48	MAIN SUPPLY FAILURE
666	6-Jan-20	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	15:00	15:53	0:52	MAIN SUPPLY FAILURE