

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 15.01.2019 to 21.01.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
1	15-Jan-19	BAGALKOT	110	BAGEWADI-MAMDAPUR2	MAMDAPUR(B)_110,BABLESHWAR_110	6:52	7:08	0:16	LINE FAULT
2	15-Jan-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	5:00	5:16	0:16	LINE FAULT
3	15-Jan-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	6:18	23:59	17:41	LINE FAULT
4	15-Jan-19	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110,ALNAVAR_33	13:12	13:19	0:07	TRANSFORMER FAULT
5	15-Jan-19	BAGALKOT	110	BPCL-NARGUND	NARGUND_110	21:00	23:51	2:51	LINE FAULT
6	15-Jan-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33	10:17	10:18	0:01	TRANSFORMER FAULT
7	15-Jan-19	BANGALORE	66	HV1	NANGALI	15:15	15:20	0:05	TRANSFORMER FAULT
8	15-Jan-19	BANGALORE	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	12:48	12:55	0:07	LINE CLEAR AVAILED
9	15-Jan-19	BANGALORE	66	ADUGODI - HAL 2	K&C VALLY, NAL (EHT)	11:28	12:55	1:27	LINE CLEAR AVAILED
10	15-Jan-19	BANGALORE	66	HV1	GOKULA	2:45	3:03	0:17	TRANSFORMER FAULT
11	15-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	8:23	8:29	0:06	LOAD CHANGE OVER
12	15-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	9:53	11:25	1:31	LINE FAULT
13	15-Jan-19	BANGALORE	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	9:53	10:27	0:34	MAIN SUPPLY FAILURE
14	15-Jan-19	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	11:39	11:50	0:11	LOAD CHANGE OVER
15	15-Jan-19	BANGALORE	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	7:37	8:31	0:54	LINE FAULT
16	15-Jan-19	BANGALORE	66	BANASHANKARI - AREHALLI	BANASHANKARI	8:35	8:40	0:05	LOAD CHANGE OVER
17	15-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	6:10	6:27	0:17	LINE FAULT
18	15-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	12:57	13:37	0:40	LINE FAULT
19	15-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 1	RBI	12:57	13:15	0:18	LINE FAULT
20	15-Jan-19	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	15:30	15:35	0:05	LOAD CHANGE OVER
21	15-Jan-19	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	12:57	13:15	0:18	MAIN SUPPLY FAILURE
22	15-Jan-19	BANGALORE	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	15:10	15:13	0:03	LOAD CHANGE OVER
23	15-Jan-19	BANGALORE	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	6:10	6:30	0:20	LINE FAULT
24	15-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	7:32	7:42	0:10	LINE FAULT
25	15-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	8:15	8:26	0:11	LINE FAULT
26	15-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	8:44	9:02	0:18	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
27	15-Jan-19	BANGALORE	66	HAROBELE - KODIHALLI	KODIHALLI, BIJJAHALLI, HUNSENAHALLI	9:02	9:20	0:18	MAIN SUPPLY FAILURE
28	15-Jan-19	GULBARGA	110	HV1	SIRWAR_110	9:37	9:51	0:14	TRANSFORMER FAULT
29	15-Jan-19	GULBARGA	110	HV2	HANUMASAGAR_110	8:12	8:45	0:33	LINE CLEAR AVAILED
30	15-Jan-19	GULBARGA	110	HV2	HANUMANAL_110	8:00	10:10	2:10	LINE CLEAR AVAILED
31	15-Jan-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGURS_IPP,CHOWDAPUR_110	5:48	5:55	0:07	LINE FAULT
32	15-Jan-19	GULBARGA	110	KOLHAR-NSSK_IPP	KOLHAR_110	19:09	19:16	0:07	LINE CLEAR AVAILED
33	15-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	19:00	19:30	0:30	LINE CLEAR AVAILED
34	15-Jan-19	GULBARGA	110	HV2	KOLHAR_110	18:30	19:30	1:00	LINE CLEAR AVAILED
35	15-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	14:20	14:28	0:08	TRANSFORMER FAULT
36	15-Jan-19	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66	6:48	7:10	0:22	LINE FAULT
37	15-Jan-19	GULBARGA	66	HV2	UPANAYAKANAHALLI_66	9:00	10:00	1:00	LINE CLEAR AVAILED
38	15-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:38	14:51	3:13	LINE CLEAR AVAILED
39	15-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	15:03	19:38	4:35	LINE FAULT
40	15-Jan-19	HASSAN	220	SHARVATHY-SHIMOGA4	SHARAVATHY_GEN	11:39	14:51	3:12	NFBC ISSUED
41	15-Jan-19	HASSAN	220	SHARVATHY-SHIMOGA4	SHARAVATHY_GEN	15:02	19:38	4:36	LINE FAULT
42	15-Jan-19	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:37	13:53	4:16	LINE CLEAR AVAILED
43	15-Jan-19	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:38	13:54	4:16	LINE CLEAR AVAILED
44	15-Jan-19	HASSAN	66	HV2	BELUR_66	16:07	16:14	0:07	TRANSFORMER FAULT
45	15-Jan-19	HASSAN	66	HV1	DODDAKADNUR_66	7:35	7:55	0:20	MAIN SUPPLY FAILURE
46	15-Jan-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	8:15	8:30	0:15	LINE FAULT
47	15-Jan-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	12:58	13:34	0:35	LINE FAULT
48	15-Jan-19	MYSORE	66	HV1	HEBBAL_66	13:10	16:02	2:51	HAND TRIPPED
49	15-Jan-19	MYSORE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 HEMMARGALA_66 KARYA_66 SUTTUR_66	6:33	6:45	0:12	LINE FAULT
50	15-Jan-19	MYSORE	66	HV2	PANDAVAPURA_66	3:56	5:04	1:08	HAND TRIPPED
51	15-Jan-19	MYSORE	66	PANNYADAHUNDI-CR NAGARA	PANDYADAHUNDI_66	6:30	6:45	0:15	LINE FAULT
52	15-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	18:48	18:58	0:10	LINE FAULT
53	15-Jan-19	TUMKUR	66	TR-1	KATTIGE_66	8:38	8:50	0:11	TRANSFORMER FAULT
54	15-Jan-19	TUMKUR	66	NAGALAMADIKE- RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	7:27	7:29	0:02	LINE FAULT
55	15-Jan-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	7:27	7:29	0:02	LINE FAULT
56	15-Jan-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	9:22	9:32	0:09	TRANSFORMER FAULT
57	16-Jan-19	BAGALKOT	110	110/11KV,HV1	GADAG ROAD_110	3:36	15:40	12:04	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
58	16-Jan-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:49	13:12	0:23	LINE CLEAR AVAILED
59	16-Jan-19	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	12:55	13:54	0:59	LINE CLEAR AVAILED
60	16-Jan-19	BAGALKOT	110	220/110KV,LV1	KARWAR_220	10:47	10:49	0:02	HAND TRIPPED
61	16-Jan-19	BAGALKOT	110	220/110KV,LV1	KARWAR_220	12:36	12:37	0:01	HAND TRIPPED
62	16-Jan-19	BANGALORE	66	CHINTAMANI - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	12:25	12:35	0:10	MAIN SUPPLY FAILURE
63	16-Jan-19	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	16:10	16:12	0:02	LOAD CHANGEOVER
64	16-Jan-19	BANGALORE	66	T K HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:14	17:31	0:16	LINE FAULT
65	16-Jan-19	BANGALORE	66	T K HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:14	17:31	0:16	LINE FAULT
66	16-Jan-19	BANGALORE	66	HOODY 220N - POTTERY ROAD	POTTERY ROAD	17:39	18:06	0:26	LINE FAULT
67	16-Jan-19	BANGALORE	66	MELEHALLI - KEMPANAHALLI	JALAMAMGALA, KUTAGALLU, CHIKKAGANGANAWADI	13:31	14:02	0:30	LINE FAULT
68	16-Jan-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	12:25	12:35	0:10	MAIN SUPPLY FAILURE
69	16-Jan-19	BANGALORE	66	HV2	HOSKOTE 66	16:23	16:29	0:06	TRANSFORMER FAULT
70	16-Jan-19	BANGALORE	66	HV2	NANGALI	11:44	12:35	0:50	LINE CLEAR AVAILED
71	16-Jan-19	BANGALORE	66	HV3	NELAMANGALA 66	14:39	15:32	0:53	TRANSFORMER FAULT
72	16-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA	7:40	7:51	0:11	LINE FAULT
73	16-Jan-19	GULBARGA	110	HV2	HANUMANAL_110	12:25	12:35	0:10	TRANSFORMER FAULT
74	16-Jan-19	GULBARGA	110	HV2	KOLHAR_110	12:20	12:45	0:25	LINE CLEAR AVAILED
75	16-Jan-19	GULBARGA	110	HV3	KOLHAR_110	12:54	13:44	0:50	LINE CLEAR AVAILED
76	16-Jan-19	GULBARGA	110	HV1	SIRWAR_110	14:04	14:10	0:06	TRANSFORMER FAULT
77	16-Jan-19	GULBARGA	110	HUMNABAD220-BHALKI1	BHALKI_110,LADHA_110,MGSSK_IPP	15:58	16:32	0:34	LINE CLEAR AVAILED
78	16-Jan-19	GULBARGA	110	WADAGERA-COREGREEN IPP	WADAGERA_110	15:15	17:38	2:23	LINE CLEAR AVAILED
79	16-Jan-19	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	18:37	20:20	1:43	NFBC ISSUED
80	16-Jan-19	GULBARGA	66	LV1	ITTAGI_220	6:38	6:46	0:08	TRANSFORMER FAULT
81	16-Jan-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1,2	HIREHADAGALI_66,GIRIYAPURA_66,S OVENAHALLI_66,MAGLA_66,TUNGAB HADRA_IPP	6:38	6:50	0:12	LINE FAULT
82	16-Jan-19	GULBARGA	66	HV1	ITTAGI_220	6:38	6:48	0:10	TRANSFORMER FAULT
83	16-Jan-19	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66	11:02	11:11	0:09	LINE FAULT
84	16-Jan-19	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66	11:25	11:34	0:09	LINE FAULT
85	16-Jan-19	GULBARGA	66	HV1	ITTAGI_220	12:25	12:30	0:05	TRANSFORMER FAULT
86	16-Jan-19	GULBARGA	66	HV1	ITTAGI_220	14:25	14:34	0:09	LINE CLEAR AVAILED
87	16-Jan-19	GULBARGA	66	HV1	ITTAGI_220	14:45	14:54	0:09	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
88	16-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	2:18	23:59	21:41	HAND TRIPPED
89	16-Jan-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	11:43	20:44	9:01	LINE CLEAR AVAILED
90	16-Jan-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	10:42	13:43	3:01	LINE CLEAR AVAILED
91	16-Jan-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:43	20:43	9:00	NFBC ISSUED
92	16-Jan-19	HASSAN	220	HV2	PUTTUR_220	11:05	11:28	0:23	LINE CLEAR AVAILED
93	16-Jan-19	HASSAN	110	LV2	PUTTUR_220	11:05	11:29	0:24	LINE CLEAR AVAILED
94	16-Jan-19	HASSAN	110	HV1	KEMAR_220	23:46	23:59	0:13	LINE CLEAR AVAILED
95	16-Jan-19	HASSAN	110	ARSK2-ARSKR	ARSIKERE_220	14:19	14:47	0:28	LINE CLEAR AVAILED
96	16-Jan-19	HASSAN	110	ARSK2-ARSKR	ARSIKERE_220	17:38	17:46	0:08	LINE CLEAR AVAILED
97	16-Jan-19	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	14:21	14:48	0:27	LINE CLEAR AVAILED
98	16-Jan-19	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	17:36	17:47	0:11	LINE CLEAR AVAILED
99	16-Jan-19	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	9:12	9:23	0:11	LINE CLEAR AVAILED
100	16-Jan-19	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	14:15	14:47	0:32	LINE CLEAR AVAILED
101	16-Jan-19	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	9:13	9:23	0:10	LINE CLEAR AVAILED
102	16-Jan-19	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	14:23	14:51	0:28	LINE CLEAR AVAILED
103	16-Jan-19	HASSAN	110	HV1	ARSIKERE_220	9:24	14:34	5:10	LINE CLEAR AVAILED
104	16-Jan-19	HASSAN	110	HV2	ARSIKERE_220	14:26	17:46	3:20	LINE CLEAR AVAILED
105	16-Jan-19	HASSAN	110	LV1	ARSIKERE_220	9:32	14:36	5:04	LINE CLEAR AVAILED
106	16-Jan-19	HASSAN	110	LV2	ARSIKERE_220	14:29	17:43	3:14	LINE CLEAR AVAILED
107	16-Jan-19	HASSAN	66	HV1	HASSAN_220	6:45	7:32	0:47	TRANSFORMER FAULT
108	16-Jan-19	HASSAN	66	LINGADAHALLI	BHADRA_GEN	14:54	15:00	0:06	LINE FAULT
109	16-Jan-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADNUR_66	11:00	17:06	6:06	LINE CLEAR AVAILED
110	16-Jan-19	HASSAN	66	HV1	DODDAKADNUR_66	11:00	17:06	6:06	LINE CLEAR AVAILED
111	16-Jan-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	11:00	17:06	6:06	LINE CLEAR AVAILED
112	16-Jan-19	HASSAN	66	HV1	HARIHARPURA_66	13:12	13:19	0:07	TRANSFORMER FAULT
113	16-Jan-19	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	6:50	7:35	0:45	LINE FAULT
114	16-Jan-19	HASSAN	66	HASSN220-PGCL	HASSAN_220	6:50	7:35	0:45	LINE FAULT
115	16-Jan-19	HASSAN	66	HASSN220-HSN66	HASSAN_220	6:50	7:35	0:45	LINE FAULT
116	16-Jan-19	HASSAN	66	HASSN220-CRP2	HASSAN_220	6:50	7:35	0:45	LINE FAULT
117	16-Jan-19	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	6:50	7:35	0:45	LINE FAULT
118	16-Jan-19	HASSAN	66	HNPUR2-MYSOR2	HNPURA_220	10:56	16:58	6:02	LINE CLEAR AVAILED
119	16-Jan-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:20	10:26	0:06	LINE FAULT
120	16-Jan-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:20	10:25	0:05	LOAD CURTAILMENT
121	16-Jan-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:25	10:30	0:05	HAND TRIPPED
122	16-Jan-19	MYSORE	66	HV2	JAKKANAHALLY_66	10:11	17:31	7:20	LINE CLEAR AVAILED
123	16-Jan-19	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66	9:23	9:32	0:09	LINE FAULT
124	16-Jan-19	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66	17:10	17:31	0:21	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
125	16-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	3:24	8:15	4:50	HAND TRIPPED
126	16-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	13:28	23:59	10:30	HAND TRIPPED
127	16-Jan-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA	MRSMSG_220	10:43	13:44	3:01	LINE CLEAR AVAILED
128	16-Jan-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:05	16:30	0:24	HAND TRIPPED
129	16-Jan-19	TUMKUR	110	TR-1	KALLUR_110	13:13	21:28	8:14	LINE CLEAR AVAILED
130	16-Jan-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	7:54	9:14	1:20	HAND TRIPPED
131	16-Jan-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	7:54	9:14	1:19	HAND TRIPPED
132	16-Jan-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	7:54	9:38	1:44	HAND TRIPPED
133	16-Jan-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	15:09	20:20	5:10	LINE CLEAR AVAILED
134	16-Jan-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	CHITRADURGA_66	11:33	12:34	1:00	LINE CLEAR AVAILED
135	16-Jan-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	CHITRADURGA_66	11:33	12:34	1:00	LINE CLEAR AVAILED
136	16-Jan-19	TUMKUR	66	TR-1	HANAGAL_66	11:08	11:26	0:17	LINE CLEAR AVAILED
137	16-Jan-19	TUMKUR	66	HARAPPANAHALLI-ITTAGI	HARAPPANAHALLI_66	13:25	15:15	1:50	LINE CLEAR AVAILED
138	16-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:46	7:54	0:08	LINE FAULT
139	16-Jan-19	TUMKUR	66	TR-2	SHYLAPURA_66	12:38	12:40	0:01	HAND TRIPPED
140	16-Jan-19	TUMKUR	66	TR-1	SASALUHALLA_66	7:52	7:57	0:04	TRANSFORMER FAULT
141	16-Jan-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:39	18:46	0:07	HAND TRIPPED
142	16-Jan-19	TUMKUR	66	TR-2	TUMKUR_66	1:01	1:18	0:16	TRANSFORMER FAULT
143	16-Jan-19	TUMKUR	66	TR-1	YEDIYUR_66	13:24	17:20	3:56	LINE CLEAR AVAILED
144	17-Jan-19	BAGALKOT	110	110/11KV,HV1	GADAG_110	14:57	17:00	2:03	LINE CLEAR AVAILED
145	17-Jan-19	BAGALKOT	110	GHATAPRABHA220-NAGAR MUAVALLI	NAGAR MUAVALLI_110	5:43	5:52	0:09	LINE FAULT
146	17-Jan-19	BAGALKOT	220	NARENDRA400-GHATAPRABHA	GHATAPRABHA_220	9:35	18:30	8:55	NFBC ISSUED
147	17-Jan-19	BAGALKOT	220	BIDNAL-HAVERI	HAVERI_220	8:41	17:32	8:51	NFBC ISSUED
148	17-Jan-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	13:03	13:04	0:01	HAND TRIPPED
149	17-Jan-19	BAGALKOT	110	110/11KV,HV2	UGARKHUD_110	19:51	20:01	0:10	TRANSFORMER FAULT
150	17-Jan-19	BAGALKOT	110	220/110KV,HV2	HUBLI_220	15:41	16:56	1:15	LINE CLEAR AVAILED
151	17-Jan-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	10:15	15:01	4:46	LINE CLEAR AVAILED
152	17-Jan-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	14:53	15:14	0:21	LINE CLEAR AVAILED
153	17-Jan-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	16:49	17:04	0:15	LINE CLEAR AVAILED
154	17-Jan-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	15:20	16:12	0:52	LINE CLEAR AVAILED
155	17-Jan-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,ITANAL_110,HI DIKAL_110	10:55	11:10	0:15	TRANSFORMER FAULT
156	17-Jan-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	11:06	11:17	0:11	MAIN SUPPLY FAILURE
157	17-Jan-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	0:00	16:05	16:05	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
158	17-Jan-19	BANGALORE	66	HV2	DEVARABISANAHALLI	22:05	22:10	0:05	TRANSFORMER FAULT
159	17-Jan-19	BANGALORE	66	GOLF LINKS - ADUGODI 2	GOLF LINKS	11:50	11:55	0:05	LOAD CHANGEOVER
160	17-Jan-19	BANGALORE	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	14:00	14:05	0:05	LOAD CHANGEOVER
161	17-Jan-19	BANGALORE	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA	16:31	16:57	0:25	LINE CLEAR AVAILED
162	17-Jan-19	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1 & 2	ELECTRONIC CITY, INFOSYS (EHT), BOMMASANDRA I/A, BIOCON (EHT)	15:21	16:25	1:03	MAIN SUPPLY FAILURE
163	17-Jan-19	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 1 & 2	ANEKAL, SURYANAGAR	15:21	16:25	1:03	MAIN SUPPLY FAILURE
164	17-Jan-19	BANGALORE	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	15:21	16:25	1:03	MAIN SUPPLY FAILURE
165	17-Jan-19	BANGALORE	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YARANDANAHALLI 220	15:21	16:25	1:03	LINE CLEAR AVAILED
166	17-Jan-19	BANGALORE	220	YARANDANAHALLI 220 - HOSUR 220	YARANDANAHALLI 220	15:21	16:37	1:15	LINE CLEAR AVAILED
167	17-Jan-19	BANGALORE	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220	15:21	16:10	0:49	LINE CLEAR AVAILED
168	17-Jan-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	15:21	16:10	0:49	MAIN SUPPLY FAILURE
169	17-Jan-19	BANGALORE	66	HV1	YARANDANAHALLI 220	15:21	16:37	1:15	MAIN SUPPLY FAILURE
170	17-Jan-19	BANGALORE	66	HV2	YARANDANAHALLI 220	15:21	16:37	1:15	MAIN SUPPLY FAILURE
171	17-Jan-19	BANGALORE	66	HV3	YARANDANAHALLI 220	15:21	16:37	1:15	MAIN SUPPLY FAILURE
172	17-Jan-19	BANGALORE	66	DB PURA 220 - CB PURA 1 & 2	TUBUGERE, CB PURA I/A, CB PURA URBAN	13:26	15:07	1:41	LINE CLEAR AVAILED
173	17-Jan-19	BANGALORE	66	HV1	GUNDLU KOTTUR	16:59	17:19	0:19	LINE CLEAR AVAILED
174	17-Jan-19	BANGALORE	66	HV1	HULLENAHALLI	10:40	11:07	0:27	LINE CLEAR AVAILED
175	17-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	KYALANUR, VEMGAL	5:49	5:53	0:03	LINE FAULT
176	17-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	KYALANUR, VEMGAL	6:25	13:45	7:20	LINE FAULT
177	17-Jan-19	BANGALORE	66	YELAHANKA 220 - DG3	MANYATHA TECH PARK, ABBIGERE, ATTUR YELAHANKA	11:21	11:35	0:14	LINE FAULT
178	17-Jan-19	BANGALORE	66	MATHIKERE - GOKULA	MATHIKERE	10:05	10:10	0:05	LOAD CHANGEOVER
179	17-Jan-19	BANGALORE	66	MATHIKERE - HEBBAL 220	MATHIKERE	12:10	12:14	0:04	LOAD CHANGEOVER
180	17-Jan-19	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	15:24	16:57	1:33	LINE FAULT
181	17-Jan-19	GULBARGA	110	HALBURGA-ACMESOLAR	HALBURGA_220	12:25	12:35	0:10	LINE FAULT
182	17-Jan-19	GULBARGA	110	BYAGAWAT-ACMBSLR	BYAGAWAT_110	12:41	13:01	0:20	LINE FAULT
183	17-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:00	12:15	0:15	LINE FAULT
184	17-Jan-19	GULBARGA	110	HV2	KOLHAR_110	17:10	17:20	0:10	TRANSFORMER FAULT
185	17-Jan-19	GULBARGA	110	HV1	RAICHUR_220	23:14	23:16	0:02	TRANSFORMER FAULT
186	17-Jan-19	GULBARGA	66	SOVENAHALLI-ITTAGGI	SOVENAHALLI_66	10:55	11:33	0:38	LINE CLEAR AVAILED
187	17-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	7:08	7:08	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
188	17-Jan-19	HASSAN	220	HV1	KADUR_220	9:10	15:10	6:00	LINE CLEAR AVAILED
189	17-Jan-19	HASSAN	220	HV2	KADUR_220	15:15	18:47	3:32	LINE CLEAR AVAILED
190	17-Jan-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	0:00	16:48	16:48	LINE CLEAR AVAILED
191	17-Jan-19	HASSAN	220	VARAHI-KEMAR3	VARAHI_GEN	0:00	16:46	16:46	NFBC ISSUED
192	17-Jan-19	HASSAN	110	HV2	HALADY_110	11:29	12:54	1:25	LINE CLEAR AVAILED
193	17-Jan-19	HASSAN	110	LV1	KADUR_220	9:10	15:10	6:00	LINE CLEAR AVAILED
194	17-Jan-19	HASSAN	110	LV2	KADUR_220	15:15	18:47	3:32	LINE CLEAR AVAILED
195	17-Jan-19	HASSAN	110	HV4	PUTTUR_110	9:59	13:06	3:07	LINE CLEAR AVAILED
196	17-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:06	17:32	10:26	LINE CLEAR AVAILED
197	17-Jan-19	HASSAN	66	HNPR2-HASS3	HOLENRASIPURA_220	8:05	8:25	0:20	LINE FAULT
198	17-Jan-19	HASSAN	66	HNPR2-MYSOR1	HOLENRASIPURA_220	16:24	16:35	0:11	LINE FAULT
199	17-Jan-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	16:36	16:40	0:04	MAIN SUPPLY FAILURE
200	17-Jan-19	HASSAN	66	HV2	KIADB_66	11:45	12:00	0:15	TRANSFORMER FAULT
201	17-Jan-19	HASSAN	66	HV2	KIADB_66	12:00	12:20	0:20	TRANSFORMER FAULT
202	17-Jan-19	HASSAN	66	HV2	KIADB_66	13:10	13:20	0:10	TRANSFORMER FAULT
203	17-Jan-19	MYSORE	66	HV2	AKKIHEBBAL_66	7:25	7:37	0:12	LOAD CURTAILMENT
204	17-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	7:25	7:41	0:16	LOAD CURTAILMENT
205	17-Jan-19	MYSORE	66	HV2	CHINAKURALI_66	7:26	7:57	0:30	LOAD CURTAILMENT
206	17-Jan-19	MYSORE	66	DEVNUR(MYS)-VAJAMANGALA	DEVANOORMYS_66	10:52	10:57	0:05	LINE FAULT
207	17-Jan-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	DEVANOORMYS_66	10:52	10:59	0:06	LINE FAULT
208	17-Jan-19	MYSORE	66	DEVNUR(MYS)-VAJAMANGALA	DEVANOORMYS_66	14:56	15:02	0:06	LINE FAULT
209	17-Jan-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	DEVANOORMYS_66	14:56	15:07	0:11	LINE FAULT
210	17-Jan-19	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	7:18	7:26	0:07	LINE FAULT
211	17-Jan-19	MYSORE	66	HV1	JAKKANAHALLY_66	11:00	11:13	0:12	LOAD CURTAILMENT
212	17-Jan-19	MYSORE	66	HV2	KIRUGAVALU_66	7:26	7:45	0:19	LOAD CURTAILMENT
213	17-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K_HONNALGERE_66	11:13	11:15	0:01	HAND TRIPPED
214	17-Jan-19	MYSORE	66	KM DODDI-SCSL	KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K_HONNALGERE_66	11:13	11:15	0:01	HAND TRIPPED
215	17-Jan-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 BILIKERE_66 GVGUDI_66 KRNAGARA_66 BHERYA_66	3:08	3:18	0:10	LINE FAULT
216	17-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	11:01	17:44	6:42	LINE CLEAR AVAILED
217	17-Jan-19	MYSORE	66	HV1	PERIYAPATNA_66	13:29	14:26	0:56	LINE CLEAR AVAILED
218	17-Jan-19	MYSORE	66	HV2	PERIYAPATNA_66	12:01	13:24	1:22	LINE CLEAR AVAILED
219	17-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	7:26	7:30	0:04	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
220	17-Jan-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:26	7:41	0:14	LOAD CURTAILMENT
221	17-Jan-19	MYSORE	66	HV4	SFCSHIVA_66	19:16	23:59	4:42	NFBC ISSUED
222	17-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	13:09	20:12	7:02	HAND TRIPPED
223	17-Jan-19	TUMKUR	110	TR-1	GUBBI_110	19:25	19:39	0:13	TRANSFORMER FAULT
224	17-Jan-19	TUMKUR	110	HUNSEGHATTA_11-KBCROSS_66(HONNAVALI)	HUNSEGHATTA_110,	16:21	17:03	0:42	LINE CLEAR AVAILED
225	17-Jan-19	TUMKUR	110	TR-1	SAMPIGE_110	21:06	21:12	0:06	TRANSFORMER FAULT
226	17-Jan-19	TUMKUR	66	TR-1	BADAVANAHALLI_66	13:49	15:45	1:55	LINE CLEAR AVAILED
227	17-Jan-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:01	12:55	2:54	LINE CLEAR AVAILED
228	17-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:35	17:34	8:59	HAND TRIPPED
229	17-Jan-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	16:15	16:39	0:24	LINE CLEAR AVAILED
230	17-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:18	8:31	0:12	MAIN SUPPLY FAILURE
231	17-Jan-19	TUMKUR	66	TR-1	LINGADAHALLY_66	18:56	19:08	0:12	TRANSFORMER FAULT
232	17-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	16:09	16:13	0:04	HAND TRIPPED
233	18-Jan-19	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	7:33	23:59	16:26	NFBC ISSUED
234	18-Jan-19	BAGALKOT	220	220/110KV,HV1&LV1	SOUDATTI_220	12:29	13:27	0:58	LINE CLEAR AVAILED
235	18-Jan-19	BAGALKOT	220	220/110KV,HV1&LV1	SOUDATTI_220	13:27	15:04	1:37	HAND TRIPPED
236	18-Jan-19	BAGALKOT	220	220/110KV,HV2&LV2	SOUDATTI_220	15:43	18:03	2:20	LINE CLEAR AVAILED
237	18-Jan-19	BAGALKOT	220	220/110KV,HV2&LV2	SOUDATTI_220	18:03	18:14	0:11	HAND TRIPPED
238	18-Jan-19	BAGALKOT	220	220/110KV,HV2&LV2	SOUDATTI_220	18:14	18:40	0:26	HAND TRIPPED
239	18-Jan-19	BAGALKOT	110	110/33KV,HV3	ANKALI_110,NANDIKURALI 33KV	22:14	22:23	0:09	TRANSFORMER FAULT
240	18-Jan-19	BAGALKOT	110	110/11KV,HV1	GOKAK_110	9:52	12:00	2:08	TRANSFORMER FAULT
241	18-Jan-19	BAGALKOT	110	JAMBAGI-VAJRAMATTI	MUDHOL_110(STATION NOT INTERRUPTED)	0:00	16:13	16:13	HAND TRIPPED
242	18-Jan-19	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	16:02	23:59	7:57	HAND TRIPPED
243	18-Jan-19	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	12:08	13:57	1:49	LINE CLEAR AVAILED
244	18-Jan-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	10:23	13:48	3:25	LINE CLEAR AVAILED
245	18-Jan-19	BAGALKOT	110	RAMANAKOPPA-MUNDAGOD	MUNDAGOD_110	18:08	18:45	0:37	LINE CLEAR AVAILED
246	18-Jan-19	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	15:13	17:33	2:20	LINE CLEAR AVAILED
247	18-Jan-19	BAGALKOT	110	110/11KV,HV1	GADAG ROAD_110	10:06	11:25	1:19	LINE CLEAR AVAILED
248	18-Jan-19	BAGALKOT	110	110/11KV,HV1	KIRUVATTI_110	10:36	15:30	4:54	LINE CLEAR AVAILED
249	18-Jan-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YELLAPUR_33	16:28	19:21	2:53	LINE CLEAR AVAILED
250	18-Jan-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	14:54	15:00	0:06	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
251	18-Jan-19	BENGALURU	66	NANGALI - KEMBODI	NANGALI	11:20	11:41	0:21	LINE CLEAR AVAILED
252	18-Jan-19	BENGALURU	66	HV2	TEMAGONDALU	8:29	8:50	0:21	LINE CLEAR AVAILED
253	18-Jan-19	BENGALURU	66	HV1	MAGADI 220	18:13	18:18	0:05	LOAD CHANGEOVER
254	18-Jan-19	BENGALURU	220	HV1	YARANDANAHALLI 220	4:55	5:36	0:41	TRANSFORMER FAULT
255	18-Jan-19	BENGALURU	66	HV1	YARANDANAHALLI 220	4:55	5:36	0:41	MAIN SUPPLY FAILURE
256	18-Jan-19	BENGALURU	66	HV2	YARANDANAHALLI 220	4:55	5:36	0:41	MAIN SUPPLY FAILURE
257	18-Jan-19	BENGALURU	66	HV3	YARANDANAHALLI 220	4:55	5:36	0:41	MAIN SUPPLY FAILURE
258	18-Jan-19	BENGALURU	66	HV2	VICTORIA HOSPITAL	11:27	11:36	0:08	TRANSFORMER FAULT
259	18-Jan-19	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	0:40	1:04	0:23	LINE FAULT
260	18-Jan-19	BENGALURU	66	HV2	GOKULA	10:05	11:50	1:45	LINE CLEAR AVAILED
261	18-Jan-19	GULBARGA	220	BMMISPAT-ITTAGI	ITTAGI_220	7:19	9:10	1:51	LINE FAULT
262	18-Jan-19	GULBARGA	220	BMMISPAT-ITTAGI	ITTAGI_220	18:27	19:23	0:56	LINE CLEAR AVAILED
263	18-Jan-19	GULBARGA	220	HUMNABAD220-KAPNOOR1	HUMNABAD_220	15:45	19:10	3:25	LINE CLEAR AVAILED
264	18-Jan-19	GULBARGA	110	SINDHANOOR220-SIRUGUPPA	DHADESUGUR_110,SIRIGUPPA_110,T EKKALAKOTE_110,NSL_SUGAR_IPP	6:47	6:54	0:07	LINE FAULT
265	18-Jan-19	GULBARGA	110	WADAGERA-CLEANSOLAR	WADAGERA_110	18:34	23:59	5:25	LINE CLEAR AVAILED
266	18-Jan-19	GULBARGA	66	HV1	ITTAGI_220	12:22	12:27	0:05	TRANSFORMER FAULT
267	18-Jan-19	GULBARGA	66	HV1	ITTAGI_220	12:32	12:38	0:06	TRANSFORMER FAULT
268	18-Jan-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	12:04	23:59	11:55	LINE CLEAR AVAILED
269	18-Jan-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	6:40	7:10	0:30	LINE FAULT
270	18-Jan-19	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	12:09	23:59	11:50	NFBC ISSUED
271	18-Jan-19	HASSAN	110	HV1	BIRUR_110	15:30	17:35	2:05	LINE CLEAR AVAILED
272	18-Jan-19	HASSAN	110	HV2	BIRUR_110	10:15	15:30	5:15	LINE CLEAR AVAILED
273	18-Jan-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	13:05	13:10	0:05	LINE CLEAR AVAILED
274	18-Jan-19	HASSAN	110	HV3	MANIPAL_110	9:52	12:59	3:07	LINE CLEAR AVAILED
275	18-Jan-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLI_66	10:20	14:20	4:00	NFBC ISSUED
276	18-Jan-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	11:28	14:13	2:45	LOAD CURTAILMENT
277	18-Jan-19	HASSAN	66	HV1	DODDAKADANUR_66	11:21	14:15	2:54	LOAD CURTAILMENT
278	18-Jan-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	11:21	14:11	2:50	LOAD CURTAILMENT
279	18-Jan-19	HASSAN	66	HIREMAN-RDL	HIREMAGALUR_66	0:42	0:48	0:06	LINE FAULT
280	18-Jan-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:20	13:48	2:28	LINE CLEAR AVAILED
281	18-Jan-19	HASSAN	66	HNPR2-MYSOR2	HNPR2	11:20	13:48	2:28	LINE CLEAR AVAILED
282	18-Jan-19	MYSORE	66	BASARALU-NAGAMANGALA	BASARALU_66	7:05	8:50	1:45	NFBC ISSUED
283	18-Jan-19	MYSORE	66	BG NAGARA-NAGAMANGALA	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	7:05	9:10	2:05	LINE CLEAR AVAILED
284	18-Jan-19	MYSORE	66	BOGADHI-HOOTAGALLI	BOGADHI_66	10:04	16:48	6:44	LINE CLEAR AVAILED
285	18-Jan-19	MYSORE	66	ELAVALA-HOOTAGALLI	ELAVALA_66	10:58	12:08	1:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
286	18-Jan-19	MYSORE	66	ELAVALA-HUNSUR	ELAVALA_66	10:58	12:11	1:13	LINE CLEAR AVAILED
287	18-Jan-19	MYSORE	66	HV2	KMDODDI_66	13:42	14:46	1:03	TRANSFORMER FAULT
288	18-Jan-19	MYSORE	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 THUMLA_66 TNARASIPURA_66	7:28	7:41	0:13	LINE FAULT
289	18-Jan-19	MYSORE	66	HV1	MADIKERI_66	10:38	12:14	1:36	LINE CLEAR AVAILED
290	18-Jan-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	6:41	6:48	0:06	LINE FAULT
291	18-Jan-19	MYSORE	66	HV2	PANDAVAPURA_66	15:21	16:00	0:39	LINE CLEAR AVAILED
292	18-Jan-19	MYSORE	66	HV2	RKNAGARA_66	10:09	14:54	4:45	LINE CLEAR AVAILED
293	18-Jan-19	MYSORE	66	HV1	SANTHEMARAHALLI_66	13:19	17:26	4:07	LINE CLEAR AVAILED
294	18-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	4:22	14:04	9:41	HAND TRIPPED
295	18-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	21:19	23:59	2:39	HAND TRIPPED
296	18-Jan-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	7:03	9:03	2:00	LINE CLEAR AVAILED
297	18-Jan-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	16:46	16:55	0:08	HAND TRIPPED
298	18-Jan-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	7:43	8:40	0:56	HAND TRIPPED
299	18-Jan-19	TUMKUR	110	TR-3	GUBBI_110	18:44	19:51	1:07	TRANSFORMER FAULT
300	18-Jan-19	TUMKUR	110	TR-2	KBCROSS_220	13:31	13:33	0:01	LINE CLEAR AVAILED
301	18-Jan-19	TUMKUR	110	TR1	KBCROSS_220	13:33	15:11	1:37	LINE CLEAR AVAILED
302	18-Jan-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:54	20:39	5:44	LINE CLEAR AVAILED
303	18-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	17:03	17:11	0:07	TRANSFORMER FAULT
304	18-Jan-19	TUMKUR	66	TR-1	CHITRADURGA_66	8:40	9:06	0:26	TRANSFORMER FAULT
305	18-Jan-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	7:11	7:21	0:09	HAND TRIPPED
306	18-Jan-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	7:11	7:19	0:08	HAND TRIPPED
307	18-Jan-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:11	7:17	0:06	HAND TRIPPED
308	18-Jan-19	TUMKUR	66	HARAPPANAHALLI-ITTAGI	HARAPPANAHALLI_66	11:27	13:15	1:47	HAND TRIPPED
309	18-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	7:15	7:24	0:09	MAIN SUPPLY FAILURE
310	18-Jan-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	12:22	12:27	0:05	HAND TRIPPED
311	18-Jan-19	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	18:36	21:36	2:59	LINE CLEAR AVAILED
312	18-Jan-19	TUMKUR	66	TR-1	LINGADAHALLY_66	14:35	15:36	1:01	HAND TRIPPED
313	18-Jan-19	TUMKUR	66	TR-1	MAVINAKATTE_66	3:57	4:51	0:53	TRANSFORMER FAULT
314	18-Jan-19	TUMKUR	66	TR-2	RAMPURA_66	12:40	12:48	0:08	LINE CLEAR AVAILED
315	19-Jan-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110,YADWAD_33, VANTAGODI_33	12:02	13:00	0:58	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
316	19-Jan-19	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:28	14:45	1:17	LINE CLEAR AVAILED
317	19-Jan-19	BAGALKOT	110	110/33KV, HV2	RATTIHALLI_110,HALLUR_33,MASSUR_33	10:39	18:54	8:15	LINE CLEAR AVAILED
318	19-Jan-19	BAGALKOT	110	110/11KV, HV3	RATTIHALLI_110	10:39	19:05	8:26	LINE CLEAR AVAILED
319	19-Jan-19	BAGALKOT	110	RANEENNUR-RATTIHALI	RATTIHALLI_110	12:07	19:04	6:57	LINE CLEAR AVAILED
320	19-Jan-19	BAGALKOT	110	SOUDATTI2-RAMDURGA	RAMDURGA_110	12:08	12:55	0:47	LINE CLEAR AVAILED
321	19-Jan-19	BAGALKOT	220	SHIROLKOPPA-RANEENNUR	RANEENNUR_220	19:49	23:59	4:10	HAND TRIPPED
322	19-Jan-19	BAGALKOT	110	NARENDRA-KUD1	KUD DHARWAD_110	12:43	23:59	11:16	HAND TRIPPED
323	19-Jan-19	BAGALKOT	110	BPCL-NARGUND	NARGUND_110	18:43	19:19	0:36	LINE CLEAR AVAILED
324	19-Jan-19	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	9:58	16:58	7:00	LINE CLEAR AVAILED
325	19-Jan-19	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	0:00	15:09	15:09	LINE CLEAR AVAILED
326	19-Jan-19	BAGALKOT	110	110/11KV,HV-2	GOKAK_110	14:27	23:59	9:32	TRANSFORMER FAULT
327	19-Jan-19	BAGALKOT	110	BIDNAL-NAVLKD(NARAGUND - GOPANAKOPPA	GOPANAKOPPA_110	10:31	16:29	5:58	NFBC ISSUED
328	19-Jan-19	BAGALKOT	110	110/11KV,HV-1A	JAMAKHANDI_110	20:07	23:47	3:40	LINE CLEAR AVAILED
329	19-Jan-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	10:45	16:55	6:10	LINE CLEAR AVAILED
330	19-Jan-19	BAGALKOT	110	110/11KV,HV-1	KONNUR_110	10:18	17:02	6:44	LINE CLEAR AVAILED
331	19-Jan-19	BAGALKOT	110	KONNUR-KERUR	KONNUR_110	10:58	23:59	13:01	LINE CLEAR AVAILED
332	19-Jan-19	BAGALKOT	110	KONNUR-ANANT SOLAR	KONNUR_110	11:49	18:20	6:31	LINE CLEAR AVAILED
333	19-Jan-19	BAGALKOT	110	NARENDRA -KUD DHARWAD	KUD DHARWAD_110	13:51	14:48	0:57	LINE CLEAR AVAILED
334	19-Jan-19	BANGALORE	66	HV2	TUBUGERE	14:47	14:52	0:05	TRANSFORMER FAULT
335	19-Jan-19	BANGALORE	66	HV2	SOMAYAJJANAHALLI	11:24	11:50	0:25	LINE CLEAR AVAILED
336	19-Jan-19	BANGALORE	66	HV2	NARASAPURA	13:46	14:00	0:14	TRANSFORMER FAULT
337	19-Jan-19	BANGALORE	66	HV2	THIMMAMPALLI	13:00	14:08	1:08	LINE CLEAR AVAILED
338	19-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	7:07	7:36	0:29	LINE FAULT
339	19-Jan-19	BANGALORE	66	HV2	GUDIBANDE	13:04	13:08	0:03	LINE CLEAR AVAILED
340	19-Jan-19	BANGALORE	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	11:49	12:32	0:42	LINE CLEAR AVAILED
341	19-Jan-19	BANGALORE	66	HV2	CB PURA URBAN	12:08	12:10	0:01	LINE CLEAR AVAILED
342	19-Jan-19	BANGALORE	66	HV1	CHELUR	14:59	15:02	0:03	TRANSFORMER FAULT
343	19-Jan-19	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE, MATHIKERE	11:04	12:11	1:06	MAIN SUPPLY FAILURE
344	19-Jan-19	BANGALORE	66	HV2	HAL 220	11:07	12:00	0:53	LINE CLEAR AVAILED
345	19-Jan-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	6:39	7:06	0:26	LINE FAULT
346	19-Jan-19	BANGALORE	66	HV2	KADUBISANAHALLI	15:35	16:35	1:00	LINE CLEAR AVAILED
347	19-Jan-19	BANGALORE	66	HV1	KADUBISANAHALLI	14:15	15:02	0:47	LINE CLEAR AVAILED
348	19-Jan-19	BANGALORE	66	HV2	LEELA VENTURE	9:20	9:52	0:32	LINE CLEAR AVAILED
349	19-Jan-19	BANGALORE	66	HV1	NANDINI LAYOUT	13:55	14:00	0:05	LINE CLEAR AVAILED
350	19-Jan-19	BANGALORE	66	HV2	NANDINI LAYOUT	11:00	11:05	0:05	LINE CLEAR AVAILED
351	19-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	10:37	10:40	0:03	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
352	19-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	9:33	9:38	0:05	LOAD CHANGEOVER
353	19-Jan-19	BANGALORE	66	HV2	VICTORIA HOSPITAL	2:49	2:58	0:09	TRANSFORMER FAULT
354	19-Jan-19	BANGALORE	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	11:21	11:43	0:22	LINE FAULT
355	19-Jan-19	BANGALORE	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220	11:21	11:25	0:03	LINE FAULT
356	19-Jan-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS	11:21	11:46	0:24	MAIN SUPPLY FAILURE
357	19-Jan-19	BANGALORE	66	HSR LAYOUT 220 - ST JOHNS WOOD	ST JOHNS WOOD	11:21	11:46	0:24	MAIN SUPPLY FAILURE
358	19-Jan-19	BANGALORE	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	11:21	11:46	0:24	MAIN SUPPLY FAILURE
359	19-Jan-19	BANGALORE	66	NIMHANS 220 - AUDUGODI	ADUGODI, BOSCH (EHT), KC VALLEY, NAL(EHT)	11:21	11:56	0:35	MAIN SUPPLY FAILURE
360	19-Jan-19	BANGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA	11:21	11:34	0:12	MAIN SUPPLY FAILURE
361	19-Jan-19	BANGALORE	66	JAYADEVA - NIMHANS 220	JAYADEVA	11:56	11:58	0:02	LOAD CHANGEOVER
362	19-Jan-19	BANGALORE	66	JAYADEVA - SARAKKI 1 & 2	JAYADEVA	15:56	16:06	0:10	LOAD CHANGEOVER
363	19-Jan-19	BANGALORE	66	NIMHANS 220 - JAYANAGARA	JAYANAGARA	11:21	11:50	0:29	MAIN SUPPLY FAILURE
364	19-Jan-19	BANGALORE	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	11:21	11:52	0:30	MAIN SUPPLY FAILURE
365	19-Jan-19	BANGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	13:48	13:54	0:06	LOAD CHANGEOVER
366	19-Jan-19	BANGALORE	220	HV3	YARANDANAHALLI 220	6:48	7:07	0:19	TRANSFORMER FAULT
367	19-Jan-19	BANGALORE	66	HV1	YARANDANAHALLI 220	6:48	7:07	0:19	MAIN SUPPLY FAILURE
368	19-Jan-19	BANGALORE	66	HV2	YARANDANAHALLI 220	6:48	7:07	0:19	MAIN SUPPLY FAILURE
369	19-Jan-19	BANGALORE	66	HV3	YARANDANAHALLI 220	6:48	7:07	0:19	MAIN SUPPLY FAILURE
370	19-Jan-19	GULBARGA	220	LINGAPUR-GUDAHALLI-2	LINGAPUR_220	10:31	15:12	4:41	LINE CLEAR AVAILED
371	19-Jan-19	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	20:26	20:57	0:31	LINE FAULT
372	19-Jan-19	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	20:26	20:57	0:31	LINE FAULT
373	19-Jan-19	GULBARGA	110	WADAGERA-CLEANSOLAR	WADAGERA_110	0:00	1:35	1:35	LINE CLEAR AVAILED
374	19-Jan-19	GULBARGA	110	HV3	DEODURGA_110	11:34	12:16	0:42	LINE CLEAR AVAILED
375	19-Jan-19	GULBARGA	110	HV2	KAMPLI_GLB_110	11:24	12:45	1:21	LINE CLEAR AVAILED
376	19-Jan-19	GULBARGA	110	ALIPUR-MUNIRABAD	KUDITINI_110,KURUGOD_110,TORAN GALLU_110,KAMALAPUR_110,METRI_110	20:26	20:57	0:31	LINE FAULT
377	19-Jan-19	GULBARGA	110	ALIPUR-BELLARY SOUTH2	BELLARYSOUTH_110,HALKUNDI_110	9:15	17:28	8:13	LINE CLEAR AVAILED
378	19-Jan-19	GULBARGA	110	WADAGERA-CLEANSOLAR_IPP	WADAGERA_110	18:14	21:26	3:12	LINE CLEAR AVAILED
379	19-Jan-19	HASSAN	220	HV1	HASSAN_220	10:25	14:10	3:45	LINE CLEAR AVAILED
380	19-Jan-19	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	10:25	14:10	3:45	LINE CLEAR AVAILED
381	19-Jan-19	HASSAN	66	HASSN220-BELUR	HASSAN_220	10:21	10:42	0:21	LINE CLEAR AVAILED
382	19-Jan-19	HASSAN	66	HASSN220-BELUR	HASSAN_220	14:09	14:17	0:08	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
383	19-Jan-19	HASSAN	66	LV1	HASSAN_220	10:25	14:10	3:45	LINE CLEAR AVAILED
384	19-Jan-19	HASSAN	66	HASSN220-CRP2	HASSAN_220	10:25	14:10	3:45	LINE CLEAR AVAILED
385	19-Jan-19	HASSAN	66	HASSN220-SKPURA	HASSAN_220	10:22	14:18	3:56	LINE CLEAR AVAILED
386	19-Jan-19	HASSAN	66	HASSN220-SKPURA	HASSAN_220	14:18	14:23	0:05	HAND TRIPPED
387	19-Jan-19	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	10:22	10:43	0:21	HAND TRIPPED
388	19-Jan-19	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	14:09	14:17	0:08	HAND TRIPPED
389	19-Jan-19	HASSAN	110	HV2	GANDSI_110	19:22	19:31	0:09	TRANSFORMER FAULT
390	19-Jan-19	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	15:30	16:14	0:44	LINE CLEAR AVAILED
391	19-Jan-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:58	13:05	1:07	MAIN SUPPLY FAILURE
392	19-Jan-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	13:06	13:24	0:18	MAIN SUPPLY FAILURE
393	19-Jan-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	14:26	17:38	3:12	LINE CLEAR AVAILED
394	19-Jan-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:45	16:22	0:37	LINE CLEAR AVAILED
395	19-Jan-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:45	16:22	0:37	LINE CLEAR AVAILED
396	19-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:35	16:32	4:57	LINE CLEAR AVAILED
397	19-Jan-19	HASSAN	66	HV1	BYACHANAHALLI_66	11:05	11:30	0:25	LINE CLEAR AVAILED
398	19-Jan-19	HASSAN	66	HV1	HASSAN_66	10:07	12:55	2:48	LINE CLEAR AVAILED
399	19-Jan-19	HASSAN	66	KIADB-HASAN I\C	KIADB_66	15:57	18:50	2:53	MAIN SUPPLY FAILURE
400	19-Jan-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	14:55	18:01	3:06	LINE CLEAR AVAILED
401	19-Jan-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	14:55	18:03	3:08	LINE CLEAR AVAILED
402	19-Jan-19	HASSAN	66	HV1	SHANTHIGRAMA_66	10:10	10:15	0:05	TRANSFORMER FAULT
403	19-Jan-19	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	10:28	14:46	4:18	MAIN SUPPLY FAILURE
404	19-Jan-19	TUMKUR	220	DAVANGERE SRS- GutrIn3	GUTTUR_66	14:38	19:48	5:10	NFBC ISSUED
405	19-Jan-19	TUMKUR	110	TR-3	GUBBI_110	11:35	16:28	4:52	LINE CLEAR AVAILED
406	19-Jan-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:49	19:41	4:51	LINE CLEAR AVAILED
407	19-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:41	8:44	0:03	TRANSFORMER FAULT
408	19-Jan-19	TUMKUR	66	TR-2	DAVANAGERE_66	12:03	12:31	0:27	LINE CLEAR AVAILED
409	19-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:41	17:46	9:05	HAND TRIPPED
410	19-Jan-19	TUMKUR	66	TR-1	HALUVAGALU_66	18:17	18:18	0:01	LINE CLEAR AVAILED
411	19-Jan-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	9:17	9:28	0:11	LINE FAULT
412	19-Jan-19	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	11:04	12:09	1:05	LINE CLEAR AVAILED
413	19-Jan-19	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66, RAMPURA_66	9:03	9:22	0:18	LINE FAULT
414	19-Jan-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	9:03	9:33	0:29	LINE FAULT
415	19-Jan-19	TUMKUR	66	NEELAGUNDA 220kv-HULUVAGALU	HALUVAGALU_66	7:51	17:23	9:32	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
416	19-Jan-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	18:02	18:10	0:08	HAND TRIPPED
417	19-Jan-19	TUMKUR	66	TR-2	RAMPURA_66	9:03	9:38	0:35	TRANSFORMER FAULT
418	19-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	22:00	22:05	0:04	HAND TRIPPED
419	19-Jan-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	13:04	13:25	0:21	HAND TRIPPED
420	19-Jan-19	TUMKUR	66	TR-1	SAVALANGA_66	13:04	13:25	0:21	HAND TRIPPED
421	19-Jan-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	7:43	7:52	0:09	LINE FAULT
422	20-Jan-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110,YADWAD_33, VANTAGODI_33	2:33	3:10	0:37	LINE CLEAR AVAILED
423	20-Jan-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	13:29	13:54	0:25	LINE FAULT
424	20-Jan-19	BAGALKOT	110	NARENDRA-KUD1	KUD DHARWAD_110	0:00	8:53	8:53	HAND TRIPPED
425	20-Jan-19	BAGALKOT	110	DAMBAL-MUNDARGI	MUNDARGI_110	21:57	22:50	0:53	LINE FAULT
426	20-Jan-19	BAGALKOT	110	110/11KV, HV1	MAMDAPUR(B)_110	17:12	17:42	0:30	LINE CLEAR AVAILED
427	20-Jan-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	0:32	1:49	1:17	TRANSFORMER FAULT
428	20-Jan-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	1:52	3:34	1:42	TRANSFORMER FAULT
429	20-Jan-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	7:06	10:23	3:17	LINE CLEAR AVAILED
430	20-Jan-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110	16:17	16:20	0:03	TRANSFORMER FAULT
431	20-Jan-19	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINKOPPA_110	9:09	19:27	10:18	LINE CLEAR AVAILED
432	20-Jan-19	BAGALKOT	110	110/33KV,HV2	TARIHAL_110, DUMMAWAD_33, INDUSTRIAL ESTATE_33	10:00	18:30	8:30	LINE CLEAR AVAILED
433	20-Jan-19	BAGALKOT	110	110/11KV, HV3	TARIHAL_110	10:00	18:30	8:30	LINE CLEAR AVAILED
434	20-Jan-19	BAGALKOT	110	HUBLI2-TARIHAL	TARIHAL_110	10:05	18:30	8:25	LINE CLEAR AVAILED
435	20-Jan-19	BAGALKOT	110	BELGAUM220-BELGAUM 110	BELGAUM_110	9:27	16:05	6:38	LINE CLEAR AVAILED
436	20-Jan-19	BAGALKOT	110	BELGAUM-KANABARGI	KANABARGI_110	9:27	16:05	6:38	LINE CLEAR AVAILED
437	20-Jan-19	BAGALKOT	110	110/11KV,HV-2	GOKAK_110	0:00	16:25	16:25	LINE CLEAR AVAILED
438	20-Jan-19	BAGALKOT	110	110/11KV,HV-1	HATTARAGI_110	11:40	13:00	1:20	LINE CLEAR AVAILED
439	20-Jan-19	BAGALKOT	110	110/11KV,HV-1A	JAMAKHANDI_110	7:21	8:27	1:06	LINE CLEAR AVAILED
440	20-Jan-19	BAGALKOT	110	110/11KV,HV-1	KALADAGI_110	13:20	13:51	0:31	LINE CLEAR AVAILED
441	20-Jan-19	BAGALKOT	110	AMBEWADI-KAVALAWAD	KAVALAWAD_110	13:10	13:32	0:22	LINE CLEAR AVAILED
442	20-Jan-19	BAGALKOT	110	110/33KV,HV-2	KIRUVATTI_110 (33KVYALLAPUR)	9:56	14:05	4:09	LINE CLEAR AVAILED
443	20-Jan-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	10:18	23:59	13:41	LINE CLEAR AVAILED
444	20-Jan-19	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	10:17	23:59	13:42	LINE CLEAR AVAILED
445	20-Jan-19	BANGALORE	66	HV2	CHAKAVELU	11:04	11:20	0:15	TRANSFORMER FAULT
446	20-Jan-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:44	10:52	0:08	LOAD CHANGE OVER
447	20-Jan-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	16:41	17:09	0:28	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
448	20-Jan-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSEHANAHALLI, CHEEMANGALA	6:39	6:49	0:09	LINE FAULT
449	20-Jan-19	BANGALORE	66	HULLENAHALLI - KUDUR	KUDUR	11:05	11:20	0:14	MAIN SUPPLY FAILURE
450	20-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	11:04	11:22	0:17	LOAD CURTAILMENT
451	20-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL	9:53	16:35	6:41	LINE CLEAR AVAILED
452	20-Jan-19	BANGALORE	66	KYALANUR - VEMGAL	KYALANUR	9:53	10:19	0:25	LINE CLEAR AVAILED
453	20-Jan-19	BANGALORE	66	KYALANUR - TALAGAWARA	KYALANUR	15:55	16:15	0:20	LOAD CHANGEOVER
454	20-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	7:32	8:00	0:27	LINE FAULT
455	20-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	10:29	11:00	0:31	LINE FAULT
456	20-Jan-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220	10:55	11:15	0:20	LOAD CHANGEOVER
457	20-Jan-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	16:15	16:30	0:15	LOAD CHANGEOVER
458	20-Jan-19	BANGALORE	66	HV1	AMARJYOTHI	10:56	12:25	1:28	LINE CLEAR AVAILED
459	20-Jan-19	BANGALORE	66	HV1	AMARJYOTHI	13:57	14:05	0:08	LINE CLEAR AVAILED
460	20-Jan-19	BANGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	9:20	10:10	0:50	LOAD CHANGEOVER
461	20-Jan-19	BANGALORE	66	HV2	BRINDAVANA	11:25	12:18	0:53	HAND TRIPPED
462	20-Jan-19	BANGALORE	66	GOLF LINKS - ADUGODI 2	GOLF LINKS	12:10	12:20	0:10	LOAD CHANGEOVER
463	20-Jan-19	BANGALORE	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	14:00	14:05	0:05	LOAD CHANGEOVER
464	20-Jan-19	BANGALORE	66	HV2	KHODAYS 220	21:23	21:35	0:11	TRANSFORMER FAULT
465	20-Jan-19	BANGALORE	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	21:23	21:35	0:11	MAIN SUPPLY FAILURE
466	20-Jan-19	BANGALORE	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	21:23	21:35	0:11	MAIN SUPPLY FAILURE
467	20-Jan-19	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2	ELECTRONIC CITY PH 2 SEC 2, BIOCON (EHT), TECH MAHINDRA (EHT)	8:43	9:12	0:29	LINE FAULT
468	20-Jan-19	BANGALORE	66	NATIONAL COLLEGE - JAYANAGARA	NATIONAL COLLEGE	9:51	9:56	0:05	LOAD CHANGEOVER
469	20-Jan-19	BANGALORE	66	NATIONAL COLLEGE - BMTC	NATIONAL COLLEGE	16:20	16:32	0:11	LOAD CHANGEOVER
470	20-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	21:54	22:01	0:06	LOAD CHANGEOVER
471	20-Jan-19	BANGALORE	66	SIR MV LAYOUT - VRISHABHAVATHI 220	SIR MV LAYOUT	10:10	10:30	0:20	LOAD CHANGEOVER
472	20-Jan-19	BANGALORE	66	SIR MV LAYOUT - KENGERI SATELLITE TOWN	SIR MV LAYOUT	10:38	11:08	0:30	LOAD CHANGEOVER
473	20-Jan-19	BANGALORE	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	10:10	10:18	0:08	LOAD CHANGEOVER
474	20-Jan-19	BANGALORE	66	KENGERI SATELLITE TOWN - KUMBALGODU	KENGERI SATELLITE TOWN	10:38	11:08	0:30	LOAD CHANGEOVER
475	20-Jan-19	BANGALORE	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	21:24	22:00	0:36	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
476	20-Jan-19	BANGALORE	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT, KENGRI SATELLITE TOWN	21:24	22:00	0:36	MAIN SUPPLY FAILURE
477	20-Jan-19	BANGALORE	66	VRISHBHAVATHI 220 - REMCO	REMCO	21:24	22:00	0:36	MAIN SUPPLY FAILURE
478	20-Jan-19	BANGALORE	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	21:24	22:00	0:36	MAIN SUPPLY FAILURE
479	20-Jan-19	BANGALORE	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	21:24	22:03	0:39	MAIN SUPPLY FAILURE
480	20-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	10:55	11:15	0:20	MAIN SUPPLY FAILURE
481	20-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	10:55	11:15	0:20	MAIN SUPPLY FAILURE
482	20-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	10:55	11:10	0:15	MAIN SUPPLY FAILURE
483	20-Jan-19	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	10:55	11:15	0:20	MAIN SUPPLY FAILURE
484	20-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:35	16:52	0:17	LOAD CHANGEOVER
485	20-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	16:35	16:52	0:17	LOAD CHANGEOVER
486	20-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	VIKAS TECH PARK 220	16:35	16:52	0:17	LOAD CHANGEOVER
487	20-Jan-19	BANGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	16:35	16:52	0:17	LOAD CHANGEOVER
488	20-Jan-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	10:50	11:05	0:15	LOAD CHANGEOVER
489	20-Jan-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	16:30	16:40	0:10	LOAD CHANGEOVER
490	20-Jan-19	BANGALORE	66	HV1	JIGANI 220	10:50	11:05	0:15	LOAD CHANGEOVER
491	20-Jan-19	BANGALORE	66	HV1	JIGANI 220	16:30	16:40	0:10	LOAD CHANGEOVER
492	20-Jan-19	BANGALORE	66	HV2	JIGANI 220	10:50	11:05	0:15	LOAD CHANGEOVER
493	20-Jan-19	BANGALORE	66	HV2	JIGANI 220	16:30	16:40	0:10	LOAD CHANGEOVER
494	20-Jan-19	GULBARGA	110	HV3	DEODURGA_110	12:45	13:35	0:50	LINE CLEAR AVAILED
495	20-Jan-19	GULBARGA	110	GURGUNTA-LJVL_IPP	GURGUNTA_110	23:13	23:25	0:12	LINE FAULT
496	20-Jan-19	GULBARGA	110	RAJESHWAR-WARDA_IPP	RAJESHWAR_110	11:05	11:25	0:20	LINE FAULT
497	20-Jan-19	GULBARGA	110	HV3	YADGIR_110	17:15	19:02	1:47	LINE CLEAR AVAILED
498	20-Jan-19	GULBARGA	110	HV1	YADGIR_110	17:15	19:20	2:05	LINE CLEAR AVAILED
499	20-Jan-19	GULBARGA	110	HV2	YADGIR_110	16:35	20:52	4:17	TRANSFORMER FAULT
500	20-Jan-19	GULBARGA	110	HV2	MADIYAL_110	13:40	14:00	0:20	TRANSFORMER FAULT
501	20-Jan-19	GULBARGA	110	STARMETALLIC-MUNIRABD	MUNIRABAD_220	18:36	19:12	0:36	LINE FAULT
502	20-Jan-19	GULBARGA	110	WADAGERA-KHANAPUR	WADAGERA_110	6:15	6:20	0:05	LINE FAULT
503	20-Jan-19	GULBARGA	110	WADAGERA-RENEWSOLAR_IPP	WADAGERA_110	6:15	14:20	8:05	LINE FAULT
504	20-Jan-19	GULBARGA	110	WADAGERA-KHANAPUR	WADAGERA_110	6:25	6:35	0:10	LINE FAULT
505	20-Jan-19	GULBARGA	110	WADAGERA-KHANAPUR	WADAGERA_110	8:12	8:20	0:08	LINE FAULT
506	20-Jan-19	GULBARGA	110	WADAGERA-KHANAPUR	WADAGERA_110	15:29	15:36	0:07	LINE FAULT
507	20-Jan-19	GULBARGA	110	WADAGERA-RENEWSOLAR_IPP	WADAGERA_110	15:29	20:18	4:49	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
508	20-Jan-19	GULBARGA	66	HV1	HAMPASAGAR_66	7:07	7:30	0:23	TRANSFORMER FAULT
509	20-Jan-19	HASSAN	220	GOPALAPR-HSN400	GOPALPURA_220	9:16	18:37	9:21	LINE CLEAR AVAILED
510	20-Jan-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	8:45	9:45	1:00	LINE CLEAR AVAILED
511	20-Jan-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	8:45	9:45	1:00	LINE CLEAR AVAILED
512	20-Jan-19	HASSAN	66	HNPR2-HNPR1	HOLENARSIPURA_220	11:50	12:05	0:15	LINE CLEAR AVAILED
513	20-Jan-19	HASSAN	66	HNPR2-MYSOR1	HOLENARSIPURA_220	8:27	8:35	0:08	LINE FAULT
514	20-Jan-19	MYSORE	66	HV1	BGNAGARA_66	13:32	14:22	0:50	LINE CLEAR AVAILED
515	20-Jan-19	MYSORE	66	HV2	KMDODDI_66	11:15	13:24	2:09	LINE CLEAR AVAILED
516	20-Jan-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALI_66	0:04	0:18	0:13	LINE FAULT
517	20-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	11:48	23:59	12:10	HAND TRIPPED
518	20-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	9:50	10:20	0:30	HAND TRIPPED
519	20-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	10:30	11:05	0:35	HAND TRIPPED
520	20-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	11:30	13:00	1:30	HAND TRIPPED
521	20-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	13:30	17:40	4:10	HAND TRIPPED
522	20-Jan-19	TUMKUR	110	TR-1	GUBBI_110	19:28	19:34	0:05	TRANSFORMER FAULT
523	20-Jan-19	TUMKUR	66	TR-1	BAGUR_TMK_66	11:01	18:24	7:22	LINE CLEAR AVAILED
524	20-Jan-19	TUMKUR	66	TR-2	BAGUR_TMK_66	11:01	18:24	7:22	HAND TRIPPED
525	20-Jan-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:02	16:09	0:07	LINE FAULT
526	20-Jan-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:13	17:27	0:14	LINE FAULT
527	20-Jan-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	7:43	8:32	0:48	HAND TRIPPED
528	20-Jan-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	16:09	16:12	0:03	TRANSFORMER FAULT
529	21-Jan-19	BAGALKOT	110	110/11KV,HV-1	ACHANUR_110	18:25	18:43	0:18	LOAD CURTAILMENT
530	21-Jan-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	18:26	18:46	0:20	LOAD CURTAILMENT
531	21-Jan-19	BAGALKOT	110	220/110KV,LV-2	BELAGAUM_220	0:06	0:20	0:14	HAND TRIPPED
532	21-Jan-19	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	12:03	12:40	0:37	LINE FAULT
533	21-Jan-19	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	7:17	8:24	1:07	LINE FAULT
534	21-Jan-19	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	8:30	8:39	0:09	LINE FAULT
535	21-Jan-19	BAGALKOT	220	ALAMTTI 1-BAGALKOT	BAGALKOT_220	0:00	14:41	14:41	HAND TRIPPED
536	21-Jan-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	18:26	18:42	0:16	LOAD CURTAILMENT
537	21-Jan-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:17	18:20	0:03	LOAD CURTAILMENT
538	21-Jan-19	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	13:12	16:05	2:53	LINE FAULT
539	21-Jan-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	13:30	15:28	1:58	LINE CLEAR AVAILED
540	21-Jan-19	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	12:49	14:01	1:12	LINE CLEAR AVAILED
541	21-Jan-19	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	9:13	10:00	0:47	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
542	21-Jan-19	BAGALKOT	220	SHIROLKOPPA(BALLAGAVI)-RANEENNUR	RANEENNUR_220	0:00	10:44	10:44	HAND TRIPPED
543	21-Jan-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	16:06	23:59	7:53	HAND TRIPPED
544	21-Jan-19	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	10:40	12:59	2:19	HAND TRIPPED
545	21-Jan-19	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	18:25	18:32	0:07	LOAD CURTAILMENT
546	21-Jan-19	BAGALKOT	110	DODDANAVAR SOLAR-NANADI	NANADI_110	18:24	23:59	5:35	LINE CLEAR AVAILED
547	21-Jan-19	BAGALKOT	110	110/11KV,HV2	MAMAPUR(B)_110	15:57	17:01	1:04	LINE CLEAR AVAILED
548	21-Jan-19	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	14:26	16:03	1:37	HAND TRIPPED
549	21-Jan-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:05	12:52	0:47	MAIN SUPPLY FAILURE
550	21-Jan-19	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66,AREMALLAPUR_33	18:17	18:30	0:13	LOAD CURTAILMENT
551	21-Jan-19	BANGALORE	220	MAGADI 220 - NELAMANGALA 400	MAGADI 220	12:01	13:41	1:39	LINE FAULT
552	21-Jan-19	BANGALORE	66	HV1	AKKURMOLE	13:20	16:58	3:37	LINE CLEAR AVAILED
553	21-Jan-19	BANGALORE	66	HV1	LAKKUR	11:00	11:05	0:05	LINE CLEAR AVAILED
554	21-Jan-19	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI	12:43	15:00	2:17	LINE CLEAR AVAILED
555	21-Jan-19	BANGALORE	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA	12:38	15:18	2:40	LINE CLEAR AVAILED
556	21-Jan-19	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), K&C VALLY, NAL (EHT)	13:03	13:18	0:15	LINE FAULT
557	21-Jan-19	BANGALORE	66	HV3	SHAMRAJ TECH PARK	10:10	12:29	2:18	TRANSFORMER FAULT
558	21-Jan-19	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	15:33	15:46	0:12	LINE FAULT
559	21-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	15:24	15:37	0:13	LOAD CHANGEOVER
560	21-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	15:15	15:22	0:07	LOAD CHANGEOVER
561	21-Jan-19	BANGALORE	220	HV2	TK HALLI 220	11:02	11:15	0:13	TRANSFORMER FAULT
562	21-Jan-19	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR, AKKURMOLE	11:02	11:18	0:16	LINE FAULT
563	21-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 1	MANDYA	11:02	11:22	0:20	LINE FAULT
564	21-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	11:02	11:22	0:20	MAIN SUPPLY FAILURE
565	21-Jan-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	11:02	11:39	0:37	MAIN SUPPLY FAILURE
566	21-Jan-19	BANGALORE	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	14:01	14:39	0:38	LINE FAULT
567	21-Jan-19	BANGALORE	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	21:35	22:05	0:30	LINE FAULT
568	21-Jan-19	BANGALORE	66	HV2	NRS 220	14:01	14:22	0:21	LOAD CHANGEOVER
569	21-Jan-19	BANGALORE	66	HV2	NRS 220	16:09	16:16	0:06	LOAD CHANGEOVER
570	21-Jan-19	BANGALORE	66	HV2	NRS 220	21:35	22:04	0:29	LOAD CHANGEOVER
571	21-Jan-19	BANGALORE	66	HEJJALA - BIDADI 220	HEJJALA	23:50	23:59	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
572	21-Jan-19	BANGALORE	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	15:41	15:44	0:02	LOAD CHANGEOVER
573	21-Jan-19	GULBARGA	220	LINGAPUR-JVSL1	LINGAPUR_220	15:47	17:39	1:52	LINE CLEAR AVAILED
574	21-Jan-19	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	12:11	17:41	5:30	LINE CLEAR AVAILED
575	21-Jan-19	GULBARGA	110	HV2	HANUMANAL_110	8:10	8:40	0:30	LINE CLEAR AVAILED
576	21-Jan-19	GULBARGA	110	SIDHANOOR220-RAICHUR2	MANVI_110,MADALAPURA_110,	1:00	9:48	8:48	LINE FAULT
577	21-Jan-19	GULBARGA	110	MUNIRABAD-STARMETALLIC_IPP	STARMETALLIC_IPP	6:42	6:59	0:17	LINE FAULT
578	21-Jan-19	GULBARGA	110	HV1	ALAND_110	11:30	12:05	0:35	LINE CLEAR AVAILED
579	21-Jan-19	GULBARGA	110	HV4	ALAND_110	18:26	18:59	0:33	LOAD CURTAILMENT
580	21-Jan-19	GULBARGA	110	HV2	KOLHAR_110	18:15	18:20	0:05	TRANSFORMER FAULT
581	21-Jan-19	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHAKTI NAGAR_110	11:48	13:14	1:26	LINE FAULT
582	21-Jan-19	GULBARGA	110	HV1,HV2,HV4	LINGASUGUR_220	18:25	18:38	0:13	LOAD CURTAILMENT
583	21-Jan-19	GULBARGA	110	HV1	DEODURGA_110	18:26	18:40	0:14	LINE CLEAR AVAILED
584	21-Jan-19	GULBARGA	110	HV3	DEODURGA_110	18:19	18:42	0:23	LINE CLEAR AVAILED
585	21-Jan-19	GULBARGA	66	HV1	CJHALLI_66	18:19	18:26	0:07	LOAD CURTAILMENT
586	21-Jan-19	HASSAN	220	HASSN22-SHANTHIGRAMA	HASSAN_220	15:55	17:00	1:05	LINE FAULT
587	21-Jan-19	HASSAN	220	MRSSHM-DAVANGERE 2	MRSMSG_220	9:09	15:42	6:33	LINE CLEAR AVAILED
588	21-Jan-19	HASSAN	220	MRSSHM-DAVANGERE1	MRSMSG_220	9:09	15:40	6:31	LINE CLEAR AVAILED
589	21-Jan-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	SHARAVATHY_GEN	10:34	15:58	5:24	LINE CLEAR AVAILED
590	21-Jan-19	HASSAN	220	SHRAVTY-TALAGUPPA1	SHARAVATHY_GEN	10:12	17:19	7:07	LINE CLEAR AVAILED
591	21-Jan-19	HASSAN	220	HV2	SHIRALKOPPA_220	0:11	0:18	0:07	TRANSFORMER FAULT
592	21-Jan-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:34	11:09	0:35	MAIN SUPPLY FAILURE
593	21-Jan-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	10:12	17:18	7:06	LINE CLEAR AVAILED
594	21-Jan-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:51	13:31	0:40	LINE FAULT
595	21-Jan-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:17	0:26	0:09	HAND TRIPPED
596	21-Jan-19	HASSAN	110	LV2	SHIRALKOPPA_220	0:11	0:18	0:07	TRANSFORMER FAULT
597	21-Jan-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:34	11:09	0:35	MAIN SUPPLY FAILURE
598	21-Jan-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	0:11	0:18	0:07	HAND TRIPPED
599	21-Jan-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:34	11:09	0:35	MAIN SUPPLY FAILURE
600	21-Jan-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	0:11	0:18	0:07	HAND TRIPPED
601	21-Jan-19	HASSAN	110	HV2	BARANGI_110	10:14	12:10	1:56	TRANSFORMER FAULT
602	21-Jan-19	HASSAN	110	HV1	BIRUR_110	18:17	18:41	0:24	MAIN SUPPLY FAILURE
603	21-Jan-19	HASSAN	110	HV2	GERUMARA_110	18:25	18:48	0:23	MAIN SUPPLY FAILURE
604	21-Jan-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:35	14:15	3:40	NFBC ISSUED
605	21-Jan-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:45	10:55	0:10	LINE CLEAR AVAILED
606	21-Jan-19	HASSAN	110	IDLE	SAGARA_110	0:45	0:55	0:10	HAND TRIPPED
607	21-Jan-19	HASSAN	110	SORABA-SHR220	SORABA_110	0:15	0:25	0:10	LINE FAULT
608	21-Jan-19	HASSAN	110	SORABA-SHR220	SORABA_110	0:35	0:55	0:20	LINE FAULT
609	21-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:06	19:03	11:57	LINE CLEAR AVAILED
610	21-Jan-19	HASSAN	66	HV1	HANGRANAHALLI_66	10:58	13:20	2:22	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
611	21-Jan-19	HASSAN	66	HV1	HANGRANAHALLI_66	18:25	18:35	0:10	MAIN SUPPLY FAILURE
612	21-Jan-19	HASSAN	66	HV1	KANDLI_66	18:17	18:25	0:08	MAIN SUPPLY FAILURE
613	21-Jan-19	HASSAN	66	HV1	MATTANAVILE_66	18:30	18:35	0:05	MAIN SUPPLY FAILURE
614	21-Jan-19	HASSAN	66	HV1	RAMNATHPURA_66	18:25	18:35	0:10	MAIN SUPPLY FAILURE
615	21-Jan-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	18:25	18:30	0:05	MAIN SUPPLY FAILURE
616	21-Jan-19	HASSAN	66	HV1	RAMESHWARNAGARA_66	11:45	18:00	6:15	TRANSFORMER FAULT
617	21-Jan-19	HASSAN	66	HV2	SALAGAME_66	18:17	18:26	0:09	MAIN SUPPLY FAILURE
618	21-Jan-19	HASSAN	66	HV1	SATHENAHALLI_66	18:17	18:25	0:08	MAIN SUPPLY FAILURE
619	21-Jan-19	HASSAN	66	HV1	S.BELAGOLA_66	18:17	18:25	0:08	MAIN SUPPLY FAILURE
620	21-Jan-19	HASSAN	66	HV2	SHANTHIGRAMA_66	9:00	9:10	0:10	TRANSFORMER FAULT
621	21-Jan-19	HASSAN	66	HV2	SHANTHIGRAMA_66	18:20	18:30	0:10	MAIN SUPPLY FAILURE
622	21-Jan-19	HASSAN	66	HV2	BASAVAGHATTA_66	18:30	18:40	0:10	MAIN SUPPLY FAILURE
623	21-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	18:25	18:35	0:09	LOAD CURTAILMENT
624	21-Jan-19	MYSORE	66	HV1	BGNAGARA_66	18:25	18:35	0:09	LOAD CURTAILMENT
625	21-Jan-19	MYSORE	66	HV1	BILIKERE_66	18:25	18:39	0:13	LOAD CURTAILMENT
626	21-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	18:25	18:40	0:14	LOAD CURTAILMENT
627	21-Jan-19	MYSORE	66	HV2	DODDINADUVADI_66	18:25	18:35	0:09	LOAD CURTAILMENT
628	21-Jan-19	MYSORE	66	HV2	HDKOTE_66	18:25	18:45	0:19	LOAD CURTAILMENT
629	21-Jan-19	MYSORE	66	HV2	JAIPUR_66	18:25	18:40	0:14	LOAD CURTAILMENT
630	21-Jan-19	MYSORE	66	HV1	JYOTHINAGARA_66	8:57	9:08	0:11	TRANSFORMER FAULT
631	21-Jan-19	MYSORE	66	HV2	KMDODDI_66	18:26	18:34	0:07	LOAD CURTAILMENT
632	21-Jan-19	MYSORE	66	HV2	KOLLEGALA_66	18:26	18:35	0:08	LOAD CURTAILMENT
633	21-Jan-19	MYSORE	66	HV2	KRPET_66	15:42	19:02	3:20	LINE CLEAR AVAILED
634	21-Jan-19	MYSORE	66	HV1	KRPET_66	10:25	18:45	8:20	LINE CLEAR AVAILED
635	21-Jan-19	MYSORE	66	HV3	KRPET_66	15:25	18:30	3:05	LINE CLEAR AVAILED
636	21-Jan-19	MYSORE	66	HV1	KUSHALNAGARA_220	18:25	18:43	0:17	LOAD CURTAILMENT
637	21-Jan-19	MYSORE	66	HV1	NAGAMANGALA_66	18:26	18:30	0:03	LOAD CURTAILMENT
638	21-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	18:17	18:28	0:10	LOAD CURTAILMENT
639	21-Jan-19	MYSORE	66	HV2	PONNAMPET_66	18:17	18:30	0:12	LOAD CURTAILMENT
640	21-Jan-19	MYSORE	66	HV1	SATHEGALA_66	18:26	18:35	0:08	LOAD CURTAILMENT
641	21-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	18:26	18:33	0:06	LOAD CURTAILMENT
642	21-Jan-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:27	18:42	0:14	LOAD CURTAILMENT
643	21-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	2:18	8:30	6:11	HAND TRIPPED
644	21-Jan-19	MYSORE	66	HV1	KMDODDI_66,K_HONNALGERE_66 KIADBMANDYA_66 KOLKARANADODDI_66 MADDUR_66	11:00	11:25	0:25	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
645	21-Jan-19	MYSORE	66	HV2	KMDODDI_66,K_HONNALGERE_66 KIADBMANDYA_66 KOLKARANADODDI_66 MADDUR_67	11:00	11:25	0:25	HAND TRIPPED
646	21-Jan-19	MYSORE	66	KR PETE-KIKKERI	KIKKERI_66	16:32	18:00	1:28	LINE FAULT
647	21-Jan-19	MYSORE	66	HANNUR-COWDALLI	HANNUR_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	15:36	17:22	1:46	LINE CLEAR AVAILED
648	21-Jan-19	MYSORE	66	HANNUR-MADHUVANAHALL 1	HANNUR_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	15:36	17:22	1:46	LINE CLEAR AVAILED
649	21-Jan-19	MYSORE	66	HANNUR-MADHUVANAHALL 2	HANNUR_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	15:36	17:22	1:46	LINE CLEAR AVAILED
650	21-Jan-19	MYSORE	66	HANNUR-DODDINDUVADI	HANNUR_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	15:36	17:22	1:46	LINE CLEAR AVAILED
651	21-Jan-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, K_HONNALGERE_66 MADDUR_66	17:30	20:05	2:35	LINE CLEAR AVAILED
652	21-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	18:44	20:05	1:20	LINE CLEAR AVAILED
653	21-Jan-19	MYSORE	66	KR PETE-HUYGONAHALLI 2	KRPET_66 AKKIHEBBAL_66	16:25	18:00	1:35	LINE CLEAR AVAILED
654	21-Jan-19	TUMKUR	220	TR-1 & TR-2(HV SIDE)	ANCHEPALYA_220	13:41	13:45	0:03	HAND TRIPPED
655	21-Jan-19	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	15:13	16:31	1:18	LINE FAULT
656	21-Jan-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	15:13	16:30	1:17	LINE FAULT
657	21-Jan-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	8:17	12:42	4:24	HAND TRIPPED
658	21-Jan-19	TUMKUR	110	TR-1	GUBBI_110	16:44	16:50	0:06	TRANSFORMER FAULT
659	21-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	13:41	14:03	0:22	HAND TRIPPED
660	21-Jan-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	13:41	14:03	0:22	HAND TRIPPED
661	21-Jan-19	TUMKUR	66			13:41	14:03	0:22	LINE CLEAR AVAILED
662	21-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	13:41	14:03	0:22	HAND TRIPPED
663	21-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	13:41	14:03	0:22	HAND TRIPPED
664	21-Jan-19	TUMKUR	66	TR-1 & TR-2(LV SIDE)	ANCHEPALYA_220	13:41	13:46	0:04	HAND TRIPPED
665	21-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGODODDI_66	13:41	14:03	0:22	HAND TRIPPED
666	21-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	13:41	14:03	0:22	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
667	21-Jan-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:12	15:42	0:29	LINE FAULT
668	21-Jan-19	TUMKUR	66	TR-1	BADAVANAHALLI_66	12:56	13:14	0:18	LINE CLEAR AVAILED
669	21-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:24	17:35	9:11	HAND TRIPPED
670	21-Jan-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	12:42	12:47	0:04	LINE FAULT
671	21-Jan-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	14:07	14:20	0:12	LINE FAULT
672	21-Jan-19	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	15:29	15:35	0:05	TRANSFORMER FAULT
673	21-Jan-19	TUMKUR	66	TR-1	MALEBENNUR_66	23:25	23:41	0:15	TRANSFORMER FAULT
674	21-Jan-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	12:52	13:01	0:09	TRANSFORMER FAULT