

400/220/110/66 kV TRANSMISSION OUTAGES FROM 07.12.21 TO 13.12.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	7-Dec-2021	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)	12:29 (7.12.2021)	655:59 hrs	TRANSFORMER CHARGED
2	7-Dec-2021	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	10:05	16:40	6:35	LINE CLEAR AVAILED
3	7-Dec-2021	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(B)_110	14:50	14:59	0:09	HAND TRIPPED
4	7-Dec-2021	BAGALKOT	110	110/11KV, HV1	GAJENDRAGAD_110	12:30	15:45	3:15	TRANSFORMER FAULT
5	7-Dec-2021	BAGALKOT	110	110/11KV, HV1	GAJENDRAGAD_110	16:20	19:35	3:15	TRANSFORMER FAULT
6	7-Dec-2021	BAGALKOT	110	110/11KV, HV1	SHIROL_110	12:00	13:50	1:50	LINE CLEAR AVAILED
7	7-Dec-2021	BAGALKOT	110	110/11KV, HV2	HUKKERI_110	15:00	22:33	7:33	LINE CLEAR AVAILED
8	7-Dec-2021	BAGALKOT	110	110/11KV, HV2	SALAHALLI_110	10:15	16:48	6:33	LINE CLEAR AVAILED
9	7-Dec-2021	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(B)_110	14:50	14:59	0:09	HAND TRIPPED
10	7-Dec-2021	BAGALKOT	110	110/11KV, HV2	GAJENDRAGAD_110	14:25	16:20	1:55	TRANSFORMER FAULT
11	7-Dec-2021	BAGALKOT	110	110/11KV, HV2	SHIRAGUPPI_110	16:40	17:35	0:55	LINE CLEAR AVAILED
12	7-Dec-2021	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	13:30	14:30	1:00	LINE CLEAR AVAILED
13	7-Dec-2021	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	15:30	16:13	0:43	LINE CLEAR AVAILED
14	7-Dec-2021	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	18:19	18:21	0:02	LINE CLEAR AVAILED
15	7-Dec-2021	BAGALKOT	110	110/11KV,HV3	LAXMESHWAR_110	18:19	18:21	0:02	LINE CLEAR AVAILED
16	7-Dec-2021	BAGALKOT	110	110/33KV, HV3	SALAHALLI_110,HULKUND_33	10:55	16:48	5:53	LINE CLEAR AVAILED
17	7-Dec-2021	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:27 (04.12.2021)	18:22 (07.12.2021)	17:55	TRANSFORMER CHARGED
18	7-Dec-2021	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	23:17 (07.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
19	7-Dec-2021	BAGALKOT	110	AMBEWADI- KAVALWAD	KAVALWAD_110	9:56	10:03	0:07	MAIN SUPPLY FAILURE
20	7-Dec-2021	BAGALKOT	110	AMBEWADI- NK2	AMBEWADI_220	9:58	10:03	0:05	HAND TRIPPED
21	7-Dec-2021	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_10	11:13	12:24	1:11	LINE CLEAR AVAILED
22	7-Dec-2021	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_10	21:10	21:31	0:21	LINE FAULT
23	7-Dec-2021	BAGALKOT	110	BAGALKO220- NAVANAGAR1	NAVANAGAR(B)_110	10:29	14:59	4:30	NFBC ISSUED
24	7-Dec-2021	BAGALKOT	110	BAGALKOT220- GULEDGUDDA	BAGALKOT_220	15:51	17:38	1:47	LINE CLEAR AVAILED
25	7-Dec-2021	BAGALKOT	110	BAGALKOT220- NAVANAGAR1	BAGALKOT_220	11:21	13:15	1:54	LINE CLEAR AVAILED
26	7-Dec-2021	BAGALKOT	110	BAGALKOT220- NEERBUDIHAL	BAGALKOT_220	11:05	12:39	1:34	LINE CLEAR AVAILED
27	7-Dec-2021	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	10:12	18:26	8:14	HAND TRIPPED
28	7-Dec-2021	BAGALKOT	110	BELLATTI-ENERCON	BELLATTI_110	10:12	18:23	8:11	HAND TRIPPED
29	7-Dec-2021	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPUND_110	9:32	15:58	6:26	LINE CLEAR AVAILED
30	7-Dec-2021	BAGALKOT	110	GADAG-LAKSHMESHWAR	LAKSHMESHWAR_110	9:29 (03.12.2021)	18:19 (7.12.2021)	93:43 hrs	LINE CHARGED
31	7-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
32	7-Dec-2021	BAGALKOT	110	HALIYAL- ALNAVAR(GMR)	HALIYAL_110	1:55	2:13	0:18	LINE FAULT
33	7-Dec-2021	BAGALKOT	110	HAVERI- SAVANUR	HAVERI_220	6:38	6:48	0:10	LINE FAULT
34	7-Dec-2021	BAGALKOT	110	HUBLI220- KALGHATAGI	HUBLI_220	10:17	13:47	3:30	LINE CLEAR AVAILED
35	7-Dec-2021	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	12:42	18:46	6:04	LINE CLEAR AVAILED
36	7-Dec-2021	BAGALKOT	110	MUKARTHIHAL-MATRIX WINDS	MUKARTHIHAL_110	11:15	16:00	4:45	LINE CLEAR AVAILED
37	7-Dec-2021	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	RANEBENNUR_220	5:01	5:19	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
38	7-Dec-2021	BAGALKOT	110	SALAHALLI- GMNAVAR	SALAHALLI_110	10:42	17:56	7:14	LINE CLEAR AVAILED
39	7-Dec-2021	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	6:53	7:20	0:27	HAND TRIPPED
40	7-Dec-2021	BAGALKOT	110	SHIRAHATTI- LAXMESHWAR	SHIRAHATTI_110	10:08	18:13	8:05	NFBC ISSUED
41	7-Dec-2021	BAGALKOT	110	SUVARNASOUDA- MACHE	SUVARNASOUDA_110	19:50	20:20	0:30	LINE FAULT
42	7-Dec-2021	BAGALKOT	110	UTTUR- RANNABELAGALI	UTTUR_110	6:54	7:06	0:12	LINE FAULT
43	7-Dec-2021	BAGALKOT	110	YADWAD-ISEL SOLAR	YADWAD_110	6:54	7:12	0:18	LINE FAULT
44	7-Dec-2021	BAGALKOT	220	220/110KV, HV1	MUGALKOD_220	12:07	13:48	1:41	LINE CLEAR AVAILED
45	7-Dec-2021	BAGALKOT	220	220/110KV, HV2	NARENDRA_220	10:17	10:52	0:35	LINE CLEAR AVAILED
46	7-Dec-2021	BAGALKOT	220	220/110KV, HV2	MUGALKOD_220	9:45	12:00	2:15	LINE CLEAR AVAILED
47	7-Dec-2021	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220	8:30	18:41	10:11	LINE CLEAR AVAILED
48	7-Dec-2021	BAGALKOT	220	400/220KV, ICT1(LV)	DHONI_400	11:24	16:59	5:35	LINE CLEAR AVAILED
49	7-Dec-2021	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAILED
50	7-Dec-2021	BAGALKOT	220	BAGEWADI-BALUTI (LIS)	BAGEWADI_220	11:20	15:12	3:52	LINE CLEAR AVAILED
51	7-Dec-2021	BAGALKOT	220	BAGEWADI-MASUTI (LIS)	BAGEWADI_220	8:08	8:16	0:08	LINE FAULT
52	7-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
53	7-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
54	7-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
55	7-Dec-2021	BAGALKOT	220	GUTTUR- HAVERI	HAVERI_220	10:46	14:48	4:02	LINE CLEAR AVAILED
56	7-Dec-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	14:41	17:42	3:01	LINE CLEAR AVAILED
57	7-Dec-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	14:40	17:46	3:06	LINE CLEAR AVAILED
58	7-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
59	7-Dec-2021	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	10:31	15:21	4:50	LINE CLEAR AVAILED
60	7-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
61	7-Dec-2021	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
62	7-Dec-2021	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
63	7-Dec-2021	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	15:14	18:39	3:25	LINE FAULT
64	7-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
65	7-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
66	7-Dec-2021	BAGALKOT	400	400/220KV, ICT1(HV)	DHONI_400	11:26	16:55	5:29	LINE CLEAR AVAILED
67	7-Dec-2021	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	11:25	11:44	0:19	MAIN SUPPLY FAILURE
68	7-Dec-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	14:08	14:12	0:04	LOAD CHANGE OVER
69	7-Dec-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	16:05	16:10	0:05	LOAD CHANGE OVER
70	7-Dec-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	12:40	12:50	0:10	MAIN SUPPLY FAILURE
71	7-Dec-2021	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	16:30	16:40	0:10	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
72	7-Dec-2021	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	8:35	8:45	0:10	LOAD CHANGE OVER
73	7-Dec-2021	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	11:25	11:35	0:10	LINE FAULT
74	7-Dec-2021	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	9:10	9:23	0:13	LOAD CHANGE OVER
75	7-Dec-2021	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	16:32	16:36	0:04	LOAD CHANGE OVER
76	7-Dec-2021	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	16:50	16:55	0:05	LOAD CHANGE OVER
77	7-Dec-2021	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	9:10	9:40	0:30	LOAD CHANGE OVER
78	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	1:50	3:40	1:50	MAIN SUPPLY FAILURE
79	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	17:35	17:45	0:10	MAIN SUPPLY FAILURE
80	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	1:50	3:50	2:00	MAIN SUPPLY FAILURE
81	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	17:35	17:45	0:10	MAIN SUPPLY FAILURE
82	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	NO STATION AFFECTED	1:50	3:40	1:50	MAIN SUPPLY FAILURE
83	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	NO STATION AFFECTED	17:35	17:45	0:10	MAIN SUPPLY FAILURE
84	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	1:50	3:40	1:50	MAIN SUPPLY FAILURE
85	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	17:35	17:45	0:10	MAIN SUPPLY FAILURE
86	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	1:50	3:40	1:50	MAIN SUPPLY FAILURE
87	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	17:35	17:45	0:10	MAIN SUPPLY FAILURE
88	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	1:50	3:40	1:50	MAIN SUPPLY FAILURE
89	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	17:35	17:45	0:10	MAIN SUPPLY FAILURE
90	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI	1:50	3:40	1:50	MAIN SUPPLY FAILURE
91	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI	17:35	17:45	0:10	MAIN SUPPLY FAILURE
92	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	1:50	3:40	1:50	MAIN SUPPLY FAILURE
93	7-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	17:35	17:45	0:10	MAIN SUPPLY FAILURE
94	7-Dec-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	21:46	21:49	0:03	LOAD CHANGE OVER
95	7-Dec-2021	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	12:07	16:15	4:08	LINE CLEAR AVAILED
96	7-Dec-2021	BENGALURU	66	HV1	NAGANATHPURA 220	13:15	13:19	0:04	LINE CLEAR AVAILED
97	7-Dec-2021	BENGALURU	66	HV1	NANDINI LAYOUT	10:28	10:29	0:01	LINE CLEAR AVAILED
98	7-Dec-2021	BENGALURU	66	HV1	MITTEMARI 220	1:50	4:38	2:48	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
99	7-Dec-2021	BENGALURU	66	HV1	MITTEMARI 220	6:54	7:01	0:07	LOAD CHANGE OVER
100	7-Dec-2021	BENGALURU	66	HV1	MITTEMARI 220	17:33	17:53	0:20	MAIN SUPPLY FAILURE
101	7-Dec-2021	BENGALURU	66	HV1	SARJAPURA 220	9:10	16:17	7:07	LINE CLEAR AVAILED
102	7-Dec-2021	BENGALURU	66	HV1	NANDIGANAHALLI	13:36	13:40	0:04	LINE CLEAR AVAILED
103	7-Dec-2021	BENGALURU	66	HV1	CHINTAMANI 66	14:03	14:08	0:04	LINE CLEAR AVAILED
104	7-Dec-2021	BENGALURU	66	HV2	NANDINI LAYOUT	12:43	12:44	0:01	LINE CLEAR AVAILED
105	7-Dec-2021	BENGALURU	66	HV2	SARJAPURA 220	9:10	16:17	7:07	LINE CLEAR AVAILED
106	7-Dec-2021	BENGALURU	66	HV2	MALLASANDRA	10:27	11:12	0:45	LINE CLEAR AVAILED
107	7-Dec-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	19:44	20:14	0:30	LINE FAULT
108	7-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
109	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	1:50	4:38	2:48	MAIN SUPPLY FAILURE
110	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	6:54	7:01	0:07	LOAD CHANGE OVER
111	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	17:33	17:53	0:20	MAIN SUPPLY FAILURE
112	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	1:50	4:38	2:48	MAIN SUPPLY FAILURE
113	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	6:54	7:01	0:07	LOAD CHANGE OVER
114	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	17:33	17:53	0:20	MAIN SUPPLY FAILURE
115	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	1:50	4:38	2:48	MAIN SUPPLY FAILURE
116	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	6:54	7:01	0:07	LOAD CHANGE OVER
117	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	17:33	17:53	0:20	MAIN SUPPLY FAILURE
118	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	1:50	4:38	2:48	MAIN SUPPLY FAILURE
119	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	6:54	7:01	0:07	LOAD CHANGE OVER
120	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	17:33	17:53	0:20	MAIN SUPPLY FAILURE
121	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	1:50	4:38	2:48	MAIN SUPPLY FAILURE
122	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	6:54	7:01	0:07	LOAD CHANGE OVER
123	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	17:33	17:53	0:20	MAIN SUPPLY FAILURE
124	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	1:50	4:38	2:48	MAIN SUPPLY FAILURE
125	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:54	7:01	0:07	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
126	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	17:33	17:53	0:20	MAIN SUPPLY FAILURE
127	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	1:50	4:38	2:48	MAIN SUPPLY FAILURE
128	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	6:54	7:01	0:07	LOAD CHANGE OVER
129	7-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	17:33	17:53	0:20	MAIN SUPPLY FAILURE
130	7-Dec-2021	BENGALURU	66	NANDIGANAHALLI - CHINTAMANI 220	NANDIGANAHALLI	15:40	17:10	1:30	LINE CLEAR AVAILED
131	7-Dec-2021	BENGALURU	66	SADLI - DIBURALLI	DIBBURALLI	10:00	18:00	8:00	LINE CLEAR AVAILED
132	7-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	12:40	12:50	0:10	LINE FAULT
133	7-Dec-2021	BENGALURU	66	TELECOM LAYOUT - NRS 220	TELECOM LAYOUT	18:23	18:32	0:09	LOAD CHANGE OVER
134	7-Dec-2021	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	20:56	21:12	0:16	LINE FAULT
135	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	12:05	12:18	0:13	LOAD CHANGE OVER
136	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	14:30	14:40	0:10	LOAD CHANGE OVER
137	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:05	12:18	0:13	LOAD CHANGE OVER
138	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	14:30	14:40	0:10	LOAD CHANGE OVER
139	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:05	12:18	0:13	LOAD CHANGE OVER
140	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:30	14:40	0:10	LOAD CHANGE OVER
141	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:05	12:18	0:13	LOAD CHANGE OVER
142	7-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:30	14:40	0:10	LOAD CHANGE OVER
143	7-Dec-2021	BENGALURU	220	BEGUR 220	HV1	10:26	18:25	7:59	LINE CLEAR AVAILED
144	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	17:35	17:45	0:10	MAIN SUPPLY FAILURE
145	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	1:50	3:15	1:25	LINE FAULT
146	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	17:35	17:45	0:10	LINE CLEAR AVAILED
147	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	1:50	3:15	1:25	LINE FAULT
148	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	17:35	17:45	0:10	LINE CLEAR AVAILED
149	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	NO STATION AFFECTED	1:50	8:10	6:20	MAIN SUPPLY FAILURE
150	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	NO STATION AFFECTED	17:35	17:45	0:10	MAIN SUPPLY FAILURE
151	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	RAILWAY TRACTION	1:50	8:10	6:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
152	7-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	RAILWAY TRACTION	17:35	17:45	0:10	MAIN SUPPLY FAILURE
153	7-Dec-2021	BENGALURU	220	HV1	MITTEMARI 220	1:50	6:48	4:58	MAIN SUPPLY FAILURE
154	7-Dec-2021	BENGALURU	220	HV1	MITTEMARI 220	17:33	17:51	0:18	MAIN SUPPLY FAILURE
155	7-Dec-2021	BENGALURU	220	HV1	SARJAPURA 220	9:10	16:17	7:07	LINE CLEAR AVAILED
156	7-Dec-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	1:50	3:40	1:50	MAIN SUPPLY FAILURE
157	7-Dec-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	17:35	17:45	0:10	MAIN SUPPLY FAILURE
158	7-Dec-2021	BENGALURU	220	HV2	MITTEMARI 220	1:50	6:50	5:00	MAIN SUPPLY FAILURE
159	7-Dec-2021	BENGALURU	220	HV2	MITTEMARI 220	17:33	17:51	0:18	MAIN SUPPLY FAILURE
160	7-Dec-2021	BENGALURU	220	HV2	SARJAPURA 220	9:10	16:17	7:07	LINE CLEAR AVAILED
161	7-Dec-2021	BENGALURU	220	HV2	GOWRIBIDANUR 220	1:50	3:40	1:50	MAIN SUPPLY FAILURE
162	7-Dec-2021	BENGALURU	220	HV2	GOWRIBIDANUR 220	17:35	17:45	0:10	MAIN SUPPLY FAILURE
163	7-Dec-2021	BENGALURU	220	HV3	GOWRIBIDANUR 220	1:50	3:40	1:50	MAIN SUPPLY FAILURE
164	7-Dec-2021	BENGALURU	220	HV3	GOWRIBIDANUR 220	17:35	17:45	0:10	MAIN SUPPLY FAILURE
165	7-Dec-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	1:50	6:45	4:55	LINE FAULT
166	7-Dec-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	17:33	17:50	0:17	MAIN SUPPLY FAILURE
167	7-Dec-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	1:50	6:45	4:55	LINE FAULT
168	7-Dec-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	17:33	17:50	0:17	MAIN SUPPLY FAILURE
169	7-Dec-2021	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	9:10	16:15	7:05	LINE CLEAR AVAILED
170	7-Dec-2021	GULBARGA	66	TELEGI-YEARAGUNTE	TELEGI_66	4:35	4:45	0:10	MAIN SUPPLY FAILURE
171	7-Dec-2021	GULBARGA	66	UCHCHANGIDURGA-PUNABGHATTA	UCHCHANGIDURGA_66	6:20	6:30	0:10	MAIN SUPPLY FAILURE
172	7-Dec-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANAGALLU_110,KUDITINI_110,KURUGO D_110,SHATAVAHANA_IPP,AGARWAL_IPP,SU ZLON_IPP,KAMALAPUR_IPP,RBNS FACTORY,MATRI_110	9:04	12:20	3:16	LINE FAULT
173	7-Dec-2021	GULBARGA	110	BISLAHALLI-BELLARYNORTH	BISLAHALLI_110	1:50	2:07	0:17	MAIN SUPPLY FAILURE
174	7-Dec-2021	GULBARGA	110	BISLAHALLI-BELLARYNORTH	BISLAHALLI_110	2:27	2:36	0:09	MAIN SUPPLY FAILURE
175	7-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	17:25(6.12.2021)	2:00(7.12.2021)	8:35HRS	LINE CHARGED
176	7-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	17:35	22:40	5:05	LINE CLEAR AVAILED
177	7-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	22:50	23:00	0:10	LINE CLEAR AVAILED
178	7-Dec-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	15:58	16:06	0:08	LINE FAULT
179	7-Dec-2021	GULBARGA	110	HV1	BENNUR_110	9:10	9:30	0:20	TRANSFORMER FAULT
180	7-Dec-2021	GULBARGA	110	HV1	BENNUR_110	13:05	13:20	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
181	7-Dec-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	12:25	12:30	0:05	LINE FAULT
182	7-Dec-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS	12:55	15:45	2:50	LINE CLEAR AVAILED
183	7-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
184	7-Dec-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,KURDI CROSS_110,MADALAPUR_110	19:19	19:24	0:05	LINE FAULT
185	7-Dec-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,KURDI CROSS_110,MADALAPUR_110	22:55	22:58	0:03	LINE FAULT
186	7-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
187	7-Dec-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	22:20	22:25	0:05	LINE CLEAR AVAILED
188	7-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADGERA_110,SANNATHI_110,CORE GREEN SUGUR_IPP	0:19	0:28	0:09	LINE FAULT
189	7-Dec-2021	GULBARGA	110	SINDHANOOR-SIRAGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	15:00	15:10	0:10	MAIN SUPPLY FAILURE
190	7-Dec-2021	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	9:02	9:12	0:10	MAIN SUPPLY FAILURE
191	7-Dec-2021	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	11:25	12:20	0:55	MAIN SUPPLY FAILURE
192	7-Dec-2021	GULBARGA	220	HV1	MUNIRABAD_220	9:01	17:17	8:16	LINE CLEAR AVAILED
193	7-Dec-2021	GULBARGA	220	LINGAPUR-MUNIRABAD	MUNIRABAD_220	9:01	17:12	8:11	LINE CLEAR AVAILED
194	7-Dec-2021	GULBARGA	220	NEELGUND-GUTTUR	NEELGUND_220	12:27	16:03	0:15	LINE CLEAR AVAILED
195	7-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
196	7-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:32	6:23	4:51	LINE CLEAR AVAILED
197	7-Dec-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	23:20(07.12.2021)			LINE OPEN:LINE CLEAR AVAILED
198	7-Dec-2021	GULBARGA	400	RTPS-MEHABOOB NAGAR	MEHABOOB NAGAR_400	9:46 (7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
199	7-Dec-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	13:35	13:55	0:20	LINE FAULT
200	7-Dec-2021	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	12:29	13:08	0:39	LINE CLEAR AVAILED
201	7-Dec-2021	HASSAN	66	HASSN220-HN PURA	HASSAN_220	13:21	13:35	0:14	HAND TRIPPED
202	7-Dec-2021	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	11:10	17:20	6:10	LINE CLEAR AVAILED
203	7-Dec-2021	HASSAN	66	HIREMAN-CKM220	HIREMANGALUR_66	11:10	15:10	4:00	LINE CLEAR AVAILED
204	7-Dec-2021	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	11:00	15:10	4:10	LINE CLEAR AVAILED
205	7-Dec-2021	HASSAN	66	HNPUR2-RNPR1	HOLENARASIPURA_220	20:38	20:43	0:05	LINE FAULT
206	7-Dec-2021	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	10:50	12:10	1:20	LINE CLEAR AVAILED
207	7-Dec-2021	HASSAN	66	HV1	CHIKMAGALUR_66	11:15	17:23	6:08	LINE CLEAR AVAILED
208	7-Dec-2021	HASSAN	66	HV1	HANBALU_66	12:29	13:08	0:39	LINE CLEAR AVAILED
209	7-Dec-2021	HASSAN	66	HV1	HIREMANGALUR_66	11:10	15:10	4:00	LINE CLEAR AVAILED
210	7-Dec-2021	HASSAN	66	HV1	HOLALUR_66	10:04	17:42	7:38	LINE CLEAR AVAILED
211	7-Dec-2021	HASSAN	66	HV2	BASAVAGHATTA_66	11:12	12:27	1:15	LINE CLEAR AVAILED
212	7-Dec-2021	HASSAN	66	HV2	CHIKMAGALUR_66	11:15	17:25	6:10	LINE CLEAR AVAILED
213	7-Dec-2021	HASSAN	66	HV2	HOLALUR_66	10:07	17:43	7:36	LINE CLEAR AVAILED
214	7-Dec-2021	HASSAN	66	HV2	KANDLI_66	11:35	12:25	0:50	LINE CLEAR AVAILED
215	7-Dec-2021	HASSAN	66	HV2	SALAGAME_66	3:24	4:10	0:46	TRANSFORMER FAULT
216	7-Dec-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	2:26	2:43	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
217	7-Dec-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	8:50	14:17	5:27	NFBC ISSUED
218	7-Dec-2021	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	12:40	12:55	0:15	LINE FAULT
219	7-Dec-2021	HASSAN	110	AJAMPU-SHIVNI	AJAMPURA_110	13:19	13:30	0:11	LINE FAULT
220	7-Dec-2021	HASSAN	110	BRAHMAVA-NITTUR	BRAHMAVARA_110	11:06	11:14	0:08	HAND TRIPPED
221	7-Dec-2021	HASSAN	110	BRAHMAVA-NITTUR	BRAHMAVARA_110	13:13	13:17	0:04	HAND TRIPPED
222	7-Dec-2021	HASSAN	110	HV1	JADE_110	12:05	13:00	0:55	LINE CLEAR AVAILED
223	7-Dec-2021	HASSAN	110	HV2	NITTUR_110	9:55	13:25	3:30	LINE CLEAR AVAILED
224	7-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	10:45(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
225	7-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	12:10	14:43	2:33	LINE CLEAR AVAILED
226	7-Dec-2021	HASSAN	110	KADUR-TNGL	KADUR_220	10:25	18:12	7:47	LINE CLEAR AVAILED
227	7-Dec-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:02	11:05	0:03	HAND TRIPPED
228	7-Dec-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:02(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
229	7-Dec-2021	HASSAN	110	LV1	PUTTUR_220	11:43	12:29	0:46	LINE CLEAR AVAILED
230	7-Dec-2021	HASSAN	110	LV2	PUTTUR_220	11:11	11:40	0:29	LINE CLEAR AVAILED
231	7-Dec-2021	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	13:15	13:20	0:05	HAND TRIPPED
232	7-Dec-2021	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	11:12	13:17	2:05	LINE CLEAR AVAILED
233	7-Dec-2021	HASSAN	220	HV1	PUTTUR_220	11:43	12:29	0:46	LINE CLEAR AVAILED
234	7-Dec-2021	HASSAN	220	HV2	PUTTUR_220	11:11	11:40	0:29	LINE CLEAR AVAILED
235	7-Dec-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	16:19(07.12.2021)			LINE OPEN:LINE CLEAR AVAILED
236	7-Dec-2021	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	3:53	13:02	9:09	LINE FAULT
237	7-Dec-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	16:19(07.12.2021)			LINE OPEN:LINE FAULT
238	7-Dec-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	3:53	13:01	9:08	LINE FAULT
239	7-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21(3.12.2021)	8:35(7.12.2021)	104:13 hrs	LINE CHARGED
240	7-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:24(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
241	7-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	8:41	12:17	3:36	LINE FAULT
242	7-Dec-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:42(06.12.2021)	7:29(7.12.2021)	8:46 hrs	LINE CHARGED
243	7-Dec-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	9:47	9:56	0:09	LINE FAULT
244	7-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
245	7-Dec-2021	MYSURU	66	HEBBANI-MEGALAPURA	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66	8:46	8:54	0:08	LINE FAULT
246	7-Dec-2021	MYSURU	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	10:50			LINE OPEN:LINE CLEAR AVAILED
247	7-Dec-2021	MYSURU	66	HOOTAGALLI-BELAGOLA	NO STATIONS EFFECTED	9:51	11:17	1:26	LINE CLEAR AVAILED
248	7-Dec-2021	MYSURU	66	HOOTAGALLI-HAMPAPURA (DODDAKADNUR)	NO STATIONS EFFECTED	9:19	11:47	2:28	LINE CLEAR AVAILED
249	7-Dec-2021	MYSURU	66	HOOTAGALLI-KHB	NO STATIONS EFFECTED	10:26	12:12	1:46	LINE CLEAR AVAILED
250	7-Dec-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	15:24	15:28	0:04	TRANSFORMER FAULT
251	7-Dec-2021	MYSURU	66	KADKOLA-KOZHICODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
252	7-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
253	7-Dec-2021	MYSURU	220	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	11:25	11:37	0:12	HAND TRIPPED
254	7-Dec-2021	MYSURU	220	MADHUVANAHALLI-CR NAGARA 2	NO STATIONS EFFECTED	14:32	14:37	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
255	7-Dec-2021	MYSURU	220	MADHUVANAHALLI-VARADA SOLAR	NO STATIONS EFFECTED	18:08	18:10	0:02	HAND TRIPPED
256	7-Dec-2021	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	22:24	22:29	0:05	LINE FAULT
257	7-Dec-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	14:30	16:44	2:13	LINE CLEAR AVAILED
258	7-Dec-2021	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	18:33	18:56	0:23	HAND TRIPPED
259	7-Dec-2021	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	15:00	17:22	2:21	LINE CLEAR AVAILED
260	7-Dec-2021	TUMKUR	66	PATTNAYAKANAHALLI66-TAVAREKERE66	PATTNAYAKANAHALLI_66	16:03	17:45	1:41	LINE CLEAR AVAILED
261	7-Dec-2021	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	2:20	2:30	0:10	LINE FAULT
262	7-Dec-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	14:30	16:59	2:29	LINE CLEAR AVAILED
263	7-Dec-2021	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	14:30	17:03	2:33	LINE CLEAR AVAILED
264	7-Dec-2021	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	14:30	17:04	2:34	LINE CLEAR AVAILED
265	7-Dec-2021	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	14:33	16:40	2:07	LINE CLEAR AVAILED
266	7-Dec-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	14:00	14:05	0:04	TRANSFORMER FAULT
267	7-Dec-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	14:16	14:20	0:04	TRANSFORMER FAULT
268	7-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	18:35	18:45	0:09	TRANSFORMER FAULT
269	7-Dec-2021	TUMKUR	66	TR-1	PD KOTE_66	14:31	16:46	2:15	LINE CLEAR AVAILED
270	7-Dec-2021	TUMKUR	66	TR-1	PATTNAYAKANAHALLI_66	16:20	17:45	1:24	LINE CLEAR AVAILED
271	7-Dec-2021	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	10:35	17:48	7:13	LINE CLEAR AVAILED
272	7-Dec-2021	TUMKUR	66	TR-2	HARIYABBE_66	15:13	15:31	0:17	TRANSFORMER FAULT
273	7-Dec-2021	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	16:20	17:45	1:24	LINE CLEAR AVAILED
274	7-Dec-2021	TUMKUR	110	NTTTUR220-KALLUR110	KALLUR_110	0:44	1:05	0:20	LINE FAULT
275	7-Dec-2021	TUMKUR	110	TR-1	SOMLAPURA_110	12:25	18:07	5:42	LINE CLEAR AVAILED
276	7-Dec-2021	TUMKUR	110	TR-1	THIMMANAHALLI_110	13:30	17:39	4:09	LINE CLEAR AVAILED
277	7-Dec-2021	TUMKUR	110	TR-2(HV SIDE)	KBCROSS_220	16:47	17:35	0:48	LINE CLEAR AVAILED
278	7-Dec-2021	TUMKUR	220	TR-1(HV SDE)	ANTHRASANAHALLI_220	10:35	17:48	7:13	LINE CLEAR AVAILED
279	7-Dec-2021	TUMKUR	220	TR-2(HV SIDE)	KIADB V N PURA_220	12:19	19:21	7:02	LINE CLEAR AVAILED
280	8-Dec-2021	BAGALKOT	110	110/11KV, HV1	SIRSI_220	11:38	14:45	3:07	HAND TRIPPED
281	8-Dec-2021	BAGALKOT	110	110/11KV, HV1	MUDEDEBIHAL_110	15:34	16:14	0:40	LINE CLEAR AVAILED
282	8-Dec-2021	BAGALKOT	110	110/11KV, HV2	SUARNASOUDA_110	16:10	16:43	0:33	LINE CLEAR AVAILED
283	8-Dec-2021	BAGALKOT	110	110/11KV, HV2	SIRSI_220	11:38	14:45	3:07	HAND TRIPPED
284	8-Dec-2021	BAGALKOT	110	110/11KV, HV2	MUNDARGI_110	10:00	18:45	8:45	LINE CLEAR AVAILED
285	8-Dec-2021	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	12:11	13:00	0:49	LINE CLEAR AVAILED
286	8-Dec-2021	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	11:20	13:13	1:53	TRANSFORMER FAULT
287	8-Dec-2021	BAGALKOT	110	110/11KV,HV1	KANABARGI_110	14:30	14:54	0:24	LINE CLEAR AVAILED
288	8-Dec-2021	BAGALKOT	110	110/11KV,HV1	SHIROL_110	12:15	14:00	1:45	LINE CLEAR AVAILED
289	8-Dec-2021	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	11:35	13:55	2:20	LINE CLEAR AVAILED
290	8-Dec-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	15:34	15:51	0:17	TRANSFORMER FAULT
291	8-Dec-2021	BAGALKOT	110	110/11KV,HV2	KANABARGI_110	15:04	15:29	0:25	LINE CLEAR AVAILED
292	8-Dec-2021	BAGALKOT	110	110/11KV,HV2	MAREGUDDI_110	12:15	12:20	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
293	8-Dec-2021	BAGALKOT	110	110/11KV,HV2	SHIRAGUPPI_110	10:35	15:05	4:30	LINE CLEAR AVAILED
294	8-Dec-2021	BAGALKOT	110	110/33KV, HV3	MUNDARGI_110, WATER SUPPLY_33, SINGATALUR_33	10:00	18:40	8:40	LINE CLEAR AVAILED
295	8-Dec-2021	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	11:55 (08.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
296	8-Dec-2021	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	23:17 (07.12.2021)	8:00 (08.12.2021)	8:43	TRANSFORMER CHARGED
297	8-Dec-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	22:59	23:05	0:06	LINE FAULT
298	8-Dec-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	23:54	23:58	0:04	LINE FAULT
299	8-Dec-2021	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	22:59	23:05	0:06	LINE FAULT
300	8-Dec-2021	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	23:54	23:58	0:04	LINE FAULT
301	8-Dec-2021	BAGALKOT	110	AMBEWADI-HALIYAL	HALIYAL_110	9:28	17:50	8:22	LINE CLEAR AVAILED
302	8-Dec-2021	BAGALKOT	110	AMBEWADI-KAVALWADA	KAVALWADA_110	9:06	9:15	0:09	MAIN SUPPLY FAILURE
303	8-Dec-2021	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	9:16	17:49	8:33	HAND TRIPPED
304	8-Dec-2021	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	19:06 (8.12.2021)			LINE OPEN:LINE FAULT
305	8-Dec-2021	BAGALKOT	110	AMBEWADI-NK-2	KAVALWAD_110	9:06	17:49	8:43	HAND TRIPPED
306	8-Dec-2021	BAGALKOT	110	AMBEWADI-NK-2	KAVALWAD_110	19:18 (8.12.2021)			LINE OPEN:LINE FAULT
307	8-Dec-2021	BAGALKOT	110	BAGALKOT-NAVANAGAR-1	BAGAKOT_220	4:46	5:05	0:15	LINE FAULT
308	8-Dec-2021	BAGALKOT	110	DAMBAL-MUNDARAGI L1 & L2	MUNDARAGI_110	10:21	17:37	7:16	NFBC ISSUED
309	8-Dec-2021	BAGALKOT	110	DAMBAL-SMABAPUR ROAD	SMBAPUR ROAD_110	5:50	10:35	4:45	LINE FAULT
310	8-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
311	8-Dec-2021	BAGALKOT	110	MACHE- UDYAMBAG	MACHE_110	19:35	19:46	0:11	HAND TRIPPED
312	8-Dec-2021	BAGALKOT	110	MUNDARGI- DAMBAL	MUNDARGI_110	10:20	17:50	7:30	LINE CLEAR AVAILED
313	8-Dec-2021	BAGALKOT	110	MUNDARGI- VIJAYNAGAR SUGARS	MUNDARGI_110	10:00	18:20	8:20	LINE CLEAR AVAILED
314	8-Dec-2021	BAGALKOT	110	RANEBENNUR-HIREKERUR	RANEBENNUR_220	11:20	11:30	0:10	LINE FAULT
315	8-Dec-2021	BAGALKOT	110	SAMBAPUR ROAD- DAMBAL	SAMBAPUR ROAD_110	5:50	10:36	4:46	LINE FAULT
316	8-Dec-2021	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	11:10	11:17	0:07	HAND TRIPPED
317	8-Dec-2021	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	11:10	11:17	0:07	HAND TRIPPED
318	8-Dec-2021	BAGALKOT	110	SIRSI- ESALE1(SIRSI220)	SIRSI_110	13:40	14:00	0:20	HAND TRIPPED
319	8-Dec-2021	BAGALKOT	110	SIRSI- ESALE2(SIRSI220)	SIRSI_110	13:40	14:00	0:20	HAND TRIPPED
320	8-Dec-2021	BAGALKOT	110	SIRSI-UMMACHAGI	SIRSI_220	11:34	14:06	2:32	LINE CLEAR AVAILED
321	8-Dec-2021	BAGALKOT	110	SUVARNASOUDA-MACHE	SUVARNASOUDA_110	19:50	20:20	0:30	LINE FAULT
322	8-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	10:55	11:10	0:15	LINE FAULT
323	8-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	11:10	13:15	2:05	LINE FAULT
324	8-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	13:15	15:25	2:10	LINE CLEAR AVAILED
325	8-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN:LINE FAULT
326	8-Dec-2021	BAGALKOT	220	220/110KV, HV1 & LV1	KARWAR_220	10:34	13:16	2:42	LINE CLEAR AVAILED
327	8-Dec-2021	BAGALKOT	220	220/110KV, HV1&LV2	SOUDATTI_220	8:50	18:32	9:42	LINE CLEAR AVAILED
328	8-Dec-2021	BAGALKOT	220	220/110KV,HV1,LV1	SIRSI_220	11:35	14:05	2:30	LINE CLEAR AVAILED
329	8-Dec-2021	BAGALKOT	220	400/220KV,ICT2(LV)	DHONI_400	10:51	18:03	7:12	LINE CLEAR AVAILED
330	8-Dec-2021	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
331	8-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
332	8-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
333	8-Dec-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:02	7:30	7:28	HAND TRIPPED
334	8-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
335	8-Dec-2021	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	5:17	6:24	1:07	LINE CLEAR AVAILED
336	8-Dec-2021	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	5:21	6:25	1:04	LINE CLEAR AVAILED
337	8-Dec-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	11:45 (08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
338	8-Dec-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:45 (08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
339	8-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
340	8-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
341	8-Dec-2021	BAGALKOT	220	SIRSI- SHARAVATHI1	SIRSI_220	11:30	14:07	6:29	LINE CLEAR AVAILED
342	8-Dec-2021	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)	21:17 (08.12.2021)	508:57 hrs	LINE CHARGED
343	8-Dec-2021	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)	21:17 (08.12.2021)	340:57 hrs	LINE CHARGED
344	8-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
345	8-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
346	8-Dec-2021	BAGALKOT	400	400/220KV,ICT2(HV)	DHONI_400	10:51	18:03	7:12	LINE CLEAR AVAILED
347	8-Dec-2021	BENGALURU	66	HV1	IISc	16:58	17:05	0:07	LOAD CHANGE OVER
348	8-Dec-2021	BENGALURU	66	HV1	IISc	19:05	19:12	0:07	LOAD CHANGE OVER
349	8-Dec-2021	BENGALURU	66	HV1	KORAMANGALA 220	12:48	12:50	0:02	LINE CLEAR AVAILED
350	8-Dec-2021	BENGALURU	66	HV2	ELECTRONIC CITY	12:37	13:02	0:25	LINE CLEAR AVAILED
351	8-Dec-2021	BENGALURU	66	HV2	REMCO	10:53	11:01	0:08	LOAD CHANGE OVER
352	8-Dec-2021	BENGALURU	66	HV2	REMCO	16:43	16:48	0:05	LOAD CHANGE OVER
353	8-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
354	8-Dec-2021	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	12:46	13:10	0:24	LINE CLEAR AVAILED
355	8-Dec-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	10:53	11:03	0:10	LOAD CHANGE OVER
356	8-Dec-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	16:43	16:50	0:07	LOAD CHANGE OVER
357	8-Dec-2021	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	10:10	11:42	1:32	LINE CLEAR AVAILED
358	8-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
359	8-Dec-2021	GULBARGA	66	ITTAGI-CLEANSOLAR1&2_IPP	ITTAGI_220	11:10	18:13	7:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
360	8-Dec-2021	GULBARGA	66	ITTAGI-HIREHADAGALI12,HUVINAHADAGALI	HIREHADAGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGABHADRA_IPP,HUVINAHADAGALI_66,HOLAGUNDI_66,UPANAYA KANAHALLI_66,HBHALLI_66,KOTTUR,UJJAINI_66,BENNEHALLI_66,HAMPASAGAR_66,MORAGERE_66,TAMBRAHALLI_66	10:10	18:07	7:57	LINE CLEAR AVAILED
361	8-Dec-2021	GULBARGA	66	ITTAGI-KUDLIGI1&2	KUDLIGI_66,KOGALI_66,HANASI_66,CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANAVEKAL_66,CHORNOOR_66	10:10	18:07	7:57	LINE CLEAR AVAILED
362	8-Dec-2021	GULBARGA	66	ITTAGI-TAMBRAHALLI,HBHALLI	TAMBRAHALLI_66,HAMPASAGAR_66,MORAGERE_66	11:15	16:25	5:10	LINE CLEAR AVAILED
363	8-Dec-2021	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	13:40	13:49	0:09	LINE FAULT
364	8-Dec-2021	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	4:05	4:10	0:05	MAIN SUPPLY FAILURE
365	8-Dec-2021	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110,DEODURGA_110	23:25	23:30	0:05	MAIN SUPPLY FAILURE
366	8-Dec-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	3:35	3:40	0:05	MAIN SUPPLY FAILURE
367	8-Dec-2021	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGA SOUTH	GULBARGAUNIVERSITY_110	13:00	16:00	3:00	LINE CLEAR AVAILED
368	8-Dec-2021	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	10:03(08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
369	8-Dec-2021	GULBARGA	110	HV1	HUNSIGI_110	21:50	22:00	0:10	TRANSFORMER FAULT
370	8-Dec-2021	GULBARGA	110	HV1	YERAGERA_110	15:35	15:40	0:05	LOAD CURTAILMENT
371	8-Dec-2021	GULBARGA	110	HV2	YERAGERA_110	15:45	15:50	0:05	LOAD CURTAILMENT
372	8-Dec-2021	GULBARGA	110	HV3	YERAGERA_110	15:50	15:55	0:05	LOAD CURTAILMENT
373	8-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGA WEST_110,GULBARGA SOUTH_110	10:39	18:00	7:21	LINE CLEAR AVAILED
374	8-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGA WEST_110,GULBARGA SOUTH_110	11:05	13:40	2:35	LINE CLEAR AVAILED
375	8-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGA WEST_110,GULBARGA SOUTH_110	13:32	15:00	1:28	LINE CLEAR AVAILED
376	8-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGA WEST_110,GULBARGA SOUTH_110	15:15	16:20	1:05	LINE CLEAR AVAILED
377	8-Dec-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS	4:06	4:11	0:05	LINE FAULT
378	8-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
379	8-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HWAR_110	0:33	0:50	0:17	LINE FAULT
380	8-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HWAR_110	2:23	2:40	0:17	LINE FAULT
381	8-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HWAR_110	4:40	4:55	0:15	LINE FAULT
382	8-Dec-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	4:02	13:08	9:06	LINE FAULT
383	8-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	23:29	23:33	0:04	LINE FAULT
384	8-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:35	3:40	0:05	LINE FAULT
385	8-Dec-2021	GULBARGA	110	RAICHUR-SINDHNOOR2	MANVI_110,KURDI CROSS_110,MADALAPUR_110	3:25	3:30	0:05	LINE FAULT
386	8-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
387	8-Dec-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	2:13	2:25	0:12	LINE FAULT
388	8-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	0:38	0:51	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
389	8-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	0:38	0:51	0:13	LINE FAULT
390	8-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
391	8-Dec-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	15:03	15:15	0:12	TRANSFORMER FAULT
392	8-Dec-2021	GULBARGA	220	ITTAGI-BMMISPAT_IPP	ITTAGI_220	11:00	17:10	6:10	LINE CLEAR AVAILED
393	8-Dec-2021	GULBARGA	220	ITTAGI-EMBASSEY_IPP,WETASWIND_IPP,NEELGUNDA_220	ITTAGI_220	10:15	18:55	8:40	LINE CLEAR AVAILED
394	8-Dec-2021	GULBARGA	220	LINGAPUR-BTPSG	LINGAPUR_220	8:07	13:15	5:08	LINE CLEAR AVAILED
395	8-Dec-2021	GULBARGA	220	NEELGUNDA-ITTAGI	NEELGUNDA_220	10:28	18:04	7:36	NFBC ISSUED
396	8-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (7.12.2021)	7:07 (08.12.2021)	9:02 HRS	LINE CHARGED
397	8-Dec-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	23:20(07.12.2021)	16:23(08.08.2021)	17:03	LINE CHARGED
398	8-Dec-2021	GULBARGA	400	RTPS-MEHABOOB NAGAR	MEHABOOB NAGAR_400	9:46 (7.12.2021)	16:37(08.12.2021)	30:51HRS	LINE CHARGED
399	8-Dec-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	10:32	15:35	5:03	LINE CLEAR AVAILED
400	8-Dec-2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	13:06	13:14	0:08	LINE FAULT
401	8-Dec-2021	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	10:32	15:51	5:19	NFBC ISSUED
402	8-Dec-2021	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	10:32	15:51	5:19	NFBC ISSUED
403	8-Dec-2021	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	10:32	16:08	5:36	LINE CLEAR AVAILED
404	8-Dec-2021	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	10:31	16:49	6:18	LINE CLEAR AVAILED
405	8-Dec-2021	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	10:31	15:58	5:27	LINE CLEAR AVAILED
406	8-Dec-2021	HASSAN	66	CRPATNA2-CRPTNA1	CRPATNA_220	10:48	15:50	5:02	LINE CLEAR AVAILED
407	8-Dec-2021	HASSAN	66	CRPATNA2-CRPTNA2	CRPATNA_220	10:48	15:50	5:02	LINE CLEAR AVAILED
408	8-Dec-2021	HASSAN	66	GANGUR-HASSAN	GANGUR_66	14:41	17:36	2:55	LINE CLEAR AVAILED
409	8-Dec-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:02	18:13	0:11	LINE FAULT
410	8-Dec-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	2:33	2:43	0:10	LINE FAULT
411	8-Dec-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	3:58	4:07	0:09	LINE FAULT
412	8-Dec-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	11:21	11:30	0:09	HAND TRIPPED
413	8-Dec-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	14:05	14:10	0:05	LINE FAULT
414	8-Dec-2021	HASSAN	66	HV1	BAGUR_66	10:32	16:19	5:47	LINE CLEAR AVAILED
415	8-Dec-2021	HASSAN	66	HV1	CHANNARAYAPATNA_66	10:32	15:52	5:20	LINE CLEAR AVAILED
416	8-Dec-2021	HASSAN	66	HV1	GANGUR_66	14:41	17:37	2:56	LINE CLEAR AVAILED
417	8-Dec-2021	HASSAN	66	HV1	HOLEHONNUR_66	11:08	13:29	2:21	TRANSFORMER FAULT
418	8-Dec-2021	HASSAN	66	HV1	HOLEHONNUR_66	14:05	17:00	2:55	LINE CLEAR AVAILED
419	8-Dec-2021	HASSAN	66	HV1	KANDLI_66	11:53	12:53	1:00	LINE CLEAR AVAILED
420	8-Dec-2021	HASSAN	66	HV1	RAMPURA_66	10:35	16:04	5:29	LINE CLEAR AVAILED
421	8-Dec-2021	HASSAN	66	HV1	S.BELAGOLA_66	22:08	22:18	0:10	TRANSFORMER FAULT
422	8-Dec-2021	HASSAN	66	HV1	HETTUR_66	10:02	16:34	6:32	LINE CLEAR AVAILED
423	8-Dec-2021	HASSAN	66	HV2	BAGUR_66	10:32	16:01	5:29	LINE CLEAR AVAILED
424	8-Dec-2021	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:32	15:59	5:27	LINE CLEAR AVAILED
425	8-Dec-2021	HASSAN	66	HV2	KANDLI_66	10:47	11:51	1:04	LINE CLEAR AVAILED
426	8-Dec-2021	HASSAN	66	HV2	KANDLI_66	12:00	12:04	0:04	LINE CLEAR AVAILED
427	8-Dec-2021	HASSAN	66	HV2	RAMPURA_66	10:35	16:05	5:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
428	8-Dec-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:50	13:02	1:12	LINE FAULT
429	8-Dec-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:21	15:24	5:03	NFBC ISSUED
430	8-Dec-2021	HASSAN	110	HV1	GURUVAYANAKERE_110	8:20	14:06	5:46	LINE CLEAR AVAILED
431	8-Dec-2021	HASSAN	110	HV1	KONAJE_110	10:13	15:41	5:28	LINE CLEAR AVAILED
432	8-Dec-2021	HASSAN	110	HV2	KONAJE_110	10:16	15:44	5:28	LINE CLEAR AVAILED
433	8-Dec-2021	HASSAN	110	HV3	KONAJE_110	10:16	15:42	5:26	LINE CLEAR AVAILED
434	8-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	10:45(07.12.2021)	16:48(08.12.2021)	30:03hrs	LINE CHARGED
435	8-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	16:26(08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
436	8-Dec-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:20	15:24	5:04	LINE CLEAR AVAILED
437	8-Dec-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:02(07.12.2021)			LINE OPEN:LINE CLEAR AVAILED
438	8-Dec-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	16:19(07.12.2021)	10:00(08.12.2021)	17:41hrs	LINE CHARGED
439	8-Dec-2021	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:52	13:25	2:33	LINE CLEAR AVAILED
440	8-Dec-2021	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	14:06	15:24	1:18	LINE CLEAR AVAILED
441	8-Dec-2021	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	13:21	21:03	7:42	NFBC ISSUED
442	8-Dec-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	16:19(07.12.2021)	10:00(08.12.2021)	17:41hrs	LINE CHARGED
443	8-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:24(07.12.2021)	14:18(08.12.2021)	25:54hrs	LINE CHARGED
444	8-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:39(08.12.2021)			LINE OPEN:LINE FAULT
445	8-Dec-2021	MYSURU	66	BEGUR 220-BEGUR	NANJANGUD_66	18:11	18:17	0:06	LINE FAULT
446	8-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
447	8-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
448	8-Dec-2021	MYSURU	66	HOOTAGALLI-FTS1	NO STATIONS EFFECTED	6:30	6:48	0:18	LINE FAULT
449	8-Dec-2021	MYSURU	66	HV1	DB HALLI_66	10:10	14:30	4:20	LINE CLEAR AVAILED
450	8-Dec-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	11:18	12:20	1:02	LINE CLEAR AVAILED
451	8-Dec-2021	MYSURU	66	HV2	BILIKERE_66	11:36:09 (8.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
452	8-Dec-2021	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	10:42	13:17	2:35	LINE CLEAR AVAILED
453	8-Dec-2021	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	10:44	13:19	2:35	LINE CLEAR AVAILED
454	8-Dec-2021	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	10:44	13:20	2:36	LINE CLEAR AVAILED
455	8-Dec-2021	MYSURU	66	KADKOLA-KOZHICODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
456	8-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
457	8-Dec-2021	MYSURU	66	MYSORESOUTH-KADAKOLA	NO STATIONS EFFECTED	10:47	13:19	2:31	HAND TRIPPED
458	8-Dec-2021	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	10:46	13:20	2:34	HAND TRIPPED
459	8-Dec-2021	MYSURU	220	HEBBANI-TK HALLI1	NO STATIONS EFFECTED	9:36	11:47	2:11	LINE CLEAR AVAILED
460	8-Dec-2021	MYSURU	220	HEBBANI-TK HALLI2	NO STATIONS EFFECTED	11:49	12:50	1:01	LINE CLEAR AVAILED
461	8-Dec-2021	MYSURU	220	MADHUVANAHALLI-HEBBANI1	NO STATIONS EFFECTED	16:45	16:55	0:10	HAND TRIPPED
462	8-Dec-2021	MYSURU	220	MADHUVANAHALLI-HEBBANI2	NO STATIONS EFFECTED	17:25	17:28	0:03	HAND TRIPPED
463	8-Dec-2021	MYSURU	220	MADHUVANAHALLI-HV1	NO STATIONS EFFECTED	14:31	14:45	0:14	HAND TRIPPED
464	8-Dec-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	16:23	17:01	0:38	HAND TRIPPED
465	8-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	8:04	14:48	6:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
466	8-Dec-2021	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	3:28	3:34	0:05	LINE FAULT
467	8-Dec-2021	TUMKUR	66	MATHOD- HOSADURGA	HOSADURGA_66,BAGUR_66,MADADAKERE_66,HALURAMESHWARA_66,NEERAGUNDA66	5:20	5:25	0:05	LINE FAULT
468	8-Dec-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	6:35	6:48	0:13	HAND TRIPPED
469	8-Dec-2021	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	6:35	7:40	1:05	HAND TRIPPED
470	8-Dec-2021	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	6:35	7:40	1:05	HAND TRIPPED
471	8-Dec-2021	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	6:31	6:38	0:07	LINE FAULT
472	8-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	5:18	5:25	0:06	TRANSFORMER FAULT
473	8-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_220	4:40	4:43	0:02	TRANSFORMER FAULT
474	8-Dec-2021	TUMKUR	66	TR-1	THIPPUR_66	8:00	8:17	0:16	TRANSFORMER FAULT
475	8-Dec-2021	TUMKUR	110	TR-1(HV SDE)	KATRIKEHAL_110	3:00	3:12	0:11	MAIN SUPPLY FAILURE
476	8-Dec-2021	TUMKUR	110	TR-1(LV SIDE)	KATRIKEHAL_110	3:01	3:12	0:11	MAIN SUPPLY FAILURE
477	9-Dec-21	BAGALKOT	110	110/11KV,HV1	BEDI_110	15:11	16:21	1:10	LINE CLEAR AVAILED
478	9-Dec-21	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	2:20	3:04	0:44	TRANSFORMER FAULT
479	9-Dec-21	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	10:59	11:02	0:03	HAND TRIPPED
480	9-Dec-21	BAGALKOT	110	110/11KV,HV1	TUMMINAKATTI_110	16:27	16:35	0:08	TRANSFORMER FAULT
481	9-Dec-21	BAGALKOT	110	110/11KV,HV1	TUMMINAKATTI_110	16:37	17:01	0:24	TRANSFORMER FAULT
482	9-Dec-21	BAGALKOT	110	110/11KV,HV1&2	HUBLI_220	19:06	19:10	0:04	HAND TRIPPED
483	9-Dec-21	BAGALKOT	110	110/11KV,HV2	BEDI_110	12:54	15:09	2:15	LINE CLEAR AVAILED
484	9-Dec-21	BAGALKOT	110	110/33KV,HV1&2	RM1_33,ALUCAST_33, MACHE_110	6:11	7:23	1:12	LINE CLEAR AVAILED
485	9-Dec-21	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110	3:57	4:17	0:20	TRANSFORMER FAULT
486	9-Dec-21	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110	12:56	14:09	1:13	LINE CLEAR AVAILED
487	9-Dec-21	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	11:55 (08.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
488	9-Dec-21	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	2:01	2:07	0:06	LINE FAULT
489	9-Dec-21	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	4:21	4:22	0:01	LINE FAULT
490	9-Dec-21	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	2:01	2:07	0:06	LINE FAULT
491	9-Dec-21	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	4:21	4:22	0:01	LINE FAULT
492	9-Dec-21	BAGALKOT	110	AMBEWADI-(NK-2)KAVALWADA	AMBEWADI_220	22:28 (09.12.2021)			LINE OPEN:LINE FAULT
493	9-Dec-21	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	19:06 (8.12.2021)			LINE OPEN:LINE FAULT
494	9-Dec-21	BAGALKOT	110	AMBEWADI-NK-2	KAVALWAD_110	19:18 (8.12.2021)			LINE OPEN:LINE FAULT
495	9-Dec-21	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	6:15	9:30	3:15	NFBC ISSUED
496	9-Dec-21	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	9:29	9:30	0:01	HAND TRIPPED
497	9-Dec-21	BAGALKOT	110	BIDNAL-PG COMPOUND	BIDNAL_220	18:43	18:49	0:06	HAND TRIPPED
498	9-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
499	9-Dec-21	BAGALKOT	110	HUBLI-(SIRS)KALAGATAGI	HUBLI_220	19:06	19:23	0:17	HAND TRIPPED
500	9-Dec-21	BAGALKOT	110	HUBLI-ANAND NAGAR	HUBLI_220	18:17	19:06	0:49	HAND TRIPPED
501	9-Dec-21	BAGALKOT	110	HUBLI-HALIYAL	HALIYAL_110	18:22	18:37	0:15	MAIN SUPPLY FAILURE
502	9-Dec-21	BAGALKOT	110	HUBLI-KADANAKOPPA	HUBLI_220	19:06	19:21	0:15	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
503	9-Dec-21	BAGALKOT	110	HUBLI-PH COMPOUND	HUBLI_220	19:06	19:14	0:08	HAND TRIPPED
504	9-Dec-21	BAGALKOT	110	HUBLI-RAMANKOPPA	HUBLI_220	19:06	19:16	0:10	HAND TRIPPED
505	9-Dec-21	BAGALKOT	110	HUBLI-TARIHAL2	HUBLI_220	19:06 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
506	9-Dec-21	BAGALKOT	110	KADANAKOPPA-HUBLI	KADANAKOPPA_110	18:49	19:30	0:41	HAND TRIPPED
507	9-Dec-21	BAGALKOT	110	MUNDAGOD-RAMANAKOPPA(HUBLI)	MUNDAGOD_110	19:01	21:03	2:02	LINE CLEAR AVAILED
508	9-Dec-21	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	0:18	0:23	0:05	LINE FAULT
509	9-Dec-21	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	6:11	6:17	0:06	LINE FAULT
510	9-Dec-21	BAGALKOT	110	TARIHAL-HUBLI2	TARIHAL_110	18:48 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
511	9-Dec-21	BAGALKOT	110	UDYAMBAG-MACHE	MACHE_110	9:42	9:43	0:01	HAND TRIPPED
512	9-Dec-21	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN:LINE FAULT
513	9-Dec-21	BAGALKOT	220	220/110 HV1,LV1	HUBLI_220	19:06 (09.12.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
514	9-Dec-21	BAGALKOT	220	220/110 HV1,LV1	KARWAR_220	10:34	13:16	2:42	LINE CLEAR AVAILED
515	9-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	HAVERI_220	11:15	17:24	6:09	LINE CLEAR AVAILED
516	9-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	HUBLI_220	18:17 (09.12.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
517	9-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	SODATTI_220	8:51	18:37	9:46	LINE CLEAR AVAILED
518	9-Dec-21	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAILED
519	9-Dec-21	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	13:4 2(9.12.2021)			LINE OPEN:LINE FAULT
520	9-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
521	9-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
522	9-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
523	9-Dec-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	11:45 (08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
524	9-Dec-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:45 (08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
525	9-Dec-21	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	20:47 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
526	9-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
527	9-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
528	9-Dec-21	BAGALKOT	220	RANEBENNUR-BALLIGAVI	RANEBENNUR_220	11:10	14:50	3:40	NFBC ISSUED
529	9-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
530	9-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
531	9-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
532	9-Dec-21	BENGALURU	66	HBR LAYOUT - HEBBALA 220	HBR LAYOUT	19:19	19:25	0:06	LOAD CHANGE OVER
533	9-Dec-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	18:50	18:53	0:03	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
534	9-Dec-21	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	18:54	19:03	0:09	LINE FAULT
535	9-Dec-21	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	16:13	17:23	1:10	LINE FAULT
536	9-Dec-21	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	19:19	19:56	0:37	LINE FAULT
537	9-Dec-21	BENGALURU	66	HOODY 220 - BAGHMANE TECH PARK	NO STATION AFFECTED	7:24	9:50	2:26	LINE FAULT
538	9-Dec-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 66	HOSKOTE 66	8:05	8:40	0:35	LINE FAULT
539	9-Dec-21	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	19:58	20:00	0:02	LINE CLEAR AVAILED
540	9-Dec-21	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	19:58	20:02	0:04	LINE CLEAR AVAILED
541	9-Dec-21	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	19:08	20:08	1:00	LINE CLEAR AVAILED
542	9-Dec-21	BENGALURU	66	HOSKOTE 66 - GRIND WELL(EHT)	GRIND WELL(EHT)	8:05	9:20	1:15	MAIN SUPPLY FAILURE
543	9-Dec-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	8:05	8:40	0:35	MAIN SUPPLY FAILURE
544	9-Dec-21	BENGALURU	66	HV1	ARMY WELFARE	21:11	21:47	0:36	TRANSFORMER FAULT
545	9-Dec-21	BENGALURU	66	HV1	BANASAWADI	18:54	19:03	0:09	MAIN SUPPLY FAILURE
546	9-Dec-21	BENGALURU	66	HV1	BANASAWADI	19:46	19:50	0:04	LOAD CHANGE OVER
547	9-Dec-21	BENGALURU	66	HV1	BIJJAHALLI	15:18	16:28	1:10	LINE CLEAR AVAILED
548	9-Dec-21	BENGALURU	66	HV1	GODURU	11:38	11:59	0:21	LINE CLEAR AVAILED
549	9-Dec-21	BENGALURU	66	HV1	KEMBODI	15:45	16:25	0:40	LINE CLEAR AVAILED
550	9-Dec-21	BENGALURU	66	HV1	TALAGUNDA	14:30	15:40	1:10	LINE CLEAR AVAILED
551	9-Dec-21	BENGALURU	66	HV1	YELAHANKA 220	10:02	13:55	3:53	LINE CLEAR AVAILED
552	9-Dec-21	BENGALURU	66	HV2	KODIHALLI HAROBELE	11:11	11:15	0:04	LINE CLEAR AVAILED
553	9-Dec-21	BENGALURU	66	HV2	NG HULKUR	7:50	7:55	0:05	LINE CLEAR AVAILED
554	9-Dec-21	BENGALURU	66	HV2	TYMAGONDLU	10:05	10:20	0:15	LINE CLEAR AVAILED
555	9-Dec-21	BENGALURU	66	HV2	YELAHANKA 220	10:02	13:56	3:54	LINE CLEAR AVAILED
556	9-Dec-21	BENGALURU	66	HV3	BANASAWADI	18:54	19:03	0:09	MAIN SUPPLY FAILURE
557	9-Dec-21	BENGALURU	66	HV3	BANASAWADI	19:46	19:50	0:04	LOAD CHANGE OVER
558	9-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
559	9-Dec-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:56	12:26	0:30	LINE CLEAR AVAILED
560	9-Dec-21	BENGALURU	66	SRINIVASPURA - KODIHALLI	SRINIVASPURA, YELDUR	8:15	8:30	0:15	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
561	9-Dec-21	BENGALURU	66	SRINIVASPURA - KOLAR 220	SRINIVASPURA, YELDUR	9:10	9:25	0:15	LOAD CHANGE OVER
562	9-Dec-21	BENGALURU	66	ST.JOHN WOOD - ADUGODI	ST.JOHN WOOD	16:38	16:44	0:06	LOAD CHANGE OVER
563	9-Dec-21	BENGALURU	66	ST.JOHN WOOD - HSR LAYOUT 220	ST.JOHN WOOD	13:53	13:58	0:05	LOAD CHANGE OVER
564	9-Dec-21	BENGALURU	66	YELAHANKA 220 - KANASAWADI	KANASAWADI	6:04	6:09	0:05	LINE FAULT
565	9-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	15:33(8-12-2021)	16:48(09/12/2021)	24:15HRS	LINE CHARGED
566	9-Dec-21	BENGALURU	400	NELAMANGALA 400 - TALGUPPA 400	NO STATION AFFECTED	14:39(8-12-2021)	17:32(09/12/2021)	26:53HRS	LINE CHARGED
567	9-Dec-21	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	6:34	6:42	0:08	LINE FAULT
568	9-Dec-21	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	10:03(08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
569	9-Dec-21	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP	11:40	15:04	3:24	LINE CLEAR AVAILED
570	9-Dec-21	GULBARGA	110	HV1	NIRNA_110	9:40	9:45	0:05	TRANSFORMER FAULT
571	9-Dec-21	GULBARGA	110	HV1,HV2	YAPALDINI_110	13:05	13:10	0:05	LOAD CURTAILMENT
572	9-Dec-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	0:48	1:00	0:12	LINE FAULT
573	9-Dec-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
574	9-Dec-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	1:21	1:32	0:11	LINE FAULT
575	9-Dec-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HVAR_110	11:12	13:40	2:28	LINE CLEAR AVAILED
576	9-Dec-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:41	4:49	0:08	LINE FAULT
577	9-Dec-21	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	6:45	7:15	0:30	MAIN SUPPLY FAILURE
578	9-Dec-21	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	6:45	7:15	0:30	MAIN SUPPLY FAILURE
579	9-Dec-21	GULBARGA	110	RAICHUR-SINDHANOOR1	RAICHUR	11:05	13:35	2:30	LINE CLEAR AVAILED
580	9-Dec-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_1 10	0:15	0:18	0:03	LINE FAULT
581	9-Dec-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA _110,SANNATHI_110,CORE GREEN SUGARS_IPP	2:12	2:21	0:09	LINE FAULT
582	9-Dec-21	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110,GANGAVATHI_110,VENKATGIRI_ 110	11:15	11:25	0:10	LINE FAULT
583	9-Dec-21	GULBARGA	220	HV1	SHAHABAD	6:46	11:48	5:02	LINE CLEAR AVAILED
584	9-Dec-21	GULBARGA	220	HV1,LV1	KAPNOOR_220	0:48	0:57	0:09	TRANSFORMER FAULT
585	9-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
586	9-Dec-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	11:40	14:40	0.125	NFBC ISSUED
587	9-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:51	7:33	4:42	LINE CLEAR AVAILED
588	9-Dec-21	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	3:44	4:09	0:25	MAIN SUPPLY FAILURE
589	9-Dec-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETIHALLY_66	5:55	6:01	0:06	LINE FAULT
590	9-Dec-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETIHALLY_66	6:09	9:29	3:20	NFBC ISSUED
591	9-Dec-21	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	6:10	6:33	0:23	LINE FAULT
592	9-Dec-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:54	7:05	0:11	LINE FAULT
593	9-Dec-21	HASSAN	66	HV1	BYACHANAHALLY_66	5:50	9:39	3:49	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
594	9-Dec-21	HASSAN	66	HV1	HALLYMYSORE_66	12:35	12:55	0:20	LINE CLEAR AVAILED
595	9-Dec-21	HASSAN	66	HV1	MAGGE_66	3:46	3:58	0:12	MAIN SUPPLY FAILURE
596	9-Dec-21	HASSAN	66	HV1	MALALI_66	6:55	7:01	0:06	MAIN SUPPLY FAILURE
597	9-Dec-21	HASSAN	66	HV2	MAGGE_66	3:46	3:58	0:12	MAIN SUPPLY FAILURE
598	9-Dec-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	3:44	3:55	0:11	MAIN SUPPLY FAILURE
599	9-Dec-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:07	18:35	0:28	LINE FAULT
600	9-Dec-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	6:55	7:02	0:07	MAIN SUPPLY FAILURE
601	9-Dec-21	HASSAN	66	SAKALE-HASSAN	SAKALESHPURA_66	3:44	3:59	0:15	LINE FAULT
602	9-Dec-21	HASSAN	110	HV1	KALLUSADRHALLY	15:05	15:16	0:11	LINE CLEAR AVAILED
603	9-Dec-21	HASSAN	110	HV2	HALADY_110	6:20	6:29	0:09	TRANSFORMER FAULT
604	9-Dec-21	HASSAN	110	JOG-JLT4	mghejog_gen	16:26(08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
605	9-Dec-21	HASSAN	110	LV1	KADUR_220	11:14	12:34	1:20	LINE CLEAR AVAILED
606	9-Dec-21	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:03	16:22	6:19	LINE CLEAR AVAILED
607	9-Dec-21	HASSAN	220	MRS-SHARAVATHY1	MRS_220	13:46	16:08	2:22	LINE FAULT
608	9-Dec-21	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	13:46	16:08	2:22	LINE FAULT
609	9-Dec-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:06	12:35	1:29	LINE CLEAR AVAILED
610	9-Dec-21	HASSAN	400	NELAMANGALA#2	TALAGUPPA_400	14:39(08.12.2021)	17:32(9.12.2021)	26:56hrs	LINE CHARGED
611	9-Dec-21	MYSURU	66	BESAGRALLI-DUNDANAHALLI	NO STATIONS EFFECTED	7:18	11:53	4:35	HAND TRIPPED
612	9-Dec-21	MYSURU	66	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66 HONNALLY_MYS_66 ARKALAWADI_66	6:43	6:51	0:07	LINE FAULT
613	9-Dec-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	9:50	10:02	0:12	LINE FAULT
614	9-Dec-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:07	10:25	0:17	LINE FAULT
615	9-Dec-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:43	11:52	0:09	LINE FAULT
616	9-Dec-21	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	6:03	6:19	0:16	LINE FAULT
617	9-Dec-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
618	9-Dec-21	MYSURU	66	HAMPAPURA-BASARALU	BASARALU_66 BESAGARAHALLI_66 KOPPA_66	6:04	6:28	0:24	LINE FAULT
619	9-Dec-21	MYSURU	66	HAMPAPURA-BASARALU	BASARALU_66 BESAGARAHALLI_66 KOPPA_66	6:44	7:04	0:20	LINE FAULT
620	9-Dec-21	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
621	9-Dec-21	MYSURU	66	HV1	KADABALLY_66	12:34	12:49	0:15	LINE CLEAR AVAILED
622	9-Dec-21	MYSURU	66	HV1	SUTTUR_66	6:26	6:33	0:06	HAND TRIPPED
623	9-Dec-21	MYSURU	66	HV2	BILIKERE_66	13:57	14:25	0:27	LINE CLEAR AVAILED
624	9-Dec-21	MYSURU	66	HV2	CHANDAKAVADI_66	10:47	10:58	0:10	TRANSFORMER FAULT
625	9-Dec-21	MYSURU	66	KADKOLA-KOZHICODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
626	9-Dec-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
627	9-Dec-21	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	18:10	18:18	0:07	LINE FAULT
628	9-Dec-21	MYSURU	66	MALAVALLI-TK HALLI	KADKOTHANAHALLI_66 MALAVALLI_66	10:04	10:36	0:32	HAND TRIPPED
629	9-Dec-21	MYSURU	66	MALAVALLI-TK HALLI	KADKOTHANAHALLI_66 MALAVALLI_66	15:14	15:42	0:28	HAND TRIPPED
630	9-Dec-21	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66	13:33	13:48	0:14	LINE FAULT
631	9-Dec-21	MYSURU	66	MEGALAPURA-VAJMANGALA	NO STATIONS EFFECTED	10:50	11:02	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
632	9-Dec-21	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	9:49	9:59	0:09	LINE FAULT
633	9-Dec-21	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	9:48	9:52	0:04	LINE FAULT
634	9-Dec-21	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	9:48	9:51	0:03	LINE FAULT
635	9-Dec-21	MYSURU	220	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	9:34	15:23	5:49	LINE CLEAR AVAILED
636	9-Dec-21	TUMKUR	66	BRAHMASANDRA- SIRA(ANKASANDRA)	BRAHMASANDRA_66	8:00	8:21	0:20	LINE FAULT
637	9-Dec-21	TUMKUR	66	BRAHMASANDRA-SUNWIKI STEEL	SUNWIKI STEEL_EHT_66	8:00	8:21	0:20	LINE FAULT
638	9-Dec-21	TUMKUR	66	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	1:01	1:11	0:10	LINE FAULT
639	9-Dec-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	6:53	6:57	0:03	LINE FAULT
640	9-Dec-21	TUMKUR	66	HARIYABBE-PD KOTE	HARIYABBE_66	6:53	6:57	0:03	HAND TRIPPED
641	9-Dec-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	4:19	4:37	0:18	LINE FAULT
642	9-Dec-21	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66,JAVAGONDANAHALLI_66,D ASUDI_66	5:25	5:45	0:20	LINE FAULT
643	9-Dec-21	TUMKUR	66	HIRIYUR220-PR PURA66	PRPUR_66	6:25	6:35	0:10	LINE FAULT
644	9-Dec-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:02	20:10	0:07	LINE FAULT
645	9-Dec-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:10	15:24	0:13	LINE FAULT
646	9-Dec-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	23:29	23:39	0:10	LINE FAULT
647	9-Dec-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	20:50	20:55	0:05	LINE FAULT
648	9-Dec-21	TUMKUR	66	MATHOD- HOSADURGA	HOSADURGA_66,BAGUR_66,MADADAKERE_66,HALURAMESHWARA_66,NEERAGUNDA66	6:53	7:01	0:07	LINE FAULT
649	9-Dec-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	2:50	4:44	1:53	HAND TRIPPED
650	9-Dec-21	TUMKUR	66	TR-1	MATHOD_66	6:53	7:01	0:07	TRANSFORMER FAULT
651	9-Dec-21	TUMKUR	66	TR-1	GULIGENAHALLI_66	12:55	13:42	0:47	LINE CLEAR AVAILED
652	9-Dec-21	TUMKUR	66	TR-2(HV SIDE)	DAVANGERE_SRS_220	10:42	13:57	3:15	LINE CLEAR AVAILED
653	9-Dec-21	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	5:45	6:24	0:38	LINE FAULT
654	9-Dec-21	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	22:01	22:03	0:01	HAND TRIPPED
655	9-Dec-21	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	21:49	22:09	0:19	LINE FAULT
656	9-Dec-21	TUMKUR	110	TR-1	SOMLAPURA_110	10:55	13:07	2:12	LINE CLEAR AVAILED
657	9-Dec-21	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 1	ANTHRASANAHALLI_220	11:44	12:56	1:12	HAND TRIPPED
658	9-Dec-21	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	12:56	17:03	4:07	HAND TRIPPED
659	9-Dec-21	TUMKUR	220	TR-3	HIRIYUR_220	5:24	5:30	0:06	TRANSFORMER FAULT
660	10-Dec-21	BAGALKOT	110	110/11KV, HV1	SUVARNASOUDHA_110	10:31	12:58	2:27	LINE CLEAR AVAILED
661	10-Dec-21	BAGALKOT	110	110/11KV, HV1	YELPARAHATTI_110	14:25	17:12	2:47	LINE CLEAR AVAILED
662	10-Dec-21	BAGALKOT	110	110/33KV, HV1	YARGATTI_110, SHIVAPUR_33, CHINCHNUR_33	18:02	18:46	0:44	LINE CLEAR AVAILED
663	10-Dec-21	BAGALKOT	110	110/33KV, HV3	HIDIKAL DAM_110, WATER SUUPLY1&2_33	13:00	13:34	0:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
664	10-Dec-21	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	11:55 (08.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
665	10-Dec-21	BAGALKOT	110	AMBEWADI- HALIYAL	HALIYAL_110	1:30	16:27	14:57	LINE FAULT
666	10-Dec-21	BAGALKOT	110	AMBEWADI- NK1(HALIYAL)	AMBEWADI_220	1:31	16:27	14:56	LINE FAULT
667	10-Dec-21	BAGALKOT	110	AMBEWADI-(NK-2)KAVALWADA	AMBEWADI_220	22:28 (09.12.2021)	16:27 (10.12.2021)	17:59	LINE FAULT
668	10-Dec-21	BAGALKOT	110	BELGAUM220- UCHAGOAN	UCHAGOAN_110	13:45	15:33	1:48	LINE CLEAR AVAIED
669	10-Dec-21	BAGALKOT	110	BELGAUM-UCHAGOAN	UCHAGOAN_110	13:54	15:08	1:14	NFBC ISSUED
670	10-Dec-21	BAGALKOT	110	BIDNAL- NAVALGUND	BIDNAL_220	0:59	10:39	9:40	LINE FAULT
671	10-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAIED
672	10-Dec-21	BAGALKOT	110	HIDIKAL DAM- ANKALAGI	HIDIKAL DAM_110	14:13	15:20	1:07	LINE CLEAR AVAIED
673	10-Dec-21	BAGALKOT	110	HUBLI-TARIHAL2	HUBLI_220	19:06 (09.12.2021)	12:19 (10.12.2021)	17:13	LINE CHARGED
674	10-Dec-21	BAGALKOT	110	ISLAMPUR- HIDIKAL DAM	ISLAMPUR_110	14:11	15:54	1:43	HAND TRIPPED
675	10-Dec-21	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	1:32	1:52	0:20	MAIN SUPPLY FAILURE
676	10-Dec-21	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	21:11	21:18	0:07	LINE FAULT
677	10-Dec-21	BAGALKOT	110	TARIHAL-HUBLI2	TARIHAL_110	18:48 (09.12.2021)	13:01 (10.12.2021)	18:13	LINE CHARGED
678	10-Dec-21	BAGALKOT	110	UDIKERI- NOKAR SOLAR	UDIKERI_110	11:10	11:20	0:10	LINE FAULT
679	10-Dec-21	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN:LINE FAULT
680	10-Dec-21	BAGALKOT	220	220/110KV, HV1&LV1	MUGALKOD_220	13:51	14:26	0:35	HAND TRIPPED
681	10-Dec-21	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220	8:36	18:34	9:58	LINE CLEAR AVAIED
682	10-Dec-21	BAGALKOT	220	220/110KV,HV1,LV1	HUBLI_220	19:06 (09.12.2021)	10:41 (10.12.2021)	15:35	TRANSFORMER FAULT
683	10-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	HUBLI_220	18:17 (09.12.2021)	10:48 (10.12.2021)	16:31	TRANSFORMER FAULT
684	10-Dec-21	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAIED
685	10-Dec-21	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	13:42 (9.12.2021)	9:41 (10.12.2021)	19:59	LINE FAULT
686	10-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAIED
687	10-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAIED
688	10-Dec-21	BAGALKOT	220	BELGAUM- KANABARGI1(NARENDRA1)	BELGAUM_220	11:03	11:13	0:10	HAND TRIPPED
689	10-Dec-21	BAGALKOT	220	BELGAUM- KANABARGI1(NARENDRA1)	BELGAUM_220	16:22	16:51	0:29	HAND TRIPPED
690	10-Dec-21	BAGALKOT	220	BELGAUM- KANABARGI2(NARENDRA2)	BELGAUM_220	10:58	16:51	5:53	LINE CLEAR AVAIED
691	10-Dec-21	BAGALKOT	220	BIDNAL- HARTI1	BIDNAL_220	12:20	12:45	0:25	LINE CLEAR AVAIED
692	10-Dec-21	BAGALKOT	220	BIDNAL- HARTI1	BIDNAL_220	13:14	14:54	1:40	LINE CLEAR AVAIED
693	10-Dec-21	BAGALKOT	220	BIDNAL- HARTI2	BIDNAL_220	9:05	11:37	2:32	LINE CLEAR AVAIED
694	10-Dec-21	BAGALKOT	220	BIDNAL- HARTI2	BIDNAL_220	12:15	16:51	4:36	LINE CLEAR AVAIED
695	10-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAIED
696	10-Dec-21	BAGALKOT	220	GHATAPRABHA- NARENDRA1	GHATAPRABHA_220	10:21	19:22	9:01	LINE CLEAR AVAIED
697	10-Dec-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	11:45 (08.12.2021)			LINE OPEN:LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
698	10-Dec-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:45 (08.12.2021)			LINE OPEN:LINE CLEAR AVAILED
699	10-Dec-21	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	20:47 (09.12.2021)	6:00 (10.12.2021)	9:13	LINE CHARGED
700	10-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
701	10-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
702	10-Dec-21	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	10:57	16:51	5:54	LINE CLEAR AVAILED
703	10-Dec-21	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	10:57	16:51	5:54	LINE CLEAR AVAILED
704	10-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
705	10-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
706	10-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
707	10-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
708	10-Dec-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:01	13:38	0:37	LINE CLEAR AVAILED
709	10-Dec-21	BENGALURU	66	GANJIGUNTE - PALLICHERLU	PALLICHERLU	15:50	15:55	0:05	LINE FAULT
710	10-Dec-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	6:06	6:34	0:28	LINE FAULT
711	10-Dec-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	10:59	11:09	0:10	LINE FAULT
712	10-Dec-21	BENGALURU	66	HV1	CHINTAMANI 66	14:55	14:59	0:03	LINE CLEAR AVAILED
713	10-Dec-21	BENGALURU	66	HV1	DASHAVARA	19:33	19:38	0:05	TRANSFORMER FAULT
714	10-Dec-21	BENGALURU	66	HV1	HOSKOTE 220	10:30	13:43	3:13	LINE CLEAR AVAILED
715	10-Dec-21	BENGALURU	66	HV1	KUMBALAGODU	12:05	12:34	0:29	LINE CLEAR AVAILED
716	10-Dec-21	BENGALURU	66	HV1	KUMBALAGODU	15:50	16:15	0:25	LINE CLEAR AVAILED
717	10-Dec-21	BENGALURU	66	HV2	KGF	0:27	1:28	1:01	TRANSFORMER FAULT
718	10-Dec-21	BENGALURU	66	HV3	KGF	0:27	1:30	1:03	TRANSFORMER FAULT
719	10-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
720	10-Dec-21	BENGALURU	66	ST. JOHNS WOOD - HSR LAYOUT 220	ST.JOHNS WOOD	16:00	16:04	0:04	LOAD CHANGE OVER
721	10-Dec-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	17:07(10/12/2021)			LINE OPEN:LINE FAULT
722	10-Dec-21	GULBARGA	66	HALAVAGALU-NEELGUNDA	HALAVAGALU_66	6:30	6:40	0:10	MAIN SUPPLY FAILURE
723	10-Dec-21	GULBARGA	66	HV1	HANASI_66	7:30	7:40	0:10	TRANSFORMER FAULT
724	10-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
725	10-Dec-21	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	6:34	6:42	0:08	LINE FAULT
726	10-Dec-21	GULBARGA	110	ADAVIAMERESHWAR-MALLAT	ADAVIAMERESHWAR_110	19:30	19:38	0:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
727	10-Dec-21	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	8:00(9.12.2021)			LINE OPEN:LINE CLEAR AVAILED
728	10-Dec-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	1:40	1:45	0:05	MAIN SUPPLY FAILURE
729	10-Dec-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:40	4:50	0:10	MAIN SUPPLY FAILURE
730	10-Dec-21	GULBARGA	110	HV2	YEDRAMI_110	13:25	13:45	0:20	TRANSFORMER FAULT
731	10-Dec-21	GULBARGA	110	HV3	KEREHALLI_110	15:40	15:50	0:10	TRANSFORMER FAULT
732	10-Dec-21	GULBARGA	110	KAMALNAGAR-DONGARGOAN	KAMALNAGAR_110	6:05	6:50	0:45	MAIN SUPPLY FAILURE
733	10-Dec-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN:LINE CLEAR AVAILED
734	10-Dec-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_220	19:26	19:36	0:10	LINE FAULT
735	10-Dec-21	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	6:08	6:22	0:14	LINE FAULT
736	10-Dec-21	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	16:37	16:47	0:10	LINE FAULT
737	10-Dec-21	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	8:22	8:35	0:13	LINE FAULT
738	10-Dec-21	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	5:50	6:00	0:10	LINE FAULT
739	10-Dec-21	GULBARGA	110	RAICHUR-APMC1 &2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	20:19	20:22	0:03	LINE FAULT
740	10-Dec-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110, KORWAR TEMPLE_110	22:23	22:59	0:36	LINE FAULT
741	10-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
742	10-Dec-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110,NALWAR_110	5:52	5:59	0:07	LINE FAULT
743	10-Dec-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	1:35	1:43	0:08	LINE FAULT
744	10-Dec-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	4:40	4:54	0:14	LINE FAULT
745	10-Dec-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	6:25	6:34	0:09	LINE FAULT
746	10-Dec-21	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	16:49	16:54	0:05	LINE FAULT
747	10-Dec-21	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	23:17	23:27	0:10	LINE FAULT
748	10-Dec-21	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	16:49	16:54	0:05	LINE FAULT
749	10-Dec-21	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	23:17	23:27	0:10	LINE FAULT
750	10-Dec-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110, SRNAGAR_110,MALLAPURA_110	6:25	6:35	0:10	LINE FAULT
751	10-Dec-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	5:25	5:35	0:10	MAIN SUPPLY FAILURE
752	10-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
753	10-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (10.12.2021)			LINE OPEN:LINE CLEAR AVAILED
754	10-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:18	7:15	5:57	LINE CLEAR AVAILED
755	10-Dec-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	7:21	7:32	0:11	LINE FAULT
756	10-Dec-21	HASSAN	66	HV1	HALLYMYSORE_66	5:30	5:40	0:10	TRANSFORMER FAULT
757	10-Dec-21	HASSAN	66	HV1	HALLYMYSORE_66	7:42	7:53	0:11	TRANSFORMER FAULT
758	10-Dec-21	HASSAN	66	HV1	MALLAPURA_66	13:50	15:13	1:23	LINE CLEAR AVAILED
759	10-Dec-21	HASSAN	66	HV2	HALLYMYSORE_66	7:21	7:45	0:24	TRANSFORMER FAULT
760	10-Dec-21	HASSAN	66	HV2	MALLAPURA_66	13:50	15:13	1:23	LINE CLEAR AVAILED
761	10-Dec-21	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	13:50	15:13	1:23	LINE CLEAR AVAILED
762	10-Dec-21	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:23	13:01	2:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
763	10-Dec-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	12:15	14:07	1:52	LINE CLEAR AVAILED
764	10-Dec-21	HASSAN	110	HV1	KONAJE_110	13:49	13:53	0:04	HAND TRIPPED
765	10-Dec-21	HASSAN	110	HV1	KONAJE_110	15:03	15:08	0:05	HAND TRIPPED
766	10-Dec-21	HASSAN	110	HV2	KONAJE_110	13:49	13:53	0:04	HAND TRIPPED
767	10-Dec-21	HASSAN	110	HV2	KONAJE_110	15:03	15:08	0:05	HAND TRIPPED
768	10-Dec-21	HASSAN	110	HV3	KONAJE_110	13:49	13:53	0:04	HAND TRIPPED
769	10-Dec-21	HASSAN	110	HV3	KONAJE_110	15:03	15:08	0:05	HAND TRIPPED
770	10-Dec-21	HASSAN	110	JOG-JLT4	mghejog_gen	16:26(08.12.2021)	18:59 (10.12.2021)	50:32 hrs	LINE CHARGED
771	10-Dec-21	HASSAN	110	KEMAR-Guruvkere2	KEMAR_220	12:15	14:07	1:52	LINE CLEAR AVAILED
772	10-Dec-21	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	18:52	23:20	4:28	LINE CLEAR AVAILED
773	10-Dec-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:15	11:44	0:29	MAIN SUPPLY FAILURE
774	10-Dec-21	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	10:08	10:11	0:03	HAND TRIPPED
775	10-Dec-21	HASSAN	110	MSEZ-BAIKAMPADI	MSEZ_220	10:41	15:37	4:56	LINE CLEAR AVAILED
776	10-Dec-21	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	18:50	23:20	4:30	NFBC ISSUED
777	10-Dec-21	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	10:01	13:04	3:03	LINE CLEAR AVAILED
778	10-Dec-21	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	11:15	11:33	0:18	LINE FAULT
779	10-Dec-21	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	14:07	14:50	0:43	LINE CLEAR AVAILED
780	10-Dec-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	11:17	11:32	0:15	MAIN SUPPLY FAILURE
781	10-Dec-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:09	15:15	5:06	LINE CLEAR AVAILED
782	10-Dec-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:07	13:56	2:49	NFBC ISSUED
783	10-Dec-21	MYSURU	66	DATAGALLI-HOOTGALLY	NO STATIONS EFFECTED	10:10	10:38	0:27	HAND TRIPPED
784	10-Dec-21	MYSURU	66	DR PETE-MADHUVANALLI	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66 THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66	23:04	23:08	0:04	LINE FAULT
785	10-Dec-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
786	10-Dec-21	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
787	10-Dec-21	MYSURU	66	HEBBANI-MADHUVANALLI	NO STATIONS EFFECTED	10:15	16:15	6:00	LINE CLEAR AVAILED
788	10-Dec-21	MYSURU	66	HEBBANI-MEGHALAPURA	CHIDRAWALLI_66 BG PURA_66	12:54	13:03	0:09	LINE FAULT
789	10-Dec-21	MYSURU	66	HEBBANI-SFC3	NO STATIONS EFFECTED	11:05	15:36	4:31	LINE CLEAR AVAILED
790	10-Dec-21	MYSURU	66	HEBBANI-SFC4	NO STATIONS EFFECTED	11:05	15:36	4:31	LINE CLEAR AVAILED
791	10-Dec-21	MYSURU	66	HEBBANI-SFC5	NO STATIONS EFFECTED	11:05	15:36	4:31	LINE CLEAR AVAILED
792	10-Dec-21	MYSURU	66	HEBBANI-SFC9	NO STATIONS EFFECTED	9:36	15:47	6:11	LINE CLEAR AVAILED
793	10-Dec-21	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	11:24	12:26	1:02	LINE CLEAR AVAILED
794	10-Dec-21	MYSURU	66	HEBBANI-VAJAMANGLA	NO STATIONS EFFECTED	11:05	15:36	4:31	LINE CLEAR AVAILED
795	10-Dec-21	MYSURU	66	HOOTGALLY-DATTAGALLI	NO STATIONS EFFECTED	9:58	10:30	0:32	LINE FAULT
796	10-Dec-21	MYSURU	66	HV1	JAKKANALLI_66	10:23	15:05	4:41	LINE CLEAR AVAILED
797	10-Dec-21	MYSURU	66	HV1	KABHALLY_66	12:27	13:22	0:54	LINE CLEAR AVAILED
798	10-Dec-21	MYSURU	66	JAKKANALLI-NAGMANGLA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	5:39	5:48	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
799	10-Dec-21	MYSURU	66	KADKOLA-KOZHICODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
800	10-Dec-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30(24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
801	10-Dec-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	10:13	16:15	6:02	NFBC ISSUED
802	10-Dec-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	11:34	11:40	0:06	LINE FAULT
803	10-Dec-21	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	4:38	4:42	0:03	LINE FAULT
804	10-Dec-21	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	7:53	8:12	0:19	LINE FAULT
805	10-Dec-21	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	7:53	8:06	0:13	LINE FAULT
806	10-Dec-21	TUMKUR	66	THALLAK 220kV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	2:47	8:34	5:47	LINE FAULT
807	10-Dec-21	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	6:23	6:35	0:11	LINE FAULT
808	10-Dec-21	TUMKUR	66	TR-1	HAGALWADI_66	12:50	14:46	1:56	LINE CLEAR AVAILED
809	10-Dec-21	TUMKUR	66	TR-1	NANDIHALLI CROSS_66	11:16	11:46	0:29	LINE CLEAR AVAILED
810	10-Dec-21	TUMKUR	66	TR-1	NMAVINAKATTE_66	10:43	10:53	0:09	TRANSFORMER FAULT
811	10-Dec-21	TUMKUR	66	TR-1(LV-1)	THALLAK_220	6:23	6:33	0:09	TRANSFORMER FAULT
812	10-Dec-21	TUMKUR	220	TR-1	THALLAK_220	6:23	6:30	0:07	TRANSFORMER FAULT
813	10-Dec-21	TUMKUR	220	TR-3	HIRIYUR_220	4:38	4:42	0:03	TRANSFORMER FAULT
814	11-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	13:22	14:28	1:06	LINE CLEAR AVAILED
815	11-Dec-21	BAGALKOT	110	110/11KV, HV1	MUDALAGI_110	15:49	17:43	1:54	LINE CLEAR AVAILED
816	11-Dec-21	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	10:09	18:25	8:16	NFBC ISSUED
817	11-Dec-21	BAGALKOT	110	110/11KV, HV2	GUTTAL_110	7:47	8:19	0:32	LINE CLEAR AVAILED
818	11-Dec-21	BAGALKOT	110	110/11KV, HV3	MUDALAGI_110	15:49	17:43	1:54	LINE CLEAR AVAILED
819	11-Dec-21	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	10:09	18:22	8:13	NFBC ISSUED
820	11-Dec-21	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	11:55 (08.12.2021)	11:05 (11.12.2021)	71:10 hrs	TRANSFORMER CHARGED
821	11-Dec-21	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	5:47	6:06	0:19	LINE CLEAR AVAILED
822	11-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
823	11-Dec-21	BAGALKOT	110	MUGALKOD- RAIBAG1	MUGALKOD_220	9:35	18:18	8:43	LINE CLEAR AVAILED
824	11-Dec-21	BAGALKOT	110	MUGALKOD- RAIBAG2	MUGALKOD_220	9:35	18:20	8:45	LINE CLEAR AVAILED
825	11-Dec-21	BAGALKOT	110	RAIBAG-ITNAL	RAIBAG_110	9:34	18:18	8:44	NFBC ISSUED
826	11-Dec-21	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN:LINE FAULT
827	11-Dec-21	BAGALKOT	220	220/110KV, HV1&LV1	MKHUBLI_220	11:05	18:10	7:05	LINE CLEAR AVAILED
828	11-Dec-21	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	15:00	16:32	1:32	LINE CLEAR AVAILED
829	11-Dec-21	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220	8:18	14:26	6:08	LINE CLEAR AVAILED
830	11-Dec-21	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_220	13:58	13:59	0:01	HAND TRIPPED
831	11-Dec-21	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_220	15:23	15:25	0:02	HAND TRIPPED
832	11-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	15:26	15:29	0:03	HAND TRIPPED
833	11-Dec-21	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAILED
834	11-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
835	11-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
836	11-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
837	11-Dec-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	11:45 (08.12.2021)	19:10 (11.12.2021)	79:25 hrs	LINE CHARGED
838	11-Dec-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	10:22	18:55	8:33	LINE CLEAR AVAILED
839	11-Dec-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:45 (08.12.2021)	19:12 (11.12.2021)	79:27 hrs	LINE CHARGED
840	11-Dec-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	10:23	18:57	8:34	LINE CLEAR AVAILED
841	11-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
842	11-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	13:51	13:52	0:01	HAND TRIPPED
843	11-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	15:19	15:20	0:01	HAND TRIPPED
844	11-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
845	11-Dec-21	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	13:36	13:38	0:03	HAND TRIPPED
846	11-Dec-21	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	14:21	14:22	0:01	HAND TRIPPED
847	11-Dec-21	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	13:39	13:40	0:01	HAND TRIPPED
848	11-Dec-21	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	15:12	15:13	0:01	HAND TRIPPED
849	11-Dec-21	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	13:45	13:46	0:01	HAND TRIPPED
850	11-Dec-21	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	15:21	15:22	0:01	HAND TRIPPED
851	11-Dec-21	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	13:56	13:57	0:01	HAND TRIPPED
852	11-Dec-21	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	15:15	15:16	0:01	HAND TRIPPED
853	11-Dec-21	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	13:54	13:55	0:01	HAND TRIPPED
854	11-Dec-21	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	15:16	15:17	0:01	HAND TRIPPED
855	11-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
856	11-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAILED
857	11-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
858	11-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
859	11-Dec-21	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	6:24	6:49	0:25	LINE FAULT
860	11-Dec-21	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	6:24	6:46	0:22	LINE FAULT
861	11-Dec-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL(SOLAR)	NO STATION AFFECTED	14:49	14:54	0:05	LINE FAULT
862	11-Dec-21	BENGALURU	66	HEBBALA 220 - LR BANDE	LR BANDE	20:16	20:18	0:02	LINE FAULT
863	11-Dec-21	BENGALURU	66	HOODY 220 - BAGHMANE TECH PARK 2	NO STATION AFFECTED	6:41	10:21	3:40	LINE FAULT
864	11-Dec-21	BENGALURU	66	HV1	ABBIGERE	12:11	12:13	0:02	LINE CLEAR AVAILED
865	11-Dec-21	BENGALURU	66	HV1	ATTIBELE	14:57	15:00	0:02	LINE CLEAR AVAILED
866	11-Dec-21	BENGALURU	66	HV1	KEMBODI	13:10	13:30	0:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
867	11-Dec-21	BENGALURU	66	HV1	KEMBODI	13:10	13:30	0:19	LOAD CHANGE OVER
868	11-Dec-21	BENGALURU	66	HV1	MITTEMARI 220	14:20	14:53	0:32	MAIN SUPPLY FAILURE
869	11-Dec-21	BENGALURU	66	HV1	MITTEMARI 220	15:07	15:43	0:36	MAIN SUPPLY FAILURE
870	11-Dec-21	BENGALURU	66	HV2	ABBIGERE	13:24	13:27	0:03	LINE CLEAR AVAILED
871	11-Dec-21	BENGALURU	66	HV2	N G HULKUR	19:39	19:55	0:16	LINE CLEAR AVAILED
872	11-Dec-21	BENGALURU	66	HV5	NRS 220	13:06	13:36	0:30	LINE CLEAR AVAILED
873	11-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
874	11-Dec-21	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	13:33	13:37	0:04	LOAD CHANGE OVER
875	11-Dec-21	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	20:58	21:03	0:05	LOAD CHANGE OVER
876	11-Dec-21	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	11:16	11:29	0:13	MAIN SUPPLY FAILURE
877	11-Dec-21	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	20:16	20:18	0:02	MAIN SUPPLY FAILURE
878	11-Dec-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:55	12:56	2:01	LINE CLEAR AVAILED
879	11-Dec-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:55	12:54	1:59	LINE CLEAR AVAILED
880	11-Dec-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	14:20	14:50	0:30	MAIN SUPPLY FAILURE
881	11-Dec-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	14:53	15:30	0:37	MAIN SUPPLY FAILURE
882	11-Dec-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	14:20	14:50	0:30	MAIN SUPPLY FAILURE
883	11-Dec-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	14:53	15:30	0:37	MAIN SUPPLY FAILURE
884	11-Dec-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:20	14:50	0:30	MAIN SUPPLY FAILURE
885	11-Dec-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:53	15:30	0:37	MAIN SUPPLY FAILURE
886	11-Dec-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	14:20	14:50	0:30	MAIN SUPPLY FAILURE
887	11-Dec-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	14:53	15:30	0:37	MAIN SUPPLY FAILURE
888	11-Dec-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	14:20	14:50	0:30	MAIN SUPPLY FAILURE
889	11-Dec-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	14:53	15:30	0:37	MAIN SUPPLY FAILURE
890	11-Dec-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	14:20	14:50	0:30	MAIN SUPPLY FAILURE
891	11-Dec-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	14:53	15:30	0:37	MAIN SUPPLY FAILURE
892	11-Dec-21	BENGALURU	66	SADLI - DIBBURAHALLI	DIBBURAHALLI	14:35	14:40	0:05	LOAD CHANGE OVER
893	11-Dec-21	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	12:18	12:25	0:07	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
894	11-Dec-21	BENGALURU	220	GOWRIBIDANUR - MITTEMARI 1	MITTEMARI 220	14:18	15:04	0:46	LINE FAULT
895	11-Dec-21	BENGALURU	220	GOWRIBIDANUR - MITTEMARI 2	NO STATION AFFECTED	14:49	16:44	1:55	LINE FAULT
896	11-Dec-21	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	NO STATION AFFECTED	15:25	15:35	0:10	LINE CLEAR AVOIDED
897	11-Dec-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	17:07(10/12/2021)	13:04(11/12/2021)	19:57HRS	LINE CHARGED
898	11-Dec-21	BENGALURU	220	HV1	MITTEMARI 220	14:20	14:50	0:30	MAIN SUPPLY FAILURE
899	11-Dec-21	BENGALURU	220	HV1	MITTEMARI 220	14:53	15:25	0:32	MAIN SUPPLY FAILURE
900	11-Dec-21	BENGALURU	220	HV2	MITTEMARI 220	14:20	14:50	0:30	MAIN SUPPLY FAILURE
901	11-Dec-21	BENGALURU	220	HV2	MITTEMARI 220	14:53	15:25	0:32	MAIN SUPPLY FAILURE
902	11-Dec-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	14:53	15:52	0:59	LINE FAULT
903	11-Dec-21	GULBARGA	66	HV2	KOGALI_66	9:20	9:35	0:15	TRANSFORMER FAULT
904	11-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
905	11-Dec-21	GULBARGA	66	ITTAGI-RENEW SOLAR_IPP	ITTAGI_220	22:14 (11.12.2021)			LINE OPEN:LINE FAULT
906	11-Dec-21	GULBARGA	66	NEELGUNDA-PUNABGHATA	PUNABGHATA_66,UCHANGIDURGA_66	18:15	18:20	0:05	LINE FAULT
907	11-Dec-21	GULBARGA	110	ACMESLR-BYGWAT	BYGWAT_110	13:52	14:09	0:17	LINE FAULT
908	11-Dec-21	GULBARGA	110	ACMESLR-BYGWAT	BYGWAT_110	19:16	19:55	0:39	LINE FAULT
909	11-Dec-21	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	12:35	12:40	0:05	LINE FAULT
910	11-Dec-21	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	1:23	1:29	0:06	LINE FAULT
911	11-Dec-21	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGASOUTH	GULBARGAUNIVERSITY_110	9:30	12:15	2:45	NFBC ISSUED
912	11-Dec-21	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	8:00(9.12.2021)			LINE OPEN:LINE CLEAR AVOIDED
913	11-Dec-21	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	10:31	10:37	0:06	LINE FAULT
914	11-Dec-21	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	15:47	15:49	0:02	LINE FAULT
915	11-Dec-21	GULBARGA	110	NALWAR-WARDHASOLAR_IPP	NALWAR_110	18:10	22:35	4:25	LINE CLEAR AVOIDED
916	11-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
917	11-Dec-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	0:03	0:11	0:08	LINE FAULT
918	11-Dec-21	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	4:58	5:04	0:06	LINE FAULT
919	11-Dec-21	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	4:58	5:04	0:06	LINE FAULT
920	11-Dec-21	GULBARGA	220	HV1	HUMNABAD_220	18:12	18:35	0:23	TRANSFORMER FAULT
921	11-Dec-21	GULBARGA	220	HV1	ITTAGI_220	22:14	22:25	0:11	TRANSFORMER FAULT
922	11-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
923	11-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (10.12.2021)	6:16 (11.12.2021)	8:11 HRS	LINE CHARGED
924	11-Dec-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:03	6:57	6:54	LINE CLEAR AVOIDED
925	11-Dec-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:46	12:20	1:34	LINE CLEAR AVOIDED
926	11-Dec-21	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:46	12:20	1:34	LINE CLEAR AVOIDED
927	11-Dec-21	HASSAN	66	HV2	TAVARECHATNAHALLI_66	13:01	13:18	0:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
928	11-Dec-21	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	9:36	16:18	6:42	LINE CLEAR AVAILED
929	11-Dec-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	19:25 (11.12.2021)			LINE OPEN:LINE FAULT
930	11-Dec-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:05	16:39	5:34	NFBC ISSUED
931	11-Dec-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	18:28 (11.12.2021)			LINE OPEN:LINE FAULT
932	11-Dec-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:05	16:39	5:34	NFBC ISSUED
933	11-Dec-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	19:54(11.12.2021)			LINE OPEN:LINE FAULT
934	11-Dec-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	10:23	16:36	6:13	LINE CLEAR AVAILED
935	11-Dec-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	19:25	19:54	0:29	LINE FAULT
936	11-Dec-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:28 (11.12.20221)			LINE OPEN:LINE FAULT
937	11-Dec-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:07	13:56	2:49	LINE FAULT
938	11-Dec-21	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARALLI_66 KUNTHUR_66 MUGUR_66	3:34	3:42	0:07	LINE FAULT
939	11-Dec-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
940	11-Dec-21	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
941	11-Dec-21	MYSURU	66	HEBBANI-MEGHALAPURA	CHIDRAWALLI_66 BG PURA_66	14:59	15:13	0:14	LINE FAULT
942	11-Dec-21	MYSURU	66	HEBBANI-MEGHALAPURA	CHIDRAWALLI_66 BG PURA_66	18:02	18:15	0:13	LINE FAULT
943	11-Dec-21	MYSURU	66	HEBBANI-VADKEPURA	VADKEPURA_66	14:59	15:12	0:13	LINE FAULT
944	11-Dec-21	MYSURU	66	HV2	BG NAGARA_66	15:06	16:31	1:24	LINE CLEAR AVAILED
945	11-Dec-21	MYSURU	66	KADAKOLA-SARGUR1	HAMPAPURA_66 DOORA_66 HURA_66 HULLALLI_66 JAYAPURA_66 CHANDRAWADI_66	14:38	14:45	0:07	LINE FAULT
946	11-Dec-21	MYSURU	66	KADAKOLA-SARGUR2	HAMPAPURA_66 DOORA_66 HURA_66 HULLALLI_66 JAYAPURA_66 CHANDRAWADI_66	14:38	14:45	0:07	LINE FAULT
947	11-Dec-21	MYSURU	66	KADKOLA-KOZHIKODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)	17:19:33 (11.12.2021)	176:52 hrs	LINE CHARGED
948	11-Dec-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
949	11-Dec-21	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	16:37	16:42	0:05	LINE FAULT
950	11-Dec-21	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	16:55	17:04	0:09	LINE FAULT
951	11-Dec-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	6:05	6:12	0:07	LINE FAULT
952	11-Dec-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	17:37:49 (11.12.2021)			LINE OPEN:LINE CLEAR AVAILED
953	11-Dec-21	TUMKUR	66	HIRIYUR 220kV - CHITRADURGA(SIRA)	SANEKERE_66, CHALKERE_66, IMANGALA_66, BALENAHALLI_66	18:20	18:39	0:19	LINE FAULT
954	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	1:03	1:08	0:05	HAND TRIPPED
955	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	1:02	1:11	0:08	HAND TRIPPED
956	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:43	17:53	0:09	HAND TRIPPED
957	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	18:29	18:39	0:09	HAND TRIPPED
958	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	1:02	1:11	0:08	HAND TRIPPED
959	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	17:43	17:53	0:10	HAND TRIPPED
960	11-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	18:29	18:39	0:09	HAND TRIPPED
961	11-Dec-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	5:19	5:27	0:08	LINE FAULT
962	11-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	2:22	2:28	0:05	LINE FAULT
963	11-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	4:20	4:29	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
964	11-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	5:25	5:35	0:09	LINE FAULT
965	11-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	5:57	6:11	0:14	LINE FAULT
966	11-Dec-21	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	10:36	12:25	1:48	LINE CLEAR AVAILED
967	11-Dec-21	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	10:32	12:34	2:02	LINE FAULT
968	11-Dec-21	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	10:32	12:33	2:00	LINE FAULT
969	11-Dec-21	TUMKUR	66	PAVAGADA 220kV- SHYLAPURA	SHYLAPURA_66	12:52	13:50	0:58	HAND TRIPPED
970	11-Dec-21	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	12:31	13:52	1:20	HAND TRIPPED
971	11-Dec-21	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	18:30	19:09	0:39	MAIN SUPPLY FAILURE
972	11-Dec-21	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	18:29	19:04	0:34	MAIN SUPPLY FAILURE
973	11-Dec-21	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	18:29	19:02	0:32	MAIN SUPPLY FAILURE
974	11-Dec-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WLSPNSOLAR1	12:50	12:59	0:08	LOAD CURTAILMENT
975	11-Dec-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WLSPNSOLAR2	12:50	12:59	0:08	LOAD CURTAILMENT
976	11-Dec-21	TUMKUR	66	TR-1	BHARAMAGIRI_66	8:48	8:52	0:04	TRANSFORMER FAULT
977	11-Dec-21	TUMKUR	66	TR-1	HANGAL_66	18:04	18:19	0:14	TRANSFORMER FAULT
978	11-Dec-21	TUMKUR	66	TR-1	MADADKERE_66	15:52	16:00	0:08	TRANSFORMER FAULT
979	11-Dec-21	TUMKUR	66	TR-1	NIDASALI_66	11:35	13:10	1:34	TRANSFORMER FAULT
980	11-Dec-21	TUMKUR	66	TR-1(LV-1)	PAVAGADA_220	12:39	13:50	1:11	HAND TRIPPED
981	11-Dec-21	TUMKUR	66	TR-2	NYAMATHI_66	10:53	13:29	2:35	LINE CLEAR AVAILED
982	11-Dec-21	TUMKUR	66	TR-2(LV-2)	PAVAGADA_220	12:39	13:49	1:10	HAND TRIPPED
983	11-Dec-21	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	11:04	11:21	0:17	LINE FAULT
984	11-Dec-21	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALI_110	11:04	11:35	0:31	LINE FAULT
985	11-Dec-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	12:00	13:41	1:41	LINE FAULT
986	11-Dec-21	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA 2	HOSKERE_66 MADHUGIRI_66,PAVAGADA_66	12:31	13:36	1:04	LINE CLEAR AVAILED
987	11-Dec-21	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI_220	12:31	13:36	1:04	LINE CLEAR AVAILED
988	11-Dec-21	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	12:30	13:47	1:16	LINE CLEAR AVAILED
989	11-Dec-21	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 2	PAVAGADA_220	12:31	13:47	1:15	LINE CLEAR AVAILED
990	11-Dec-21	TUMKUR	220	TR-3	HIRIYUR_220	0:46	1:03	0:17	TRANSFORMER FAULT
991	12-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	12:55	14:05	1:10	LINE CLEAR AVAILED
992	12-Dec-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	7:48	7:52	0:04	TRANSFORMER FAULT
993	12-Dec-21	BAGALKOT	110	110/33KV, HV3	MUNAVALLY_110	2:49	10:19	7:30	TRANSFORMER FAULT
994	12-Dec-21	BAGALKOT	110	ATHANI220-BALIGERI110	BALIGERI(TAUSHI)_110	10:12	16:56	6:44	NFBC ISSUED
995	12-Dec-21	BAGALKOT	110	ATHANI220-BALIGERI110	BALIGERI(TAUSHI)_110	10:12	16:56	6:44	NFBC ISSUED
996	12-Dec-21	BAGALKOT	110	BELLATTI- AB SOLAR	BELLATTI_110	16:05	16:49	0:44	HAND TRIPPED
997	12-Dec-21	BAGALKOT	110	BELLATTI- ENERCON2	BELLATTI_110	16:05	17:04	0:59	HAND TRIPPED
998	12-Dec-21	BAGALKOT	110	BIDNAL- NARGUND	NARAGUND_110	1:00	1:50	0:50	MAIN SUPPLY FAILURE
999	12-Dec-21	BAGALKOT	110	BIDNAL- NARGUND	NARAGUND_110	1:00	1:50	0:50	MAIN SUPPLY FAILURE
1000	12-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1001	12-Dec-21	BAGALKOT	110	HUKKERI- VISHWANATH SUGARS	HUKKERI_110	6:54	7:24	0:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1002	12-Dec-21	BAGALKOT	110	KIADB BIJAPUR- BAGEWADI(JUMNAL)	KIADB BIJAPUR_110	17:49	17:53	0:04	HAND TRIPPED
1003	12-Dec-21	BAGALKOT	110	KULGERI CROSS- KERUR	KULGERI CROSS_110	10:45	11:12	0:27	HAND TRIPPED
1004	12-Dec-21	BAGALKOT	110	LAXMESHWAR- GADAG1	LAXMESHWAR_110	16:53	17:00	0:07	HAND TRIPPED
1005	12-Dec-21	BAGALKOT	110	MANTUR-SHIROL	MANTUR(B)_110	6:40	6:55	0:15	LINE FAULT
1006	12-Dec-21	BAGALKOT	110	MANTUR-SHIROL	MANTUR(B)_110	6:40	6:55	0:15	LINE FAULT
1007	12-Dec-21	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	6:40	6:55	0:15	MAIN SUPPLY FAILURE
1008	12-Dec-21	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	6:40	6:55	0:15	MAIN SUPPLY FAILURE
1009	12-Dec-21	BAGALKOT	110	MANTUR-VAJRAMATTI	MANTUR(B)_110	6:40	6:50	0:10	LINE FAULT
1010	12-Dec-21	BAGALKOT	110	MANTUR-VAJRAMATTI	MANTUR(B)_110	6:40	6:50	0:10	LINE FAULT
1011	12-Dec-21	BAGALKOT	110	SHIRAHATTI- LAXMESHWAR	SHIRAHATTI_110	15:58	16:47	0:49	HAND TRIPPED
1012	12-Dec-21	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	21:19	21:24	0:05	LINE FAULT
1013	12-Dec-21	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN:LINE FAULT
1014	12-Dec-21	BAGALKOT	220	220/110KV, HV1&LV1	MKHUBLI_220	8:14	17:59	9:45	LINE CLEAR AVAIED
1015	12-Dec-21	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1016	12-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAIED
1017	12-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAIED
1018	12-Dec-21	BAGALKOT	220	CHIKKODI- GHATAPRABHA2 (KUDACHI2)	CHIKKODI_220	17:19	17:37	0:18	LINE FAULT
1019	12-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAIED
1020	12-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
1021	12-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1022	12-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1023	12-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1024	12-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:46 (09.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1025	12-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1026	12-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
1027	12-Dec-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	9:17	9:19	0:02	LOAD CHANGE OVER
1028	12-Dec-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	6:52	6:54	0:02	LOAD CHANGE OVER
1029	12-Dec-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	17:39	17:46	0:07	LOAD CHANGE OVER
1030	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	14:52	15:26	0:34	MAIN SUPPLY FAILURE
1031	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	14:52	15:26	0:34	MAIN SUPPLY FAILURE
1032	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	14:52	15:30	0:38	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1033	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	14:52	15:31	0:39	MAIN SUPPLY FAILURE
1034	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	14:52	15:26	0:34	MAIN SUPPLY FAILURE
1035	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	14:52	15:30	0:38	MAIN SUPPLY FAILURE
1036	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	14:52	15:30	0:38	MAIN SUPPLY FAILURE
1037	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:52	15:29	0:37	MAIN SUPPLY FAILURE
1038	12-Dec-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS	14:52	15:29	0:37	MAIN SUPPLY FAILURE
1039	12-Dec-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	2:59	3:10	0:10	LINE FAULT
1040	12-Dec-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	4:03	4:16	0:13	LINE FAULT
1041	12-Dec-21	BENGALURU	66	HV1	BANASAWADI	9:45	9:48	0:03	LOAD CHANGE OVER
1042	12-Dec-21	BENGALURU	66	HV1	BANASAWADI	11:11	11:26	0:15	LOAD CHANGE OVER
1043	12-Dec-21	BENGALURU	66	HV1	KOLAR 220	14:54	15:29	0:35	MAIN SUPPLY FAILURE
1044	12-Dec-21	BENGALURU	66	HV1	SARJAPURA 220	14:54	15:29	0:34	MAIN SUPPLY FAILURE
1045	12-Dec-21	BENGALURU	66	HV1	SRIGANDAKAVALU	10:11	10:13	0:02	LINE CLEAR AVAIED
1046	12-Dec-21	BENGALURU	66	HV2	KOLAR 220	14:54	15:29	0:35	MAIN SUPPLY FAILURE
1047	12-Dec-21	BENGALURU	66	HV2	SARJAPURA 220	14:54	15:29	0:35	MAIN SUPPLY FAILURE
1048	12-Dec-21	BENGALURU	66	HV2	SRIGANDAKAVALU	12:58	13:05	0:07	LINE CLEAR AVAIED
1049	12-Dec-21	BENGALURU	66	HV3	BANASAWADI	16:22	16:24	0:02	LOAD CHANGE OVER
1050	12-Dec-21	BENGALURU	66	HV3	YARANDANAHALLI 220	11:06	11:51	0:45	LINE CLEAR AVAIED
1051	12-Dec-21	BENGALURU	66	IISc - HEBBALA 220	IISc	6:21	6:28	0:07	LOAD CHANGE OVER
1052	12-Dec-21	BENGALURU	66	IISc - NRS 220	IISc	17:45	17:48	0:03	LOAD CHANGE OVER
1053	12-Dec-21	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	14:08	14:20	0:12	LOAD CHANGE OVER
1054	12-Dec-21	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	13:03	13:06	0:03	LOAD CHANGE OVER
1055	12-Dec-21	BENGALURU	66	KOLAR 220 - BANGARPET	BANGARPET	14:54	15:30	0:36	MAIN SUPPLY FAILURE
1056	12-Dec-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	14:54	15:31	0:37	MAIN SUPPLY FAILURE
1057	12-Dec-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	14:54	15:30	0:36	MAIN SUPPLY FAILURE
1058	12-Dec-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:04	15:28	1:24	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1059	12-Dec-21	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALANUR	14:54	15:29	0:35	MAIN SUPPLY FAILURE
1060	12-Dec-21	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	14:54	15:30	0:36	MAIN SUPPLY FAILURE
1061	12-Dec-21	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	14:54	15:29	0:35	MAIN SUPPLY FAILURE
1062	12-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
1063	12-Dec-21	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	16:20	16:23	0:03	LOAD CHANGE OVER
1064	12-Dec-21	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	14:58	15:03	0:05	LOAD CHANGE OVER
1065	12-Dec-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:52	15:31	0:39	MAIN SUPPLY FAILURE
1066	12-Dec-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	14:52	15:31	0:38	MAIN SUPPLY FAILURE
1067	12-Dec-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, THORALAKKI	14:52	15:30	0:38	MAIN SUPPLY FAILURE
1068	12-Dec-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	14:52	15:30	0:38	MAIN SUPPLY FAILURE
1069	12-Dec-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:52	15:31	0:38	MAIN SUPPLY FAILURE
1070	12-Dec-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:52	15:30	0:37	MAIN SUPPLY FAILURE
1071	12-Dec-21	BENGALURU	66	SARIJAPURA 220 - ATTIBELE	ATTIBELE	14:54	15:32	0:37	MAIN SUPPLY FAILURE
1072	12-Dec-21	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	14:54	15:38	0:44	MAIN SUPPLY FAILURE
1073	12-Dec-21	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:54	15:30	0:36	MAIN SUPPLY FAILURE
1074	12-Dec-21	BENGALURU	66	SUBRAMANYAPURA 220 - PADMANABHANAGARA	NO STATION AFFECTED	2:40	15:28	12:48	LINE FAULT
1075	12-Dec-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	14:51	15:30	0:39	MAIN SUPPLY FAILURE
1076	12-Dec-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	14:51	15:30	0:39	MAIN SUPPLY FAILURE
1077	12-Dec-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:51	15:30	0:39	MAIN SUPPLY FAILURE
1078	12-Dec-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:51	15:30	0:39	MAIN SUPPLY FAILURE
1079	12-Dec-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	15:28	15:39	0:11	LINE FAULT
1080	12-Dec-21	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	14:52	15:22	0:30	MAIN SUPPLY FAILURE
1081	12-Dec-21	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	14:52	15:22	0:30	MAIN SUPPLY FAILURE
1082	12-Dec-21	BENGALURU	220	HV1	MALUR 220	14:52	15:28	0:36	MAIN SUPPLY FAILURE
1083	12-Dec-21	BENGALURU	220	HV2	MALUR 220	14:52	15:29	0:36	MAIN SUPPLY FAILURE
1084	12-Dec-21	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	14:52	15:26	0:34	MAIN SUPPLY FAILURE
1085	12-Dec-21	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	14:35	14:45	0:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1086	12-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1087	12-Dec-21	GULBARGA	66	ITTAGI-RENEW SOLAR_IPP	ITTAGI_220	22:14 (11.12.2021)	1:19 (12.12.2021)	3:05 HRS	LINE CHARGED
1088	12-Dec-21	GULBARGA	110	ADAVIAMERESHWAR-MALLAT	ADAVIAMERESHWAR_110	2:27	2:33	0:06	MAIN SUPPLY FAILURE
1089	12-Dec-21	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	20:39	21:39	1:00	LINE FAULT
1090	12-Dec-21	GULBARGA	110	GULBARGAUNIVERSITY-SHAHABAD	GULBARGAUNIVERSITY_110	20:40	20:50	0:10	MAIN SUPPLY FAILURE
1091	12-Dec-21	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	8:00(9.12.2021)	21:02(12.12.2021)	85:02HRS	LINE CHARGED
1092	12-Dec-21	GULBARGA	110	GULBARGAWEST-KAPNOOR	GULBARGAWEST_110	14:11	14:13	0:02	MAIN SUPPLY FAILURE
1093	12-Dec-21	GULBARGA	110	GULBARGAWEST-KAPNOOR	GULBARGAWEST_110	15:29	15:36	0:07	MAIN SUPPLY FAILURE
1094	12-Dec-21	GULBARGA	110	HV1	NIRNA_110	13:30	13:35	0:05	TRANSFORMER FAULT
1095	12-Dec-21	GULBARGA	110	HV2	DEODURGA_110	9:40	9:50	0:10	TRANSFORMER FAULT
1096	12-Dec-21	GULBARGA	110	HV2	DEODURGA_110	14:50	15:00	0:10	TRANSFORMER FAULT
1097	12-Dec-21	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	6:10	6:25	0:15	MAIN SUPPLY FAILURE
1098	12-Dec-21	GULBARGA	110	KAPNOOR220-KAPNOOR110	KAPNOOR_110	15:58	16:06	0:08	LINE FAULT
1099	12-Dec-21	GULBARGA	110	KAPNOOR-GULBARGANORTH1,2	GULBARGA NORTH_110,GULBARGA SOUTH_110,GULBARGA UNIVERSITY_110	15:48	15:51	0:03	LINE FAULT
1100	12-Dec-21	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGA WEST_110,GULBARGA SOUTH_110	14:11	14:13	0:02	LINE FAULT
1101	12-Dec-21	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGA WEST_110,GULBARGA SOUTH_110	15:29	15:35	0:06	LINE FAULT
1102	12-Dec-21	GULBARGA	110	KUSTAGI-TAWARGERE	TAWARGERE_110	6:20	6:33	0:13	LINE FAULT
1103	12-Dec-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	1:20	1:40	0:20	LINE FAULT
1104	12-Dec-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	19:10	19:23	0:13	LINE FAULT
1105	12-Dec-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HWAR_110	2:20	2:35	0:15	LINE FAULT
1106	12-Dec-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	17:55	18:05	0:10	LINE FAULT
1107	12-Dec-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	20:38	21:53	1:15	MAIN SUPPLY FAILURE
1108	12-Dec-21	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	20:38	20:48	0:10	MAIN SUPPLY FAILURE
1109	12-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:25	19:30	0:05	LINE FAULT
1110	12-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1111	12-Dec-21	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	6:15	6:25	0:10	LINE FAULT
1112	12-Dec-21	GULBARGA	110	YEDRAMI-SHAHABAD	YEDRAMI_110	20:40	21:35	0:55	LINE FAULT
1113	12-Dec-21	GULBARGA	110	YERADONA-BENNUR	BENNUR_110	0:35	0:40	0:05	LINE FAULT
1114	12-Dec-21	GULBARGA	220	HV1	NEELGUNDA_220	10:35	18:15	7:40	LINE CLEAR AVAILED
1115	12-Dec-21	GULBARGA	220	HV1	SHAHABAD_220	20:40	22:20	1:40	TRANSFORMER FAULT
1116	12-Dec-21	GULBARGA	220	HV1,LV1	KAPNOOR_220	2:28	3:05	0:37	TRANSFORMER FAULT
1117	12-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1118	12-Dec-21	GULBARGA	220	HV2	SHAHABAD_220	20:40	21:35	0:55	TRANSFORMER FAULT
1119	12-Dec-21	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	2:28	3:08	0:40	LINE FAULT
1120	12-Dec-21	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	2:31	10:01	7:30	LINE FAULT
1121	12-Dec-21	GULBARGA	220	SHAHABAD-KAPNOOR	SHAHABAD_220	20:40	21:55	1:15	LINE FAULT
1122	12-Dec-21	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	20:40	21:30	0:50	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1123	12-Dec-21	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	2:30	3:06	0:36	LINE FAULT
1124	12-Dec-21	HASSAN	110	HV1	HIRIYADKA_110	9:50	16:46	6:56	LINE CLEAR AVAILED
1125	12-Dec-21	HASSAN	110	HV3	BAIKAMPADI_110	10:00	17:25	7:25	LINE CLEAR AVAILED
1126	12-Dec-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	19:25 (11.12.2021)	13:56 (12.12.2021)	18:33 hrs	LINE CHARGED
1127	12-Dec-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	18:28 (11.12.2021)			LINE OPEN:LINE FAULT
1128	12-Dec-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	19:54(11.12.2021)	13:55(12.12.2021)	18:04 hrs	LINE CHARGED
1129	12-Dec-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:28 (11.12.2021)			LINE OPEN:LINE FAULT
1130	12-Dec-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1131	12-Dec-21	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1132	12-Dec-21	MYSURU	66	HEBBANI-VADKEPURA	VADKEPURA_66	6:34	6:47	0:13	LINE FAULT
1133	12-Dec-21	MYSURU	66	KR PETE 220-MADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 MADESHWARAPURA_66 JAKANAHALLI_66	6:19	6:33	0:14	LINE FAULT
1134	12-Dec-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30(24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1135	12-Dec-21	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	15:09	16:07	0:58	LINE FAULT
1136	12-Dec-21	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	9:58	10:06	0:08	LINE FAULT
1137	12-Dec-21	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	16:40	16:52	0:12	LINE FAULT
1138	12-Dec-21	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	20:56	21:04	0:08	LINE FAULT
1139	12-Dec-21	MYSURU	66	YEREHALLI HAND POST-HD KOTE	HD KOTE_66 ANTARASANTE_66	9:35	9:45	0:10	LINE FAULT
1140	12-Dec-21	MYSURU	66	YEREHALLI HAND POST-HD KOTE	HD KOTE_66 ANTARASANTE_66	11:20	11:40	0:20	LINE FAULT
1141	12-Dec-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	17:37:49 (11.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1142	12-Dec-21	TUMKUR	66	ANCHEPALYA 220KV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	9:51	15:13	5:21	LINE CLEAR AVAILED
1143	12-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:23	17:11	6:47	LINE CLEAR AVAILED
1144	12-Dec-21	TUMKUR	66	BHARAMAGIRI-HIRIYUR220	BHARAMAGIRI_66	7:19	16:05	8:45	LINE CLEAR AVAILED
1145	12-Dec-21	TUMKUR	66	BRAHMASANDRA- THOVINKERE	THOVINAKERE_66, KORA_66	10:09	17:44	7:35	LINE CLEAR AVAILED
1146	12-Dec-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	6:37	6:48	0:11	LINE FAULT
1147	12-Dec-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	6:26	6:32	0:06	LINE FAULT
1148	12-Dec-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:32	9:35	0:03	LINE FAULT
1149	12-Dec-21	TUMKUR	66	HOSADURRG-MATHOD	HOSADURGA_66	13:32	16:53	3:20	MAIN SUPPLY FAILURE
1150	12-Dec-21	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	9:50	16:53	7:02	NFBC ISSUED
1151	12-Dec-21	TUMKUR	66	KORA- ANTHRASANAHALLI	KADEHALLI_110	10:02	17:19	7:16	LINE CLEAR AVAILED
1152	12-Dec-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	10:02	17:19	7:16	LINE CLEAR AVAILED
1153	12-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	19:57	20:08	0:11	LINE FAULT
1154	12-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	20:56	21:02	0:05	LINE FAULT
1155	12-Dec-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	22:17	22:29	0:12	LINE FAULT
1156	12-Dec-21	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	7:32	7:49	0:17	LINE FAULT
1157	12-Dec-21	TUMKUR	66	TAVAREKERE (H)- I/CHIRIYUR	TAVAREKERE(H)_66	9:27	9:49	0:22	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1158	12-Dec-21	TUMKUR	66	TR-1	KORA_66	10:02	17:19	7:16	LINE CLEAR AVAIED
1159	12-Dec-21	TUMKUR	66	TR-1	MADADKERE_66	16:13	16:22	0:08	TRANSFORMER FAULT
1160	12-Dec-21	TUMKUR	66	TR-1	PKOTE_66	13:12	13:22	0:10	TRANSFORMER FAULT
1161	12-Dec-21	TUMKUR	66	TR-2	HOSAKERE_66	9:26	9:59	0:33	LINE CLEAR AVAIED
1162	12-Dec-21	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	6:36	10:50	4:14	TRANSFORMER FAULT
1163	12-Dec-21	TUMKUR	66	TR-2	KORA_66	10:02	17:19	7:16	LINE CLEAR AVAIED
1164	12-Dec-21	TUMKUR	66	TR-2	MADADKERE_66	16:13	16:22	0:08	TRANSFORMER FAULT
1165	12-Dec-21	TUMKUR	66	TR-2	PKOTE_66	6:02	12:42	6:40	TRANSFORMER FAULT
1166	12-Dec-21	TUMKUR	110	TR-2	NITTUR_220	13:18	13:38	0:19	LINE CLEAR AVAIED
1167	12-Dec-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	2:07	6:44	4:36	LOAD CURTAILMENT
1168	13-Dec-21	BAGALKOT	110	110/11KV,HV 2	ALMEL_110	13:03	18:05	5:02	LINE CLEAR AVAIED
1169	13-Dec-21	BAGALKOT	110	110/11KV,HV 2	DEVANGOAN_110	12:29	15:42	3:13	LINE CLEAR AVAIED
1170	13-Dec-21	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:49 (13.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
1171	13-Dec-21	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1172	13-Dec-21	BAGALKOT	110	BADAMI(IDLE)-HIREHAL	HIREHAL_110	11:00 (13.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1173	13-Dec-21	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	4:06	5:16	1:10	LINE FAULT
1174	13-Dec-21	BAGALKOT	110	GHATAPRABHA-GOKAK	GHATAPRABHA_220	5:51	6:01	0:10	LINE FAULT
1175	13-Dec-21	BAGALKOT	110	GHATAPRABHA-KABBUR	GHATAPRABHA_220	7:13	7:22	0:09	LINE FAULT
1176	13-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAIED
1177	13-Dec-21	BAGALKOT	110	HAVERI-BYADAGI	HAVERI_220	11:43	11:55	0:12	HAND TRIPPED
1178	13-Dec-21	BAGALKOT	110	HIREHAL-MAYFAIR SOLAR	HIREHAL_110	10:46	11:00	0:14	HAND TRIPPED
1179	13-Dec-21	BAGALKOT	110	HUBLI-PH COMPOUND	HUBLI_20	10:20	14:06	3:46	LINE CLEAR AVAIED
1180	13-Dec-21	BAGALKOT	110	ITNAL-HIDIKAL	ITNAL_110	11:57	13:03	1:06	LINE CLEAR AVAIED
1181	13-Dec-21	BAGALKOT	110	KUMTA-SIRSI 1(KRCL)	KUMTA_110	14:20	14:37	0:17	LINE FAULT
1182	13-Dec-21	BAGALKOT	110	RATTIHALLI-TUMMINKATTI	TUMMINKATTI_110	13:14	16:29	3:15	LINE FAULT
1183	13-Dec-21	BAGALKOT	110	RON-HIREHAL	RON_110	10:46	10:54	0:08	HAND TRIPPED
1184	13-Dec-21	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1185	13-Dec-21	BAGALKOT	110	TUMMINKATTI-RATTIHALLI	RATTIHALLI_110	13:10	13:36	0:26	LINE CLEAR AVAIED
1186	13-Dec-21	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN:LINE FAULT
1187	13-Dec-21	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1188	13-Dec-21	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	13:51	14:22	0:31	LINE CLEAR AVAIED
1189	13-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAIED
1190	13-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAIED
1191	13-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAIED
1192	13-Dec-21	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1193	13-Dec-21	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN:LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1194	13-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1195	13-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1196	13-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:46 (09.12.2021)	19:06 (13.12.2021)	104:20 hrs	LINE CHARGED
1197	13-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:46 (09.12.2021)	19:06 (13.12.2021)	104:20 hrs	LINE CHARGED
1198	13-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1199	13-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1200	13-Dec-21	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	10:47	10:56	0:08	LOAD CHANGE OVER
1201	13-Dec-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:47	10:56	0:08	LOAD CHANGE OVER
1202	13-Dec-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, D CROSS	21:17	21:49	0:32	LINE CLEAR AVAILED
1203	13-Dec-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:58	11:15	0:16	LINE CLEAR AVAILED
1204	13-Dec-21	BENGALURU	66	GANJIGUNTE - DIBURALLI	DIBURALLI	9:59	17:47	7:48	LINE CLEAR AVAILED
1205	13-Dec-21	BENGALURU	66	HV1	CHIKKABALLAPURA URBAN	13:21	13:25	0:04	LINE CLEAR AVAILED
1206	13-Dec-21	BENGALURU	66	HV1	DODDABELAVANGALA	10:51	11:15	0:24	LINE CLEAR AVAILED
1207	13-Dec-21	BENGALURU	66	HV1	PALLICHERLU	16:35	16:40	0:04	LINE CLEAR AVAILED
1208	13-Dec-21	BENGALURU	66	HV2	CESSNA	10:48	11:00	0:12	LINE CLEAR AVAILED
1209	13-Dec-21	BENGALURU	66	HV2	KHODAYS 220	10:59	11:01	0:02	LINE CLEAR AVAILED
1210	13-Dec-21	BENGALURU	66	HV3	NELAMANGALA 66	17:24	17:35	0:11	TRANSFORMER FAULT
1211	13-Dec-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	12:19	13:31	1:12	LINE CLEAR AVAILED
1212	13-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
1213	13-Dec-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	12:19	12:22	0:03	LOAD CHANGE OVER
1214	13-Dec-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	13:06	13:17	0:11	LOAD CHANGE OVER
1215	13-Dec-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	7:33	7:42	0:09	LINE FAULT
1216	13-Dec-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	7:33	7:42	0:09	LINE FAULT
1217	13-Dec-21	BENGALURU	66	MANYATHA 220 - HOSKOTE 2	SHOBHA CITY	18:35	18:50	0:15	LINE CLEAR AVAILED
1218	13-Dec-21	BENGALURU	66	SADLI - CHINTAMANI 220	SADLI	10:00	10:15	0:15	LOAD CHANGE OVER
1219	13-Dec-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	5:08	5:15	0:07	LINE FAULT
1220	13-Dec-21	BENGALURU	66	VIJAYPURA - MELUR	VIJAYAPURA, JANGAMAKOTE	12:15	12:21	0:06	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1221	13-Dec-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	NO STATION AFFECTED	14:01	18:25	4:24	LINE FAULT
1222	13-Dec-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	7:22	7:26	0:04	LOAD CHANGE OVER
1223	13-Dec-21	BENGALURU	220	KOTIPURA 220 - BIDADI 220	KOTIPURA 220	13:06	13:17	0:11	LOAD CHANGE OVER
1224	13-Dec-21	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	KOTIPURA 220	12:19	12:22	0:03	LOAD CHANGE OVER
1225	13-Dec-21	GULBARGA	66	HV1	BENNEHALLI_66	13:25	13:30	0:05	LINE CLEAR AVAIED
1226	13-Dec-21	GULBARGA	66	HV1	KUDLIGI_220	16:55	17:05	0:10	LINE CLEAR AVAIED
1227	13-Dec-21	GULBARGA	66	HV2	BENNEHALLI_66	13:25	13:30	0:05	LINE CLEAR AVAIED
1228	13-Dec-21	GULBARGA	66	HV2	HALVAGALU_66	12:30	12:35	0:05	TRANSFORMER FAULT
1229	13-Dec-21	GULBARGA	66	HV2	TAMBRAHALI_66	11:50	11:55	0:05	LINE CLEAR AVAIED
1230	13-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1231	13-Dec-21	GULBARGA	110	ADAVIAMERESHWAR-MALLAT	ADAVIAMERESHWAR_110	1:50	1:58	0:08	MAIN SUPPLY FAILURE
1232	13-Dec-21	GULBARGA	110	BISIHALLI-BELLARYNORTH	BISIHALLI_110	13:17	13:22	0:05	MAIN SUPPLY FAILURE
1233	13-Dec-21	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	1:35	1:45	0:10	MAIN SUPPLY FAILURE
1234	13-Dec-21	GULBARGA	110	CHINCHOLI-RENEW WIND IPP	CHINCHOLI_110	10:00	10:15	0:15	LINE FAULT
1235	13-Dec-21	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	2:05	2:10	0:05	LINE FAULT
1236	13-Dec-21	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	19:25	19:35	0:10	MAIN SUPPLY FAILURE
1237	13-Dec-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:15	4:50	0:35	MAIN SUPPLY FAILURE
1238	13-Dec-21	GULBARGA	110	HV1	MATAMARI_110	8:45	8:50	0:05	TRANSFORMER FAULT
1239	13-Dec-21	GULBARGA	110	HV1	VALKAMDINI_110	7:55	8:00	0:05	TRANSFORMER FAULT
1240	13-Dec-21	GULBARGA	110	HV2	MADALAPUR_110	2:35	2:45	0:10	TRANSFORMER FAULT
1241	13-Dec-21	GULBARGA	110	HV2	MADALAPUR_110	6:09	6:16	0:07	TRANSFORMER FAULT
1242	13-Dec-21	GULBARGA	110	HV2	NIRNA_110	17:25	17:30	0:05	TRANSFORMER FAULT
1243	13-Dec-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	12:15	13:49	1:34	LINE CLEAR AVAIED
1244	13-Dec-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1245	13-Dec-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	1:35	1:46	0:11	LINE FAULT
1246	13-Dec-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HWAR_110	2:00	2:05	0:05	LINE FAULT
1247	13-Dec-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARES HWAR_110	17:08	17:15	0:07	LINE CLEAR AVAIED
1248	13-Dec-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDI CROSS_110,MANVI_110,MADLAPUR_110	15:28 (13.12.2021)			LINE OPEN:LINE FAULT
1249	13-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAIED
1250	13-Dec-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADONA_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	6:29	6:39	0:10	LINE FAULT
1251	13-Dec-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	16:15	17:43	1:28	LINE CLEAR AVAIED
1252	13-Dec-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	6:25	6:40	0:15	MAIN SUPPLY FAILURE
1253	13-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	21:48 (13.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1254	13-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	3:20	7:00	3:40	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1255	13-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1256	13-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (13.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1257	13-Dec-21	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA_66	10:26	16:13	5:47	LINE CLEAR AVAILED
1258	13-Dec-21	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	13:42	13:48	0:06	HAND TRIPPED
1259	13-Dec-21	HASSAN	66	HV1	DUDDA_66	16:00	16:31	0:31	LINE CLEAR AVAILED
1260	13-Dec-21	HASSAN	66	HV1	RAMESHWARNAGARA_66	13:07	16:27	3:20	LINE CLEAR AVAILED
1261	13-Dec-21	HASSAN	66	HV2	DIDIGA_66	13:43	13:45	0:02	LINE CLEAR AVAILED
1262	13-Dec-21	HASSAN	66	HV2	HALLYMYSORE_66	16:02	16:56	0:54	TRANSFORMER FAULT
1263	13-Dec-21	HASSAN	66	HV2	RAMESHWARNAGARA_66	10:10	17:19	7:09	LINE CLEAR AVAILED
1264	13-Dec-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:26	12:57	2:31	NFBC ISSUED
1265	13-Dec-21	HASSAN	110	HV1	KONAJE_110	17:45	17:52	0:07	HAND TRIPPED
1266	13-Dec-21	HASSAN	110	HV1	VITLA_110	12:26	13:57	1:31	LINE CLEAR AVAILED
1267	13-Dec-21	HASSAN	110	HV2	KONAJE_110	17:45	17:52	0:07	HAND TRIPPED
1268	13-Dec-21	HASSAN	110	HV2	SHIRALKOPPA_110	11:36	12:30	0:54	LINE CLEAR AVAILED
1269	13-Dec-21	HASSAN	110	HV2	VITLA_110	10:38	12:25	1:47	LINE CLEAR AVAILED
1270	13-Dec-21	HASSAN	110	HV2	VITLA_110	14:30	15:19	0:49	LINE CLEAR AVAILED
1271	13-Dec-21	HASSAN	110	HV3	KONAJE_110	17:45	17:52	0:07	HAND TRIPPED
1272	13-Dec-21	HASSAN	110	KADUR-NGNHL	KADUR_220	11:52	12:16	0:24	LINE CLEAR AVAILED
1273	13-Dec-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:26	12:57	2:31	LINE CLEAR AVAILED
1274	13-Dec-21	HASSAN	110	LV1	PUTTUR_220	17:09(13.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1275	13-Dec-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	18:28 (11.12.2021)			LINE OPEN:LINE FAULT
1276	13-Dec-21	HASSAN	220	HASSN22-SHANTHIGRAM	HASSAN_220	10:28	14:21	3:53	LINE CLEAR AVAILED
1277	13-Dec-21	HASSAN	220	HV1	PUTTUR_220	17:09(13.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1278	13-Dec-21	HASSAN	220	KEMAR-VARAH12	KEMAR_220	13:59	14:09	0:10	LINE FAULT
1279	13-Dec-21	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	12:27	13:44	1:17	LINE CLEAR AVAILED
1280	13-Dec-21	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	12:27	13:45	1:18	LINE CLEAR AVAILED
1281	13-Dec-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:28 (11.12.2021)			LINE OPEN:LINE FAULT
1282	13-Dec-21	HASSAN	220	VARAH1-KEMAR2	varahi_gen	13:59	14:09	0:10	LINE FAULT
1283	13-Dec-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	12:16	13:52	1:36	NFBC ISSUED
1284	13-Dec-21	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	12:16	13:45	1:29	NFBC ISSUED
1285	13-Dec-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:37(13.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1286	13-Dec-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1287	13-Dec-21	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1288	13-Dec-21	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	9:40	11:20	1:40	LINE FAULT
1289	13-Dec-21	MYSURU	66	HV1	JAKKANAHALLY_66	17:43	17:56	0:13	TRANSFORMER FAULT
1290	13-Dec-21	MYSURU	66	HV1	MADDUR_66	21:30	23:53	2:22	LINE CLEAR AVAILED
1291	13-Dec-21	MYSURU	66	HV1	SRIRANGAPATNA_66	9:59	18:10	8:10	LINE CLEAR AVAILED
1292	13-Dec-21	MYSURU	66	JAKKANAHALLI-TUBINKERE	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLY_66	14:40	14:50	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1293	13-Dec-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLY_66 MADESWARAPURA_66	5:55	6:13	0:17	LINE FAULT
1294	13-Dec-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLY_66MADESWARAPURA_66	6:19	6:23	0:04	LINE FAULT
1295	13-Dec-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	14:44	18:22	3:37	LINE CLEAR AVAIED
1296	13-Dec-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAIED
1297	13-Dec-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	4:37	4:44	0:07	LINE FAULT
1298	13-Dec-21	MYSURU	66	MAHADESHWARAPURA-KR PETE	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLY_66MADESWARAPURA_66	13:40	13:45	0:05	HAND TRIPPED
1299	13-Dec-21	MYSURU	66	SFC SIVA-ATRIA	NO STATIONS EFFECTED	7:35	8:15	0:40	LINE CLEAR AVAIED
1300	13-Dec-21	MYSURU	66	TUBINKERE-MANDYA 2	NO STATIONS EFFECTED	9:24	9:29	0:05	LINE FAULT
1301	13-Dec-21	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	12:04	12:13	0:09	LINE FAULT
1302	13-Dec-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	17:37:49 (11.12.2021)	17:49:02 (13.12.2021)	48:11 hrs	LINE CHARGED
1303	13-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	14:06	14:16	0:10	LINE FAULT
1304	13-Dec-21	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	2:46	6:35	3:49	LINE CLEAR AVAIED
1305	13-Dec-21	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	11:05	12:02	0:56	LINE CLEAR AVAIED
1306	13-Dec-21	TUMKUR	66	TR-1	PD KOTE_66	8:26	8:30	0:04	HAND TRIPPED
1307	13-Dec-21	TUMKUR	66	TR-1	PD KOTE_66	8:27	8:30	0:03	HAND TRIPPED
1308	13-Dec-21	TUMKUR	66	TR-2	JAVAGONDANAHALLY_66	11:34	15:07	3:33	LINE CLEAR AVAIED
1309	13-Dec-21	TUMKUR	66	TR-2	KADAJJI_66	11:08	11:16	0:07	TRANSFORMER FAULT
1310	13-Dec-21	TUMKUR	66	TR-2	SIRA_66	6:26	6:42	0:16	TRANSFORMER FAULT
1311	13-Dec-21	TUMKUR	110	BANDIHALLI 110- KB CROSS	BANDIHALLI_110	14:18	14:35	0:16	LINE CLEAR AVAIED
1312	13-Dec-21	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110,HALKURKE_110,HUNSEGHATTA_110,KEREKODI_110	14:24	14:36	0:12	LINE CLEAR AVAIED
1313	13-Dec-21	TUMKUR	110	TR-1	BANDIHALLI_110	14:18	14:29	0:10	LINE CLEAR AVAIED
1314	13-Dec-21	TUMKUR	110	TR-1	TIMMANAHALLY_110	14:28	18:57	4:28	LINE CLEAR AVAIED
1315	13-Dec-21	TUMKUR	220	DAVANGERE SRS- CHITRADURGA	CHITRADURGA_220	6:23	6:36	0:13	LINE FAULT
1316	13-Dec-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	5:30	13:02	7:31	LINE FAULT
1317	13-Dec-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS11	DAVANGERE_SRS_220	5:30	13:02	7:32	LINE FAULT
1318	13-Dec-21	TUMKUR	220	JAGALUR_400-ICT 2	JAGLUR_400	11:15	16:02	4:46	LINE CLEAR AVAIED
1319	13-Dec-21	TUMKUR	400	JAGALUR_400-ICT 2	JAGLUR_400	11:42	16:07	4:24	LINE CLEAR AVAIED