

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM :08.06.2021 TO 14.6.2021

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
1	8/Jun/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT
2	8/Jun/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVALIED
3	8/Jun/2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
4	8/Jun/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVALIED
5	8/Jun/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVALIED
6	8/Jun/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
7	8/Jun/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
8	8/Jun/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVALIED
9	8/Jun/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVALIED
10	8/Jun/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17(15.05.2021)	10:50 (08.06.2021)	571:33HRS	LINE CHARGED
11	8/Jun/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17(15.05.2021)	10:52 (08.06.2021)	571:35HRS	LINE CHARGED
12	8/Jun/2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVALIED
13	8/Jun/2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	8:14 (07.06.2021)			LINE OPEN, LINE CLEAR AVALIED
14	8/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	12:59	16:38	3:39	LINE CLEAR AVALIED
15	8/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	16:44	17:16	0:32	TRANSFORMER FAULT
16	8/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:17	18:08	0:51	TRANSFORMER FAULT
17	8/Jun/2021	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	16:31	17:18	0:47	LINE CLEAR AVALIED
18	8/Jun/2021	BAGALKOT	110	BIJKDB-B .BAGEWADI2(INCOMER 2)	STATION NOT AFFECTED KIADB BIJAPUR_110	11:31	11:45	0:14	LINE FAULT
19	8/Jun/2021	BAGALKOT	110	BIJKDB-BHUTANAL	BHUTANAL_110	11:32	12:21	0:49	LINE FAULT
20	8/Jun/2021	BAGALKOT	220	220/110KV, HV4	GADAG_220	8:57	13:25	4:28	LINE CLEAR AVALIED
21	8/Jun/2021	BAGALKOT	110	110/11KV, HV4	HIDIKAL_110, ALAGAWADI_33	15:07	15:28	0:21	HAND TRIPPED
22	8/Jun/2021	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	13:53	14:00	0:07	TRANSFORMER FAULT
23	8/Jun/2021	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	14:04	14:13	0:09	TRANSFORMER FAULT
24	8/Jun/2021	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	19:58 (08.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
25	8/Jun/2021	BAGALKOT	110	NALAVAGUND- KONNUR	NAVALAGUND_110	11:52	12:32	0:40	LINE CLEAR AVALIED
26	8/Jun/2021	BAGALKOT	110	SHIRAHATTI- BPCL2	SHIRAHATTI_110	9:31	9:33	0:02	HAND TRIPPED
27	8/Jun/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:11(08.06.2021)			LINE OPEN, LINE CLEAR AVALIED
28	8/Jun/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:11(08.06.2021)			LINE OPEN, LINE CLEAR AVALIED
29	8/Jun/2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	11:02	14:11	3:09	LINE CLEAR AVALIED
30	8/Jun/2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:07	14:01	2:54	LINE CLEAR AVALIED
31	8/Jun/2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	11:07	14:03	2:56	LINE CLEAR AVALIED
32	8/Jun/2021	BAGALKOT	110	110/11KV, HV1	SHIGGOAN_110	9:50	10:03	0:13	TRANSFORMER FAULT
33	8/Jun/2021	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	6:00	17:17	11:17	LINE FAULT
34	8/Jun/2021	BAGALKOT	220	KUDACHI-CHIKKODI2	KUDACHI_220	10:31	17:25	6:54	LINE CLEAR AVALIED
35	8/Jun/2021	BAGALKOT	220	CHIKKODI- KUDACHI2	CHIKKODI_220	6:00	17:25	11:25	LINE FAULT
36	8/Jun/2021	BAGALKOT	220	CHIKKODI- KUDACHI1	CHIKKODI_220	6:00	6:30	0:30	LINE FAULT
37	8/Jun/2021	BAGALKOT	220	220/110KV,HV2&LV2	BIJAPUR_220	11:30	11:50	0:20	TRANSFORMER FAULT
38	8/Jun/2021	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	8:56	9:09	0:13	HAND TRIPPED
39	8/Jun/2021	BAGALKOT	110	GADAG-LAXMESHAWR 2	LAXMESHAWR_110	8:56	9:10	0:14	HAND TRIPPED
40	8/Jun/2021	BAGALKOT	110	TAKKALAKI-VARADA	TAKKALAKI_110	11:31	12:30	0:59	HAND TRIPPED
41	8/Jun/2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	TAKKALAKI_110	11:31	12:30	0:59	HAND TRIPPED
42	8/Jun/2021	BAGALKOT	110	110/11KV,HV1	ZALKI_110 & DHULKED,NEVERAGI&HALSANGI_33	16:33	18:11	1:38	LINE CLEAR AVALIED
43	8/Jun/2021	BAGALKOT	110	110/33KV,HV 4	ZALKI_110	9:46	9:57	0:11	TRANSFORMER FAULT
44	8/Jun/2021	BAGALKOT	110	SODATTI220-RAMADURGA2	RAMADURGA_110	12:31	13:28	0:57	LINE FAULT
45	8/Jun/2021	BAGALKOT	110	SODATTI220-RAMADURGA1 (NARAGUND)	NARAGUND_110	12:32	13:41	1:09	LINE FAULT
46	8/Jun/2021	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	5:51	6:18	0:27	LINE FAULT
47	8/Jun/2021	BENGALURU	66	HV1	DEVARABISANAHALLI	13:19	13:25	0:06	LINE CLEAR AVALIED
48	8/Jun/2021	BENGALURU	66	HV2	HANUMANTHNAGARA	13:02	14:25	1:23	LINE CLEAR AVALIED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
49	8/Jun/2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	21:46	21:56	0:10	LINE FAULT
50	8/Jun/2021	BENGALURU	66	HV1	DODDABELAVANGALA	12:00	13:12	1:12	LINE CLEAR AVOID
51	8/Jun/2021	BENGALURU	66	HV1	TYAMAGONDALU	12:50	12:55	0:05	LINE CLEAR AVOID
52	8/Jun/2021	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	10:22	10:28	0:06	LOAD CHANGE OVER
53	8/Jun/2021	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	16:34	16:40	0:06	LOAD CHANGE OVER
54	8/Jun/2021	BENGALURU	66	HV3	KGF	6:10	9:25	3:15	TRANSFORMER FAULT
55	8/Jun/2021	BENGALURU	66	HV3	KGF	9:35	9:50	0:15	LINE CLEAR AVOID
56	8/Jun/2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI, TATA SOLAR	12:40	12:50	0:10	LINE FAULT
57	8/Jun/2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI, TATA SOLAR	13:00	13:30	0:30	LINE FAULT
58	8/Jun/2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI, TATA SOLAR	13:45	13:50	0:05	LINE FAULT
59	8/Jun/2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI, TATA SOLAR	15:00	16:00	1:00	LINE CLEAR AVOID
60	8/Jun/2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:16	18:26	0:10	LINE FAULT
61	8/Jun/2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:14	18:20	0:06	LINE FAULT
62	8/Jun/2021	GULBARGA	110	SHAHAPUR-KEMBAVI	KEMBAVI_110,UGARSUGAR_IPP	10:41	11:47	1:06	LINE CLEAR AVOID
63	8/Jun/2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	12:58	13:17	0:19	LINE CLEAR AVOID
64	8/Jun/2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:04	5:18	0:14	LINE FAULT
65	8/Jun/2021	GULBARGA	110	SEDAM-SHAHAPUR	SEDAM_220	16:10	19:20	3:10	LINE FAULT
66	8/Jun/2021	GULBARGA	66	HV3	KUDLIGI_66	0:50	13:45	12:55	LINE CLEAR AVOID
67	8/Jun/2021	GULBARGA	66	HOSAHALLI-SML_WIND	HOSAHALLI_66	0:00	0:15	0:15	LINE FAULT
68	8/Jun/2021	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	11:05	12:55	1:50	LINE CLEAR AVOID
69	8/Jun/2021	GULBARGA	66	ITTAGI-CLENAMAX2_IPP	ITTAGI_220	12:30	12:45	0:15	LINE CLEAR AVOID
70	8/Jun/2021	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	13:40	13:45	0:05	LINE CLEAR AVOID
71	8/Jun/2021	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	14:10	14:20	0:10	LINE CLEAR AVOID
72	8/Jun/2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:52(06.06.2021)			LINE OPEN, LINE CLEAR AVOID
73	8/Jun/2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)	11:53 (8.06.2021)	578:01hrs	TRANSFORMER CHARGED
74	8/Jun/2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:26	6:20	5:54	LINE CLEAR AVOID
75	8/Jun/2021	HASSAN	220	HV2	KAVOOR_220	9:13	15:02	5:49	LINE CLEAR AVOID
76	8/Jun/2021	HASSAN	110	LV2	KAVOOR_220	9:13	15:02	5:49	LINE CLEAR AVOID
77	8/Jun/2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:18	12:28	3:10	NFBC ISSUED
78	8/Jun/2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:16	12:28	3:12	LINE CLEAR AVOID
79	8/Jun/2021	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	12:01	12:17	0:16	LINE FAULT
80	8/Jun/2021	HASSAN	110	HV2	BANAVARA_110	4:50	9:00	4:10	TRANSFORMER FAULT
81	8/Jun/2021	HASSAN	110	HV3	GURUVAYANAKERE_110	15:18	17:35	2:17	TRANSFORMER FAULT
82	8/Jun/2021	HASSAN	110	HV2	JOG_110	11:20	12:55	1:35	LINE CLEAR AVOID
83	8/Jun/2021	HASSAN	110	HV2	KADUR_220	11:28	11:56	0:28	TRANSFORMER FAULT
84	8/Jun/2021	HASSAN	110	HV1	MADHUVANA_110	10:32	12:41	2:09	LINE CLEAR AVOID
85	8/Jun/2021	HASSAN	110	HV1	MOODABIDRE_110	10:35	12:07	1:32	LINE CLEAR AVOID
86	8/Jun/2021	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	10:52	12:55	2:03	LINE CLEAR AVOID
87	8/Jun/2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:19	13:41	0:22	LINE CLEAR AVOID
88	8/Jun/2021	HASSAN	110	HV1	BRAHMAVARA_110	9:50	11:15	1:25	LINE CLEAR AVOID
89	8/Jun/2021	HASSAN	66	HV1	AREHALLI_HSN_66	14:25	15:55	1:30	LINE CLEAR AVOID
90	8/Jun/2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	6:48	6:55	0:07	MAIN SUPPLY FAILURE
91	8/Jun/2021	HASSAN	66	HV1	HADAVANAHALLY_66	11:45	12:55	1:10	LINE CLEAR AVOID
92	8/Jun/2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	6:48	6:55	0:07	LINE FAULT
93	8/Jun/2021	HASSAN	66	HV1	KANDLI_66	12:50	12:55	0:05	TRANSFORMER FAULT
94	8/Jun/2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:11	12:22	0:11	LINE FAULT
95	8/Jun/2021	HASSAN	66	HV1	MALLAPURA_66	14:05	15:30	1:25	LINE CLEAR AVOID
96	8/Jun/2021	HASSAN	66	HV2	MALLAPURA_66	14:05	15:30	1:25	LINE CLEAR AVOID
97	8/Jun/2021	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	14:05	15:30	1:25	LINE CLEAR AVOID
98	8/Jun/2021	MYSURU	66	HV1	BGPURA_66	9:57	11:36	1:38	LINE CLEAR AVOID
99	8/Jun/2021	MYSURU	66	HV2	BGPURA_66	11:36	12:30	0:53	LINE CLEAR AVOID
100	8/Jun/2021	MYSURU	66	HV1	DEVANOORMYS_66	12:31	14:15	1:44	LINE CLEAR AVOID
101	8/Jun/2021	MYSURU	66	HV2	DEVANOORMYS_66	14:28	14:56	0:28	LINE CLEAR AVOID
102	8/Jun/2021	MYSURU	220	KR PETE 220-YACHANAHALLI	NO STATIONS EFFECTED	12:01	12:25	0:24	LINE FAULT
103	8/Jun/2021	MYSURU	66	HV2	NAGAMANGALA_66	13:35	14:14	0:39	LINE CLEAR AVOID
104	8/Jun/2021	MYSURU	66	HV2	PERIYAPATNA_66	18:09	18:18	0:08	TRANSFORMER FAULT
105	8/Jun/2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	00:49 (07/06/2021)	16:50 (08/06/2021)	40:01HRS	LINE CHARGED
106	8/Jun/2021	TUMKUR	220	TR-3	CHITRADURGA_220	18:59	19:08	0:08	TRANSFORMER FAULT
107	8/Jun/2021	TUMKUR	220	JAGALUR400-KUDLIGI220KV	JAGALUR_220	13:33	14:11	0:37	LINE FAULT
108	8/Jun/2021	TUMKUR	110	TR-3	AMMASANDRA_110	21:45	21:55	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
109	8/Jun/2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	19:00	19:08	0:07	TRANSFORMER FAULT
110	8/Jun/2021	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALI_66, CHALLAKERE_66, SANIKERE_66	19:06	19:20	0:14	HAND TRIPPED
111	8/Jun/2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	19:06	19:19	0:12	HAND TRIPPED
112	8/Jun/2021	TUMKUR	66	TR-1	CHITRAHALI_66	8:52	8:56	0:03	LINE CLEAR AVAILED
113	8/Jun/2021	TUMKUR	66	TR-2	CHITRAHALI_66	16:18	17:30	1:11	LINE CLEAR AVAILED
114	8/Jun/2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:30	12:31	0:01	HAND TRIPPED
115	8/Jun/2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:44	16:53	0:09	LINE FAULT
116	8/Jun/2021	TUMKUR	66	KUNDUR- HONNALI	KUNDUR_66, MALEBENNUR_66	14:16	14:30	0:13	HAND TRIPPED
117	8/Jun/2021	TUMKUR	66	TR-1	KUNDUR_66	6:10	6:30	0:19	TRANSFORMER FAULT
118	8/Jun/2021	TUMKUR	66	TR-1	KUNDUR_66	14:16	14:56	0:40	LINE CLEAR AVAILED
119	8/Jun/2021	TUMKUR	66	TR-2	MADADKERE_66	8:35	8:42	0:07	TRANSFORMER FAULT
120	8/Jun/2021	TUMKUR	66	TR-1	PDKOTE_66	11:07	16:08	5:00	LINE CLEAR AVAILED
121	8/Jun/2021	TUMKUR	66	TR-1	PAVAGADA_220	11:03	12:05	1:01	LINE CLEAR AVAILED
122	8/Jun/2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	19:02	19:58	0:56	LINE FAULT
123	9/Jun/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
124	9/Jun/2021	BAGALKOT	66	HONNALI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
125	9/Jun/2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
126	9/Jun/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
127	9/Jun/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
128	9/Jun/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
129	9/Jun/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
130	9/Jun/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
131	9/Jun/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
132	9/Jun/2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVAILED
133	9/Jun/2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	8:14 (07.06.2021)			LINE OPEN, LINE CLEAR AVAILED
134	9/Jun/2021	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	19:58 (08.06.2021)	17:56 (9.6.2021)	21:54HRS	TRANSFORMER CHARGED
135	9/Jun/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:11(08.06.2021)			LINE OPEN, LINE CLEAR AVAILED
136	9/Jun/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:11(08.06.2021)			LINE OPEN, LINE CLEAR AVAILED
137	9/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	15:24	15:50	0:26	LINE CLEAR AVAILED
138	9/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	15:58	16:21	0:23	TRANSFORMER FAULT
139	9/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	16:23	17:15	0:52	TRANSFORMER FAULT
140	9/Jun/2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:58	18:42	0:44	LINE CLEAR AVAILED
141	9/Jun/2021	BAGALKOT	110	HATTARAGI-O/GBELGAUM(DADDI)	STATION NOT AFFECTED DADDI_110	10:05	12:42	2:37	LINE CLEAR AVAILED
142	9/Jun/2021	BAGALKOT	220	HAVERI-GUTTUR 2	STATION NOT AFFECTED HAVERI_220	10:30	10:47	0:17	HAND TRIPPED
143	9/Jun/2021	BAGALKOT	110	KD JAMBAGI-VAJRAMATTI(MUDHOL)	MUDHOL_110	18:50(06.04.21)	11:12(09.06.21)	64:22HRS	LINE CHARGED
144	9/Jun/2021	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	9:06	11:42	2:36	LINE CLEAR AVAILED
145	9/Jun/2021	BAGALKOT	220	220/110KV ,HV1&LV1	KARAWAR_220	10:37	12:00	1:23	LINE CLEAR AVAILED
146	9/Jun/2021	BAGALKOT	110	110/33KV,HV4&3	MACHE_110 &ALUCAST&RM-1_33	13:04	13:12	0:08	HAND TRIPPED
147	9/Jun/2021	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	7:52	9:16	1:24	LINE CLEAR AVAILED
148	9/Jun/2021	BAGALKOT	110	SOUDATTI-SOUDATT- 1(MUNAVALLY)	SOUDATTI_110	10:45	13:23	2:38	LINE CLEAR AVAILED
149	9/Jun/2021	BAGALKOT	110	110/33KV,HV3	ZALAKI_110 &HORTI_33	13:43	14:21	0:38	TRANSFORMER FAULT
150	9/Jun/2021	BAGALKOT	110	110/33KV,HV4	ZALAKI_110 &DHULKED,HALASANGI, NEVARAGI_33	16:12	17:49	1:37	LINE CLEAR AVAILED
151	9/Jun/2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:47	18:57	0:10	LINE FAULT
152	9/Jun/2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	19:44	21:05	1:21	LINE FAULT
153	9/Jun/2021	BENGALURU	66	HV1	BIJALAHALLI	11:39	12:51	1:12	LINE CLEAR AVAILED
154	9/Jun/2021	BENGALURU	66	HV1	DALASNUR	12:52	13:40	0:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
155	9/Jun/2021	BENGALURU	66	HV1	PATH PALYA	12:18	13:06	0:48	LINE CLEAR AVAILED
156	9/Jun/2021	BENGALURU	66	HV2	SM MANGALA	8:42	9:21	0:39	LINE CLEAR AVAILED
157	9/Jun/2021	BENGALURU	66	HV1	SOMENAHALLI	6:50	7:04	0:14	TRANSFORMER FAULT
158	9/Jun/2021	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	18:07	18:45	0:38	LINE FAULT
159	9/Jun/2021	BENGALURU	66	HV3	NAGANATHPURA 220	11:46	11:50	0:04	LINE CLEAR AVAILED
160	9/Jun/2021	BENGALURU	66	HV3	NAGANATHPURA 220	13:51	13:53	0:02	LOAD CHANGE OVER
161	9/Jun/2021	BENGALURU	66	HV1	ST.JOHNS WOOD	12:37	12:45	0:08	LINE CLEAR AVAILED
162	9/Jun/2021	BENGALURU	66	HV1	ST.JOHNS WOOD	13:13	13:19	0:06	LOAD CHANGE OVER
163	9/Jun/2021	BENGALURU	66	T K HALLI 220 - SIMSHA	T K HALLI 220	13:40	13:56	0:16	LINE FAULT
164	9/Jun/2021	BENGALURU	66	T K HALLI 220 - SIMSHA	T K HALLI 220	14:34	14:53	0:19	LINE FAULT
165	9/Jun/2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	23:46(09/06/2021)			LINE OPEN,LINE FAULT
166	9/Jun/2021	BENGALURU	66	HV3	ADUGODI	23:59(09/06/2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
167	9/Jun/2021	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	3:08(09.06.2021)	8:55(10.06.2021)	29:47HRS	LINE CHARGED
168	9/Jun/2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	3:10	6:05	2:55	LINE CLEAR AVAILED
169	9/Jun/2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	3:27	6:14	2:47	LINE CLEAR AVAILED
170	9/Jun/2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN, LINE CLEAR AVAILED
171	9/Jun/2021	GULBARGA	110	HV1	SANKLAPUR_110	7:39	7:49	0:10	TRANSFORMER FAULT
172	9/Jun/2021	GULBARGA	110	BELLARYNORTH-BISIHALLI	BISIHALLI_110	6:53	8:10	1:17	MAIN SUPPLY FAILURE
173	9/Jun/2021	GULBARGA	110	SIRIGUPPA-TEKKALKOTE	TEKKALKOTE	12:30	12:35	0:05	LINE FAULT
174	9/Jun/2021	GULBARGA	110	SIRIGUPPA-TEKKALKOTE	TEKKALKOTE	2:10	2:15	0:05	LINE FAULT
175	9/Jun/2021	GULBARGA	110	HV1	HATTI_110	9:28	9:32	0:04	TRANSFORMER FAULT
176	9/Jun/2021	GULBARGA	110	HV1	HATTI_110	16:42	16:47	0:05	TRANSFORMER FAULT
177	9/Jun/2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHPUR_110	19:13	19:25	0:12	LINE FAULT
178	9/Jun/2021	GULBARGA	110	GULBARGA SOUTH-SHAHABAD	FARTHABAD_110	16:42	17:40	0:58	LINE CLEAR AVAILED
179	9/Jun/2021	GULBARGA	110	SIRIGUPPA-TEKKALKOTE	TEKKALKOTE_110	0:30	0:35	0:05	LINE FAULT
180	9/Jun/2021	GULBARGA	110	SIRIGUPPA-TEKKALKOTE	TEKKALKOTE_110	2:10	2:15	0:05	LINE FAULT
181	9/Jun/2021	GULBARGA	110	KANAKAGIRI-NAVLI	NAVALI_110	10:55	11:15	0:20	MAIN SUPPLY FAILURE
182	9/Jun/2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	19:13	19:19	0:06	LINE FAULT
183	9/Jun/2021	GULBARGA	110	KANAKAGIRI-NAVLI	NAVLI_110	2:10	2:15	0:05	MAIN SUPPLY FAILURE
184	9/Jun/2021	GULBARGA	66	HV1	CHORNOOR_66	12:00	12:03	0:03	TRANSFORMER FAULT
185	9/Jun/2021	GULBARGA	66	HV1	TAMBRAHALLI_66	12:00	12:05	0:05	LINE CLEAR AVAILED
186	9/Jun/2021	GULBARGA	66	HV2	TAMBRAHALLI_66	12:00	12:05	0:05	LINE CLEAR AVAILED
187	9/Jun/2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:52(06.06.2021)			LINE OPEN, LINE CLEAR AVAILED
188	9/Jun/2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:17	6:20	6:03	LINE CLEAR AVAILED
189	9/Jun/2021	HASSAN	220	HV2	KAVOOR_220	9:25	14:05	4:40	LINE CLEAR AVAILED
190	9/Jun/2021	HASSAN	110	LV2	KAVOOR_220	9:25	14:05	4:40	LINE CLEAR AVAILED
191	9/Jun/2021	HASSAN	220	MRSSHM-VARAH3	MRSMG_220	9:31	12:41	3:10	LINE CLEAR AVAILED
192	9/Jun/2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	14:11	21:39	7:28	LINE CLEAR AVAILED
193	9/Jun/2021	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	14:11	21:40	7:29	LINE CLEAR AVAILED
194	9/Jun/2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:33	12:41	3:08	LINE CLEAR AVAILED
195	9/Jun/2021	HASSAN	110	HV1	NITTUR_110	10:26	13:07	2:41	LINE CLEAR AVAILED
196	9/Jun/2021	HASSAN	110	HV2	BARANGI_110	6:08	14:55	8:47	TRANSFORMER FAULT
197	9/Jun/2021	HASSAN	110	HV1	BARANGI_110	9:36	9:41	0:05	HAND TRIPPED
198	9/Jun/2021	HASSAN	110	HV1	KADUR_220	11:35	13:16	1:41	LINE CLEAR AVAILED
199	9/Jun/2021	HASSAN	110	HV1	KARAYA_110	15:11	15:15	0:04	MAIN SUPPLY FAILURE
200	9/Jun/2021	HASSAN	110	HV2	KARAYA_110	15:11	15:15	0:04	MAIN SUPPLY FAILURE
201	9/Jun/2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	12:21	15:14	2:53	LINE FAULT
202	9/Jun/2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	9:57	9:59	0:02	HAND TRIPPED
203	9/Jun/2021	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	11:10	14:21	3:11	MAIN SUPPLY FAILURE
204	9/Jun/2021	HASSAN	66	CHIKKAK-HASN	CHIKKAKONDAGOLA_66	11:10	13:47	2:37	MAIN SUPPLY FAILURE
205	9/Jun/2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	11:10	13:47	2:37	MAIN SUPPLY FAILURE
206	9/Jun/2021	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	11:10	13:47	2:37	MAIN SUPPLY FAILURE
207	9/Jun/2021	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA_66	11:10	14:25	3:15	MAIN SUPPLY FAILURE
208	9/Jun/2021	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	11:10	13:47	2:37	MAIN SUPPLY FAILURE
209	9/Jun/2021	HASSAN	66	HV1	DUDDA_66	11:10	13:50	2:40	MAIN SUPPLY FAILURE
210	9/Jun/2021	HASSAN	66	HV1	KANDLI_66	11:55	12:00	0:05	TRANSFORMER FAULT
211	9/Jun/2021	HASSAN	66	HV2	KANDLI_66	12:35	16:15	3:40	TRANSFORMER FAULT
212	9/Jun/2021	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	11:10	13:46	2:36	LINE CLEAR AVAILED
213	9/Jun/2021	HASSAN	66	HV1	BASAVAGHATTA_66	11:10	14:30	3:20	MAIN SUPPLY FAILURE
214	9/Jun/2021	HASSAN	66	HV2	BASAVAGHATTA_66	11:10	14:30	3:20	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
215	9/Jun/2021	MYSURU	66	HV1	CHINAKURALI_66	11:45	12:59	1:14	LINE CLEAR AVAILED
216	9/Jun/2021	MYSURU	66	HV2	CHINAKURALI_66	10:41	11:51	1:10	LINE CLEAR AVAILED
217	9/Jun/2021	MYSURU	66	HV2	CHINAKURALI_66	16:10	16:40	0:29	LINE CLEAR AVAILED
218	9/Jun/2021	MYSURU	66	HV1	COWDALLI_66	2:57	3:33	0:35	TRANSFORMER FAULT
219	9/Jun/2021	MYSURU	66	HV1	HULLAHALLI_66	16:37	17:05	0:27	LINE CLEAR AVAILED
220	9/Jun/2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
221	9/Jun/2021	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	10:02	10:09	0:06	LINE FAULT
222	9/Jun/2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
223	9/Jun/2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	16:49	17:02	0:13	HAND TRIPPED
224	9/Jun/2021	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	5:01	5:26	0:24	LINE FAULT
225	9/Jun/2021	TUMKUR	220	TR-3	CHITRADURGA_220	10:09	10:29	0:20	TRANSFORMER FAULT
226	9/Jun/2021	TUMKUR	220	TR-1	DAVANGERE_220	10:11	13:10	2:59	LINE CLEAR AVAILED
227	9/Jun/2021	TUMKUR	220	TR-2	HIRIYUR_220	10:35	10:46	0:10	TRANSFORMER FAULT
228	9/Jun/2021	TUMKUR	220	TR-3	HIRIYUR_220	10:35	10:46	0:10	TRANSFORMER FAULT
229	9/Jun/2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	7:00	7:10	0:09	TRANSFORMER FAULT
230	9/Jun/2021	TUMKUR	110	TR-1	KALLUR_110	10:05	15:48	5:42	LINE CLEAR AVAILED
231	9/Jun/2021	TUMKUR	110	TR-2	KALLUR_110	12:10	12:39	0:29	LINE CLEAR AVAILED
232	9/Jun/2021	TUMKUR	110	TR-2	KALLUR_110	14:29	19:00	4:31	LINE CLEAR AVAILED
233	9/Jun/2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	10:09	10:31	0:22	TRANSFORMER FAULT
234	9/Jun/2021	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	10:23	10:34	0:11	HAND TRIPPED
235	9/Jun/2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	10:23	10:33	0:10	HAND TRIPPED
236	9/Jun/2021	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON2_IPP_66	10:23	10:35	0:12	HAND TRIPPED
237	9/Jun/2021	TUMKUR	66	TR-1(LV-1)	DAVANAGERE_220	10:11	13:13	3:01	LINE CLEAR AVAILED
238	9/Jun/2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:06	10:10	0:04	HAND TRIPPED
239	9/Jun/2021	TUMKUR	66	TR-3	HARIYABBE_66	10:42	11:09	0:27	LINE CLEAR AVAILED
240	9/Jun/2021	TUMKUR	66	TR-3	HARIYABBE_66	11:22	13:12	1:50	LINE CLEAR AVAILED
241	9/Jun/2021	TUMKUR	66	TR-3	HARIYABBE_66	15:37	16:05	0:27	LINE CLEAR AVAILED
242	9/Jun/2021	TUMKUR	66	TR-1	HARIYABBE_66	9:55	10:20	0:25	LINE CLEAR AVAILED
243	9/Jun/2021	TUMKUR	66	TR-1	HARIYABBE_66	12:55	14:05	1:10	LINE CLEAR AVAILED
244	9/Jun/2021	TUMKUR	66	TR-2	HARIYABBE_66	9:55	10:20	0:25	LINE CLEAR AVAILED
245	9/Jun/2021	TUMKUR	66	TR-2	HIRIYUR_66	13:19	13:31	0:11	TRANSFORMER FAULT
246	9/Jun/2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:41	10:55	0:13	HAND TRIPPED
247	9/Jun/2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:41	10:55	0:13	HAND TRIPPED
248	9/Jun/2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	10:40	10:54	0:13	HAND TRIPPED
249	9/Jun/2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:35	10:56	0:21	LINE FAULT
250	9/Jun/2021	TUMKUR	66	HIRIYUR 220KV- PR PURA_66	RANGENAHALLI_66, PR PURA_66	10:35	10:58	0:23	LINE FAULT
251	9/Jun/2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:45	10:55	0:09	LINE FAULT
252	9/Jun/2021	TUMKUR	66	TR-2	RAMPURA_66	9:25	9:35	0:09	TRANSFORMER FAULT
253	10-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT
254	10-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
255	10-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
256	10-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
257	10-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
258	10-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
259	10-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
260	10-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
261	10-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
262	10-Jun-2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVAILED
263	10-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	8:14 (07.06.2021)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
264	10-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:11(08.06.2021)	19:10 (10.06.2021)	52:59HRS	LINE CHARGED
265	10-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:11(08.06.2021)	19:11 (10.06.2021)	53:00HRS	LINE CHARGED
266	10-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
267	10-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
268	10-Jun-2021	BAGALKOT	110	SUPA1-AMBEWADI 220	STATION NOT AFFECTED AMBEWADI_220	16:06	16:17	0:11	LINE FAULT
269	10-Jun-2021	BAGALKOT	220	NGJRI2-AMBEWADI 220	STATION NOT AFFECTED AMBEWADI_220	19:47	22:11	2:24	LOAD CURTAILMENT
270	10-Jun-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	18:03	18:21	0:18	HAND TRIPPED
271	10-Jun-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	10:50	12:11	1:21	LINE CLEAR AVAILED
272	10-Jun-2021	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	7:40	7:46	0:06	TRANSFORMER FAULT
273	10-Jun-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	12:29	12:45	0:16	TRANSFORMER FAULT
274	10-Jun-2021	BAGALKOT	110	110/11KV, HV1	MUDDEBIHAL_110	7:46	9:34	1:48	LINE CLEAR AVAILED
275	10-Jun-2021	BAGALKOT	110	110/11KV, HV1	SHIGGOAN_110	4:16	4:30	0:14	TRANSFORMER FAULT
276	10-Jun-2021	BAGALKOT	110	110/11KV, HV3	HIDIKAL DAM_110	14:35	17:24	2:49	LINE CLEAR AVAILED
277	10-Jun-2021	BENGALURU	66	HOODY 220 - GRAPHIC INDIA (EHT)	GRAPHIC INDIA (EHT)	11:03	13:18	2:15	LINE CLEAR AVAILED
278	10-Jun-2021	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI	13:11	13:20	0:09	LINE FAULT
279	10-Jun-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	7:20	7:31	0:11	LINE FAULT
280	10-Jun-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	18:45	18:52	0:07	LINE FAULT
281	10-Jun-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	17:02	17:08	0:05	LINE FAULT
282	10-Jun-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	17:02	17:16	0:14	LINE FAULT
283	10-Jun-2021	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	8:53	11:31	2:37	LINE FAULT
284	10-Jun-2021	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	20:13	21:10	0:56	LINE FAULT
285	10-Jun-2021	BENGALURU	66	HV3	ADUGODI	0:02	0:07	0:05	TRANSFORMER FAULT
286	10-Jun-2021	BENGALURU	66	HV1	BYADRAHALLI	13:57	16:27	2:29	LINE CLEAR AVAILED
287	10-Jun-2021	BENGALURU	66	HV2	HSR LAYOUT 220	0:06	0:48	0:42	TRANSFORMER FAULT
288	10-Jun-2021	BENGALURU	66	HV2	NGEF	11:08	11:28	0:20	LINE CLEAR AVAILED
289	10-Jun-2021	BENGALURU	66	HV1	M GOLLAHALLI	18:25	18:30	0:04	TRANSFORMER FAULT
290	10-Jun-2021	BENGALURU	66	HV3	ADUGODI	23:59(09/06/2021)	00:05(10/06/2021)	0:06MIN	TRANSFORMER CHARGED
291	10-Jun-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	23:46(09/06/2021)	16:37:00(10/06/2021)	16:50HRS	LINE CHARGED
292	10-Jun-2021	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	20:03(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
293	10-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	20:08(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
294	10-Jun-2021	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	1:09	6:15	5:06	LINE CLEAR AVAILED
295	10-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	3:10	6:05	2:55	LINE CLEAR AVAILED
296	10-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:17	15:33	3:16	LINE CLEAR AVAILED
297	10-Jun-2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	3:27	6:14	2:47	LINE CLEAR AVAILED
298	10-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN, LINE CLEAR AVAILED
299	10-Jun-2021	GULBARGA	110	HV2	DEODURGA_110	21:05	21:20	0:15	TRANSFORMER FAULT
300	10-Jun-2021	GULBARGA	110	HV2	HATTI_110	15:50	15:55	0:05	TRANSFORMER FAULT
301	10-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	9:48	9:56	0:08	MAIN SUPPLY FAILURE
302	10-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	10:55	11:10	0:15	MAIN SUPPLY FAILURE
303	10-Jun-2021	GULBARGA	110	HV1	NIRNA_110	16:05	16:10	0:05	TRANSFORMER FAULT
304	10-Jun-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	17:03	17:11	0:08	LINE FAULT
305	10-Jun-2021	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	12:17	12:29	0:12	LINE FAULT
306	10-Jun-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSK FACTORY	15:41	16:15	0:34	LINE FAULT
307	10-Jun-2021	GULBARGA	110	HV2	ALIPUR_220	10:45	14:21	3:36	LINE CLEAR AVAILED
308	10-Jun-2021	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	14:25	14:50	0:25	LINE CLEAR AVAILED
309	10-Jun-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	12:40	15:11	2:31	LINE CLEAR AVAILED
310	10-Jun-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	16:17	16:34	0:17	LINE CLEAR AVAILED
311	10-Jun-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	19:00	19:06	0:06	LINE CLEAR AVAILED
312	10-Jun-2021	GULBARGA	66	HV1	HANASI_66	17:40	19:10	1:30	LINE CLEAR AVAILED
313	10-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:52(06.06.2021)			LINE OPEN, LINE CLEAR AVAILED
314	10-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:43	6:43	5:00	LINE CLEAR AVAILED
315	10-Jun-2021	HASSAN	220	HGGUNJE-KEMAR	HEGGUNJE_220	15:15	15:56	0:41	NFBC ISSUED
316	10-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:21	12:17	1:56	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
317	10-Jun-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:25	14:46	2:21	LINE CLEAR AVAILED
318	10-Jun-2021	HASSAN	220	KEMAR-HEGGUNJE	KEMAR_220	15:15	15:56	0:41	LINE CLEAR AVAILED
319	10-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:23	12:21	1:58	NFBC ISSUED
320	10-Jun-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:28	14:46	2:18	NFBC ISSUED
321	10-Jun-2021	HASSAN	110	HV1	HALADY_110	15:38	15:44	0:06	HAND TRIPPED
322	10-Jun-2021	HASSAN	110	HV2	HALADY_110	15:38	15:44	0:06	HAND TRIPPED
323	10-Jun-2021	HASSAN	110	HV2	SHIRALKOPPA_110	5:43	9:28	3:45	TRANSFORMER FAULT
324	10-Jun-2021	HASSAN	110	HV2	SHIRALKOPPA_110	9:48	10:28	0:40	LINE CLEAR AVAILED
325	10-Jun-2021	HASSAN	110	HV2	SHIRALKOPPA_110	18:49	19:24	0:35	LINE CLEAR AVAILED
326	10-Jun-2021	HASSAN	110	HV2	SORABA_110	13:23	14:53	1:30	LINE CLEAR AVAILED
327	10-Jun-2021	HASSAN	110	HV1	TALAGUPPA_110	9:09	11:25	2:16	LINE CLEAR AVAILED
328	10-Jun-2021	HASSAN	110	HV2	TALAGUPPA_110	11:42	13:48	2:06	LINE CLEAR AVAILED
329	10-Jun-2021	HASSAN	66	HV1	CHIKMAGALUR_66	12:25	14:00	1:35	LINE CLEAR AVAILED
330	10-Jun-2021	HASSAN	66	HV1	CHIKMAGALUR_66	14:07	14:15	0:08	LINE CLEAR AVAILED
331	10-Jun-2021	HASSAN	66	HV1	DUDDA_66	11:48	12:01	0:13	TRANSFORMER FAULT
332	10-Jun-2021	HASSAN	66	HV2	HALLYMYSORE_66	6:10	6:20	0:10	TRANSFORMER FAULT
333	10-Jun-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	6:11	6:16	0:05	LINE FAULT
334	10-Jun-2021	HASSAN	66	HV2	HOLALUR_66	8:00	9:20	1:20	LINE CLEAR AVAILED
335	10-Jun-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	11:52	11:56	0:04	LINE FAULT
336	10-Jun-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	14:31	14:43	0:12	LINE FAULT
337	10-Jun-2021	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	11:24	13:15	1:51	NFBC ISSUED
338	10-Jun-2021	MYSURU	66	HV1	BASARALU_66	13:10	14:25	1:15	LINE CLEAR AVAILED
339	10-Jun-2021	MYSURU	66	HV2	BASARALU_66	9:42	13:10	3:27	LINE CLEAR AVAILED
340	10-Jun-2021	MYSURU	66	HV2	HANAGODU_66	12:19	13:21	1:02	LINE CLEAR AVAILED
341	10-Jun-2021	MYSURU	66	HV2	HANNUR_66	18:31	18:40	0:08	TRANSFORMER FAULT
342	10-Jun-2021	MYSURU	66	HV1	HULLAHALLI_66	12:42	13:22	0:39	LINE CLEAR AVAILED
343	10-Jun-2021	MYSURU	66	JYOTHINAGARA-DK MAIDANA	DKMAIDANA_66	16:15	16:20	0:05	LINE FAULT
344	10-Jun-2021	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 CHANDRAVADI_66 HULLAHALLI_66 HURA_66	5:45	5:49	0:04	LINE FAULT
345	10-Jun-2021	MYSURU	66	KR PETE 220-KR PETE 1	KRPET_66 KIKKERI_66 AKKIHEBBAL_66	12:45	12:55	0:09	LINE FAULT
346	10-Jun-2021	MYSURU	66	KR PETE 220-KR PETE 2	KRPET_66 KIKKERI_66 AKKIHEBBAL_66	12:45	12:55	0:09	LINE FAULT
347	10-Jun-2021	MYSURU	66	HV2	PONNAMPET_66	16:30	16:50	0:19	LINE CLEAR AVAILED
348	10-Jun-2021	MYSURU	66	HV1	SUNTIKOPPA_66	15:30	15:53	0:23	LINE CLEAR AVAILED
349	10-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
350	10-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
351	10-Jun-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	11:23	14:18	2:55	LINE CLEAR AVAILED
352	10-Jun-2021	TUMKUR	110	TR-1	MAYASANDRA_110	10:13	17:32	7:18	LINE CLEAR AVAILED
353	10-Jun-2021	TUMKUR	110	TR-1	MAYASANDRA_110	17:58	18:50	0:52	LINE CLEAR AVAILED
354	10-Jun-2021	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	14:34	16:32	1:58	LINE CLEAR AVAILED
355	10-Jun-2021	TUMKUR	66	TR-1	HULIYAR_110	1:03	1:44	0:40	TRANSFORMER FAULT
356	10-Jun-2021	TUMKUR	66	TR-2	CHITRADURGA_66	17:15	17:34	0:18	TRANSFORMER FAULT
357	10-Jun-2021	TUMKUR	66	TR-1	HIRIYUR_66	1:03	1:44	0:40	TRANSFORMER FAULT
358	10-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:36	15:01	0:24	LINE FAULT
359	10-Jun-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	3:14	3:22	0:08	LINE FAULT
360	10-Jun-2021	TUMKUR	66	TR-2	HONNUDIKE_66	15:03	15:26	0:23	LINE CLEAR AVAILED
361	10-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	11:40	13:24	1:44	LINE CLEAR AVAILED
362	10-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	13:32	14:10	0:38	LINE CLEAR AVAILED
363	10-Jun-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:21	8:51	0:29	LINE CLEAR AVAILED
364	10-Jun-2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	10:42	10:49	0:07	HAND TRIPPED
365	10-Jun-2021	TUMKUR	66	TR-1	SHYLAPURA_66	12:33	13:02	0:29	LINE CLEAR AVAILED
366	10-Jun-2021	TUMKUR	66	TR-2	KIADB V N PURA_220	13:55	14:49	0:54	LINE CLEAR AVAILED
367	11-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT
368	11-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
369	11-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
370	11-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
371	11-Jun-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVALIED
372	11-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
373	11-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
374	11-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVALIED
375	11-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVALIED
376	11-Jun-2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVALIED
377	11-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	8:14 (07.06.2021)	10:00(12.06.2021)	121:46HRS	LINE CHARGED
378	11-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVALIED
379	11-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVALIED
380	11-Jun-2021	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	13:07	13:57	0:50	LINE CLEAR AVALIED
381	11-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED KAVALWADA_110	9:34 (11.06.2021)			LINE OPEN, LINE CLEAR AVALIED
382	11-Jun-2021	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	10:37	13:24	2:47	LINE CLEAR AVALIED
383	11-Jun-2021	BAGALKOT	110	CHIKKODI220- DKSS COGEN	CHIKKODI_220	12:01	16:14	4:13	LINE CLEAR AVALIED
384	11-Jun-2021	BAGALKOT	110	110/11KV, HV1	HIREKERUR_110	14:07	16:38	2:31	LINE CLEAR AVALIED
385	11-Jun-2021	BAGALKOT	110	110/11KV, HV3	HIREKERUR_110	14:34	16:38	2:04	LINE CLEAR AVALIED
386	11-Jun-2021	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	9:07	12:40	3:33	NFBC ISSUED
387	11-Jun-2021	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(B)_110	13:37	13:43	0:06	TRANSFORMER FAULT
388	11-Jun-2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, HALASANGI_33, NEVARGI_33 STATION NOT AFFECTED ZALKI_110	18:44	18:53	0:09	TRANSFORMER FAULT
389	11-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YELPARAHATTI_110	15:32	15:57	0:25	LINE CLEAR AVALIED
390	11-Jun-2021	BAGALKOT	220	SOUDATTI-MAHALINAPUR	STATION NOT AFFECTED SOUDATTI_220	9:30	13:07	3:37	LINE CLEAR AVALIED
391	11-Jun-2021	BAGALKOT	110	SOUDATTI220-RAMDURG1(NARAGUND)	STATION NOT AFFECTED SOUDATTI_220	13:07	13:57	0:50	LINE CLEAR AVALIED
392	11-Jun-2021	BENGALURU	66	HV1	ALLIMARADANAHALLI	9:34	9:45	0:11	TRANSFORMER FAULT
393	11-Jun-2021	BENGALURU	66	HV1	EPIP 220	1:37	1:45	0:08	TRANSFORMER FAULT
394	11-Jun-2021	BENGALURU	66	HV2	HSR LAYOUT 220	15:18	15:20	0:02	LINE CLEAR AVALIED
395	11-Jun-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	13:00	13:08	0:08	LINE FAULT
396	11-Jun-2021	BENGALURU	66	HV2	NAGNATHPURA 220	11:50	11:52	0:02	LOAD CHANGE OVER
397	11-Jun-2021	BENGALURU	66	HV2	NAGNATHPURA 220	14:50	14:51	0:01	LOAD CHANGE OVER
398	11-Jun-2021	BENGALURU	66	PLATINUM CITY - ATTUR YELAHANAKA	PLATINUM CITY	6:21	6:40	0:19	MAIN SUPPLY FAILURE
399	11-Jun-2021	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	9:21	9:26	0:05	LOAD CHANGE OVER
400	11-Jun-2021	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	6:06	6:14	0:08	LINE FAULT
401	11-Jun-2021	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	6:53	6:55	0:02	LOAD CHANGE OVER
402	11-Jun-2021	BENGALURU	66	HV2	LEELA VENTURE	10:18	10:23	0:05	LINE CLEAR AVALIED
403	11-Jun-2021	BENGALURU	66	HV1	LEELA VENTURE	13:20	13:25	0:05	LINE CLEAR AVALIED
404	11-Jun-2021	BENGALURU	66	HV1	LEELA VENTURE	16:34	16:38	0:04	LOAD CHANGE OVER
405	11-Jun-2021	BENGALURU	66	ATTUR YELAHANKA - DG 3	PLATINUM CITY	6:20	6:34	0:14	LINE FAULT
406	11-Jun-2021	BENGALURU	66	ATTUR YELAHANKA - DG 4	ABBIGERE, WELCASTE	9:24	9:33	0:09	LINE FAULT
407	11-Jun-2021	BENGALURU	66	WELCASTE - SRS PEENYA 220	WELCASTE	13:12	13:17	0:05	LOAD CHANGE OVER
408	11-Jun-2021	BENGALURU	66	HV2	MAASTHI	10:20	10:30	0:10	TRANSFORMER FAULT
409	11-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	12:50	12:55	0:05	LINE CLEAR AVALIED
410	11-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	12:30	12:50	0:20	LINE CLEAR AVALIED
411	11-Jun-2021	BENGALURU	66	HV2	DODDABELAVANGALA	16:11	17:09	0:57	LINE CLEAR AVALIED
412	11-Jun-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	5:57	6:11	0:14	LINE FAULT
413	11-Jun-2021	BENGALURU	66	HV3	DEVANAHALLI 66	10:15	10:25	0:10	TRANSFORMER FAULT
414	11-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	8:58	17:02	8:04	LINE FAULT
415	11-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	17:02:00(11-06-2021)			LINE OPEN,LINE FAULT
416	11-Jun-2021	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	20:03(10.06.2021)	09:01(11.06.2021)	12:58HRS	LINE CHARGED
417	11-Jun-2021	GULBARGA	220	LINGAPUR-GD HALLI	GD HALLI_220	9:34	15:55	6:21	LINE CLEAR AVALIED
418	11-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD LINE1	HALBARGA_220	2:55	9:25	6:30	LINE CLEAR AVALIED
419	11-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD LINE1	HALBARGA_220	11:35	11:45	0:10	LINE CLEAR AVALIED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
420	11-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	20:08(10.06.2021)	6:10(11.06.2021)	10:02HRS	LINE CHARGED
421	11-Jun-2021	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	2:33	6:15	3:42	LINE CLEAR AVAILED
422	11-Jun-2021	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	2:33	11:42	9:09	LINE FAULT
423	11-Jun-2021	GULBARGA	220	ITTAGI-NEELGUNDA	ITTAGI_220	2:55	3:25	0:30	LINE FAULT
424	11-Jun-2021	GULBARGA	220	ITTAGI-BMMISPAT_IPP	ITTAGI_220	8:27	8:35	0:08	LINE FAULT
425	11-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN, LINE CLEAR AVAILED
426	11-Jun-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	SIRGUPPA_110	10:50	11:55	1:05	LINE CLEAR AVAILED
427	11-Jun-2021	GULBARGA	110	HV1	NIRNA_110	15:57	16:05	0:08	TRANSFORMER FAULT
428	11-Jun-2021	GULBARGA	110	HV2	SINDHANOOR_110	22:40	22:45	0:05	TRANSFORMER FAULT
429	11-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	12:28	12:33	0:05	TRANSFORMER FAULT
430	11-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:40	18:50	0:10	LINE FAULT
431	11-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	2:06	2:22	0:16	LINE FAULT
432	11-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	12:20	12:35	0:15	LINE CLEAR AVAILED
433	11-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	13:26	14:28	1:02	LINE CLEAR AVAILED
434	11-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	18:38	18:42	0:04	LINE CLEAR AVAILED
435	11-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	8:39	8:44	0:05	LINE FAULT
436	11-Jun-2021	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	12:30	13:20	0:50	MAIN SUPPLY FAILURE
437	11-Jun-2021	GULBARGA	66	KOGALI-ITTAGGI	KOGALI_66	8:25	8:40	0:15	MAIN SUPPLY FAILURE
438	11-Jun-2021	GULBARGA	66	KOGALI-ATRSRLR	KOGALI_66	8:30	9:11	0:41	LINE CLEAR AVAILED
439	11-Jun-2021	GULBARGA	66	HV2	KUDLIGI_66	14:07	14:15	0:08	TRANSFORMER FAULT
440	11-Jun-2021	GULBARGA	66	HV2	KUDLIGI_66	16:00	16:45	0:45	LINE CLEAR AVAILED
441	11-Jun-2021	GULBARGA	66	HV3	KUDLIGI_66	14:30	14:35	0:05	TRANSFORMER FAULT
442	11-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	11:00	11:20	0:20	LINE CLEAR AVAILED
443	11-Jun-2021	GULBARGA	66	BALADADUKU-GUDEKOTE	GUDEKOTE_66	16:36	18:20	1:44	MAIN SUPPLY FAILURE
444	11-Jun-2021	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	12:09	12:14	0:05	LINE CLEAR AVAILED
445	11-Jun-2021	GULBARGA	66	ITTAGI-CLEANMAX1_IPP	ITTAGI_220	12:30	12:39	0:09	LINE CLEAR AVAILED
446	11-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:52(06.06.2021)	7:31(11.6.21)	115:39hrs	LINE CHARGED
447	11-Jun-2021	HASSAN	220	ARSK2-HSN	ARASIKERE_220	12:05	14:13	2:08	LINE FAULT
448	11-Jun-2021	HASSAN	220	HV2	KAVOOR_220	9:16	12:49	3:33	LINE CLEAR AVAILED
449	11-Jun-2021	HASSAN	110	LV2	KAVOOR_220	9:16	12:49	3:33	LINE CLEAR AVAILED
450	11-Jun-2021	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	9:55	13:40	3:45	LINE CLEAR AVAILED
451	11-Jun-2021	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	9:53	18:26	8:33	NFBC ISSUED
452	11-Jun-2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:54	18:26	8:32	NFBC ISSUED
453	11-Jun-2021	HASSAN	110	HV1	JOG_110	11:14	12:14	1:00	LINE CLEAR AVAILED
454	11-Jun-2021	HASSAN	110	HV1	KONDENALU_110	7:48	12:49	5:01	LINE CLEAR AVAILED
455	11-Jun-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	20:32	20:38	0:06	LINE FAULT
456	11-Jun-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:41	14:59	0:18	LINE FAULT
457	11-Jun-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:59	16:44	1:45	LINE FAULT
458	11-Jun-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	17:00	17:15	0:15	LINE FAULT
459	11-Jun-2021	MYSURU	66	KR PETE 220-KR PETE 2	NO STATIONS EFFECTED	13:43	15:08	1:25	LINE CLEAR AVAILED
460	11-Jun-2021	MYSURU	66	HV1	THANDYA_66	21:11	21:15	0:03	TRANSFORMER FAULT
461	11-Jun-2021	MYSURU	66	HV2	THANDYA_66	20:22	23:22	2:59	TRANSFORMER FAULT
462	11-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
463	11-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
464	11-Jun-2021	TUMKUR	220	TR-1	ANTHRASANAHALI_220	8:52	18:45	9:53	LINE CLEAR AVAILED
465	11-Jun-2021	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	12:06	14:11	2:05	LINE FAULT
466	11-Jun-2021	TUMKUR	110	TR-2	KADEHALLI_110	18:33	18:43	0:10	LINE CLEAR AVAILED
467	11-Jun-2021	TUMKUR	110	TR-1	MAYASANDRA_110	10:40	11:18	0:38	LINE CLEAR AVAILED
468	11-Jun-2021	TUMKUR	66	TR-3	ANTHRASANAHALI_220	18:45	18:59	0:13	HAND TRIPPED
469	11-Jun-2021	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	8:14	8:22	0:07	HAND TRIPPED
470	11-Jun-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	13:06	13:18	0:11	LINE FAULT
471	11-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:18	16:04	2:46	LINE CLEAR AVAILED
472	11-Jun-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:10	14:17	0:06	LINE FAULT
473	11-Jun-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:01	12:09	0:08	LINE FAULT
474	11-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:50	11:53	0:03	LINE FAULT
475	11-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:33	12:35	0:01	LINE FAULT
476	11-Jun-2021	TUMKUR	66	TR-1	KORATAGERE_66	16:29	17:11	0:41	LINE CLEAR AVAILED
477	11-Jun-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	10:27	13:01	2:34	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
478	11-Jun-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	10:27	12:57	2:30	LINE CLEAR AVAILED
479	12-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT
480	12-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
481	12-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
482	12-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
483	12-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
484	12-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
485	12-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
486	12-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
487	12-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
488	12-Jun-2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVAILED
489	12-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
490	12-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
491	12-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED KAVALWADA_110	9:34 (11.06.2021)			LINE OPEN, LINE CLEAR AVAILED
492	12-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA1 (XELDOM)	STATION NOT AFFECTED AMBEWADI_220	17:00	19:34	2:34	LINE FAULT
493	12-Jun-2021	BAGALKOT	110	110/11KV, HV3	BIJAPUR CITY_110	17:55	18:06	0:11	TRANSFORMER FAULT
494	12-Jun-2021	BAGALKOT	110	110/33KV, HV2	CHIKKODI_110, KERUR_33, KAROSHI_33	11:37	11:44	0:07	TRANSFORMER FAULT
495	12-Jun-2021	BAGALKOT	110	GAJENDRAGAD- RON1&2	GAJENDRAGAD_110	10:56	11:43	0:47	LINE CLEAR AVAILED
496	12-Jun-2021	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	8:06	8:13	0:07	LINE FAULT
497	12-Jun-2021	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	9:44	10:15	0:31	HAND TRIPPED
498	12-Jun-2021	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	13:22	14:03	0:41	HAND TRIPPED
499	12-Jun-2021	BAGALKOT	110	HIREHAL-BADAMI	HIREHAL_110	11:45	12:02	0:17	HAND TRIPPED
500	12-Jun-2021	BAGALKOT	110	HIREHAL- MFR SOLAR	HIREHAL_110	10:01	10:15	0:14	HAND TRIPPED
501	12-Jun-2021	BAGALKOT	110	KERUR- BADAMI	BADAMI_110	11:24	12:57	1:33	LINE CLEAR AVAILED
502	12-Jun-2021	BAGALKOT	220	HAVERI- GUTTURI	HAVERI_220	10:42	12:56	2:14	LINE CLEAR AVAILED
503	12-Jun-2021	BAGALKOT	110	KIRUVATTI- SIRSI(KAVALWADA)	KIRUVATTI_110	11:36	23:56	12:20	LINE CLEAR AVAILED
504	12-Jun-2021	BAGALKOT	110	KARWAR220- ARG	ARGA_110	23:43 (12.06.2021)			LINE OPEN,LINE FAULT
505	12-Jun-2021	BAGALKOT	110	110/11KV, HV3	LAXMESHWAR_110, MMCL_33, SSM_33	6:01	7:03	1:02	TRANSFORMER FAULT
506	12-Jun-2021	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	23:35(12.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
507	12-Jun-2021	BAGALKOT	110	110/11KV, HV3	MUDHOL_110	11:47	11:50	0:03	HAND TRIPPED
508	12-Jun-2021	BAGALKOT	110	110/11KV, HV3	MUDHOL_110	13:17	13:54	0:37	TRANSFORMER FAULT
509	12-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UDYAMBAG_110	7:16	8:51	1:35	LINE CLEAR AVAILED
510	12-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TODALBAGI_110	15:40	18:15	2:35	LINE CLEAR AVAILED
511	12-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SAVALAGI_110	14:25	16:43	2:18	LINE CLEAR AVAILED
512	12-Jun-2021	BAGALKOT	110	110/33KV, HV3	KALABILAGI_33, TUNGLI_33, HIREPADASLAGI LIS_33 STATION NOT AFFECTED SAVALAGI_110	14:27	16:45	2:18	LINE CLEAR AVAILED
513	12-Jun-2021	BAGALKOT	110	RON-GAMESH	GAMESH IPP_110 RON_110	8:22	8:40	0:18	HAND TRIPPED
514	12-Jun-2021	BAGALKOT	110	RON-GAMESH	GAMESH IPP_110 RON_110	9:41	9:59	0:18	HAND TRIPPED
515	12-Jun-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	16:01	16:04	0:03	LOAD CHANGE OVER
516	12-Jun-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	17:30	17:32	0:02	LOAD CHANGE OVER
517	12-Jun-2021	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	10:39	11:00	0:21	MAIN SUPPLY FAILURE
518	12-Jun-2021	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	14:21	14:26	0:05	LOAD CHANGE OVER
519	12-Jun-2021	BENGALURU	66	HV3	BRINDAVANA 220	8:00	8:30	0:30	TRANSFORMER FAULT
520	12-Jun-2021	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	10:39	11:27	0:48	MAIN SUPPLY FAILURE
521	12-Jun-2021	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	13:18	13:21	0:03	LOAD CHANGE OVER
522	12-Jun-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	1:15	2:15	1:00	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
523	12-Jun-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	12:03	12:08	0:05	LOAD CHANGE OVER
524	12-Jun-2021	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	16:39	16:48	0:09	TRANSFORMER FAULT
525	12-Jun-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	1:16	1:36	0:20	LINE FAULT
526	12-Jun-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	1:36	2:16	0:40	LINE FAULT
527	12-Jun-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	6:00	6:21	0:21	LINE FAULT
528	12-Jun-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	8:17	8:22	0:05	LOAD CHANGE OVER
529	12-Jun-2021	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	7:51	7:54	0:03	LINE FAULT
530	12-Jun-2021	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	22:52	22:59	0:07	LOAD CHANGE OVER
531	12-Jun-2021	BENGALURU	66	IISC - HEBBAL 220	IISC	23:01	23:07	0:06	LOAD CHANGE OVER
532	12-Jun-2021	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	14:58	15:04	0:06	LINE FAULT
533	12-Jun-2021	BENGALURU	66	JAYADEVA - ADUGODI	NO STATION AFFECTED	14:58	17:47	2:49	LINE FAULT
534	12-Jun-2021	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI	KENGERI SATELLITE TOWN, SIR MV LAYOUT	10:45	11:25	0:40	MAIN SUPPLY FAILURE
535	12-Jun-2021	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN, SIR MV LAYOUT	14:16	14:25	0:09	LOAD CHANGE OVER
536	12-Jun-2021	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	14:38	16:15	1:37	LINE FAULT
537	12-Jun-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	22:40	22:44	0:04	LOAD CHANGE OVER
538	12-Jun-2021	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	14:55	15:06	0:11	LINE FAULT
539	12-Jun-2021	BENGALURU	66	HV2	REMC0	10:39	10:50	0:11	MAIN SUPPLY FAILURE
540	12-Jun-2021	BENGALURU	66	HV2	REMC0	14:09	14:11	0:02	LOAD CHANGE OVER
541	12-Jun-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	22:45	22:48	0:03	LOAD CHANGE OVER
542	12-Jun-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:15	14:30	0:15	LINE FAULT
543	12-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	15:04	15:23	0:19	LINE FAULT
544	12-Jun-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA	TK HALLI 220	13:14	13:37	0:23	LINE FAULT
545	12-Jun-2021	BENGALURU	66	HV1	REMC0	10:40	11:05	0:25	MAIN SUPPLY FAILURE
546	12-Jun-2021	BENGALURU	66	HV2	REMC0	11:55	12:00	0:05	LOAD CHANGE OVER
547	12-Jun-2021	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	10:39	13:20	2:41	MAIN SUPPLY FAILURE
548	12-Jun-2021	BENGALURU	220	VRISHBHAVATHI 220 - NRS 220	VRISHBHAVATHI 220	10:39	12:24	1:45	LINE FAULT
549	12-Jun-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	18:42	18:45	0:03	LOAD CHANGE OVER
550	12-Jun-2021	BENGALURU	66	NELAMANGALA 66 - DABUSPETE 220	NELAMANGALA 66	11:06	11:45	0:39	LOAD CHANGE OVER
551	12-Jun-2021	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	13:44	13:52	0:08	LOAD CHANGE OVER
552	12-Jun-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	7:05	7:09	0:03	LINE CLEAR AVAILED
553	12-Jun-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	7:05	7:09	0:03	LINE CLEAR AVAILED
554	12-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	7:05	7:09	0:03	LINE CLEAR AVAILED
555	12-Jun-2021	BENGALURU	66	HV1	MITTEMARI 220	6:58	7:01	0:02	LINE CLEAR AVAILED
556	12-Jun-2021	BENGALURU	66	HV2	MAASTHI	17:50	17:55	0:05	TRANSFORMER FAULT
557	12-Jun-2021	BENGALURU	66	HV2	KYALANUR	15:53	16:05	0:12	TRANSFORMER FAULT
558	12-Jun-2021	BENGALURU	66	HV1	HUKUNDA	7:15	7:20	0:04	TRANSFORMER FAULT
559	12-Jun-2021	BENGALURU	66	HV2	HUKUNDA	14:20	14:25	0:05	TRANSFORMER FAULT
560	12-Jun-2021	BENGALURU	66	HV2	HUKUNDA	13:35	13:40	0:05	TRANSFORMER FAULT
561	12-Jun-2021	BENGALURU	66	HV2	HUKUNDA	18:20	18:25	0:05	TRANSFORMER FAULT
562	12-Jun-2021	BENGALURU	66	HV1	BANGARPET	17:20	18:10	0:49	LINE CLEAR AVAILED
563	12-Jun-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:36	13:50	0:13	LINE FAULT
564	12-Jun-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:36	13:50	0:13	LINE FAULT
565	12-Jun-2021	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	15:53	16:05	0:12	LINE FAULT
566	12-Jun-2021	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	9:50	9:54	0:04	LOAD CHANGE OVER
567	12-Jun-2021	BENGALURU	66	HV1	CHINTAMANI 66	16:14	16:26	0:11	TRANSFORMER FAULT
568	12-Jun-2021	BENGALURU	66	HV2	DEVANAHALLI 66	18:07	18:15	0:07	TRANSFORMER FAULT
569	12-Jun-2021	BENGALURU	220	NELAMANGALA 400 - DABUSPETE 220	DABUSPETE 220	11:07	13:22	2:15	LINE FAULT
570	12-Jun-2021	BENGALURU	220	HV1	DABUSPETE 220	11:07	13:31	2:24	TRANSFORMER FAULT
571	12-Jun-2021	BENGALURU	220	HV2	DABUSPETE 220	11:07	14:48	3:41	TRANSFORMER FAULT
572	12-Jun-2021	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	11:07	15:18	4:11	MAIN SUPPLY FAILURE
573	12-Jun-2021	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	11:07	13:58	2:51	MAIN SUPPLY FAILURE
574	12-Jun-2021	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	11:07	13:52	2:45	MAIN SUPPLY FAILURE
575	12-Jun-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	11:07	13:50	2:43	MAIN SUPPLY FAILURE
576	12-Jun-2021	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	11:07	14:07	3:00	MAIN SUPPLY FAILURE
577	12-Jun-2021	BENGALURU	66	HV1	DABUSPETE 220	11:07	13:45	2:38	MAIN SUPPLY FAILURE
578	12-Jun-2021	BENGALURU	66	HV2	DABUSPETE 220	11:07	13:45	2:38	MAIN SUPPLY FAILURE
579	12-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	17:02:00(11-06-2021)	16:10(12-06-2021)	23:07HRS	LINE CHARGED
580	12-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	16:14(12-06-2021)			LINE OPEN,LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
581	12-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN, LINE CLEAR AVAILED
582	12-Jun-2021	GULBARGA	220	HV1	HUMNABAD_220	19:03	19:19	0:16	TRANSFORMER FAULT
583	12-Jun-2021	GULBARGA	110	HV1	NIRNA_110	9:00	9:05	0:05	TRANSFORMER FAULT
584	12-Jun-2021	GULBARGA	110	HV1	NIRNA_110	9:25	9:30	0:05	TRANSFORMER FAULT
585	12-Jun-2021	GULBARGA	110	HV1	NIRNA_110	14:45	14:52	0:07	TRANSFORMER FAULT
586	12-Jun-2021	GULBARGA	110	HV1	SHORAPUR_110	15:40	15:58	0:18	LINE CLEAR AVAILED
587	12-Jun-2021	GULBARGA	110	HV1	SHORAPUR_110	16:05	16:33	0:28	LINE CLEAR AVAILED
588	12-Jun-2021	GULBARGA	110	HV2	SHORAPUR_110	11:30	16:33	5:03	LINE CLEAR AVAILED
589	12-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	8:50	9:33	0:43	MAIN SUPPLY FAILURE
590	12-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	16:29	16:38	0:09	TRANSFORMER FAULT
591	12-Jun-2021	GULBARGA	110	HV2	SANKLAPUR_110	16:30	16:39	0:09	TRANSFORMER FAULT
592	12-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	17:40	17:50	0:10	TRANSFORMER FAULT
593	12-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	20:00	20:08	0:08	TRANSFORMER FAULT
594	12-Jun-2021	GULBARGA	110	KUSHATGI-HANUMSAGAR	HANUMASAGAR_110	10:15	10:20	0:05	LINE FAULT
595	12-Jun-2021	GULBARGA	110	KUSHATGI-HANUMSAGAR	HANUMASAGAR_110	10:55	11:05	0:10	LINE FAULT
596	12-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:44	19:48	0:04	LINE FAULT
597	12-Jun-2021	GULBARGA	110	SHAHPUR-NALWAR	NALWAR_110	5:20	5:40	0:20	LINE FAULT
598	12-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	18:38	18:42	0:04	LINE FAULT
599	12-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	1:30	1:40	0:10	LINE FAULT
600	12-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	18:42	18:47	0:05	LINE FAULT
601	12-Jun-2021	GULBARGA	66	HV3	KUDLIGI_66	15:00	15:10	0:10	TRANSFORMER FAULT
602	12-Jun-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	15:37	16:00	0:23	TRANSFORMER FAULT
603	12-Jun-2021	GULBARGA	66	HV1	CHORNOOR_66	17:29	17:45	0:16	LINE CLEAR AVAILED
604	12-Jun-2021	GULBARGA	66	HV1	ITTAGI_220	10:22	10:28	0:06	TRANSFORMER FAULT
605	12-Jun-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	19:56 (12.06.2021)			LINE OPEN,LINE FAULT
606	12-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:11	15:25	6:14	LINE CLEAR AVAILED
607	12-Jun-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:12	15:28	6:16	LINE CLEAR AVAILED
608	12-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:11	15:25	6:14	NFBC ISSUED
609	12-Jun-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:12	15:28	6:16	NFBC ISSUED
610	12-Jun-2021	HASSAN	110	HV1	BANAVARA_110	14:15	16:00	1:45	LINE CLEAR AVAILED
611	12-Jun-2021	HASSAN	110	HV1	MANIPAL_110	21:37	21:51	0:14	TRANSFORMER FAULT
612	12-Jun-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	16:40	18:18	1:38	NFBC ISSUED
613	12-Jun-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	20:24	21:55	1:31	MAIN SUPPLY FAILURE
614	12-Jun-2021	HASSAN	66	HV1	DUDDA_66	13:11	13:22	0:11	TRANSFORMER FAULT
615	12-Jun-2021	MYSURU	66	JAKKANAHALLI-NAGMANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	16:42	16:49	0:07	LINE FAULT
616	12-Jun-2021	MYSURU	66	HV2	THANDYA_66	7:34	8:35	1:00	LINE CLEAR AVAILED
617	12-Jun-2021	MYSURU	66	HV2	JAKKANAHALLY_66	15:02	15:16	0:14	TRANSFORMER FAULT
618	12-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
619	12-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
620	12-Jun-2021	TUMKUR	220	TR-3	HIRIYUR_220	13:37	13:45	0:07	TRANSFORMER FAULT
621	12-Jun-2021	TUMKUR	220	TR-2	HIRIYUR_220	13:37	13:45	0:07	TRANSFORMER FAULT
622	12-Jun-2021	TUMKUR	66	TR-1	GULIGENAHALLI_66	14:30	14:40	0:10	TRANSFORMER FAULT
623	12-Jun-2021	TUMKUR	66	TR-2	GULIGENAHALLI_66	13:03	13:55	0:51	LINE CLEAR AVAILED
624	12-Jun-2021	TUMKUR	66	TR-2	GUTTUR_66	16:56	17:29	0:33	TRANSFORMER FAULT
625	12-Jun-2021	TUMKUR	66	TR-2	GUTTUR_66	17:34	17:58	0:23	TRANSFORMER FAULT
626	12-Jun-2021	TUMKUR	66	TR-2	GUTTUR_66	14:50	15:10	0:20	TRANSFORMER FAULT
627	12-Jun-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	13:48	14:00	0:11	MAIN SUPPLY FAILURE
628	12-Jun-2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:42	14:05	0:23	LINE FAULT
629	12-Jun-2021	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:37	13:45	0:07	HAND TRIPPED
630	12-Jun-2021	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON2_IPP_66	13:37	13:45	0:07	HAND TRIPPED
631	12-Jun-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	13:37	13:45	0:07	HAND TRIPPED
632	12-Jun-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	13:37	13:45	0:07	HAND TRIPPED
633	12-Jun-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON2_IPP_66	ENERCON2_IPP_66	13:37	13:45	0:07	HAND TRIPPED
634	12-Jun-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	13:40	13:50	0:09	LINE FAULT
635	12-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:01	10:21	0:19	LOAD CURTAILMENT
636	12-Jun-2021	TUMKUR	66	TR-2	HONNUDIKE_66	15:20	15:41	0:21	LINE CLEAR AVAILED
637	12-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:27	10:31	0:03	LINE FAULT
638	12-Jun-2021	TUMKUR	66	TR-1	KUNDUR_66	13:04	13:12	0:07	TRANSFORMER FAULT
639	12-Jun-2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	19:45	20:17	0:32	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
640	12-Jun-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	13:17	13:28	0:11	LINE FAULT
641	12-Jun-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	17:50	18:05	0:15	LINE CLEAR AVAILED
642	12-Jun-2021	TUMKUR	66	PDKOTE_66-CLEAR SOLAR	CLEAR SOLAR_66	16:40	16:45	0:05	LINE FAULT
643	12-Jun-2021	TUMKUR	66	SANIKERE- HIRIYUR	SANIKERE_66	17:05	17:10	0:05	MAIN SUPPLY FAILURE
644	13-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT
645	13-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
646	13-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
647	13-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
648	13-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
649	13-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
650	13-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
651	13-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
652	13-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
653	13-Jun-2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVAILED
654	13-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
655	13-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
656	13-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED KAVALWADA_110	9:34 (11.06.2021)			LINE OPEN, LINE CLEAR AVAILED
657	13-Jun-2021	BAGALKOT	110	KARWAR220- ARGA	ARGA_110	23:43 (12.06.2021)	12:13 (13.06.2021)	12:30HRS	LINE CHARGED
658	13-Jun-2021	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	23:35(12.06.2021)	10:01(13.06.2021)	10:26HRS	TRANSFORMER CHARGED
659	13-Jun-2021	BAGALKOT	110	ANKOLA- ARGA	ANKOLA_110	12:25	12:29	0:04	HAND TRIPPED
660	13-Jun-2021	BAGALKOT	110	KUDAL SANGAM- HUNGUND	KUDAL SANGAM_110	13:29	13:31	0:02	HAND TRIPPED
661	13-Jun-2021	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	13:30	13:37	0:07	LINE CLEAR AVAILED
662	13-Jun-2021	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	13:51	14:43	0:52	TRANSFORMER FAULT
663	13-Jun-2021	BAGALKOT	110	110/11KV, HV1	RATTIHALLI_110	7:14	7:19	0:05	TRANSFORMER FAULT
664	13-Jun-2021	BENGALURU	66	BIEC - SRS PEENYA 220	BIEC	6:05	6:19	0:14	LOAD CHANGE OVER
665	13-Jun-2021	BENGALURU	66	BIEC - YELAHANKA 220	BIEC	14:03	14:14	0:11	LOAD CHANGE OVER
666	13-Jun-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	11:56	12:34	0:38	MAIN SUPPLY FAILURE
667	13-Jun-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	16:19	16:29	0:10	MAIN SUPPLY FAILURE
668	13-Jun-2021	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	13:36	13:42	0:06	LOAD CHANGE OVER
669	13-Jun-2021	BENGALURU	66	IISC - NRS 220	IISC	14:08	14:11	0:03	LOAD CHANGE OVER
670	13-Jun-2021	BENGALURU	66	HV2	KADUGODI	12:51	12:55	0:04	TRANSFORMER FAULT
671	13-Jun-2021	BENGALURU	66	HV1	KOTIPURA 220	8:30	9:30	1:00	LINE CLEAR AVAILED
672	13-Jun-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	7:02	7:07	0:05	LOAD CHANGE OVER
673	13-Jun-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	15:15	15:20	0:05	LOAD CHANGE OVER
674	13-Jun-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	13:58	14:03	0:05	LOAD CHANGE OVER
675	13-Jun-2021	BENGALURU	220	NAGNATHPURA 220 - SOMANAHALLI 220	NAGNATHPURA 220	11:54	12:26	0:32	LINE FAULT
676	13-Jun-2021	BENGALURU	220	NAGNATHPURA 220 - HSR LAYOUT 220	NAGNATHPURA 220	15:25	15:36	0:11	LOAD CHANGE OVER
677	13-Jun-2021	BENGALURU	220	NAGNATHPURA 220 - SOMANAHALLI 220	NAGNATHPURA 220	16:08	16:25	0:17	LINE FAULT
678	13-Jun-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	11:54	12:27	0:33	LINE CLEAR AVAILED
679	13-Jun-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT)	11:54	12:27	0:33	LINE CLEAR AVAILED
680	13-Jun-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	16:08	16:26	0:18	LINE CLEAR AVAILED
681	13-Jun-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT)	16:08	16:26	0:18	LINE CLEAR AVAILED
682	13-Jun-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	5:15	5:20	0:05	LOAD CHANGE OVER
683	13-Jun-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	12:32	12:37	0:05	LOAD CHANGE OVER
684	13-Jun-2021	BENGALURU	66	HV2	RESCO	12:16	12:26	0:10	MAIN SUPPLY FAILURE
685	13-Jun-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	13:51	13:54	0:03	LOAD CHANGE OVER
686	13-Jun-2021	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NO STATION AFFECTED	11:53	15:15	3:22	LINE FAULT
687	13-Jun-2021	BENGALURU	66	HV1	VIJAYANAGARA	12:16	12:24	0:08	MAIN SUPPLY FAILURE
688	13-Jun-2021	BENGALURU	66	HV1	VIJAYANAGARA	15:14	15:18	0:04	LOAD CHANGE OVER
689	13-Jun-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	3:55	4:15	0:20	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
690	13-Jun-2021	BENGALURU	66	SARAKKI - JAYADEVA 1 & 2	SARAKKI	6:30	6:41	0:11	LOAD CHANGE OVER
691	13-Jun-2021	BENGALURU	66	ALUR - PEENYA 220	ALUR	5:40	5:50	0:10	LOAD CHANGE OVER
692	13-Jun-2021	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	14:25	14:30	0:05	LOAD CHANGE OVER
693	13-Jun-2021	BENGALURU	66	HV1	MELUR	11:22	12:24	1:02	TRANSFORMER FAULT
694	13-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	20:45	21:01	0:15	TRANSFORMER FAULT
695	13-Jun-2021	BENGALURU	66	HV1	BANGARPET	13:33	14:10	0:36	LINE CLEAR AVAILED
696	13-Jun-2021	BENGALURU	66	HV2	ATTIBELE	14:00	15:26	1:26	LINE CLEAR AVAILED
697	13-Jun-2021	BENGALURU	220	KOLAR 220 - PGCIL 2	NO STATION AFFECTED	8:41	13:47	5:06	LINE CLEAR AVAILED
698	13-Jun-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	0:06	0:13	0:06	LINE FAULT
699	13-Jun-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:01	10:26	0:24	LINE FAULT
700	13-Jun-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE, BIJJAHALLI, KUNUR	11:35	12:04	0:29	LINE FAULT
701	13-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	23:37:42(13-06-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
702	13-Jun-2021	BENGALURU	220	NELAMANGALA 400 - HIRIYUR 400	NO STATION AFFECTED	03:54:45(13-06-2021)			LINE OPEN,LINE FAULT
703	13-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	16:14(12-06-2021)			LINE OPEN,LINE FAULT
704	13-Jun-2021	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NO STATION AFFECTED	16:08(13/06/2021)			LINE OPEN,LINE FAULT
705	13-Jun-2021	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN,LINE FAULT
706	13-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN, LINE CLEAR AVAILED
707	13-Jun-2021	GULBARGA	110	HV2	TEKKALKOTE_110	16:25	16:40	0:15	TRANSFORMER FAULT
708	13-Jun-2021	GULBARGA	110	SHAHAPUR-SEDAM	SEDAM_220	0:51	6:06	5:15	LINE CLEAR AVAILED
709	13-Jun-2021	GULBARGA	110	SEDAM-HUMNABAD2	HUMNABAD_220	1:35	6:03	4:28	LINE CLEAR AVAILED
710	13-Jun-2021	GULBARGA	110	HV2	DEODURGA_110	15:25	15:35	0:10	TRANSFORMER FAULT
711	13-Jun-2021	GULBARGA	110	KOLHAR-SHAHISLR	SHAHISLR_IPP	12:15	12:20	0:05	LINE FAULT
712	13-Jun-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	23:40	23:50	0:10	LINE FAULT
713	13-Jun-2021	GULBARGA	110	KAPNOOR-HUMNABAD LINE1	MAHAGAON_110,MARGUTTI_110	11:27	11:54	0:27	LINE FAULT
714	13-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	4:10	5:40	1:30	TRANSFORMER FAULT
715	13-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	5:50	6:00	0:10	LINE CLEAR AVAILED
716	13-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	6:00	6:35	0:35	TRANSFORMER FAULT
717	13-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	6:55	7:00	0:05	LINE CLEAR AVAILED
718	13-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	10:00	10:05	0:05	TRANSFORMER FAULT
719	13-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	11:10	11:20	0:10	TRANSFORMER FAULT
720	13-Jun-2021	GULBARGA	66	HV2,HV1	TAMBRAHALLI_66	3:05	4:15	1:10	TRANSFORMER FAULT
721	13-Jun-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	7:55	8:20	0:25	LINE CLEAR AVAILED
722	13-Jun-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	6:30	6:35	0:05	TRANSFORMER FAULT
723	13-Jun-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	9:30	9:35	0:05	LINE CLEAR AVAILED
724	13-Jun-2021	GULBARGA	66	HV1	GUDEKOTE_66	19:26	19:35	0:09	TRANSFORMER FAULT
725	13-Jun-2021	GULBARGA	66	HV1	GUDEKOTE_66	16:49	17:05	0:16	TRANSFORMER FAULT
726	13-Jun-2021	GULBARGA	66	HV1	HANASI_66	5:09	5:20	0:11	LINE CLEAR AVAILED
727	13-Jun-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	19:56 (12.06.2021)	9:51 (13.06.2021)	13:55hrs	LINE CHARGED
728	13-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:06 (13.06.2021)			LINE OPEN, LINE CLEAR AVAILED
729	13-Jun-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	23:16 (13.06.2021)			LINE OPEN, LINE CLEAR AVAILED
730	13-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	23:08(13.6.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
731	13-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	23:08(13.6.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
732	13-Jun-2021	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	23:08(13.6.2021)			LINE OPEN, LINE CLEAR AVAILED
733	13-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	23:08(13.6.2021)			LINE OPEN, LINE CLEAR AVAILED
734	13-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	23:08(13.6.2021)			LINE OPEN,LINE FAULT
735	13-Jun-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	23:08(13.6.2021)			LINE OPEN, LINE CLEAR AVAILED
736	13-Jun-2021	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	12:06	12:27	0:21	LINE FAULT
737	13-Jun-2021	HASSAN	110	HV2	ANANDPURA_110	11:02	11:22	0:20	TRANSFORMER FAULT
738	13-Jun-2021	HASSAN	110	HV1	BANAVARA_110	9:05	14:05	5:00	LINE CLEAR AVAILED
739	13-Jun-2021	HASSAN	110	HV1	BIRUR_110	16:27	16:32	0:05	TRANSFORMER FAULT
740	13-Jun-2021	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	13:15	14:01	0:46	LINE FAULT
741	13-Jun-2021	HASSAN	110	HV1	JAVAGAL_110	12:30	13:36	1:06	LINE CLEAR AVAILED
742	13-Jun-2021	HASSAN	110	HV2	SHIRALKOPPA_110	1:10	7:11	6:01	TRANSFORMER FAULT
743	13-Jun-2021	HASSAN	110	HV2	SHIRALKOPPA_110	10:16	10:30	0:14	TRANSFORMER FAULT
744	13-Jun-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	20:19	20:50	0:31	LINE FAULT
745	13-Jun-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	8:00	9:35	1:35	NFBC ISSUED
746	13-Jun-2021	MYSURU	66	HV2	BANNIMANTAP_66	11:46	11:52	0:05	HAND TRIPPED
747	13-Jun-2021	MYSURU	66	HV2	BETTADHAPURA_66	13:03	13:20	0:16	LINE CLEAR AVAILED
748	13-Jun-2021	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	12:07	12:24	0:17	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
749	13-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
750	13-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
751	13-Jun-2021	TUMKUR	220	TR-3	ANTHRASANAHALI_220	10:25	10:52	0:27	LINE CLEAR AVAILED
752	13-Jun-2021	TUMKUR	66	TR-1	ANTHRASANAHALI_220	10:26	10:55	0:28	HAND TRIPPED
753	13-Jun-2021	TUMKUR	66	TR-2	ANTHRASANAHALI_220	10:26	11:56	1:30	LINE CLEAR AVAILED
754	13-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	0:01	0:16	0:15	LINE FAULT
755	13-Jun-2021	TUMKUR	66	TR-3	HARIYABBE_66	22:35	22:57	0:22	LINE CLEAR AVAILED
756	13-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:04	6:26	0:22	LINE FAULT
757	13-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:34	13:35	1:00	LINE CLEAR AVAILED
758	13-Jun-2021	TUMKUR	66	PANDARAHALLI- HOLALKERE66	HOLALKERE_66, RAMAGIRI_66, CHITRAHALI_66, HDPURA_66,	6:04	6:13	0:09	LINE FAULT
759	13-Jun-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	6:31	6:33	0:02	HAND TRIPPED
760	13-Jun-2021	TUMKUR	66	TR-1	DYAVARANAHALI_66	8:00	8:45	0:45	LINE CLEAR AVAILED
761	14-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT
762	14-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
763	14-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
764	14-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
765	14-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
766	14-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
767	14-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
768	14-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
769	14-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
770	14-Jun-2021	BAGALKOT	110	JAMAKAHANDI-(PRABHULINGESHWAR) SIDDAPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:12(04.06.2021)			LINE OPEN, LINE CLEAR AVAILED
771	14-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
772	14-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02(10.06.2021)			LINE OPEN, LINE CLEAR AVAILED
773	14-Jun-2021	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:34 (11.06.2021)			LINE OPEN, LINE CLEAR AVAILED
774	14-Jun-2021	BAGALKOT	110	SUPA1-AMBEWADI 220	STATION NOT AFFECTED AMBEWADI_220	22:34	22:50	0:16	LINE FAULT
775	14-Jun-2021	BAGALKOT	220	220/110KV,HV1 ,LV1	STATION NOT AFFECTED BAGALKOT_220	11:55	12:39	0:44	TRANSFORMER FAULT
776	14-Jun-2021	BAGALKOT	220	BAGALKOT-VJRM TI1	STATION NOT AFFECTED BAGALKOT_220	11:55	12:53	0:58	LINE FAULT
777	14-Jun-2021	BAGALKOT	220	BAGALKOT-VJRM TI2	STATION NOT AFFECTED BAGALKOT_220	11:55	12:54	0:59	LINE FAULT
778	14-Jun-2021	BAGALKOT	110	BAGALKOT-F4 NAVANAGAR 2	NAVANAGAR_110	12:09	13:23	1:14	LINE FAULT
779	14-Jun-2021	BAGALKOT	110	BAGALKOT-F3 NAVANAGAR1	NAVANAGAR_110	12:18	12:33	0:15	HAND TRIPPED
780	14-Jun-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	11:56	13:09	1:13	LINE FAULT
781	14-Jun-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	STATION NOT AFFECTED VAJRAMATTI_220	11:56	13:09	1:13	LINE CLEAR AVAILED
782	14-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_110	7:36	7:43	0:07	TRANSFORMER FAULT
783	14-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_110	14:48	14:57	0:09	TRANSFORMER FAULT
784	14-Jun-2021	BAGALKOT	110	110/11KV, HV3 (HV4)	STATION NOT AFFECTED TODALBAGI_110	15:36	16:28	0:52	TRANSFORMER FAULT
785	14-Jun-2021	BAGALKOT	110	110/11KV, HV1	HIDIKAL_110	19:09	19:10	0:01	TRANSFORMER FAULT
786	14-Jun-2021	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAYANAGAR_110	13:15	13:29	0:14	LINE CLEAR AVAILED
787	14-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29(14.06.2021)			LINE OPEN, LINE CLEAR AVAILED
788	14-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT1	STATION NOT AFFECTED NAVANAGAR(B)_110	9:50(07.04.2021)	12:27(14.06.2021)	1634:37HRS	LINE CHARGED
789	14-Jun-2021	BENGALURU	66	HV1	AMAR JYOTHI	16:54	17:00	0:06	LINE CLEAR AVAILED
790	14-Jun-2021	BENGALURU	66	HV1	GOKULA	12:30	14:30	2:00	TRANSFORMER FAULT
791	14-Jun-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	12:06	12:10	0:04	LINE CLEAR AVAILED
792	14-Jun-2021	BENGALURU	66	HV2	KHB	21:12	21:22	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
793	14-Jun-2021	BENGALURU	220	MYLSANDRA 400 - YARANDANAHALLI 220	YARANDANAHALLI 220	15:07	16:14	1:07	LINE FAULT
794	14-Jun-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	15:30	15:36	0:06	LOAD CHANGE OVER
795	14-Jun-2021	BENGALURU	220	YARANDANAHALLI 220 - MYLSANDRA 400	YARANDANAHALLI 220	15:07	16:15	1:08	MAIN SUPPLY FAILURE
796	14-Jun-2021	BENGALURU	220	HV2	YARANDANAHALLI 220	15:07	16:17	1:10	TRANSFORMER FAULT
797	14-Jun-2021	BENGALURU	220	HV3	YARANDANAHALLI 220	15:07	16:17	1:10	TRANSFORMER FAULT
798	14-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:07	15:50	0:43	LINE FAULT
799	14-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	15:07	16:26	1:19	LINE CLEAR AVAILED
800	14-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	15:07	15:40	0:33	LINE CLEAR AVAILED
801	14-Jun-2021	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	15:07	15:50	0:43	LINE CLEAR AVAILED
802	14-Jun-2021	BENGALURU	220	JIGANI 220 - MYLSANDRA 220	JIGANI 220	15:07	15:58	0:51	LINE FAULT
803	14-Jun-2021	BENGALURU	220	JIGANI 220 - JIGANI 66	JIGANI 220	16:32	16:40	0:08	LOAD CHANGE OVER
804	14-Jun-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	15:07	16:40	1:33	MAIN SUPPLY FAILURE
805	14-Jun-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	15:07	15:50	0:43	MAIN SUPPLY FAILURE
806	14-Jun-2021	BENGALURU	66	JIGANI 66 - SOMANAHALLI 220	JIGANI 66	16:32	16:42	0:10	LOAD CHANGE OVER
807	14-Jun-2021	BENGALURU	66	JIGANI 220 - JIGANI LINK ROAD	JIGANI LINK ROAD	15:07	15:17	0:10	MAIN SUPPLY FAILURE
808	14-Jun-2021	BENGALURU	66	KYALANUR - TALAGWARA	NO STATION AFFECTED	10:45	11:10	0:25	LINE CLEAR AVAILED
809	14-Jun-2021	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	15:10	15:20	0:10	LINE FAULT
810	14-Jun-2021	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	16:40	16:45	0:05	LOAD CHANGE OVER
811	14-Jun-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	NO STATION AFFECTED	12:01	14:46	2:45	LINE CLEAR AVAILED
812	14-Jun-2021	BENGALURU	66	HV1	BANGARPET	7:49	8:40	0:50	LINE CLEAR AVAILED
813	14-Jun-2021	BENGALURU	66	HV2	MAASTHI	10:45	10:56	0:11	TRANSFORMER FAULT
814	14-Jun-2021	BENGALURU	66	HV2	MAASTHI	13:35	14:00	0:25	TRANSFORMER FAULT
815	14-Jun-2021	BENGALURU	66	HV2	MAASTHI	15:39	16:35	0:55	LINE CLEAR AVAILED
816	14-Jun-2021	BENGALURU	66	HV2	KYALANUR	15:10	17:00	1:03	TRANSFORMER FAULT
817	14-Jun-2021	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	14:01	15:39	1:37	LINE CLEAR AVAILED
818	14-Jun-2021	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	15:40	15:52	0:12	LINE CLEAR AVAILED
819	14-Jun-2021	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	NO STATION AFFECTED	16:02	17:05	1:03	LINE CLEAR AVAILED
820	14-Jun-2021	BENGALURU	400	NELAMANGALA 400 - TALGUPPA 400	NO STATION AFFECTED	9:37	11:42	1:03	LINE CLEAR AVAILED
821	14-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	23:37:42(13-06-2021)	14:05(14-06-2021)	14:26HRS	TRANSFORMER CHARGED
822	14-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 400	NO STATION AFFECTED	03:54:45(13-06-2021)	7:15(14-06-2021)	27:19HRS	LINE CHARGED
823	14-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	16:14(12-06-2021)	12:40(14-06-2021)	44:24HRS	LINE CHARGED
824	14-Jun-2021	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NO STATION AFFECTED	16:08(13/06/2021)	15:08(14/06/2021)	23:00HRS	LINE CHARGED
825	14-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN,LINE FAULT
826	14-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
827	14-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	13:47(14-06-2021)			LINE OPEN,LINE FAULT
828	14-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)	18:16(14.06.2021)	220:31HRS	LINE CHARGED
829	14-Jun-2021	GULBARGA	110	HV2	DEODURGA_110	11:50	15:20	3:30	LINE CLEAR AVAILED
830	14-Jun-2021	GULBARGA	110	HV3	GULBARGASOUTH_110	10:30(14.06.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
831	14-Jun-2021	GULBARGA	0:00	RAICHUR-SHAHAPUR2	GOOGLE_110	20:41	20:50	0:09	LINE FAULT
832	14-Jun-2021	GULBARGA	110	HV1	NALWAR_110	16:55	17:15	0:20	LINE CLEAR AVAILED
833	14-Jun-2021	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	23:57(14.06.2021)			MAIN SUPPLY FAILURE
834	14-Jun-2021	GULBARGA	0:00	GURUMITAKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	20:37	20:45	0:08	LINE FAULT
835	14-Jun-2021	GULBARGA	0:00	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	5:52	5:56	0:04	LINE FAULT
836	14-Jun-2021	GULBARGA	0:00	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSKSUGAR FACTORY	5:56	6:19	0:23	LINE FAULT
837	14-Jun-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSKSUGAR FACTORY	15:19	16:15	0:56	LINE CLEAR AVAILED
838	14-Jun-2021	GULBARGA	110	HV1	HALBARGA_220	16:33	16:58	0:25	LINE CLEAR AVAILED
839	14-Jun-2021	GULBARGA	0:00	HV1	CHORNOOR_66	19:18	19:25	0:07	TRANSFORMER FAULT
840	14-Jun-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	10:20	11:55	1:35	LINE CLEAR AVAILED
841	14-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:16(14.06.2021)			LINE OPEN, LINE CLEAR AVAILED
842	14-Jun-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	23:08(13.6.2021)	4:56(14.6.2021)	5:48hrs	LINE CHARGED
843	14-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	23:08(13.6.2021)	15:48(15.06.2021)	16:40hrs	LINE CHARGED
844	14-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	23:08(13.6.2021)	4:54(14.6.2021)	5:46hrs	LINE CHARGED
845	14-Jun-2021	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	23:08(13.6.2021)	5:15(14.6.2021)	6:07hrs	LINE CHARGED
846	14-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	23:08(13.6.2021)	5:15(14.6.2021)	6:07hrs	TRANSFORMER CHARGED
847	14-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	23:08(13.6.2021)	5:15(14.6.2021)	6:07hrs	TRANSFORMER CHARGED
848	14-Jun-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	23:16 (13.06.2021)	5:17(14.6.2021)	6:01hrs	LINE CHARGED
849	14-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:06 (13.06.2021)	6:30(14.06.2021)	7:24hrs	LINE CHARGED
850	14-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALGUPPA_400	9:37	11:42	2:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
851	14-Jun-2021	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	10:35	14:59	4:24	LINE CLEAR AVAILED
852	14-Jun-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:35	14:59	4:24	NFBC ISSUED
853	14-Jun-2021	HASSAN	110	HV1	BARANGI_110	11:10	12:25	1:15	LINE CLEAR AVAILED
854	14-Jun-2021	HASSAN	110	HV2	BARANGI_110	11:15	12:30	1:15	LINE CLEAR AVAILED
855	14-Jun-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	15:00	15:45	0:45	HAND TRIPPED
856	14-Jun-2021	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJANUR_110	11:05	11:15	0:10	MAIN SUPPLY FAILURE
857	14-Jun-2021	HASSAN	110	HV1	GURUVAYANAKERE_110	12:36	13:17	0:41	LINE CLEAR AVAILED
858	14-Jun-2021	HASSAN	110	HV1	HOSUR_110	13:20	13:29	0:09	HAND TRIPPED
859	14-Jun-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:17	12:28	1:11	LINE CLEAR AVAILED
860	14-Jun-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	11:17	12:28	1:11	NFBC ISSUED
861	14-Jun-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	11:13	15:45	4:32	LINE CLEAR AVAILED
862	14-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	4:58	5:16	0:18	HAND TRIPPED
863	14-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	11:53	13:23	1:30	LINE CLEAR AVAILED
864	14-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	11:53	13:23	1:30	LINE CLEAR AVAILED
865	14-Jun-2021	HASSAN	110	NANDIKU-ISTR1	NANDIKUR_110	11:53	13:28	1:35	LINE CLEAR AVAILED
866	14-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	4:58	5:16	0:18	HAND TRIPPED
867	14-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	11:53	13:23	1:30	LINE CLEAR AVAILED
868	14-Jun-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	4:58	5:16	0:18	HAND TRIPPED
869	14-Jun-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	11:53	13:23	1:30	LINE CLEAR AVAILED
870	14-Jun-2021	HASSAN	66	HV1	KANDLI_66	12:01	17:10	5:09	LINE CLEAR AVAILED
871	14-Jun-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:07	12:23	0:16	LINE FAULT
872	14-Jun-2021	MYSURU	66	HV1	CHIKKA_MANDYA_66	6:30	8:00	1:30	TRANSFORMER FAULT
873	14-Jun-2021	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	5:57	6:05	0:07	LINE FAULT
874	14-Jun-2021	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66, , KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	11:25	11:43	0:17	LINE FAULT
875	14-Jun-2021	MYSURU	66	KUSHALNAGARA-MADIKERI	NO STATIONS EFFECTED	16:52	18:05	1:13	LINE FAULT
876	14-Jun-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66,VIRAJPET_66	11:49	11:58	0:09	LINE FAULT
877	14-Jun-2021	MYSURU	66	HV2	PERIYAPATNA_66	11:05	13:32	2:26	LINE CLEAR AVAILED
878	14-Jun-2021	MYSURU	66	SUNTIKOPPA-MADIKERI	MADIKERI_66	16:56	17:03	0:07	LINE FAULT
879	14-Jun-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	4:35	4:43	0:07	LINE FAULT
880	14-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
881	14-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN, LINE CLEAR AVAILED
882	14-Jun-2021	TUMKUR	220	TR-2	ANCHEPALYA_220	13:05	13:19	0:14	LINE CLEAR AVAILED
883	14-Jun-2021	TUMKUR	220	TR-2(HV SIDE)	KIADB V N PURA_220	10:36	13:07	2:31	LINE CLEAR AVAILED
884	14-Jun-2021	TUMKUR	110	TR-1	MAYASANDRA_110	10:10	18:43	8:32	LINE CLEAR AVAILED
885	14-Jun-2021	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	13:05	13:19	0:14	LINE CLEAR AVAILED
886	14-Jun-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	11:27	11:33	0:05	TRANSFORMER FAULT
887	14-Jun-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	9:30	9:41	0:10	TRANSFORMER FAULT
888	14-Jun-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:19	13:32	0:12	TRANSFORMER FAULT
889	14-Jun-2021	TUMKUR	66	TR-3	HARIYABBE_66	17:03	17:57	0:54	LINE CLEAR AVAILED
890	14-Jun-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	7:13	7:55	0:42	TRANSFORMER FAULT
891	14-Jun-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	11:31	14:04	2:33	LINE CLEAR AVAILED
892	14-Jun-2021	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	11:31	14:04	2:33	LINE CLEAR AVAILED
893	14-Jun-2021	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	15:48	16:16	0:27	LINE CLEAR AVAILED
894	14-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:23	8:39	0:15	LINE FAULT
895	14-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:07	9:42	0:35	LINE FAULT
896	14-Jun-2021	TUMKUR	66	TR-2	HONNUDIKE_66	11:05	11:08	0:03	HAND TRIPPED
897	14-Jun-2021	TUMKUR	66	TR-2	HONNUDIKE_66	14:15	18:15	4:00	LINE CLEAR AVAILED
898	14-Jun-2021	TUMKUR	66	TR-1	HONNUDIKE_66	14:15	18:15	4:00	LINE CLEAR AVAILED
899	14-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	13:32	14:56	1:23	LINE CLEAR AVAILED
900	14-Jun-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	11:24	11:32	0:07	MAIN SUPPLY FAILURE
901	14-Jun-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	10:36	10:40	0:03	TRANSFORMER FAULT
902	14-Jun-2021	TUMKUR	66	TR-1	NIDSALE_66	14:43	14:55	0:11	HAND TRIPPED
903	14-Jun-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA	PAVAGADA_220	12:23	13:54	1:30	LINE CLEAR AVAILED
904	14-Jun-2021	TUMKUR	66	SHYLAPURA- MADHUGIRI	YNHOSKOTE_66, MANGALWADA_66,LINGDHALLI_66	12:24	16:07	3:43	LINE CLEAR AVAILED