

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 12.02.2019 to 18.02.2019

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1	12-Feb-19	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAWALWAD_110	14:39	15:14	0:35	LINE CLEAR AVAILED
2	12-Feb-19	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	HALIYAL_110	14:41	23:59	9:18	LINE FAULT
3	12-Feb-19	BAGALKOT	110	AMBEWADI-SUPA2	AMBEWADI_220	14:58	15:25	0:27	LINE CLEAR AVAILED
4	12-Feb-19	BAGALKOT	110	AMBEWADI-SUPA1	AMBEWADI_220	14:58	15:15	0:17	LINE CLEAR AVAILED
5	12-Feb-19	BAGALKOT	110	110/33KV,HV3	ANKALI_110,NANDIKURALI 33KV	9:39	14:48	5:09	LINE CLEAR AVAILED
6	12-Feb-19	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR_110	10:19	15:07	4:48	LINE CLEAR AVAILED
7	12-Feb-19	BAGALKOT	110	110/11KV,HV2	TORVI_110	16:33	16:42	0:09	HAND TRIPPED
8	12-Feb-19	BAGALKOT	110	110/11KV,HV2	TORVI_110	20:13	20:14	0:01	HAND TRIPPED
9	12-Feb-19	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110	11:45	12:05	0:20	LINE FAULT
10	12-Feb-19	BAGALKOT	220	NARENDRA2-BELGAUM220	BELGAUM_220	16:42	19:08	2:26	LINE CLEAR AVAILED
11	12-Feb-19	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	20:19	23:59	3:40	LINE CLEAR AVAILED
12	12-Feb-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	4:13	4:32	0:19	LINE FAULT
13	12-Feb-19	BAGALKOT	110	INDI220 -HIREBEVANUR	HIREBEVANUR_110	16:17	16:28	0:11	LINE CLEAR AVAILED
14	12-Feb-19	BAGALKOT	110	DS SHIVAKUMAR SUGER-HIREBEVANUR	HIREBEVANUR_110	18:40	19:00	0:20	LINE CLEAR AVAILED
15	12-Feb-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33	0:02	0:03	0:01	TRANSFORMER FAULT
16	12-Feb-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	14:45	15:26	0:41	LINE CLEAR AVAILED
17	12-Feb-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	22:33	22:45	0:12	LINE CLEAR AVAILED
18	12-Feb-19	BAGALKOT	110	SIRSI220-SIRSI110	SIRSI_110	22:33	22:45	0:12	LINE CLEAR AVAILED
19	12-Feb-19	BAGALKOT	110	110/33KV,HV3	SINDAGI_110,KALKERI_33,ALMEL_33	13:28	13:41	0:13	LINE CLEAR AVAILED
20	12-Feb-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	9:58	23:59	14:01	NFBC ISSUED
21	12-Feb-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	13:29	13:41	0:12	TRANSFORMER FAULT
22	12-Feb-19	BAGALKOT	110	110/33KV,HV3	MACHE_110	13:33	13:34	0:01	HAND TRIPPED
23	12-Feb-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33	22:21	22:31	0:10	TRANSFORMER FAULT
24	12-Feb-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	0:00	14:46	14:46	LINE CLEAR AVAILED
25	12-Feb-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	15:26	22:37	7:11	LINE CLEAR AVAILED
26	12-Feb-19	BAGALKOT	220	220/110KV,HV1&LV1	KUDUCHI_220	13:04	16:32	3:28	TRANSFORMER FAULT
27	12-Feb-19	BAGALKOT	110	KUDUCHI220-AINAPUR	AINAPUR_110	10:23	11:15	0:52	LINE CLEAR AVAILED
28	12-Feb-19	BAGALKOT	110	KUDUCHI220-AINAPUR	AINAPUR_110	13:49	16:01	2:12	LINE CLEAR AVAILED
29	12-Feb-19	BAGALKOT	110	INDI220-INDI	INDI_110	0:00	11:32	11:32	LINE CLEAR AVAILED
30	12-Feb-19	BAGALKOT	110	INDI220-INDI	INDI_110	13:37	13:57	0:20	LINE CLEAR AVAILED
31	12-Feb-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:05	21:14	0:09	LINE FAULT
32	12-Feb-19	BANGALORE	66	HV3	CB PURA 220	15:38	16:22	0:44	LINE CLEAR AVAILED
33	12-Feb-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGATTA	SIDLAGATTA, MELUR	14:04	14:08	0:04	LINE FAULT
34	12-Feb-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	10:31	10:40	0:08	LOAD CHANGEOVER
35	12-Feb-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	12:56	13:01	0:04	LOAD CHANGEOVER
36	12-Feb-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	10:32	10:38	0:06	LOAD CHANGEOVER
37	12-Feb-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	12:35	12:39	0:04	LOAD CHANGEOVER

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
38	12-Feb-19	BANGALORE	66	DB PURA 220 - D CROSS	D CROSS	10:25	10:30	0:05	LOAD CHANGEOVER
39	12-Feb-19	BANGALORE	66	DB PURA 220 - D CROSS	D CROSS	12:22	12:34	0:12	LOAD CHANGEOVER
40	12-Feb-19	BANGALORE	66	JANGAMKOTE - VIJAYAPURA	JANGAMKOTE	10:25	10:35	0:10	LOAD CHANGEOVER
41	12-Feb-19	BANGALORE	66	JANGAMKOTE - MELUR	JANGAMKOTE	14:45	14:55	0:10	LOAD CHANGEOVER
42	12-Feb-19	BANGALORE	66	HV2	NARASAPURA	23:11	23:17	0:06	TRANSFORMER FAULT
43	12-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:10	17:20	0:10	LINE FAULT
44	12-Feb-19	BANGALORE	66	HV1	HAROBELE	15:33	15:38	0:05	LINE CLEAR AVAILED
45	12-Feb-19	BANGALORE	66	HV2	KODIHALLI	12:56	13:00	0:04	LINE CLEAR AVAILED
46	12-Feb-19	BANGALORE	66	JAYADEVA - NIMHANS 220	JAYADEVA	16:55	17:32	0:37	LINE FAULT
47	12-Feb-19	BANGALORE	66	HV3	ADUGODI	16:55	17:45	0:50	MAIN SUPPLY FAILURE
48	12-Feb-19	BANGALORE	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), NAL(EHT), K&C VALLEY	17:36	17:40	0:04	LOAD CHANGEOVER
49	12-Feb-19	BANGALORE	66	JAYADEVA - SARAKKI 1 & 2	JAYADEVA	18:39	18:48	0:08	LOAD CHANGEOVER
50	12-Feb-19	BANGALORE	66	ALUR - SRS PEENYA 220	ALUR	10:13	10:24	0:11	LOAD CHANGEOVER
51	12-Feb-19	BANGALORE	66	ALUR - NELAMANGALA 66	ALUR	16:45	16:51	0:06	LOAD CHANGEOVER
52	12-Feb-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:15	10:18	0:03	LOAD CHANGEOVER
53	12-Feb-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:07	17:09	0:02	LOAD CHANGEOVER
54	12-Feb-19	BANGALORE	220	HV2	SRS PEENYA 220	11:50	12:26	0:36	TRANSFORMER FAULT
55	12-Feb-19	BANGALORE	220	HV4	SRS PEENYA 220	11:50	12:58	1:08	TRANSFORMER FAULT
56	12-Feb-19	BANGALORE	66	SRS PEENYA 220 - NELAKADERANAHALLI	NELAKADERANAHALLI	11:50	12:50	1:00	MAIN SUPPLY FAILURE
57	12-Feb-19	BANGALORE	66	SRS PEENYA 220 - GOKULA 1 & 2	GOKULA	11:50	12:45	0:55	MAIN SUPPLY FAILURE
58	12-Feb-19	BANGALORE	66	SRS PEENYA 220 - DG4	PLATINUM CITY	11:50	12:43	0:53	MAIN SUPPLY FAILURE
59	12-Feb-19	BANGALORE	220	LV4	SRS PEENYA 220	13:40	16:28	2:48	TRANSFORMER FAULT
60	12-Feb-19	BANGALORE	66	SRS PEENYA 220 - BRINDAVANA	BRINDAVANA	11:50	14:35	2:45	LINE FAULT
61	12-Feb-19	BANGALORE	66	SRS PEENYA 220 - WIDIA	WIDIA, WIDIA (EHT), MEI LAYOUT	11:50	12:45	0:55	MAIN SUPPLY FAILURE
62	12-Feb-19	BANGALORE	66	BRINDAVANA - SRS PEENYA	BRINDAVANA	17:17	17:25	0:07	LINE FAULT
63	12-Feb-19	BANGALORE	66	HV3	ELECTRONIC CITY	13:56	14:04	0:07	TRANSFORMER FAULT
64	12-Feb-19	BANGALORE	66	MATHIKERE - GOKULA	MATHIKERE	11:50	12:50	1:00	MAIN SUPPLY FAILURE
65	12-Feb-19	BANGALORE	66	MATHIKERE - GOKULA	MATHIKERE	15:00	15:10	0:10	LOAD CHANGEOVER
66	12-Feb-19	BANGALORE	66	MATHIKERE - HEBBAL 220	MATHIKERE	16:46	16:50	0:04	LOAD CHANGEOVER
67	12-Feb-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	11:50	12:40	0:50	MAIN SUPPLY FAILURE
68	12-Feb-19	BANGALORE	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	16:50	17:10	0:20	LOAD CHANGEOVER
69	12-Feb-19	BANGALORE	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	17:15	17:35	0:20	LINE CLEAR AVAILED
70	12-Feb-19	BANGALORE	66	GOKULA - BEL (EHT)	BEL (EHT)	11:50	12:50	1:00	MAIN SUPPLY FAILURE
71	12-Feb-19	BANGALORE	66	GOKULA - HMT (EHT)	HMT (EHT)	11:50	12:50	1:00	MAIN SUPPLY FAILURE
72	12-Feb-19	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	16:30	20:16	3:46	LINE FAULT
73	12-Feb-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	14:13	16:53	2:40	NFBC ISSUED
74	12-Feb-19	GULBARGA	220	HV1	SEDAM_220	14:25	16:56	2:31	LINE CLEAR AVAILED
75	12-Feb-19	GULBARGA	220	SEDAM-CLNMAX	SEDAM_220	14:10	19:25	5:15	LINE CLEAR AVAILED
76	12-Feb-19	GULBARGA	110	HV2	HANUMANAL_110	8:25	8:35	0:10	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
77	12-Feb-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGUR FACTORY,CHOWDAPUR_110	23:51	23:56	0:05	LINE FAULT
78	12-Feb-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	6:55	7:05	0:10	LINE FAULT
79	12-Feb-19	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110,RAJESHWAR_110 CEMENTS,KORWAR TEMPLE_110	13:50	14:04	0:14	LINE CLEAR AVAILED
80	12-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:24	20:10	4:46	LINE CLEAR AVAILED
81	12-Feb-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:47	13:11	0:24	LINE FAULT
82	12-Feb-19	HASSAN	220	GERSOPPA-TALGUPA2	gerusoppa_gen	12:47	13:20	0:33	LINE FAULT
83	12-Feb-19	HASSAN	220	KADUR-ABUSET	KADUR_220	15:42	19:27	3:45	LINE FAULT
84	12-Feb-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:30	19:43	9:13	LINE CLEAR AVAILED
85	12-Feb-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:35	19:42	9:07	LINE CLEAR AVAILED
86	12-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:09	12:11	3:02	LINE CLEAR AVAILED
87	12-Feb-19	HASSAN	110	HV1	ANAVATTI_110	9:14	10:39	1:25	LINE CLEAR AVAILED
88	12-Feb-19	HASSAN	110	HV2	ANAVATTI_110	9:14	10:39	1:25	LINE CLEAR AVAILED
89	12-Feb-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	9:10	12:15	3:05	LINE CLEAR AVAILED
90	12-Feb-19	HASSAN	110	ANAVATI-ANVATTI	BARANGI_110	10:10	12:15	2:05	LINE CLEAR AVAILED
91	12-Feb-19	HASSAN	110	HV1	HIRIYADKA_110	9:36	11:53	2:17	LINE CLEAR AVAILED
92	12-Feb-19	HASSAN	110	JOG-NK2	mghe_gen	14:33	14:48	0:15	LINE CLEAR AVAILED
93	12-Feb-19	HASSAN	110	HV2	KONAJE_110	10:56	14:16	3:20	LINE CLEAR AVAILED
94	12-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:06	13:18	0:12	LINE FAULT
95	12-Feb-19	HASSAN	66	BELUR-MUDIGERE	BELUR_66	10:07	10:23	0:16	LINE CLEAR AVAILED
96	12-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGLUR_66	10:39	10:49	0:10	LINE FAULT
97	12-Feb-19	MYSORE	66	HV1	CHINAKURALI_66	14:12	14:54	0:42	LINE CLEAR AVAILED
98	12-Feb-19	MYSORE	66	HV1	JYOTHINAGARA_66	22:28	0:02	1:30	TRANSFORMER FAULT
99	12-Feb-19	MYSORE	66	HV1	KRNAGARA_66	10:50	11:03	0:12	TRANSFORMER FAULT
100	12-Feb-19	MYSORE	66	HV2	KRNAGARA_66	10:50	11:00	0:09	TRANSFORMER FAULT
101	12-Feb-19	MYSORE	66	MANDYA-CHIKKA MANDAYA	CHIKKA_MANDYA_66 HAMPAPURA(K)_66 BESAGARAHALLI_66 DUNDANAHALLI_66	12:07	12:15	0:07	HAND TRIPPED
102	12-Feb-19	MYSORE	66	HV2	SFCSHIVA_66	16:45	23:59	7:13	LINE CLEAR AVAILED
103	12-Feb-19	MYSORE	66	HV1	SINDHUVALLI_66	10:16	18:06	7:49	LINE CLEAR AVAILED
104	12-Feb-19	MYSORE	66	HV2	SINDHUVALLI_66	10:16	18:06	7:49	LINE CLEAR AVAILED
105	12-Feb-19	TUMKUR	220	TR-1(LV SIDE)	MADHUGIRI_220	12:15	12:52	0:36	LINE CLEAR AVAILED
106	12-Feb-19	TUMKUR	220	TR-1(LV SIDE)	MADHUGIRI_220	12:55	14:20	1:25	LINE CLEAR AVAILED
107	12-Feb-19	TUMKUR	66	TR-1	DAVANAGERE_66	17:06	18:01	0:55	LINE CLEAR AVAILED
108	12-Feb-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:12	14:29	0:17	LINE FAULT
109	12-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P-R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	10:59	17:54	6:54	LINE CLEAR AVAILED
110	12-Feb-19	TUMKUR	66	TR-2	HOLAVINAHALLY_66	12:01	12:17	0:16	TRANSFORMER FAULT
111	12-Feb-19	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	12:15	12:53	0:37	LINE CLEAR AVAILED
112	12-Feb-19	TUMKUR	66	TR-2(LV2)	MADHUGIRI_220	12:55	14:20	1:25	LINE CLEAR AVAILED
113	12-Feb-19	TUMKUR	66	TR-2	NITRAHALLI_66	15:33	16:13	0:40	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
114	12-Feb-19	TUMKUR	66	TR-1	PAVAGADA_66	16:29	17:21	0:52	TRANSFORMER FAULT
115	12-Feb-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	16:16	16:29	0:12	LINE FAULT
116	12-Feb-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	13:58	14:13	0:15	LINE CLEAR AVAILED
117	12-Feb-19	TUMKUR	66	TR-1	SAVALANGA_66	3:49	8:20	4:31	TRANSFORMER FAULT
118	12-Feb-19	TUMKUR	66	TR-1	SAVALANGA_66	13:58	14:14	0:16	LINE CLEAR AVAILED
119	12-Feb-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-1	CHALLAKERE_66, SANIKERE_66	22:56	23:08	0:12	LINE FAULT
120	12-Feb-19	TUMKUR	66	THALLAK 220kV- THALLAK	THALLAK_66	14:22	14:45	0:23	LINE CLEAR AVAILED
121	12-Feb-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2 WELSPUNSOLAR1_IPP_66	WELSPUNSOLAR1_IPP_66	10:04	14:08	4:04	LINE FAULT
122	13-Feb-19	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	9:42	18:42	9:00	LINE CLEAR AVAILED
123	13-Feb-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	9:43	18:42	8:59	LINE CLEAR AVAILED
124	13-Feb-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	9:48	18:27	8:39	LINE CLEAR AVAILED
125	13-Feb-19	BAGALKOT	110	AMBEWADI-HALIYAL	HALIYAL_110	0:00	18:40	18:40	LINE CLEAR AVAILED
126	13-Feb-19	BAGALKOT	110	AMBEWADI-KAVALWADA	KAVALWADA_110	9:47	18:49	9:02	LINE CLEAR AVAILED
127	13-Feb-19	BAGALKOT	220	NARENDRA2-AMBEWADI	AMBEWADI_220	20:02	23:59	3:57	LINE CLEAR AVAILED
128	13-Feb-19	BAGALKOT	220	220/110KV,HV1,LV1	BIDNAL_220,NAVALGUND_110,ANNIGERI_110,GADAG_110,P H COMPOUND_110	1:28	7:44	6:16	TRANSFORMER FAULT
129	13-Feb-19	BAGALKOT	110	110/11KV,HV2	BIDNAL_220	1:47	2:54	1:07	LINE CLEAR AVAILED
130	13-Feb-19	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	1:47	2:54	1:07	LINE CLEAR AVAILED
131	13-Feb-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	1:28	23:59	22:31	LINE FAULT
132	13-Feb-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	1:47	16:47	15:00	LINE CLEAR AVAILED
133	13-Feb-19	BAGALKOT	110	BIDNAL220-GADAG ROAD	GADAG ROAD_110	1:47	16:50	15:03	LINE CLEAR AVAILED
134	13-Feb-19	BAGALKOT	110	BIDNAL220-PH COMPOUND	PH COMPOUND_110	1:47	12:02	10:15	LINE CLEAR AVAILED
135	13-Feb-19	BAGALKOT	110	HUBLI2-BIDNAL	BIDNAL_220	9:34	23:59	14:25	LINE CLEAR AVAILED
136	13-Feb-19	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	10:05	13:02	2:57	LINE CLEAR AVAILED
137	13-Feb-19	BAGALKOT	110	110/11KV,HV2	DAVALESHWARA_110	13:27	13:33	0:06	HAND TRIPPED
138	13-Feb-19	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GADAG ROAD_110	1:46	1:53	0:07	HAND TRIPPED
139	13-Feb-19	BAGALKOT	110	GOPANAKOPPA-MRITYUNJAYNAGAR 1&2	MRITYUNJAYNAGAR_110	16:57	16:58	0:01	HAND TRIPPED
140	13-Feb-19	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110	16:22	17:17	0:55	TRANSFORMER FAULT
141	13-Feb-19	BAGALKOT	110	110/33KV,HV5	INDI_110,TADAVALLA_33,TAMBA_33	17:51	18:22	0:31	LINE CLEAR AVAILED
142	13-Feb-19	BAGALKOT	220	DHONI1-GADAG	GADAG_220	5:19	11:07	5:48	LINE FAULT
143	13-Feb-19	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_66	11:13	16:08	4:55	LINE CLEAR AVAILED
144	13-Feb-19	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	2:27	2:49	0:22	LINE CLEAR AVAILED
145	13-Feb-19	BAGALKOT	110	110/33KV, HV2	HUBLI_220	11:55	12:38	0:43	LINE CLEAR AVAILED
146	13-Feb-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	18:43	18:51	0:08	LINE CLEAR AVAILED
147	13-Feb-19	BAGALKOT	110	110/33KV,HV2&HV3	MURDESHWAR_110, BHATKAL_33, KASARKOD_33	12:44	13:44	1:00	LINE CLEAR AVAILED
148	13-Feb-19	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEWAR- GENNUR_33	12:27	12:52	0:25	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
149	13-Feb-19	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEWAR-GENNUR_33	13:20	13:59	0:39	LINE CLEAR AVAILED
150	13-Feb-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	18:59	23:59	5:00	LINE CLEAR AVAILED
151	13-Feb-19	BAGALKOT	110	KUDACHI220-MORAB	MORAB_110	11:38	12:59	1:21	LINE CLEAR AVAILED
152	13-Feb-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	9:17	9:57	0:40	MAIN SUPPLY FAILURE
153	13-Feb-19	BAGALKOT	110	KADANKOPPA-KAVALWADA	KADANKOPPA_110	18:42	23:59	5:17	LINE CLEAR AVAILED
154	13-Feb-19	BANGALORE	66	HV3	ADUGODI	6:33	6:40	0:07	LOAD CHANGEOVER
155	13-Feb-19	BANGALORE	66	BRINDAVAN - NELAKADERANAHALLI	NELAKADERANAHALLI	18:56	19:05	0:09	LOAD CHANGEOVER
156	13-Feb-19	BANGALORE	66	HV1	GOKULA	11:27	12:58	1:31	LINE CLEAR AVAILED
157	13-Feb-19	BANGALORE	66	ITI - BANASWADI	BANASWADI	8:05	8:19	0:14	LINE CLEAR AVAILED
158	13-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	8:33	8:43	0:09	LINE FAULT
159	13-Feb-19	BANGALORE	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	14:00	15:26	1:25	LINE CLEAR AVAILED
160	13-Feb-19	BANGALORE	66	HV2	HAL 220	11:00	11:05	0:04	LINE CLEAR AVAILED
161	13-Feb-19	BANGALORE	66	HV1	AKKURMOLE	9:05	9:15	0:09	TRANSFORMER FAULT
162	13-Feb-19	BANGALORE	66	BAGHMANE WTP - HAL 2	NGEF, NGEF (EHT)	7:39	8:08	0:29	LINE FAULT
163	13-Feb-19	BANGALORE	66	HV1	BAGHMANE WTP	12:18	12:25	0:07	LINE CLEAR AVAILED
164	13-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	15:19	15:36	0:17	LINE FAULT
165	13-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:59	18:03	0:04	LINE FAULT
166	13-Feb-19	BANGALORE	66	HV2	DEVANGONDHI	11:33	11:39	0:05	TRANSFORMER FAULT
167	13-Feb-19	BANGALORE	66	HV2	DEVANGONDHI	12:21	12:35	0:13	TRANSFORMER FAULT
168	13-Feb-19	BANGALORE	66	HV2	DEVANGONDHI	7:10	7:40	0:30	TRANSFORMER FAULT
169	13-Feb-19	BANGALORE	220	HV1	HOSKOTE 220	17:46	17:49	0:02	LINE CLEAR AVAILED
170	13-Feb-19	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	17:46	17:52	0:05	MAIN SUPPLY FAILURE
171	13-Feb-19	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	17:46	17:55	0:08	MAIN SUPPLY FAILURE
172	13-Feb-19	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:46	17:50	0:03	MAIN SUPPLY FAILURE
173	13-Feb-19	BANGALORE	66	HV1	JIGANI LINK ROAD	2:53	3:12	0:19	TRANSFORMER FAULT
174	13-Feb-19	BANGALORE	66	KOLAR 220 - NANAGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:03	10:10	0:06	LOAD CURTAILMENT
175	13-Feb-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:30	10:35	0:05	LOAD CURTAILMENT
176	13-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:39	18:45	0:05	LINE FAULT
177	13-Feb-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELMANGALA 66	12:37	12:40	0:02	LOAD CHANGEOVER
178	13-Feb-19	BANGALORE	66	HV1	NANGALI	14:19	14:26	0:06	TRANSFORMER FAULT
179	13-Feb-19	BANGALORE	66	HV2	NANGALI	14:42	14:58	0:16	TRANSFORMER FAULT
180	13-Feb-19	GULBARGA	220	BTPS-LINGAPUR	BTPS_220	9:49	17:50	8:01	NFBC ISSUED
181	13-Feb-19	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	12:22	12:32	0:10	LINE CLEAR AVAILED
182	13-Feb-19	GULBARGA	220	SEDAM-SHAHPUR	SEDAM_220	12:35	12:40	0:05	LINE CLEAR AVAILED
183	13-Feb-19	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	12:44	13:04	0:20	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
184	13-Feb-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	12:55	13:00	0:05	LINE CLEAR AVAILED
185	13-Feb-19	GULBARGA	220	HV2,LV2	SIDHANOOR_220	11:44	12:13	0:29	LINE CLEAR AVAILED
186	13-Feb-19	GULBARGA	220	HV1,LV1	SIDHANOOR_220	12:23	12:49	0:26	LINE CLEAR AVAILED
187	13-Feb-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	1:57	2:16	0:19	LINE FAULT
188	13-Feb-19	GULBARGA	220	LINGAPUR-MUNIRABAD TR2	MUNIRABAD_220	13:13	13:52	0:39	LINE FAULT
189	13-Feb-19	GULBARGA	220	LINGAPUR-GADAG2	LINGAPUR_220	13:13	14:09	0:56	LINE FAULT
190	13-Feb-19	GULBARGA	220	LINGAPUR-GADAG1	LINGAPUR_220	13:13	14:25	1:12	LINE FAULT
191	13-Feb-19	GULBARGA	220	LINGAPUR-LINGASUGUR	LINGAPUR_220	13:13	14:11	0:58	LINE FAULT
192	13-Feb-19	GULBARGA	220	LINGAPUR-JVSL2	JVSWL_220	13:13	13:57	0:44	LINE FAULT
193	13-Feb-19	GULBARGA	220	LINGAPUR-JVSL1	JVSWL_220	13:13	14:12	0:59	LINE FAULT
194	13-Feb-19	GULBARGA	220	LINGAPUR-GUDAHALLI1	GUDADAHALLI_220	13:13	13:54	0:41	LINE FAULT
195	13-Feb-19	GULBARGA	220	LINGAPUR-MUNIRABAD TR1	MUNIRABAD_220	13:13	14:24	1:11	LINE FAULT
196	13-Feb-19	GULBARGA	220	LINGAPUR-HKT MINING	LINGAPUR_220	13:13	14:45	1:32	LINE FAULT
197	13-Feb-19	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	13:13	14:00	0:47	LINE FAULT
198	13-Feb-19	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110	9:32	10:05	0:33	LINE CLEAR AVAILED
199	13-Feb-19	GULBARGA	110	HV1	KOLHAR_110	18:04	19:11	1:07	LINE CLEAR AVAILED
200	13-Feb-19	GULBARGA	110	KOLHAR-SHAHI SLR	KOLHAR_110	12:13	12:20	0:07	LINE FAULT
201	13-Feb-19	GULBARGA	110	HV3	BEVOOR_110	23:54	23:59	0:05	TRANSFORMER FAULT
202	13-Feb-19	GULBARGA	110	HALBARGA-ACMVSLR	HALBARGA_220	5:05	5:18	0:13	LINE FAULT
203	13-Feb-19	GULBARGA	110	HALBARGA-SANTHAPUR	JANAWADA_110,SANTHAPUR_110,DONG RAGOAN_110,DIGGI_110	9:48	9:58	0:10	LINE FAULT
204	13-Feb-19	GULBARGA	110	HV1	MADIYAL_110	0:36	0:41	0:05	TRANSFORMER FAULT
205	13-Feb-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110, GANADAL_110	11:41	11:45	0:04	LINE CLEAR AVAILED
206	13-Feb-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110	11:52	12:00	0:08	LINE CLEAR AVAILED
207	13-Feb-19	GULBARGA	66	HV2	CJHALLI_66	10:48	11:23	0:35	LINE CLEAR AVAILED
208	13-Feb-19	GULBARGA	66	HV2	CJHALLI_66	12:09	12:13	0:04	TRANSFORMER FAULT
209	13-Feb-19	GULBARGA	66	HV1	KOTTUR_66	11:00	13:02	2:02	LINE CLEAR AVAILED
210	13-Feb-19	GULBARGA	66	HV2	TAMBRAHALLI_66	10:59	11:32	0:33	LINE CLEAR AVAILED
211	13-Feb-19	GULBARGA	66	ITTAGI-CLNMAX1,2	ITTAGI_220	13:15	13:25	0:10	LINE FAULT
212	13-Feb-19	GULBARGA	66	ITTAGI-CLNMAX2	ITTAGI_220	13:48	14:08	0:20	LINE FAULT
213	13-Feb-19	GULBARGA	66	HV1,HV2	CJHALLI_66	9:33	10:33	1:00	LINE CLEAR AVAILED
214	13-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:03	13:48	2:45	LINE CLEAR AVAILED
215	13-Feb-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:10	13:24	3:14	LINE CLEAR AVAILED
216	13-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	8:41	8:46	0:05	LINE FAULT
217	13-Feb-19	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	18:48	19:17	0:29	MAIN SUPPLY FAILURE
218	13-Feb-19	HASSAN	110	HV2	KADUR_220	20:40	21:50	1:10	LINE CLEAR AVAILED
219	13-Feb-19	HASSAN	110	HV2	KADUR_220	22:02	23:59	1:57	LINE CLEAR AVAILED
220	13-Feb-19	HASSAN	110	HV3	KONAJE_110	10:00	16:39	6:39	LINE CLEAR AVAILED
221	13-Feb-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	18:47	19:17	0:30	LINE CLEAR AVAILED
222	13-Feb-19	HASSAN	110	HV2	MSEZ_220	18:09	18:32	0:23	TRANSFORMER FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
223	13-Feb-19	HASSAN	110	HV1	VITLA_110	11:28	11:44	0:16	LINE CLEAR AVAILED
224	13-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:00	12:25	0:25	LINE FAULT
225	13-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	13:37	13:45	0:08	HAND TRIPPED
226	13-Feb-19	HASSAN	66	HV1	HASSAN_66	15:43	15:59	0:16	LINE CLEAR AVAILED
227	13-Feb-19	HASSAN	66	HV2	HASSAN_66	15:21	18:43	3:22	LINE CLEAR AVAILED
228	13-Feb-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	9:45	10:10	0:25	LINE CLEAR AVAILED
229	13-Feb-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	8:25	8:30	0:05	TRANSFORMER FAULT
230	13-Feb-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	8:30	10:15	1:45	LINE CLEAR AVAILED
231	13-Feb-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	13:23	13:33	0:10	LINE FAULT
232	13-Feb-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	21:05	21:14	0:09	LINE FAULT
233	13-Feb-19	MYSORE	66	HV1	ATTIGULIPURA_66	5:33	5:53	0:20	TRANSFORMER FAULT
234	13-Feb-19	MYSORE	66	HV2	MADHUVANAHALLI_220	9:16	9:20	0:04	TRANSFORMER FAULT
235	13-Feb-19	MYSORE	66	HV2	KALAMANDIRA_66	11:25	13:47	2:22	LINE CLEAR AVAILED
236	13-Feb-19	MYSORE	66	HV2	KALAMANDIRA_66	16:05	18:04	1:59	LINE CLEAR AVAILED
237	13-Feb-19	MYSORE	66	HV2	NAGAMANGALA_66	17:20	17:44	0:24	LINE CLEAR AVAILED
238	13-Feb-19	MYSORE	220	HV3	HOOTAGALLY_220	10:25	13:43	3:18	LINE CLEAR AVAILED
239	13-Feb-19	MYSORE	66	DODDARAYAPET-KUNTHUR	SANTHEMARAHALLI_66 ,MUGUR_66 TNARASIPURA_66 THUMLA_66 THAYURU_66 CHIDRAVALLI_66	13:20	13:30	0:10	LINE FAULT
240	13-Feb-19	TUMKUR	66	TR-1	DAVANAGERE_66	8:14	8:25	0:10	LINE CLEAR AVAILED
241	13-Feb-19	TUMKUR	66	TR-2	DAVANAGERE_66	7:47	10:05	2:17	LINE CLEAR AVAILED
242	13-Feb-19	TUMKUR	66	DEVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:27	17:31	9:03	LINE CLEAR AVAILED
243	13-Feb-19	TUMKUR	66	TR-1	HARIHAR_66	15:36	16:19	0:43	LINE CLEAR AVAILED
244	13-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	18:00	18:06	0:06	TRANSFORMER FAULT
245	13-Feb-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:00	15:08	0:08	TRANSFORMER FAULT
246	13-Feb-19	TUMKUR	66	TR-1	HANAGAL_66	10:47	11:10	0:23	LINE CLEAR AVAILED
247	13-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	21:31	22:00	0:29	LINE FAULT
248	13-Feb-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	21:46	21:58	0:12	LINE CLEAR AVAILED
249	13-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	15:33	15:44	0:10	LINE FAULT
250	14-Feb-19	BAGALKOT	220	DHONI1-GADAG	GADAG_220	6:23	18:34	12:11	LINE FAULT
251	14-Feb-19	BAGALKOT	220	DHONI2-GADAG	GADAG_220	0:00	18:33	18:33	LINE CLEAR AVAILED
252	14-Feb-19	BAGALKOT	220	NARENDRA2-AMBEWADI	AMBEWADI_220	0:00	12:05	12:05	LINE CLEAR AVAILED
253	14-Feb-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	18:34	18:40	0:06	LOAD CURTAILMENT
254	14-Feb-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	18:34	18:39	0:05	LOAD CURTAILMENT
255	14-Feb-19	BAGALKOT	110	110/11KV,HV2	AREMALLAPURA_110	12:02	13:25	1:23	LINE CLEAR AVAILED
256	14-Feb-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	18:36	18:56	0:20	LOAD CURTAILMENT
257	14-Feb-19	BAGALKOT	110	BAGALKOT220-NEERBUDHIHAL	NEERBUDHIHAL_110	14:52	15:00	0:08	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
258	14-Feb-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	10:36	10:45	0:09	TRANSFORMER FAULT
259	14-Feb-19	BAGALKOT	110	BELGAUM220-KANABARGI	KANABARGI_110	13:08	13:12	0:04	HAND TRIPPED
260	14-Feb-19	BAGALKOT	220	GHATAPRABHA1-CHIKKODI	CHIKKODI_220	10:39	12:58	2:19	LINE CLEAR AVAILED
261	14-Feb-19	BAGALKOT	110	DAVALESHWARA-SAIDAPUR	SAIDAPUR_110	15:06	16:35	1:29	LINE CLEAR AVAILED
262	14-Feb-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	18:35	18:45	0:10	LOAD CURTAILMENT
263	14-Feb-19	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33,BOMMANAHALLI_33	18:35	19:02	0:27	LOAD CURTAILMENT
264	14-Feb-19	BAGALKOT	110	HAVERI220-HANAGAL	HANAGAL_110	14:26	14:39	0:13	LINE FAULT
265	14-Feb-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	13:22	14:08	0:46	LINE CLEAR AVAILED
266	14-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33	18:36	18:44	0:08	LOAD CURTAILMENT
267	14-Feb-19	BAGALKOT	110	DS SHIVAKUMAR SUGARS-HIREBEVANUR	HIREBEVANUR_110	18:54	19:00	0:06	HAND TRIPPED
268	14-Feb-19	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	14:06	14:09	0:03	TRANSFORMER FAULT
269	14-Feb-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33	13:40	14:05	0:25	TRANSFORMER FAULT
270	14-Feb-19	BAGALKOT	220	AMBEWADI1-NARENDRA	NARENDRA_220	7:13	12:06	4:53	LINE CLEAR AVAILED
271	14-Feb-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI 33KV	19:02	19:03	0:01	TRANSFORMER FAULT
272	14-Feb-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	18:39	18:46	0:07	LOAD CURTAILMENT
273	14-Feb-19	BAGALKOT	110	HUBLI-TARIHAL	TARIHAL_110	12:44	19:58	7:14	LINE CLEAR AVAILED
274	14-Feb-19	BAGALKOT	110	110/33KV,HV2	HUBLI_220	9:47	12:38	2:51	LINE CLEAR AVAILED
275	14-Feb-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	16:27	16:37	0:10	LINE CLEAR AVAILED
276	14-Feb-19	BAGALKOT	110	110/33KV,HV2	SAVALGI_110,KALBILGI 33KV,HIREPADASALAGI 33KV	18:35	19:17	0:42	LOAD CURTAILMENT
277	14-Feb-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	13:45	14:21	0:36	LINE CLEAR AVAILED
278	14-Feb-19	BAGALKOT	110	110/33KV,HV3	MUDEDEBIHAL_110,NALATWAD 33KV	15:06	15:17	0:11	TRANSFORMER FAULT
279	14-Feb-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	18:34	18:37	0:03	LOAD CURTAILMENT
280	14-Feb-19	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,DEWAR JENNUR 33KV	16:21	16:46	0:25	LINE CLEAR AVAILED
281	14-Feb-19	BAGALKOT	110	110/11KV,HV1	LAXMESWAR_110	18:35	18:47	0:12	LOAD CURTAILMENT
282	14-Feb-19	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_66	10:56	15:59	5:03	LINE CLEAR AVAILED
283	14-Feb-19	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66,AREMALLAPUR 33KV	18:39	20:06	1:27	LOAD CURTAILMENT
284	14-Feb-19	Bangalore	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI, THIMMAMPALLI	8:57	9:03	0:05	LINE CLEAR AVAILED
285	14-Feb-19	Bangalore	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:13	7:20	0:07	LINE FAULT
286	14-Feb-19	Bangalore	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:48	19:14	0:25	LOAD CURTAILMENT
287	14-Feb-19	Bangalore	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU, THIMMAMPALLI, SOMANATHPURA	19:15	19:44	0:29	LOAD CURTAILMENT
288	14-Feb-19	Bangalore	66	HV1	KANAKAPURA 66	13:01	14:36	1:35	LINE CLEAR AVAILED
289	14-Feb-19	Bangalore	66	HV1	KANAKAPURA 66	16:41	16:45	0:03	LINE CLEAR AVAILED
290	14-Feb-19	Bangalore	66	HV2	KANAKAPURA 66	13:01	16:44	3:42	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
291	14-Feb-19	Bangalore	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:59	19:42	0:43	LOAD CURTAILMENT
292	14-Feb-19	Bangalore	66	KOLAR 220 - VEMAGAL	VEMAGAL , KYALANUR	19:00	19:42	0:42	LOAD CURTAILMENT
293	14-Feb-19	Bangalore	66	SUGUTUR - KOLAR 220	SUGUTUR, KYALANUR	18:58	19:42	0:44	LOAD CURTAILMENT
294	14-Feb-19	Bangalore	66	GOWRIBIDANUR 220 - BAGEPALLI 2	BAGEPALLI , VIDHURASHWATHA , GUNDLU KOTTUR	18:55	20:00	1:05	LOAD CURTAILMENT
295	14-Feb-19	Bangalore	66	GOWRIBIDANUR 220 - RAMAPURA	HOSUR RAMAPURA, NITRALLI	13:50	14:20	0:30	LINE CLEAR AVAILED
296	14-Feb-19	Bangalore	66	HV1	CHANDRAPPA CIRCLE	19:03	19:11	0:07	TRANSFORMER FAULT
297	14-Feb-19	Bangalore	66	HV2	CHANDRAPPA CIRCLE	18:50	19:03	0:13	TRANSFORMER FAULT
298	14-Feb-19	Bangalore	66	HV2	HOODY 220	18:05	19:01	0:56	TRANSFORMER FAULT
299	14-Feb-19	Bangalore	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	8:13	8:21	0:08	LINE FAULT
300	14-Feb-19	Bangalore	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	12:59	14:32	1:32	LINE CLEAR AVAILED
301	14-Feb-19	Bangalore	66	HV1	KORMANGALA	18:22	18:43	0:20	TRANSFORMER FAULT
302	14-Feb-19	Bangalore	66	MELEHALLI - JALAMANGALA	JALAMANGALA, KUTAGALLU, CHIKKAGANGANAWADI	15:36	15:47	0:10	LINE CLEAR AVAILED
303	14-Feb-19	Bangalore	66	HV2	PRESTIGE SHANTINIKETHAN	15:51	16:49	0:58	LINE CLEAR AVAILED
304	14-Feb-19	Bangalore	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	13:15	13:23	0:08	LINE CLEAR AVAILED
305	14-Feb-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	10:43	17:14	6:31	LINE CLEAR AVAILED
306	14-Feb-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	12:02	18:10	6:08	LINE CLEAR AVAILED
307	14-Feb-19	GULBARGA	220	LINGAPUR-GADAG1	GADAG_220	12:04	18:57	6:53	NFBC ISSUED
308	14-Feb-19	GULBARGA	110	HV2	UPANAYAKANAHALLI_66	12:00	12:02	0:02	TRANSFORMER FAULT
309	14-Feb-19	GULBARGA	110	HV2	DHADESUGUR_110	11:42	12:08	0:26	LINE CLEAR AVAILED
310	14-Feb-19	GULBARGA	110	HV1	DHADESUGUR_110	11:18	11:40	0:22	LINE CLEAR AVAILED
311	14-Feb-19	GULBARGA	110	HV3	KOPPAL_110	11:34	14:38	3:04	LINE CLEAR AVAILED
312	14-Feb-19	GULBARGA	110	KUSTAGI-BEVOOR	BEVOOR_110	9:55	11:33	1:38	LINE CLEAR AVAILED
313	14-Feb-19	GULBARGA	110	HV3	BEVOOR_110	9:55	12:48	2:53	LINE CLEAR AVAILED
314	14-Feb-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KUSTAGI_220	11:54	18:19	6:25	LINE CLEAR AVAILED
315	14-Feb-19	GULBARGA	110	HV3	BEVOOR_110	17:30	17:45	0:15	TRANSFORMER FAULT
316	14-Feb-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	10:39	13:15	2:36	LINE CLEAR AVAILED
317	14-Feb-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	12:42	12:57	0:15	LINE FAULT
318	14-Feb-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	12:42	13:22	0:40	LINE FAULT
319	14-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:31	15:09	4:38	LINE CLEAR AVAILED
320	14-Feb-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:40	13:15	2:35	NFBC ISSUED
321	14-Feb-19	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	12:45	12:58	0:13	MAIN SUPPLY FAILURE
322	14-Feb-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:45	13:22	0:37	MAIN SUPPLY FAILURE
323	14-Feb-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	10:31	15:09	4:38	LINE CLEAR AVAILED
324	14-Feb-19	HASSAN	110	HV1	HALADY_110	18:35	18:51	0:16	MAIN SUPPLY FAILURE
325	14-Feb-19	HASSAN	110	HV1	BIRUR_110	18:39	18:49	0:10	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
326	14-Feb-19	HASSAN	110	HV2	GANDASI_110	18:37	18:43	0:06	MAIN SUPPLY FAILURE
327	14-Feb-19	HASSAN	110	HV2	GURUVAYANAKERE_110	14:57	16:42	1:45	LINE CLEAR AVAILED
328	14-Feb-19	HASSAN	110	HV2	KADUR_220	9:49	9:52	0:03	HAND TRIPPED
329	14-Feb-19	HASSAN	110	HV2	KONAJE_110	10:33	17:01	6:28	LINE CLEAR AVAILED
330	14-Feb-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	12:42	13:15	0:33	MAIN SUPPLY FAILURE
331	14-Feb-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:55	14:12	4:17	LINE CLEAR AVAILED
332	14-Feb-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	9:49	13:14	3:25	LINE CLEAR AVAILED
333	14-Feb-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:34	14:08	4:34	LINE CLEAR AVAILED
334	14-Feb-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	9:34	14:08	4:34	LINE CLEAR AVAILED
335	14-Feb-19	HASSAN	110	HV1	PUTTUR_220	12:45	13:00	0:15	MAIN SUPPLY FAILURE
336	14-Feb-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	12:42	13:03	0:21	MAIN SUPPLY FAILURE
337	14-Feb-19	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	12:42	13:01	0:19	MAIN SUPPLY FAILURE
338	14-Feb-19	HASSAN	110	HV1	VITLA_110	9:50	9:54	0:04	HAND TRIPPED
339	14-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:14	18:15	11:01	MAIN SUPPLY FAILURE
340	14-Feb-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:06	18:14	11:08	MAIN SUPPLY FAILURE
341	14-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:06	18:13	11:07	LINE CLEAR AVAILED
342	14-Feb-19	HASSAN	66	HV1	HANGRANAHALLI_66	18:37	18:49	0:12	MAIN SUPPLY FAILURE
343	14-Feb-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	14:04	14:12	0:08	LINE FAULT
344	14-Feb-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	18:33	18:39	0:06	MAIN SUPPLY FAILURE
345	14-Feb-19	HASSAN	66	HV2	SALAGAME_66	18:33	18:39	0:06	MAIN SUPPLY FAILURE
346	14-Feb-19	HASSAN	66	HV1	SATHENAHALLI_66	18:34	18:39	0:05	MAIN SUPPLY FAILURE
347	14-Feb-19	HASSAN	66	HV1	SATHENAHALLI_66	18:39	18:43	0:04	MAIN SUPPLY FAILURE
348	14-Feb-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:37	18:41	0:04	MAIN SUPPLY FAILURE
349	14-Feb-19	HASSAN	66	HV2	BASAVAGHATTA_66	18:37	18:53	0:16	MAIN SUPPLY FAILURE
350	14-Feb-19	MYSORE	66	HV2	ADDIHALLI_66	18:37	18:41	0:04	LOAD CURTAILMENT
351	14-Feb-19	MYSORE	66	HV2	AKKIHEBBAL_66	18:37	23:59	5:21	LOAD CURTAILMENT
352	14-Feb-19	MYSORE	66	HV1	BILIKERE_66	18:37	18:47	0:09	TRANSFORMER FAULT
353	14-Feb-19	MYSORE	66	HV1	BOMMALAPURA_66	10:30	14:45	4:15	LINE CLEAR AVAILED
354	14-Feb-19	MYSORE	66	HV2	BOMMALAPURA_66	10:30	14:45	4:15	LINE CLEAR AVAILED
355	14-Feb-19	MYSORE	66	HV2	BOMMALAPURA_66	14:47	16:24	1:36	LINE CLEAR AVAILED
356	14-Feb-19	MYSORE	66	HV2	BOOKANAKERE_66	18:37	18:47	0:10	LOAD CURTAILMENT
357	14-Feb-19	MYSORE	66	HV2	CHINAKURALI_66	18:37	18:56	0:18	LOAD CURTAILMENT
358	14-Feb-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	13:56	14:03	0:07	LINE FAULT
359	14-Feb-19	MYSORE	66	HV1	DODDINADUVADI_66	18:37	18:49	0:11	LOAD CURTAILMENT
360	14-Feb-19	MYSORE	66	HV2	DODDARAYAPET_66	18:37	18:55	0:17	LOAD CURTAILMENT
361	14-Feb-19	MYSORE	66	HV1	DODDARAYAPET_66	8:05	8:18	0:12	LINE CLEAR AVAILED
362	14-Feb-19	MYSORE	66	HV1	DODDARAYAPET_66	12:00	12:35	0:34	LINE CLEAR AVAILED
363	14-Feb-19	MYSORE	66	HV2	ELAVALA_66	18:37	18:48	0:10	LOAD CURTAILMENT
364	14-Feb-19	MYSORE	66	HV1	HANAGODU_66	18:37	19:10	0:32	LOAD CURTAILMENT
365	14-Feb-19	MYSORE	66	HV2	HANNUR_66	18:37	19:10	0:32	LOAD CURTAILMENT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
366	14-Feb-19	MYSORE	66	HV2	HDKOTE_66	18:37	19:10	0:32	LOAD CURTAILMENT
367	14-Feb-19	MYSORE	66	HV2	JAIPUR_66	18:37	18:51	0:13	LOAD CURTAILMENT
368	14-Feb-19	MYSORE	66	HV2	KIRUGAVALU_66	18:38	18:58	0:19	LOAD CURTAILMENT
369	14-Feb-19	MYSORE	66	HV2	KMDODDI_66	18:37	18:52	0:14	LOAD CURTAILMENT
370	14-Feb-19	MYSORE	66	HV3	KRPET_66	12:49	13:28	0:38	LINE CLEAR AVAILED
371	14-Feb-19	MYSORE	66	HV1	KUSHALANAGARA_66	18:37	18:50	0:12	LOAD CURTAILMENT
372	14-Feb-19	MYSORE	66	HV1	MADIKERI_66	10:40	11:19	0:38	LINE CLEAR AVAILED
373	14-Feb-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	8:17	8:23	0:06	LINE FAULT
374	14-Feb-19	MYSORE	66	HV1	NAGAMANGALA_66	18:38	18:45	0:06	LOAD CURTAILMENT
375	14-Feb-19	MYSORE	66	HV1	PANDAVAPURA_66	18:33	18:52	0:18	LOAD CURTAILMENT
376	14-Feb-19	MYSORE	66	HV2	PONNAMPET_66	18:33	18:44	0:10	LOAD CURTAILMENT
377	14-Feb-19	MYSORE	66	HV1	SATHEGALA_66	18:34	18:50	0:15	LOAD CURTAILMENT
378	14-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	18:33	18:39	0:05	LOAD CURTAILMENT
379	14-Feb-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:33	18:48	0:14	LOAD CURTAILMENT
380	14-Feb-19	MYSORE	66	HV1	SFCSHIVA_66	17:35	18:49	1:13	LINE CLEAR AVAILED
381	14-Feb-19	MYSORE	66	HV2	SFCSHIVA_66	17:35	18:49	1:13	LINE CLEAR AVAILED
382	14-Feb-19	MYSORE	66	HV4	SFCSHIVA_66	17:35	18:50	1:14	LINE CLEAR AVAILED
383	14-Feb-19	MYSORE	66	HV3	SFCSHIVA_66	17:22	23:59	6:36	LINE CLEAR AVAILED
384	14-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	14:41	0:00	9:18	LINE CLEAR AVAILED
385	14-Feb-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 MALIYURU_66 KIRUGAVALU_66	6:33	6:44	0:10	LINE FAULT
386	14-Feb-19	MYSORE	66	HV1	YELANDUR_66	18:37	18:45	0:07	LOAD CURTAILMENT
387	14-Feb-19	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	11:45	11:48	0:02	TRANSFORMER FAULT
388	14-Feb-19	TUMKUR	110	TR-3	AMMASANDRA_110	9:53	10:12	0:18	TRANSFORMER FAULT
389	14-Feb-19	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	18:53	19:47	0:53	LOAD CURTAILMENT
390	14-Feb-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	18:51	19:53	1:02	LOAD CURTAILMENT
391	14-Feb-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	16:08	16:25	0:17	TRANSFORMER FAULT
392	14-Feb-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	18:51	19:52	1:01	LOAD CURTAILMENT
393	14-Feb-19	TUMKUR	66	DYAVARANAHALI-RANGENAHALLI (P-R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:58	17:42	9:43	LINE CLEAR AVAILED
394	14-Feb-19	TUMKUR	66	TR-1	HONNALI_66	11:59	16:23	4:24	LINE CLEAR AVAILED
395	14-Feb-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	19:01	19:36	0:35	LOAD CURTAILMENT
396	14-Feb-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	18:44	18:54	0:09	LOAD CURTAILMENT
397	14-Feb-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:58	17:54	6:56	LINE FAULT
398	14-Feb-19	TUMKUR	66	THALLAK 220kv- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	4:29	6:25	1:56	LINE FAULT
399	14-Feb-19	TUMKUR	66	TR-2	TUMKUR_66	9:55	16:26	6:31	LINE CLEAR AVAILED
400	15-Feb-19	BAGALKOT	110	110/11KV, HV1	ACHANUR_110	8:22	8:28	0:06	LOAD CURTAILMENT
401	15-Feb-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	8:22	8:29	0:07	LOAD CURTAILMENT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
402	15-Feb-19	BAGALKOT	220	KAKMARI1-ATHANI	ATHANI_220	23:31	23:59	0:28	LINE FAULT
403	15-Feb-19	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	8:24	8:55	0:31	LOAD CURTAILMENT
404	15-Feb-19	BAGALKOT	110	ATHANI220-TAUSHI	TAUSHI_110	20:17	20:24	0:07	LINE FAULT
405	15-Feb-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	0:05	1:27	1:22	LINE FAULT
406	15-Feb-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	1:32	15:11	13:39	LINE CLEAR AVAILED
407	15-Feb-19	BAGALKOT	110	110/11KV, HV2	TORVI_110	12:22	13:05	0:43	LINE CLEAR AVAILED
408	15-Feb-19	BAGALKOT	220	220/110KV, HV2	CHIKKODI_220	10:05	13:37	3:32	LINE CLEAR AVAILED
409	15-Feb-19	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	17:12	17:37	0:25	LINE CLEAR AVAILED
410	15-Feb-19	BAGALKOT	110	110/11KV, HV1	GADAG_110	16:48	16:53	0:05	TRANSFORMER FAULT
411	15-Feb-19	BAGALKOT	220	GADAG-DHONI2	GADAG_220	10:25	19:08	8:43	LINE CLEAR AVAILED
412	15-Feb-19	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	8:22	8:42	0:20	LOAD CURTAILMENT
413	15-Feb-19	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	1:02	1:28	0:26	LINE CLEAR AVAILED
414	15-Feb-19	BAGALKOT	110	110/33KV, HV1	HANGAL_110, PALA_33	9:21	9:47	0:26	LOAD CURTAILMENT
415	15-Feb-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	8:58	9:09	0:11	LINE FAULT
416	15-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110, KOLIGUDDA_33, SULTANAPUR_33	8:23	8:29	0:06	LOAD CURTAILMENT
417	15-Feb-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	9:35	9:42	0:07	TRANSFORMER FAULT
418	15-Feb-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	11:06	11:11	0:05	TRANSFORMER FAULT
419	15-Feb-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	19:00	19:03	0:03	TRANSFORMER FAULT
420	15-Feb-19	BAGALKOT	110	ANANTPUR SOLAR-KONNUR	KONNUR_110	0:22	1:30	1:08	LINE CLEAR AVAILED
421	15-Feb-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	8:22	8:35	0:13	LOAD CURTAILMENT
422	15-Feb-19	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66, AREMALLAPUR_33	9:22	10:02	0:40	LOAD CURTAILMENT
423	15-Feb-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKED 33KV,NEVARGI 33KV	11:40	11:46	0:06	TRANSFORMER FAULT
424	15-Feb-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI 33KV	15:05	15:07	0:02	TRANSFORMER FAULT
425	15-Feb-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	16:11	17:40	1:29	LINE CLEAR AVAILED
426	15-Feb-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	9:22	9:30	0:08	LOAD CURTAILMENT
427	15-Feb-19	BAGALKOT	110	110/33KV,HV2	SAVALGI_110,HIREPADASLAGI 33KV& KALBILAGI 33KV	8:23	8:49	0:26	LOAD CURTAILMENT
428	15-Feb-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	1:18	1:27	0:09	HAND TRIPPED
429	15-Feb-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	17:58	18:06	0:08	HAND TRIPPED
430	15-Feb-19	BAGALKOT	110	BPCL-NARGUND	NARAGUND_110	1:31	1:35	0:04	LINE FAULT
431	15-Feb-19	BAGALKOT	220	KAVATAGI LIS-VAJRAMATTI	VAJRAMATTI_220	15:47	16:52	1:05	LINE CLEAR AVAILED
432	15-Feb-19	BAGALKOT	110	MAMADAPUR-SHIRBUR	MAMADAPUR_110	1:37	1:39	0:02	LINE FAULT
433	15-Feb-19	BAGALKOT	110	110/11KV,HV4	M K HUBLI_110	17:33	18:53	1:20	LINE CLEAR AVAILED
434	15-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:23	15:44	2:21	LINE CLEAR AVAILED
435	15-Feb-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGATTA	SIDLAGATTA, MELUR	13:11	13:18	0:07	LINE FAULT
436	15-Feb-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGATTA	SIDLAGATTA, MELUR	14:35	15:44	1:08	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
437	15-Feb-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	6:35	6:41	0:06	LINE FAULT
438	15-Feb-19	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	16:08	16:15	0:07	LOAD CHANGEOVER
439	15-Feb-19	BANGALORE	66	HV2	HBR LAYOUT	12:33	12:55	0:22	TRANSFORMER FAULT
440	15-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	13:46	14:31	0:44	LINE CLEAR AVAILED
441	15-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	7:14	7:53	0:39	LINE FAULT
442	15-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:33	15:01	2:28	LINE FAULT
443	15-Feb-19	BANGALORE	66	HV1	JIGANI 66	18:05	20:29	2:23	MAIN SUPPLY FAILURE
444	15-Feb-19	BANGALORE	66	HV2	JIGANI 66	7:05	7:34	0:29	MAIN SUPPLY FAILURE
445	15-Feb-19	BANGALORE	66	HV3	JIGANI 66	7:05	7:34	0:29	MAIN SUPPLY FAILURE
446	15-Feb-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	17:07	19:03	1:56	LINE CLEAR AVAILED
447	15-Feb-19	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:30	19:03	3:33	LINE FAULT
448	15-Feb-19	BANGALORE	66	KOLAR 220 - NARASAPURA	NARASAPURA	7:18	7:26	0:08	LINE FAULT
449	15-Feb-19	BANGALORE	66	HV1	KONDASPURA	15:40	16:08	0:27	LINE CLEAR AVAILED
450	15-Feb-19	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	22:15	22:59	0:43	MAIN SUPPLY FAILURE
451	15-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:15	22:54	0:38	MAIN SUPPLY FAILURE
452	15-Feb-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	22:15	23:59	1:43	MAIN SUPPLY FAILURE
453	15-Feb-19	BANGALORE	220	LV1	MALUR 220	22:15	22:50	0:34	TRANSFORMER FAULT
454	15-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:24	12:03	0:38	LINE CLEAR AVAILED
455	15-Feb-19	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	17:34	17:37	0:03	LOAD CHANGEOVER
456	15-Feb-19	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	17:26	17:40	0:14	LOAD CHANGEOVER
457	15-Feb-19	BANGALORE	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE, RBI	18:35	19:19	0:43	LINE FAULT
458	15-Feb-19	BANGALORE	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE, RBI	19:32	20:14	0:42	LINE FAULT
459	15-Feb-19	BANGALORE	66	HANUMANTHANAGARA - YEDUMADU	YEDUMADU	6:15	6:25	0:10	LOAD CHANGEOVER
460	15-Feb-19	BANGALORE	220	HOODY 400 - ITPL(EHT)	ITPL(EHT), EPIP 220	10:08	10:34	0:25	LINE FAULT
461	15-Feb-19	BANGALORE	66	EPIP 220 - CHANDAPURA 2	SHAMRAJ TECH PARK, KACHMARANAHALLI	10:08	10:46	0:37	MAIN SUPPLY FAILURE
462	15-Feb-19	BANGALORE	66	EPIP 220 - GEI	SHAMRAJ TECH PARK, KACHMARANAHALLI	10:08	10:46	0:37	MAIN SUPPLY FAILURE
463	15-Feb-19	BANGALORE	66	HV2	EPIP 220	10:08	10:46	0:37	MAIN SUPPLY FAILURE
464	15-Feb-19	BANGALORE	66	HV1	EPIP 220	10:08	10:46	0:37	MAIN SUPPLY FAILURE
465	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	15:38	15:41	0:02	LINE FAULT
466	15-Feb-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	17:17	17:25	0:07	LOAD CHANGEOVER

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
467	15-Feb-19	BANGALORE	66	KHODAYS 220 - BMRCL (EHT)	BMRCL (EHT)	17:17	17:25	0:08	LOAD CHANGEOVER
468	15-Feb-19	BANGALORE	66	HV1	KHODAYS 220	17:19	17:24	0:05	LOAD CHANGEOVER
469	15-Feb-19	BANGALORE	66	HV2	KHODAYS 220	17:19	17:25	0:05	LOAD CHANGEOVER
470	15-Feb-19	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	17:15	17:20	0:05	LOAD CHANGEOVER
471	15-Feb-19	BANGALORE	220	SOMANAHALLI 220 - HAROHALLI (EHT)	KANAKAPURA 220, HAROHALLI (EHT)	13:35	13:39	0:04	LINE FAULT
472	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	13:35	13:48	0:13	MAIN SUPPLY FAILURE
473	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	13:35	13:49	0:13	MAIN SUPPLY FAILURE
474	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, DODDALAHALLI	13:35	13:49	0:13	MAIN SUPPLY FAILURE
475	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	13:35	13:49	0:13	MAIN SUPPLY FAILURE
476	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHAGAR	13:35	13:49	0:13	MAIN SUPPLY FAILURE
477	15-Feb-19	BANGALORE	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	13:35	13:49	0:13	MAIN SUPPLY FAILURE
478	15-Feb-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	18:05	20:37	2:32	LINE CLEAR AVAILED
479	15-Feb-19	BANGALORE	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	10:32	10:55	0:23	MAIN SUPPLY FAILURE
480	15-Feb-19	BANGALORE	220	TK HALLI 220 - KOLLEGALA 220	TK HALLI 220	10:32	10:55	0:23	MAIN SUPPLY FAILURE
481	15-Feb-19	BANGALORE	220	HV1	TK HALLI 220	10:32	10:56	0:24	MAIN SUPPLY FAILURE
482	15-Feb-19	BANGALORE	220	HV2	TK HALLI 220	10:32	11:01	0:29	MAIN SUPPLY FAILURE
483	15-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB (EHT)	10:32	11:02	0:30	MAIN SUPPLY FAILURE
484	15-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB (EHT)	10:32	11:02	0:30	MAIN SUPPLY FAILURE
485	15-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB (EHT)	10:32	11:02	0:30	MAIN SUPPLY FAILURE
486	15-Feb-19	BANGALORE	66	HV1	TK HALLI 220	10:32	11:02	0:30	MAIN SUPPLY FAILURE
487	15-Feb-19	BANGALORE	66	HV2	TK HALLI 220	10:32	11:02	0:30	MAIN SUPPLY FAILURE
488	15-Feb-19	BANGALORE	66	TK HALLI 220 - MANDYA 1 & 2	KM DODDI, KK DODDI, KIADB MANDYA, MANDYA	10:32	11:57	1:25	MAIN SUPPLY FAILURE
489	15-Feb-19	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR	10:32	11:02	0:30	MAIN SUPPLY FAILURE
490	15-Feb-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	10:32	11:02	0:30	MAIN SUPPLY FAILURE
491	15-Feb-19	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE, K HONALGERE	10:32	11:57	1:25	MAIN SUPPLY FAILURE
492	15-Feb-19	BANGALORE	220	TK HALLI 220 - KANAKAPURA 220	TK HALLI 220	13:35	13:55	0:20	MAIN SUPPLY FAILURE
493	15-Feb-19	BANGALORE	220	HV1	TK HALLI 220	13:35	13:55	0:20	MAIN SUPPLY FAILURE
494	15-Feb-19	BANGALORE	220	HV2	TK HALLI 220	13:35	14:51	1:16	MAIN SUPPLY FAILURE
495	15-Feb-19	BANGALORE	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	14:23	14:35	0:12	LINE FAULT
496	15-Feb-19	BANGALORE	220	HV1	TK HALLI 220	14:23	14:36	0:13	MAIN SUPPLY FAILURE
497	15-Feb-19	BANGALORE	66	HV1	TK HALLI 220	13:35	14:51	1:16	MAIN SUPPLY FAILURE
498	15-Feb-19	BANGALORE	66	HV2	TK HALLI 220	13:35	14:51	1:16	MAIN SUPPLY FAILURE
499	15-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB (EHT)	13:35	14:51	1:16	MAIN SUPPLY FAILURE
500	15-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB (EHT)	13:35	14:51	1:16	MAIN SUPPLY FAILURE
501	15-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB (EHT)	13:35	14:51	1:16	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
502	15-Feb-19	BANGALORE	66	TK HALLI 220 - MANDYA 1 & 2	KM DODDI, KK DODDI, KIADB MANDYA, MANDYA	13:35	14:51	1:16	MAIN SUPPLY FAILURE
503	15-Feb-19	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR	13:35	14:51	1:16	MAIN SUPPLY FAILURE
504	15-Feb-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	13:35	14:51	1:16	MAIN SUPPLY FAILURE
505	15-Feb-19	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE, K HONALGERE	13:35	14:51	1:16	MAIN SUPPLY FAILURE
506	15-Feb-19	GULBARGA	220	HV1,HV2	HALBURGA_220	6:30	6:40	0:10	TRANSFORMER FAULT
507	15-Feb-19	GULBARGA	220	ITTAGGI-HARAKNAL	ITTAGGI_220	9:45	17:28	7:43	LINE CLEAR AVAILED
508	15-Feb-19	GULBARGA	110	HV4	YELBURGA_110	8:21	8:40	0:19	LOAD CURTAILMENT
509	15-Feb-19	GULBARGA	110	SIDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHAD ESUGUR_110	3:02	3:15	0:13	LINE FAULT
510	15-Feb-19	GULBARGA	110	HV2	RAICHUR_220	12:11	12:16	0:05	TRANSFORMER FAULT
511	15-Feb-19	GULBARGA	110	HV2,HV2	RAJESHWAR_110	9:30	9:45	0:15	LOAD CURTAILMENT
512	15-Feb-19	GULBARGA	110	HV2	KOLHAR_110	9:22	9:30	0:08	LOAD CURTAILMENT
513	15-Feb-19	GULBARGA	110	HV1,HV2	SANKLAPUR_110	15:32	16:10	0:38	LINE CLEAR AVAILED
514	15-Feb-19	GULBARGA	110	HV1	WADAGERA_110	8:22	8:40	0:18	LOAD CURTAILMENT
515	15-Feb-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOA_110,KAM ALANAGAR_110	15:05	15:55	0:50	LINE FAULT
516	15-Feb-19	GULBARGA	110	HV1	GANADAL_110	8:21	8:27	0:06	LOAD CURTAILMENT
517	15-Feb-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	15:05	23:59	8:54	LINE FAULT
518	15-Feb-19	GULBARGA	110	HV1	KURKUNTA_110	8:30	9:05	0:35	TRANSFORMER FAULT
519	15-Feb-19	GULBARGA	110	HV1	KEMBHAVI_110	8:00	8:10	0:10	LOAD CURTAILMENT
520	15-Feb-19	GULBARGA	110	HV1	KEMBHAVI_110	7:15	7:20	0:05	LOAD CURTAILMENT
521	15-Feb-19	GULBARGA	110	HV1	KEMBHAVI_110	14:15	16:05	1:50	LINE CLEAR AVAILED
522	15-Feb-19	GULBARGA	66	HV2	UPANAYAKANAHALLI_66	12:48	12:54	0:06	TRANSFORMER FAULT
523	15-Feb-19	GULBARGA	66	HV2	UPANAYAKANAHALLI_66	13:49	14:00	0:11	TRANSFORMER FAULT
524	15-Feb-19	GULBARGA	66	HV1	CJHALLI_66	8:20	8:30	0:10	LOAD CURTAILMENT
525	15-Feb-19	GULBARGA	66	HV1	SOVENAHALLI_66	9:25	9:35	0:10	TRANSFORMER FAULT
526	15-Feb-19	GULBARGA	66	ITTAGGI-CLEANMAX2	ITTAGGI_220	19:45	19:55	0:10	LINE CLEAR AVAILED
527	15-Feb-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:00	14:51	4:51	LINE FAULT
528	15-Feb-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:14	12:25	0:11	LINE FAULT
529	15-Feb-19	HASSAN	110	SHRLKPBARANG	SHIRALKOPPA_220	12:22	12:28	0:06	HAND TRIPPED
530	15-Feb-19	HASSAN	110	SHRLKPKITTADAHALLI	SHIRALKOPPA_220	12:22	12:27	0:05	HAND TRIPPED
531	15-Feb-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:22	12:26	0:04	HAND TRIPPED
532	15-Feb-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:22	12:30	0:08	HAND TRIPPED
533	15-Feb-19	HASSAN	110	SHRLKPSORAB	SHIRALKOPPA_220	12:22	12:29	0:07	HAND TRIPPED
534	15-Feb-19	HASSAN	220	TALAGU-STRP2	TALAGUPA_400	10:00	14:52	4:52	LINE FAULT
535	15-Feb-19	HASSAN	110	HV1	HALADY_110	8:24	8:34	0:10	MAIN SUPPLY FAILURE
536	15-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	19:41	19:58	0:17	LINE FAULT
537	15-Feb-19	HASSAN	110	HV2	GERUMARA_110	14:56	23:59	9:03	LINE CLEAR AVAILED
538	15-Feb-19	HASSAN	110	HV2	KARAYA_110	9:59	12:09	2:10	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
539	15-Feb-19	HASSAN	110	KAVOOR-EMAR	KAVOOR_220	21:25	21:34	0:09	LINE FAULT
540	15-Feb-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:13	14:52	4:39	LINE CLEAR AVAILED
541	15-Feb-19	HASSAN	110	HV2	NAVUNDA_110	8:35	8:48	0:13	TRANSFORMER FAULT
542	15-Feb-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	5:30	5:41	0:11	LINE FAULT
543	15-Feb-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	12:51	12:59	0:08	HAND TRIPPED
544	15-Feb-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	16:05	18:15	2:10	LINE CLEAR AVAILED
545	15-Feb-19	HASSAN	66	HV1	GENDEHALLY_66	12:51	12:59	0:08	HAND TRIPPED
546	15-Feb-19	HASSAN	66	HV1	GENDEHALLY_66	16:05	18:15	2:10	LINE CLEAR AVAILED
547	15-Feb-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	16:05	18:15	2:10	LINE CLEAR AVAILED
548	15-Feb-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	0:16	1:10	0:54	LINE FAULT
549	15-Feb-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:48	10:52	1:04	LINE CLEAR AVAILED
550	15-Feb-19	MYSORE	66	HV2	BGNAGARA_66	11:06	11:37	0:31	LINE CLEAR AVAILED
551	15-Feb-19	MYSORE	66	HV1	CHINAKURALI_66	14:32	23:59	9:26	LINE CLEAR AVAILED
552	15-Feb-19	MYSORE	220	CR NAGARA-MADHUVANAHALLI 1	CRNAGAR_220, MADHUVANAHALLI_220, CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66, TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66, BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66, SANTHEMARAHALLI_66 KUNTHUR_66, SATHEGALA_66 YELANDUR_66, KOLLEGALA_66 MARTAHALLI_66, DODDINADUVADI_66 HANNUR_66, BANDALLI_66 COWDALLI_66, RAMAPURA_MYS_66 PGPALYA_66	11:15	11:39	0:24	LINE CLEAR AVAILED
553	15-Feb-19	MYSORE	220	CR NAGARA-MADHUVANAHALLI 2	CRNAGAR_220, MADHUVANAHALLI_220, CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66, TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66, BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66, SANTHEMARAHALLI_66 KUNTHUR_66, SATHEGALA_66 YELANDUR_66, KOLLEGALA_66 MARTAHALLI_66, DODDINADUVADI_66 HANNUR_66, BANDALLI_66 COWDALLI_66, RAMAPURA_MYS_66 PGPALYA_66	11:15	11:39	0:24	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
554	15-Feb-19	MYSORE	220	CR NAGARA-MADHUVANAHALLI 1	CRNAGAR_220, CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAkanAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66	13:34	15:13	1:39	MAIN SUPPLY FAILURE
555	15-Feb-19	MYSORE	220	CR NAGARA-MADHUVANAHALLI 2	CRNAGAR_220, CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAkanAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66	13:34	15:13	1:39	MAIN SUPPLY FAILURE
556	15-Feb-19	MYSORE	66	HV4	DODDARAYAPET_66	7:49	7:57	0:07	LINE CLEAR AVAILED
557	15-Feb-19	MYSORE	66	HV2	GUNDULPET_66	15:07	15:21	0:14	LOAD CURTAILMENT
558	15-Feb-19	MYSORE	220	KADAKOLA-BASTIPURA 1	KADAKOLA_220 JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66	10:13	10:49	0:35	LINE FAULT
559	15-Feb-19	MYSORE	220	KADAKOLA-BASTIPURA 1	KADAKOLA_220 JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66	11:15	11:53	0:38	LINE FAULT
560	15-Feb-19	MYSORE	220	KADAKOLA-BASTIPURA 2	KADAKOLA_220 JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66	10:27	11:15	0:48	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
561	15-Feb-19	MYSORE	220	KADAKOLA-CR NAGARA 1	CRNAGAR_220, MADHUVANAHALLI_220, CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66, TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66, BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66, SANTHEMARAHALLI_66 KUNTHUR_66, SATHEGALA_66 YELANDUR_66, KOLLEGALA_66 MARTAHALLI_66, DODDINADUVADI_66 HANNUR_66, BANDALLI_66 COWDALLI_66, RAMAPURA_MYS_66 PGPALYA_66	10:27	10:55	0:28	LINE CLEAR AVAILED
562	15-Feb-19	MYSORE	220	KADAKOLA-CR NAGARA 1	CRNAGAR_220, MADHUVANAHALLI_220, CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66, TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66, BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66, SANTHEMARAHALLI_66 KUNTHUR_66, SATHEGALA_66 YELANDUR_66, KOLLEGALA_66 MARTAHALLI_66, DODDINADUVADI_66 HANNUR_66, BANDALLI_66 COWDALLI_66, RAMAPURA_MYS_66 PGPALYA_66	11:15	13:04	1:49	LINE CLEAR AVAILED
563	15-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66,	16:07	16:19	0:11	LOAD CURTAILMENT
564	15-Feb-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66,	16:07	16:19	0:11	LOAD CURTAILMENT
565	15-Feb-19	MYSORE	66	KM DODDI-HV1	KMDODDI_66 KOLKARANADODDI_66, KIADBMANDYA_66 MADDUR_66, K_HONNALGERE_66	10:30	11:58	1:28	LINE CLEAR AVAILED
566	15-Feb-19	MYSORE	66	KM DODDI-HV2	KMDODDI_66 KOLKARANADODDI_66, KIADBMANDYA_66 MADDUR_66, K_HONNALGERE_66	10:30	23:59	13:28	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
567	15-Feb-19	MYSORE	66	KM DODDI-HV1	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	13:35	14:50	1:15	LINE CLEAR AVAILED
568	15-Feb-19	MYSORE	66	KM DODDI-HV2	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	13:35	14:50	1:14	LINE CLEAR AVAILED
569	15-Feb-19	MYSORE	66	KM DODDI-HV1	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	15:32	15:41	0:09	HAND TRIPPED
570	15-Feb-19	MYSORE	66	KM DODDI-HV2	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	15:32	15:41	0:09	HAND TRIPPED
571	15-Feb-19	MYSORE	66	HV2	KMDODDI_66	17:23	17:28	0:05	TRANSFORMER FAULT
572	15-Feb-19	MYSORE	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	7:07	7:18	0:11	LINE FAULT
573	15-Feb-19	MYSORE	66	HV1	KRPET_220	16:52	17:25	0:32	LINE CLEAR AVAILED
574	15-Feb-19	MYSORE	220	MADHUVANAHALLI-TK HALLI 1	MADHUVANAHALLI_220, KOLLEGALA_66 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66	13:40	14:53	1:13	LINE CLEAR AVAILED
575	15-Feb-19	MYSORE	220	MADHUVANAHALLI-TK HALLI 2	MADHUVANAHALLI_220, KOLLEGALA_66 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66	13:40	14:53	1:13	LINE CLEAR AVAILED
576	15-Feb-19	MYSORE	66	HV1	SATHEGALA_66	8:20	8:30	0:09	LOAD CURTAILMENT
577	15-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	8:20	8:25	0:04	LOAD CURTAILMENT
578	15-Feb-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	8:20	8:31	0:10	LOAD CURTAILMENT
579	15-Feb-19	MYSORE	66	HV4	SFCSHIVA_66	9:30	15:41	6:11	LINE CLEAR AVAILED
580	15-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	4:44	13:27	8:43	LINE CLEAR AVAILED
581	15-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	13:40	23:59	10:19	LINE CLEAR AVAILED
582	15-Feb-19	MYSORE	66	SFC SIVA-MADHUVANAHALLI	SFCSHIVA_66	10:30	11:15	0:45	MAIN SUPPLY FAILURE
583	15-Feb-19	MYSORE	66	SFC SIVA-MADHUVANAHALLI	SFCSHIVA_66	13:30	14:50	1:20	MAIN SUPPLY FAILURE
584	15-Feb-19	MYSORE	66	SFC SIVA-SANTHEGALA	SFCSHIVA_66	10:30	11:15	0:45	MAIN SUPPLY FAILURE
585	15-Feb-19	MYSORE	66	SFC SIVA-SANTHEGALA	SFCSHIVA_66	13:30	14:50	1:20	MAIN SUPPLY FAILURE
586	15-Feb-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:29	11:37	0:08	LINE FAULT
587	15-Feb-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:49	11:54	0:04	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
588	15-Feb-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	10:33	14:37	4:03	LINE CLEAR AVAILED
589	15-Feb-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	10:34	12:14	1:40	LINE CLEAR AVAILED
590	15-Feb-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	13:39	14:24	0:45	LINE CLEAR AVAILED
591	15-Feb-19	MYSORE	66	VAJAMANGALA-MEGALAPURA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	10:33	14:35	4:01	LINE CLEAR AVAILED
592	15-Feb-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	10:25	12:12	1:47	LINE CLEAR AVAILED
593	15-Feb-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	13:35	14:25	0:50	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
594	15-Feb-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	BANNUR_66 KIRUGAVALU_66 MALIYURU_66 MEGALAPURA_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 BANNIMANTAP_66	10:34	14:35	4:01	LINE CLEAR AVAILED
595	15-Feb-19	MYSORE	220	VAJAMANGALA-TK HALLI	VAJAMANGALA_220	10:25	12:00	1:35	LINE CLEAR AVAILED
596	15-Feb-19	MYSORE	220	VAJAMANGALA-TK HALLI	VAJAMANGALA_220	13:35	14:46	1:11	LINE CLEAR AVAILED
597	15-Feb-19	MYSORE	220	HV1	VAJAMANGALA_220	10:28	0:00	13:31	LINE CLEAR AVAILED
598	15-Feb-19	MYSORE	220	HV1	VAJAMANGALA_220	13:34	14:14	0:40	LINE CLEAR AVAILED
599	15-Feb-19	MYSORE	220	HV2	VAJAMANGALA_220	10:26	12:01	1:34	LINE CLEAR AVAILED
600	15-Feb-19	MYSORE	220	HV2	VAJAMANGALA_220	13:37	14:14	0:37	LINE CLEAR AVAILED
601	15-Feb-19	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	17:40	18:54	1:14	LINE CLEAR AVAILED
602	15-Feb-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	17:40	17:56	0:15	LINE CLEAR AVAILED
603	15-Feb-19	TUMKUR	110	TR-1	GUBBI_110	4:04	4:09	0:04	TRANSFORMER FAULT
604	15-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:37	13:38	3:00	LINE CLEAR AVAILED
605	15-Feb-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:48	16:01	0:13	LINE FAULT
606	15-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:01	17:10	9:09	LINE CLEAR AVAILED
607	15-Feb-19	TUMKUR	66	TR-2	HARIYABBE_66	14:19	14:28	0:09	TRANSFORMER FAULT
608	15-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	17:40	18:03	0:23	LINE CLEAR AVAILED
609	15-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	17:40	18:03	0:23	LINE CLEAR AVAILED
610	15-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:54	7:57	0:03	HAND TRIPPED
611	15-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:49	11:01	0:12	LINE CLEAR AVAILED
612	15-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:50	17:00	0:09	LINE FAULT
613	15-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	21:08	21:28	0:19	LINE FAULT
614	15-Feb-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	0:56	1:31	0:35	LINE CLEAR AVAILED
615	15-Feb-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	18:38	18:56	0:17	LINE CLEAR AVAILED
616	15-Feb-19	TUMKUR	66	TR-1	KATTIGE_66	8:58	9:11	0:12	TRANSFORMER FAULT
617	15-Feb-19	TUMKUR	66	TR-1	KATTIGE_66	17:42	17:54	0:12	TRANSFORMER FAULT
618	15-Feb-19	TUMKUR	66	TR-2	MADHUGIRI_66	11:03	11:40	0:37	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
619	15-Feb-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	10:01	10:11	0:09	LINE FAULT
620	16-Feb-19	BAGALKOT	110	110/11KV, HV2	BANHATTI_110	13:04	14:50	1:46	LINE CLEAR AVAILED
621	16-Feb-19	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	10:13	15:27	5:14	LINE CLEAR AVAILED
622	16-Feb-19	BAGALKOT	220	KAKMARI1-ATHANI	ATHANI_220	0:00	0:26	0:26	LINE CLEAR AVAILED
623	16-Feb-19	BAGALKOT	220	220/110KV,HV1,LV1	GADAG_220	19:54	20:20	0:26	TRANSFORMER FAULT
624	16-Feb-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110	0:00	19:15	19:15	LINE CLEAR AVAILED
625	16-Feb-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110	19:54	23:59	4:05	LINE FAULT
626	16-Feb-19	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	20:01	20:38	0:37	LINE CLEAR AVAILED
627	16-Feb-19	BAGALKOT	110	RANEBENNUR-BYDAGI	BYADAGI_110	4:40	15:23	10:43	LINE FAULT
628	16-Feb-19	BAGALKOT	110	RANEBENNUR-BYDAGI	BYADAGI_110	15:23	15:27	0:04	LINE FAULT
629	16-Feb-19	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	19:59	20:41	0:42	TRANSFORMER FAULT
630	16-Feb-19	BAGALKOT	110	SUZLON1(L3)-DAMBAL	DAMBAL_110	20:33	20:55	0:22	LINE CLEAR AVAILED
631	16-Feb-19	BAGALKOT	110	SUZLON2(L2)-DAMBAL	DAMBAL_110	20:33	20:55	0:22	LINE CLEAR AVAILED
632	16-Feb-19	BAGALKOT	110	ENECORN-DAMBAL	DAMBAL_110	20:33	21:00	0:27	LINE CLEAR AVAILED
633	16-Feb-19	BAGALKOT	110	GADAG2(SAMBAPUR ROAD)-DAMBAL	DAMBAL_110	20:36	20:45	0:09	HAND TRIPPED
634	16-Feb-19	BAGALKOT	110	DAMBAL-MUNDARGI	MUNDARGI_110	20:37	20:47	0:10	HAND TRIPPED
635	16-Feb-19	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	20:37	20:47	0:10	LINE FAULT
636	16-Feb-19	BAGALKOT	110	GADAG ROAD -GOPPANKOPPA	GOPPANKOPPA_110	9:35	15:55	6:20	LINE CLEAR AVAILED
637	16-Feb-19	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPPANKOPPA	GOPPANKOPPA_110	8:47	9:34	0:47	LINE CLEAR AVAILED
638	16-Feb-19	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPPANKOPPA	GOPPANKOPPA_110	15:56	16:02	0:06	HAND TRIPPED
639	16-Feb-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	16:32	16:35	0:03	HAND TRIPPED
640	16-Feb-19	BAGALKOT	110	110/11KV,HV1	KIRUVATTI_110	12:05	12:18	0:13	LINE CLEAR AVAILED
641	16-Feb-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR 33KV	11:05	16:59	5:54	TRANSFORMER FAULT
642	16-Feb-19	BAGALKOT	110	ASHOK IRON PLANT-MACHE	MACHE_110	15:22	19:11	3:49	LINE CLEAR AVAILED
643	16-Feb-19	BAGALKOT	110	GSML1-MAHALINGAPUR	MAHALINGAPUR_220	16:20	16:41	0:21	LINE CLEAR AVAILED
644	16-Feb-19	BAGALKOT	110	VIJAY NAGAR SUGERS-MUNDARGI	MUNDARGI_110	20:55	20:57	0:02	HAND TRIPPED
645	16-Feb-19	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	10:38	12:52	2:14	LINE CLEAR AVAILED
646	16-Feb-19	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	10:21	17:22	7:01	LINE CLEAR AVAILED
647	16-Feb-19	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	16:52	20:46	3:54	TRANSFORMER FAULT
648	16-Feb-19	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	12:32	12:45	0:13	TRANSFORMER FAULT
649	16-Feb-19	BAGALKOT	110	110/11KV, HV2	RON_110	15:47	16:28	0:41	LINE CLEAR AVAILED
650	16-Feb-19	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	12:53	17:14	4:21	LINE CLEAR AVAILED
651	16-Feb-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	9:40	11:30	1:50	LINE CLEAR AVAILED
652	16-Feb-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	4:18	15:44	11:26	LINE FAULT
653	16-Feb-19	BAGALKOT	110	SIRSI220-SIRSI2(IDLE3)	SIRSI_110	3:25	3:41	0:16	LINE FAULT
654	16-Feb-19	BAGALKOT	110	SIRSI-KUMATA1	KUMTA_110	3:20	7:25	4:05	LINE FAULT
655	16-Feb-19	GULBARGA	110	HV3	BEVOOR_110	7:23	7:42	0:19	TRANSFORMER FAULT
656	16-Feb-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	0:00	10:39	10:39	LINE FAULT
657	16-Feb-19	GULBARGA	110	HANUMANAL-VARIKAL	HANUMANAL_110	14:40	15:15	0:35	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
658	16-Feb-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	BTPS_WATER_WORKS,MUKUNDA_110, KAMPLI_GLB_110	3:25	3:41	0:16	LINE FAULT
659	16-Feb-19	GULBARGA	110	HV2	KEMBHAVI_110	8:08	8:21	0:13	TRANSFORMER FAULT
660	16-Feb-19	GULBARGA	110	HV2	KEMBHAVI_110	12:30	13:35	1:05	LINE CLEAR AVAILED
661	16-Feb-19	GULBARGA	110	HV2	KEMBHAVI_110	14:16	15:33	1:17	LINE CLEAR AVAILED
662	16-Feb-19	GULBARGA	110	HV1	KEMBHAVI_110	11:35	13:45	2:10	LINE CLEAR AVAILED
663	16-Feb-19	GULBARGA	110	HV1	KEMBHAVI_110	16:35	17:00	0:25	LINE CLEAR AVAILED
664	16-Feb-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:46	14:03	3:17	NFBC ISSUED
665	16-Feb-19	HASSAN	220	HV2	MRSMSG_220	12:11	17:46	5:35	LINE CLEAR AVAILED
666	16-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:46	14:04	3:18	LINE CLEAR AVAILED
667	16-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	14:13	15:56	1:43	LINE CLEAR AVAILED
668	16-Feb-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	8:43	10:26	1:43	NFBC ISSUED
669	16-Feb-19	HASSAN	110	LV2	MRSMSG_220	12:11	17:47	5:36	LINE CLEAR AVAILED
670	16-Feb-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	10:34	10:42	0:08	HAND TRIPPED
671	16-Feb-19	HASSAN	110	HV1	MRSMSG_220	11:54	11:56	0:02	HAND TRIPPED
672	16-Feb-19	HASSAN	110	HV1	MRSMSG_220	18:02	18:03	0:01	HAND TRIPPED
673	16-Feb-19	HASSAN	110	HV2	MRSMSG_220	11:54	11:56	0:02	HAND TRIPPED
674	16-Feb-19	HASSAN	110	HV2	MRSMSG_220	18:02	18:03	0:01	HAND TRIPPED
675	16-Feb-19	HASSAN	110	HV3	MRSMSG_220	11:57	11:59	0:02	HAND TRIPPED
676	16-Feb-19	HASSAN	110	HV3	MRSMSG_220	18:03	18:05	0:02	HAND TRIPPED
677	16-Feb-19	HASSAN	110	HV4	MRSMSG_220	11:57	11:59	0:02	HAND TRIPPED
678	16-Feb-19	HASSAN	110	HV4	MRSMSG_220	18:03	18:05	0:02	HAND TRIPPED
679	16-Feb-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	10:41	10:49	0:08	MAIN SUPPLY FAILURE
680	16-Feb-19	HASSAN	110	HV2	GERUMARA_110	0:00	13:39	13:39	LINE CLEAR AVAILED
681	16-Feb-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	13:34	14:26	0:52	LINE CLEAR AVAILED
682	16-Feb-19	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:31	13:19	2:48	LINE CLEAR AVAILED
683	16-Feb-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:12	13:31	3:19	LINE CLEAR AVAILED
684	16-Feb-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:30	13:21	2:51	LINE CLEAR AVAILED
685	16-Feb-19	HASSAN	110	KULASH-KERKNJ	KULASHEKARA_110	10:30	13:21	2:51	LINE CLEAR AVAILED
686	16-Feb-19	HASSAN	110	HV1	PUTTUR_220	10:27	11:48	1:21	LINE CLEAR AVAILED
687	16-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	5:05	5:22	0:17	LINE FAULT
688	16-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	11:47	13:30	1:43	LINE CLEAR AVAILED
689	16-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	14:30	15:35	1:05	MAIN SUPPLY FAILURE
690	16-Feb-19	HASSAN	66	HV1	DODDAKADANUR_66	1:04	1:53	0:49	TRANSFORMER FAULT
691	16-Feb-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:52	12:24	0:32	LINE CLEAR AVAILED
692	16-Feb-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:45	12:10	0:25	LINE CLEAR AVAILED
693	16-Feb-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	18:02	18:06	0:04	HAND TRIPPED
694	16-Feb-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	13:32	13:45	0:13	LINE CLEAR AVAILED
695	16-Feb-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	18:28	18:43	0:15	LINE CLEAR AVAILED
696	16-Feb-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	14:59	15:45	0:46	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
697	16-Feb-19	MYSORE	66	HV1	GARUDANAUKADDA_66	7:51	23:59	16:07	TRANSFORMER FAULT
698	16-Feb-19	MYSORE	66	HV1	HEBBAL_66	8:39	9:44	1:05	LINE CLEAR AVAILED
699	16-Feb-19	MYSORE	66	HOOTAGALLI-HEBBAL	HEBBAL_66 METAGALLY_66	10:10	14:19	4:08	LINE CLEAR AVAILED
700	16-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 SANTHESARAGUR_66 B MATKERE_66	13:44	13:56	0:12	LINE CLEAR AVAILED
701	16-Feb-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66,	13:45	13:57	0:11	LINE FAULT
702	16-Feb-19	MYSORE	66	HV1	KMDODDI_66, KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K_HONNALGERE_66	6:30	6:40	0:10	HAND TRIPPED
703	16-Feb-19	MYSORE	66	HV2	KMDODDI_66, KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K_HONNALGERE_66	6:30	6:40	0:10	HAND TRIPPED
704	16-Feb-19	MYSORE	66	HV2	KMDODDI_66	11:49	12:01	0:11	TRANSFORMER FAULT
705	16-Feb-19	MYSORE	66	KM DODDI-HV2	KMDODDI_66	12:54	13:01	0:07	LINE FAULT
706	16-Feb-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 KRNAGARA_66 BHERYA_66	12:07	12:19	0:11	LINE FAULT
707	16-Feb-19	MYSORE	220	HV1	KUSHALANAGARA_66 SUNTIKOPPA_66 MADIKERI_66 BYLUKUPPE_66 PERIYAPATNA_66 PONNAMPET_66 BETTADHAPURA_66 RAVANDUR_66 CHUNCHUNKATTE_66 KRNAGARA_66 MIRLE_66 KITTUR_66 VIRAJPET_66	14:32	15:17	0:44	LINE CLEAR AVAILED
708	16-Feb-19	MYSORE	220	HV2	KUSHALANAGARA_66 SUNTIKOPPA_66 MADIKERI_66 BYLUKUPPE_66 PERIYAPATNA_66 PONNAMPET_66 BETTADHAPURA_66 RAVANDUR_66 CHUNCHUNKATTE_66 KRNAGARA_66 MIRLE_66 KITTUR_66 VIRAJPET_66	14:32	15:17	0:45	LINE CLEAR AVAILED
709	16-Feb-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	13:35	13:43	0:08	LINE FAULT
710	16-Feb-19	MYSORE	66	MUGUR-MADHUVANAHALLI	MUGUR_66 THAYURU_66 TNARASIPURA_66 THUMLA_66	14:39	14:52	0:12	LINE FAULT
711	16-Feb-19	MYSORE	66	HV2	SALIGRAMA_66	8:09	8:15	0:05	TRANSFORMER FAULT
712	16-Feb-19	MYSORE	66	HV2	SALIGRAMA_66	13:47	13:51	0:04	TRANSFORMER FAULT
713	16-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	20:01	20:10	0:09	TRANSFORMER FAULT
714	16-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	7:53	15:57	8:04	LINE CLEAR AVAILED
715	16-Feb-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	14:21	14:32	0:11	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
716	16-Feb-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	6:55	7:06	0:10	LINE FAULT
717	16-Feb-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	13:51	15:33	1:41	LINE CLEAR AVAILED
718	16-Feb-19	TUMKUR	220	NITTUR 220kV- HASSAN	NITTUR_220	9:49	10:14	0:24	LINE FAULT
719	16-Feb-19	TUMKUR	110	TR-1	TURUVEKERE_110	17:02	17:16	0:14	TRANSFORMER FAULT
720	16-Feb-19	TUMKUR	110	TR-1	BANDIHALLI_110	13:46	14:19	0:33	LINE CLEAR AVAILED
721	16-Feb-19	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	9:49	10:13	0:23	LINE FAULT
722	16-Feb-19	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	9:48	10:13	0:24	LINE FAULT
723	16-Feb-19	TUMKUR	110	TR-2(HV 2)	NITTUR_220	9:49	10:13	0:23	TRANSFORMER FAULT
724	16-Feb-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	9:48	10:21	0:32	LINE FAULT
725	16-Feb-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	9:48	10:15	0:27	LINE FAULT
726	16-Feb-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	9:48	10:15	0:27	LINE FAULT
727	16-Feb-19	TUMKUR	110	NITTUR 220kV- SOMALAPURA	SOMALAPURA_66	9:48	10:36	0:48	LINE FAULT
728	16-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:38	7:53	0:14	LINE FAULT
729	16-Feb-19	TUMKUR	66	TR-2	BAGUR_66	15:02	15:18	0:16	LINE CLEAR AVAILED
730	16-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:26	8:29	0:03	TRANSFORMER FAULT
731	16-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P-R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:16	11:42	3:26	LINE CLEAR AVAILED
732	16-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P-R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	14:04	15:47	1:43	LINE CLEAR AVAILED
733	16-Feb-19	TUMKUR	66	TR-2	HARIYABBE_66	9:20	9:27	0:07	TRANSFORMER FAULT
734	16-Feb-19	TUMKUR	66	TR-2	HARIYABBE_66	9:41	16:19	6:37	TRANSFORMER FAULT
735	16-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:30	16:43	6:13	LINE CLEAR AVAILED
736	16-Feb-19	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	16:12	16:19	0:06	LINE FAULT
737	16-Feb-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	9:58	10:06	0:07	LINE FAULT
738	17-Feb-19	BAGALKOT	110	110/33KV, HV1	BAILHONGAL_110, MURGOD_33, NEGINHAL_33	17:07	17:27	0:20	LINE CLEAR AVAILED
739	17-Feb-19	BAGALKOT	110	10/11KV, HV2	BELUR_110	10:53	18:39	7:46	LINE CLEAR AVAILED
740	17-Feb-19	BAGALKOT	110	NARENDRA2-BELUR	BELUR_110	14:57	18:37	3:40	LINE CLEAR AVAILED
741	17-Feb-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	15:19	15:28	0:09	TRANSFORMER FAULT
742	17-Feb-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	2:06	9:07	7:01	LINE CLEAR AVAILED
743	17-Feb-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:05	23:59	5:54	LINE CLEAR AVAILED
744	17-Feb-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	20:00	23:59	3:59	LINE CLEAR AVAILED
745	17-Feb-19	BAGALKOT	220	220/110KV,HV2	BELGAUM_220	8:07	19:13	11:06	LINE CLEAR AVAILED
746	17-Feb-19	BAGALKOT	220	220/110KV,HV2	BELGAUM_220	8:07	19:16	11:09	LINE CLEAR AVAILED
747	17-Feb-19	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	10:07	11:26	1:19	LINE CLEAR AVAILED
748	17-Feb-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110	0:00	11:43	11:43	LINE CLEAR AVAILED
749	17-Feb-19	BAGALKOT	110	SUZLON2(L2)-DAMBAL	DAMBAL_110	11:25	11:32	0:07	HAND TRIPPED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
750	17-Feb-19	BAGALKOT	110	SUZLON1(L3)-DAMBAL	DAMBAL_110	11:25	11:32	0:07	HAND TRIPPED
751	17-Feb-19	BAGALKOT	110	ENECORN-DAMBAL	DAMBAL_110	11:25	11:31	0:06	HAND TRIPPED
752	17-Feb-19	BAGALKOT	110	110/11KV,HV3	JAMKHANDI_110	15:19	17:20	2:01	LINE CLEAR AVAILED
753	17-Feb-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	13:49	14:25	0:36	MAIN SUPPLY FAILURE
754	17-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA 33KV	16:13	16:20	0:07	TRANSFORMER FAULT
755	17-Feb-19	BAGALKOT	110	ANANTPURAM-KONNUR	KONNUR_110	12:11	12:19	0:08	LINE FAULT
756	17-Feb-19	BAGALKOT	110	ASHOK IRON PLANT-MACHE	MACHE_110	21:36	23:59	2:23	LINE CLEAR AVAILED
757	17-Feb-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	15:05	16:59	1:54	LINE CLEAR AVAILED
758	17-Feb-19	BAGALKOT	110	110/11KV, HV1	NIPPANI_110	10:05	14:24	4:19	LINE CLEAR AVAILED
759	17-Feb-19	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	9:00	15:36	6:36	LINE CLEAR AVAILED
760	17-Feb-19	BAGALKOT	110	CHIKKODI1-RAIBAG	RAIBAG_110	11:23	15:33	4:10	LINE CLEAR AVAILED
761	17-Feb-19	BAGALKOT	110	CHIKKODI2-RAIBAG	RAIBAG_110	11:24	15:34	4:10	LINE CLEAR AVAILED
762	17-Feb-19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	18:26	22:10	3:44	LINE CLEAR AVAILED
763	17-Feb-19	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	20:41	22:11	1:30	LINE CLEAR AVAILED
764	17-Feb-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	14:26	15:44	1:18	LINE FAULT
765	17-Feb-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33	2:00	2:03	0:03	TRANSFORMER FAULT
766	17-Feb-19	BAGALKOT	110	VADAGOAN-MACHE	MACHE_110	7:50	19:30	11:40	LINE CLEAR AVAILED
767	17-Feb-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	16:26	16:38	0:12	TRANSFORMER FAULT
768	17-Feb-19	BAGALKOT	110	110/11KV,HV2	SATTI_110	12:10	12:16	0:06	TRANSFORMER FAULT
769	17-Feb-19	BAGALKOT	110	110/11KV,HV2	SATTI_110	13:53	14:06	0:13	TRANSFORMER FAULT
770	17-Feb-19	BAGALKOT	110	110/11KV,HV2	SATTI_110	14:27	14:31	0:04	LINE CLEAR AVAILED
771	17-Feb-19	BANGALORE	66	HV1	BRIGADE METROPOLIS	11:27	11:45	0:18	LINE CLEAR AVAILED
772	17-Feb-19	BANGALORE	66	HV2	BTM 4TH PHASE	19:53	20:05	0:12	TRANSFORMER FAULT
773	17-Feb-19	BANGALORE	66	HV3	EPIP 220	10:17	16:44	6:26	LINE CLEAR AVAILED
774	17-Feb-19	BANGALORE	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	7:20	8:30	1:10	LINE CLEAR AVAILED
775	17-Feb-19	BANGALORE	66	GOLF LINKS - ADUGODI 2	GOLF LINKS	11:58	12:05	0:07	LOAD CHANGEOR
776	17-Feb-19	BANGALORE	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	14:40	14:45	0:05	LOAD CHANGEOR
777	17-Feb-19	BANGALORE	220	HAL 220 - HOODY 2	HAL 220	11:59	14:11	2:12	LINE CLEAR AVAILED
778	17-Feb-19	BANGALORE	220	HV1	HAL 220	11:59	14:25	2:26	MAIN SUPPLY FAILURE
779	17-Feb-19	BANGALORE	220	HV2	HAL 220	11:59	14:23	2:23	MAIN SUPPLY FAILURE
780	17-Feb-19	BANGALORE	66	HV1	HAL 220	11:59	14:23	2:24	MAIN SUPPLY FAILURE
781	17-Feb-19	BANGALORE	66	HV2	HAL 220	11:59	14:24	2:25	MAIN SUPPLY FAILURE
782	17-Feb-19	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE, AMARJYOTHI	11:58	14:27	2:28	MAIN SUPPLY FAILURE
783	17-Feb-19	BANGALORE	66	HAL 220 - B STATION 1 & 2	B STATION	11:58	14:25	2:27	MAIN SUPPLY FAILURE
784	17-Feb-19	BANGALORE	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:57	14:26	2:28	MAIN SUPPLY FAILURE
785	17-Feb-19	BANGALORE	66	HAL 220 - HOODY 1	ISRO(EHT)	11:58	14:29	2:31	MAIN SUPPLY FAILURE
786	17-Feb-19	BANGALORE	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	11:58	14:29	2:30	MAIN SUPPLY FAILURE
787	17-Feb-19	BANGALORE	66	HAL 220 - HAL(EHT)	HAL (EHT)	11:58	14:30	2:31	MAIN SUPPLY FAILURE
788	17-Feb-19	BANGALORE	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	18:20	18:21	0:01	LOAD CHANGEOR
789	17-Feb-19	BANGALORE	66	HV1	HEBBAL 220	13:08	13:58	0:49	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
790	17-Feb-19	BANGALORE	66	HV2	NRS 220	12:53	12:55	0:02	LINE CLEAR AVAILED
791	17-Feb-19	BANGALORE	66	HV2	NRS 220	14:29	14:38	0:08	LINE CLEAR AVAILED
792	17-Feb-19	BANGALORE	66	NIMHANS 220 - JAYANAGARA	JAYANAGARA, PADMANABHANAGARA	14:17	14:38	0:20	LOAD CURTAILMENT
793	17-Feb-19	BANGALORE	66	HV2	NGEF	14:32	14:40	0:08	LINE CLEAR AVAILED
794	17-Feb-19	BANGALORE	66	HV1	MAHALAKSHMI LAYOUT	13:07	15:29	2:21	LINE CLEAR AVAILED
795	17-Feb-19	BANGALORE	66	HV2	MAHALAKSHMI LAYOUT	12:29	14:23	1:54	LINE CLEAR AVAILED
796	17-Feb-19	BANGALORE	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	12:58	14:10	1:11	LINE CLEAR AVAILED
797	17-Feb-19	BANGALORE	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	8:59	9:00	0:01	LINE CLEAR AVAILED
798	17-Feb-19	BANGALORE	66	KADABISANAHALLI - HAL 220	KADUBISANAHALLI	11:56	12:05	0:09	LOAD CHANGEOVER
799	17-Feb-19	BANGALORE	66	KADUBISANAHALLI - CESSNO	KADUBISANAHALLI	14:30	14:35	0:05	LOAD CHANGEOVER
800	17-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	7:00	7:14	0:13	LINE FAULT
801	17-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	12:24	12:32	0:07	LINE FAULT
802	17-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	14:11	14:32	0:20	LINE CLEAR AVAILED
803	17-Feb-19	BANGALORE	66	HV1	KIADB DB PURA 220	18:45	18:47	0:01	LOAD CHANGEOVER
804	17-Feb-19	BANGALORE	66	HV1	KIADB DB PURA 220	19:21	19:35	0:13	LOAD CHANGEOVER
805	17-Feb-19	BANGALORE	66	HV2	KIADB DB PURA 220	18:14	18:31	0:17	LOAD CHANGEOVER
806	17-Feb-19	BANGALORE	66	HV2	KIADB DB PURA 220	18:45	18:46	0:01	LOAD CHANGEOVER
807	17-Feb-19	BANGALORE	66	KIADB DB PURA 220 - APARAL PARK	APARAL PARK	18:14	19:00	0:45	MAIN SUPPLY FAILURE
808	17-Feb-19	BANGALORE	66	KIADB DB PURA 220 - APARAL PARK	APARAL PARK	19:22	19:35	0:13	MAIN SUPPLY FAILURE
809	17-Feb-19	BANGALORE	220	HV2	KIADB DB PURA 220	18:31	18:56	0:24	LINE CLEAR AVAILED
810	17-Feb-19	BANGALORE	220	HV1	KIADB DB PURA 220	18:56	19:33	0:36	LINE CLEAR AVAILED
811	17-Feb-19	BANGALORE	66	HV1	DABUSPET 220	10:21	16:41	6:19	LINE CLEAR AVAILED
812	17-Feb-19	BANGALORE	66	HV1	DODDABELAVANGALA	21:45	22:41	0:55	TRANSFORMER FAULT
813	17-Feb-19	BANGALORE	66	DB PURA 220 - DG2	AIR (EHT)	21:44	22:22	0:38	MAIN SUPPLY FAILURE
814	17-Feb-19	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI, TUBUGERE	21:40	22:23	0:42	MAIN SUPPLY FAILURE
815	17-Feb-19	BANGALORE	66	DB PURA 220 - D CROSS	D CROSS	18:17	18:48	0:31	LINE FAULT
816	17-Feb-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	21:40	23:07	1:27	LINE FAULT
817	17-Feb-19	BANGALORE	220	LV1	DB PURA 220	21:40	22:20	0:40	TRANSFORMER FAULT
818	17-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:52	12:06	0:13	LINE CLEAR AVAILED
819	17-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:53	12:05	0:12	LINE CLEAR AVAILED
820	17-Feb-19	BANGALORE	66	HV2	HONNIGANAHALLI	14:00	14:11	0:11	TRANSFORMER FAULT
821	17-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	9:29	9:46	0:17	LINE FAULT
822	17-Feb-19	BANGALORE	66	HV1	HOSKOTE 220	12:06	12:19	0:12	TRANSFORMER FAULT
823	17-Feb-19	BANGALORE	66	HV1	HOSKOTE 220	12:20	15:28	3:08	TRANSFORMER FAULT
824	17-Feb-19	BANGALORE	66	KGF - KAMASAMUDRA	KAMASAMUDRA	6:22	6:38	0:15	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
825	17-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	6:22	6:36	0:13	LINE FAULT
826	17-Feb-19	BANGALORE	66	HV1	NARASAPURA	7:03	10:14	3:10	LINE CLEAR AVAILED
827	17-Feb-19	BANGALORE	66	RAMANAGARA - BIDADI	RAMANAGARA	11:02	11:04	0:01	LINE FAULT
828	17-Feb-19	BANGALORE	66	HV1	TK HALLI 220	12:17	12:19	0:02	TRANSFORMER FAULT
829	17-Feb-19	BANGALORE	66	HV1	TK HALLI 220	22:05	22:35	0:30	TRANSFORMER FAULT
830	17-Feb-19	BANGALORE	66	TK HALLI 220 - MANDYA 1	MANDYA	6:33	6:41	0:08	LINE FAULT
831	17-Feb-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA, K HONALGERE	6:33	6:41	0:08	LINE FAULT
832	17-Feb-19	BANGALORE	66	HV2	ANDERSONPET	14:40	14:53	0:13	TRANSFORMER FAULT
833	17-Feb-19	BANGALORE	66	HV2	ATTIBELE	19:57	20:40	0:43	LINE CLEAR AVAILED
834	17-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	18:02	18:07	0:04	LINE FAULT
835	17-Feb-19	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	9:49	12:12	2:22	MAIN SUPPLY FAILURE
836	17-Feb-19	BANGALORE	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	10:00	10:09	0:09	LOAD CHANGEOVER
837	17-Feb-19	BANGALORE	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	11:44	11:49	0:04	LOAD CHANGEOVER
838	17-Feb-19	BANGALORE	66	HV1	DABUSPET 220	11:52	11:55	0:02	LOAD CHANGEOVER
839	17-Feb-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI, AVANI, MULBAGAL	21:05	21:11	0:06	LINE FAULT
840	17-Feb-19	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:43	17:21	0:38	LINE FAULT
841	17-Feb-19	BANGALORE	66	KYALANUR - VEMGAL	KYALANUR	18:25	18:55	0:30	LINE FAULT
842	17-Feb-19	BANGALORE	66	KYALANUR - VEMGAL	KYALANUR	18:55	19:35	0:40	LINE FAULT
843	17-Feb-19	BANGALORE	66	MELUR - VIJAYAPURA	JANGAMKOTE, VIJAYAPURA	6:54	7:14	0:19	LINE FAULT
844	17-Feb-19	BANGALORE	66	MELUR - VIJAYAPURA	JANGAMKOTE, VIJAYAPURA	7:49	8:09	0:19	LINE FAULT
845	17-Feb-19	BANGALORE	66	HV1	NARASAPURA	10:44	13:22	2:38	LINE CLEAR AVAILED
846	17-Feb-19	BANGALORE	66	VIJAYAPURA - MELUR	JANGAMKOTE, VIJAYAPURA	15:54	16:04	0:09	LOAD CHANGEOVER
847	17-Feb-19	BANGALORE	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR, JANGAMKOTE, VIJAYAPURA	13:40	13:50	0:10	LINE FAULT
848	17-Feb-19	BANGALORE	66	HV1	BRINDAVANA	9:54	11:54	2:00	LINE CLEAR AVAILED
849	17-Feb-19	BANGALORE	66	HV2	BRINDAVANA	9:54	15:56	6:01	LINE CLEAR AVAILED
850	17-Feb-19	BANGALORE	66	HV3	BRINDAVANA	9:20	11:20	2:00	LINE CLEAR AVAILED
851	17-Feb-19	BANGALORE	66	HV1	BRINDAVANA	15:39	15:56	0:17	LINE CLEAR AVAILED
852	17-Feb-19	BANGALORE	66	BRINDAVAN - NELAKADERANAHALLI	NELAKADERANAHALLI	9:12	10:13	1:01	LINE CLEAR AVAILED
853	17-Feb-19	BANGALORE	66	BRINDAVAN - NELAKADERANAHALLI	NELAKADERANAHALLI	15:08	16:10	1:01	LINE CLEAR AVAILED
854	17-Feb-19	BANGALORE	66	HV2	BTM 4TH PHASE	12:47	12:54	0:06	TRANSFORMER FAULT
855	17-Feb-19	BANGALORE	66	HV1	EPIP 220	9:31	15:20	5:48	LINE CLEAR AVAILED
856	17-Feb-19	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	8:05	8:45	0:40	LINE FAULT
857	17-Feb-19	BANGALORE	66	HV1	ISRO LAYOUT	11:07	11:13	0:05	LINE CLEAR AVAILED
858	17-Feb-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	6:49	8:42	1:53	LINE FAULT
859	17-Feb-19	BANGALORE	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	6:49	7:10	0:20	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
860	17-Feb-19	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	9:40	9:45	0:05	LOAD CHANGEOVER
861	17-Feb-19	BANGALORE	66	HV2	ATTUR YELAHANKA	18:29	18:43	0:14	TRANSFORMER FAULT
862	17-Feb-19	BANGALORE	66	HV2	ATTUR YELAHANKA	19:55	20:24	0:28	TRANSFORMER FAULT
863	17-Feb-19	BANGALORE	66	HV1	HSR LAYOUT 220	12:41	12:51	0:10	TRANSFORMER FAULT
864	17-Feb-19	BANGALORE	66	HV1	TK HALLI 220	15:49	16:15	0:26	TRANSFORMER FAULT
865	17-Feb-19	GULBARGA	110	HV3	BEVOOR_110	18:41	19:00	0:19	TRANSFORMER FAULT
866	17-Feb-19	GULBARGA	110	HV1	BEVOOR_110	17:10	17:45	0:35	LINE CLEAR AVAILED
867	17-Feb-19	GULBARGA	110	HV2	KAMPLI_GLB_110	13:54	14:04	0:10	TRANSFORMER FAULT
868	17-Feb-19	GULBARGA	110	LV2	RAICHUR_220	20:50	21:15	0:25	TRANSFORMER FAULT
869	17-Feb-19	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	20:50	23:59	3:09	LINE FAULT
870	17-Feb-19	GULBARGA	110	BETAGERA-DAMBAL	BETAGERA_110	10:05	11:25	1:20	MAIN SUPPLY FAILURE
871	17-Feb-19	GULBARGA	66	HV2	CHORNOOR_66	14:10	15:18	1:08	LINE CLEAR AVAILED
872	17-Feb-19	GULBARGA	66	ITTAGI-HADAGALLI1	HUVINA_HADAGALLI_66,HOLAGUNDI_66	18:34	18:41	0:07	LINE CLEAR AVAILED
873	17-Feb-19	GULBARGA	66	ITTAGI-RENEWSOLAR1,2	ITTAGI_220	18:27	18:30	0:03	LINE CLEAR AVAILED
874	17-Feb-19	GULBARGA	66	ITTAGI-TBHALLI	HAMPASAGAR_66,MORAGERE_66, TAMBRAHALLI_66	20:00	20:12	0:12	LINE FAULT
875	17-Feb-19	GULBARGA	66	HV2	UPANAYAKANAHALLI_66	18:29	19:10	0:41	LINE CLEAR AVAILED
876	17-Feb-19	GULBARGA	66	HV1	CHORNOOR_66	16:57	18:37	1:40	LINE CLEAR AVAILED
877	17-Feb-19	GULBARGA	66	HV1	ITTAGI_220	0:28	0:48	0:20	TRANSFORMER FAULT
878	17-Feb-19	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINA_HADAGALLI_66,HOLAGUNDI_66	10:05	10:13	0:08	LINE FAULT
879	17-Feb-19	GULBARGA	66	HV1	ITTAGI_220	11:10	11:20	0:10	LINE CLEAR AVAILED
880	17-Feb-19	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINA_HADAGALLI_66,HOLAGUNDI_66	12:02	12:07	0:05	LINE FAULT
881	17-Feb-19	GULBARGA	66	HV1	ITTAGI_220	12:45	13:05	0:20	LINE CLEAR AVAILED
882	17-Feb-19	GULBARGA	66	LV1, LV2	ITTAGI_220	13:45	13:50	0:05	TRANSFORMER FAULT
883	17-Feb-19	GULBARGA	66	ITTAGI-RENEWSOLAR2	ITTAGI_220	14:46	15:04	0:18	LINE CLEAR AVAILED
884	17-Feb-19	GULBARGA	66	ITTAGI-BANVEKAL	BANAVEKAL_66	15:10	15:25	0:15	LINE CLEAR AVAILED
885	17-Feb-19	GULBARGA	66	KOGALI-ATRSOLAR	KOGALI_66	15:27	15:36	0:09	HAND TRIPPED
886	17-Feb-19	GULBARGA	66	KOTTUR-KUDLIGI	UJJANI_66	6:25	7:06	0:41	LINE FAULT
887	17-Feb-19	GULBARGA	66	KOTTUR-BENNIHALLI	KOTTUR_66	13:44	14:01	0:17	LINE FAULT
888	17-Feb-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	7:03	7:05	0:02	HAND TRIPPED
889	17-Feb-19	HASSAN	220	HV1	MRSMSG_220	8:30	12:55	4:25	LINE CLEAR AVAILED
890	17-Feb-19	HASSAN	220	HV3	MRSMSG_220	12:55	17:13	4:18	LINE CLEAR AVAILED
891	17-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	6:17	11:24	5:07	LINE FAULT
892	17-Feb-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	0:47	5:54	5:07	LINE FAULT
893	17-Feb-19	HASSAN	110	LV1	MRSMSG_220	8:30	12:55	4:25	LINE CLEAR AVAILED
894	17-Feb-19	HASSAN	110	LV3	MRSMSG_220	12:55	17:14	4:19	LINE CLEAR AVAILED
895	17-Feb-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	8:24	8:27	0:03	HAND TRIPPED
896	17-Feb-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:16	17:17	0:01	HAND TRIPPED
897	17-Feb-19	HASSAN	110	HV1	ARASIKERE_220	15:26	15:48	0:22	TRANSFORMER FAULT
898	17-Feb-19	HASSAN	110	HV4	BAIKAMPADY_110	11:39	13:06	1:27	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
899	17-Feb-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	8:25	8:30	0:05	MAIN SUPPLY FAILURE
900	17-Feb-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	17:15	17:20	0:05	MAIN SUPPLY FAILURE
901	17-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	9:04	9:14	0:10	LINE CLEAR AVAILED
902	17-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	13:07	13:15	0:08	LINE CLEAR AVAILED
903	17-Feb-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	7:47	7:55	0:08	LINE FAULT
904	17-Feb-19	MYSORE	66	HV1	BANNUR	13:37	13:42	0:05	TRANSFORMER FAULT
905	17-Feb-19	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR	17:53	23:59	6:05	LINE FAULT
906	17-Feb-19	MYSORE	66	JAKKANAHALLI-NAGAMANGLA	G MALLIGERE, GUDDENAHALLI, BOGADHI & NAGAMANGALA	4:41	4:52	0:11	LINE FAULT
907	17-Feb-19	MYSORE	66	KADAKOLA-DKMAIDANA	JAIPURA, HAMPAPURA, ANTHARASANTHE, HD KOTE, DOORA, HURA, HULLAHALLI, SANTHESARGUR, NANJANGUD, THANDYA & B MATAKERE	7:16	8:16	0:59	LINE CLEAR AVAILED
908	17-Feb-19	MYSORE	66	KADAKOLA-NANJANGUD 1	JAIPURA, HAMPAPURA, ANTHARASANTHE, HD KOTE, DOORA, HURA, HULLAHALLI, SANTHESARGUR, NANJANGUD, THANDYA & B MATAKERE	7:18	8:15	0:57	LINE CLEAR AVAILED
909	17-Feb-19	MYSORE	66	KADAKOLA-NANJANGUD 2	JAIPURA, HAMPAPURA, ANTHARASANTHE, HD KOTE, DOORA, HURA, HULLAHALLI, SANTHESARGUR, NANJANGUD, THANDYA & B MATAKERE	7:17	8:15	0:57	LINE CLEAR AVAILED
910	17-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	JAIPURA, HAMPAPURA, ANTHARASANTHE, HD KOTE, DOORA, HURA, HULLAHALLI, SANTHESARGUR, NANJANGUD, THANDYA & B MATAKERE	7:16	8:15	0:58	LINE CLEAR AVAILED
911	17-Feb-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPURA, HAMPAPURA, ANTHARASANTHE, HD KOTE, DOORA, HURA, HULLAHALLI, SANTHESARGUR, NANJANGUD, THANDYA & B MATAKERE	7:16	8:15	0:58	LINE CLEAR AVAILED
912	17-Feb-19	MYSORE	66	HV3	KR PETE-	19:03	23:59	4:55	TRANSFORMER FAULT
913	17-Feb-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE, KR NAGARA & BHERYA	18:29	18:39	0:10	LINE FAULT
914	17-Feb-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKAMANDYA, HAMPAPURA, KOPPA, BESAGARAHALLI & DUNDANAHALLI	10:50	10:58	0:08	LINE FAULT
915	17-Feb-19	MYSORE	66	HV5	SFCSIVA-	5:26	9:41	4:15	LINE CLEAR AVAILED
916	17-Feb-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE, GAMANAHALLI & TARIPURA	11:12	11:15	0:03	HAND TRIPPED
917	17-Feb-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR & K HONNALAGERE	2:11	2:14	0:03	LINE FAULT
918	17-Feb-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR & K HONNALAGERE	4:10	4:17	0:06	LINE FAULT
919	17-Feb-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	16:40	17:18	0:37	LINE FAULT
920	17-Feb-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	12:09	15:00	2:50	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
921	17-Feb-19	TUMKUR	220	THALLAK 220KV- CHITRADURGA	CHITRADURGA_220	16:40	17:33	0:52	LINE FAULT
922	17-Feb-19	TUMKUR	110	TR-1	TURUVEKERE_110	3:21	3:34	0:13	TRANSFORMER FAULT
923	17-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	4:07	10:32	6:24	LINE CLEAR AVAILED
924	17-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	11:44	13:01	1:16	LINE FAULT
925	17-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	13:21	16:28	3:06	LINE FAULT
926	17-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	17:22	17:41	0:19	LINE FAULT
927	17-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	6:20	6:31	0:11	LINE FAULT
928	17-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	8:52	10:14	1:21	LINE CLEAR AVAILED
929	17-Feb-19	TUMKUR	66	BENNEHALLI-KOTTUR	BENNEHALLI_66	6:26	6:38	0:12	LINE FAULT
930	17-Feb-19	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	14:56	17:46	2:50	LINE CLEAR AVAILED
931	17-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P-R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:09	17:37	9:28	LINE CLEAR AVAILED
932	17-Feb-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	13:58	14:31	0:33	LINE FAULT
933	17-Feb-19	TUMKUR	66	HIREHALLI - BADDIHALLI	BADDIHALLI_66	10:49	12:37	1:47	LINE CLEAR AVAILED
934	17-Feb-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	6:43	6:50	0:07	HAND TRIPPED
935	17-Feb-19	TUMKUR	66	TR-2	HULIYURDURGA_66	11:03	11:15	0:11	TRANSFORMER FAULT
936	17-Feb-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	11:24	11:29	0:05	HAND TRIPPED
937	17-Feb-19	TUMKUR	66	TR-1	KATTIGE_66	19:48	19:57	0:09	TRANSFORMER FAULT
938	17-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:23	12:25	0:02	HAND TRIPPED
939	17-Feb-19	TUMKUR	66	TR-2	PAVAGADA_66	7:13	10:24	3:10	LINE CLEAR AVAILED
940	17-Feb-19	TUMKUR	66	TR-2	PAVAGADA_66	11:58	12:37	0:39	LINE CLEAR AVAILED
941	18-Feb-19	BAGALKOT	110	110/11KV, HV1	ACHANUR_110	7:08	7:13	0:05	LOAD CURTAILMENT
942	18-Feb-19	BAGALKOT	110	110/11KV, HV2	AINAPUR_110	7:08	7:10	0:02	LOAD CURTAILMENT
943	18-Feb-19	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	7:08	7:38	0:30	LOAD CURTAILMENT
944	18-Feb-19	BAGALKOT	110	110/11KV, HV1	BILAGI_110	10:37	11:18	0:41	LINE CLEAR AVAILED
945	18-Feb-19	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	7:08	7:17	0:09	LOAD CURTAILMENT
946	18-Feb-19	BAGALKOT	110	110/33KV, HV1	HANGAL_110, PALA_33, BOMMANAHALLI_33	7:08	7:15	0:07	LOAD CURTAILMENT
947	18-Feb-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:18	7:18	LINE CLEAR AVAILED
948	18-Feb-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:00	7:20	7:20	LINE CLEAR AVAILED
949	18-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110, KOLIGUDDA_33	7:08	7:22	0:14	LOAD CURTAILMENT
950	18-Feb-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	15:34	16:15	0:41	LINE CLEAR AVAILED
951	18-Feb-19	BAGALKOT	220	DHONI-ARRESS STEEL	DHONI_400	14:26	23:59	9:33	LINE FAULT
952	18-Feb-19	BAGALKOT	110	110/11KV, HV1	LAXMESWAR_110	7:08	7:25	0:17	LOAD CURTAILMENT
953	18-Feb-19	BAGALKOT	110	ASHOKA IRON PLANT-MACHE	MACHE_110	0:00	16:08	16:08	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
954	18-Feb-19	BAGALKOT	110	ASHOKA IRON PLANT-MACHE	MACHE_110	18:16	23:59	5:43	LINE FAULT
955	18-Feb-19	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	17:08	17:20	0:12	LINE CLEAR AVAILED
956	18-Feb-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI 33KV &,DHULKED 33KV	10:28	10:39	0:11	TRANSFORMER FAULT
957	18-Feb-19	BAGALKOT	110	VAJRAMATTI220-MANTUR2	MANTUR_110	9:23	11:31	2:08	LINE CLEAR AVAILED
958	18-Feb-19	BAGALKOT	110	VAJRAMATTI220-MANTUR2	MANTUR_110	11:43	11:47	0:04	LINE CLEAR AVAILED
959	18-Feb-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110	17:01	17:12	0:11	TRANSFORMER FAULT
960	18-Feb-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110	17:18	17:27	0:09	TRANSFORMER FAULT
961	18-Feb-19	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	10:22	11:49	1:27	LINE CLEAR AVAILED
962	18-Feb-19	BAGALKOT	110	110/33KV,HV3	TILUVALI_110,KALKERE 33KV,KNML 33KV	11:26	12:28	1:02	LINE CLEAR AVAILED
963	18-Feb-19	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	12:41	18:22	5:41	LINE CLEAR AVAILED
964	18-Feb-19	BAGALKOT	110	110/11KV,HV3	SOUDATTI_110	13:50	14:42	0:52	TRANSFORMER FAULT
965	18-Feb-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGATAGI_110	8:11	14:15	6:04	LINE FAULT
966	18-Feb-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGATAGI_110	14:21	19:16	4:55	LINE FAULT
967	18-Feb-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	10:19	14:27	4:08	LINE CLEAR AVAILED
968	18-Feb-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	16:21	19:23	3:02	LINE CLEAR AVAILED
969	18-Feb-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	13:53	16:04	2:11	LINE FAULT
970	18-Feb-19	BAGALKOT	110	110/11KV,HV2	SAVALGI_110,KALBILGI 33KV, & HIREPADASALGI 33KV	7:08	7:45	0:37	LOAD CURTAILMENT
971	18-Feb-19	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	7:08	7:13	0:05	LOAD CURTAILMENT
972	18-Feb-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	11:19	14:51	3:32	LINE CLEAR AVAILED
973	18-Feb-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	16:23	16:28	0:04	LOAD CHANGEOVER
974	18-Feb-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	14:04	15:27	1:22	MAIN SUPPLY FAILURE
975	18-Feb-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	12:32	12:54	0:21	MAIN SUPPLY FAILURE
976	18-Feb-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	8:08	8:14	0:05	LOAD CHANGEOVER
977	18-Feb-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	11:29	11:32	0:03	LOAD CHANGEOVER
978	18-Feb-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	8:08	8:14	0:05	LOAD CHANGEOVER
979	18-Feb-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	11:29	11:32	0:03	LOAD CHANGEOVER
980	18-Feb-19	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	8:08	8:13	0:05	LOAD CHANGEOVER
981	18-Feb-19	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	11:29	11:32	0:02	LOAD CHANGEOVER
982	18-Feb-19	BANGALORE	66	HV1	DALASNUR	18:03	18:29	0:26	LINE CLEAR AVAILED
983	18-Feb-19	BANGALORE	66	HV2	DALASNUR	18:13	18:31	0:17	LINE CLEAR AVAILED
984	18-Feb-19	BANGALORE	66	HV1	DABUSPET 220	13:49	14:09	0:20	TRANSFORMER FAULT
985	18-Feb-19	BANGALORE	66	HV1	D CROSS	12:49	15:03	2:13	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
986	18-Feb-19	BANGALORE	66	HV2	D CROSS	12:49	15:03	2:13	LINE CLEAR AVAILED
987	18-Feb-19	BANGALORE	66	DB PURA 220 - DG 2	AIR (EHT)	17:29	17:30	0:01	LOAD CHANGEOVER
988	18-Feb-19	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	12:32	12:56	0:24	MAIN SUPPLY FAILURE
989	18-Feb-19	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	14:04	15:32	1:28	MAIN SUPPLY FAILURE
990	18-Feb-19	BANGALORE	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	16:25	16:33	0:08	LOAD CHANGEOVER
991	18-Feb-19	BANGALORE	66	HV2	GANJIGUNTE	11:21	12:07	0:46	TRANSFORMER FAULT
992	18-Feb-19	BANGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:55	22:15	0:19	LINE FAULT
993	18-Feb-19	BANGALORE	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	12:32	15:10	2:37	LINE CLEAR AVAILED
994	18-Feb-19	BANGALORE	66	HV2	NANGALI	18:50	22:20	3:29	TRANSFORMER FAULT
995	18-Feb-19	BANGALORE	66	NANGALI - KEMBODI	NANGALI	18:50	22:20	3:29	LINE FAULT
996	18-Feb-19	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARI NAGAR	20:50	21:00	0:10	LINE FAULT
997	18-Feb-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	17:03	18:54	1:51	LINE FAULT
998	18-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:32	12:46	0:13	LINE FAULT
999	18-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:04	14:25	0:21	LINE FAULT
1000	18-Feb-19	BANGALORE	66	HV3	ELECTRONIC CITY	18:24	23:59	5:34	TRANSFORMER FAULT
1001	18-Feb-19	BANGALORE	66	HV1	ELITE PROMENEDE	11:12	15:23	4:10	LINE CLEAR AVAILED
1002	18-Feb-19	BANGALORE	66	HV1	HEBBAL 220	12:26	13:32	1:06	LINE CLEAR AVAILED
1003	18-Feb-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	17:46	17:50	0:04	LOAD CHANGEOVER
1004	18-Feb-19	BANGALORE	66	KHODAYS 220 - BMRCL (EHT)	BMRCL (EHT)	17:46	17:51	0:04	LOAD CHANGEOVER
1005	18-Feb-19	BANGALORE	66	HV1	KHODAYS 220	17:48	17:50	0:02	LOAD CHANGEOVER
1006	18-Feb-19	BANGALORE	66	HV2	KHODAYS 220	17:47	17:51	0:03	LOAD CHANGEOVER
1007	18-Feb-19	BANGALORE	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	18:57	20:11	1:13	LINE FAULT
1008	18-Feb-19	BANGALORE	220	HV1	TK HALLI 220	21:18	21:26	0:08	TRANSFORMER FAULT
1009	18-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB 3 (EHT)	21:18	21:48	0:30	LINE FAULT
1010	18-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB 1 (EHT)	21:18	21:48	0:30	MAIN SUPPLY FAILURE
1011	18-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	21:18	21:48	0:30	MAIN SUPPLY FAILURE
1012	18-Feb-19	BANGALORE	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	21:18	21:48	0:30	MAIN SUPPLY FAILURE
1013	18-Feb-19	BANGALORE	66	HV1	TK HALLI 220	21:18	21:48	0:30	MAIN SUPPLY FAILURE
1014	18-Feb-19	BANGALORE	66	HV1	TELECOM LAYOUT	14:20	15:11	0:51	LINE CLEAR AVAILED
1015	18-Feb-19	BANGALORE	66	HV2	TELECOM LAYOUT	11:34	12:51	1:16	LINE CLEAR AVAILED
1016	18-Feb-19	BANGALORE	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	15:55	16:00	0:05	LOAD CHANGEOVER
1017	18-Feb-19	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	12:36	12:55	0:18	LINE FAULT
1018	18-Feb-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	12:30	15:05	2:35	LINE CLEAR AVAILED
1019	18-Feb-19	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	15:35	15:38	0:03	LOAD CHANGEOVER
1020	18-Feb-19	BANGALORE	220	HV1	NRS 220	20:53	21:36	0:42	TRANSFORMER FAULT
1021	18-Feb-19	BANGALORE	220	HV2	NRS 220	20:53	21:36	0:42	TRANSFORMER FAULT
1022	18-Feb-19	BANGALORE	66	NRS 220 - SRS PEENYA 2	NRS 220	20:53	22:28	1:34	LINE FAULT
1023	18-Feb-19	BANGALORE	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	20:53	22:25	1:31	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1024	18-Feb-19	BANGALORE	66	NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	20:53	22:41	1:47	MAIN SUPPLY FAILURE
1025	18-Feb-19	BANGALORE	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	20:53	22:25	1:31	MAIN SUPPLY FAILURE
1026	18-Feb-19	BANGALORE	66	HV1	NRS 220	20:53	22:14	1:20	MAIN SUPPLY FAILURE
1027	18-Feb-19	BANGALORE	66	HV2	NRS 220	20:53	22:28	1:34	MAIN SUPPLY FAILURE
1028	18-Feb-19	BANGALORE	66	HV3	NRS 220	20:53	22:15	1:21	MAIN SUPPLY FAILURE
1029	18-Feb-19	BANGALORE	66	HV4	NRS 220	20:53	22:15	1:21	MAIN SUPPLY FAILURE
1030	18-Feb-19	BANGALORE	66	HV5	NRS 220	20:53	22:14	1:20	MAIN SUPPLY FAILURE
1031	18-Feb-19	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	18:24	19:03	0:38	LINE FAULT
1032	18-Feb-19	BANGALORE	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	20:50	21:45	0:54	MAIN SUPPLY FAILURE
1033	18-Feb-19	BANGALORE	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	11:29	11:38	0:08	LOAD CHANGEOVER
1034	18-Feb-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	18:25	18:28	0:03	LOAD CHANGEOVER
1035	18-Feb-19	BANGALORE	66	HV2	VIJAYANAGARA	19:48	19:58	0:09	LOAD CHANGEOVER
1036	18-Feb-19	BANGALORE	66	HV1	VIJAYANAGARA	20:53	22:57	2:04	MAIN SUPPLY FAILURE
1037	18-Feb-19	BANGALORE	220	HV1	VIKAS TECH PARK 220	12:32	12:54	0:21	MAIN SUPPLY FAILURE
1038	18-Feb-19	BANGALORE	220	HV2	VIKAS TECH PARK 220	12:32	12:54	0:21	MAIN SUPPLY FAILURE
1039	18-Feb-19	BANGALORE	220	HV2	VIKAS TECH PARK 220	14:04	14:29	0:25	MAIN SUPPLY FAILURE
1040	18-Feb-19	BANGALORE	220	HV1	VIKAS TECH PARK 220	14:04	14:29	0:25	MAIN SUPPLY FAILURE
1041	18-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	12:32	12:54	0:21	MAIN SUPPLY FAILURE
1042	18-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:32	12:54	0:21	MAIN SUPPLY FAILURE
1043	18-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	14:04	14:29	0:25	MAIN SUPPLY FAILURE
1044	18-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:04	14:29	0:25	MAIN SUPPLY FAILURE
1045	18-Feb-19	GULBARGA	220	KUSTAGI-LINGSUGUR	LINGASUGUR_220	13:50	14:20	0:30	LINE FAULT
1046	18-Feb-19	GULBARGA	220	KUSTAGI-ILKAL1&2	ILKAL_110	13:50	14:30	0:40	LINE FAULT
1047	18-Feb-19	GULBARGA	220	HV2	KUSTAGI_220	14:05	14:20	0:15	LINE CLEAR AVAILED
1048	18-Feb-19	GULBARGA	220	LINGAPUR-SIDHANOOR	LINGAPUR_220	13:47	14:03	0:16	LINE FAULT
1049	18-Feb-19	GULBARGA	110	HV2	ALIPUR_220	11:08	12:24	1:16	LINE CLEAR AVAILED
1050	18-Feb-19	GULBARGA	110	HV2	HANUMAL_110	9:40	9:50	0:10	TRANSFORMER FAULT
1051	18-Feb-19	GULBARGA	110	HV2	HATTI_110	7:05	7:10	0:05	LOAD CURTAILMENT
1052	18-Feb-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	8:41	8:58	0:17	LINE FAULT
1053	18-Feb-19	GULBARGA	110	RAICHUR-SIDHANOOR2	KURDICROSS_110	7:14	14:03	6:49	LINE CLEAR AVAILED
1054	18-Feb-19	GULBARGA	110	HV4	YADGIR_110	7:10	7:35	0:25	LOAD CURTAILMENT
1055	18-Feb-19	GULBARGA	110	HV1	BEVOORG_110	10:00	13:35	3:35	LINE CLEAR AVAILED
1056	18-Feb-19	GULBARGA	110	HV3	BEVOORG_110	16:40	16:45	0:05	TRANSFORMER FAULT
1057	18-Feb-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	11:02	15:01	3:59	LINE CLEAR AVAILED
1058	18-Feb-19	HASSAN	220	MRSSHM-DAVANGERE	MRSMSG_220	10:01	23:59	13:58	LINE CLEAR AVAILED
1059	18-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	13:57	16:17	2:20	LINE CLEAR AVAILED
1060	18-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	16:27	18:43	2:16	LINE FAULT
1061	18-Feb-19	HASSAN	220	SHRAVTY-SHIMOGA2	sharavathy_gen	13:57	16:17	2:20	LINE CLEAR AVAILED
1062	18-Feb-19	HASSAN	220	SHRAVTY-SHIMOGA2	sharavathy_gen	16:27	18:43	2:16	LINE FAULT
1063	18-Feb-19	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	14:10	20:40	6:30	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1064	18-Feb-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	14:10	20:40	6:30	LINE FAULT
1065	18-Feb-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	11:02	15:38	4:36	NFBC ISSUED
1066	18-Feb-19	HASSAN	110	HV1	HALADY_110	7:09	7:26	0:17	MAIN SUPPLY FAILURE
1067	18-Feb-19	HASSAN	110	HV1	BIRUR_110	7:08	7:22	0:14	MAIN SUPPLY FAILURE
1068	18-Feb-19	HASSAN	110	HV2	GANDASI_110	13:00	13:34	0:34	LINE CLEAR AVAILED
1069	18-Feb-19	HASSAN	110	HV1	SHIRALKOPPA_220	10:57	11:50	0:53	LINE CLEAR AVAILED
1070	18-Feb-19	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	14:46	15:24	0:38	LINE CLEAR AVAILED
1071	18-Feb-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:38	17:41	10:03	LINE CLEAR AVAILED
1072	18-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:37	17:38	10:01	LINE CLEAR AVAILED
1073	18-Feb-19	MYSORE	66	HV1	BASARALU_66	11:15	11:16	0:01	TRANSFORMER FAULT
1074	18-Feb-19	MYSORE	66	HV2	BASARALU_66	11:15	23:59	12:43	TRANSFORMER FAULT
1075	18-Feb-19	MYSORE	66	HV1	JAKKANAHALLY_66	8:58	9:20	0:22	TRANSFORMER FAULT
1076	18-Feb-19	MYSORE	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	11:14	11:21	0:06	LINE FAULT
1077	18-Feb-19	MYSORE	66	HV2	MANDYA_66	15:50	16:54	1:03	LINE CLEAR AVAILED
1078	18-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	11:52	14:57	3:05	LINE CLEAR AVAILED
1079	18-Feb-19	MYSORE	66	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66	6:21	6:29	0:08	LINE FAULT
1080	18-Feb-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	9:29	9:46	0:17	TRANSFORMER FAULT
1081	18-Feb-19	TUMKUR	110	TR-1	GUBBI_110	14:06	14:12	0:06	TRANSFORMER FAULT
1082	18-Feb-19	TUMKUR	110	TR-1	SHEYKERE_110	10:40	18:50	8:09	LINE CLEAR AVAILED
1083	18-Feb-19	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	10:33	14:13	3:39	LINE CLEAR AVAILED
1084	18-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	20:03	20:19	0:15	LINE FAULT
1085	18-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	22:01	22:07	0:05	TRANSFORMER FAULT
1086	18-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:29	17:52	9:22	LINE CLEAR AVAILED
1087	18-Feb-19	TUMKUR	66	TR-3(LV SIDE))	HIRIYUR_220	9:29	9:56	0:27	TRANSFORMER FAULT
1088	18-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	9:34	10:01	0:26	LINE CLEAR AVAILED
1089	18-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	7:06	8:15	1:08	LINE CLEAR AVAILED
1090	18-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	9:36	10:01	0:24	LINE CLEAR AVAILED
1091	18-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	9:29	10:01	0:31	LINE CLEAR AVAILED
1092	18-Feb-19	TUMKUR	66	TR-1	HONNALI_66	12:23	17:14	4:50	LINE CLEAR AVAILED
1093	18-Feb-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	18:15	18:24	0:09	LINE FAULT
1094	18-Feb-19	TUMKUR	66	TR-1	KATTIGE_66	11:02	12:05	1:02	TRANSFORMER FAULT
1095	18-Feb-19	TUMKUR	66	TR-2	MALEBENNUR_66	8:57	9:11	0:13	TRANSFORMER FAULT
1096	18-Feb-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	20:28	21:03	0:35	LINE FAULT
1097	18-Feb-19	TUMKUR	66	TR-1	SAVALANGA_66	16:49	17:02	0:12	LINE CLEAR AVAILED
1098	18-Feb-19	TUMKUR	66	TR-2	TAVAREKERE(H)_66	8:22	9:52	1:29	TRANSFORMER FAULT