

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 01.02.2022 TO 07.02.2022

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	1-Feb-22	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	10:05	17:33	7:28	LINE CLEAR AVAILED
2	1-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKKALI_110	12:47	13:05	0:18	TRANSFORMER FAULT
3	1-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	18:00 (31.01.2022)	17:25 (01.02.2022)	23:25	TRANSFORMER CHARGED
4	1-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	17:25	17:31	0:06	LINE CLEAR AVAILED
5	1-Feb-22	BAGALKOT	110	110/11KV, HV2	STATON NOT AFFECTED RON_110	16:22	16:38	0:16	HAND TRIPPED
6	1-Feb-22	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	14:34	14:35	0:01	HAND TRIPPED
7	1-Feb-22	BAGALKOT	110	110/11KV,HV2	MK HUBLI_220	23:30 (31.01.2022)	1:24 (01.02.2022)	1:54 hrs	TRANSFORMER CHARGED
8	1-Feb-22	BAGALKOT	110	110/33KV,HV3	MANTUR_110 GALAGALI_33, GANI_33	12:17	12:32	0:15	TRANSFORMER FAULT
9	1-Feb-22	BAGALKOT	110	AMBEWADI-(HALIYAL)NK-2	STATION NOT AFFECTED AMBEWADI_220	10:34	14:15	3:59	LINE CLEAR AVAILED
10	1-Feb-22	BAGALKOT	110	AMBEWADI-(NK1)HALIYAL	STATION NOT AFFECTED AMBEWADI_220	9:58 (30.01.2022)	14:15 (01.02.2022)	52:13 hrs	LINE CHARGED
11	1-Feb-22	BAGALKOT	110	AMBEWADI-HALIYAL	HALIYAL_110	9:50	14:15	4:25	NFBC ISSUED
12	1-Feb-22	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	3:11	9:23	6:12	LINE FAULT
13	1-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
14	1-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
15	1-Feb-22	BAGALKOT	110	HIREMASALI-ATHARGA	ATHARGA_110	3:32	4:03	0:31	LINE FAULT
16	1-Feb-22	BAGALKOT	110	HIREMASALI-ATHARGA	ATHARGA_110	5:19	5:41	0:22	LINE FAULT
17	1-Feb-22	BAGALKOT	110	HIREMASALI-ATHARGA	ATHARGA_110	6:17	6:45	0:28	LINE FAULT
18	1-Feb-22	BAGALKOT	110	INDI220-DEVARA HIPPARAGI	DEVARA HIPPARAGI_110,ATHARGA_110,HIR EMASALI_110	3:33	3:45	0:12	LINE FAULT
19	1-Feb-22	BAGALKOT	110	INDI220-DEVARA HIPPARAGI	DEVARA HIPPARAGI_110,ATHARGA_110,HIR EMASALI_110	5:20	5:30	0:10	LINE FAULT
20	1-Feb-22	BAGALKOT	110	INDI220-DEVARA HIPPARAGI	DEVARA HIPPARAGI_110,ATHARGA_110,HIR EMASALI_110	6:20	6:44	0:24	LINE FAULT
21	1-Feb-22	BAGALKOT	110	INDI-HIREMASALI	ATHARGA_110	3:32	4:03	0:31	LINE FAULT
22	1-Feb-22	BAGALKOT	110	INDI-HIREMASALI	ATHARGA_110	5:19	5:41	0:22	LINE FAULT
23	1-Feb-22	BAGALKOT	110	INDI-HIREMASALI	ATHARGA_110	6:17	6:45	0:28	LINE FAULT
24	1-Feb-22	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA_110	9:50	15:03	5:13	LOAD CHANGE OVER
25	1-Feb-22	BAGALKOT	110	NAVALGUND-BIDNAL	STATION NOT AFFECTED NAVALGUND_110	4:20	11:46	7:26	LINE FAULT
26	1-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
27	1-Feb-22	BAGALKOT	220	GHATAPRABHA-NARENDRA2	STATION NOT AFFECTED GHATAPRABHA_220	10:34	17:53	7:20	LINE CLEAR AVAILED
28	1-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
29	1-Feb-22	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	12:53	13:24	0:31	LINE FAULT
30	1-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
31	1-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
32	1-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
33	1-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
34	1-Feb-22	BENGALURU	66	AGALAKOTE - MATHIKERE(NELAMANGALA)	MATHIKERE(NELAMANGALA)	13:21	13:49	0:28	LINE CLEAR AVAILED
35	1-Feb-22	BENGALURU	66	ARMY WELFARE - KADUGODI	ARMY WELFARE	21:28	22:50	1:22	MAIN SUPPLY FAILURE
36	1-Feb-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	19:59	20:19	0:20	LINE FAULT
37	1-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB2	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	7:15	8:15	1:00	LOAD CURTAILMENT
38	1-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE, SOMENAHALLI	9:35	10:35	1:00	LOAD CURTAILMENT
39	1-Feb-22	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	22:30	22:33	0:03	LOAD CHANGE OVER
40	1-Feb-22	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	9:09	9:13	0:04	LOAD CHANGE OVER
41	1-Feb-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	7:20	7:26	0:06	LOAD CHANGE OVER
42	1-Feb-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	18:03	18:06	0:03	LOAD CHANGE OVER
43	1-Feb-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	20:55	20:58	0:03	LOAD CHANGE OVER
44	1-Feb-22	BENGALURU	66	HV2	MULBAGAL	13:44	14:56	1:12	LINE CLEAR AVAILED
45	1-Feb-22	BENGALURU	66	HV2	NIMHANS 220	12:42	12:49	0:07	LINE CLEAR AVAILED
46	1-Feb-22	BENGALURU	66	HV2	TAYALUR	13:35	13:51	0:16	LINE CLEAR AVAILED
47	1-Feb-22	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	12:15	12:21	0:06	LOAD CHANGE OVER
48	1-Feb-22	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	13:40	13:42	0:02	LOAD CHANGE OVER
49	1-Feb-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	6:40	6:52	0:12	LINE FAULT
50	1-Feb-22	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, HAROBELE	7:05	7:15	0:10	LINE CLEAR AVAILED
51	1-Feb-22	BENGALURU	66	KOLAR - BANGARPETE 2	BANGARPETE	7:27	8:17	0:50	LOAD CURTAILMENT
52	1-Feb-22	BENGALURU	66	KOLAR - BANGARPETE 2	BANGARPETE	22:45	23:45	1:00	LOAD CURTAILMENT
53	1-Feb-22	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	19:18	20:00	0:42	LOAD CURTAILMENT
54	1-Feb-22	BENGALURU	66	KONDASPURA - KADUGODI	KONDASPURA	21:28	22:08	0:40	MAIN SUPPLY FAILURE
55	1-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
56	1-Feb-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	7:41	8:16	0:35	LOAD CURTAILMENT
57	1-Feb-22	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:03	16:14	0:11	LINE FAULT
58	1-Feb-22	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:03	16:14	0:11	LINE FAULT
59	1-Feb-22	BENGALURU	66	MALUR 220 - MASTHI	MAASTHI, DEVANGONDHI, LAKKUR	7:09	8:06	0:57	LOAD CURTAILMENT
60	1-Feb-22	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	11:50	11:56	0:06	LOAD CHANGE OVER
61	1-Feb-22	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	16:15	16:19	0:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
62	1-Feb-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	4:16	4:44	0:28	LINE FAULT
63	1-Feb-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	22:58	23:13	0:15	LINE FAULT
64	1-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
65	1-Feb-22	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	8:00	9:30	1:30	LOAD CURTAILMENT
66	1-Feb-22	GULBARGA	66	HV2	PUNAB GHATA_66	15:15	15:20	0:05	TRANSFORMER FAULT
67	1-Feb-22	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,M AGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	11:22	11:30	0:08	LINE FAULT
68	1-Feb-22	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPASAGAR_66,MORGERE_66,T AMBRAHALLI_66	11:55	12:05	0:10	LINE FAULT
69	1-Feb-22	GULBARGA	66	PUNAB GHATA-UCHCHANI DURGA	UCHCHANGIIDURGA_66	8:10	8:20	0:10	LINE FAULT
70	1-Feb-22	GULBARGA	110	HUMNABAD-HALBURGA	HALBURGA_220	17:50	20:03	2:13	LINE CLEAR AVAILED
71	1-Feb-22	GULBARGA	110	HV1	BEVOOR_110	17:50	18:50	1:00	LINE CLEAR AVAILED
72	1-Feb-22	GULBARGA	110	HV1	CHINCHOLI_110	9:25	22:15	12:50	LINE CLEAR AVAILED
73	1-Feb-22	GULBARGA	110	HV1	GULBARGAUNIVRSITY_110	7:45	7:50	0:05	TRANSFORMER FAULT
74	1-Feb-22	GULBARGA	110	HV1	KURKUNTA_110	18:45	18:50	0:05	TRANSFORMER FAULT
75	1-Feb-22	GULBARGA	110	HV1	MANVI_110	16:14	16:22	0:08	TRANSFORMER FAULT
76	1-Feb-22	GULBARGA	110	HV1	TEKKALKOTE_110	18:48	18:59	0:11	LOAD CURTAILMENT
77	1-Feb-22	GULBARGA	110	HV3	VALKAMDINNI_110	3:24	3:29	0:05	TRANSFORMER FAULT
78	1-Feb-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	7:40	8:11	0:31	LINE CLEAR AVAILED
79	1-Feb-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAR_110,HIREGONNAGAR _110,HANUMANAL_110	7:38	7:56	0:18	LINE CLEAR AVAILED
80	1-Feb-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	0:05	0:14	0:09	LINE FAULT
81	1-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI _110	5:07	5:17	0:10	LINE FAULT
82	1-Feb-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:33	1:43	0:10	LINE FAULT
83	1-Feb-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	14:20	14:30	0:10	LINE FAULT
84	1-Feb-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:48	21:58	0:10	LINE FAULT
85	1-Feb-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	20:11	20:17	0:06	LINE FAULT
86	1-Feb-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	22:57	23:01	0:04	LINE FAULT
87	1-Feb-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_1 10,DR NAGAR_110,KARATAGI_110	11:11	11:21	0:10	LINE FAULT
88	1-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHA KTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
89	1-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	7:20	8:55	1:35	LOAD CURTAILMENT
90	1-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	15:45	16:41	0:56	LOAD CURTAILMENT
91	1-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	7:50	8:55	1:05	LOAD CURTAILMENT
92	1-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	10:20	10:24	0:04	LINE FAULT
93	1-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
94	1-Feb-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBAVI_110,UGAR SUGARS_IPP,HUNASAGI_110	7:36	7:50	0:14	LOAD CURTAILMENT
95	1-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:10 (01.02.2022)			LINE OPEN:LINE CLEAR AVAILED
96	1-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:46 (31.01.2022)	8:53 (01.02.2022)	12:07 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
97	1-Feb-22	GULBARGA	110	YERADONA-BENUR	BENUR_110	22:05	22:10	0:05	LINE FAULT
98	1-Feb-22	GULBARGA	220	HV1	SINDHANOOR_220	18:15	18:25	0:10	TRANSFORMER FAULT
99	1-Feb-22	GULBARGA	220	HV1,LV1	KAPNOOR_220	10:45	15:03	4:18	LINE CLEAR AVAILED
100	1-Feb-22	GULBARGA	220	HV2	ALIPUR_220	13:30	13:41	0:11	TRANSFORMER FAULT
101	1-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
102	1-Feb-22	GULBARGA	220	HV2	SINDHANOOR_220	18:13	18:28	0:15	TRANSFORMER FAULT
103	1-Feb-22	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	12:33	15:00	2:27	LINE CLEAR AVAILED
104	1-Feb-22	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	19:04	19:13	0:09	HAND TRIPPED
105	1-Feb-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	13:20	13:40	0:20	LINE FAULT
106	1-Feb-22	HASSAN	66	HV1	HANGARAHALLY_66	13:50	13:56	0:06	TRANSFORMER FAULT
107	1-Feb-22	HASSAN	66	HV1	UDAYAPURA_66	14:30	14:35	0:05	TRANSFORMER FAULT
108	1-Feb-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	10:13	14:20	4:07	NFBC ISSUED
109	1-Feb-22	HASSAN	110	HV2	MSEZ_220	8:55(31.01.2022)	14:17(01.02.2022)	29:12hrs	TRANSFORMER CHARGED
110	1-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE FAULT
111	1-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
112	1-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
113	1-Feb-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
114	1-Feb-22	HASSAN	110	KAVOOR-AMR	KAVOOR_220	5:01	5:22	0:21	LINE FAULT
115	1-Feb-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:13	14:20	4:07	LINE CLEAR AVAILED
116	1-Feb-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
117	1-Feb-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
118	1-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
119	1-Feb-22	MYSURU	66	HV2	SATHEGALA_66	12:25	13:20	0:55	LINE CLEAR AVAILED
120	1-Feb-22	MYSURU	66	HV3	KUSHALANAGARA_66	15:17	15:25	0:08	HAND TRIPPED
121	1-Feb-22	MYSURU	66	HV3	KUSHALANAGARA_66	16:55	17:31	0:36	LINE CLEAR AVAILED
122	1-Feb-22	MYSURU	66	HV4	KUSHALANAGARA_66	15:17	15:25	0:08	HAND TRIPPED
123	1-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
124	1-Feb-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
125	1-Feb-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
126	1-Feb-22	MYSURU	66	YERALLI HAND POST-HD KOTE	ANTHARSANTHE_66HDKOTE_66	12:55	13:05	0:10	LINE FAULT
127	1-Feb-22	MYSURU	220	HV2	BEGUR_220	11:17	12:57	1:40	LINE CLEAR AVAILED
128	1-Feb-22	MYSURU	220	HV2	TUBINAKERE_220	14:59	15:50	0:51	LINE CLEAR AVAILED
129	1-Feb-22	TUMKUR	66	DAVANGERE220kV-DAVANGERE SRS	DAVANAGERE_66	12:07	12:16	0:09	LINE FAULT
130	1-Feb-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENHALLI_66	7:17	8:36	1:19	LOAD CURTAILMENT
131	1-Feb-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENHALLI_66	22:19	22:24	0:05	LOAD CURTAILMENT
132	1-Feb-22	TUMKUR	66	ANCHEPALYA 220kV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	7:17	8:36	1:19	LOAD CURTAILMENT
133	1-Feb-22	TUMKUR	66	ANCHEPALYA 220kV-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	7:17	8:36	1:19	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
134	1-Feb-22	TUMKUR	66	ANTHRASANAHALI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	7:15	7:34	0:19	LOAD CURTAILMENT
135	1-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV-MELEKOTE	MELKOTE_66, BADDIHALI_66	7:15	7:29	0:14	LOAD CURTAILMENT
136	1-Feb-22	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	6:44	7:10	0:25	LINE FAULT
137	1-Feb-22	TUMKUR	66	BRAHMASANDRA- THOVINKERE	THOVINAKERE_66, KORA_66	6:44	7:11	0:26	LINE FAULT
138	1-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	10:24	10:39	0:15	LOAD CURTAILMENT
139	1-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	11:00	11:19	0:19	LOAD CURTAILMENT
140	1-Feb-22	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	7:23	7:35	0:11	LOAD CURTAILMENT
141	1-Feb-22	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	22:37	22:49	0:11	LOAD CURTAILMENT
142	1-Feb-22	TUMKUR	66	DAVANGERE SRS-AVAREGERE66(CTA-1)	AVAREGERE_66, MELLEKATTE_66, KADAJI_66	12:29	12:41	0:12	LINE FAULT
143	1-Feb-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:24	10:25	0:01	LINE FAULT
144	1-Feb-22	TUMKUR	66	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:01	12:15	0:13	LINE FAULT
145	1-Feb-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(PD KOTE)	HARIYABBE_66	16:08	17:43	1:34	LINE CLEAR AVAILED
146	1-Feb-22	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	6:44	7:10	0:25	LINE FAULT
147	1-Feb-22	TUMKUR	66	MADHUGIRI 220kV-BADAVANAHALLI	MADHUGIRI_66, BADAVANAHALLI_66	7:34	7:41	0:06	LOAD CURTAILMENT
148	1-Feb-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66, HDPURA_66,	7:38	7:44	0:06	LINE FAULT
149	1-Feb-22	TUMKUR	66	PATTNAYAKANAHALLI-TAVAREKERE(SIRA)	PATTNAYAKANAHALLI_66	10:42	11:00	0:17	LINE FAULT
150	1-Feb-22	TUMKUR	66	PATTNAYAKANAHALLI-TAVAREKERE(SIRA)	PATTNAYAKANAHALLI_66	11:57	12:03	0:06	LINE FAULT
151	1-Feb-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	7:31	8:43	1:11	MAIN SUPPLY FAILURE
152	1-Feb-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	16:09	18:15	2:05	LINE CLEAR AVAILED
153	1-Feb-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	7:31	8:35	1:04	MAIN SUPPLY FAILURE
154	1-Feb-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	16:09	18:13	2:04	LINE CLEAR AVAILED
155	1-Feb-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	16:11	17:48	1:37	LINE CLEAR AVAILED
156	1-Feb-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	10:10	10:40	0:30	MAIN SUPPLY FAILURE
157	1-Feb-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	10:42	10:52	0:10	MAIN SUPPLY FAILURE
158	1-Feb-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	10:58	11:20	0:22	MAIN SUPPLY FAILURE
159	1-Feb-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	11:55	12:05	0:10	MAIN SUPPLY FAILURE
160	1-Feb-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	12:06	12:10	0:04	MAIN SUPPLY FAILURE
161	1-Feb-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	7:31	9:10	1:38	MAIN SUPPLY FAILURE
162	1-Feb-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	16:09	18:17	2:08	LINE CLEAR AVAILED
163	1-Feb-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 2	PATNAYAKANAHALLI LINE2	7:30	8:34	1:04	LOAD CURTAILMENT
164	1-Feb-22	TUMKUR	66	TR-1	CHIKKABANAGERE_66	7:02	8:40	1:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
165	1-Feb-22	TUMKUR	66	TR-1	CHIKKABANAGERE_66	10:28	10:35	0:06	LOAD CURTAILMENT
166	1-Feb-22	TUMKUR	66	TR-1	HANGAL_66	8:43	8:50	0:06	TRANSFORMER FAULT
167	1-Feb-22	TUMKUR	66	TR-1	HONNALLI_66	16:26	19:56	3:29	TRANSFORMER FAULT
168	1-Feb-22	TUMKUR	66	TR-1	NAGASAMUDRA_66	15:19	15:23	0:03	MAIN SUPPLY FAILURE
169	1-Feb-22	TUMKUR	66	TR-1	PDKOTE_66	16:11	18:02	1:51	LINE CLEAR AVAILED
170	1-Feb-22	TUMKUR	66	TR-1	RAMAPURA_66	11:07	11:12	0:05	TRANSFORMER FAULT
171	1-Feb-22	TUMKUR	66	TR-1	SARA_66	12:39	13:29	0:49	LINE CLEAR AVAILED
172	1-Feb-22	TUMKUR	66	TR-1	SASALUHALLA_66	16:23	16:33	0:09	TRANSFORMER FAULT
173	1-Feb-22	TUMKUR	66	TR-2	CHIKKABANAGERE_66	10:28	10:35	0:06	LOAD CURTAILMENT
174	1-Feb-22	TUMKUR	66	TR-2	PDKOTE_66	16:11	18:02	1:51	LINE CLEAR AVAILED
175	1-Feb-22	TUMKUR	66	TR-2	SARA_66	12:15	12:37	0:22	LINE CLEAR AVAILED
176	1-Feb-22	TUMKUR	110	TR-1	KALLUR_110	6:47	7:11	0:23	TRANSFORMER FAULT
177	1-Feb-22	TUMKUR	110	TR-1(LV-1)	KBCROSS_220	6:03	7:28	1:25	TRANSFORMER FAULT
178	1-Feb-22	TUMKUR	220	TR-1	KBCROSS_220	6:03	7:37	1:34	TRANSFORMER FAULT
1	02-Feb-22	BAGALKOT	110	110/11KV,HV1	ALABAL_110	12:08	12:13	0:05	TRANSFORMER FAULT
2	02-Feb-22	BAGALKOT	110	110/11KV,HV1	BELUR_110	13:32	13:44	0:12	LINE CLEAR AVAILED
3	02-Feb-22	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	15:31	18:41	3:10	LINE CLEAR AVAILED
4	02-Feb-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	14:21	14:25	0:04	TRANSFORMER FAULT
5	02-Feb-22	BAGALKOT	110	110/11KV,HV1	KUD DHARWAD_110	17:21	18:03	0:42	LINE CLEAR AVAILED
6	02-Feb-22	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	11:03	11:08	0:05	TRANSFORMER FAULT
7	02-Feb-22	BAGALKOT	110	110/11KV,HV2	RON_110	16:00	17:21	1:21	LINE CLEAR AVAILED
8	02-Feb-22	BAGALKOT	110	110/11KV,HV2	SHIROL_110	14:05	14:55	0:50	LINE CLEAR AVAILED
9	02-Feb-22	BAGALKOT	110	110/11KV,HV2	TAKKALAKI_110	17:07	17:59	0:52	LINE CLEAR AVAILED
10	02-Feb-22	BAGALKOT	110	110/11KV,HV3	TODALBAGI_110	17:22	18:57	1:35	LINE CLEAR AVAILED
11	02-Feb-22	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	7:20	20:26	13:06	LINE FAULT
12	02-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
13	02-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
14	02-Feb-22	BAGALKOT	110	KONNUR-KERUR	KONNUR_110	7:00	7:10	0:10	LINE FAULT
15	02-Feb-22	BAGALKOT	110	KUMATA-KRCL(SIRSI 1)	KUMATA_110	7:02	7:10	0:08	LINE FAULT
16	02-Feb-22	BAGALKOT	110	KUMATA-KRCL(SIRSI 1)	KUMATA_110	8:26	8:32	0:06	LINE FAULT
17	02-Feb-22	BAGALKOT	110	KUMATA-KRCL(SIRSI 1)	KUMATA_110	13:23	13:30	0:07	LINE FAULT
18	02-Feb-22	BAGALKOT	110	MURDESHWAR- KRCL(HONNAVAR)	MURDESHWAR_110	6:56	7:05	0:09	LINE FAULT
19	02-Feb-22	BAGALKOT	110	MURDESHWAR- KRCL(HONNAVAR)	MURDESHWAR_110	13:29	13:40	0:11	LINE FAULT
20	02-Feb-22	BAGALKOT	110	RON-GAMESH	RON_110	19:05	19:25	0:20	HAND TRIPPED
21	02-Feb-22	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	12:10	17:59	5:49	LINE CLEAR AVAILED
22	02-Feb-22	BAGALKOT	110	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_220	13:17	20:21	7:04	LINE CLEAR AVAILED
23	02-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
24	02-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
25	02-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
26	02-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
27	02-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
28	02-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
29	02-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
30	02-Feb-22	BENGALURU	66	ABBIGERE - WELCAST	ABBIGERE	12:28	12:35	0:07	LOAD CHANGE OVER
31	02-Feb-22	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	14:45	14:50	0:05	LOAD CHANGE OVER
32	02-Feb-22	BENGALURU	66	ARMY WELFARE - KONDASPURA	ARMY WELFARE	4:42	4:45	0:03	LOAD CHANGE OVER
33	02-Feb-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	5:31	5:39	0:08	LINE FAULT
34	02-Feb-22	BENGALURU	66	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:56	10:25	0:29	LINE FAULT
35	02-Feb-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI	21:28(01/02/2022)	00:11(02/02/2022)	2:43HRS	LINE CHARGED
36	02-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB2	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	7:06	7:56	0:50	LOAD CURTAILMENT
37	02-Feb-22	BENGALURU	66	HBR LAYOUT - HEBBALA 220	HBR LAYOUT	6:08	6:11	0:03	LOAD CHANGE OVER
38	02-Feb-22	BENGALURU	66	HV1	CESSNA	5:01	6:15	1:14	LINE CLEAR AVAILED
39	02-Feb-22	BENGALURU	66	HV1	DODDABELAVANGALA	2:58	4:45	1:47	TRANSFORMER FAULT
40	02-Feb-22	BENGALURU	66	HV1	EPIP 220	20:23	21:06	0:43	LINE CLEAR AVAILED
41	02-Feb-22	BENGALURU	66	HV1	EPIP 220	21:06	21:07	0:01	LINE CLEAR AVAILED
42	02-Feb-22	BENGALURU	66	HV1	EPIP 220	21:08	21:35	0:27	LINE CLEAR AVAILED
43	02-Feb-22	BENGALURU	66	HV1	HAL 220	10:38	10:40	0:02	LINE CLEAR AVAILED
44	02-Feb-22	BENGALURU	66	HV1	PALLICHERLU	15:12	15:15	0:02	LINE CLEAR AVAILED
45	02-Feb-22	BENGALURU	66	HV1	SIDDLAGHATTA	13:15	13:32	0:16	LINE CLEAR AVAILED
46	02-Feb-22	BENGALURU	66	HV2	EXORA	9:08	9:13	0:05	LINE CLEAR AVAILED
47	02-Feb-22	BENGALURU	66	HV2	KGF	6:00	6:10	0:10	TRANSFORMER FAULT
48	02-Feb-22	BENGALURU	66	KADUGODI -EPIP 220	KADUGODI, ARMY WELFARE, KONDASPURA	5:15	5:40	0:25	LINE FAULT
49	02-Feb-22	BENGALURU	66	KADUGODI -EPIP 220	KADUGODI, ARMY WELFARE, KONDASPURA	7:11	7:25	0:14	LINE FAULT
50	02-Feb-22	BENGALURU	66	KGF - MALUR 1 & 2	KGF, KAMASAMUDRA, BEML(EHT)	11:45	13:10	1:25	LINE CLEAR AVAILED
51	02-Feb-22	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:10	8:05	0:55	LOAD CURTAILMENT
52	02-Feb-22	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:17	22:30	0:13	LOAD CURTAILMENT
53	02-Feb-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	13:51	14:43	0:52	LINE FAULT
54	02-Feb-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:43	15:16	0:33	LINE FAULT
55	02-Feb-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	15:16	18:17	3:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
56	02-Feb-22	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	20:03	20:30	0:27	LOAD CURTAILMENT
57	02-Feb-22	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR, TALAGUNDA	15:38	17:20	1:42	LINE CLEAR AVAILED
58	02-Feb-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:05	19:35	0:30	LOAD CURTAILMENT
59	02-Feb-22	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	5:03	5:48	0:45	LOAD CHANGE OVER
60	02-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
61	02-Feb-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:49	7:03	0:14	LINE FAULT
62	02-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	1:28	2:40	1:12	LINE FAULT
63	02-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	5:40	6:07	0:27	LINE FAULT
64	02-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	6:17	10:18	4:01	LINE FAULT
65	02-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	10:28	10:33	0:05	LINE CLEAR AVAILED
66	02-Feb-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:08	14:23	0:15	LINE FAULT
67	02-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
68	02-Feb-22	GULBARGA	66	HV1	UCCHANGIDURGA_66	19:10(2.02.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
69	02-Feb-22	GULBARGA	66	ITTAGI-RENEW SOLAR2_IPP	ITTAGI_220	13:44	14:10	0:26	LINE FAULT
70	02-Feb-22	GULBARGA	66	ITTAGI-RENEW SOLAR2_IPP	ITTAGI_220	14:44	18:26	3:42	LINE FAULT
71	02-Feb-22	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPASAGAR_66,MORGERE_66,T AMBRAHALLI_66	8:15	8:30	0:15	LINE FAULT
72	02-Feb-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	8:25	8:35	0:10	LOAD CURTAILMENT
73	02-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	ADAVI AMARESHWAR_110	8:27	20:20	11:53	NFBC ISSUED
74	02-Feb-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110	14:00	14:20	0:20	MAIN SUPPLY FAILURE
75	02-Feb-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IP P,BHALKI SUGAR_IPP	15:35	18:39	3:04	LINE CLEAR AVAILED
76	02-Feb-22	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	6:29	6:40	0:11	LINE FAULT
77	02-Feb-22	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	15:35	18:49	3:14	LINE CLEAR AVAILED
78	02-Feb-22	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	13:35	14:15	0:40	MAIN SUPPLY FAILURE
79	02-Feb-22	GULBARGA	110	HV1	HUMNABAD_220	9:50	17:20	7:30	LOAD CHANGE OVER
80	02-Feb-22	GULBARGA	110	JAWALGERA- ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	2:55	3:05	0:10	LINE FAULT
81	02-Feb-22	GULBARGA	110	JAWALGERA-SINDHANOOR	JAWALGERA_110	19:50	20:20	0:30	MAIN SUPPLY FAILURE
82	02-Feb-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNA GAR_110,HANUMANAL_110	17:06	17:30	0:24	LINE FAULT
83	02-Feb-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	23:57	23:59	0:02	LINE FAULT
84	02-Feb-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	3:57	4:10	0:13	LINE FAULT
85	02-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	3:30	3:39	0:09	LINE FAULT
86	02-Feb-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	2:31	2:40	0:09	LINE FAULT
87	02-Feb-22	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	19:49	20:11	0:22	MAIN SUPPLY FAILURE
88	02-Feb-22	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPURA_110	19:50	20:17	0:27	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
89	02-Feb-22	GULBARGA	110	NANDOOR-SHAHBAD	NANDOOR_110	13:57	14:18	0:21	MAIN SUPPLY FAILURE
90	02-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
91	02-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	7:29	8:29	1:00	LOAD CURTAILMENT
92	02-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	7:29	8:29	1:00	LOAD CURTAILMENT
93	02-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	19:05	19:36	0:31	LOAD CURTAILMENT
94	02-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	7:29	8:30	1:01	LOAD CURTAILMENT
95	02-Feb-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	15:48	15:50	0:02	LOAD CURTAILMENT
96	02-Feb-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	15:48	16:23	0:35	LINE CLEAR AVAILED
97	02-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
98	02-Feb-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:34	5:41	0:07	LINE FAULT
99	02-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	18:59 (02.02.2022)			LINE OPEN:LINE CLEAR AVAILED
100	02-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:10 (01.02.2022)	8:42 (02.02.2022)	13:32 HRS	LINE CHARGED
101	02-Feb-22	GULBARGA	110	SINDHANOOR110-SINDHANOOR220	SINDHANOOR_110,VALKAMDINNI_110,MUDDAPUR_110	19:20	20:20	1:00	MAIN SUPPLY FAILURE
102	02-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	13:10	13:20	0:10	LINE FAULT
103	02-Feb-22	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,MUDDAPUR_110,MASKI_110,VALAKAMDINNI_110	2:35	2:45	13:40	LINE FAULT
104	02-Feb-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	7:45	8:20	0:35	MAIN SUPPLY FAILURE
105	02-Feb-22	GULBARGA	220	HALBARGA-HUMNABAD	HALBARGA_220	13:57	14:18	0:21	MAIN SUPPLY FAILURE
106	02-Feb-22	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	14:05	14:20	0:15	LINE CLEAR AVAILED
107	02-Feb-22	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	14:06	14:21	0:15	LINE CLEAR AVAILED
108	02-Feb-22	GULBARGA	220	HUMNABAD-SEDAM-1	SEDAM_220	13:58	18:21	4:23	LINE CLEAR AVAILED
109	02-Feb-22	GULBARGA	220	HUMNABAD-SEDAM-2	SEDAM_220	13:59	14:18	0:19	LINE CLEAR AVAILED
110	02-Feb-22	GULBARGA	220	HV1	SHAHAPUR_220	13:35	13:52	0:17	TRANSFORMER FAULT
111	02-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
112	02-Feb-22	GULBARGA	220	HV2	SHAHAPUR_220	13:35	13:54	0:19	TRANSFORMER FAULT
113	02-Feb-22	GULBARGA	220	HV2	SINDHANOOR_220	19:45(02.02.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
114	02-Feb-22	GULBARGA	220	KAPNOOR-HUMNABAD1,2	KAPNOOR_220	13:55	15:00	1:05	LINE FAULT
115	02-Feb-22	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	13:55	15:00	1:05	LINE FAULT
116	02-Feb-22	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	13:33	14:26	0:53	LINE FAULT
117	02-Feb-22	GULBARGA	220	LINGASUGUR-SINDHANOOR1	SINDHANOOR_220	19:49	20:34	0:45	LINE FAULT
118	02-Feb-22	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	13:35	14:29	0:54	LINE FAULT
119	02-Feb-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:55	18:25	7:30	LINE FAULT
120	02-Feb-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:53	11:07	0:14	LINE FAULT
121	02-Feb-22	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHARPURA_66	12:43	13:50	1:07	LINE CLEAR AVAILED
122	02-Feb-22	HASSAN	66	HV1	HARIHARPURA_66	12:43	13:50	1:07	LINE CLEAR AVAILED
123	02-Feb-22	HASSAN	66	HV1	SAKALESH PURA_66	14:40	15:18	0:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
124	02-Feb-22	HASSAN	66	HV1	SAKALESH PURA_66	14:40	15:30	0:50	LINE CLEAR AVAILED
125	02-Feb-22	HASSAN	66	HV4	BALEHONNUR_66	8:48 (2.02.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
126	02-Feb-22	HASSAN	66	MARRNAV-DIDGTHL	MATTANAVILE_66	10:58	11:07	0:09	LINE FAULT
127	02-Feb-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	12:54	13:05	0:11	LINE FAULT
128	02-Feb-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:55	11:10	0:15	MAIN SUPPLY FAILURE
129	02-Feb-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:55	18:18	7:23	MAIN SUPPLY FAILURE
130	02-Feb-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:50	18:12	8:22	MAIN SUPPLY FAILURE
131	02-Feb-22	HASSAN	110	HV1	HOSUR_110	10:14	10:22	0:08	HAND TRIPPED
132	02-Feb-22	HASSAN	110	HV1	KONAJE_110	10:17	10:22	0:05	LOAD CHANGE OVER
133	02-Feb-22	HASSAN	110	HV1	KONAJE_110	13:58	14:02	0:04	LOAD CHANGE OVER
134	02-Feb-22	HASSAN	110	HV1	MSEZ_220	10:18	16:17	5:59	LINE CLEAR AVAILED
135	02-Feb-22	HASSAN	110	HV2	KONAJE_110	10:17	10:22	0:05	LOAD CHANGE OVER
136	02-Feb-22	HASSAN	110	HV2	KONAJE_110	13:58	14:02	0:04	LOAD CHANGE OVER
137	02-Feb-22	HASSAN	110	HV3	KONAJE_110	10:17	10:22	0:05	LOAD CHANGE OVER
138	02-Feb-22	HASSAN	110	HV3	KONAJE_110	13:58	14:02	0:04	LOAD CHANGE OVER
139	02-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE FAULT
140	02-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
141	02-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
142	02-Feb-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
143	02-Feb-22	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
144	02-Feb-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:30	13:53	3:23	NFBC ISSUED
145	02-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	9:45	18:12	8:27	LINE CLEAR AVAILED
146	02-Feb-22	HASSAN	220	MRSSHM-CHMLR	MRS MG_220	16:36	17:43	1:07	LINE FAULT
147	02-Feb-22	MYSURU	66	DEVNUR(MYS)-RAJEEV NAGARA	DEVANOORMYS_66	14:20	15:02	0:41	HAND TRIPPED
148	02-Feb-22	MYSURU	66	DEVNUR(MYS)-VAJMANGALA	NO STATIONS EFFECTED	14:21	17:43	3:21	LINE FAULT
149	02-Feb-22	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	14:50	17:50	3:00	LOAD CHANGE OVER
150	02-Feb-22	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	14:38	17:44	3:06	LOAD CHANGE OVER
151	02-Feb-22	MYSURU	66	FTS-RAJEEV NAGARA	RAJEEVNAGARA_66	14:38	14:53	0:14	LOAD CHANGE OVER
152	02-Feb-22	MYSURU	66	HV1	HAMPAPURA(K)_66	12:51	13:54	1:03	LINE CLEAR AVAILED
153	02-Feb-22	MYSURU	66	HV1	HONGANURU_66	15:20	15:25	0:05	TRANSFORMER FAULT
154	02-Feb-22	MYSURU	66	HV1	HONGANURU_66	22:03	22:10	0:07	TRANSFORMER FAULT
155	02-Feb-22	MYSURU	66	HV1	KHBCOLONY_66	11:34	12:10	0:36	LINE CLEAR AVAILED
156	02-Feb-22	MYSURU	66	HV1	MADIKERI_66	16:41	17:42	1:01	LINE CLEAR AVAILED
157	02-Feb-22	MYSURU	66	HV1	MANDGERE_66	12:00	12:15	0:15	TRANSFORMER FAULT
158	02-Feb-22	MYSURU	66	HV1	YERAHALLI_66	13:55	14:00	0:05	TRANSFORMER FAULT
159	02-Feb-22	MYSURU	66	HV2	HAMPAPURA(K)_66	11:25	12:45	1:20	LINE CLEAR AVAILED
160	02-Feb-22	MYSURU	66	HV2	KOLKARANADODDI_66	17:55	18:40	0:45	LINE CLEAR AVAILED
161	02-Feb-22	MYSURU	66	HV2	SFCSHIVA_66	14:54	16:05	1:11	HAND TRIPPED
162	02-Feb-22	MYSURU	66	KADABALLI-YACHENAHALLI	KADABALLY_66	11:00	11:10	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
163	02-Feb-22	MYSURU	66	KIADB MANDYA-MADDUR	KMDODDI_66 KKDODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBEKERE _66MADDUR_66	14:14	14:33	0:19	HAND TRIPPED
164	02-Feb-22	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	15:43	15:48	0:04	LINE FAULT
165	02-Feb-22	MYSURU	66	KUNTHUR-DR PETE	NO STATIONS EFFECTED	2:18	2:25	0:06	LINE FAULT
166	02-Feb-22	MYSURU	66	LOKKANAHALLI-PG PALYA	PGPALYA_66	23:45	23:50	0:05	LINE FAULT
167	02-Feb-22	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66	15:12	15:45	0:33	LINE FAULT
168	02-Feb-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	2:19	2:25	0:06	LINE FAULT
169	02-Feb-22	MYSURU	66	SUNTIKOPPA-KUSHALNAGARA	NO STATIONS EFFECTED	11:16			LINE OPEN:LINE CLEAR AVAILED
170	02-Feb-22	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	11:05	15:40	4:35	LINE CLEAR AVAILED
171	02-Feb-22	MYSURU	66	TALAGAWADI-MANDYA	TALAGAWADI_66	14:10	14:35	0:25	LINE FAULT
172	02-Feb-22	TUMKUR	66	BRAHMASANDRA- THOVINKERE(KORA)	THOVINKERE_66, KORA_66	11:11	11:39	0:28	LINE CLEAR AVAILED
173	02-Feb-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	18:20	18:28	0:08	LINE FAULT
174	02-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:07	9:17	0:10	MAIN SUPPLY FAILURE
175	02-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:01	19:13	0:12	MAIN SUPPLY FAILURE
176	02-Feb-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:19	9:29	0:10	LINE FAULT
177	02-Feb-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:13	17:59	0:46	LINE FAULT
178	02-Feb-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	9:01	12:50	3:49	LINE CLEAR AVAILED
179	02-Feb-22	TUMKUR	66	PAVAGADA220- NAGALAMADIKE66	PAVAGADA_220	15:06	15:10	0:03	LINE FAULT
180	02-Feb-22	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	7:45	7:50	0:05	LINE FAULT
181	02-Feb-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	10:15	11:24	1:09	LINE CLEAR AVAILED
182	02-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	18:00	18:32	0:32	HAND TRIPPED
183	02-Feb-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	18:00	18:32	0:32	HAND TRIPPED
184	02-Feb-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	18:00	18:32	0:32	HAND TRIPPED
185	02-Feb-22	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	18:00	18:18	0:18	HAND TRIPPED
186	02-Feb-22	TUMKUR	66	TR-1	BELLAVI_66	3:16	3:34	0:18	TRANSFORMER FAULT
187	02-Feb-22	TUMKUR	66	TR-1	KUKKAWADA_66	11:44	17:30	5:46	LINE CLEAR AVAILED
188	02-Feb-22	TUMKUR	66	TR-1	PDKOTE_66	18:00	18:22	0:22	HAND TRIPPED
189	02-Feb-22	TUMKUR	66	TR-1	PULAMGHATTA_66	10:35	10:40	0:05	TRANSFORMER FAULT
190	02-Feb-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	6:56	7:00	0:04	TRANSFORMER FAULT
191	02-Feb-22	TUMKUR	66	TR-2	KUKKAWADA_66	18:28	18:29	0:01	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
192	02-Feb-22	TUMKUR	66	TR-2	MALEBENNUR_66	16:05	18:29	2:24	LINE CLEAR AVOIDED
193	02-Feb-22	TUMKUR	66	TR-2	PULAMGHATTA_66	10:35	10:40	0:05	TRANSFORMER FAULT
194	02-Feb-22	TUMKUR	66	TR-3	HARIYABBE_66	17:27	17:52	0:25	LINE CLEAR AVOIDED
195	02-Feb-22	TUMKUR	110	TR-1	DODDAGUNI_110	10:08	15:12	5:04	LINE CLEAR AVOIDED
196	02-Feb-22	TUMKUR	110	TR-1	KBCROSS_220	5:22	7:03	1:41	TRANSFORMER FAULT
197	02-Feb-22	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	12:35	12:58	0:23	LINE FAULT
198	02-Feb-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	16:02	17:37	1:35	LINE CLEAR AVOIDED
199	02-Feb-22	TUMKUR	220	TR-1	KBCROSS_220	5:22	7:03	1:41	TRANSFORMER FAULT
1	3-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_220	12:34	13:09	0:35	LINE CLEAR AVOIDED
2	3-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MANTUR_110	16:30	16:50	0:20	LINE CLEAR AVOIDED
3	3-Feb-22	BAGALKOT	110	110/11KV,HV1	HEBBALLI_110	15:10	15:27	0:17	TRANSFORMER FAULT
4	3-Feb-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	14:23	14:26	0:03	TRANSFORMER FAULT
5	3-Feb-22	BAGALKOT	110	110/11KV,HV1	UAS DHARWAD_110	23:09	23:17	0:08	TRANSFORMER FAULT
6	3-Feb-22	BAGALKOT	110	110/11KV,HV2	MANTUR(G)_110	10:52	11:22	0:30	LINE CLEAR AVOIDED
7	3-Feb-22	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	12:18	16:34	4:16	LINE CLEAR AVOIDED
8	3-Feb-22	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	16:34	18:40	2:06	LINE CLEAR AVOIDED
9	3-Feb-22	BAGALKOT	110	110/11KV,HV3	RATTIHALI_110	23:14	23:20	0:06	TRANSFORMER FAULT
10	3-Feb-22	BAGALKOT	110	110/33KV,HV2	HIREKERUR_110 &CHIKKERUR,KODA_33	10:00	18:32	8:32	LINE CLEAR AVOIDED
11	3-Feb-22	BAGALKOT	110	110/33KV,HV3	RUSTUMPUR,W/S1,2&3_33 STATION NOT AFFECTED HIDIDKAL DAM_110	11:02	17:23	6:21	LINE CLEAR AVOIDED
12	3-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVOIDED
13	3-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
14	3-Feb-22	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT AFFECTED HUKKERI_110	0:00	23:59	23:59	NFBC ISSUED
15	3-Feb-22	BAGALKOT	110	JOG 2-SIRSI	SIRSI_110	14:38	16:54	2:16	LINE CLEAR AVOIDED
16	3-Feb-22	BAGALKOT	110	MALGHAN-BSAVA SUGARS	MALGHAN_110	15:29	15:30	0:01	HAND TRIPPED
17	3-Feb-22	BAGALKOT	110	NAREGAL-BETAGERI	NAREGAL_110	12:40	13:51	1:11	LINE CLEAR AVOIDED
18	3-Feb-22	BAGALKOT	110	RANNABELAGALI- UTTUR(MUDHOL)	UTTUR_110	11:22	13:33	2:11	LINE CLEAR AVOIDED
19	3-Feb-22	BAGALKOT	110	VAJRAMATTI- MUDHOL(MANTUR)	MUDHOL_110	9:07	9:11	0:04	LOAD CHANGE OVER
20	3-Feb-22	BAGALKOT	220	220/110KV,HV1 &LV1	KUDACHI_220	12:05	16:15	4:10	LINE CLEAR AVOIDED
21	3-Feb-22	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	9:20	18:11	8:51	LINE CLEAR AVOIDED
22	3-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVOIDED
23	3-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
24	3-Feb-22	BAGALKOT	220	HUBLI-NARENDRA	STATION NOT AFFECTED HUBLI_220	12:35	17:23	4:48	LINE CLEAR AVOIDED
25	3-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
26	3-Feb-22	BAGALKOT	220	RANEENNUR220-HIREKERUR	STATION NOT AFFECTED RANEENNUR_220	4:40	4:46	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
27	3-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
28	3-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
29	3-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
30	3-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
31	3-Feb-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR, DALASNUR	7:41	8:13	0:31	LOAD CURTAILMENT
32	3-Feb-22	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	16:41	16:47	0:05	LOAD CHANGE OVER
33	3-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	BAGEPALLI, VIDHURASHWATHA, GUNDLU KOTTUR	17:30	18:30	1:00	LOAD CURTAILMENT
34	3-Feb-22	BENGALURU	66	HV1	GURUVINAPURA	15:45	15:58	0:13	LOAD CHANGE OVER
35	3-Feb-22	BENGALURU	66	HV1	GURUVINAPURA	15:45	15:58	0:13	LOAD CHANGE OVER
36	3-Feb-22	BENGALURU	66	HV1	HOSKOTE 220	3:23(03/02/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
37	3-Feb-22	BENGALURU	66	HV1	HOSOR RAMAPURA	14:50	15:50	1:00	LINE CLEAR AVAILED
38	3-Feb-22	BENGALURU	66	HV1	MAGADI 220	11:53	13:38	1:44	LINE CLEAR AVAILED
39	3-Feb-22	BENGALURU	66	HV1	NAGANATHPURA 220	9:50	12:04	2:14	LINE CLEAR AVAILED
40	3-Feb-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	9:00	9:05	0:05	LINE CLEAR AVAILED
41	3-Feb-22	BENGALURU	66	HV2	NAGANATHPURA 220	9:50	10:32	0:42	LINE CLEAR AVAILED
42	3-Feb-22	BENGALURU	66	HV2	NAGANATHPURA 220	12:15	13:20	1:04	LINE CLEAR AVAILED
43	3-Feb-22	BENGALURU	66	HV2	NAGANATHPURA 220	13:25	13:41	0:16	LINE CLEAR AVAILED
44	3-Feb-22	BENGALURU	66	HV2	SIDDALAGATTA	10:55	11:01	0:05	TRANSFORMER FAULT
45	3-Feb-22	BENGALURU	66	HV2	TEMAGONDALU	17:20	18:40	1:20	TRANSFORMER FAULT
46	3-Feb-22	BENGALURU	66	HV3	NAGANATHPURA 220	9:50	10:32	0:42	LINE CLEAR AVAILED
47	3-Feb-22	BENGALURU	66	HV3	NAGANATHPURA 220	14:37	15:44	1:06	LINE CLEAR AVAILED
48	3-Feb-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJAHALLI, KUNUR	3:56	4:10	0:13	LINE FAULT
49	3-Feb-22	BENGALURU	66	KIADB HARDWARE PARK 220 - BHP (EHT)	BHP (EHT)	9:38	19:14	9:36	LINE CLEAR AVAILED
50	3-Feb-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	7:19	7:53	0:34	LOAD CURTAILMENT
51	3-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
52	3-Feb-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI	11:53	13:37	1:44	LINE CLEAR AVAILED
53	3-Feb-22	BENGALURU	66	MAGADI 220 - TG HALLI	TG HALLI, TAVAREKAERE, VG DODDI	11:53	13:37	1:44	LINE CLEAR AVAILED
54	3-Feb-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	10:04	10:28	0:23	LINE CLEAR AVAILED
55	3-Feb-22	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	10:04	10:28	0:23	LINE CLEAR AVAILED
56	3-Feb-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	13:58	15:58	2:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
57	3-Feb-22	BENGALURU	220	HV1	MAGADI 220	11:53	13:34	1:40	LINE CLEAR AVAILED
58	3-Feb-22	BENGALURU	220	KOLAR 220 - MALUR 1 220	NO STATION AFFECTED	7:28	7:52	0:24	LINE FAULT
59	3-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
60	3-Feb-22	GULBARGA	66	HV1	UCCHANGIDURGA_66	19:10(2.02.2022)	11:05(03.02.2022)	15:55 hrs	LINE CLEAR AVAILED
61	3-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110,JAWALGERA_110	1:45	1:56	0:11	MAIN SUPPLY FAILURE
62	3-Feb-22	GULBARGA	110	HV1	CHINCHOLI_110	15:02	17:42	2:40	LINE CLEAR AVAILED
63	3-Feb-22	GULBARGA	110	HV1,HV2	MYLAR_110	11:01	15:30	4:29	LINE CLEAR AVAILED
64	3-Feb-22	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	19:07	19:18	0:11	LINE FAULT
65	3-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:15	15:04	4:49	LOAD CHANGE OVER
66	3-Feb-22	GULBARGA	110	MALLAPURA-MUNIRABAD	MALLAPURA_110,KAMPLI_GLB_110	13:40	14:01	0:21	MAIN SUPPLY FAILURE
67	3-Feb-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	6:14	6:24	0:10	LINE FAULT
68	3-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	1:46	1:56	0:10	LINE FAULT
69	3-Feb-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPUR_110	13:26	13:37	0:11	LINE FAULT
70	3-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
71	3-Feb-22	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	7:45	8:21	0:36	LOAD CURTAILMENT
72	3-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	6:25	7:25	1:00	LOAD CURTAILMENT
73	3-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	11:40	12:10	0:30	LOAD CURTAILMENT
74	3-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:25	7:25	1:00	LOAD CURTAILMENT
75	3-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:40	12:10	0:30	LOAD CURTAILMENT
76	3-Feb-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:16	14:29	0:13	LINE FAULT
77	3-Feb-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	10:44	17:08	6:24	LINE CLEAR AVAILED
78	3-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
79	3-Feb-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	1:17	1:22	0:05	LINE FAULT
80	3-Feb-22	GULBARGA	110	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	4:06	4:14	0:08	LINE FAULT
81	3-Feb-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	2:30	2:53	0:23	LINE FAULT
82	3-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	16:11 (03.02.2022)			LINE OPEN:LINE CLEAR AVAILED
83	3-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	18:59 (02.02.2022)	8:40 (03.02.2022)	13:41 HRS	LINE CHARGED
84	3-Feb-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	7:45	8:20	0:35	MAIN SUPPLY FAILURE
85	3-Feb-22	GULBARGA	110	YEREGERA-MALIYABAD	YEREGERA_110	7:45	8:22	0:37	MAIN SUPPLY FAILURE
86	3-Feb-22	GULBARGA	110	YEREGERA-MALIYABAD	YEREGERA_110	7:45	8:22	0:37	MAIN SUPPLY FAILURE
87	3-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
88	3-Feb-22	GULBARGA	220	HV2	SINDHANOOR_220	19:45(02.02.2022)	08:15(03.02.2022)	12:30HRS	TRANSFORMER CHARGED
89	3-Feb-22	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	11:57	17:50	5:53	LINE CLEAR AVAILED
90	3-Feb-22	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	10:10	17:56	7:46	LINE CLEAR AVAILED
91	3-Feb-22	GULBARGA	220	SEDAM-RTPS2	RTPS_220	5:01	6:49	1:48	LINE FAULT
92	3-Feb-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	11:51	12:03	0:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
93	3-Feb-22	HASSAN	66	HV1	HOLALUR_66	7:11	7:46	0:35	TRANSFORMER FAULT
94	3-Feb-22	HASSAN	66	HV3	BALEHONNUR_66	18:19	18:58	0:39	HAND TRIPPED
95	3-Feb-22	HASSAN	66	HV4	BALEHONNUR_66	8:48 (2.02.2022)			TRANSFORMER OPEN:LINE CLEAR AVALIED
96	3-Feb-22	HASSAN	66	LV1	CRPATNA_220	13:15	14:36	1:21	LINE CLEAR AVALIED
97	3-Feb-22	HASSAN	110	HV1	KARAYA_110	10:24	12:48	2:24	LINE CLEAR AVALIED
98	3-Feb-22	HASSAN	110	HV2	ESSUR_110	14:34	17:06	2:32	LINE CLEAR AVALIED
99	3-Feb-22	HASSAN	110	HV2	KARAYA_110	12:49	14:34	1:45	LINE CLEAR AVALIED
100	3-Feb-22	HASSAN	110	HV2	KARAYA_110	19:19	20:52	1:33	LINE CLEAR AVALIED
101	3-Feb-22	HASSAN	110	HV4	MANIPAL_110	10:15	17:08	6:53	LINE CLEAR AVALIED
102	3-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE FAULT
103	3-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVALIED
104	3-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVALIED
105	3-Feb-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVALIED
106	3-Feb-22	HASSAN	110	KEMAR-BELMAN	KEMAR_220	10:17	13:05	2:48	LINE CLEAR AVALIED
107	3-Feb-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:07	14:09	4:02	LOAD CHANGE OVER
108	3-Feb-22	HASSAN	110	MRSSTM-BADRAVATY1	MRSMTG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVALIED
109	3-Feb-22	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	9:57	15:01	5:04	LINE CLEAR AVALIED
110	3-Feb-22	HASSAN	220	HV1	CRPATNA_220	13:16	14:36	1:20	LINE CLEAR AVALIED
111	3-Feb-22	HASSAN	220	KADUR-DABUSET	KADUR_220	15:24	15:46	0:22	LINE FAULT
112	3-Feb-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVALIED
113	3-Feb-22	MYSURU	66	HAMPAPURA K-KADAKOLA	HAMPAPURA(K)_66	10:00	19:30	9:30	NFBC ISSUED
114	3-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVALIED
115	3-Feb-22	MYSURU	66	HULLAHALLI-KADAKOLA	HULLAHALLI_66HURA_66	10:15	12:17	2:02	NFBC ISSUED
116	3-Feb-22	MYSURU	66	HULLAHALLI-KADAKOLA	HULLAHALLI_66HURA_66	18:29	19:40	1:10	NFBC ISSUED
117	3-Feb-22	MYSURU	66	HV1	BGPURA_66	7:48	10:03	2:14	LINE CLEAR AVALIED
118	3-Feb-22	MYSURU	66	HV1	PERIYAPATNA_66	14:03	15:03	0:59	LINE CLEAR AVALIED
119	3-Feb-22	MYSURU	66	HV1	SHIVALLY_66	16:23	16:55	0:32	LINE CLEAR AVALIED
120	3-Feb-22	MYSURU	66	HV1	SRIRANGAPATNA_66	14:49	16:31	1:42	LINE CLEAR AVALIED
121	3-Feb-22	MYSURU	66	HV2	HDKOTE_66	10:55	18:33	7:38	LINE CLEAR AVALIED
122	3-Feb-22	MYSURU	66	HV2	KADAKOLA_220	14:36	15:16	0:40	LINE CLEAR AVALIED
123	3-Feb-22	MYSURU	66	HV2	KADKOTHANAHALLI_66	13:05	16:15	3:10	LINE CLEAR AVALIED
124	3-Feb-22	MYSURU	66	HV2	KOPPA_66	18:14	18:22	0:08	HAND TRIPPED
125	3-Feb-22	MYSURU	66	HV2	PERIYAPATNA_66	12:14	14:01	1:47	LINE CLEAR AVALIED
126	3-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVALIED
127	3-Feb-22	MYSURU	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66 KALAMANDIRA_66	10:36	10:43	0:07	LINE FAULT
128	3-Feb-22	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	12:48	12:51	0:02	LOAD CHANGE OVER
129	3-Feb-22	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66	10:00	12:22	2:22	LINE CLEAR AVALIED
130	3-Feb-22	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66	17:40	19:25	1:45	LINE CLEAR AVALIED
131	3-Feb-22	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66	10:17	19:39	9:22	NFBC ISSUED
132	3-Feb-22	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	12:48	12:56	0:07	LOAD CHANGE OVER
133	3-Feb-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)	14:25:00 (3.2.2022)	510:25 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
134	3-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
135	3-Feb-22	MYSURU	66	LOKKANAHALLY-P G PALYA	PGPALYA_66	1:00	1:05	0:05	LINE FAULT
136	3-Feb-22	MYSURU	66	LOKKANAHALLY-P G PALYA	PGPALYA_66	4:15	4:20	0:05	LINE FAULT
137	3-Feb-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	11:42	12:07	0:25	LINE FAULT
138	3-Feb-22	MYSURU	66	MUGUR-KUNTHUR	MUGUR_66 THAYURU_66JANNUR_66	11:42	11:52	0:10	LINE FAULT
139	3-Feb-22	MYSURU	66	NANJANGUDU-THANDYA	NO STATIONS EFFECTED	12:48	12:59	0:10	LINE FAULT
140	3-Feb-22	MYSURU	66	SUNTIKOPPA-KUSHALNAGARA	NO STATIONS EFFECTED	11:16:58 (2.2.2022)	17:01:00 (3.2.2022)	29:44 hrs	LINE CHARGED
141	3-Feb-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
142	3-Feb-22	MYSURU	66	TUBINAKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66	12:35	13:00	0:25	LINE CLEAR AVAILED
143	3-Feb-22	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR_66	ANCHEPALYA 66	2:26	2:34	0:08	LINE FAULT
144	3-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	10:25	10:48	0:23	MAIN SUPPLY FAILURE
145	3-Feb-22	TUMKUR	66	BUKKAPATNA-SIRA	BUKKAPATNA_66	11:35	12:10	0:35	LINE FAULT
146	3-Feb-22	TUMKUR	66	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	ANTHRASANAHALLI 66	7:00	17:54	10:53	LINE CLEAR AVAILED
147	3-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE	9:05	9:10	0:05	MAIN SUPPLY FAILURE
148	3-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE	9:32	9:42	0:10	MAIN SUPPLY FAILURE
149	3-Feb-22	TUMKUR	66	HOSAKERE66-CHELUR66	HOSKERE_66	18:00	21:00	3:00	MAIN SUPPLY FAILURE
150	3-Feb-22	TUMKUR	66	KOLALA_66, URDIGERE_66	ANTHRASANAHALLI 66	6:33	6:53	0:20	LINE FAULT
151	3-Feb-22	TUMKUR	66	KORATAGERE66-MADHUGIRI	KORATAGERE_66	16:20	16:25	0:05	MAIN SUPPLY FAILURE
152	3-Feb-22	TUMKUR	66	KORATAGERE66-MADHUGIRI	KORATAGERE_66	12:00	12:10	0:10	MAIN SUPPLY FAILURE
153	3-Feb-22	TUMKUR	66	KUKKAWADA-LINGADAHALLI(HONNALLI)	KUKKAWADA_66	7:30	7:40	0:10	MAIN SUPPLY FAILURE
154	3-Feb-22	TUMKUR	66	PATTNAYAKANAHALLI66-SIRA66	PATANAYAKNAHLI 66	15:40	17:40	2:00	LINE CLEAR AVAILED
155	3-Feb-22	TUMKUR	66	PAVAGADA66-MADHUGIRI66	PAVAGADA_66	14:05	14:10	0:05	LINE FAULT
156	3-Feb-22	TUMKUR	66	PAVAGADA66-MADHUGIRI66	PAVAGADA_66	16:30	16:40	0:10	LINE CLEAR AVAILED
157	3-Feb-22	TUMKUR	66	TR1	JIDDIGERE	14:25	16:35	2:10	TRANSFORMER FAULT
158	3-Feb-22	TUMKUR	66	TR2	HOSAKRE_66	11:55	12:07	0:12	TRANSFORMER FAULT
159	3-Feb-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI	5:25	5:32	0:07	LOAD CURTAILMENT
160	3-Feb-22	TUMKUR	110	NITTUR 220-K G TEMPLE	NITTUR 110	7:20	8:05	0:45	LOAD CURTAILMENT
161	3-Feb-22	TUMKUR	110	TR1	TURUVEKERE 110	9:40	9:46	0:06	TRANSFORMER FAULT
162	3-Feb-22	TUMKUR	220	HONNALLI 220kv-CHANNAGIRI(NALLUR)	HONNALI 220	20:28	20:50	0:22	LINE FAULT
163	3-Feb-22	TUMKUR	220	HONNALLI 220kv-CHANNAGIRI(NALLUR)	HONNALI 220	21:22	21:32	0:10	LINE FAULT
164	3-Feb-22	TUMKUR	220	TR-1	MADHUGIRI 220	13:25	15:40	2:15	LINE CLEAR AVAILED
165	3-Feb-22	TUMKUR	220	TR-2	MADHUGIRI 220	11:55	13:25	1:30	LINE CLEAR AVAILED
1	4-Feb-22	BAGALKOT	110	10/11KV,HV2	KIRUVATT_110	17:54	18:47	0:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
2	4-Feb-22	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	6:46	9:03	2:17	MAIN SUPPLY FAILURE
3	4-Feb-22	BAGALKOT	110	110/11KV, HV2	KATARKI_110	13:00	15:50	2:50	TRANSFORMER FAULT
4	4-Feb-22	BAGALKOT	110	110/11KV,HV	BENAKATTI_110	6:48	9:00	2:12	TRANSFORMER FAULT
5	4-Feb-22	BAGALKOT	110	110/11KV,HV1	BELGAUM_110	12:08	15:38	3:30	LINE CLEAR AVAILED
6	4-Feb-22	BAGALKOT	110	110/11KV,HV1	HIDIKAL DAM_110	10:00	19:08	9:08	LINE CLEAR AVAILED
7	4-Feb-22	BAGALKOT	110	110/11KV,HV1	SULTANPUR_110	11:06	11:41	0:35	LINE CLEAR AVAILED
8	4-Feb-22	BAGALKOT	110	110/11KV,HV1	UKKALI_110	8:31	10:02	1:31	LINE CLEAR AVAILED
9	4-Feb-22	BAGALKOT	110	110/11KV,HV1&HV2	GOPANAKOPPA_110	10:06	17:02	6:56	LINE CLEAR AVAILED
10	4-Feb-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	4:07	4:08	0:01	TRANSFORMER FAULT
11	4-Feb-22	BAGALKOT	110	110/11KV,HV2	BELGAUM_110	15:46	18:10	2:24	LINE CLEAR AVAILED
12	4-Feb-22	BAGALKOT	110	110/11KV,HV2	THORVI_110	16:15	17:27	1:12	LINE CLEAR AVAILED
13	4-Feb-22	BAGALKOT	110	110/33KV, HV-4	NANDIKURLI_33 STATION NOT AFFECTED ANKALI_110	9:15	9:40	0:25	TRANSFORMER FAULT
14	4-Feb-22	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
15	4-Feb-22	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
16	4-Feb-22	BAGALKOT	110	BAGALKOT-RAMDURG1	STATION NOT AFFECTED BAGALKOT_220	8:03	8:08	0:05	LINE CLEAR AVAILED
17	4-Feb-22	BAGALKOT	110	BAGALKOT-RAMDURG2	STATION NOT AFFECTED BAGALKOT_220	10:47	10:49	0:02	LINE CLEAR AVAILED
18	4-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
19	4-Feb-22	BAGALKOT	110	GARAG- KITTUR	KITTUR_110	12:45	19:04	6:19	LINE FAULT
20	4-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
21	4-Feb-22	BAGALKOT	110	HIREBEVANUR-RODAGI (INDI- LACHYAN)	RODAGI_110	15:46	15:49	0:03	HAND TRIPPED
22	4-Feb-22	BAGALKOT	110	KIRUVATTI-UMACHAGI	UMACHAGI_110	17:54	19:13	1:19	LINE CLEAR AVAILED
23	4-Feb-22	BAGALKOT	110	MRUTYUNJANAGAR- GOPANAKOPPA	MRUTYUNJAYANAGAR_110	13:29	15:41	2:12	LOAD CHANGE OVER
24	4-Feb-22	BAGALKOT	110	MRUTYUNJANAGAR-UAS DHARWAD(NARENDRA)	MRUTYUNJAYANAGAR_110	8:33	13:29	4:56	LOAD CHANGE OVER
25	4-Feb-22	BAGALKOT	110	NARENDRA220-UAS DHARWAD	UAS DHARWAD_110	7:58	13:34	5:36	LINE FAULT
26	4-Feb-22	BAGALKOT	110	SIRSI220-KAVALAWADA	KAVALAWADA_110	10:28	10:41	0:13	HAND TRIPPED
27	4-Feb-22	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	9:35	9:40	0:05	LOAD CHANGE OVER
28	4-Feb-22	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	9:35	9:40	0:05	LOAD CHANGE OVER
29	4-Feb-22	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	14:07	14:11	0:04	HAND TRIPPED
30	4-Feb-22	BAGALKOT	110	SOUDATTI220- RAMADURGA-1	RAMADURG_110	6:46	10:52	4:07	LINE FAULT
31	4-Feb-22	BAGALKOT	110	SOUDATTI220-BENAKATTI	BENAKATTI_110	6:46	8:54	2:08	MAIN SUPPLY FAILURE
32	4-Feb-22	BAGALKOT	110	SOUDATTI220-MMCL	MMCL IPP_110 SOUNDATTI_220	6:46	9:05	2:19	MAIN SUPPLY FAILURE
33	4-Feb-22	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	6:46	8:58	2:12	LINE FAULT
34	4-Feb-22	BAGALKOT	110	SOUDATTI220-RAMADURGA-2	RAMADURG_110	6:46	10:53	4:08	LINE FAULT
35	4-Feb-22	BAGALKOT	110	SOUDATTI220-SAUNDATTI-1	SOUDATTI_110	6:46	9:00	2:14	MAIN SUPPLY FAILURE
36	4-Feb-22	BAGALKOT	110	SOUDATTI220-SAUNDATTI-2	SOUDATTI_110	6:46	9:00	2:14	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
37	4-Feb-22	BAGALKOT	110	SLOUDATTI220-UDAKERI	UDAKERI_110	6:46	9:20	2:34	MAIN SUPPLY FAILURE
38	4-Feb-22	BAGALKOT	110	UAS DHARWAD-MRUTYUNJAYANAGAR	MRUTYUNJAYANAGAR_110	8:00	13:23	5:23	LINE FAULT
39	4-Feb-22	BAGALKOT	110	UMACHAGI-KIRUVATTI	KIRUVATTI_110	14:16	19:12	4:56	LINE CLEAR AVAILED
40	4-Feb-22	BAGALKOT	220	220/110KV, HV-1	SLOUDATTI_220	6:46	8:40	1:54	MAIN SUPPLY FAILURE
41	4-Feb-22	BAGALKOT	220	220/110KV, HV-1 & LV-1	CHIKKODI_220	10:25	12:35	2:10	LINE CLEAR AVAILED
42	4-Feb-22	BAGALKOT	220	220/110KV, HV-2	SLOUDATTI_220	6:46	8:40	1:54	MAIN SUPPLY FAILURE
43	4-Feb-22	BAGALKOT	220	220/110KV,HV3&LV3	KUDACHI_220	12:12	13:48	1:36	LINE CLEAR AVAILED
44	4-Feb-22	BAGALKOT	220	AMBEWADI220-AP - 1	STATION NOT AFFECTED AMBEWADI_220	12:03	16:42	4:39	LINE CLEAR AVAILED
45	4-Feb-22	BAGALKOT	220	AMBEWADI220-AP - 2	STATION NOT AFFECTED AMBEWADI_220	12:06	16:54	4:48	LINE CLEAR AVAILED
46	4-Feb-22	BAGALKOT	220	BAGALKOT - ALAMATTI-2	STATION NOT AFFECTED BAGALKOT_220	15:55	0:00	8:05	LINE CLEAR AVAILED
47	4-Feb-22	BAGALKOT	220	BIDNAL-SLOUDATTI	BIDNAL_220	6:48	8:30	1:42	LINE FAULT
48	4-Feb-22	BAGALKOT	220	BIDNAL-SLOUDATTI	BIDNAL_220	16:03	18:03	2:00	LINE CLEAR AVAILED
49	4-Feb-22	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
50	4-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
51	4-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
52	4-Feb-22	BAGALKOT	220	NARENDRA220-TADASINAKOPPA	TADASINAKOPPA_110	5:53	6:40	0:47	LINE FAULT
53	4-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
54	4-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
55	4-Feb-22	BAGALKOT	220	SLOUDATTI- BIDNAL LINE	SLOUDATTI_220	6:46	8:33	1:47	LINE FAULT
56	4-Feb-22	BAGALKOT	220	SLOUDATTI -MAHALINGAPUR	SLOUDATTI_220	2:46	11:12	8:26	LINE FAULT
57	4-Feb-22	BAGALKOT	220	SLOUDATTI-BIDNAL LINE	SLOUDATTI_220	16:01	18:03	2:02	NFBC ISSUED
58	4-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
59	4-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
60	4-Feb-22	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	15:07	15:12	0:05	LOAD CHANGE OVER
61	4-Feb-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	13:12	13:15	0:03	LOAD CHANGE OVER
62	4-Feb-22	BENGALURU	66	CESSSNA - HAL 220	CESSNA, EXORA	16:35	16:45	0:10	LOAD CHANGE OVER
63	4-Feb-22	BENGALURU	66	CESSSNA - HSR LAYOUT 220	CESSNA, EXORA	14:15	14:35	0:20	MAIN SUPPLY FAILURE
64	4-Feb-22	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	7:58	8:06	0:08	LOAD CHANGE OVER
65	4-Feb-22	BENGALURU	66	CHELUR - ES SUN POWER (IPP)	NO STATIONS AFFECTED	7:18	7:35	0:17	LINE FAULT
66	4-Feb-22	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	9:55	17:15	7:20	LINE CLEAR AVAILED
67	4-Feb-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	9:47	9:50	0:03	LOAD CHANGE OVER
68	4-Feb-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	17:09	17:13	0:04	LOAD CHANGE OVER
69	4-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB2	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	2:43	2:55	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
70	4-Feb-22	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	6:58	7:20	0:22	MAIN SUPPLY FAILURE
71	4-Feb-22	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	7:38	7:40	0:02	LOAD CHANGE OVER
72	4-Feb-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	6:58	7:40	0:42	LINE CLEAR AVAIED
73	4-Feb-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	6:58	7:30	0:32	LINE CLEAR AVAIED
74	4-Feb-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	19:50	22:35	2:45	LINE FAULT
75	4-Feb-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	6:58	7:30	0:32	LINE CLEAR AVAIED
76	4-Feb-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:58	7:40	0:42	LINE CLEAR AVAIED
77	4-Feb-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	12:38	13:11	0:33	LINE CLEAR AVAIED
78	4-Feb-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	12:38	13:11	0:33	LINE CLEAR AVAIED
79	4-Feb-22	BENGALURU	66	HV1	AREHALLI	11:45	11:47	0:02	LINE CLEAR AVAIED
80	4-Feb-22	BENGALURU	66	HV1	HOSKOTE 220	3:23(03/02/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
81	4-Feb-22	BENGALURU	66	HV1	HOSUR RAMAPURA	11:00	12:00	1:00	LINE CLEAR AVAIED
82	4-Feb-22	BENGALURU	66	HV1	MITTEMARI 220	11:45	13:10	1:25	MAIN SUPPLY FAILURE
83	4-Feb-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	12:28	12:42	0:14	LINE CLEAR AVAIED
84	4-Feb-22	BENGALURU	66	HV2	AREHALLI	11:49	11:51	0:02	LINE CLEAR AVAIED
85	4-Feb-22	BENGALURU	66	HV2	MITTEMARI 220	11:45	13:10	1:25	MAIN SUPPLY FAILURE
86	4-Feb-22	BENGALURU	66	HV2	SARJAPURA 220	2:51	3:07	0:16	TRANSFORMER FAULT
87	4-Feb-22	BENGALURU	66	HV2	TEKAL	9:15	9:24	0:09	TRANSFORMER FAULT
88	4-Feb-22	BENGALURU	66	HV3	HSR LAYOUT 220	10:16	10:29	0:13	LOAD CHANGE OVER
89	4-Feb-22	BENGALURU	66	HV3	HSR LAYOUT 220	7:07	7:13	0:06	LOAD CHANGE OVER
90	4-Feb-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	4:33	4:45	0:12	LINE FAULT
91	4-Feb-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	5:20	5:32	0:12	LINE FAULT
92	4-Feb-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	5:51	9:10	3:19	LINE CLEAR AVAIED
93	4-Feb-22	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	11:45	13:10	1:25	MAIN SUPPLY FAILURE
94	4-Feb-22	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	14:05	14:10	0:05	LOAD CHANGE OVER
95	4-Feb-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	11:45	13:10	1:25	MAIN SUPPLY FAILURE
96	4-Feb-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	11:45	13:10	1:25	MAIN SUPPLY FAILURE
97	4-Feb-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	11:45	13:10	1:25	MAIN SUPPLY FAILURE
98	4-Feb-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	11:45	13:10	1:25	MAIN SUPPLY FAILURE
99	4-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
100	4-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	7:18	7:25	0:06	LINE FAULT
101	4-Feb-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	5:30	5:35	0:05	LOAD CHANGE OVER
102	4-Feb-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	0:53	1:15	0:22	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
103	4-Feb-22	BENGALURU	66	SRS PEENYA 220 - BYDRAHALLI	BYDRAHALLI, KODIGEHALI, SRIGANDAKAVALU	0:52	1:22	0:30	MAIN SUPPLY FAILURE
104	4-Feb-22	BENGALURU	66	SRS PEENYA 220 - BYDRAHALLI	BYDRAHALLI, KODIGEHALI, SRIGANDAKAVALU	5:50	5:53	0:03	LOAD CHANGE OVER
105	4-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	10:26	13:23	2:57	LINE FAULT
106	4-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	16:42	17:27	0:45	LINE FAULT
107	4-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	18:00	19:39	1:39	LINE FAULT
108	4-Feb-22	BENGALURU	66	T K HALLI 220 - EBBANI	NO STATION AFFECTED	13:31	13:40	0:09	LINE FAULT
109	4-Feb-22	BENGALURU	220	HOSKOTE 220 - KIADB 2 220	HOSKOTE 220	6:58	7:25	0:27	LINE FAULT
110	4-Feb-22	BENGALURU	220	HV1	HOSKOTE 220	6:58	7:35	0:37	LINE CLEAR AVOIDED
111	4-Feb-22	BENGALURU	220	HV2	HOSKOTE 220	6:58	7:29	0:31	LINE CLEAR AVOIDED
112	4-Feb-22	BENGALURU	220	HV3	SRS PEENYA 220	0:52	2:56	2:04	TRANSFORMER FAULT
113	4-Feb-22	BENGALURU	220	LV3	MITTEMARI 220	11:45	13:05	1:20	TRANSFORMER FAULT
114	4-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
115	4-Feb-22	GULBARGA	66	HV1	ITTAGI_220	12:50	13:50	1:00	TRANSFORMER FAULT
116	4-Feb-22	GULBARGA	66	HV2	TAMBRAHALI_66	5:30	5:35	0:05	TRANSFORMER FAULT
117	4-Feb-22	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,M AGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	11:02	14:25	3:23	LINE CLEAR AVOIDED
118	4-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110,JAWALGERA_110	23:05	23:16	0:11	MAIN SUPPLY FAILURE
119	4-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110,JAWALGERA_110	23:29	23:51	0:22	MAIN SUPPLY FAILURE
120	4-Feb-22	GULBARGA	110	HUNSAGI-KEMBHAVI	HUNSAGI_110	21:25	21:35	0:10	MAIN SUPPLY FAILURE
121	4-Feb-22	GULBARGA	110	HV1	KUSTAGI_220	8:10	8:27	0:17	TRANSFORMER FAULT
122	4-Feb-22	GULBARGA	110	HV1	MASKI_110	10:27	10:41	0:14	LINE CLEAR AVOIDED
123	4-Feb-22	GULBARGA	110	HV2	HARAPANAHALI_66	7:05	7:10	0:05	TRANSFORMER FAULT
124	4-Feb-22	GULBARGA	110	HV2	KUSTAGI_220	14:15	14:30	0:15	TRANSFORMER FAULT
125	4-Feb-22	GULBARGA	110	KAMALAPUR-MUNIRABAD	KAMALAPUR_110	2:00	6:40	0:10	MAIN SUPPLY FAILURE
126	4-Feb-22	GULBARGA	110	KUDLIGI-CHORNOOR	CHORNOOR_66	23:30	23:40	0:10	LINE FAULT
127	4-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:30	16:00	5:30	LOAD CHANGE OVER
128	4-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	23:30			LINE OPEN:LINE FAULT
129	4-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	23:06	23:16	0:10	LINE FAULT
130	4-Feb-22	GULBARGA	110	PDHALLI-CLNMAX	PD_HALLI_110	11:28	11:40	0:12	LINE FAULT
131	4-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
132	4-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:10	21:17	1:00	LOAD CURTAILMENT
133	4-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:04	22:07	1:00	LOAD CURTAILMENT
134	4-Feb-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	9:40	0.8	9:32	LINE CLEAR AVOIDED
135	4-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
136	4-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:29 (04.02.2022)			LINE OPEN:LINE CLEAR AVOIDED
137	4-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	16:11 (03.02.2022)	9:08 (04.02.2022)	16:57 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
138	4-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERD ONA_110,SRNAGAR_110,MALLAPU RA_110	4:15	4:25	0:10	LINE FAULT
139	4-Feb-22	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	0:15	2:30	2:15	LINE FAULT
140	4-Feb-22	GULBARGA	110	TEKKALKOTE-KURUGOD	TEKKALKOTE_110	0:15	0:25	0:10	MAIN SUPPLY FAILURE
141	4-Feb-22	GULBARGA	110	TEKKALKOTE-KURUGOD	TEKKALKOTE_110	0:30	0:38	0:08	MAIN SUPPLY FAILURE
142	4-Feb-22	GULBARGA	110	TEKKALKOTE-RENEW_SLR	TEKKALKOTE_110	1:50	2:38	0:48	LINE CLEAR AVAILED
143	4-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
144	4-Feb-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	10:52	12:55	2:03	LINE CLEAR AVAILED
145	4-Feb-22	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	14:04	15:17	1:13	LINE CLEAR AVAILED
146	4-Feb-22	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	7:05	7:20	0:15	LINE FAULT
147	4-Feb-22	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	22:01	23:00	0:59	HAND TRIPPED
148	4-Feb-22	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	2:00	22:54	20:54	HAND TRIPPED
149	4-Feb-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	22:00	22:53	0:53	HAND TRIPPED
150	4-Feb-22	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	22:00	22:55	0:55	HAND TRIPPED
151	4-Feb-22	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	22:00	22:52	0:52	HAND TRIPPED
152	4-Feb-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	22:00	22:58	0:58	HAND TRIPPED
153	4-Feb-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	22:01	22:59	0:58	HAND TRIPPED
154	4-Feb-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	21:59	22:56	0:57	HAND TRIPPED
155	4-Feb-22	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	21:59	22:56	0:57	HAND TRIPPED
156	4-Feb-22	HASSAN	66	HV1	BALEHONNUR_66	8:38	8:51	0:13	HAND TRIPPED
157	4-Feb-22	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:21	12:39	0:18	LINE CLEAR AVAILED
158	4-Feb-22	HASSAN	66	HV1	HANBALU_66	14:04	15:17	1:13	LINE CLEAR AVAILED
159	4-Feb-22	HASSAN	66	HV1	HNPURA_66	21:55	22:53	0:58	MAIN SUPPLY FAILURE
160	4-Feb-22	HASSAN	66	HV1	HOLENARASIPURA_220	22:05	22:51	0:46	HAND TRIPPED
161	4-Feb-22	HASSAN	66	HV1	NAGARTHI_66	21:55	23:00	1:05	MAIN SUPPLY FAILURE
162	4-Feb-22	HASSAN	66	HV1	SALGAME_66	12:33	15:00	2:27	LINE CLEAR AVAILED
163	4-Feb-22	HASSAN	66	HV1	YESLUR_66	7:06	7:21	0:15	HAND TRIPPED
164	4-Feb-22	HASSAN	66	HV2	HNPURA_66	21:55	22:53	0:58	MAIN SUPPLY FAILURE
165	4-Feb-22	HASSAN	66	HV4	BALEHONNUR_66	8:48 (2.02.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
166	4-Feb-22	HASSAN	66	MATTNNAV-DIDGTHL	MATTANAVILE_66	15:57	16:07	0:10	LINE FAULT
167	4-Feb-22	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:33	9:48	0:15	HAND TRIPPED
168	4-Feb-22	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:33	9:47	0:14	HAND TRIPPED
169	4-Feb-22	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	14:05	14:10	0:05	HAND TRIPPED
170	4-Feb-22	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	14:49	14:56	0:07	HAND TRIPPED
171	4-Feb-22	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:44	10:47	0:03	LOAD CHANGE OVER
172	4-Feb-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	11:26	14:09	2:43	LINE CLEAR AVAILED
173	4-Feb-22	HASSAN	110	HV1	KONAJE_110	12:22	12:26	0:04	LOAD CHANGE OVER
174	4-Feb-22	HASSAN	110	HV1	KONAJE_110	16:54	17:00	0:06	LOAD CHANGE OVER
175	4-Feb-22	HASSAN	110	HV1	SALATHUR_110	10:10	13:30	3:20	LINE CLEAR AVAILED
176	4-Feb-22	HASSAN	110	HV1	SALATHUR_110	14:10	16:49	2:39	LINE CLEAR AVAILED
177	4-Feb-22	HASSAN	110	HV2	KONAJE_110	12:21	12:27	0:06	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
178	4-Feb-22	HASSAN	110	HV2	KONAJE_110	16:54	17:01	0:07	LOAD CHANGE OVER
179	4-Feb-22	HASSAN	110	HV3	KONAJE_110	12:22	12:26	0:04	LOAD CHANGE OVER
180	4-Feb-22	HASSAN	110	HV3	KONAJE_110	16:54	17:00	0:06	LOAD CHANGE OVER
181	4-Feb-22	HASSAN	110	HV3	PUTTUR_110	1:03	1:13	0:10	TRANSFORMER FAULT
182	4-Feb-22	HASSAN	110	HV3	PUTTUR_110	1:42	1:47	0:05	TRANSFORMER FAULT
183	4-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE FAULT
184	4-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
185	4-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
186	4-Feb-22	HASSAN	110	JOG-NK2	mghejog_gen	11:5104.02.2022)			LINE OPEN:LINE CLEAR AVAILED
187	4-Feb-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)	10:16(04.02.2022)	910:57HRS	LINE CHARGED
188	4-Feb-22	HASSAN	110	KAVOOR-AMR	KAVOOR_220	10:45	10:50	0:05	LOAD CHANGE OVER
189	4-Feb-22	HASSAN	110	KEMAR-BELMAN	KEMAR_220	10:31	11:39	1:08	LINE CLEAR AVAILED
190	4-Feb-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:26	14:09	2:43	LINE CLEAR AVAILED
191	4-Feb-22	HASSAN	110	LV1	MRSMSG_220	9:33	9:42	0:09	HAND TRIPPED
192	4-Feb-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:23	15:14	4:51	LOAD CHANGE OVER
193	4-Feb-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
194	4-Feb-22	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	9:33	9:45	0:12	HAND TRIPPED
195	4-Feb-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	9:38	10:00	0:22	HAND TRIPPED
196	4-Feb-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	10:19	10:29	0:10	HAND TRIPPED
197	4-Feb-22	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	9:33	9:46	0:13	HAND TRIPPED
198	4-Feb-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	12:29	14:01	1:32	LINE CLEAR AVAILED
199	4-Feb-22	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	14:02	16:46	2:44	LINE CLEAR AVAILED
200	4-Feb-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	22:14	22:22	0:08	LINE FAULT
201	4-Feb-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	14:56	16:06	1:10	LINE CLEAR AVAILED
202	4-Feb-22	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	21:57	22:44	0:47	LINE FAULT
203	4-Feb-22	HASSAN	220	GOPALAP-HNPUR21	GOPALPURA_220	21:57	22:48	0:51	LINE FAULT
204	4-Feb-22	HASSAN	220	GOPALAP-HNPUR22	GOPALPURA_220	2:57	22:50	19:53	LINE FAULT
205	4-Feb-22	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	21:57(04.02.2022)			LINE OPEN:LINE FAULT
206	4-Feb-22	HASSAN	220	HV1	MRSMSG_220	9:33	9:40	0:07	TRANSFORMER FAULT
207	4-Feb-22	HASSAN	220	KADUR-DABUSET	KADUR_220	9:42	10:09	0:27	LINE FAULT
208	4-Feb-22	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:42	14:04	2:22	LINE CLEAR AVAILED
209	4-Feb-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:42	14:04	2:22	LINE CLEAR AVAILED
210	4-Feb-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
211	4-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
212	4-Feb-22	MYSURU	66	HEBBANI-T K HALLI	NO STATIONS EFFECTED	13:31	13:40	0:09	LINE FAULT
213	4-Feb-22	MYSURU	66	HV1	BEGUR_66	11:50	12:30	0:40	LINE CLEAR AVAILED
214	4-Feb-22	MYSURU	66	HV1	BHARGI_66	10:00	10:40	0:40	TRANSFORMER FAULT
215	4-Feb-22	MYSURU	66	HV1	COWDALLI_66	18:58	19:35	0:37	TRANSFORMER FAULT
216	4-Feb-22	MYSURU	66	HV1	HALAGUR_66	7:25	8:25	1:00	HAND TRIPPED
217	4-Feb-22	MYSURU	66	HV1	HARADANAHALLI_66	21:55	22:50	0:55	HAND TRIPPED
218	4-Feb-22	MYSURU	66	HV1	KADABALLY_66	16:00	16:10	0:10	HAND TRIPPED
219	4-Feb-22	MYSURU	66	HV1	KADKOTHANAHALLI_66	7:20	7:40	0:20	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
220	4-Feb-22	MYSURU	66	HV1	KADKOTHANAHALLI_66	13:10	13:55	0:45	LINE CLEAR AVAIED
221	4-Feb-22	MYSURU	66	HV2	BEGUR_66	12:30	13:02	0:32	LINE CLEAR AVAIED
222	4-Feb-22	MYSURU	66	HV2	BILIKERE_66	11:35	11:55	0:19	TRANSFORMER FAULT
223	4-Feb-22	MYSURU	66	HV2	DEVANOORNGUDU_66	11:35	13:05	1:30	LINE CLEAR AVAIED
224	4-Feb-22	MYSURU	66	HV2	K_HONNALGERE_66	11:21	12:42	1:20	LINE CLEAR AVAIED
225	4-Feb-22	MYSURU	66	HV2	MADIKERI_66	16:03	17:58	1:54	LINE CLEAR AVAIED
226	4-Feb-22	MYSURU	66	HV2	MANDYA_66	14:13	14:20	0:07	TRANSFORMER FAULT
227	4-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAIED
228	4-Feb-22	MYSURU	66	KIADB SOMANAHALLI-MADDUR	SOMANAHALLI_66	8:45	9:08	0:23	LINE FAULT
229	4-Feb-22	MYSURU	66	KK HALLI-SHIMSHA	KADKOTHANAHALLI_66 MALAVALLI_66HADLI_66	14:45	16:25	1:40	LINE CLEAR AVAIED
230	4-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAIED
231	4-Feb-22	MYSURU	66	MANDGERE-HV1	MANDGERE_66	21:55	23:00	1:05	HAND TRIPPED
232	4-Feb-22	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	12:00	12:08	0:08	HAND TRIPPED
233	4-Feb-22	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	SUNTIKOPPA_66	11:26	11:48	0:21	LINE CLEAR AVAIED
234	4-Feb-22	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	11:20	11:55	0:35	LINE CLEAR AVAIED
235	4-Feb-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAIED
236	4-Feb-22	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	6:13	16:08	9:54	LINE FAULT
237	4-Feb-22	TUMKUR	66	BRAHMASANDRA- SIRA(ANKASANDRA)	BRAHMASANDRA_66	6:49	7:40	0:50	LINE FAULT
238	4-Feb-22	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	11:54	12:25	0:31	HAND TRIPPED
239	4-Feb-22	TUMKUR	66	H D PURA- SUZLON_IPP_66	SUZLON_IPP_66	6:18	6:42	0:24	HAND TRIPPED
240	4-Feb-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	13:10	13:21	0:10	LINE FAULT
241	4-Feb-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:19	14:41	0:22	LINE FAULT
242	4-Feb-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:19	16:32	0:12	LINE FAULT
243	4-Feb-22	TUMKUR	66	PAVAGADA66-MADHUGIRI66	PAVAGADA_66	13:47	13:52	0:05	LINE FAULT
244	4-Feb-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	13:47	14:00	0:12	LINE FAULT
245	4-Feb-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	18:30	21:25	2:55	LINE CLEAR AVAIED
246	4-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR_IPP_66	14:14	14:21	0:06	HAND TRIPPED
247	4-Feb-22	TUMKUR	66	THERIYUR66-PAVAGADA66	THERIYUR_66	15:24	21:20	5:56	LINE CLEAR AVAIED
248	4-Feb-22	TUMKUR	66	TR-1	KADAJJI_66	11:12	16:07	4:54	LINE CLEAR AVAIED
249	4-Feb-22	TUMKUR	66	TR-2	BEVINAHALLI_66	8:19	8:54	0:35	LINE CLEAR AVAIED
250	4-Feb-22	TUMKUR	66	TR-2	KADAJJI_66	11:12	16:07	4:54	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
251	4-Feb-22	TUMKUR	66	TR-2	KADAJJI_66	21:04	21:07	0:03	TRANSFORMER FAULT
252	4-Feb-22	TUMKUR	66	TR-2	KADAJJI_66	23:03	23:13	0:09	TRANSFORMER FAULT
253	4-Feb-22	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	11:25	12:05	0:40	TRANSFORMER FAULT
254	4-Feb-22	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	13:28	13:40	0:12	TRANSFORMER FAULT
255	4-Feb-22	TUMKUR	110	TR-2	NIITUR_110	11:47	17:34	5:47	LINE CLEAR AVAIED
256	4-Feb-22	TUMKUR	110	TR-2	NIITUR_110	17:36	17:59	0:23	TRANSFORMER FAULT
257	4-Feb-22	TUMKUR	110	TR-2	KBCROSS_220	10:35	15:34	4:59	LINE CLEAR AVAIED
258	5-Feb-22	BAGALKOT	110	110/11 KV HV2	STATION NOT AFFECTED MUNDAGOD_110	17:07	17:42	0:35	LINE CLEAR AVAIED
259	5-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MANTUR_110	13:25	13:35	0:10	LINE CLEAR AVAIED
260	5-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NANADI_110	5:51	9:09	3:18	TRANSFORMER FAULT
261	5-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TAKKALAKI_110	12:18	12:31	0:13	TRANSFORMER FAULT
262	5-Feb-22	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	11:05	12:33	1:28	LINE CLEAR AVAIED
263	5-Feb-22	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	14:00	15:35	1:35	LINE CLEAR AVAIED
264	5-Feb-22	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	10:51	19:00	8:09	LINE CLEAR AVAIED
265	5-Feb-22	BAGALKOT	110	110/11KV,HV2	KIRUUVATTI_110	10:15	11:17	1:02	LINE CLEAR AVAIED
266	5-Feb-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	12:22	15:43	3:21	LINE CLEAR AVAIED
267	5-Feb-22	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)			LINE OPEN:LINE CLEAR AVAIED
268	5-Feb-22	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)			LINE OPEN:LINE CLEAR AVAIED
269	5-Feb-22	BAGALKOT	110	BIDNAL220-MUNDARGI	MUNDARGI_110	6:30	13:00	6:30	LINE FAULT
270	5-Feb-22	BAGALKOT	110	BILGI-SIRAGUPPI	SIRAGUPPI_110,BILAGI_110,GIRISA GAR_110, BISNAL_110,TOLAMATTI_110	12:15	12:25	0:10	LINE FAULT
271	5-Feb-22	BAGALKOT	110	CHIKKODI- SADALAGA	SADALAGA_110	6:35	9:40	3:05	LINE FAULT
272	5-Feb-22	BAGALKOT	110	CHIKKODI-KADAKLAT	KADAKLAT_110	3:18	9:17	5:59	LINE FAULT
273	5-Feb-22	BAGALKOT	110	CHKKODI220-RAIBAG-2	STATION NOT AFFECTED CHIKKODI_220	8:06	12:25	4:19	LINE FAULT
274	5-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAIED
275	5-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAIED
276	5-Feb-22	BAGALKOT	110	KATARKI-VAJRAMATTI	KATARKI_110	12:15	12:30	0:15	LINE FAULT
277	5-Feb-22	Bagalkot	110	MUNDARAGI-SINGATALURU	MUNDARGI_110	6:30	7:00	0:30	LINE FAULT
278	5-Feb-22	BAGALKOT	110	MUNDARAGI-SINGATALURU	MUNDARGI_110	7:10	13:00	5:50	LINE CLEAR AVAIED
279	5-Feb-22	BAGALKOT	110	MUNDARAGI-SINGATALURU	SINGATALUR_110	7:10	13:10	6:00	MAIN SUPPLY FAILURE
280	5-Feb-22	BAGALKOT	110	MUNDARGI-VIJAYA SUGARS	VIJAYA SUGARS_110 STATION NOT AFFECTED MUNDARGI_110	6:24	7:21	0:57	LINE FAULT
281	5-Feb-22	BAGALKOT	110	SADALAGA-CHIKKODI220	SADALAGA_110	6:36	9:40	3:04	LINE FAULT
282	5-Feb-22	BAGALKOT	110	TADASINAKOPPA-KIADB GAMANAGATTI	STATION NOT AFFECTED TADASINAKOPPA_110	13:14 (04.02.2022)	14:50 (05.02.2022)	25:40 hrs	LINE CLEAR AVAIED
283	5-Feb-22	BAGALKOT	110	TODALABAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUAGRS_110 STATION NOT AFFECTED TODALBAGI_110	17:15	17:21	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
284	5-Feb-22	BAGALKOT	110	VSPL-MUNDARGI	MUNDARGI_110	6:30	7:45	1:15	LINE FAULT
285	5-Feb-22	BAGALKOT	110	YALLAMMANAWADI-ALBAL	ALBAL_110	17:15	17:29	0:14	LINE FAULT
286	5-Feb-22	BAGALKOT	220	220/110 HV1,LV1	STATON NOT EFFECTED KARWAR_220	11:25	12:55	1:30	LINE CLEAR AVAILED
287	5-Feb-22	BAGALKOT	220	220/110 HV3,LV3	STATON NOT EFFECTED HUBLI_220	15:59	16:33	0:34	LINE CLEAR AVAILED
288	5-Feb-22	BAGALKOT	220	BAGALKOT - ALAMATTI-2	STATION NOT AFFECTED BAGAKOT_220	3:45 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
289	5-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
290	5-Feb-22	BAGALKOT	220	CHIKKODI-GHATAPRABHA2(KUDCHI-2)	STATON NOT EFFECTED CHIKKODI_220	7:32	9:36	2:04	LINE FAULT
291	5-Feb-22	BAGALKOT	220	CHIKKODI-KUDCHI-1	STATION NOT AFFECTED CHIKKODI_220	7:09	9:35	2:26	LINE FAULT
292	5-Feb-22	BAGALKOT	220	ENERCON SOLAR-VAJRAMATTI	STATION NOT AFFECTED VAJRAMATTI_220	18:55	23:33	4:38	LINE CLEAR AVAILED
293	5-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
294	5-Feb-22	BAGALKOT	220	KUDUCH-CHIKKODI1	STATON NOT EFFECTED KUDUCHI_220	7:08	9:35	2:27	LINE FAULT
295	5-Feb-22	BAGALKOT	220	KUDUCH-CHIKKODI2	STATON NOT EFFECTED KUDUCHI_220	7:35	9:42	2:07	LINE FAULT
296	5-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
297	5-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
298	5-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
299	5-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
300	5-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
301	5-Feb-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	19:06	19:13	0:07	LOAD CHANGE OVER
302	5-Feb-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	5:20	5:27	0:06	LINE FAULT
303	5-Feb-22	BENGALURU	66	DODALAHALLI - KANAKPURA 220	DODALAHALLI	10:47	17:28	6:41	LINE CLEAR AVAILED
304	5-Feb-22	BENGALURU	66	ELECTRONIC CITY P2 S2 - BIOCON (EHT)	BIOCON (EHT)	10:15	20:33	10:18	LINE CLEAR AVAILED
305	5-Feb-22	BENGALURU	66	ELECTRONIC CITY PH-2 SEC- 2 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-2	10:15	18:40	8:25	LINE CLEAR AVAILED
306	5-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	13:09	13:22	0:13	LINE FAULT
307	5-Feb-22	BENGALURU	66	HONNIGANAHALLI - T K HALLI 220	ACHALU, HONNIGANAHALLI, HALAGUR	18:00	18:05	0:05	LOAD CHANGE OVER
308	5-Feb-22	BENGALURU	66	HV1	AMAR JYOTHI	14:20	16:05	1:45	LINE CLEAR AVAILED
309	5-Feb-22	BENGALURU	66	HV1	HANUMANTHAGARA	13:20	13:30	0:10	TRANSFORMER FAULT
310	5-Feb-22	BENGALURU	66	HV1	HOSKOTE 220	3:23(03/02/2022)	18:18(5-2-2022)	62:24 hrs	TRANSFORMER CHARGED
311	5-Feb-22	BENGALURU	66	HV1	KOLAR 220	14:53	15:28	0:35	MAIN SUPPLY FAILURE
312	5-Feb-22	BENGALURU	66	HV1	WEL CAST STEEL	14:10	18:35	4:25	LINE CLEAR AVAILED
313	5-Feb-22	BENGALURU	66	HV2	AMAR JYOTHI	9:50	13:44	3:54	LINE CLEAR AVAILED
314	5-Feb-22	BENGALURU	66	HV2	ANEKAL	5:07	5:13	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
315	5-Feb-22	BENGALURU	66	HV2	AUSTIN TOWN	10:01	10:03	0:02	LINE CLEAR AVOID
316	5-Feb-22	BENGALURU	66	HV2	KOLAR 220	14:53	15:28	0:35	MAIN SUPPLY FAILURE
317	5-Feb-22	BENGALURU	66	HV2	SARJAPURA 220	13:18	14:08	0:50	LINE CLEAR AVOID
318	5-Feb-22	BENGALURU	66	HV2	SARJAPURA 220	4:54	6:53	1:59	TRANSFORMER FAULT
319	5-Feb-22	BENGALURU	66	HV2	WEL CAST STEEL	18:04	19:05	1:00	LINE CLEAR AVOID
320	5-Feb-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	10:05	17:05	7:00	LINE CLEAR AVOID
321	5-Feb-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, ACHALU, HALAGURU, DOODALAHALLI	10:39	10:45	0:06	LINE CLEAR AVOID
322	5-Feb-22	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	15:13	15:29	0:16	MAIN SUPPLY FAILURE
323	5-Feb-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	15:13	15:28	0:15	MAIN SUPPLY FAILURE
324	5-Feb-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	14:01	15:45	1:44	LINE CLEAR AVOID
325	5-Feb-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	15:13	15:29	0:16	MAIN SUPPLY FAILURE
326	5-Feb-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	15:13	15:29	0:16	MAIN SUPPLY FAILURE
327	5-Feb-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	14:48	16:21	1:33	LINE CLEAR AVOID
328	5-Feb-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	16:23	16:27	0:04	LINE CLEAR AVOID
329	5-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
330	5-Feb-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA	9:42	10:22	0:39	LINE FAULT
331	5-Feb-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	12:16	12:21	0:05	LINE FAULT
332	5-Feb-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:45	6:52	0:07	LINE FAULT
333	5-Feb-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	18:40	19:05	0:25	MAIN SUPPLY FAILURE
334	5-Feb-22	BENGALURU	66	SOMAJYANAHALLI - TATA SOLAR(IPP)	NO STATION AFFECTED	12:36	13:09	0:33	LINE CLEAR AVOID
335	5-Feb-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	RR NAGAR, GLOBAL VILLAGE (EHT)	18:40	19:05	0:25	LINE FAULT
336	5-Feb-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:00	11:08	0:08	LINE FAULT
337	5-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	6:54	7:24	0:30	LINE FAULT
338	5-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	6:54	7:19	0:25	LINE FAULT
339	5-Feb-22	BENGALURU	220	HV3	KOLAR 220	14:53	15:26	0:33	MAIN SUPPLY FAILURE
340	5-Feb-22	BENGALURU	220	LV3	KOLAR 220	14:53	15:27	0:34	TRANSFORMER FAULT
341	5-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
342	5-Feb-22	BENGALURU	220	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	7:44	7:53	0:08	LINE FAULT
343	5-Feb-22	GULBARGA	66	HV2	HALAVAGALU_66	7:40	7:45	0:05	TRANSFORMER FAULT
344	5-Feb-22	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	12:18	12:24	0:06	LINE FAULT
345	5-Feb-22	GULBARGA	66	MAGALA-ITTAGGI	MAGALA_66	7:04	8:00	0:56	LINE CLEAR AVOID
346	5-Feb-22	GULBARGA	66	UCHANGIDURGA-BILCHOD	BILCHOD_66	15:00	15:20	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
347	5-Feb-22	GULBARGA	66	UCHCHANGIDURGA-NEELAGUNDA	UCCHANGI DURGA_66	15:00	15:10	0:10	LINE CLEAR AVAILED
348	5-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	ADAVI AMARESHWAR_110	0:14	0:22	0:08	LINE FAULT
349	5-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	ADAVI AMARESHWAR_110	2:39	2:45	0:06	LINE FAULT
350	5-Feb-22	GULBARGA	110	CHILKMUKI-BEVOOR	CHILKMUKI_110	5:00	5:10	0:10	MAIN SUPPLY FAILURE
351	5-Feb-22	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	8:30	8:45	0:15	MAIN SUPPLY FAILURE
352	5-Feb-22	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	17:30	17:40	0:10	MAIN SUPPLY FAILURE
353	5-Feb-22	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	13:44	20:40	6:56	MAIN SUPPLY FAILURE
354	5-Feb-22	GULBARGA	110	HATTI-SINDANOOR	HATTI_110	15:22	17:46	2:24	MAIN SUPPLY FAILURE
355	5-Feb-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_220	18:26	19:39	1:13	LOAD CURTAILMENT
356	5-Feb-22	GULBARGA	110	KAVITAL-SINDANOOR	KAVITAL_110	15:20	17:50	2:30	MAIN SUPPLY FAILURE
357	5-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:08	16:17	6:09	LOAD CHANGE OVER
358	5-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	23:30(04.02.2022)	14:45(05.02.2022)	14:55HRS	LINE CHARGED
359	5-Feb-22	GULBARGA	110	MUNIRABD-HAGARI	SANKLAPURA_110,RBSNN,KAMALA PUR_110	15:27	15:32	0:05	LINE CLEAR AVAILED
360	5-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
361	5-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	6:50	7:43	0:53	LOAD CURTAILMENT
362	5-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	10:18	11:00	0:42	LOAD CURTAILMENT
363	5-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	13:32	14:30	0:58	LOAD CURTAILMENT
364	5-Feb-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	9:18	17:57	8:39	LINE CLEAR AVAILED
365	5-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
366	5-Feb-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBAVI_110,UGAR SUGARS_IPP,HUNASAGI_110	0:04	0:10	0:06	LINE FAULT
367	5-Feb-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBAVI_110,UGAR SUGARS_IPP,HUNASAGI_110	19:39	19:43	0:04	LINE FAULT
368	5-Feb-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:39	4:44	0:05	LINE FAULT
369	5-Feb-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	6:24	6:29	0:05	LINE FAULT
370	5-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:29 (04.02.2022)	8:49 (05.02.2022)	11:20 HRS	LINE CHARGED
371	5-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
372	5-Feb-22	GULBARGA	220	RTPS-LINGASUGUR3	MALLAT_220	3:14	3:40	0:26	LINE FAULT
373	5-Feb-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	3:02	3:13	0:11	LINE FAULT
374	5-Feb-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	0:08	0:16	0:08	LINE FAULT
375	5-Feb-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	0:00	6:37	6:37	LINE CLEAR AVAILED
376	5-Feb-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	11:49	16:29	4:40	LINE CLEAR AVAILED
377	5-Feb-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	17:27	17:34	0:07	LINE FAULT
378	5-Feb-22	HASSAN	66	CRPATNA-SBELAGOLA2	CRPATNA_220	5:36	6:21	0:45	HAND TRIPPED
379	5-Feb-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:50	14:02	2:12	LINE CLEAR AVAILED
380	5-Feb-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:36	14:03	1:27	LINE CLEAR AVAILED
381	5-Feb-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	6:22	6:30	0:08	LINE FAULT
382	5-Feb-22	HASSAN	66	HV1	DODDAHALLY_66	12:37	14:09	1:32	MAIN SUPPLY FAILURE
383	5-Feb-22	HASSAN	66	HV1	HIRESAVE_66	0:15	2:30	2:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
384	5-Feb-22	HASSAN	66	HV1	HIRESAVE_66	6:30	6:45	0:15	LOAD CHANGE OVER
385	5-Feb-22	HASSAN	66	HV1	MALLAPURA_66	15:53	17:33	1:40	LINE CLEAR AVAILED
386	5-Feb-22	HASSAN	66	HV1	MANJUNATHPURA_66	13:21	13:35	0:14	TRANSFORMER FAULT
387	5-Feb-22	HASSAN	66	HV1	NAGARTHI_66	12:36	14:04	1:28	MAIN SUPPLY FAILURE
388	5-Feb-22	HASSAN	66	HV2	SHANTHIGRAMA_66	7:44	9:37	1:53	TRANSFORMER FAULT
389	5-Feb-22	HASSAN	66	HV4	BALEHONNUR_66	8:48 (2.02.2022)	16:45(05.02.2022)	79:57HRS	TRANSFORMER CHARGED
390	5-Feb-22	HASSAN	66	MATTANAV--CRPATNA	MATTANAVILE_66	2:31	6:42	4:11	NFBC ISSUED
391	5-Feb-22	HASSAN	66	MATTANAV-DIDGTHL	MATTANAVILE_66	16:36	16:44	0:08	LINE FAULT
392	5-Feb-22	HASSAN	66	NGRTHI-L1	NAGARTHI_66	12:45	14:04	1:19	MAIN SUPPLY FAILURE
393	5-Feb-22	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	12:13	22:32	10:19	LINE FAULT
394	5-Feb-22	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	13:22	14:40	1:18	MAIN SUPPLY FAILURE
395	5-Feb-22	HASSAN	110	HV1	BAIKAMPADY_110	10:33	12:44	2:11	LINE CLEAR AVAILED
396	5-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE FAULT
397	5-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
398	5-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
399	5-Feb-22	HASSAN	110	JOG-NK2	mghejog_gen	11:5104.02.2022)	16:09(05.02.2022)	844:18HRS	LINE CHARGED
400	5-Feb-22	HASSAN	110	LV1	SHIRALKOPPA_220	14:03	14:19	0:16	TRANSFORMER FAULT
401	5-Feb-22	HASSAN	110	LV1	SHIRALKOPPA_220	14:33	14:44	0:11	TRANSFORMER FAULT
402	5-Feb-22	HASSAN	110	LV1	SHIRALKOPPA_220	14:03	14:19	0:16	TRANSFORMER FAULT
403	5-Feb-22	HASSAN	110	LV2	SHIRALKOPPA_220	14:33	14:44	0:11	TRANSFORMER FAULT
404	5-Feb-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:49	15:05	0:16	HAND TRIPPED
405	5-Feb-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	16:34	16:54	0:20	HAND TRIPPED
406	5-Feb-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
407	5-Feb-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	14:05	14:25	0:20	LINE FAULT
408	5-Feb-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	14:30	14:45	0:15	LINE FAULT
409	5-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:03	14:22	0:19	MAIN SUPPLY FAILURE
410	5-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:33	14:47	0:14	MAIN SUPPLY FAILURE
411	5-Feb-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:03	14:21	0:18	MAIN SUPPLY FAILURE
412	5-Feb-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:33	15:14	0:41	MAIN SUPPLY FAILURE
413	5-Feb-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:03	14:20	0:17	MAIN SUPPLY FAILURE
414	5-Feb-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:33	14:44	0:11	MAIN SUPPLY FAILURE
415	5-Feb-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:03	14:27	0:24	MAIN SUPPLY FAILURE
416	5-Feb-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:32	14:47	0:15	MAIN SUPPLY FAILURE
417	5-Feb-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:03	14:23	0:20	MAIN SUPPLY FAILURE
418	5-Feb-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:33	14:54	0:21	MAIN SUPPLY FAILURE
419	5-Feb-22	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	13:21	14:38	1:17	LINE FAULT
420	5-Feb-22	HASSAN	220	HV1	SHIRALKOPPA_220	14:03	14:16	0:13	TRANSFORMER FAULT
421	5-Feb-22	HASSAN	220	HV2	SHIRALKOPPA_220	14:03	14:16	0:13	TRANSFORMER FAULT
422	5-Feb-22	HASSAN	220	HV2	SHIRALKOPPA_220	14:33	14:42	0:09	TRANSFORMER FAULT
423	5-Feb-22	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	10:03	13:46	3:43	NFBC ISSUED
424	5-Feb-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:22	14:34	1:12	LINE FAULT
425	5-Feb-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:03	13:46	3:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
426	5-Feb-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
427	5-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
428	5-Feb-22	MYSURU	66	HULLAHALLI-KADAKOLA	HULLAHALLI_66	8:35	9:39	1:03	NFBC ISSUED
429	5-Feb-22	MYSURU	66	HULLAHALLI-KADAKOLA	HULLAHALLI_66	15:54	17:10	1:16	NFBC ISSUED
430	5-Feb-22	MYSURU	66	HV1	KIADBMANDYA_66,	11:05	11:29	0:23	MAIN SUPPLY FAILURE
431	5-Feb-22	MYSURU	66	HV1	KOLKARANADODDI_66	11:00	11:08	0:08	MAIN SUPPLY FAILURE
432	5-Feb-22	MYSURU	66	HV2	KIADBMANDYA_66,	11:05	11:29	0:23	MAIN SUPPLY FAILURE
433	5-Feb-22	MYSURU	66	HV2	KOLKARANADODDI_66	11:00	11:08	0:08	MAIN SUPPLY FAILURE
434	5-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
435	5-Feb-22	MYSURU	66	KADAKOLA-SARAGURU 2	DOORA_66 HULLAHALLI_66	8:46	17:09	8:23	NFBC ISSUED
436	5-Feb-22	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	11:11	11:29	0:18	MAIN SUPPLY FAILURE
437	5-Feb-22	MYSURU	66	KIADB MANDYA-TUMBKERE	TUMBEKERE_66	11:12	11:31	0:19	MAIN SUPPLY FAILURE
438	5-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
439	5-Feb-22	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	12:59	15:02	2:02	NFBC ISSUED
440	5-Feb-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	13:05	13:30	0:25	LINE FAULT
441	5-Feb-22	MYSURU	66	MUGUR-KUNTHUR	JANNUR, MUGUR & THAYUR STATIONS INTERRUPTED	13:05	13:15	0:10	LINE FAULT
442	5-Feb-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
443	5-Feb-22	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	13:11	14:53	1:42	LINE FAULT
444	5-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:00	18:55	11:55	MAIN SUPPLY FAILURE
445	5-Feb-22	TUMKUR	66	HIRIYUR220-HIRIYUR66	HIRIYUR_66	9:00	17:05	8:05	LINE CLEAR AVAILED
446	5-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:30	15:45	0:15	MAIN SUPPLY FAILURE
447	5-Feb-22	TUMKUR	66	TR1	HOLALKERE_66	8:28	8:35	0:07	LINE CLEAR AVAILED
448	5-Feb-22	TUMKUR	66	TR2	KADAJJI_66	12:10	12:15	0:05	TRANSFORMER FAULT
449	5-Feb-22	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	6:36	6:53	0:17	MAIN SUPPLY FAILURE
450	5-Feb-22	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	9:15	10:35	1:20	LINE CLEAR AVAILED
451	5-Feb-22	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA-1	ANCHEPALYA_220	8:55	13:30	4:35	LINE CLEAR AVAILED
452	5-Feb-22	TUMKUR	220	ANCHEPALYA 66kv-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,H ONNENAHALLI_66	10:30	10:44	0:14	LINE CLEAR AVAILED
453	5-Feb-22	TUMKUR	220	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	16:34	16:54	0:20	LINE FAULT
454	5-Feb-22	TUMKUR	220	CHITRADURGA 220kv- SUZLON 1 &2	SUZLON2_IPP_66	9:06	9:16	0:10	LINE FAULT
455	5-Feb-22	TUMKUR	220	CHITRADURGA 220kv- SUZLON 1 &2	SUZLON2_IPP_66	10:22	10:30	0:08	LINE FAULT
456	5-Feb-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:00	17:00	6:00	LINE CLEAR AVAILED
457	5-Feb-22	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALI_220	15:09	15:30	0:21	LINE FAULT
458	5-Feb-22	TUMKUR	220	HONNALI66-HONNALLI220	HONNALI_66	15:09	15:42	0:33	MAIN SUPPLY FAILURE
459	5-Feb-22	TUMKUR	220	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	6:56	7:05	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
460	5-Feb-22	TUMKUR	220	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:18	6:26	0:08	LINE FAULT
461	5-Feb-22	TUMKUR	220	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:10	9:20	0:10	LINE FAULT
462	5-Feb-22	TUMKUR	220	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:34	10:44	0:10	LINE FAULT
463	5-Feb-22	TUMKUR	220	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	15:54	16:05	0:11	LINE FAULT
464	5-Feb-22	TUMKUR	220	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	6:35	6:50	0:15	LINE FAULT
465	5-Feb-22	TUMKUR	220	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66,HOLAVINAHALLY_66	5:30	5:48	0:18	LINE FAULT
466	5-Feb-22	TUMKUR	220	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66,HOLAVINAHALLY_66	6:16	7:45	1:29	LINE FAULT
467	5-Feb-22	TUMKUR	220	THALLAK 220kV- HIRIYUR PGCL	THALLAK_220	8:59	16:50	7:51	LINE FAULT
468	6-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAREGAL_110	1:07	1:21	0:14	TRANSFORMER FAULT
469	6-Feb-22	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	19:38	19:48	0:10	TRANSFORMER FAULT
470	6-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TUMMINAKATTI_110	10:04	10:13	0:09	TRANSFORMER FAULT
471	6-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI_110	17:12	19:59	2:47	TRANSFORMER FAULT
472	6-Feb-22	BAGALKOT	110	110/11KV,HV1	KUUDACHI_110	6:30	7:52	1:22	TRANSFORMER FAULT
473	6-Feb-22	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	7:44	12:23	4:39	TRANSFORMER FAULT
474	6-Feb-22	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	12:29	18:56	6:27	TRANSFORMER FAULT
475	6-Feb-22	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	22:55	23:15	0:20	TRANSFORMER FAULT
476	6-Feb-22	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	17:10	19:59	2:49	LINE CLEAR AVAILED
477	6-Feb-22	BAGALKOT	110	110/11KV,HV2	THORVI_110	9:57	10:01	0:04	TRANSFORMER FAULT
478	6-Feb-22	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	13:38	14:01	0:23	TRANSFORMER FAULT
479	6-Feb-22	BAGALKOT	110	110/33KV,HV3	MACHE_110 &RM1 ,AIP_33	8:48	16:18	7:30	LINE CLEAR AVAILED
480	6-Feb-22	BAGALKOT	110	220/110KV,LV2	STATON NOT EFFECTED CHIKODI_220	5:37	6:19	0:42	TRANSFORMER FAULT
481	6-Feb-22	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
482	6-Feb-22	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
483	6-Feb-22	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	1:30	1:42	0:12	LINE FAULT
484	6-Feb-22	BAGALKOT	110	BANAHATTI-JAMAKHANDI	JAMAKHANDI_110	16:11	16:18	0:07	LINE FAULT
485	6-Feb-22	BAGALKOT	110	BELGAUM(MACHE)- BELGAUM110	BELGAUM_110	9:12	15:20	6:08	NFBC ISSUED
486	6-Feb-22	BAGALKOT	110	BELGAUM-NEHARUNAGAR	STATON NOT EFFECTED BELGAUM_220	9:20	15:15	5:55	LINE CLEAR AVAILED
487	6-Feb-22	BAGALKOT	110	BELGAUM-NEHRU-NAGAR	NEHRU-NAGAR_110	9:20	9:25	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
488	6-Feb-22	BAGALKOT	110	BELGAUM-NEHRU-NAGAR	NEHRU-NAGAR_110	15:18	15:20	0:02	MAIN SUPPLY FAILURE
489	6-Feb-22	BAGALKOT	110	CHANDKAVATE-ALMEL	ALMEL_110	5:59	6:02	0:03	LINE FAULT
490	6-Feb-22	BAGALKOT	110	CHIKKODI- DKSSK	STATON NOT EFFECTED CHIKODI_220	5:37	8:30	2:53	LINE FAULT
491	6-Feb-22	BAGALKOT	110	CHIKKODI- SADALAGA	SADALAGA_110	6:04	8:24	2:20	LINE FAULT
492	6-Feb-22	BAGALKOT	110	CHIKKODI-BHOJ	BHOJ_110	7:03	7:46	0:43	LINE FAULT
493	6-Feb-22	BAGALKOT	110	CHIKKODI-KADAKLAT	KADAKLAT_110	6:04	13:16	7:12	LINE FAULT
494	6-Feb-22	BAGALKOT	110	CHIKKODI-RAIBAG LINE 1	STATION NOT AFFECTED CHIKKODI_220	7:05	8:47	1:42	LINE FAULT
495	6-Feb-22	BAGALKOT	110	CHIKKODI-RAIBAG LINE 1	STATION NOT AFFECTED CHIKKODI_220	8:47	15:06	6:19	LINE FAULT
496	6-Feb-22	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	18:41	18:45	0:04	HAND TRIPPED
497	6-Feb-22	BAGALKOT	110	DHAVALESHWAR-SAIDAPUR	SAIDAPUR_110	6:48	8:26	1:38	LINE FAULT
498	6-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
499	6-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
500	6-Feb-22	BAGALKOT	110	MURDESHWER-KRCL RAILWAY	KRCL RAILWAY_110 STATION NOT AFFECTED MURDESHWER_110	12:55	14:31	1:36	LINE CLEAR AVAILED
501	6-Feb-22	BAGALKOT	110	RANEBENNUR-HIREKERUR	RANEBENNUR_220	3:56	8:52	4:56	LINE FAULT
502	6-Feb-22	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	4:55	5:02	0:07	LINE FAULT
503	6-Feb-22	BAGALKOT	110	SADALAGA-CHIKKODI220	SADALAGA_110	6:04	8:50	2:46	LINE FAULT
504	6-Feb-22	BAGALKOT	110	TUMMINAKATTI- RANEBENNUR220	TUMMINAKATTI_110	4:55	5:04	0:09	LINE FAULT
505	6-Feb-22	BAGALKOT	110	YALLAMMANAWADI-ALBAL	ALBAL_110	1:29	1:46	0:17	LINE FAULT
506	6-Feb-22	BAGALKOT	220	BAGALKOT - ALAMATTI-2	STATION NOT AFFECTED BAGAKOT_220	3:45 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
507	6-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
508	6-Feb-22	BAGALKOT	220	CHIKKODI-GHATAPRABHA2(KUDCHI-2)	STATON NOT EFFECTED CHIKODI_220	6:12	10:39	4:27	LINE FAULT
509	6-Feb-22	BAGALKOT	220	CHIKKODI-GHATAPRABHA2(KUDCHI-2)	STATON NOT EFFECTED CHIKODI_220	4:12	5:15	1:03	LINE FAULT
510	6-Feb-22	BAGALKOT	220	CHIKKODI-KUDCHI-1	STATION NOT AFFECTED CHIKKODI_220	4:22	5:15	0:53	LINE FAULT
511	6-Feb-22	BAGALKOT	220	CHIKKODI-KUDCHI-1	STATION NOT AFFECTED CHIKKODI_220	6:08	10:39	4:31	LINE FAULT
512	6-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
513	6-Feb-22	BAGALKOT	220	HAVERI-GUTTUR1	STATON NOT EFFECTED HAVERI_220	5:06	17:31	12:25	LINE FAULT
514	6-Feb-22	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	11:54	15:32	3:38	LINE CLEAR AVAILED
515	6-Feb-22	BAGALKOT	220	KUDUCH-CHIKKODI1	STATON NOT EFFECTED KUDUCHI_220	4:19	5:15	0:56	LINE FAULT
516	6-Feb-22	BAGALKOT	220	KUDUCH-CHIKKODI1	STATON NOT EFFECTED KUDUCHI_220	6:15	11:01	4:46	LINE FAULT
517	6-Feb-22	BAGALKOT	220	KUDUCH-CHIKKODI2	STATON NOT EFFECTED KUDUCHI_220	6:24	11:04	4:40	LINE FAULT
518	6-Feb-22	BAGALKOT	220	KUDUCHI-CHIKKODI2	STATON NOT EFFECTED KUDUCHI_220	4:12	5:20	1:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
519	6-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
520	6-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
521	6-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
522	6-Feb-22	BAGALKOT	220	SOUDATTI-MAHALINGPUR	STATON NOT EFFECTED SOUDATTI_110	7:27	19:10	11:43	LINE FAULT
523	6-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
524	6-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
525	6-Feb-22	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	15:48	15:54	0:06	LOAD CHANGE OVER
526	6-Feb-22	BENGALURU	66	ELECTRONIC CITY - HULIMANGALA	HULIMANGALA	01:39:00(06/02/2022)			LINE OPEN:LINE FAULT
527	6-Feb-22	BENGALURU	66	ELECTRONIC CITY - NAGANATHPURA 220	ELECTRONIC CITY, HULIMANGALA	1:39	2:16	0:37	MAIN SUPPLY FAILURE
528	6-Feb-22	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-1 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-2	1:39	2:16	0:37	LINE FAULT
529	6-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	15:20	15:25	0:05	LINE FAULT
530	6-Feb-22	BENGALURU	66	HV1	DODDABELAVANGALA	10:18	10:36	0:17	TRANSFORMER FAULT
531	6-Feb-22	BENGALURU	66	HV2	NRS 220	10:37	10:48	0:11	LOAD CHANGE OVER
532	6-Feb-22	BENGALURU	66	HV2	NRS 220	15:38	15:46	0:08	LOAD CHANGE OVER
533	6-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN, CHANDRAPPA CIRCLE	15:21	15:28	0:07	LOAD CHANGE OVER
534	6-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN, CHANDRAPPA CIRCLE	10:12	10:29	0:17	LOAD CHANGE OVER
535	6-Feb-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	20:32	20:43	0:11	LINE FAULT
536	6-Feb-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	22:03	22:36	0:33	LINE FAULT
537	6-Feb-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	22:25	22:32	0:07	LOAD CHANGE OVER
538	6-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
539	6-Feb-22	BENGALURU	66	MAASTHI - ADANI SOLAR (IPP)	NO STATION AFFECTED	13:06	13:22	0:15	LINE FAULT
540	6-Feb-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA	6:39	7:22	0:42	LINE FAULT
541	6-Feb-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	0:14	0:21	0:07	LINE FAULT
542	6-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	1:59	2:07	0:07	LINE FAULT
543	6-Feb-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, ELECTRONIC CITY	1:39	2:16	0:37	LINE FAULT
544	6-Feb-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	10:14	10:18	0:04	LOAD CHANGE OVER
545	6-Feb-22	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	10:31	15:08	4:37	LINE CLEAR AVAILED
546	6-Feb-22	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	1:59	2:08	0:08	LINE FAULT
547	6-Feb-22	BENGALURU	66	V R DODDI - SOMANAHALLI 220	V R DODDI	10:12	10:17	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
548	6-Feb-22	BENGALURU	66	V R DODDI - SOMANAHALLI 220	V R DODDI	15:10	15:15	0:05	LOAD CHANGE OVER
549	6-Feb-22	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
550	6-Feb-22	GULBARGA	66	ITTAGI-HUVINAHADGALI	HUVINAHADGALI_66,HOLAGUNDI_66	18:40	18:50	0:10	LINE FAULT
551	6-Feb-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	5:35	5:45	0:10	LINE FAULT
552	6-Feb-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,GAJENDRAGAD_110,HIREGONNAGAR_110,HANUMANAL_110	6:05	7:43	1:38	LOAD CURTAILMENT
553	6-Feb-22	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANADAL_110,NAVALLI_110	6:24	7:38	1:14	LOAD CURTAILMENT
554	6-Feb-22	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	6:05	7:35	1:30	LOAD CURTAILMENT
555	6-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	9:39	16:15	6:36	LOAD CHANGE OVER
556	6-Feb-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:06	21:16	0:10	LINE FAULT
557	6-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
558	6-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	6:28	7:28	1:00	LOAD CURTAILMENT
559	6-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	9:30	10:30	1:00	LOAD CURTAILMENT
560	6-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	12:05	13:15	1:10	LOAD CURTAILMENT
561	6-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GAUBBUR_110	8:27	8:43	0:16	LINE CLEAR AVAILED
562	6-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GAUBBUR_110	17:27	17:40	0:13	LINE CLEAR AVAILED
563	6-Feb-22	GULBARGA	110	RAICHUR-SINDHANOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	6:28	7:05	0:37	LOAD CURTAILMENT
564	6-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
565	6-Feb-22	GULBARGA	110	SHAHABAD-WADI	WADI_110	19:37	19:45	0:08	LOAD CHANGE OVER
566	6-Feb-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CO RE GREEN SUGAR_IPP	20:33	20:46	0:13	LINE FAULT
567	6-Feb-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	8:26	17:14	8:48	LINE CLEAR AVAILED
568	6-Feb-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	8:26	17:14	8:48	LINE CLEAR AVAILED
569	6-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
570	6-Feb-22	GULBARGA	400	BPS-JSWL	BPS_400	11:04(01.02.2022)	17:44(06.02.2022)	126:40HRS	NFBC ISSUED
571	6-Feb-22	HASSAN	66	HV4	BALEHONNUR_66	11:44	12:58	1:14	LOAD CHANGE OVER
572	6-Feb-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:12	9:28	0:16	LINE FAULT
573	6-Feb-22	HASSAN	110	HGUNJE-HIRIYADKA	HEGGUNJE_220	9:15	9:30	0:15	LINE FAULT
574	6-Feb-22	HASSAN	110	HIRIYAD-KEMAR	HIRIYADKA_110	9:15	9:30	0:15	MAIN SUPPLY FAILURE
575	6-Feb-22	HASSAN	110	HIRIYAD-MADHUVANA	HIRIYADKA_110	9:15	9:31	0:16	MAIN SUPPLY FAILURE
576	6-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE FAULT
577	6-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
578	6-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
579	6-Feb-22	HASSAN	110	MRSSH-MBADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
580	6-Feb-22	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	21:57(04.02.2022)	6:54(05.02.2022)	8:57HRS	LINE CHARGED
581	6-Feb-22	HASSAN	220	KEMAR-1Varahi1	KEMAR_220	6:03	14:33	8:30	LINE CLEAR AVAILED
582	6-Feb-22	HASSAN	220	KEMAR2Varahi2	KEMAR_220	6:26	14:33	8:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
583	6-Feb-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	6:05	14:48	8:43	NFBC ISSUED
584	6-Feb-22	HASSAN	220	VARAHI-KEMAR2	varahi_gen	6:28	14:48	8:20	NFBC ISSUED
585	6-Feb-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
586	6-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
587	6-Feb-22	MYSURU	66	JAKKANAHALLI-NAGMANGLA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	6:46	11:41	4:54	LINE FAULT
588	6-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
589	6-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
590	6-Feb-22	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	21:50	21:55	0:05	LINE FAULT
591	6-Feb-22	MYSURU	66	SB HALLI-HARIYALDAMMA TEMPLE	HARIYALDAMMATemple_66	1:55	2:05	0:10	LINE FAULT
592	6-Feb-22	MYSURU	66	SB HALLI-HARIYALDAMMA TEMPLE	HARIYALDAMMATemple_66	5:20	5:32	0:12	LINE FAULT
593	6-Feb-22	MYSURU	66	SB HALLI-HARIYALDAMMA TEMPLE	HARIYALDAMMATemple_66	6:28	6:35	0:06	LINE FAULT
594	6-Feb-22	MYSURU	66	SB HALLI-HUYGONAHALLI	SANTHEBACHALLI_66 ADDIHALLI_66	1:55	2:05	0:10	LINE FAULT
595	6-Feb-22	MYSURU	66	SB HALLI-HUYGONAHALLI	SANTHEBACHALLI_66 ADDIHALLI_66	5:20	5:25	0:05	LINE FAULT
596	6-Feb-22	MYSURU	66	SB HALLI-HUYGONAHALLI	SANTHEBACHALLI_66 ADDIHALLI_66	5:20	5:32	0:12	LINE FAULT
597	6-Feb-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
598	6-Feb-22	MYSURU	66	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66	15:12	15:25	0:13	LINE FAULT
599	6-Feb-22	MYSURU	66	VAJMANGALA-MEGALAPURA	NO STATIONS EFFECTED	14:02	14:10	0:08	LINE FAULT
600	6-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	16:35	17:00	0:25	MAIN SUPPLY FAILURE
601	6-Feb-22	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	11:10	11:53	0:43	LINE FAULT
602	6-Feb-22	TUMKUR	66	CHITRADURGA 66kv- CHITRADURGA 2	CHITRADURGA_66	11:10	11:53	0:43	LINE FAULT
603	6-Feb-22	TUMKUR	66	HIRIYUR220-HIRIYUR66	HIRIYUR_66	9:25	15:15	5:50	LINE CLEAR AVAILED
604	6-Feb-22	TUMKUR	66	TR2	HOLALKERE_66	11:30	11:45	0:15	LINE CLEAR AVAILED
605	6-Feb-22	TUMKUR	66	TR2	HOLALKERE_66	13:05	13:11	0:06	TRANSFORMER FAULT
606	6-Feb-22	TUMKUR	66	TR2	HOLALKERE_66	13:50	13:55	0:05	TRANSFORMER FAULT
607	6-Feb-22	TUMKUR	66	TR2	HOLALKERE_66	17:45	18:20	0:35	TRANSFORMER FAULT
608	6-Feb-22	TUMKUR	66	TR2	HULIYURDURGA_66, CHAWANAKUPPE_66	4:30	4:50	0:20	TRANSFORMER FAULT
609	6-Feb-22	TUMKUR	66	TR2	KADAJJI_66	1:20	1:30	0:10	TRANSFORMER FAULT
610	6-Feb-22	TUMKUR	220	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66	12:50	13:15	0:25	LINE FAULT
611	6-Feb-22	TUMKUR	220	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	4:30	4:54	0:24	LINE FAULT
612	6-Feb-22	TUMKUR	220	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	2:05	2:19	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
613	6-Feb-22	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	5:06	17:32	12:26	LINE FAULT
614	6-Feb-22	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	11:50	15:32	3:42	LINE FAULT
615	6-Feb-22	TUMKUR	220	HONNALLI 220KV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:27	10:36	0:09	LINE FAULT
616	6-Feb-22	TUMKUR	220	HONNALLI 220KV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:25	12:35	0:10	LINE FAULT
617	6-Feb-22	TUMKUR	220	TR1	CHITRADURGA_220	4:30	5:12	0:42	TRANSFORMER FAULT
1	07-Feb-22	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	7:25	8:28	1:03	HAND TRIPPED
2	07-Feb-22	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	11:27	18:48	7:21	LINE CLEAR AVAILED
3	07-Feb-22	BAGALKOT	110	110/11KV,HV1	YELLAMANAWADI_110	10:31	11:40	1:09	LINE CLEAR AVAILED
4	07-Feb-22	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	9:05 (07.02.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
5	07-Feb-22	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	9:33	9:51	0:18	TRANSFORMER FAULT
6	07-Feb-22	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	10:02	16:09	6:07	LINE CLEAR AVAILED
7	07-Feb-22	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	12:33	13:46	1:13	LINE CLEAR AVAILED
8	07-Feb-22	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	14:48	15:09	0:21	TRANSFORMER FAULT
9	07-Feb-22	BAGALKOT	110	220/110KV,HV,LV2	CHIKODI_220	15:25	17:23	1:58	LINE CLEAR AVAILED
10	07-Feb-22	BAGALKOT	110	220/110KV,LV2	CHIKODI_220	4:25	5:30	1:05	TRANSFORMER FAULT
11	07-Feb-22	BAGALKOT	110	220/110KV,LV2	CHIKODI_220	6:37	6:43	0:06	LINE CLEAR AVAILED
12	07-Feb-22	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	6:51	6:59	0:08	LINE FAULT
13	07-Feb-22	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
14	07-Feb-22	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)			LINE OPEN:LINE CLEAR AVAILED
15	07-Feb-22	BAGALKOT	110	BIDNAL-GADAGROAD(GADAG)	STATION NOT AFFECTED BIDNAL_220	18:34	21:45	3:11	LINE FAULT
16	07-Feb-22	BAGALKOT	110	CHANDKAVATE-ALMEL	ALMEL_110	6:44	7:15	0:31	LINE FAULT
17	07-Feb-22	BAGALKOT	110	CHIKKODI-DKSSK	CHIKODI_220	6:37	9:10	2:33	LINE FAULT
18	07-Feb-22	BAGALKOT	110	CHIKKODI-KHADAKLAT	KHADKLAT_110	12:04	13:18	1:14	LINE CLEAR AVAILED
19	07-Feb-22	BAGALKOT	110	CHIKKODI-KHADAKLAT	CHIKODI_220	12:04	13:18	1:14	LINE CLEAR AVAILED
20	07-Feb-22	BAGALKOT	110	CHIKODI-BHOJ	BHOJ_110	6:34	9:10	2:36	LINE FAULT
21	07-Feb-22	BAGALKOT	110	CHIKODI-SANKESHWAR	CHIKODI_220	4:25	10:46	6:21	LINE FAULT
22	07-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
23	07-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
24	07-Feb-22	BAGALKOT	110	KHADAKLAT-NIPPANI	NIPPANI_110	12:58	13:21	0:23	LINE CLEAR AVAILED
25	07-Feb-22	BAGALKOT	220	220/110KV,HV3,LV3	CHIKODI_220	4:25	5:55	1:30	TRANSFORMER FAULT
26	07-Feb-22	BAGALKOT	220	BAGALKOT - ALAMATTI-2	STATION NOT AFFECTED BAGAKOT_220	3:45 (04.02.2022)	21:07 (07.02.2022)	89:22 hrs	LINE CHARGED
27	07-Feb-22	BAGALKOT	220	BAGEWADI-RBRK	STATION NOT AFFECTED BAGEWADI_220	15:53	15:57	0:04	LINE FAULT
28	07-Feb-22	BAGALKOT	220	BAGEWADI-RBRK	STATION NOT AFFECTED BAGEWADI_220	15:53	15:57	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
29	07-Feb-22	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
30	07-Feb-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKODI_220	5:12	6:07	0:55	LINE FAULT
31	07-Feb-22	BAGALKOT	220	CHIKKODI-KUDACHI 1	STATION NOT AFFECTED CHIKODI_220	5:22	11:10	5:48	LINE FAULT
32	07-Feb-22	BAGALKOT	220	CHIKKODI-KUDACHI 2	STATION NOT AFFECTED CHIKODI_220	5:12	11:13	6:01	LINE FAULT
33	07-Feb-22	BAGALKOT	220	CHIKODI-MUGULKHOD 1	STATION NOT AFFECTED CHIKODI_220	5:12	6:06	0:54	LINE FAULT
34	07-Feb-22	BAGALKOT	220	CHIKODI-MUGULKHOD 2	STATION NOT AFFECTED CHIKODI_220	5:12	6:06	0:54	LINE FAULT
35	07-Feb-22	BAGALKOT	220	CHIKODI-TALANDGE	STATION NOT AFFECTED CHIKODI_220	11:05	11:42	0:37	LINE FAULT
36	07-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
37	07-Feb-22	BAGALKOT	220	KUDUCHI-CHIKKODI1	STATION NOT AFFECTED KUDUCHI_220	5:22	11:08	5:46	LINE FAULT
38	07-Feb-22	BAGALKOT	220	KUDUCHI-CHIKKODI2	STATION NOT AFFECTED KUDUCHI_220	5:12	11:12	6:00	LINE FAULT
39	07-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 1	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
40	07-Feb-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
41	07-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
42	07-Feb-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
43	07-Feb-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
44	07-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
45	07-Feb-22	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	KEMPANAHALLI, AGALAKOTE, MATHIKERE (NEL)	6:35	6:55	0:20	MAIN SUPPLY FAILURE
46	07-Feb-22	BENGALURU	66	ARMY WELFARE - KONDASPURA	ARMY WELFARE	10:40	12:30	1:50	LINE CLEAR AVAILED
47	07-Feb-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	2:17	2:27	0:09	LINE FAULT
48	07-Feb-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	10:19	10:23	0:03	LINE CLEAR AVAILED
49	07-Feb-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	17:20	17:26	0:05	LOAD CHANGE OVER
50	07-Feb-22	BENGALURU	66	ELECTRONIC CITY - HULIMANGALA	HULIMANGALA	01:39:00(06/02/2022)	6:52(07/02/2022)	29:13HRS	LINE CHARGED
51	07-Feb-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI	10:47	17:16	6:29	LINE CLEAR AVAILED
52	07-Feb-22	BENGALURU	66	GURUVINAPURA - SOMANAHALLI 220	GURUVINAPURA	16:35	16:38	0:03	LOAD CHANGE OVER
53	07-Feb-22	BENGALURU	66	GURUVINAPURA - TK HALLI 220	GURUVINAPURA	15:35	15:40	0:05	LOAD CHANGE OVER
54	07-Feb-22	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:48	11:32	0:44	LOAD CHANGE OVER
55	07-Feb-22	BENGALURU	66	HBR LAYOUT - MANYATHA TECH PARK 220	HBR LAYOUT	17:42	17:49	0:07	LOAD CHANGE OVER
56	07-Feb-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	14:33	19:05	4:32	LINE CLEAR AVAILED
57	07-Feb-22	BENGALURU	66	HV1	CHATRA	14:51	15:07	0:16	LINE CLEAR AVAILED
58	07-Feb-22	BENGALURU	66	HV1	DASHAVARA	9:15	9:19	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
59	07-Feb-22	BENGALURU	66	HV1	HENNUR CROSS	10:30	10:35	0:05	LINE CLEAR AVAILED
60	07-Feb-22	BENGALURU	66	HV1	PRIMAL	9:25	9:32	0:07	LINE CLEAR AVAILED
61	07-Feb-22	BENGALURU	66	HV1	PRIMAL	16:21	16:31	0:10	LOAD CHANGE OVER
62	07-Feb-22	BENGALURU	66	HV1	TK HALLI 220	14:30	14:32	0:02	LINE CLEAR AVAILED
63	07-Feb-22	BENGALURU	66	HV1	MALLASANDRA	14:00	14:50	0:49	LINE CLEAR AVAILED
64	07-Feb-22	BENGALURU	66	HV1	DODDABELAVANGALA	12:26	12:32	0:05	TRANSFORMER FAULT
65	07-Feb-22	BENGALURU	66	HV1	DODDABELAVANGALA	13:03	13:10	0:06	TRANSFORMER FAULT
66	07-Feb-22	BENGALURU	66	HV2	CHATRA	3:30	3:45	0:15	TRANSFORMER FAULT
67	07-Feb-22	BENGALURU	66	HV2	HENNUR CROSS	16:51	16:54	0:03	LINE CLEAR AVAILED
68	07-Feb-22	BENGALURU	66	HV2	KADUGODI	0:00	0:05	0:05	TRANSFORMER FAULT
69	07-Feb-22	BENGALURU	66	HV2	TK HALLI 220	11:17	11:19	0:02	TRANSFORMER FAULT
70	07-Feb-22	BENGALURU	66	HV2	TEKAL	15:27	15:36	0:09	TRANSFORMER FAULT
71	07-Feb-22	BENGALURU	66	HV2	MANCHENAHALLI	14:38	14:48	0:10	TRANSFORMER FAULT
72	07-Feb-22	BENGALURU	66	IISc - HEBBALA 220	IISc	9:38	9:44	0:06	LOAD CHANGE OVER
73	07-Feb-22	BENGALURU	66	IISc - NRS 220	IISc	18:29	18:34	0:05	LOAD CHANGE OVER
74	07-Feb-22	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	23:41:00(07/02/2022)			LINE OPEN:LINE FAULT
75	07-Feb-22	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	7:43	7:58	0:15	LINE FAULT
76	07-Feb-22	BENGALURU	66	JAYADEVA - SARAKKI 2	SARAKKI 2	7:43	8:03	0:20	LINE CLEAR AVAILED
77	07-Feb-22	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	11:38	12:08	0:29	LINE FAULT
78	07-Feb-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	0:48	6:23	5:34	LINE FAULT
79	07-Feb-22	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA, ARMY WELFARE	17:40	17:45	0:05	LOAD CHANGE OVER
80	07-Feb-22	BENGALURU	66	KONDASPURA - KADUGODI	KONDASPURA	10:40	10:50	0:10	LOAD CHANGE OVER
81	07-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
82	07-Feb-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:43	6:50	0:07	LINE FAULT
83	07-Feb-22	BENGALURU	66	RAJANUKUNTE - DB PURA 220	RAJANUKUNTE	11:30	11:35	0:05	LOAD CHANGE OVER
84	07-Feb-22	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	10:05	10:25	0:20	MAIN SUPPLY FAILURE
85	07-Feb-22	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	9:05	9:15	0:10	LINE FAULT
86	07-Feb-22	BENGALURU	66	SRIGANDA KAVALU - BYDRAHALLI	SRIGANDA KAVALU	10:00	17:00	7:00	LINE CLEAR AVAILED
87	07-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	6:30	7:40	1:10	LINE FAULT
88	07-Feb-22	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	10:03	10:25	0:21	LINE FAULT
89	07-Feb-22	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	10:04	15:50	5:45	LOAD CURTAILMENT
90	07-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
91	07-Feb-22	GULBARGA	66	HV2	PUNABGHATA_66	12:30	12:35	0:05	TRANSFORMER FAULT
92	07-Feb-22	GULBARGA	66	HV2	PUNABGHATA_66	13:20	13:25	0:05	TRANSFORMER FAULT
93	07-Feb-22	GULBARGA	66	HV2	PUNABGHATA_66	15:05	15:10	0:05	TRANSFORMER FAULT
94	07-Feb-22	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	18:08	18:16	0:08	LINE FAULT
95	07-Feb-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	13:22	13:49	0:27	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
96	07-Feb-22	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	18:38	18:52	0:14	MAIN SUPPLY FAILURE
97	07-Feb-22	GULBARGA	110	HV2	GHATTARGA_110	11:00	13:00	2:00	LINE CLEAR AVAILED
98	07-Feb-22	GULBARGA	110	HV2	SIRIGERICROSS_110	7:05	7:15	0:10	TRANSFORMER FAULT
99	07-Feb-22	GULBARGA	110	HV3	VALKAMDINNI_110	7:22	7:32	0:10	TRANSFORMER FAULT
100	07-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:20	16:05	5:45	LOAD CHANGE OVER
101	07-Feb-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	18:35	18:47	0:12	LINE FAULT
102	07-Feb-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	20:55	21:05	0:10	LINE FAULT
103	07-Feb-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:23	5:33	0:10	LINE FAULT
104	07-Feb-22	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	7:55	19:14	11:19	LINE FAULT
105	07-Feb-22	GULBARGA	110	MUNIRABD-HAGARI	SANKLAPURA_110,RBSNN,KAMALA PUR_110	18:31	18:50	0:19	LINE FAULT
106	07-Feb-22	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	10:08	10:12	0:04	LINE CLEAR AVAILED
107	07-Feb-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
108	07-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	6:35	7:45	1:10	LOAD CURTAILMENT
109	07-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	13:45	15:00	1:15	LOAD CURTAILMENT
110	07-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GOOGLE_110,GAUBBUR_110	6:35	7:05	0:30	LINE CLEAR AVAILED
111	07-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GAUBBUR_110	6:35	7:45	1:10	LINE CLEAR AVAILED
112	07-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
113	07-Feb-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CO RE GREEN SUGAR_IPP	19:25	19:30	0:05	LINE FAULT
114	07-Feb-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:46	5:53	0:07	LINE FAULT
115	07-Feb-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:57	6:08	0:11	LINE CLEAR AVAILED
116	07-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:23 (07.02.2022)			LINE OPEN:LINE CLEAR AVAILED
117	07-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	3:52	4:07	0:15	LINE FAULT
118	07-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	6:52	7:02	0:10	LINE FAULT
119	07-Feb-22	GULBARGA	110	SIRIGIRICROSS-ALIPUR	SIRIGIRICROSS_110	7:05	7:15	0:10	MAIN SUPPLY FAILURE
120	07-Feb-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	18:32	18:40	0:08	LINE FAULT
121	07-Feb-22	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	18:40	19:06	0:26	MAIN SUPPLY FAILURE
122	07-Feb-22	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	3:55	4:10	0:15	MAIN SUPPLY FAILURE
123	07-Feb-22	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	6:40	6:50	0:10	MAIN SUPPLY FAILURE
124	07-Feb-22	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	14:00	14:45	0:45	LINE CLEAR AVAILED
125	07-Feb-22	GULBARGA	220	HV1	SINDHANOOR_220	16:15	19:00	2:45	LINE CLEAR AVAILED
126	07-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
127	07-Feb-22	GULBARGA	220	HV2	SINDHANOOR_220	11:10	16:10	5:00	LINE CLEAR AVAILED
128	07-Feb-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	10:51	14:56	4:05	LINE CLEAR AVAILED
129	07-Feb-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYPATNA_66	8:20 (6.2.2022)	2:50(7.02.2022)	18:29 hrs	LINE CHARGED
130	07-Feb-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYPATNA_66	8:20 (6.2.2022)	2:50(7.02.2022)	18:29 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
131	07-Feb-22	HASSAN	66	DODDAKA-HNPURA	DODDAKADNUR_66	17:40	21:20	3:40	MAIN SUPPLY FAILURE
132	07-Feb-22	HASSAN	66	DODDAKA-HNPURA	DODDAKADNUR_66	11:10	11:20	0:10	MAIN SUPPLY FAILURE
133	07-Feb-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	11:10	11:20	0:10	MAIN SUPPLY FAILURE
134	07-Feb-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	17:40	21:20	3:40	MAIN SUPPLY FAILURE
135	07-Feb-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	12:45	12:50	0:05	LINE FAULT
136	07-Feb-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	17:40	21:20	3:40	MAIN SUPPLY FAILURE
137	07-Feb-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURS_220	9:58	10:05	0:07	LINE FAULT
138	07-Feb-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURS_220	11:09	11:17	0:08	LINE FAULT
139	07-Feb-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURS_220	17:36	17:41	0:05	LINE FAULT
140	07-Feb-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURS_220	19:01	20:39	1:38	LINE CLEAR AVAILED
141	07-Feb-22	HASSAN	66	HV1	DODDAHALLI_66	11:05	11:15	0:10	MAIN SUPPLY FAILURE
142	07-Feb-22	HASSAN	66	HV1	DODDAHALLI_66	12:44	12:51	0:07	TRANSFORMER FAULT
143	07-Feb-22	HASSAN	66	HV1	DODDAHALLI_66	17:40	17:45	0:05	MAIN SUPPLY FAILURE
144	07-Feb-22	HASSAN	66	HV1	DODDAHALLI_66	19:00	20:47	1:47	MAIN SUPPLY FAILURE
145	07-Feb-22	HASSAN	66	HV1	DODDAHALLI_66	21:10	21:20	0:10	TRANSFORMER FAULT
146	07-Feb-22	HASSAN	66	HV1	DODDAKADNUR_66	17:40	21:20	3:40	MAIN SUPPLY FAILURE
147	07-Feb-22	HASSAN	66	HV1	DODDAKADNUR_66	11:10	11:20	0:10	MAIN SUPPLY FAILURE
148	07-Feb-22	HASSAN	66	HV1	MOSALEHOSAHALLI_66	12:15	13:06	0:51	LINE CLEAR AVAILED
149	07-Feb-22	HASSAN	66	HV1	NAGARTHI_66	11:11	11:18	0:07	MAIN SUPPLY FAILURE
150	07-Feb-22	HASSAN	66	HV1	NAGARTHI_66	17:37	17:42	0:05	MAIN SUPPLY FAILURE
151	07-Feb-22	HASSAN	66	HV2	RAMESHWARNAGAR_66	11:32	13:00	1:28	LINE CLEAR AVAILED
152	07-Feb-22	HASSAN	66	HV2	UDAYAPURA_66	22:20	22:33	0:13	TRANSFORMER FAULT
153	07-Feb-22	HASSAN	66	HV4	BALEHONNUR_66	10:18	11:16	0:58	LINE CLEAR AVAILED
154	07-Feb-22	HASSAN	66	L1	NAGARTHI_66	19:00	20:40	1:40	MAIN SUPPLY FAILURE
155	07-Feb-22	HASSAN	66	Lv1	HOLENARASIPURS_220	7:26	8:45	1:19	LINE CLEAR AVAILED
156	07-Feb-22	HASSAN	66	MATTA NAV-DIDGTHL	MATTANAVILE_66	12:31	12:49	0:18	LINE FAULT
157	07-Feb-22	HASSAN	66	SOSSAHA-HOOTGALLI	DODDAHALLI_66	12:45	12:50	0:05	LINE FAULT
158	07-Feb-22	HASSAN	66	SOSSAHA-HOOTGALLI	DODDAHALLI_66	17:40	17:45	0:05	MAIN SUPPLY FAILURE
159	07-Feb-22	HASSAN	66	SOSSAHA-HOOTGALLI	DODDAHALLI_66	19:00	20:47	1:47	MAIN SUPPLY FAILURE
160	07-Feb-22	HASSAN	66	SOSSAHA-HOOTGALLI	DODDAHALLI_66	21:10	21:30	0:20	MAIN SUPPLY FAILURE
161	07-Feb-22	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	19:35	19:40	0:05	LINE FAULT
162	07-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	23:04	23:24	0:20	MAIN SUPPLY FAILURE
163	07-Feb-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	23:04	23:26	0:22	MAIN SUPPLY FAILURE
164	07-Feb-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	23:04	23:25	0:21	MAIN SUPPLY FAILURE
165	07-Feb-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	23:04	23:27	0:23	MAIN SUPPLY FAILURE
166	07-Feb-22	HASSAN	110	SHRLKP-SORABA	SHIRALKOPPA_220	23:04	23:25	0:21	MAIN SUPPLY FAILURE
167	07-Feb-22	HASSAN	220	GERSOPA-TALGUPA1	gersoppa_gen	15:44	16:19	0:35	LINE FAULT
168	07-Feb-22	HASSAN	220	HV1	HOLENARASIPURS_220	7:26	8:45	1:19	LINE CLEAR AVAILED
169	07-Feb-22	HASSAN	220	MRSSHM-OSTRP	MRSMSG_220	15:44	16:15	0:31	LINE FAULT
170	07-Feb-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	20:15	21:24	1:09	LINE CLEAR AVAILED
171	07-Feb-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:04	14:24	4:20	LINE CLEAR AVAILED
172	07-Feb-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	23:04	23:24	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
173	07-Feb-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	23:04	23:24	0:20	LINE FAULT
174	07-Feb-22	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	20:15	21:24	1:09	LINE CLEAR AVAILED
175	07-Feb-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
176	07-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
177	07-Feb-22	MYSURU	66	HV1	BANNIMANTAP_66	11:44	12:03	0:18	LINE CLEAR AVAILED
178	07-Feb-22	MYSURU	66	HV1	BYLUKUPPE_66	10:55	11:05	0:10	TRANSFORMER FAULT
179	07-Feb-22	MYSURU	66	HV1	BYLUKUPPE_66	19:40	19:50	0:10	TRANSFORMER FAULT
180	07-Feb-22	MYSURU	66	HV1	KADABALLY_66	12:15	12:25	0:10	MAIN SUPPLY FAILURE
181	07-Feb-22	MYSURU	66	HV1	KADABALLY_66	12:30	12:45	0:15	MAIN SUPPLY FAILURE
182	07-Feb-22	MYSURU	66	HV1	KAGGERE HAMPAPURA_66	17:35	17:45	0:10	MAIN SUPPLY FAILURE
183	07-Feb-22	MYSURU	66	HV1	KAGGERE HAMPAPURA_66	19:00	19:55	0:55	MAIN SUPPLY FAILURE
184	07-Feb-22	MYSURU	66	HV1	KAGGERE HAMPAPURA_66	21:10	21:30	0:20	MAIN SUPPLY FAILURE
185	07-Feb-22	MYSURU	66	HV2	BYLUKUPPE_66	10:55	11:05	0:10	TRANSFORMER FAULT
186	07-Feb-22	MYSURU	66	HV2	BYLUKUPPE_66	19:40	19:50	0:10	TRANSFORMER FAULT
187	07-Feb-22	MYSURU	66	HV2	KADABALLY_66	12:15	12:25	0:10	MAIN SUPPLY FAILURE
188	07-Feb-22	MYSURU	66	HV2	KADABALLY_66	12:30	12:45	0:15	MAIN SUPPLY FAILURE
189	07-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
190	07-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
191	07-Feb-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
192	07-Feb-22	MYSURU	220	HV2	BEGUR 220-	17:05	19:05	2:00	LINE CLEAR AVAILED
193	07-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	6:58	19:20	12:21	LINE CLEAR AVAILED
194	07-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	21:21	21:33	0:11	LINE FAULT
195	07-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	20:03	20:09	0:05	LOAD CURTAILMENT
196	07-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	22:53	23:21	0:28	LINE FAULT
197	07-Feb-22	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	9:22	9:53	0:30	LINE FAULT
198	07-Feb-22	TUMKUR	66	CHITRADURGA 66kv- DAVANAGERE2	CHITRADURGA_66	10:50	12:45	1:55	LINE CLEAR AVAILED
199	07-Feb-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:49	17:51	0:01	LOAD CURTAILMENT
200	07-Feb-22	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:49	17:50	0:01	LOAD CURTAILMENT
201	07-Feb-22	TUMKUR	66	HAGALWADI- ANTHARASANAHALI	HAGALWADI_66	11:37	16:05	4:28	LINE CLEAR AVAILED
202	07-Feb-22	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	15:05	15:52	0:46	MAIN SUPPLY FAILURE
203	07-Feb-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:34	10:42	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
204	07-Feb-22	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:04	16:03	0:59	MAIN SUPPLY FAILURE
205	07-Feb-22	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:40	18:50	0:09	LOAD CURTAILMENT
206	07-Feb-22	TUMKUR	66	HONNALLI 220kV- SASVEHALLI	SAAVEHALLI_66	15:06	16:01	0:55	MAIN SUPPLY FAILURE
207	07-Feb-22	TUMKUR	66	HONNALLI-HONNALLI	HONNALLI_66, KATTIGE_66	17:45	17:55	0:10	LINE FAULT
208	07-Feb-22	TUMKUR	66	KUNIGAL_66 - ANCHEPALYA_220	KUNIGAL_66	12:30	13:00	0:30	LINE CLEAR AVAILED
209	07-Feb-22	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	14:39	14:44	0:05	LINE FAULT
210	07-Feb-22	TUMKUR	66	TR-1	HONNALLI_220	15:06	15:43	0:37	MAIN SUPPLY FAILURE
211	07-Feb-22	TUMKUR	66	TR-1	KUNIGAL_66	11:18	13:35	2:17	LINE CLEAR AVAILED
212	07-Feb-22	TUMKUR	66	TR-1	MAVINAKATTE_66	14:21	14:32	0:11	TRANSFORMER FAULT
213	07-Feb-22	TUMKUR	66	TR-2	BEVINAHALLI_66	12:01	12:36	0:35	LINE CLEAR AVAILED
214	07-Feb-22	TUMKUR	66	TR-2	HONNALLI_220	15:06	15:45	0:39	MAIN SUPPLY FAILURE
215	07-Feb-22	TUMKUR	66	TR-2	HONNALLI_220	11:10	11:14	0:03	LOAD CURTAILMENT
216	07-Feb-22	TUMKUR	66	TR-2	KUNIGAL_66	13:00	13:35	0:35	LINE CLEAR AVAILED
217	07-Feb-22	TUMKUR	66	TR-2	MATHOD_66	17:01	17:09	0:08	TRANSFORMER FAULT
218	07-Feb-22	TUMKUR	66	TR-2(LV2)	HONNALLI_220	15:06	15:45	0:38	MAIN SUPPLY FAILURE
219	07-Feb-22	TUMKUR	110	TR-2	MAYASANDRA_110	15:50	16:53	1:03	LINE CLEAR AVAILED
220	07-Feb-22	TUMKUR	220	DAVANGERE SRS- HONNALLI	HONNALLI_220	15:04	17:13	2:09	LINE FAULT
221	07-Feb-22	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	15:06	17:23	2:17	MAIN SUPPLY FAILURE
222	07-Feb-22	TUMKUR	220	TR-1	HONNALLI_220	15:06	15:43	0:37	MAIN SUPPLY FAILURE