

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 16.07.2019 TO 22.07.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	16-Jul-19	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110,KABBUR_33,VIJAYANAGAR_33	13:40	14:40	1:00	LINE CLEAR AVAILED
2	16-Jul-19	BAGALKOT	220	ALAMATTI1-BAGALKOT	BAGALKOT_220	13:45	20:26	6:41	LINE CLEAR AVAILED
3	16-Jul-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	15:27	15:39	0:12	LINE CLEAR AVAILED
4	16-Jul-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	9:39	17:45	8:06	NFBC ISSUED
5	16-Jul-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	17:52	18:21	0:29	NFBC ISSUED
6	16-Jul-19	BAGALKOT	110	HUBLI-KADANKOPPA	HUBLI_220	11:19	12:02	0:43	LINE CLEAR AVAILED
7	16-Jul-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:52	15:09	3:17	LINE CLEAR AVAILED
8	16-Jul-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:04	14:10	2:06	LINE CLEAR AVAILED
9	16-Jul-19	BAGALKOT	110	SHIVSAGAR SUGAR-SALAHALLI	SALAHALLI_110	0:42	9:08	8:26	LINE FAULT
10	16-Jul-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	17:00	17:14	0:14	LOAD CHANGEOVER
11	16-Jul-19	BENGALURU	66	HV2	AMARJYOTHI	13:51	15:52	2:01	LINE CLEAR AVAILED
12	16-Jul-19	BENGALURU	220	HV2	HSR LAYOUT 220	12:20	12:43	0:22	TRANSFORMER FAULT
13	16-Jul-19	BENGALURU	66	HV2	RR NAGAR	14:02	14:17	0:15	TRANSFORMER FAULT
14	16-Jul-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	12:23	12:51	0:27	MAIN SUPPLY AVAILED
15	16-Jul-19	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	17:16	17:22	0:06	LOAD CHANGEOVER
16	16-Jul-19	GULBARGA	110	HV2	BELLARYSOUTH_110	9:25	16:10	6:45	LINE CLEAR AVAILED
17	16-Jul-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURUGUNTA_110	4:10	4:20	0:10	LINE FAULT
18	16-Jul-19	GULBARGA	110	GURGUNTA-KHEL_IPP,LJVL_IPP	KHEL_IPP, LJVL_IPP	4:10	4:38	0:28	LINE FAULT
19	16-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	11:43	19:06	7:23	LINE CLEAR AVAILED
20	16-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	11:43	19:06	7:23	LINE CLEAR AVAILED
21	16-Jul-19	GULBARGA	110	HV3	HATTI_110	21:30	21:40	0:10	TRANSFORMER FAULT
22	16-Jul-19	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGUR_IPP	21:50	22:11	0:21	LINE FAULT
23	16-Jul-19	GULBARGA	110	KAPNOOR-HUMNBAD1	ALAND_110,KADAGANCHI_110	19:50	19:57	0:07	LINE FAULT
24	16-Jul-19	GULBARGA	110	SINDHANOOR220-PGLRWIND_IPP	SIDHANOOR_220	16:40	17:10	0:30	LINE FAULT
25	16-Jul-19	GULBARGA	110	SINDHANOOR220-SUZLON1_IPP	SIDHANOOR_220	23:28	23:37	0:09	LINE FAULT
26	16-Jul-19	GULBARGA	110	SINDHANOOR220-PGLRWIND_IPP	SIDHANOOR_220	23:35	23:54	0:19	LINE FAULT
27	16-Jul-19	GULBARGA	66	HAMPASAGAR-ITTAGI	HAMPASAGAR_66	10:19	14:18	3:59	MAIN SUPPLY AVAILED
28	16-Jul-19	GULBARGA	66	ITTAGI-CLEANMAX2_IPP	ITTAGI_220	15:19	15:26	0:07	LINE CLEAR AVAILED
29	16-Jul-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	11:24	12:44	1:20	MAIN SUPPLY AVAILED
30	16-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:09	6:43	6:34	LINE CLEAR AVAILED
31	16-Jul-19	HASSAN	220	HV3	KEMAR_220	8:07	18:57	10:50	LINE CLEAR AVAILED
32	16-Jul-19	HASSAN	110	LV3	KEMAR_220	8:04	19:00	10:56	LINE CLEAR AVAILED
33	16-Jul-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:51	14:24	4:33	LINE CLEAR AVAILED
34	16-Jul-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:55	14:24	4:29	LINE CLEAR AVAILED
35	16-Jul-19	HASSAN	110	SAGARA-LST3	SAGARA_110	7:34	7:47	0:13	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
36	16-Jul-19	HASSAN	66	HV1	BYACHANAHALLI_66	19:01	19:07	0:06	TRANSFORMER FAULT
37	16-Jul-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:17	13:45	1:28	LINE CLEAR AVAILED
38	16-Jul-19	HASSAN	66	HV2	HNPURA_66	13:16	13:17	0:01	MAIN SUPPLY AVAILED
39	16-Jul-19	HASSAN	66	HV2	HNPURA_66	17:41	19:20	1:39	LINE CLEAR AVAILED
40	16-Jul-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	13:16	13:58	0:42	LINE FAULT
41	16-Jul-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	12:40	12:50	0:10	LINE FAULT
42	16-Jul-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	8:46	11:17	2:31	LINE CLEAR AVAILED
43	16-Jul-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	8:46	11:17	2:31	LINE CLEAR AVAILED
44	16-Jul-19	MYSORE	66	ELAVALA-HUNSUR	ELAVALA_66 GAVADAGERE_66	8:53	23:59	15:05	LOAD CHANGEOVER
45	16-Jul-19	MYSORE	66	HV1	ELAVALA_66	9:50	10:07	0:17	TRANSFORMER FAULT
46	16-Jul-19	MYSORE	66	HV1	HALAGUR_66	15:24	16:51	1:27	LINE CLEAR AVAILED
47	16-Jul-19	MYSORE	66	HV2	HALAGUR_66	12:20	15:20	3:00	LINE CLEAR AVAILED
48	16-Jul-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66	11:16	11:20	0:03	LOAD CURTAILMENT
49	16-Jul-19	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	11:17	11:21	0:04	LOAD CURTAILMENT
50	16-Jul-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66	11:16	11:23	0:06	LOAD CURTAILMENT
51	16-Jul-19	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	11:12	11:20	0:08	LOAD CURTAILMENT
52	16-Jul-19	MYSORE	66	HV2	KIRUGAVALU_66	15:36	16:26	0:49	LINE CLEAR AVAILED
53	16-Jul-19	MYSORE	66	HV2	KMDODDI_66	7:04	7:15	0:11	TRANSFORMER FAULT
54	16-Jul-19	MYSORE	220	HV1	KUSHALNAGARA_220	8:30	8:43	0:13	TRANSFORMER FAULT
55	16-Jul-19	MYSORE	220	HV2	KUSHALNAGARA_220	8:32	8:43	0:11	TRANSFORMER FAULT
56	16-Jul-19	MYSORE	66	MANDYA-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 MALAVALLI_66 KADKOTHANAHALLI_66 HADLI_66	3:39	4:07	0:28	LINE FAULT
57	16-Jul-19	MYSORE	66	MANDYA-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 MALAVALLI_66 KADKOTHANAHALLI_66 HADLI_66	4:10	4:19	0:09	HAND TRIPPED
58	16-Jul-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 KADKOTHANAHALLI_66 HADLI_66	4:18	4:38	0:20	LOAD CURTAILMENT
59	16-Jul-19	MYSORE	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66	4:18	4:30	0:12	LOAD CURTAILMENT
60	16-Jul-19	MYSORE	66	MANDYA-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 MALAVALLI_66 KADKOTHANAHALLI_66 HADLI_66	15:30	15:40	0:10	LINE FAULT
61	16-Jul-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	11:53	12:13	0:19	LINE FAULT
62	16-Jul-19	TUMKUR	110	TR-1	HALKURKE_110	13:49	14:31	0:41	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
63	16-Jul-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	11:21	11:41	0:20	TRANSFORMER FAULT
64	16-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	14:36	14:51	0:14	TRANSFORMER FAULT
65	16-Jul-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	21:13	21:25	0:12	LINE FAULT
66	16-Jul-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	23:45	23:56	0:10	LINE FAULT
67	16-Jul-19	TUMKUR	66	TR-2	GUTTUR_66	12:42	12:46	0:04	HAND TRIPPED
68	16-Jul-19	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	21:13	21:38	0:25	LINE FAULT
69	16-Jul-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66,BRAHMASAGARA_IPP_66	21:13	21:40	0:27	LINE FAULT
70	16-Jul-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	19:15	19:18	0:02	LINE FAULT
71	16-Jul-19	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	19:15	19:16	0:01	HAND TRIPPED
72	16-Jul-19	TUMKUR	66	TR-1	PANDARAHALLI_66	16:40	16:54	0:14	LINE CLEAR AVAILED
73	16-Jul-19	TUMKUR	66	TR-1	TUMKUR_66	12:07	12:21	0:13	TRANSFORMER FAULT
74	16-Jul-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	14:13	14:21	0:08	HAND TRIPPED
75	17-Jul-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIGATTA_33,SEABIRD_33	10:05	12:08	2:02	LINE CLEAR AVAILED
76	17-Jul-19	BAGALKOT	110	110/11KV,HV1	BELUR_110	15:31	15:45	0:13	TRANSFORMER FAULT
77	17-Jul-19	BAGALKOT	220	FORTUNE 1-BAGEWADI	BAGEWADI_220	12:02	17:24	5:22	LINE FAULT
78	17-Jul-19	BAGALKOT	220	FORTUNE 2-BAGEWADI	BAGEWADI_220	12:02	12:44	0:42	LINE FAULT
79	17-Jul-19	BAGALKOT	220	MASUTHI-BAGEWADI	BAGEWADI_220	12:02	13:34	1:32	LINE FAULT
80	17-Jul-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	12:02	12:36	0:34	LINE FAULT
81	17-Jul-19	BAGALKOT	220	ATRIA-BAGEWADI	BAGEWADI_220	12:02	12:02	0:00	LINE FAULT
82	17-Jul-19	BAGALKOT	220	220/110KV,HV3&LV3	BAGEWADI_220,MUDEDEBIHAL_110,CHIM MALAGI LIS_110	12:02	12:24	0:22	TRANSFORMER FAULT
83	17-Jul-19	BAGALKOT	110	BAGEWADI220-SINDAGI	SINDAGI_110	12:02	12:29	0:27	LINE FAULT
84	17-Jul-19	BAGALKOT	110	110/11KV,HV2	BAGEWADI_220	12:02	12:20	0:18	TRANSFORMER FAULT
85	17-Jul-19	BAGALKOT	110	110/11KV,HV4	GEJENDRAGAD_110	6:20	6:44	0:24	LOAD CURTAILMENT
86	17-Jul-19	BAGALKOT	110	110/11KV,HV1	DAVALESHWARA_110	19:52	22:07	2:15	TRANSFORMER FAULT
87	17-Jul-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	6:20	7:21	1:00	LOAD CURTAILMENT
88	17-Jul-19	BAGALKOT	110	KUDUCHI220-KUDUCHI	KUDUCHI_110	14:46	14:53	0:06	HAND TRIPPED
89	17-Jul-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,HONNAVAR_33	10:33	12:58	2:25	LINE CLEAR AVAILED
90	17-Jul-19	BAGALKOT	110	110/11KV,HV1	LAKMESHVAR_110	6:19	6:28	0:09	LOAD CURTAILMENT
91	17-Jul-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	11:21	16:36	5:15	LINE CLEAR AVAILED
92	17-Jul-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	6:22	6:27	0:04	LOAD CURTAILMENT
93	17-Jul-19	BAGALKOT	220	HUBL-NAGJHARI2	HUBLI_220	13:48	19:25	5:37	LINE FAULT
94	17-Jul-19	BAGALKOT	110	HUBLI-RAMANKOPPA	RAMANKOPPA_110	16:14	23:59	7:45	LINE FAULT
95	17-Jul-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	11:12	16:27	5:15	LINE CLEAR AVAILED
96	17-Jul-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	0:00	11:06	11:06	LINE CLEAR AVAILED
97	17-Jul-19	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	0:00	11:15	11:15	LINE CLEAR AVAILED
98	17-Jul-19	BAGALKOT	110	110/11KV,HV1	MURDESHWAR_110	10:45	12:50	2:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
99	17-Jul-19	BAGALKOT	110	110/11KV,HV2	MUKARTHAL_110	8:34	8:40	0:06	TRANSFORMER FAULT
100	17-Jul-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	14:55	16:05	1:10	LINE CLEAR AVAILED
101	17-Jul-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	MAHALINGAPUR_220	9:40	17:45	8:05	LINE CLEAR AVAILED
102	17-Jul-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	MAHALINGAPUR_220	17:53	18:20	0:27	LINE CLEAR AVAILED
103	17-Jul-19	BAGALKOT	110	110/33KV,HV1	MAHALINGAPUR_220,JAGADAL_33KV,DEM PODAIRY_33KV	19:15	19:25	0:10	LINE CLEAR AVAILED
104	17-Jul-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	15:35	15:42	0:07	MAIN SUPPLY AVAILED
105	17-Jul-19	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMaDU	14:30	14:41	0:11	LOAD CHANGEOVER
106	17-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	15:41	15:49	0:07	LOAD CHANGEOVER
107	17-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	11:07	11:15	0:08	LOAD CHANGEOVER
108	17-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	11:41	11:49	0:08	LOAD CHANGEOVER
109	17-Jul-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:57	15:05	0:08	LINE FAULT
110	17-Jul-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:57	15:05	0:08	LINE FAULT
111	17-Jul-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:12	15:27	0:15	LINE FAULT
112	17-Jul-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:20	16:59	1:39	LINE CLEAR AVAILED
113	17-Jul-19	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	14:59	15:04	0:04	LINE FAULT
114	17-Jul-19	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:38	16:09	0:31	LOAD CURTAILMENT
115	17-Jul-19	BENGALURU	66	HV1	KYALANUR	16:31	17:38	1:06	LINE CLEAR AVAILED
116	17-Jul-19	BENGALURU	66	HV2	KYALANUR	13:17	13:30	0:12	LINE CLEAR AVAILED
117	17-Jul-19	BENGALURU	66	HV2	KYALANUR	16:10	16:17	0:07	LINE CLEAR AVAILED
118	17-Jul-19	BENGALURU	66	HV2	KYALANUR	16:44	16:56	0:12	LINE CLEAR AVAILED
119	17-Jul-19	BENGALURU	66	HV2	SOMANATHPURA	15:44	16:12	0:27	LINE CLEAR AVAILED
120	17-Jul-19	GULBARGA	220	HV1	KUSTAGI_220	15:07	16:37	1:30	TRANSFORMER FAULT
121	17-Jul-19	GULBARGA	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	16:18	18:02	1:44	LINE CLEAR AVAILED
122	17-Jul-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110, BTPSWATER_WORKS	5:00	5:10	0:10	LINE FAULT
123	17-Jul-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110, MADALAPURA_110	3:02	7:10	4:08	LINE FAULT
124	17-Jul-19	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	7:33	7:43	0:10	LINE FAULT
125	17-Jul-19	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	7:53	8:28	0:35	LINE FAULT
126	17-Jul-19	GULBARGA	110	HV3	HANUMASAGAR_110	6:20	7:05	0:45	LOAD CURTAILMENT
127	17-Jul-19	GULBARGA	110	HV1	HANUMASAGAR_110	11:20	12:10	0:50	TRANSFORMER FAULT
128	17-Jul-19	GULBARGA	110	KAPNOOR220-GULBARGANORTH1	GULBARGANORTH_110, GULBARGA_UNIVERSITY_110,	10:15	12:20	2:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
129	17-Jul-19	GULBARGA	110	KAPNOOR220-GULBARGANORTH2	GULBARGANORTH_110, GULBARGA_UNIVERSITY_110,	10:15	10:23	0:08	LINE CLEAR AVAILED
130	17-Jul-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110, HANUMANAL_110	15:07	23:59	8:52	LINE FAULT
131	17-Jul-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGE RA_110,SANNATHI_110,CORE GREEN SUGUR_IPP	20:04	23:22	3:18	LINE FAULT
132	17-Jul-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	23:00	23:30	0:30	LINE CLEAR AVAILED
133	17-Jul-19	GULBARGA	110	SHAHPUR-SHAHAPUR1	SHAHPUR_110,NALWAR_110	23:00	23:48	0:48	LINE CLEAR AVAILED
134	17-Jul-19	GULBARGA	110	SHAHPUR-SHAHAPUR2	GOOGLE_110	23:34	23:41	0:07	LINE CLEAR AVAILED
135	17-Jul-19	GULBARGA	110	SHAHPUR-WARDHASOLAR_IPP	SHAHPUR_220	23:00	23:51	0:51	LINE CLEAR AVAILED
136	17-Jul-19	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	22:30	22:39	0:09	LINE FAULT
137	17-Jul-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	23:27	23:40	0:13	LINE FAULT
138	17-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	10:50	23:59	13:09	LINE CLEAR AVAILED
139	17-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	10:50	18:45	7:55	LINE CLEAR AVAILED
140	17-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:58	23:59	1:01	LINE CLEAR AVAILED
141	17-Jul-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:16	11:58	0:42	LINE CLEAR AVAILED
142	17-Jul-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:24	16:13	4:49	LINE CLEAR AVAILED
143	17-Jul-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:01	11:58	0:57	NFBC ISSUED
144	17-Jul-19	HASSAN	110	HV1	BRAHMAVARA_110	6:20	6:25	0:05	MAIN SUPPLY AVAILED
145	17-Jul-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:52	16:22	2:30	LINE CLEAR AVAILED
146	17-Jul-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:08	13:10	3:02	LINE CLEAR AVAILED
147	17-Jul-19	HASSAN	110	SALATHUR-NTMDNOR	SALATHUR_110	10:30	13:30	3:00	NFBC ISSUED
148	17-Jul-19	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	5:50	6:02	0:12	LINE FAULT
149	17-Jul-19	HASSAN	66	HV1	SATHENAHALLY_66	16:40	18:45	2:05	LINE CLEAR AVAILED
150	17-Jul-19	HASSAN	66	HV2	SINGAPURA_66	13:26	13:39	0:13	LINE CLEAR AVAILED
151	17-Jul-19	HASSAN	66	USSURKO-HASSAN1	UDDURKOPLU_66	5:50	6:03	0:13	MAIN SUPPLY AVAILED
152	17-Jul-19	MYSORE	66	BG NAGARA-NAGAMANGALA	ADICHUNCHANAGIRI_66 BGNAGARA_66 VADERALLI_66	11:09	14:25	3:16	NFBC ISSUED
153	17-Jul-19	MYSORE	66	HV2	HAMPAPURA_66	12:19	12:27	0:07	TRANSFORMER FAULT
154	17-Jul-19	MYSORE	66	HV2	HONNALLY_MYS_66	12:38	13:30	0:52	HAND TRIPPED
155	17-Jul-19	MYSORE	66	HV2	JAIPUR_66	6:19	6:39	0:19	LOAD CURTAILMENT
156	17-Jul-19	MYSORE	66	HV2	KMDODDI_66	6:19	6:44	0:25	LOAD CURTAILMENT
157	17-Jul-19	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	15:20	15:59	0:38	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
158	17-Jul-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	14:57	15:05	0:07	LINE FAULT
159	17-Jul-19	MYSORE	220	HV1	MADHUVANAHALLI_220	11:41	14:51	3:09	LINE CLEAR AVAILED
160	17-Jul-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	13:09	13:51	0:42	LOAD CHANGEOVER
161	17-Jul-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	13:05	13:43	0:38	HAND TRIPPED
162	17-Jul-19	MYSORE	220	HV2	TUBINAKERE_220	13:10	13:42	0:32	LINE CLEAR AVAILED
163	17-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	BASARALU_66 SHIVALLY_66 KESLAGERE_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	10:50	14:10	3:20	LINE CLEAR AVAILED
164	17-Jul-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	20:48	21:44	0:55	LINE FAULT
165	17-Jul-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	21:45	21:52	0:07	LINE FAULT
166	17-Jul-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:56	18:45	8:49	LINE CLEAR AVAILED
167	17-Jul-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:56	18:48	8:52	LINE CLEAR AVAILED
168	17-Jul-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	11:00	19:13	8:13	MAIN SUPPLY AVAILED
169	17-Jul-19	TUMKUR	66	TR-1	HARIHAR_66	11:00	19:13	8:13	MAIN SUPPLY AVAILED
170	17-Jul-19	TUMKUR	66	TR-2	HARIHAR_66	11:00	19:13	8:13	MAIN SUPPLY AVAILED
171	17-Jul-19	TUMKUR	66	TR-1	HULIYURDURGA_66	13:13	14:23	1:09	LINE CLEAR AVAILED
172	17-Jul-19	TUMKUR	66	TR-2	HULIYURDURGA_66	13:48	14:34	0:45	LINE CLEAR AVAILED
173	17-Jul-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	17:41	18:14	0:33	LINE FAULT
174	17-Jul-19	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	20:50	22:38	1:48	LINE CLEAR AVAILED
175	17-Jul-19	TUMKUR	66	THALLAK 220KV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:42	22:20	3:38	LINE CLEAR AVAILED
176	18-Jul-19	BAGALKOT	110	110/11KV,HV2	DAVALESHWAR_110	9:49	14:35	4:46	LINE CLEAR AVAILED
177	18-Jul-19	BAGALKOT	110	110/11KV,HV1	DAVALESHWAR_110	11:00	11:55	0:55	LINE CLEAR AVAILED
178	18-Jul-19	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR_110	13:01	14:26	1:25	LINE CLEAR AVAILED
179	18-Jul-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	7:13	23:59	16:46	LINE CLEAR AVAILED
180	18-Jul-19	BAGALKOT	110	GHATAPRABHA220-P G HUNSYAL	P G HUNSYAL_110	12:32	14:18	1:46	LINE CLEAR AVAILED
181	18-Jul-19	BAGALKOT	110	KUDUCHI220-KUDUDCHI	KUDUCHI_110	10:26	16:31	6:05	LINE CLEAR AVAILED
182	18-Jul-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	SOUDATTI_220	13:26	16:11	2:45	LINE FAULT
183	18-Jul-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	10:00	14:05	4:05	LINE CLEAR AVAILED
184	18-Jul-19	BAGALKOT	110	110/11KV,HV2	NAVANAGAR(H)_110	10:00	14:05	4:05	LINE CLEAR AVAILED
185	18-Jul-19	BAGALKOT	110	P G HUNSYAL-MUDALAGI	MUDALAGI_110	12:35	14:55	2:20	LINE CLEAR AVAILED
186	18-Jul-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,HALASANGI_33 KV,DHULKHED_33KV	7:10	7:17	0:07	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
187	18-Jul-19	BAGALKOT	110	HUBLI-RAMANKOPPA	RAMANKOPPA_110	13:55	17:46	3:51	LINE CLEAR AVAILED
188	18-Jul-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	12:58	18:20	5:22	LINE FAULT
189	18-Jul-19	BAGALKOT	110	TADASINKOPPA-TARIHAL	TARIHAL_110	12:24	16:47	4:23	LINE CLEAR AVAILED
190	18-Jul-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	13:24	14:19	0:55	LINE CLEAR AVAILED
191	18-Jul-19	BENGALURU	66	SOMENAHALLI - IRGAMPALLI	SOMENAHALLI	10:15	10:25	0:10	LOAD CHANGEVER
192	18-Jul-19	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	17:00	17:20	0:20	LOAD CHANGEVER
193	18-Jul-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:03	13:12	0:09	LINE FAULT
194	18-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:20	11:33	0:12	LINE FAULT
195	18-Jul-19	BENGALURU	66	HV1	GOLF LINKS	14:47	15:29	0:41	LINE CLEAR AVAILED
196	18-Jul-19	BENGALURU	66	BMRCL	KHODAYS 220	15:57	16:26	0:28	LINE CLEAR AVAILED
197	18-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	18:00	19:02	1:02	LINE FAULT
198	18-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	18:00	19:02	1:02	LINE FAULT
199	18-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	20:53	22:14	1:21	LINE FAULT
200	18-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	20:53	22:14	1:21	LINE FAULT
201	18-Jul-19	GULBARGA	220	RAICHUR-JURALA1,2	RAICHUR_220	8:00	23:59	15:59	NFBC ISSUED
202	18-Jul-19	GULBARGA	220	HV1	SIDHANOOR_220	17:45	18:55	1:10	LINE CLEAR AVAILED
203	18-Jul-19	GULBARGA	220	HV2	SIDHANOOR_220	18:50	19:30	0:40	LINE CLEAR AVAILED
204	18-Jul-19	GULBARGA	220	HV1	ITTAGI_220	11:32	12:38	1:06	LINE CLEAR AVAILED
205	18-Jul-19	GULBARGA	220	LINGAPUR-JVSL1	JINDAL_220	14:44	15:57	1:13	LINE CLEAR AVAILED
206	18-Jul-19	GULBARGA	220	HV2	KUSTAGI_220	13:15	13:22	0:07	TRANSFORMER FAULT
207	18-Jul-19	GULBARGA	220	SINDHANOOR220-LINGASUGUR	SIDHANOOR_220	15:39	16:17	0:38	LINE CLEAR AVAILED
208	18-Jul-19	GULBARGA	220	SINDHANOOR220-LINGAPUR	SIDHANOOR_220	16:22	16:50	0:28	LINE CLEAR AVAILED
209	18-Jul-19	GULBARGA	110	KAPNOOR-GULBARGA NORTH1	GULBARGANORTH_110, GULBARGA_UNIVERSITY_110,	10:22	13:44	3:22	LINE CLEAR AVAILED
210	18-Jul-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110	0:00	7:21	7:21	LINE FAULT
211	18-Jul-19	GULBARGA	110	HV2	RAICHUR_220	10:30	14:00	3:30	LINE CLEAR AVAILED
212	18-Jul-19	GULBARGA	110	HV1	RAICHUR_220	13:39	13:59	0:20	LINE CLEAR AVAILED
213	18-Jul-19	GULBARGA	110	SHAHPUR-WARDHASOLAR_IPP	SHAHPUR_220	10:52	11:19	0:27	LINE CLEAR AVAILED
214	18-Jul-19	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	15:15	16:40	1:25	LINE FAULT
215	18-Jul-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	13:15	13:30	0:15	MAIN SUPPLY AVAILED
216	18-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	12:27	19:49	7:22	LINE CLEAR AVAILED
217	18-Jul-19	GULBARGA	110	MARAGUTTI-CLNSLR_IPP	MARAGUTTI_110,MAHAGAON_110	19:15	23:30	4:15	LINE CLEAR AVAILED
218	18-Jul-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	19:00	20:00	1:00	LINE FAULT
219	18-Jul-19	GULBARGA	66	ITTAGI-KUDILIGI1,2	KUDILIGI_66,CJHALLI_66,GUDEKOTE_66,H OSAHALLI_66,BANVEKAL_66,CHORNOOR_66	13:15	17:40	4:25	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
220	18-Jul-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66, GUDEKOTE_66,BANAVEKAL_66,HOSAHALLI_66,CHORNOOR_66	9:00	9:07	0:07	LINE FAULT
221	18-Jul-19	GULBARGA	66	HV1	HAMPASAGAR_66	12:28	12:38	0:10	LINE CLEAR AVAILED
222	18-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:53	6:53	LINE CLEAR AVAILED
223	18-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:42	23:59	1:17	LINE CLEAR AVAILED
224	18-Jul-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	11:07	13:22	2:15	LINE CLEAR AVAILED
225	18-Jul-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:08	13:41	2:33	LINE CLEAR AVAILED
226	18-Jul-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	14:30	15:53	1:23	LINE CLEAR AVAILED
227	18-Jul-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:16	16:13	1:57	LINE CLEAR AVAILED
228	18-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	14:09	23:59	9:50	LINE FAULT
229	18-Jul-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	11:07	13:23	2:16	LINE CLEAR AVAILED
230	18-Jul-19	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	11:08	13:41	2:33	NFBC ISSUED
231	18-Jul-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	14:30	15:53	1:23	NFBC ISSUED
232	18-Jul-19	HASSAN	110	LV2	PUTTUR_220	11:28	13:26	1:58	LINE CLEAR AVAILED
233	18-Jul-19	HASSAN	110	HV2	HALADY_110	11:23	11:58	0:35	LINE CLEAR AVAILED
234	18-Jul-19	HASSAN	110	HV2	KADUR_220	7:43	8:17	0:34	HAND TRIPPED
235	18-Jul-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	7:43	8:01	0:18	HAND TRIPPED
236	18-Jul-19	HASSAN	110	HV1	MRSMSG_220	9:07	13:42	4:35	LINE CLEAR AVAILED
237	18-Jul-19	HASSAN	66	LV1	MRSMSG_220	9:07	13:43	4:36	LINE CLEAR AVAILED
238	18-Jul-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:38	11:42	0:04	HAND TRIPPED
239	18-Jul-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	12:05	15:59	3:54	LINE CLEAR AVAILED
240	18-Jul-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	12:05	15:59	3:54	LINE CLEAR AVAILED
241	18-Jul-19	MYSORE	66	BG NAGARA-NAGAMANGALA	ADICHUNCHANAGIRI_66 BGNAGARA_66 VADERALLI_66	6:30	11:41	5:11	NFBC ISSUED
242	18-Jul-19	MYSORE	66	HV1	BOGADHI_66	11:25	12:43	1:17	LINE CLEAR AVAILED
243	18-Jul-19	MYSORE	66	HV2	HAMPAPURA_66	22:02	22:25	0:23	TRANSFORMER FAULT
244	18-Jul-19	MYSORE	66	HV2	HAMPAPURA_66	22:35	22:59	0:24	TRANSFORMER FAULT
245	18-Jul-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66, GAVADAGERE_66	17:21	17:24	0:02	HAND TRIPPED
246	18-Jul-19	MYSORE	66	HOOTAGALLI-KHB STATION	KHBCOLONY_66	17:24	17:28	0:04	HAND TRIPPED
247	18-Jul-19	MYSORE	66	HV2	MADDUR_66	11:35	11:46	0:11	LINE CLEAR AVAILED
248	18-Jul-19	MYSORE	66	HV2	PANDYADAHUNDI_66	14:48	15:15	0:27	LINE CLEAR AVAILED
249	18-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66, KESLAGERE_66	6:08	6:15	0:07	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
250	18-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66, KESLAGERE_66	6:15	6:30	0:15	LINE FAULT
251	18-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66,BASARALU_66, SHIVALLY_66, KESLAGERE_66	6:42	10:20	3:38	LINE CLEAR AVAILED
252	18-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66, SHIVALLY_66	10:20	11:20	1:00	LINE FAULT
253	18-Jul-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	14:28	14:43	0:15	LINE FAULT
254	18-Jul-19	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	9:07	14:14	5:07	LINE CLEAR AVAILED
255	18-Jul-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	13:14	14:11	0:56	LINE CLEAR AVAILED
256	18-Jul-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	13:14	13:44	0:29	LINE CLEAR AVAILED
257	18-Jul-19	TUMKUR	66	TR-1 & TR-2	CHIKKABANAGERE_66	13:12	13:50	0:38	LINE CLEAR AVAILED
258	18-Jul-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	16:53	17:15	0:22	LINE CLEAR AVAILED
259	18-Jul-19	TUMKUR	66	TR-1	HARIHAR_66	16:53	17:15	0:22	LINE CLEAR AVAILED
260	18-Jul-19	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	9:07	14:14	5:07	LINE CLEAR AVAILED
261	18-Jul-19	TUMKUR	66	TR-3	HONNALI_66	11:34	13:01	1:27	TRANSFORMER FAULT
262	18-Jul-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_6 6	20:44	20:46	0:02	LINE FAULT
263	18-Jul-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	10:05	10:07	0:01	HAND TRIPPED
264	18-Jul-19	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	10:05	14:18	4:13	LINE CLEAR AVAILED
265	18-Jul-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:05	12:07	2:02	LINE CLEAR AVAILED
266	18-Jul-19	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	12:27	13:04	0:37	LINE CLEAR AVAILED
267	18-Jul-19	TUMKUR	66	TR-1	PANDARAHALLI_66	10:33	17:26	6:53	LINE CLEAR AVAILED
268	19-Jul-19	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	15:54	16:17	0:23	LINE FAULT
269	19-Jul-19	BAGALKOT	220	ATRIYA1-BAGEWADI	BAGEWADI_220	16:22	17:15	0:53	LINE CLEAR AVAILED
270	19-Jul-19	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	5:54	6:23	0:29	LINE FAULT
271	19-Jul-19	BAGALKOT	220	220/110KV,HV3,LV3	GADAG_220	8:55	16:58	8:03	LINE CLEAR AVAILED
272	19-Jul-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	7:28	7:44	0:16	LOAD CURTAILMENT
273	19-Jul-19	BAGALKOT	110	110/11KV,HV1	GOKAK_110	12:00	17:50	5:50	LINE CLEAR AVAILED
274	19-Jul-19	BAGALKOT	110	110/33KV,HV2	GOKAK_110,RIDDISIDDI_33KV	12:00	18:05	6:05	LINE CLEAR AVAILED
275	19-Jul-19	BAGALKOT	110	110/11KV,HV3	GOKAK_110	12:40	17:10	4:30	LINE CLEAR AVAILED
276	19-Jul-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,MARYAKAL_33KV	11:10	14:50	3:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
277	19-Jul-19	BAGALKOT	110	VIJAYA NAGAR SUGARS-MUNDARGI	MUNDARGI_110	16:19	18:56	2:37	LINE CLEAR AVAILED
278	19-Jul-19	BAGALKOT	66	110/33KV,HV4	HARHAR-HOSPET_66,AREMALLAPUR_33	7:28	8:05	0:37	LOAD CURTAILMENT
279	19-Jul-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	15:54	17:40	1:46	LINE FAULT
280	19-Jul-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	9:26	14:39	5:13	NFBC ISSUED
281	19-Jul-19	BAGALKOT	110	MAHALINGAPUR(RANNABELAGALI)-UTTUR	UTTUR_110	16:15	23:59	7:44	LINE FAULT
282	19-Jul-19	BAGALKOT	220	SHARAVATHI1&2-SIRSI220	SIRSI_220	23:16	23:59	0:43	HAND TRIPPED
283	19-Jul-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	12:19	13:53	1:34	LINE CLEAR AVAILED
284	19-Jul-19	BAGALKOT	110	RON -GAJENDRAGAD2	GAJENDRAGAD_110	12:20	23:59	11:39	LINE FAULT
285	19-Jul-19	BAGALKOT	110	NAREGAL-RON	RON_110	12:20	13:05	0:45	MAIN SUPPLY AVAILED
286	19-Jul-19	BAGALKOT	110	110/11KV,HV1,HV2,HV3	RON_110	12:20	13:10	0:50	TRANSFORMER FAULT
287	19-Jul-19	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33KV	7:29	7:40	0:11	LOAD CURTAILMENT
288	19-Jul-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	14:34	14:41	0:07	TRANSFORMER FAULT
289	19-Jul-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	13:54	17:45	3:51	LINE FAULT
290	19-Jul-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	20:56	21:29	0:33	TRANSFORMER FAULT
291	19-Jul-19	BENGALURU	66	APPAREL PARK - KIADB DB PURA 220	APPAREL	12:59	13:54	0:55	LOAD CHANGEOVER
292	19-Jul-19	BENGALURU	66	APPAREL PARK - DB PURA 220	APPAREL	13:54	14:02	0:07	LOAD CHANGEOVER
293	19-Jul-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	16:22	16:52	0:29	LINE FAULT
294	19-Jul-19	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	14:47	15:32	0:45	MAIN SUPPLY AVAILED
295	19-Jul-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	TUBUGERE	16:03	16:12	0:08	LINE FAULT
296	19-Jul-19	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSNUR	15:10	15:26	0:16	MAIN SUPPLY AVAILED
297	19-Jul-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:32	16:23	0:50	MAIN SUPPLY AVAILED
298	19-Jul-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	15:28	16:24	0:55	MAIN SUPPLY AVAILED
299	19-Jul-19	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:37	14:48	0:10	MAIN SUPPLY AVAILED
300	19-Jul-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:15	13:05	0:50	LINE CLEAR AVAILED
301	19-Jul-19	BENGALURU	66	HV2	MELEHALLI	14:20	15:05	0:45	LINE CLEAR AVAILED
302	19-Jul-19	BENGALURU	66	HV3	YERANDANAHALLI 2200	7:42	7:51	0:09	TRANSFORMER FAULT
303	19-Jul-19	BENGALURU	66	HV1	SIDDALAGATTA	2:51	3:00	0:08	TRANSFORMER FAULT
304	19-Jul-19	BENGALURU	66	HV2	THIMMAMPALLI	12:43	12:53	0:09	LINE CLEAR AVAILED
305	19-Jul-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:53	15:20	0:27	MAIN SUPPLY AVAILED
306	19-Jul-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:14	16:19	0:05	LINE CLEAR AVAILED
307	19-Jul-19	GULBARGA	220	RAICHUR-JURALA1,2	RAICHUR_220	0:00	14:47	14:47	NFBC ISSUED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
308	19-Jul-19	GULBARGA	220	HV2	LINGASUGUR_220	5:55	6:55	1:00	TRANSFORMER FAULT
309	19-Jul-19	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	11:24	19:53	8:29	NFBC ISSUED
310	19-Jul-19	GULBARGA	220	RTPS-SEDAM	SEDAM_220	22:16	22:43	0:27	LINE FAULT
311	19-Jul-19	GULBARGA	110	HV4	YELBURGA_110	7:29	7:49	0:20	LOAD CURTAILMENT
312	19-Jul-19	GULBARGA	110	WADI-SHAHBAD220	WADI_110	10:55	13:50	2:55	LINE CLEAR AVAILED
313	19-Jul-19	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	5:49	6:15	0:26	LINE FAULT
314	19-Jul-19	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	VICATSAGAR_IPP	3:05	3:10	0:05	LINE FAULT
315	19-Jul-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	4:35	4:45	0:10	LINE FAULT
316	19-Jul-19	GULBARGA	110	SHAHPUR220-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	3:29	3:46	0:17	LINE FAULT
317	19-Jul-19	GULBARGA	110	SHAHPUR220-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	5:04	5:12	0:08	LINE FAULT
318	19-Jul-19	GULBARGA	110	SHAHPUR220-KEMBHAVI2	KBJNL_IPP	5:44	5:50	0:06	LINE FAULT
319	19-Jul-19	GULBARGA	110	HV2	RAICHUR_220	11:36	11:47	0:11	LINE CLEAR AVAILED
320	19-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	SINDHANOOR_110	2:28	2:36	0:08	LINE FAULT
321	19-Jul-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, CHOWDAPUR_110,NSLSUGARS_IPP	6:45	6:53	0:08	LINE FAULT
322	19-Jul-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	5:40	5:50	0:10	LINE FAULT
323	19-Jul-19	GULBARGA	110	HATTI-SOMANMARADI_IPP	HATTI_110	5:52	6:10	0:18	LINE FAULT
324	19-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	1:49	2:10	0:21	LINE FAULT
325	19-Jul-19	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110	5:56	6:09	0:13	LINE FAULT
326	19-Jul-19	GULBARGA	110	HV1	GABUR_110	7:29	7:35	0:06	LOAD CURTAILMENT
327	19-Jul-19	GULBARGA	110	BHALKI-HALBURGA	BHALKI_110	3:45	3:50	0:05	LINE FAULT
328	19-Jul-19	GULBARGA	110	BHALKI-LADHA	LADHA_110	3:45	4:50	1:05	LINE FAULT
329	19-Jul-19	GULBARGA	110	CHITGUPPA-HUMNABAD	CHITAGUPPA_110	5:35	5:50	0:15	LINE FAULT
330	19-Jul-19	GULBARGA	110	HV2	CHITAGUPPA_110	15:09	16:13	1:04	TRANSFORMER FAULT
331	19-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	LJVL_IPP	11:05	16:59	5:54	LINE CLEAR AVAILED
332	19-Jul-19	GULBARGA	110	LINGASUGUR-CHAYADEVI_IPP	LINGASUGUR_220	11:40	17:20	5:40	LINE CLEAR AVAILED
333	19-Jul-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	6:44	6:54	0:10	LINE FAULT
334	19-Jul-19	GULBARGA	110	PDHALLI-BASAI STEELS_IPP	PDHALLI_110	17:50	17:52	0:02	LINE CLEAR AVAILED
335	19-Jul-19	GULBARGA	110	PDHALLI-BASAI STEELS_IPP	PDHALLI_110	18:09	18:11	0:02	LINE CLEAR AVAILED
336	19-Jul-19	GULBARGA	110	SINDHANOOR-SRERAMNAGAR	SRERAMANAGAR_110	10:00	17:00	7:00	LINE CLEAR AVAILED
337	19-Jul-19	GULBARGA	110	SIDHANOOR-RAICHUR1	VALKAMDINNI_110,ALKOD_110,SIRWAR_1 10,BYAGWAT_110	21:19	21:32	0:13	LINE FAULT
338	19-Jul-19	GULBARGA	66	HV1	CJHALLI_66	7:20	7:29	0:09	LOAD CURTAILMENT
339	19-Jul-19	GULBARGA	66	HV1, HV2	TAMBRAHALLI_66	12:50	13:20	0:30	LINE CLEAR AVAILED
340	19-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:30	6:30	LINE CLEAR AVAILED
341	19-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:42	23:59	1:17	LINE CLEAR AVAILED
342	19-Jul-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	15:25	16:26	1:01	NFBC ISSUED
343	19-Jul-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	16:31	17:21	0:50	NFBC ISSUED
344	19-Jul-19	HASSAN	220	KADUR-DABUSET	KADUR_220	11:44	22:04	10:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
345	19-Jul-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	12:31	13:36	1:05	NFBC ISSUED
346	19-Jul-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	9:42	12:27	2:45	LINE CLEAR AVAILED
347	19-Jul-19	HASSAN	220	KEMAR-UPCL1	KEMAR-220	15:25	16:26	1:01	LINE CLEAR AVAILED
348	19-Jul-19	HASSAN	220	KEMAR-UPCL2	KEMAR-220	16:31	17:21	0:50	LINE CLEAR AVAILED
349	19-Jul-19	HASSAN	220	KEMAR-Varahi2	KEMAR-220	10:04	13:34	3:30	LINE CLEAR AVAILED
350	19-Jul-19	HASSAN	220	KEMAR-Varahi3	KEMAR-220	13:45	14:50	1:05	LINE CLEAR AVAILED
351	19-Jul-19	HASSAN	220	KEMAR-KAVOOR3	KEMAR-220	12:31	13:37	1:06	LINE CLEAR AVAILED
352	19-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	0:00	11:23	11:23	LINE FAULT
353	19-Jul-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:03	13:34	3:31	NFBC ISSUED
354	19-Jul-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	13:43	14:50	1:07	NFBC ISSUED
355	19-Jul-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:36	13:06	0:30	MAIN SUPPLY AVAILED
356	19-Jul-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:10	15:35	1:25	MAIN SUPPLY AVAILED
357	19-Jul-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	14:10	15:35	1:25	MAIN SUPPLY AVAILED
358	19-Jul-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	12:36	13:05	0:29	MAIN SUPPLY AVAILED
359	19-Jul-19	HASSAN	110	HV3	BAIKAMPADI_110	11:42	11:44	0:02	TRANSFORMER FAULT
360	19-Jul-19	HASSAN	110	HV1	JAVAGAL_110	7:31	7:39	0:08	TRANSFORMER FAULT
361	19-Jul-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:16	15:42	1:26	LINE CLEAR AVAILED
362	19-Jul-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	14:58	16:34	1:36	LINE CLEAR AVAILED
363	19-Jul-19	HASSAN	66	HV1	SATHENAHALLY_66	7:30	8:01	0:31	LOAD CURTAILMENT
364	19-Jul-19	MYSORE	66	CR NAGARA-PANYADAHUNDI	PANDYADAHUNDI_66 KARYA_66 HEMMARGALA_66	19:50	19:58	0:07	LINE FAULT
365	19-Jul-19	MYSORE	66	HV2	FTS_66	11:02	12:53	1:51	LINE CLEAR AVAILED
366	19-Jul-19	MYSORE	66	HAMPAPURA(K)-SARGUR 1	HAMPAPURA(K)_66	10:11	10:44	0:32	LINE FAULT
367	19-Jul-19	MYSORE	66	HV2	KIRUGAVALU_66	7:30	8:01	0:30	LOAD CURTAILMENT
368	19-Jul-19	MYSORE	66	KR PETE 220-MADESHWARAPURA	G MALLIGERE_66 JAKKANAHALLY_66 GUDDENAHALLI_66 NAGAMANGALA_66 BOGADHI MANDYA_66 MADESWARAPURA_66	7:29	7:40	0:10	LINE FAULT
369	19-Jul-19	MYSORE	66	HV1	PANDAVAPURA_66	7:31	7:45	0:14	LOAD CURTAILMENT
370	19-Jul-19	MYSORE	66	HV1	PANDAVAPURA_66	15:53	16:02	0:09	HAND TRIPPED
371	19-Jul-19	MYSORE	66	HV2	PANDAVAPURA_66	15:53	16:02	0:09	HAND TRIPPED
372	19-Jul-19	MYSORE	66	HV2	SANTHESARAGUR_66	7:31	7:40	0:09	LOAD CURTAILMENT
373	19-Jul-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:31	8:03	0:31	LOAD CURTAILMENT
374	19-Jul-19	MYSORE	66	HV3	SFCSHIVA_66	9:42	23:59	14:16	LINE CLEAR AVAILED
375	19-Jul-19	MYSORE	66	HV4	SFCSHIVA_66	9:43	23:59	14:15	LINE CLEAR AVAILED
376	19-Jul-19	TUMKUR	110	HONNAVALI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	16:36	17:20	0:44	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
377	19-Jul-19	TUMKUR	110	HONNAVALI 110-DMKURKE	DMKURKE_110	16:36	17:20	0:44	LINE CLEAR AVAILED
378	19-Jul-19	TUMKUR	110	TR-1	HONNAVALI_110	16:36	17:20	0:44	LINE CLEAR AVAILED
379	19-Jul-19	TUMKUR	110	HONNAVALI 110- KADUR220	HONNAVALI_110	16:36	17:20	0:44	LINE CLEAR AVAILED
380	19-Jul-19	TUMKUR	110	HONNAVALI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUNSEGHA TTA_110	16:36	17:20	0:44	LINE CLEAR AVAILED
381	19-Jul-19	TUMKUR	110	TR-1	KADABA_110	15:28	17:35	2:06	LINE CLEAR AVAILED
382	19-Jul-19	TUMKUR	66	TR-1	HANGLA_66	12:29	12:40	0:10	LINE CLEAR AVAILED
383	19-Jul-19	TUMKUR	66	TR-2	HARIHAR_66	16:35	16:47	0:12	HAND TRIPPED
384	19-Jul-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_6 6	0:53	1:07	0:14	HAND TRIPPED
385	19-Jul-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	13:00	13:09	0:09	LINE FAULT
386	19-Jul-19	TUMKUR	66	TR-1	PANDARAHALLI_66	10:22	18:13	7:51	LINE CLEAR AVAILED
387	19-Jul-19	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	19:03	22:41	3:38	LINE CLEAR AVAILED
388	20-Jul-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	10:36	12:47	2:11	LINE CLEAR AVAILED
389	20-Jul-19	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_110	10:47	12:16	1:29	NFBC ISSUED
390	20-Jul-19	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	11:35	12:13	0:38	HAND TRIPPED
391	20-Jul-19	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	18:28	19:03	0:35	LINE FAULT
392	20-Jul-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	12:11	13:19	1:08	LINE CLEAR AVAILED
393	20-Jul-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	13:51	14:06	0:15	HAND TRIPPED
394	20-Jul-19	BAGALKOT	110	GADAG-BETEGERI	BETEGERI_110	0:23	0:50	0:27	LINE FAULT
395	20-Jul-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	0:23	1:05	0:42	LINE FAULT
396	20-Jul-19	BAGALKOT	220	BIDNAL-TADAS2	BIDNAL_220	10:28	19:35	9:07	LINE CLEAR AVAILED
397	20-Jul-19	BAGALKOT	220	BIDNAL-HUBLI3	BIDNAL_220	11:38	19:50	8:12	LINE CLEAR AVAILED
398	20-Jul-19	BAGALKOT	110	BELGAUM220-UCHAGOAN(HUKKERI)	UCHAGOAN_110	6:08	10:06	3:58	LINE FAULT
399	20-Jul-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	18:09	18:39	0:30	LINE FAULT
400	20-Jul-19	BAGALKOT	110	GADAG ROAD -GOPANAKOPPA	GOPANAKOPPA_110	14:43	23:59	9:16	LINE FAULT
401	20-Jul-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:50	19:22	6:32	LINE FAULT
402	20-Jul-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	11:51	19:45	7:54	NFBC ISSUED
403	20-Jul-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	11:20	12:08	0:48	LINE CLEAR AVAILED
404	20-Jul-19	BAGALKOT	110	SHIVSAGAR SUGARS-SALAHALLI	SALAHALLI_110	9:00	10:20	1:20	LINE FAULT
405	20-Jul-19	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	14:09	15:53	1:44	LINE CLEAR AVAILED
406	20-Jul-19	BAGALKOT	110	RON-GAJENDRAGAD2	GAJENDRAGAD_110	0:23	14:41	14:18	LINE FAULT
407	20-Jul-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	0:23	1:17	0:54	HAND TRIPPED
408	20-Jul-19	BAGALKOT	110	110/11KV, HV1	NANADI_110	12:01	17:02	5:01	LINE CLEAR AVAILED
409	20-Jul-19	BAGALKOT	110	110/11KV, HV2	NANADI_110	10:12	18:06	7:54	LINE CLEAR AVAILED
410	20-Jul-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	12:58	17:01	4:03	LINE CLEAR AVAILED
411	20-Jul-19	BAGALKOT	110	DADDANAVARSOLAR-NANDI	NANADI_110	12:58	17:36	4:38	LINE CLEAR AVAILED
412	20-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDAGANUR_110	11:02	12:45	1:43	TRANSFORMER FAULT
413	20-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDAGANUR_110	14:31	17:03	2:32	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
414	20-Jul-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	16:08	16:13	0:05	LINE CLEAR AVAILED
415	20-Jul-19	BAGALKOT	110	NAREGAL-RON	RON_110	0:23	1:08	0:45	LINE FAULT
416	20-Jul-19	BAGALKOT	220	KUDACHI-MAHALINGAPUR	KUDACHI_220	7:59	9:57	1:58	LINE FAULT
417	20-Jul-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	12:38	15:30	2:52	LINE CLEAR AVAILED
418	20-Jul-19	BAGALKOT	110	110/11KV, HV1	KONNUR_110	12:38	16:32	3:54	LINE CLEAR AVAILED
419	20-Jul-19	BAGALKOT	110	HAVER220-SAVANUR	SAVANUR_110	8:53	11:45	2:52	LINE CLEAR AVAILED
420	20-Jul-19	BAGALKOT	110	110/33KV, HV4	GADAG_110, LAKKUNDI_33, HULKOTI_33, TDPL1&2_33	9:32	13:00	3:28	LINE CLEAR AVAILED
421	20-Jul-19	BENGALURU	66	HV1	ATTIBELE	13:15	13:22	0:07	LINE CLEAR AVAILED
422	20-Jul-19	BENGALURU	66	HV2	BANASWADI	10:01	10:22	0:21	LOAD CHANGEVER
423	20-Jul-19	BENGALURU	66	HV2	BANASWADI	15:15	15:19	0:04	LOAD CHANGEVER
424	20-Jul-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	10:15	15:05	4:50	LINE CLEAR AVAILED
425	20-Jul-19	BENGALURU	66	HV1	CHIKKABALLAPURA I/A	8:20	9:25	1:04	TRANSFORMER FAULT
426	20-Jul-19	BENGALURU	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	8:20	9:25	1:04	LINE FAULT
427	20-Jul-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	8:20	9:25	1:04	LINE FAULT
428	20-Jul-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:37	12:43	1:06	LINE CLEAR AVAILED
429	20-Jul-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	11:37	12:43	1:06	LINE CLEAR AVAILED
430	20-Jul-19	BENGALURU	66	HV2	DODDABELAVANGALA	9:33	10:09	0:35	LINE CLEAR AVAILED
431	20-Jul-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:35	13:40	0:05	TRANSFORMER FAULT
432	20-Jul-19	BENGALURU	66	HV1	KYALANUR	9:39	9:46	0:06	TRANSFORMER FAULT
433	20-Jul-19	BENGALURU	66	SADLI - CHINTAMANI 220	SADLI, JULUPALYA	10:10	10:11	0:01	LOAD CHANGEVER
434	20-Jul-19	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, JULUPALYA	17:20	17:21	0:01	LOAD CHANGEVER
435	20-Jul-19	BENGALURU	66	SOMENAHALLI - CHINTAMANI 220	SOMENAHALLI	10:10	10:11	0:01	LOAD CHANGEVER
436	20-Jul-19	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	17:20	17:21	0:01	LOAD CHANGEVER
437	20-Jul-19	BENGALURU	66	HV2	THIMAMPALLI	12:00	13:00	1:00	LINE CLEAR AVAILED
438	20-Jul-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	9:25	9:28	0:03	LOAD CHANGEVER
439	20-Jul-19	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	10:36	10:42	0:06	LOAD CHANGEVER
440	20-Jul-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:17	10:20	0:02	LOAD CHANGEVER
441	20-Jul-19	BENGALURU	66	HV2	TELECOM LAYOUT	12:20	12:43	0:22	LINE CLEAR AVAILED
442	20-Jul-19	BENGALURU	66	HV1	RR NAGAR	17:56	17:58	0:02	LOAD CHANGEVER
443	20-Jul-19	BENGALURU	66	HV2	RR NAGAR	17:55	18:03	0:07	LOAD CHANGEVER
444	20-Jul-19	BENGALURU	66	HV1	PADMANBHANAGAR	11:19	11:23	0:03	LINE CLEAR AVAILED
445	20-Jul-19	BENGALURU	66	HV1	KADUBISANAHALLI	19:24	19:40	0:15	LINE CLEAR AVAILED
446	20-Jul-19	BENGALURU	66	HV1	BRIGADE METRO POLIS	12:18	12:20	0:01	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
447	20-Jul-19	BENGALURU	66	HV2	AUSTIN PARK	10:55	11:05	0:10	LINE CLEAR AVAILED
448	20-Jul-19	BENGALURU	66	HV1	AUSTIN PARK	14:22	14:38	0:16	LINE CLEAR AVAILED
449	20-Jul-19	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	13:00	14:50	1:50	LINE CLEAR AVAILED
450	20-Jul-19	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	19:25	21:47	2:22	NFBC ISSUED
451	20-Jul-19	GULBARGA	220	ITTAGGI-NEELANGUNDA	ITTAGI_220	17:13	18:12	0:59	LINE FAULT
452	20-Jul-19	GULBARGA	220	HV2	ITTAGI_220	17:13	17:25	0:12	TRANSFORMER FAULT
453	20-Jul-19	GULBARGA	220	RTPS-SEDAM	SEDAM_220	12:30	20:28	7:58	NFBC ISSUED
454	20-Jul-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	12:35	20:16	7:41	NFBC ISSUED
455	20-Jul-19	GULBARGA	220	SEDAM-TANDUR	SEDAM_220	13:22	13:42	0:20	LOAD CHANGEOVER
456	20-Jul-19	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	18:20	21:35	3:15	LINE CLEAR AVAILED
457	20-Jul-19	GULBARGA	110	SEDAM-VASAVADATTA	SEDAM_220	20:15	21:47	1:32	LINE FAULT
458	20-Jul-19	GULBARGA	110	HV2	RAICHUR_220	13:47	14:00	0:13	LINE CLEAR AVAILED
459	20-Jul-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	4:15	4:28	0:13	LINE FAULT
460	20-Jul-19	GULBARGA	110	BHALKI-LADHA	LADHA_110	7:00	7:10	0:10	LINE FAULT
461	20-Jul-19	GULBARGA	110	PDHALLI-BASAI STEELS_IPP	PDHALLI_110	11:47	11:50	0:03	LINE FAULT
462	20-Jul-19	GULBARGA	110	PDHALLI-BASAI STEELS_IPP	PDHALLI_110	12:15	12:23	0:08	LINE FAULT
463	20-Jul-19	GULBARGA	110	HALBURGA-HALLIKHED	HALIKHED_110	5:35	5:55	0:20	LINE FAULT
464	20-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	5:45	5:57	0:12	LINE FAULT
465	20-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	6:10	6:30	0:20	LINE FAULT
466	20-Jul-19	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110	6:24	6:33	0:09	LINE FAULT
467	20-Jul-19	GULBARGA	110	GURUGUN-LIVL_IPP	GURUGUNTA_110	10:05	18:21	8:16	LINE CLEAR AVAILED
468	20-Jul-19	GULBARGA	110	GURUGUN-KHEL_IPP	GURUGUNTA_110	0:00	19:40	19:40	LINE CLEAR AVAILED
469	20-Jul-19	GULBARGA	110	HALBURGA-HALLIKHED	HALLIKHED_110	5:35	5:55	0:20	LINE FAULT
470	20-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	6:10	6:30	0:20	LINE FAULT
471	20-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	5:45	5:57	0:12	LINE FAULT
472	20-Jul-19	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110	6:24	6:33	0:09	LINE FAULT
473	20-Jul-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	6:05	13:50	7:45	LINE FAULT
474	20-Jul-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	21:38	21:43	0:05	LINE FAULT
475	20-Jul-19	GULBARGA	110	SIDHANOOR-PGLR_WIND	SIDHANOOR_220	22:40	22:50	0:10	LINE FAULT
476	20-Jul-19	GULBARGA	110	SHAHPUR-SHAHPUR2	SHAHPUR_110	20:44	21:16	0:32	LINE FAULT
477	20-Jul-19	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	21:06	21:20	0:14	HAND TRIPPED
478	20-Jul-19	GULBARGA	110	SEDAM-SHAHAPUR	SEDAM_220	9:58	23:59	14:01	NFBC ISSUED
479	20-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	8:04	8:04	LINE CLEAR AVAILED
480	20-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:54	23:59	1:05	LINE CLEAR AVAILED
481	20-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	9:20	9:20	LINE CLEAR AVAILED
482	20-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:48	23:39	0:51	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
483	20-Jul-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:35	20:14	9:39	LINE CLEAR AVAILED
484	20-Jul-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:37	17:34	6:57	LINE CLEAR AVAILED
485	20-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:35	18:23	7:48	LINE CLEAR AVAILED
486	20-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	18:40	20:14	1:34	LINE CLEAR AVAILED
487	20-Jul-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	23:58	23:59	0:01	HAND TRIPPED
488	20-Jul-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:37	17:35	6:58	LINE CLEAR AVAILED
489	20-Jul-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	23:57	23:59	0:02	HAND TRIPPED
490	20-Jul-19	HASSAN	110	HV1	KULASHEKARA_110	13:31	14:26	0:55	LINE CLEAR AVAILED
491	20-Jul-19	HASSAN	110	HV2	KULASHEKARA_110	12:59	14:26	1:27	LINE CLEAR AVAILED
492	20-Jul-19	HASSAN	110	HV1	SHIVPURA_110	15:37	16:49	1:12	LINE CLEAR AVAILED
493	20-Jul-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	0:00	13:11	13:11	LINE CLEAR AVAILED
494	20-Jul-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	20:18	20:25	0:07	LINE FAULT
495	20-Jul-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	16:52	17:36	0:44	HAND TRIPPED
496	20-Jul-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:46	11:11	0:25	LINE CLEAR AVAILED
497	20-Jul-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	12:03	12:32	0:28	LINE CLEAR AVAILED
498	20-Jul-19	MYSORE	66	HV1	DEVANOORMYS_66	11:23	12:43	1:20	LINE CLEAR AVAILED
499	20-Jul-19	MYSORE	66	HV2	HAMPAPURA_66	12:13	12:44	0:31	LINE CLEAR AVAILED
500	20-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66	10:20	14:25	4:05	NFBC ISSUED
501	20-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 SHIVALLY_66	10:25	13:15	2:50	NFBC ISSUED
502	20-Jul-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	12:05	19:37	7:31	LINE CLEAR AVAILED
503	20-Jul-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	12:05	19:37	7:31	LINE CLEAR AVAILED
504	20-Jul-19	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	17:13	20:33	3:19	LINE CLEAR AVAILED
505	20-Jul-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	18:26	20:36	2:10	LINE FAULT
506	20-Jul-19	TUMKUR	220	TR-1	NEELAGUNDA_220	17:13	18:19	1:05	MAIN SUPPLY AVAILED
507	20-Jul-19	TUMKUR	220	TR-2	NEELAGUNDA_220	17:13	18:18	1:04	MAIN SUPPLY AVAILED
508	20-Jul-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	5:32	5:54	0:22	LINE FAULT
509	20-Jul-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	9:39	10:47	1:07	LINE CLEAR AVAILED
510	20-Jul-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	7:46	12:03	4:16	TRANSFORMER FAULT
511	20-Jul-19	TUMKUR	66	BELADADARA- KORATAGERE( ANTHRASANAHALLI)	BELADARA_66	13:14	13:39	0:25	HAND TRIPPED
512	20-Jul-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	12:32	13:58	1:26	LINE CLEAR AVAILED
513	20-Jul-19	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	19:20	19:21	0:00	HAND TRIPPED
514	20-Jul-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:44	13:42	3:57	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
515	20-Jul-19	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	HARAPPANAHALLI_66	18:17	18:20	0:03	HAND TRIPPED
516	20-Jul-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	18:17	18:20	0:03	HAND TRIPPED
517	20-Jul-19	TUMKUR	66	TR-1& TR-2(LV SIDE)	NEELAGUNDA_220	17:13	18:19	1:05	LINE CLEAR AVAILED
518	20-Jul-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	18:17	18:21	0:03	HAND TRIPPED
519	20-Jul-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	18:17	18:20	0:03	HAND TRIPPED
520	20-Jul-19	TUMKUR	66	TR-1	PANDARAHALLI_66	10:12	18:25	8:13	LINE CLEAR AVAILED
521	20-Jul-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	5:32	5:54	0:22	LINE FAULT
522	21-Jul-19	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	11:46	13:01	1:15	LINE CLEAR AVAILED
523	21-Jul-19	BAGALKOT	110	GADAG ROAD -GOPANAKOPPA	GOPANAKOPPA_110	0:00	10:05	10:05	LINE CLEAR AVAILED
524	21-Jul-19	BAGALKOT	110	HIRASUGAR2-SANKESHWAR	SANKESHWAR_110	8:31	23:59	15:28	LINE CLEAR AVAILED
525	21-Jul-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	8:31	8:36	0:05	LINE CLEAR AVAILED
526	21-Jul-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	9:22	23:59	14:37	LINE CLEAR AVAILED
527	21-Jul-19	BAGALKOT	110	110/33KV, HV3	MACHE_110, ASHOK IRON_33, ALUS CAST_33	10:00	10:20	0:20	LINE CLEAR AVAILED
528	21-Jul-19	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	15:08	15:40	0:32	LINE CLEAR AVAILED
529	21-Jul-19	BENGALURU	220	GOWRIBIDANUR 220 -RVNL	RAILWAYS (EHT)	18:00	18:32	0:32	LINE FAULT
530	21-Jul-19	BENGALURU	66	HV2	MAASTHI	5:38	5:45	0:07	TRANSFORMER FAULT
531	21-Jul-19	BENGALURU	66	HV2	YELAHANKA 220	7:22	7:42	0:20	TRANSFORMER FAULT
532	21-Jul-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:24	13:44	1:20	LINE CLEAR AVAILED
533	21-Jul-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	12:24	13:44	1:20	LINE CLEAR AVAILED
534	21-Jul-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	10:15	10:43	0:27	MAIN SUPPLY AVAILED
535	21-Jul-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	10:15	10:43	0:27	MAIN SUPPLY AVAILED
536	21-Jul-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	10:16	10:35	0:19	MAIN SUPPLY AVAILED
537	21-Jul-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ATTIBELE	10:16	10:35	0:19	MAIN SUPPLY AVAILED
538	21-Jul-19	BENGALURU	66	HV1	YARANDANAHALLI 220	10:16	10:35	0:19	MAIN SUPPLY AVAILED
539	21-Jul-19	BENGALURU	66	HV3	YARANDANAHALLI 220	10:16	10:35	0:19	MAIN SUPPLY AVAILED
540	21-Jul-19	BENGALURU	66	HV2	YARANDANAHALLI 220	12:20	12:22	0:02	LOAD CHANGEVER
541	21-Jul-19	BENGALURU	66	HV2	YARANDANAHALLI 220	17:23	17:28	0:05	LOAD CHANGEVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
542	21-Jul-19	BENGALURU	66	ELECTRONIC CITY P2 S2 - ELECTRONIC CITY	ELECTRONIC CITY P2 S2, BIOCON (EHT)	10:20	10:45	0:25	LOAD CHANGEOVER
543	21-Jul-19	BENGALURU	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB 1 (EHT)	8:13	18:24	10:10	LINE CLEAR AVAILED
544	21-Jul-19	BENGALURU	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	8:13	18:24	10:10	LINE CLEAR AVAILED
545	21-Jul-19	BENGALURU	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB 3 (EHT)	8:13	18:24	10:10	LINE CLEAR AVAILED
546	21-Jul-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	9:08	9:16	0:08	LOAD CHANGEOVER
547	21-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	9:29	9:43	0:13	LINE CLEAR AVAILED
548	21-Jul-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	16:45	17:32	0:47	LINE CLEAR AVAILED
549	21-Jul-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	9:13	9:19	0:05	LOAD CHANGEOVER
550	21-Jul-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	9:30	9:34	0:04	LOAD CHANGEOVER
551	21-Jul-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	21:30	21:43	0:13	LOAD CHANGEOVER
552	21-Jul-19	BENGALURU	66	HV1	RR NAGAR	7:31	7:34	0:02	LOAD CHANGEOVER
553	21-Jul-19	BENGALURU	66	HV2	RR NAGAR	7:31	7:34	0:02	LOAD CHANGEOVER
554	21-Jul-19	BENGALURU	66	HV1	KHODAYS 220	9:13	9:18	0:05	LOAD CHANGEOVER
555	21-Jul-19	BENGALURU	66	HV2	KHODAYS 220	9:13	9:19	0:06	LOAD CHANGEOVER
556	21-Jul-19	BENGALURU	66	HV2	BG ROAD	15:06	16:10	1:03	LINE CLEAR AVAILED
557	21-Jul-19	BENGALURU	66	HV1	A STATION 66	9:48	9:56	0:07	LINE CLEAR AVAILED
558	21-Jul-19	BENGALURU	66	HV3	A STATION 66	7:32	7:34	0:02	LINE CLEAR AVAILED
559	21-Jul-19	BENGALURU	66	HV4	A STATION 66	6:11	6:16	0:04	LINE CLEAR AVAILED
560	21-Jul-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	12:57	23:59	11:02	NFBC ISSUED
561	21-Jul-19	GULBARGA	220	SEDAM-HUMNNBAD1	HUMNABAD_220	15:42	19:36	3:54	LINE FAULT
562	21-Jul-19	GULBARGA	220	SEDAM-HUMNNBAD1	HUMNABAD_220	20:09	20:30	0:21	LINE FAULT
563	21-Jul-19	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	0:41	0:44	0:03	LINE FAULT
564	21-Jul-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	0:47	0:57	0:10	LINE FAULT
565	21-Jul-19	GULBARGA	110	KAPNOOR-HUMNBAD2	ALAND_110,KADAGANCHI_110	3:40	3:46	0:06	LINE FAULT
566	21-Jul-19	GULBARGA	110	KAPNOOR-HUMNBAD2	ALAND_110,KADAGANCHI_110	3:08	3:15	0:07	LINE FAULT
567	21-Jul-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	20:10	20:18	0:08	LINE FAULT
568	21-Jul-19	GULBARGA	110	SEDAM-VASAVADATTA	VASVADATTA CEMENTS_IPP	1:21	1:28	0:07	LINE CLEAR AVAILED
569	21-Jul-19	GULBARGA	110	SEDAM-VICATASAGAR	VICATSAGAR_IPP	2:40	2:45	0:05	LINE FAULT
570	21-Jul-19	GULBARGA	66	ITTAGGI-CLN MAX1	ITTAGI_220	12:14	12:18	0:04	LINE CLEAR AVAILED
571	21-Jul-19	GULBARGA	66	ITTAGGI-SUZLON1,2	ITTAGI_220	13:44	13:52	0:08	HAND TRIPPED
572	21-Jul-19	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	13:44	13:56	0:12	LINE CLEAR AVAILED
573	21-Jul-19	GULBARGA	66	ITTAGGI-RNSLR1	ITTAGI_220	14:42	14:52	0:10	HAND TRIPPED
574	21-Jul-19	GULBARGA	66	ITTAGGI-RNSLR2	ITTAGI_220	4:44	14:52	10:08	LINE CLEAR AVAILED
575	21-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	8:07	8:07	LINE CLEAR AVAILED
576	21-Jul-19	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	0:00	4:24	4:24	LINE CLEAR AVAILED
577	21-Jul-19	HASSAN	110	HV1	BHADRAVATHI_110	12:33	13:27	0:54	LINE CLEAR AVAILED
578	21-Jul-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	0:00	4:25	4:25	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
579	21-Jul-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	10:13	11:09	0:56	LINE CLEAR AVAILED
580	21-Jul-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	10:10	11:15	1:05	LINE FAULT
581	21-Jul-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	10:13	11:09	0:56	LINE CLEAR AVAILED
582	21-Jul-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:13	11:09	0:56	LINE CLEAR AVAILED
583	21-Jul-19	HASSAN	66	HV1	SIGEBAGI_66	9:30	17:00	7:30	LINE CLEAR AVAILED
584	21-Jul-19	HASSAN	66	HV2	SINGAPURA_66	9:36	11:21	1:45	LINE CLEAR AVAILED
585	21-Jul-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	6:59	7:13	0:14	TRANSFORMER FAULT
586	21-Jul-19	TUMKUR	66	TR-1	HIRIYUR_66	8:29	8:48	0:19	TRANSFORMER FAULT
587	21-Jul-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	2:27	13:16	10:49	LINE CLEAR AVAILED
588	21-Jul-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:19	11:36	0:16	LINE FAULT
589	22-Jul-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	23:54	23:59	0:05	MAIN SUPPLY AVAILED
590	22-Jul-19	BENGALURU	66	KHODAYS 220 - SUBRAMANYAPURA 2	KHODAYS 220	23:54	23:59	0:05	MAIN SUPPLY AVAILED
591	22-Jul-19	BENGALURU	66	HV1	KHODAYS 220	23:54	23:59	0:05	MAIN SUPPLY AVAILED
592	22-Jul-19	BENGALURU	66	HV2	KHODAYS 220	23:54	23:59	0:05	MAIN SUPPLY AVAILED
593	22-Jul-19	BENGALURU	220	HV2	SOMANAHALLI 220	23:54	23:59	0:05	TRANSFORMER FAULT
594	22-Jul-19	BENGALURU	220	HV3	SOMANAHALLI 220	23:54	23:59	0:05	TRANSFORMER FAULT
595	22-Jul-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	23:54	23:59	0:05	MAIN SUPPLY AVAILED
596	22-Jul-19	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI	23:54	23:59	0:05	MAIN SUPPLY AVAILED
597	22-Jul-19	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	23:54	23:59	0:05	MAIN SUPPLY AVAILED
598	22-Jul-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	SUBRAMANYAPURA 66	23:54	23:59	0:05	MAIN SUPPLY AVAILED
599	22-Jul-19	BENGALURU	66	HV1	TK HALLI 220	7:12	7:18	0:06	TRANSFORMER FAULT
600	22-Jul-19	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	15:08	15:17	0:09	LINE FAULT
601	22-Jul-19	BENGALURU	220	HV2	NRS 220	15:08	15:28	0:20	TRANSFORMER FAULT
602	22-Jul-19	BENGALURU	66	HV1	VIJAYANAGARA	15:08	15:17	0:09	MAIN SUPPLY AVAILED
603	22-Jul-19	BENGALURU	66	VIJAYANAGARA - NRS 1	VIJAYANAGARA	17:10	19:26	2:16	LINE CLEAR AVAILED
604	22-Jul-19	BENGALURU	66	VIJAYANAGARA - NRS 2	VIJAYANAGARA	17:10	19:26	2:16	LINE CLEAR AVAILED
605	22-Jul-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT), BANASWADI	13:11	13:58	0:47	LINE FAULT
606	22-Jul-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	20:30	23:34	3:04	LINE CLEAR AVAILED
607	22-Jul-19	BENGALURU	66	HV1	BANASWADI	20:30	20:33	0:03	LOAD CHANGEOR

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
608	22-Jul-19	BENGALURU	66	HV1	BANASWADI	23:40	23:46	0:06	LOAD CHANGEOVER
609	22-Jul-19	GULBARGA	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	16:32	17:32	1:00	LINE CLEAR AVAILED
610	22-Jul-19	GULBARGA	220	RTPS-SHAHAPUR2	SHAHPUR_220	3:40	4:15	0:35	LINE FAULT
611	22-Jul-19	GULBARGA	220	SEDAM-ORIENT CEMENTS	SEDAM_220	0:00	20:09	20:09	NFBC ISSUED
612	22-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:10	7:10	LINE CLEAR AVAILED
613	22-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:30	23:59	2:29	LINE CLEAR AVAILED
614	22-Jul-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:20	15:48	4:28	LINE CLEAR AVAILED
615	22-Jul-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	0:00	7:10	7:10	LINE FAULT
616	22-Jul-19	HASSAN	66	HV1	SIGEBAGI_66	10:35	10:40	0:05	LOAD CURTAILMENT
617	22-Jul-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:35	10:40	0:05	LOAD CURTAILMENT