

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 05.11.2019 TO 11.11.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	5-Nov-19	BAGALKOT	110	110/33KV,HV2	ANKALAGI_110,KANAGOAN_33,NES ARAGI_33	0:17	0:24	0:07	TRANSFORMER FAULT
2	5-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	0:00	14:03	14:03	LINE CLEAR AVAILED
3	5-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	15:58	23:59	8:01	LINE FAULT
4	5-Nov-19	BAGALKOT	110	110/11KV,HV1	ANKALAGI_110	14:30	15:25	0:55	LINE CLEAR AVAILED
5	5-Nov-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	2:53	3:52	0:59	LINE FAULT
6	5-Nov-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTITI	BANAHATTI_110	6:04	6:22	0:18	LINE FAULT
7	5-Nov-19	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	2:25	3:39	1:14	LINE FAULT
8	5-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	3:15	6:52	3:37	LINE CLEAR AVAILED
9	5-Nov-19	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	5:15	7:35	2:20	TRANSFORMER FAULT
10	5-Nov-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	0:00	13:47	13:47	LINE CLEAR AVAILED
11	5-Nov-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	20:24	21:59	1:35	LINE FAULT
12	5-Nov-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	21:59	23:59	2:00	LINE CLEAR AVAILED
13	5-Nov-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	21:05	23:59	2:54	LINE FAULT
14	5-Nov-19	BAGALKOT	110	MAHALINGAPUR220-JAMAKHADI	JAMAKHANDI_110	6:00	6:26	0:26	LINE FAULT
15	5-Nov-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	21:28	22:38	1:10	LINE FAULT
16	5-Nov-19	BAGALKOT	110	BELGAUM220-MACHE	MACHE_110	2:20	3:44	1:24	LINE FAULT
17	5-Nov-19	BAGALKOT	110	MANALI SUGAR-MALGHAN(S)	MALGHAN(S)_110	7:02	7:35	0:33	LINE FAULT
18	5-Nov-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1&2	MAMADAPUR_110	4:50	5:00	0:10	LINE FAULT
19	5-Nov-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1&2	MAMADAPUR_110	20:07	20:20	0:13	LINE FAULT
20	5-Nov-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:02	9:33	8:31	LINE CLEAR AVAILED
21	5-Nov-19	BAGALKOT	110	NOKER SOLAR -NAVLGUND	NAVALGUND_110	18:01	18:19	0:18	LINE FAULT
22	5-Nov-19	BAGALKOT	110	HUBLI220-PH COMPOUND	PH COMPOUND_110	0:00	18:57	18:57	LINE CLEAR AVAILED
23	5-Nov-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	16:09	16:22	0:13	LINE FAULT
24	5-Nov-19	BAGALKOT	110	JAMAKHANDI-SHIROL	SHIROL_110	6:00	6:35	0:35	LINE FAULT
25	5-Nov-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:00	22:43	22:43	LINE CLEAR AVAILED
26	5-Nov-19	BAGALKOT	110	JAMAKHANDI SUGAR-TODALBAGI	TODALBAGI_110	14:15	15:16	1:01	LINE CLEAR AVAILED
27	5-Nov-19	BAGALKOT	110	110/11KV,HV1,HV2	TODALBAGI_110	9:15	9:20	0:05	TRANSFORMER FAULT
28	5-Nov-19	BAGALKOT	110	BELGAUM220-UCHAGAON	UCHAGAON_110	2:53	3:46	0:53	LINE FAULT
29	5-Nov-19	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	17:00	17:20	0:20	LINE CLEAR AVAILED
30	5-Nov-19	BENGALURU	66	HV2	CHANDAPURA	11:33	11:50	0:17	LINE CLEAR AVAILED
31	5-Nov-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:22	8:27	0:05	LINE FAULT
32	5-Nov-19	BENGALURU	66	HV2	DODDABELAVANGALA	17:00	17:50	0:50	LINE CLEAR AVAILED
33	5-Nov-19	BENGALURU	66	HV1	PATHPALYA	11:30	12:07	0:37	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
34	5-Nov-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	10:55	11:25	0:30	MAIN SUPPLY FAILURE
35	5-Nov-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:55	11:33	0:38	MAIN SUPPLY FAILURE
36	5-Nov-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:55	11:35	0:40	MAIN SUPPLY FAILURE
37	5-Nov-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	6:22	6:35	0:13	LINE FAULT
38	5-Nov-19	BENGALURU	66	KANASWADI - NRS 220	KANASWADI	18:00	18:05	0:05	LOAD CHANGE OVER
39	5-Nov-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:55	11:27	0:32	MAIN SUPPLY FAILURE
40	5-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	10:55	11:27	0:32	MAIN SUPPLY FAILURE
41	5-Nov-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:55	11:27	0:32	MAIN SUPPLY FAILURE
42	5-Nov-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	10:55	11:27	0:32	MAIN SUPPLY FAILURE
43	5-Nov-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:55	11:27	0:32	MAIN SUPPLY FAILURE
44	5-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	10:55	11:27	0:32	MAIN SUPPLY FAILURE
45	5-Nov-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	10:55	11:27	0:32	MAIN SUPPLY FAILURE
46	5-Nov-19	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	10:55	11:27	0:32	MAIN SUPPLY FAILURE
47	5-Nov-19	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	10:55	11:27	0:32	MAIN SUPPLY FAILURE
48	5-Nov-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:55	11:27	0:32	MAIN SUPPLY FAILURE
49	5-Nov-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:55	11:27	0:32	MAIN SUPPLY FAILURE
50	5-Nov-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	10:55	11:27	0:32	MAIN SUPPLY FAILURE
51	5-Nov-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	10:55	11:27	0:32	MAIN SUPPLY FAILURE
52	5-Nov-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:55	11:27	0:32	MAIN SUPPLY FAILURE
53	5-Nov-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:55	11:27	0:32	MAIN SUPPLY FAILURE
54	5-Nov-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:55	11:27	0:32	MAIN SUPPLY FAILURE
55	5-Nov-19	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	10:55	11:27	0:32	MAIN SUPPLY FAILURE
56	5-Nov-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	10:55	11:27	0:32	MAIN SUPPLY FAILURE
57	5-Nov-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	23:26	23:35	0:09	LINE FAULT
58	5-Nov-19	GULBARGA	400	BPS-YTPS1	YTPS_400	0:00	11:12	11:12	LINE FAULT
59	5-Nov-19	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHBAD_220	5:00	5:15	0:15	LINE FAULT
60	5-Nov-19	GULBARGA	220	BMMISPAT-ITTAGI	ITTAGI_220	9:00	14:28	5:28	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
61	5-Nov-19	GULBARGA	110	HV3	BEVOORG_110	16:04	16:15	0:11	TRANSFORMER FAULT
62	5-Nov-19	HASSAN	220	HV1	HASSAN_220	13:27	13:38	0:11	HAND TRIPPED
63	5-Nov-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	5:56	6:08	0:12	LINE FAULT
64	5-Nov-19	HASSAN	220	HV1	KEMAR_220	11:54	16:58	5:04	LINE CLEAR AVAILED
65	5-Nov-19	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	0:00	10:58	10:58	LINE FAULT
66	5-Nov-19	HASSAN	220	HV1	PUTTUR_220	15:30	16:22	0:52	LINE CLEAR AVAILED
67	5-Nov-19	HASSAN	220	HV2	PUTTUR_220	10:54	15:27	4:33	LINE CLEAR AVAILED
68	5-Nov-19	HASSAN	220	varahi-SHIMOGA1	varahi_gen	0:00	11:00	11:00	LINE FAULT
69	5-Nov-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:05	17:47	0:42	LINE FAULT
70	5-Nov-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:05	17:47	0:42	LINE FAULT
71	5-Nov-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	8:23	18:23	10:00	LINE CLEAR AVAILED
72	5-Nov-19	HASSAN	110	HV2	KEMAR_220	4:54	6:14	1:20	TRANSFORMER FAULT
73	5-Nov-19	HASSAN	110	LV1	KEMAR_220	11:53	17:00	5:07	LINE CLEAR AVAILED
74	5-Nov-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:37	17:04	5:27	LINE CLEAR AVAILED
75	5-Nov-19	HASSAN	110	LV1	PUTTUR_220	15:30	16:23	0:53	LINE CLEAR AVAILED
76	5-Nov-19	HASSAN	110	LV2	PUTTUR_220	10:54	15:27	4:33	LINE CLEAR AVAILED
77	5-Nov-19	HASSAN	110	HV3	BANTWAL_110	9:02	19:35	10:33	LINE CLEAR AVAILED
78	5-Nov-19	HASSAN	110	HV1	CHANDRAGUTTI_110	0:00	10:40	10:40	MAIN SUPPLY FAILURE
79	5-Nov-19	HASSAN	110	GURUVYN-KEMAR1	GURUVAYANAKERE_110	17:05	17:52	0:47	LINE FAULT
80	5-Nov-19	HASSAN	110	GURUVYN-KEMAR2	GURUVAYANAKERE_110	17:05	17:52	0:47	LINE FAULT
81	5-Nov-19	HASSAN	110	MANIPAL	HIRIYADKA_110	8:23	18:06	9:43	MAIN SUPPLY FAILURE
82	5-Nov-19	HASSAN	110	AKADUR-JAMPURA	KADUR_220	10:14	10:22	0:08	HAND TRIPPED
83	5-Nov-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	11:21	15:26	4:05	LINE CLEAR AVAILED
84	5-Nov-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	17:17	17:37	0:20	NFBC ISSUED
85	5-Nov-19	HASSAN	110	HV2	MANIPAL_110	10:40	12:33	1:53	LINE CLEAR AVAILED
86	5-Nov-19	HASSAN	110	NANDIKUR-KEMAR2	NANDIKUR_110	11:38	17:05	5:27	NFBC ISSUED
87	5-Nov-19	HASSAN	110	HOSANGDI-VTRG1	HOSANGADI_110	0:00	10:40	10:40	MAIN SUPPLY FAILURE
88	5-Nov-19	HASSAN	66	LV1	HASSAN_220	13:27	13:38	0:11	HAND TRIPPED
89	5-Nov-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	17:01	17:22	0:21	LINE CLEAR AVAILED
90	5-Nov-19	MYSORE	66	HV1	BANANGADI_66	17:07	18:13	1:06	LINE CLEAR AVAILED
91	5-Nov-19	MYSORE	66	BG NAGARA-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 , SHIVALLY_66	10:42	12:13	1:31	NFBC ISSUED
92	5-Nov-19	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66, KABHALLY_66	20:18	21:32	1:14	LINE CLEAR AVAILED
93	5-Nov-19	MYSORE	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBE_66	18:50	23:59	5:08	LINE FAULT
94	5-Nov-19	MYSORE	66	HV1	DATTAGALLY_66	15:47	15:51	0:04	TRANSFORMER FAULT
95	5-Nov-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66, SINDHUVALLI_66	20:32	21:41	1:09	MAIN SUPPLY FAILURE
96	5-Nov-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	20:48	21:42	0:54	MAIN SUPPLY FAILURE
97	5-Nov-19	MYSORE	66	GUNDLUPETE-HANGLA	HANGLA_66, BHARGI_66	20:48	21:42	0:54	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
98	5-Nov-19	MYSORE	66	GUNDLUPETE-CR NAGARA 2	GUNDULPET_66, TERAkanAMBE_66	18:50	21:38	2:48	LINE FAULT
99	5-Nov-19	MYSORE	66	HOOTAGALLY-ELAWALA	ELAVALA_66, GAVADAGERE_66	18:15	18:34	0:19	LINE FAULT
100	5-Nov-19	MYSORE	66	HV1	HULLAHALLI_66	13:25	14:38	1:13	LINE CLEAR AVAILED
101	5-Nov-19	MYSORE	66	HV2	HULLAHALLI_66	12:06	13:45	1:38	LINE CLEAR AVAILED
102	5-Nov-19	MYSORE	66	HUNSUR-ELAWALA	ELAVALA_66, GAVADAGERE_66	18:15	18:39	0:24	LINE FAULT
103	5-Nov-19	MYSORE	66	HV2	JAKKANAHALLY_66	7:28	8:01	0:32	TRANSFORMER FAULT
104	5-Nov-19	MYSORE	66	KIKKERI-KR PETE	KIKKERI_66	15:50	16:08	0:17	LINE CLEAR AVAILED
105	5-Nov-19	MYSORE	66	MADHUVANALLY-MAMBALLI	SANTHEMARAHALLI_66	6:04	6:09	0:04	LINE FAULT
106	5-Nov-19	MYSORE	66	MADHUVANALLY-MAMBALLI	MAMBALLI_66	8:39	8:46	0:06	LINE FAULT
107	5-Nov-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:50	13:33	0:43	LINE CLEAR AVAILED
108	5-Nov-19	MYSORE	66	PERIYAPATNA -HANAGODU	HANAGODU_66, PONNAMPET_66, VIRAJPET_66	10:20	10:30	0:10	LINE FAULT
109	5-Nov-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	5:49	5:59	0:10	LINE FAULT
110	5-Nov-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 , SHIVALLY_66	10:18	11:48	1:30	LINE CLEAR AVAILED
111	5-Nov-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 , SHIVALLY_66	10:18	11:47	1:29	LINE CLEAR AVAILED
112	5-Nov-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	20:15	20:25	0:10	LINE FAULT
113	5-Nov-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	16:23	16:59	0:35	TRANSFORMER FAULT
114	5-Nov-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	17:01	17:03	0:02	HAND TRIPPED
115	5-Nov-19	TUMKUR	220	TR-1	KBCROSS_220	16:09	17:28	1:18	LINE CLEAR AVAILED
116	5-Nov-19	TUMKUR	220	TR-2	KBCROSS_220	10:51	16:08	5:17	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
117	5-Nov-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	10:51	16:08	5:17	LINE CLEAR AVAILED
118	5-Nov-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:26	17:04	0:37	HAND TRIPPED
119	5-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:26	17:04	0:37	HAND TRIPPED
120	5-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:26	17:04	0:37	HAND TRIPPED
121	5-Nov-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:46	16:50	2:04	LINE CLEAR AVAILED
122	5-Nov-19	TUMKUR	66	TR-1	KUNDUR_66	12:16	14:09	1:53	LINE CLEAR AVAILED
123	5-Nov-19	TUMKUR	66	TR-2	RAMPURA_66	11:08	12:12	1:03	LINE CLEAR AVAILED
124	5-Nov-19	TUMKUR	66	TAVAREKERE (H)- I/CHIRIYUR	TAVAREKERE(H)_66	17:11	17:43	0:31	HAND TRIPPED
125	6-Nov-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEAB IRD_33	10:06	12:12	2:06	LINE CLEAR AVAILED
126	6-Nov-19	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_220	6:11	6:20	0:09	LINE FAULT
127	6-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	11:43	17:00	5:17	LINE CLEAR AVAILED
128	6-Nov-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1	MAMADAPUR_110	4:46	4:59	0:13	LINE FAULT
129	6-Nov-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR2	MAMADAPUR_110	4:46	4:59	0:13	LINE FAULT
130	6-Nov-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI2	BIDNAL_220	5:57	12:12	6:15	LINE FAULT
131	6-Nov-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	15:28	23:59	8:31	LINE FAULT
132	6-Nov-19	BAGALKOT	110	110/11KV,HV2	BHUTHNAL_110	6:23	7:05	0:42	LINE CLEAR AVAILED
133	6-Nov-19	BAGALKOT	110	110/11KV,HV2	BHUTHNAL_110	14:50	14:55	0:05	TRANSFORMER FAULT
134	6-Nov-19	BAGALKOT	220	GADAG-DHONI1	GADAG_220	11:21	16:40	5:19	LINE CLEAR AVAILED
135	6-Nov-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	11:58	12:30	0:32	TRANSFORMER FAULT
136	6-Nov-19	BAGALKOT	110	110/11KV, HV1	YELLPARHATTI_110	16:31	17:10	0:39	LINE CLEAR AVAILED
137	6-Nov-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110, VANTAGODI_33, YADWAD_33	11:59	12:04	0:05	TRANSFORMER FAULT
138	6-Nov-19	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	16:09	16:31	0:22	LINE FAULT
139	6-Nov-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:03	13:57	1:54	LINE CLEAR AVAILED
140	6-Nov-19	BAGALKOT	110	110/11KV, HV1	SAVALAGI_110	11:03	11:08	0:05	TRANSFORMER FAULT
141	6-Nov-19	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	12:21	23:59	11:38	LINE CLEAR AVAILED
142	6-Nov-19	BAGALKOT	110	BPCL-NARGUND	NARAGUND_110	22:01	23:59	1:58	LINE CLEAR AVAILED
143	6-Nov-19	BAGALKOT	110	110/33KV, HV2	MURDESHWAR_110, BHATKAL_33, KASARGOD_33	13:56	14:19	0:23	LINE CLEAR AVAILED
144	6-Nov-19	BAGALKOT	220	220/110KV, HV1& LV1	KARWAR_220	10:41	11:46	1:05	LINE CLEAR AVAILED
145	6-Nov-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	10:12	10:18	0:06	TRANSFORMER FAULT
146	6-Nov-19	BENGALURU	220	SOMANAHALLI 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	21:00	21:09	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
147	6-Nov-19	BENGALURU	66	SUBRAMANYAPURA 220 - ISRO	ISRO	7:00	8:26	1:26	LOAD CURTAILMENT
148	6-Nov-19	BENGALURU	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA	7:00	8:28	1:28	LOAD CURTAILMENT
149	6-Nov-19	BENGALURU	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA	10:21	10:29	0:08	LOAD CHANGE OVER
150	6-Nov-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	10:33	10:45	0:12	LOAD CHANGE OVER
151	6-Nov-19	BENGALURU	66	SUBRAMANYAPRUA 220 - PADMANABHANAGARA	PADMANABHANAGARA	10:33	10:45	0:12	LOAD CHANGE OVER
152	6-Nov-19	BENGALURU	66	SUBRAMANYAPRUA 220 - PADMANABHANAGARA	PADMANABHANAGARA	16:18	16:28	0:10	LOAD CHANGE OVER
153	6-Nov-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	16:18	16:28	0:10	LOAD CHANGE OVER
154	6-Nov-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	21:00	21:20	0:20	LINE FAULT
155	6-Nov-19	BENGALURU	66	HV2	R R NAGAR	14:00	14:50	0:50	LINE CLEAR AVAILED
156	6-Nov-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	12:35	14:20	1:45	LINE CLEAR AVAILED
157	6-Nov-19	BENGALURU	66	HV1	KUTAGALLU	10:30	12:22	1:52	LINE CLEAR AVAILED
158	6-Nov-19	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	12:38	12:51	0:13	LOAD CHANGE OVER
159	6-Nov-19	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:10	14:15	0:05	LOAD CHANGE OVER
160	6-Nov-19	BENGALURU	66	SIR M V LAYOUT-KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE,KENGERI SATELLITE TOWN	13:15	13:33	0:18	LINE FAULT
161	6-Nov-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	20:57	21:10	0:13	MAIN SUPPLY FAILURE
162	6-Nov-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	20:57	21:10	0:13	MAIN SUPPLY FAILURE
163	6-Nov-19	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	20:57	21:10	0:13	MAIN SUPPLY FAILURE
164	6-Nov-19	BENGALURU	220	HV1	KHODAYS 220	20:57	21:10	0:13	MAIN SUPPLY FAILURE
165	6-Nov-19	BENGALURU	220	HV2	KHODAYS 220	20:57	21:10	0:13	MAIN SUPPLY FAILURE
166	6-Nov-19	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, CESSNO PARK	16:39	16:42	0:03	LINE FAULT
167	6-Nov-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	15:01	15:46	0:45	LOAD CURTAILMENT
168	6-Nov-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	15:30	15:48	0:18	LOAD CURTAILMENT
169	6-Nov-19	BENGALURU	66	HV2	AMARJYOTHI	11:10	11:45	0:35	LINE CLEAR AVAILED
170	6-Nov-19	BENGALURU	66	HV2	BRIGADE METRO POLIS	12:33	12:39	0:06	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
171	6-Nov-19	BENGALURU	66	HV2	BTM 4TH PHASE	16:15	16:44	0:29	LINE CLEAR AVAILED
172	6-Nov-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	16:32	17:06	0:33	LOAD CURTAILMENT
173	6-Nov-19	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	4:35	4:59	0:24	LINE FAULT
174	6-Nov-19	GULBARGA	110	HV2	SHAKTINAGAR_110	15:45	16:44	0:59	LINE CLEAR AVAILED
175	6-Nov-19	GULBARGA	66	CHORNOOR-ACMESLR_IPP	CHORNOOR_110	3:35	8:00	4:25	LINE FAULT
176	6-Nov-19	GULBARGA	66	CHORNOOR-ACMESLR_IPP	CHORNOOR_110	16:35	17:50	1:15	LINE CLEAR AVAILED
177	6-Nov-19	GULBARGA	66	KOGALI-ATRSRLR_IPP	KOGALI_66	14:25	21:55	7:30	LINE CLEAR AVAILED
178	6-Nov-19	HASSAN	220	HASSN220-CHIKMNGLR	HASSAN_220	12:33	12:44	0:11	LINE FAULT
179	6-Nov-19	HASSAN	220	HASSN220-CHIKMNGLR	HASSAN_220	12:47	12:49	0:02	LINE FAULT
180	6-Nov-19	HASSAN	220	HASSN220-CHIKMNGLR	HASSAN_220	15:43	16:02	0:19	LINE FAULT
181	6-Nov-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	10:28	14:10	3:42	LINE CLEAR AVAILED
182	6-Nov-19	HASSAN	220	MRSSHM-VARAH12	MRSMG-220	15:42	20:15	4:33	LINE FAULT
183	6-Nov-19	HASSAN	220	MRSSHM-VARAH13	MRSMG-220	9:14	11:52	2:38	LINE CLEAR AVAILED
184	6-Nov-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:28	14:10	3:42	LINE CLEAR AVAILED
185	6-Nov-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	15:42	20:33	4:51	LINE FAULT
186	6-Nov-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:13	11:52	2:39	NFBC ISSUED
187	6-Nov-19	HASSAN	110	MRSSHM-GAJNUR	MRSMG-220	9:32	11:35	2:03	NFBC ISSUED
188	6-Nov-19	HASSAN	110	MRSSHM-MPM	MRSMG-220	12:03	16:47	4:44	LINE CLEAR AVAILED
189	6-Nov-19	HASSAN	110	MRSSHM-MPM	MRSMG-220	23:57	23:59	0:02	LINE FAULT
190	6-Nov-19	HASSAN	110	HV2	GANDASI_110	11:10	15:16	4:06	LINE CLEAR AVAILED
191	6-Nov-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	23:54	23:59	0:05	LINE FAULT
192	6-Nov-19	HASSAN	110	HV6	KAVOOR_220	9:58	17:27	7:29	LINE CLEAR AVAILED
193	6-Nov-19	HASSAN	110	HV1	KONAJE_110	10:27	12:10	1:43	LINE CLEAR AVAILED
194	6-Nov-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	23:52	23:59	0:07	LINE FAULT
195	6-Nov-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	12:38	13:47	1:09	NFBC ISSUED
196	6-Nov-19	HASSAN	66	HV2	HOLALUR_66	16:22	17:04	0:42	TRANSFORMER FAULT
197	6-Nov-19	HASSAN	66	HV2	HOLALUR_66	17:49	18:11	0:22	TRANSFORMER FAULT
198	6-Nov-19	HASSAN	66	HV2	HOLALUR_66	18:53	20:07	1:14	TRANSFORMER FAULT
199	6-Nov-19	HASSAN	66	HV2	MATTNAVILE_66	12:22	12:40	0:18	LINE CLEAR AVAILED
200	6-Nov-19	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66, KABHALLY_66	18:20	18:40	0:20	HAND TRIPPED
201	6-Nov-19	MYSORE	220	HV1	CRNAGAR_220	10:19	17:47	7:28	LINE CLEAR AVAILED
202	6-Nov-19	MYSORE	220	HV2	CRNAGAR_220	10:19	18:04	7:45	LINE CLEAR AVAILED
203	6-Nov-19	MYSORE	220	CR NAGARA-MADHUVANAHALLY 2	CRNAGAR_220	10:38	17:43	7:05	LINE CLEAR AVAILED
204	6-Nov-19	MYSORE	220	CR NAGARA-MADHUVANAHALLY 1	CRNAGAR_220	10:38	17:43	7:05	LINE CLEAR AVAILED
205	6-Nov-19	MYSORE	66	HV1	DUNDANAHALLI_66	10:42	10:50	0:08	MAIN SUPPLY FAILURE
206	6-Nov-19	MYSORE	66	HV2	DUNDANAHALLI_66	10:42	10:50	0:08	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
207	6-Nov-19	MYSORE	66	HV1	DUNDANAHALLI_66	12:30	12:41	0:11	MAIN SUPPLY FAILURE
208	6-Nov-19	MYSORE	66	HV2	DUNDANAHALLI_66	12:30	12:41	0:11	MAIN SUPPLY FAILURE
209	6-Nov-19	MYSORE	66	GUNDLUPETE-CR NAGARA	TERAKANAMBE_66	17:51	18:52	1:01	NFBC ISSUED
210	6-Nov-19	MYSORE	66	HV1	GUNDULPET_66	18:22	18:45	0:23	MAIN SUPPLY FAILURE
211	6-Nov-19	MYSORE	66	HV2	GUNDULPET_66	18:22	18:53	0:30	MAIN SUPPLY FAILURE
212	6-Nov-19	MYSORE	66	GUNDLUPETE-BEGURU	BEGUR_66	18:20	18:52	0:32	MAIN SUPPLY FAILURE
213	6-Nov-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	18:20	18:52	0:32	MAIN SUPPLY FAILURE
214	6-Nov-19	MYSORE	66	GUNDLUPETE-HANGALA	HANGLA_66, BHARGI_66	18:20	18:52	0:32	MAIN SUPPLY FAILURE
215	6-Nov-19	MYSORE	66	HANAGODU-PONNAMPETE	PONNAMPET_66, VIRAJPET_66	11:18	13:03	1:44	NFBC ISSUED
216	6-Nov-19	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66, PONNAMPET_66, VIRAJPET_66	23:25	23:40	0:15	LINE FAULT
217	6-Nov-19	MYSORE	66	HV2	SANTHESARAGUR_66	10:18	10:28	0:10	TRANSFORMER FAULT
218	6-Nov-19	MYSORE	66	HV2	SANTHESARAGUR_66	16:00	18:03	2:02	LINE CLEAR AVAILED
219	6-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	13:23	13:51	0:28	LINE CLEAR AVAILED
220	6-Nov-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	5:32	5:43	0:11	LINE FAULT
221	6-Nov-19	TUMKUR	220	ANCHEPALYA 220KV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	10:49	10:53	0:03	LINE FAULT
222	6-Nov-19	TUMKUR	220	TR-3(HV SIDE)	DAVANGERE_SRS_220	21:53	22:10	0:17	TRANSFORMER FAULT
223	6-Nov-19	TUMKUR	66	ANCHEPALYA 220KV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	10:42	10:45	0:02	LINE FAULT
224	6-Nov-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	22:08	22:16	0:07	HAND TRIPPED
225	6-Nov-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	22:08	22:16	0:08	HAND TRIPPED
226	6-Nov-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:53	22:15	0:22	LINE FAULT
227	6-Nov-19	TUMKUR	66	TR-2	HIREGUNTANUR_66	5:04	5:15	0:10	TRANSFORMER FAULT
228	6-Nov-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	8:28	8:40	0:12	LINE CLEAR AVAILED
229	6-Nov-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	11:18	12:00	0:41	LINE CLEAR AVAILED
230	6-Nov-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_IPP_66	8:52	9:04	0:11	MAIN SUPPLY FAILURE
231	6-Nov-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	11:38	11:46	0:08	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
232	6-Nov-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	9:15	9:44	0:28	LINE CLEAR AVAILED
233	7-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	9:04	12:53	3:49	LINE CLEAR AVAILED
234	7-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	12:56	17:38	4:42	LINE CLEAR AVAILED
235	7-Nov-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	11:16	11:27	0:11	HAND TRIPPED
236	7-Nov-19	BAGALKOT	110	110/33KV,HV4	GADAG_110,LAKUNDI_33,HULKOTI_33,TDPL1&2_33	6:37	9:51	3:14	TRANSFORMER FAULT
237	7-Nov-19	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	22:03	23:59	1:56	LINE CLEAR AVAILED
238	7-Nov-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	12:15	13:08	0:53	LINE FAULT
239	7-Nov-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	0:00	13:00	13:00	LINE CLEAR AVAILED
240	7-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:38	11:51	11:13	LINE FAULT
241	7-Nov-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:46	23:59	1:13	LINE CLEAR AVAILED
242	7-Nov-19	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	0:00	7:36	7:36	LINE CLEAR AVAILED
243	7-Nov-19	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	21:59	23:59	2:00	LINE CLEAR AVAILED
244	7-Nov-19	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,KAMATAGI_33	0:08	0:14	0:06	TRANSFORMER FAULT
245	7-Nov-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	10:05	13:48	3:43	LINE CLEAR AVAILED
246	7-Nov-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	7:05	7:46	0:41	LINE CLEAR AVAILED
247	7-Nov-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:24	7:00	6:36	LINE CLEAR AVAILED
248	7-Nov-19	BAGALKOT	110	TODLBAGI-JAMAKHANDI SUGARS (IPP)	TODLBAGI_IPP,JAMAKHANDI SUGARS_IPP	22:42	22:43	0:01	LINE FAULT
249	7-Nov-19	BAGALKOT	110	110/11KV,HV3	TODALBAGI_110	16:55	17:00	0:05	LINE CLEAR AVAILED
250	7-Nov-19	BAGALKOT	110	HUBLI220-PHCOMPOUND	PHCOMPOUND_110	11:42	12:22	0:40	HAND TRIPPED
251	7-Nov-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	16:52	17:43	0:51	LINE CLEAR AVAILED
252	7-Nov-19	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	5:15	5:25	0:10	MAIN SUPPLY FAILURE
253	7-Nov-19	BAGALKOT	110	RANEBENNUR 220-AREMALLAPUR (HONNATTI)	HONNATTI_110	7:21	7:31	0:10	LINE FAULT
254	7-Nov-19	BAGALKOT	110	RANEBENNUR 220-AREMALLAPUR (HONNATTI)	HONNATTI_111	13:49	18:07	4:18	LINE CLEAR AVAILED
255	7-Nov-19	BAGALKOT	110	BPCL-NARGUND	NARGUND_110	0:00	0:34	0:34	LINE CLEAR AVAILED
256	7-Nov-19	BAGALKOT	110	BPCL-NARGUND	NARGUND_110,BPCL_IPP	4:49	17:59	13:10	LINE CLEAR AVAILED
257	7-Nov-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	6:12	6:14	0:02	LOAD CHANGE OVER
258	7-Nov-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	7:08	7:37	0:29	LOAD CHANGE OVER
259	7-Nov-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:42	10:47	0:05	LOAD CHANGE OVER
260	7-Nov-19	BENGALURU	66	KHODAYS 220 - KHODAYS 66	KHODAYS 66	10:42	10:47	0:05	LOAD CHANGE OVER
261	7-Nov-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	7:06	7:57	0:51	LINE FAULT
262	7-Nov-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	12:29	12:30	0:01	LOAD CHANGE OVER
263	7-Nov-19	GULBARGA	220	HV2	KUSTAGI_220	11:20	12:17	0:57	LINE CLEAR AVAILED
264	7-Nov-19	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	10:43	12:15	1:32	LINE FAULT
265	7-Nov-19	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	17:32	17:45	0:13	LINE FAULT
266	7-Nov-19	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	19:46	19:55	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
267	7-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	17:48	17:48	LINE CLEAR AVAILED
268	7-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:34	23:59	0:25	HAND TRIPPED
269	7-Nov-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	17:36	19:02	1:26	LINE CLEAR AVAILED
270	7-Nov-19	HASSAN	220	AESK2-HSN	ARASIKERE_220	0:57	1:57	1:00	HAND TRIPPED
271	7-Nov-19	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	0:07	0:25	0:18	LINE FAULT
272	7-Nov-19	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	0:56	9:25	8:29	LINE CLEAR AVAILED
273	7-Nov-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	19:25	19:35	0:10	LINE FAULT
274	7-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	17:27	19:02	1:35	LINE CLEAR AVAILED
275	7-Nov-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:21	18:02	8:41	NFBC ISSUED
276	7-Nov-19	HASSAN	220	MRSSHM-HASSAN	MRSMG_220	0:07	9:23	9:16	LINE FAULT
277	7-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	17:28	18:04	0:36	LINE FAULT
278	7-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	17:13	18:54	1:41	LINE FAULT
279	7-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	17:13	18:55	1:42	LINE FAULT
280	7-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	22:05	23:59	1:54	LINE FAULT
281	7-Nov-19	HASSAN	110	MRSSHM-MPM	MRSMG_220	0:00	9:52	9:52	LINE FAULT
282	7-Nov-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	17:28	18:05	0:37	LINE FAULT
283	7-Nov-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	17:13	18:56	1:43	LINE FAULT
284	7-Nov-19	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	17:13	18:55	1:42	LINE FAULT
285	7-Nov-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	22:05	23:59	1:54	LINE FAULT
286	7-Nov-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:21	18:02	8:41	LINE CLEAR AVAILED
287	7-Nov-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	0:00	0:15	0:15	LINE FAULT
288	7-Nov-19	HASSAN	110	HV4	MANIPAL_110	17:02	17:07	0:05	HAND TRIPPED
289	7-Nov-19	HASSAN	110	HV2	MOODABIDRE_110	17:27	17:45	0:18	LINE CLEAR AVAILED
290	7-Nov-19	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	7:11	9:53	2:42	LINE FAULT
291	7-Nov-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	0:00	0:03	0:03	LINE FAULT
292	7-Nov-19	HASSAN	110	SHIVAPU-BIRUR	SHIVPURA_110	0:07	0:49	0:42	LINE FAULT
293	7-Nov-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	6:40	18:45	12:05	LINE CLEAR AVAILED
294	7-Nov-19	HASSAN	66	MALLIPATNARAKAL-A	ARKD_66	16:09	16:17	0:08	LINE FAULT
295	7-Nov-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	23:15	23:21	0:06	LINE FAULT
296	7-Nov-19	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	15:31	15:57	0:26	MAIN SUPPLY FAILURE
297	7-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	13:37	13:40	0:03	LINE FAULT
298	7-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	17:02	17:13	0:11	LINE FAULT
299	7-Nov-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	17:02	17:13	0:11	LINE FAULT
300	7-Nov-19	HASSAN	66	HV2	HOLALUR_66	10:57	12:29	1:32	LINE CLEAR AVAILED
301	7-Nov-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:14	21:21	0:07	LINE FAULT
302	7-Nov-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	9:18	9:22	0:04	TRANSFORMER FAULT
303	7-Nov-19	MYSORE	66	HV2	BOOKANAKERE_66	15:55	16:02	0:07	LINE CLEAR AVAILED
304	7-Nov-19	MYSORE	66	HV2	BOOKANAKERE_66	16:05	16:14	0:09	HAND TRIPPED
305	7-Nov-19	MYSORE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	16:18	21:01	4:43	LINE CLEAR AVAILED
306	7-Nov-19	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66, KABHALLY_66	18:34	19:04	0:30	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
307	7-Nov-19	MYSORE	66	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66, HONNALY_MYS_66	18:34	19:12	0:38	HAND TRIPPED
308	7-Nov-19	MYSORE	66	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66, HONNALY_MYS_66	19:17	19:21	0:03	LINE FAULT
309	7-Nov-19	MYSORE	66	GUNDLUPETE-CR NAGARA	TERAKANAMBE_66	17:32	19:20	1:47	NFBC ISSUED
310	7-Nov-19	MYSORE	66	HV1	GUNDULPET_66	18:36	19:17	0:41	MAIN SUPPLY FAILURE
311	7-Nov-19	MYSORE	66	HV2	GUNDULPET_66	18:36	19:17	0:41	MAIN SUPPLY FAILURE
312	7-Nov-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66	18:35	19:15	0:40	MAIN SUPPLY FAILURE
313	7-Nov-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	18:35	19:15	0:40	MAIN SUPPLY FAILURE
314	7-Nov-19	MYSORE	66	GUNDLUPETE-HANGALA	HANGLA_66, BHARGI_66	18:35	19:15	0:40	MAIN SUPPLY FAILURE
315	7-Nov-19	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	16:09	16:14	0:04	MAIN SUPPLY FAILURE
316	7-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66,HAMPAPURA(K))_66, HDKOTE_66, JAIPUR_66,	11:07	11:13	0:05	LINE FAULT
317	7-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66,HAMPAPURA(K))_66, HDKOTE_66, JAIPUR_66,	19:46	19:53	0:06	LINE FAULT
318	7-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66,HAMPAPURA(K))_66, HDKOTE_66, JAIPUR_66,	20:59	21:07	0:07	LINE FAULT
319	7-Nov-19	MYSORE	66	HV3	KUSHALANAGARA_66	11:59	13:15	1:16	LINE CLEAR AVAILED
320	7-Nov-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	7:11	7:20	0:09	LINE FAULT
321	7-Nov-19	MYSORE	66	KUSHALANAGARA 220-BETTADHAPURA	BETTADHAPURA_66, CHUNCHUNKATTE_66, KITTUR_66, RAVANDUR_66	16:40	16:52	0:12	LINE FAULT
322	7-Nov-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	18:35	23:59	5:23	LINE FAULT
323	7-Nov-19	MYSORE	66	MANDYA-CHIKKMANDYA	BESAGARAHALLI_66, CHIKKA_MANDYA_66, HAMPAPURA_66, KOPPA_66	7:06	7:16	0:10	LINE FAULT
324	7-Nov-19	MYSORE	66	MEGHALAPURA-SFC	CHIDRAVALI_66, TNARASIPURA_66, THUMBLA_66	20:35	20:50	0:15	LINE FAULT
325	7-Nov-19	MYSORE	66	HV1	SANTHESARAGUR_66	8:00	8:25	0:25	LINE CLEAR AVAILED
326	7-Nov-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:05	13:05	3:00	LINE CLEAR AVAILED
327	7-Nov-19	MYSORE	66	HV1	SANTHESARAGUR_66	18:50	18:56	0:06	TRANSFORMER FAULT
328	7-Nov-19	MYSORE	66	HV2	SANTHESARAGUR_66	12:45	18:38	5:53	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
329	7-Nov-19	MYSORE	66	HV2	SUTTUR_66	19:01	19:12	0:10	HAND TRIPPED
330	7-Nov-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	20:26	20:36	0:09	LINE FAULT
331	7-Nov-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALI_66, MEGALAPURA_66, TNARASIPURA_66, THUMBLA_66	13:04	13:20	0:15	LINE FAULT
332	7-Nov-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALI_66, MEGALAPURA_66, TNARASIPURA_66, THUMBLA_66	18:07	18:35	0:27	LINE FAULT
333	7-Nov-19	MYSORE	66	HV1	VIJAYANAGRAMYS_66	22:35	23:59	1:23	TRANSFORMER FAULT
334	7-Nov-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	13:40	18:18	4:38	LINE CLEAR AVAILED
335	7-Nov-19	TUMKUR	110	TR-3(HV SIDE)	AMMASANDRA_110	13:06	13:38	0:32	TRANSFORMER FAULT
336	7-Nov-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:17	17:33	0:16	LINE CLEAR AVAILED
337	7-Nov-19	TUMKUR	110	TR-1&TR-2	CHIKKANAYAKANAHALLI_110	17:17	17:27	0:09	LINE CLEAR AVAILED
338	7-Nov-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	17:16	17:28	0:11	LINE CLEAR AVAILED
339	7-Nov-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	19:37	20:15	0:37	HAND TRIPPED
340	7-Nov-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	20:18	20:34	0:15	LINE FAULT
341	7-Nov-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	19:37	20:21	0:44	HAND TRIPPED
342	7-Nov-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	19:37	20:14	0:37	HAND TRIPPED
343	7-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:50	12:55	0:05	LINE FAULT
344	7-Nov-19	TUMKUR	66	HIRIYURKV 220kV- SUZLON 2	SUZLON1_IPP_66	13:52	15:22	1:29	LINE CLEAR AVAILED
345	7-Nov-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	20:53	21:07	0:13	LINE FAULT
346	7-Nov-19	TUMKUR	66	TR-2(LV SIDE)	HONNALLI_220	15:06	15:48	0:42	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
347	7-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:52	14:02	0:09	LINE FAULT
348	7-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	20:53	21:06	0:12	LINE FAULT
349	7-Nov-19	TUMKUR	66	TR-2	LINGADAHALLY_66	13:23	17:53	4:30	LINE CLEAR AVAILED
350	7-Nov-19	TUMKUR	66	TR-2	RANGANATHAPURA_66	16:59	17:34	0:34	LINE CLEAR AVAILED
351	8-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	10:07	18:50	8:43	LINE CLEAR AVAILED
352	8-Nov-19	BAGALKOT	110	SUPA 2-AMBEWADI	AMBEWADI_220	11:02	11:40	0:38	LINE FAULT
353	8-Nov-19	BAGALKOT	110	SUPA 1&2-AMBEWADI	AMBEWADI_220	15:03	17:01	1:58	LINE CLEAR AVAILED
354	8-Nov-19	BAGALKOT	220	BAGAKOT-GADAG 1	BAGALKOT_220	0:00	9:06	9:06	LINE CLEAR AVAILED
355	8-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	1:07	6:55	5:48	LINE CLEAR AVAILED
356	8-Nov-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	6:57	6:57	LINE CLEAR AVAILED
357	8-Nov-19	BAGALKOT	110	110/33KV,HV4	GADAG_110	9:45	12:05	2:20	LINE CLEAR AVAILED
358	8-Nov-19	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	9:30	17:50	8:20	LINE CLEAR AVAILED
359	8-Nov-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA1&2	GHATAPRABHA_110	9:20	17:34	8:14	LINE CLEAR AVAILED
360	8-Nov-19	BAGALKOT	110	110/11KV,HV1&HV2	GHATAPRABHA_110	9:50	18:10	8:20	LINE CLEAR AVAILED
361	8-Nov-19	BAGALKOT	110	110/33KV,HV3 HV4&HV5	GHATAPRABHA_110,KALLOLLI_33,M ANTUR_33,GOKAK MILLS_33	9:50	17:35	7:45	LINE CLEAR AVAILED
362	8-Nov-19	BAGALKOT	220	KUDUCHI-GHATAPRABHA	KUDUCHI_220	0:00	8:27	8:27	LINE CLEAR AVAILED
363	8-Nov-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	10:17	12:08	1:51	LINE CLEAR AVAILED
364	8-Nov-19	BAGALKOT	110	110/33KV,HV1&HV2	HANGAL_110,PALA_33,AKKIALURU_33,BELAGALPETE_33,BOMMANAHALLI_33,LAXMIPURA_33	10:14	12:11	1:57	LINE CLEAR AVAILED
365	8-Nov-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMING AD_33,MYTRA SOLAR_33	9:03	9:36	0:33	TRANSFORMER FAULT
366	8-Nov-19	BAGALKOT	110	GHATAPRABHA-HATTARGI	HATTARGI_110	8:10	18:39	10:29	LINE CLEAR AVAILED
367	8-Nov-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:00	6:02	5:02	LINE CLEAR AVAILED
368	8-Nov-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	1:02	6:02	5:00	LINE CLEAR AVAILED
369	8-Nov-19	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	5:35	5:49	0:14	LINE FAULT
370	8-Nov-19	BAGALKOT	110	NARENDRA220-MRUTHYUNJAY NAGAR	MRUTHYUNJAY NAGAR_110	10:43	12:56	2:13	LINE CLEAR AVAILED
371	8-Nov-19	BAGALKOT	110	110/11KV, HV2	YELLAPARHATTI_110	13:10	14:11	1:01	LINE CLEAR AVAILED
372	8-Nov-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	9:39	16:18	6:39	LINE CLEAR AVAILED
373	8-Nov-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	11:28	15:18	3:50	LINE FAULT
374	8-Nov-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	13:16	13:20	0:04	LINE FAULT
375	8-Nov-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	13:01	14:03	1:02	LINE CLEAR AVAILED
376	8-Nov-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	10:04	18:26	8:22	LINE CLEAR AVAILED
377	8-Nov-19	BENGALURU	66	HV1	AREHALLI	11:22	11:25	0:03	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
378	8-Nov-19	BENGALURU	66	ELECTRONIC CITYPH-2 SEC-2 - NAGANATHPURA	ELECTRONIC CITYPH-2 SEC-2,BIOCON	13:52	14:11	0:19	LINE CLEAR AVAILED
379	8-Nov-19	BENGALURU	66	HV2	ELECTRONIC CITYPH-2 SEC-2	10:08	10:38	0:30	TRANSFORMER FAULT
380	8-Nov-19	BENGALURU	66	HV2	ELECTRONIC CITYPH-2 SEC-2	13:00	14:12	1:12	LINE CLEAR AVAILED
381	8-Nov-19	BENGALURU	66	HV1	HEBBAL 220	0:53	12:31	11:38	TRANSFORMER FAULT
382	8-Nov-19	BENGALURU	66	HEJJALA-BIDADI 220	HEJJALA	10:04	18:03	7:59	LINE CLEAR AVAILED
383	8-Nov-19	BENGALURU	66	IISC - HEBBAL 220	IISC	0:53	1:06	0:13	LOAD CHANGE OVER
384	8-Nov-19	BENGALURU	66	IISC - NRS 220	IISC	6:09	6:12	0:03	LOAD CHANGE OVER
385	8-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	14:02	23:59	9:57	LINE FAULT
386	8-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	14:35	23:59	9:24	LINE FAULT
387	8-Nov-19	BENGALURU	66	HV1	CB PURA I/A	23:37	23:59	0:22	TRANSFORMER FAULT
388	8-Nov-19	BENGALURU	66	BAGEPALLI - PATHPALYA	PATHPALYA	14:15	17:15	3:00	LINE CLEAR AVAILED
389	8-Nov-19	BENGALURU	66	HV1	BAGEPALLI	10:30	10:45	0:15	LINE CLEAR AVAILED
390	8-Nov-19	GULBARGA	66	HV1,HV2	CHORNOOR_66	7:10	7:15	0:05	LINE CLEAR AVAILED
391	8-Nov-19	GULBARGA	66	HV1	CHORNOOR_66	11:00	11:10	0:10	LINE CLEAR AVAILED
392	8-Nov-19	GULBARGA	66	HV2	CHORNOOR_66	11:00	11:05	0:05	LINE CLEAR AVAILED
393	8-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	8:08	8:08	LINE CLEAR AVAILED
394	8-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:04	23:59	9:55	LINE CLEAR AVAILED
395	8-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	14:18	14:18	LINE CLEAR AVAILED
396	8-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:35	23:59	0:24	HAND TRIPPED
397	8-Nov-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	8:20	16:20	8:00	LINE CLEAR AVAILED
398	8-Nov-19	HASSAN	220	HV1	MRSMG_220	9:14	18:11	8:57	LINE CLEAR AVAILED
399	8-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	0:00	8:46	8:46	LINE FAULT
400	8-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	10:07	13:24	3:17	LINE FAULT
401	8-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	14:06	17:01	2:55	LINE FAULT
402	8-Nov-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:21	16:10	7:49	LINE CLEAR AVAILED
403	8-Nov-19	HASSAN	220	SHRAVTY-SHSHIMOGA4	sharavathy_gen	0:00	8:46	8:46	LINE FAULT
404	8-Nov-19	HASSAN	220	SHRAVTY-SHSHIMOGA4	sharavathy_gen	10:07	13:24	3:17	LINE FAULT
405	8-Nov-19	HASSAN	220	SHRAVTY-SHSHIMOGA4	sharavathy_gen	14:06	17:02	2:56	LINE FAULT
406	8-Nov-19	HASSAN	110	LV1	MRSMG_220	9:14	18:11	8:57	LINE CLEAR AVAILED
407	8-Nov-19	HASSAN	110	HV1	PUTTUR_110	15:40	18:03	2:23	LINE CLEAR AVAILED
408	8-Nov-19	HASSAN	110	HV2	PUTTUR_110	10:41	15:06	4:25	LINE CLEAR AVAILED
409	8-Nov-19	HASSAN	110	HV1	GURUVAYANAKERE_110	20:17	23:59	3:42	LINE CLEAR AVAILED
410	8-Nov-19	HASSAN	110	HV2	KADUR_220	11:40	13:10	1:30	LINE CLEAR AVAILED
411	8-Nov-19	HASSAN	110	HV2	MOODABIDRE_110	10:11	10:34	0:23	LINE CLEAR AVAILED
412	8-Nov-19	HASSAN	110	HV2	SHIKARIPURA_110	14:41	15:13	0:32	LINE CLEAR AVAILED
413	8-Nov-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	14:35	18:00	3:25	LINE CLEAR AVAILED
414	8-Nov-19	HASSAN	66	HV1	DODDAKADANUR_66	22:04	22:19	0:15	MAIN SUPPLY FAILURE
415	8-Nov-19	HASSAN	66	HV1	HIRISAVE_66	11:30	13:55	2:25	LINE CLEAR AVAILED
416	8-Nov-19	HASSAN	66	HV2	HIRISAVE_66	12:25	13:55	1:30	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
417	8-Nov-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	21:58	22:16	0:18	LINE FAULT
418	8-Nov-19	HASSAN	66	HV2	TAVARECHANAHALLI_66	12:02	12:29	0:27	HAND TRIPPED
419	8-Nov-19	MYSORE	66	HV2	BILIKERE_66	15:48	17:28	1:40	LINE CLEAR AVAILED
420	8-Nov-19	MYSORE	66	HV1	DODDINADUVADI_66	10:44	12:11	1:26	LINE CLEAR AVAILED
421	8-Nov-19	MYSORE	66	HV1	DODDINADUVADI_66	14:02	15:15	1:12	LINE CLEAR AVAILED
422	8-Nov-19	MYSORE	66	HV1	DODDINADUVADI_66	16:18	17:48	1:30	LINE CLEAR AVAILED
423	8-Nov-19	MYSORE	66	HOOTAGALLY-HUNSUR	HUNSUR_66,BANNIKUPPE_66,HOSU RGATE_66	22:30	22:41	0:11	LINE FAULT
424	8-Nov-19	MYSORE	66	HV2	JAKKANAHALLY_66	18:51	19:10	0:19	LINE CLEAR AVAILED
425	8-Nov-19	MYSORE	66	HV1	KADAKOLA_220	9:49	13:51	4:02	LINE CLEAR AVAILED
426	8-Nov-19	MYSORE	66	HV2	KADAKOLA_220	14:40	17:15	2:35	LINE CLEAR AVAILED
427	8-Nov-19	MYSORE	66	KR PETE-AKIHABAL1	AKKIHBBAL_66	20:50	21:07	0:17	LINE FAULT
428	8-Nov-19	MYSORE	220	HV1	KUSHALNAGARA_220	16:29	16:32	0:02	TRANSFORMER FAULT
429	8-Nov-19	MYSORE	66	KUSHALNAGAR 220-MERCERA-1	MADIKERI_66,SUNTIKOPPA_66	8:49	11:35	2:46	LINE CLEAR AVAILED
430	8-Nov-19	MYSORE	66	KUSHALNAGAR 220-SUNTIKOPPA	MADIKERI_66,SUNTIKOPPA_66	8:49	11:35	2:46	LINE CLEAR AVAILED
431	8-Nov-19	MYSORE	66	HV1	SFCSHIVA_66	22:20	22:56	0:36	TRANSFORMER FAULT
432	8-Nov-19	MYSORE	66	HV2	SUTTUR_66	5:13	18:15	13:02	LINE CLEAR AVAILED
433	8-Nov-19	MYSORE	66	HV2	THALAKADU_66	3:28	3:57	0:28	TRANSFORMER FAULT
434	8-Nov-19	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66,MALIYURU_66,KIRUGA VALU_66	11:56	12:19	0:23	LINE FAULT
435	8-Nov-19	MYSORE	66	HV1	VIRAJPET_66	21:45	22:02	0:17	HAND TRIPPED
436	8-Nov-19	MYSORE	66	HV2	VIRAJPET_66	21:45	22:02	0:17	HAND TRIPPED
437	8-Nov-19	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	9:32	18:01	8:28	LINE CLEAR AVAILED
438	8-Nov-19	TUMKUR	110	TR-3	AMMASANDRA_110	15:33	19:08	3:34	LINE CLEAR AVAILED
439	8-Nov-19	TUMKUR	110	TR-1	KBCROSS_220	9:32	18:01	8:29	LINE CLEAR AVAILED
440	8-Nov-19	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	14:58	15:19	0:20	LINE FAULT
441	8-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	6:15	6:45	0:30	LINE FAULT
442	8-Nov-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	6:39	7:02	0:23	LINE FAULT
443	8-Nov-19	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	17:07	17:52	0:45	LINE CLEAR AVAILED
444	8-Nov-19	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	17:07	17:52	0:45	LINE CLEAR AVAILED
445	8-Nov-19	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	17:07	17:52	0:45	LINE CLEAR AVAILED
446	8-Nov-19	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	14:03	14:36	0:33	LINE CLEAR AVAILED
447	8-Nov-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	HIREGUNTANUR_66	11:43	12:45	1:02	LINE CLEAR AVAILED
448	8-Nov-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	HIREGUNTANUR_66	14:30	14:38	0:08	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
449	8-Nov-19	TUMKUR	66	TR-1	HIREGUNTANUR_66	11:43	12:45	1:02	LINE CLEAR AVAILED
450	8-Nov-19	TUMKUR	66	TR-1	HIREGUNTANUR_66	14:30	14:38	0:08	LINE CLEAR AVAILED
451	8-Nov-19	TUMKUR	66	TR-2	HIREGUNTANUR_66	11:43	12:45	1:02	LINE CLEAR AVAILED
452	8-Nov-19	TUMKUR	66	TR-2	HIREGUNTANUR_66	14:30	14:38	0:08	LINE CLEAR AVAILED
453	8-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	2:58	3:15	0:17	LINE FAULT
454	8-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:06	12:45	2:38	LINE FAULT
455	8-Nov-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:54	10:03	0:08	LINE FAULT
456	8-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:46	6:56	0:09	LINE FAULT
457	8-Nov-19	TUMKUR	66	TR-2(LV SIDE)	HONNALLI_220	10:39	11:53	1:14	LINE CLEAR AVAILED
458	8-Nov-19	TUMKUR	66	TR-1	LINGADAHALLY_66	11:18	16:38	5:19	LINE CLEAR AVAILED
459	8-Nov-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	6:48	7:05	0:17	MAIN SUPPLY FAILURE
460	8-Nov-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	6:48	7:05	0:17	MAIN SUPPLY FAILURE
461	9-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	10:41	16:50	6:09	LINE CLEAR AVAILED
462	9-Nov-19	BAGALKOT	220	BIDNAL-TADAS 2	BIDNAL_220	2:12	23:59	21:47	LINE FAULT
463	9-Nov-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:08	17:18	4:10	LINE FAULT
464	9-Nov-19	BAGALKOT	110	ANTHAPURAM SOLAR-KONNUR	KONNUR_110	11:54	12:11	0:17	LINE CLEAR AVAILED
465	9-Nov-19	BAGALKOT	110	220/110KV,HV2&LV2	MK HUBLI_220	13:50	17:55	4:05	LINE CLEAR AVAILED
466	9-Nov-19	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	23:36	23:59	0:23	LINE FAULT
467	9-Nov-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	3:03	8:28	5:25	TRANSFORMER FAULT
468	9-Nov-19	BAGALKOT	110	RATTIHALI-HIREKERUR	RATTIHALI_110	14:15	14:40	0:25	MAIN SUPPLY FAILURE
469	9-Nov-19	BAGALKOT	110	RATTIHALI-HIREKERUR	RATTIHALI_110	17:45	23:59	6:14	LINE CLEAR AVAILED
470	9-Nov-19	BAGALKOT	220	RANEENNUR -BALLIGAVI	RANEENNUR_220	14:16	14:51	0:35	LINE FAULT
471	9-Nov-19	BAGALKOT	110	RANEENNUR 220- TUMMINAKATTI,BYADAGI,GUTTAL,HONNATTI, HIREKERUR	TUMMINAKATTI_110,BYADAGI_110 ,GUTTAL_110,HONNATTI_110,HIREK ERUR_110	14:20	14:45	0:25	MAIN SUPPLY FAILURE
472	9-Nov-19	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	0:00	14:35	14:35	LINE CLEAR AVAILED
473	9-Nov-19	BAGALKOT	110	220/110KV,LV1	RANEENNUR_220	15:25	17:40	2:15	LINE CLEAR AVAILED
474	9-Nov-19	BAGALKOT	110	PGHUNSYAL-NAGNUR	NAGNUR_110	19:04	19:14	0:10	LINE FAULT
475	9-Nov-19	BAGALKOT	110	PGHUNSYAL-SATTISUGARS	SATTISUGAR_IPP	19:04	19:15	0:11	LINE FAULT
476	9-Nov-19	BENGALURU	66	SRS PEENYA 220 - DG 3	ATTUR YELAHANKA	15:00	15:35	0:35	LINE CLEAR AVAILED
477	9-Nov-19	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	16:58	17:23	0:25	LINE CLEAR AVAILED
478	9-Nov-19	BENGALURU	66	ABBIGERE- PUTTENAHALLI	ABBIGERE	13:11	13:15	0:04	LOAD CHANGE OVER
479	9-Nov-19	BENGALURU	66	ABBIGERE- NRS	ABBIGERE	17:41	17:45	0:04	LOAD CHANGE OVER
480	9-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	6:10	6:37	0:27	LINE FAULT
481	9-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	6:10	6:37	0:27	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
482	9-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	6:10	6:35	0:25	LINE FAULT
483	9-Nov-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	9:54	10:41	0:47	LINE FAULT
484	9-Nov-19	BENGALURU	66	HV1	CB PURA I/A	0:00	0:50	0:50	TRANSFORMER FAULT
485	9-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:27	23:59	21:32	LINE FAULT
486	9-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:49	6:49	LINE CLEAR AVAILED
487	9-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:54	23:59	0:05	HAND TRIPPED
488	9-Nov-19	HASSAN	220	HV3	MRSMG_220	11:45	13:20	1:35	LINE CLEAR AVAILED
489	9-Nov-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	14:16	14:58	0:42	LINE FAULT
490	9-Nov-19	HASSAN	220	HV2	SHIRALKOPPA_220	9:30	15:28	5:58	LINE CLEAR AVAILED
491	9-Nov-19	HASSAN	110	LV3	MRSMG_220	11:40	13:21	1:41	LINE CLEAR AVAILED
492	9-Nov-19	HASSAN	110	MRSSHM-SS1	MRSMG_220	10:42	11:19	0:37	LINE FAULT
493	9-Nov-19	HASSAN	110	ALKOLA-MRS	ALKOLA_110	10:45	11:27	0:42	LINE FAULT
494	9-Nov-19	HASSAN	110	ALKOLA-LPH	ALKOLA_110	10:45	11:10	0:25	LINE FAULT
495	9-Nov-19	HASSAN	110	HV1	GURUVAYANAKERE_110	0:00	13:16	13:16	LINE CLEAR AVAILED
496	9-Nov-19	HASSAN	110	HV1	KITTADAHALLI_110	14:20	15:00	0:40	MAIN SUPPLY FAILURE
497	9-Nov-19	HASSAN	110	HV2	KONAJE_110	15:00	16:12	1:12	LINE CLEAR AVAILED
498	9-Nov-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	10:42	10:59	0:17	LINE FAULT
499	9-Nov-19	HASSAN	110	LV2	SHIRALKOPPA_220	9:30	15:28	5:58	LINE CLEAR AVAILED
500	9-Nov-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	2:56	3:02	0:06	LINE FAULT
501	9-Nov-19	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPLU_66	14:46	18:29	3:43	LINE FAULT
502	9-Nov-19	MYSORE	66	HANNUR-COWDALLI	COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66 BANDALLI_66	22:37	22:46	0:09	LINE FAULT
503	9-Nov-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	1:35	2:06	0:31	LINE FAULT
504	9-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	3:53	3:56	0:03	LINE FAULT
505	9-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	5:30	5:37	0:07	LINE FAULT
506	9-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	19:25	19:29	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
507	9-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	20:26	20:31	0:04	LINE FAULT
508	9-Nov-19	MYSORE	66	HV1	SUTTUR_66	16:32	17:15	0:43	LINE CLEAR AVAILED
509	9-Nov-19	MYSORE	66	HV2	SUTTUR_66	14:25	16:17	1:52	LINE CLEAR AVAILED
510	9-Nov-19	TUMKUR	66	TR-1	BENNEHALLI_66	8:15	8:16	0:00	HAND TRIPPED
511	9-Nov-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	4:13	4:36	0:23	LINE FAULT
512	9-Nov-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:30	10:41	0:11	LINE FAULT
513	9-Nov-19	TUMKUR	66	NAGALAMADIKE-SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	0:56	6:30	5:33	MAIN SUPPLY FAILURE
514	10-Nov-19	BAGALKOT	110	110/11KV,HV 1	AINAPUR_110	2:44	2:49	0:05	TRANSFORMER FAULT
515	10-Nov-19	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	23:49	23:59	0:10	TRANSFORMER FAULT
516	10-Nov-19	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110	5:56	6:16	0:20	LINE FAULT
517	10-Nov-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	5:56	6:05	0:09	LINE FAULT
518	10-Nov-19	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR_110	6:36	6:55	0:19	LINE FAULT
519	10-Nov-19	BAGALKOT	110	KUDUCHI220-KUDUCHI	KUDUCHI_110	2:13	2:43	0:30	LINE FAULT
520	10-Nov-19	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	0:00	20:05	20:05	LINE CLEAR AVAILED
521	10-Nov-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	2:04	23:59	21:55	LINE CLEAR AVAILED
522	10-Nov-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	2:06	6:00	3:54	LINE CLEAR AVAILED
523	10-Nov-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	16:09	23:59	7:50	LINE CLEAR AVAILED
524	10-Nov-19	BAGALKOT	110	HIRASUGAR FACTORY 2-SANKESHWAR	SANKESHWAR_110	9:01	9:12	0:11	LINE CLEAR AVAILED
525	10-Nov-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	14:08	14:29	0:21	LINE CLEAR AVAILED
526	10-Nov-19	BAGALKOT	110	RATTIHALLI-HIREKERUR	RATTIHALLI_110	0:00	6:36	6:36	LINE CLEAR AVAILED
527	10-Nov-19	BAGALKOT	110	RANEENNUR 220-TUMMINAKATTI	TUMMINAKATTI_110	6:18	8:22	2:04	LINE FAULT
528	10-Nov-19	BENGALURU	66	HV1	ABBIGERE	9:02	9:05	0:03	LINE CLEAR AVAILED
529	10-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	16:00	16:45	0:45	LINE FAULT
530	10-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	16:00	16:45	0:45	LINE FAULT
531	10-Nov-19	BENGALURU	66	KADBISANHALLI - CESSNA TECH PARK	KADBISANAHALLI	11:39	12:03	0:24	LOAD CHANGE OVER
532	10-Nov-19	BENGALURU	66	HV2	KODIHALLI HAROBELE	1:17	1:22	0:05	TRANSFORMER FAULT
533	10-Nov-19	BENGALURU	66	HV2	KODIHALLI HAROBELE	3:25	3:35	0:10	TRANSFORMER FAULT
534	10-Nov-19	BENGALURU	66	HV2	KODIHALLI HAROBELE	3:35	4:00	0:25	TRANSFORMER FAULT
535	10-Nov-19	BENGALURU	66	HV2	KODIHALLI HAROBELE	5:30	6:05	0:35	TRANSFORMER FAULT
536	10-Nov-19	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	10:20	10:40	0:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
537	10-Nov-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	BTPS_WATER,MUKUNDA_110,KAM PLI_110	12:55	13:09	0:14	LINE FAULT
538	10-Nov-19	GULBARGA	110	SINDHANOOR220-NIRLOOPI	SIDHANOOR_220	12:58	14:10	1:12	LINE FAULT
539	10-Nov-19	GULBARGA	110	SINDHANOOR220-NIRLOOPI	SIDHANOOR_220	17:55	18:22	0:27	LINE FAULT
540	10-Nov-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	19:35	19:50	0:15	LINE FAULT
541	10-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	12:49	12:49	LINE FAULT
542	10-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:13	23:59	7:46	LINE CLEAR AVAILED
543	10-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	9:48	9:48	LINE CLEAR AVAILED
544	10-Nov-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	23:23	23:59	0:36	HAND TRIPPED
545	10-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	23:15	23:59	0:44	HAND TRIPPED
546	10-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	23:16	23:59	0:43	HAND TRIPPED
547	10-Nov-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	17:53	23:59	6:06	LINE FAULT
548	10-Nov-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	22:21	23:59	1:38	LINE CLEAR AVAILED
549	10-Nov-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	22:21	23:59	1:38	LINE CLEAR AVAILED
550	10-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	15:09	15:27	0:18	LINE FAULT
551	10-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	23:19	23:59	0:40	HAND TRIPPED
552	10-Nov-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	17:52	23:59	6:07	LINE FAULT
553	10-Nov-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:10	16:42	1:32	LINE FAULT
554	10-Nov-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:10	16:42	1:32	LINE FAULT
555	10-Nov-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:09	16:46	1:37	LINE FAULT
556	10-Nov-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:09	16:46	1:37	LINE FAULT
557	10-Nov-19	HASSAN	110	HV2	KONAJE_110	12:14	13:07	0:53	LINE CLEAR AVAILED
558	10-Nov-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	16:33	16:47	0:14	MAIN SUPPLY FAILURE
559	10-Nov-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	16:33	17:00	0:27	LINE FAULT
560	10-Nov-19	HASSAN	110	SALATHUNTMDNOR	SALATHUR_110	16:57	17:09	0:12	MAIN SUPPLY FAILURE
561	10-Nov-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:22	12:43	0:21	LINE FAULT
562	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66 CHANDAKAVADI_66	0:28	0:35	0:07	LINE FAULT
563	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66 CHANDAKAVADI_66	0:39	0:50	0:10	LINE FAULT
564	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66 B MATKERE_66	0:04	0:09	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
565	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66 B MATKERE_66	0:28	0:36	0:08	LINE FAULT
566	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66 B MATKERE_66	0:39	0:53	0:14	LINE FAULT
567	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66 B MATKERE_66	1:51	1:57	0:05	LINE FAULT
568	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66 B MATKERE_66	2:22	2:27	0:05	LINE FAULT
569	10-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66 B MATKERE_66	2:52	2:59	0:07	LINE FAULT
570	10-Nov-19	MYSORE	66	HV1	KIADBMANDYA_66	3:02	3:25	0:23	HAND TRIPPED
571	10-Nov-19	MYSORE	66	KR PETE 220-BOOKANAKERE	BOOKANAKERE_66 GANJIGERE_66 CHINAKURALI_66 SHEELUNERE_66 BANANGADI_66	12:01	18:16	6:15	LINE FAULT
572	10-Nov-19	MYSORE	66	KR PETE 220-KR PETE 1	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	12:01	13:15	1:14	LINE FAULT
573	10-Nov-19	MYSORE	66	KR PETE 220-KR PETE 2	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	12:01	18:44	6:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
574	10-Nov-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66	16:34	16:41	0:07	LINE FAULT
575	10-Nov-19	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	23:44	23:58	0:14	LINE FAULT
576	10-Nov-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66	13:10	13:17	0:07	LINE FAULT
577	10-Nov-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66	9:48	9:50	0:02	LINE FAULT
578	11-Nov-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	11:59	13:20	1:21	LINE CLEAR AVAILED
579	11-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	10:10	19:32	9:22	LINE CLEAR AVAILED
580	11-Nov-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	14:47	17:02	2:15	LINE CLEAR AVAILED
581	11-Nov-19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	11:10	14:01	2:51	LINE CLEAR AVAILED
582	11-Nov-19	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	14:47	18:05	3:18	LINE CLEAR AVAILED
583	11-Nov-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	13:04	17:00	3:56	LINE CLEAR AVAILED
584	11-Nov-19	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	21:47	23:59	2:12	TRANSFORMER FAULT
585	11-Nov-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	13:43	14:16	0:33	LINE CLEAR AVAILED
586	11-Nov-19	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	21:18	21:44	0:26	LINE FAULT
587	11-Nov-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:00	9:05	9:05	LINE CLEAR AVAILED
588	11-Nov-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:00	9:05	9:05	LINE CLEAR AVAILED
589	11-Nov-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA(EHT)_110	3:07	23:59	20:52	LINE FAULT
590	11-Nov-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	11:46	18:40	6:54	LINE CLEAR AVAILED
591	11-Nov-19	BENGALURU	66	ABBIGERE-PUTTENAHALLI	ABBIGERE	17:26	17:51	0:25	LINE FAULT
592	11-Nov-19	BENGALURU	66	CHANDRA LAYOUT-SUBRAMANYAPURA	CHANDRA LAYOUT	15:37	15:45	0:08	LINE CLEAR AVAILED
593	11-Nov-19	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	12:58	13:23	0:25	LINE CLEAR AVAILED
594	11-Nov-19	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	16:18	16:38	0:20	LINE CLEAR AVAILED
595	11-Nov-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	18:18	18:22	0:04	LINE FAULT
596	11-Nov-19	BENGALURU	66	HV3	JIGANI	13:06	13:10	0:04	LINE CLEAR AVAILED
597	11-Nov-19	BENGALURU	66	HV2	JANGAMAKOTE	9:24	9:57	0:33	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
598	11-Nov-19	BENGALURU	66	HV2	SIDLAGHATTA	15:15	16:58	1:43	LINE CLEAR AVAILED
599	11-Nov-19	GULBARGA	220	BMMISPAT-LINGAPUR	LINGAPUR_220	13:53	16:22	2:29	NFBC ISSUED
600	11-Nov-19	GULBARGA	220	LINGAPUR-JSWVL	JSWVL_220	9:02	12:53	3:51	NFBC ISSUED
601	11-Nov-19	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	14:30	18:02	3:32	LINE CLEAR AVAILED
602	11-Nov-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATER WORKS	6:05	6:20	0:15	LINE FAULT
603	11-Nov-19	GULBARGA	110	BYAGWAT-ACMESOLAR_IPP	BYAGAWAT_110	8:00	11:30	3:30	LINE CLEAR AVAILED
604	11-Nov-19	GULBARGA	110	SHAHPUR-WARDHASOLAR_IPP	SHAHPUR_220	18:41	19:12	0:31	LINE CLEAR AVAILED
605	11-Nov-19	GULBARGA	110	HV1	SHAHPUR_220	10:22	11:18	0:56	LINE CLEAR AVAILED
606	11-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	11:06	11:06	LINE CLEAR AVAILED
607	11-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:10	23:59	10:49	LINE FAULT
608	11-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:27	7:27	LINE CLEAR AVAILED
609	11-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	2:09	2:09	LINE CLEAR AVAILED
610	11-Nov-19	HASSAN	220	HV1	KAVOOR_220	15:29	16:08	0:39	LINE CLEAR AVAILED
611	11-Nov-19	HASSAN	220	HV2	KAVOOR_220	11:09	12:39	1:30	LINE CLEAR AVAILED
612	11-Nov-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	0:00	7:18	7:18	LINE CLEAR AVAILED
613	11-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	7:15	7:15	LINE CLEAR AVAILED
614	11-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	0:00	7:18	7:18	LINE CLEAR AVAILED
615	11-Nov-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:00	13:56	13:56	LINE FAULT
616	11-Nov-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	0:00	7:18	7:18	LINE CLEAR AVAILED
617	11-Nov-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	0:00	7:16	7:16	LINE CLEAR AVAILED
618	11-Nov-19	HASSAN	220	VARAHI-KEMAR2	PUTTUR_220	0:00	7:18	7:18	LINE CLEAR AVAILED
619	11-Nov-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:00	13:55	13:55	LINE FAULT
620	11-Nov-19	HASSAN	110	LV1	KAVOOR_220	15:29	16:08	0:39	LINE CLEAR AVAILED
621	11-Nov-19	HASSAN	110	LV2	KAVOOR_220	11:09	15:28	4:19	LINE CLEAR AVAILED
622	11-Nov-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	5:20	17:15	11:55	LINE FAULT
623	11-Nov-19	HASSAN	110	HV1	ANAVATTI_110	5:20	17:15	11:55	TRANSFORMER FAULT
624	11-Nov-19	HASSAN	110	HV2	ANAVATTI_110	5:20	17:15	11:55	TRANSFORMER FAULT
625	11-Nov-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	5:20	17:15	11:55	LINE FAULT
626	11-Nov-19	HASSAN	110	HV2	MANIPAL_110	11:55	12:41	0:46	TRANSFORMER FAULT
627	11-Nov-19	HASSAN	110	HV1	NERALAKERE_110	0:45	8:17	7:32	TRANSFORMER FAULT
628	11-Nov-19	HASSAN	110	HV1	NERALAKERE_110	13:06	13:50	0:44	LINE CLEAR AVAILED
629	11-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	8:34	11:43	3:09	LINE CLEAR AVAILED
630	11-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	16:20	16:57	0:37	LINE CLEAR AVAILED
631	11-Nov-19	HASSAN	66	HV2	CHIKMAGALUR_66	16:20	16:57	0:37	LINE CLEAR AVAILED
632	11-Nov-19	HASSAN	66	HV1	DUDDA_66	11:24	18:05	6:41	LINE CLEAR AVAILED
633	11-Nov-19	HASSAN	66	HV2	DUDDA_66	15:40	15:50	0:10	TRANSFORMER FAULT
634	11-Nov-19	MYSORE	66	HV2	CHANDAKAVADI_66	12:42	14:14	1:32	LINE CLEAR AVAILED
635	11-Nov-19	MYSORE	66	HV1	CHANDAKAVADI_66	13:00	14:05	1:05	LINE CLEAR AVAILED
636	11-Nov-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	14:31	16:54	2:23	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
637	11-Nov-19	MYSORE	66	HV2	DODDABYADARAHALLI_66	12:36	14:27	1:51	LINE CLEAR AVAILED
638	11-Nov-19	MYSORE	66	HV2	HUNSUR_66	12:32	15:07	2:35	LINE CLEAR AVAILED
639	11-Nov-19	MYSORE	66	HV1	JAKKANAHALLY_66	13:41	14:30	0:48	LINE CLEAR AVAILED
640	11-Nov-19	MYSORE	66	HV1	KIRUGAVALU_66	6:25	17:43	11:18	TRANSFORMER FAULT
641	11-Nov-19	MYSORE	66	NANJANAGUDU-BEGUR	SINDHUVALI_66	15:21	15:33	0:12	LINE FAULT
642	11-Nov-19	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	13:33	14:32	0:58	LINE CLEAR AVAILED
643	11-Nov-19	TUMKUR	220	TR-2(LV SIDE)	ANCHEPALYA_220	15:13	16:03	0:50	LINE CLEAR AVAILED
644	11-Nov-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	16:55	17:16	0:21	LINE CLEAR AVAILED
645	11-Nov-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	15:35	16:49	1:14	LINE CLEAR AVAILED
646	11-Nov-19	TUMKUR	110	TR-1	SAMPIGE_110	13:28	13:57	0:28	HAND TRIPPED
647	11-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	12:52	15:46	2:54	LINE CLEAR AVAILED
648	11-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	15:48	18:20	2:31	LINE CLEAR AVAILED
649	11-Nov-19	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMPIGE_110	13:28	13:57	0:29	HAND TRIPPED
650	11-Nov-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	13:27	14:00	0:32	HAND TRIPPED
651	11-Nov-19	TUMKUR	66	TR-1	ANCHEPALYA_220	13:33	14:33	1:00	LINE CLEAR AVAILED
652	11-Nov-19	TUMKUR	66	TR-2	ANCHEPALYA_220	15:13	16:04	0:51	LINE CLEAR AVAILED
653	11-Nov-19	TUMKUR	66	TR-2	BENNEHALLI_66	15:50	16:16	0:26	LINE CLEAR AVAILED
654	11-Nov-19	TUMKUR	66	BENNEHALLI-KOTTUR	BENNEHALLI_66	20:59	21:13	0:13	LINE FAULT
655	11-Nov-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	11:43	12:08	0:25	HAND TRIPPED
656	11-Nov-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	16:16	16:43	0:27	LINE FAULT
657	11-Nov-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	11:42	12:08	0:26	HAND TRIPPED
658	11-Nov-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	13:01	14:08	1:06	LINE CLEAR AVAILED
659	11-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:24	12:29	2:05	LINE FAULT
660	11-Nov-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:25	15:35	0:10	LINE FAULT
661	11-Nov-19	TUMKUR	66	TR-1	MADHUGIRI_220	13:10	17:09	3:58	LINE CLEAR AVAILED