

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 30.03.21 TO 05.04.2021

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1	30-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
2	30-Mar-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI 110	23:26	23:51	0:25	HAND TRIPPED
3	30-Mar-21	BAGALKOT	110	110/11KV,HV1	SIRSI 110	16:00	16:32	0:32	LINE CLEAR AVOIDED
4	30-Mar-21	BAGALKOT	110	110/11KV,HV2	MUKARTHAL 110	9:34	10:17	0:43	TRANSFORMER FAULT
5	30-Mar-21	BAGALKOT	110	220/110, LV1	STATION NOT AFFECTED VAJJRAMATTI 220	16:39	17:22	0:43	TRANSFORMER FAULT
6	30-Mar-21	BAGALKOT	110	AMBEWADI-NARENDRA1	STATION NOT AFFECTED AMBEWADI 220	12:45	19:10	6:25	LINE CLEAR AVOIDED
7	30-Mar-21	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT AFFECTED BELGAUM 220	07:20	13:51	6:31	LINE FAULT
8	30-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
9	30-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD 110	13:49 (19.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
10	30-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVOIDED
11	30-Mar-21	BAGALKOT	110	HAVERI220-KNNL	STATION NOT AFFECTED HAVERI 220	8:24	12:17	3:53	LINE CLEAR AVOIDED
12	30-Mar-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI 110	19:0 (20.03.2021)	8:59 (30.03.2021)	253:59 hrs	LINE CHARGED
13	30-Mar-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI 110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
14	30-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
15	30-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
16	30-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL 110	0:13 (14.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
17	30-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
18	30-Mar-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
19	30-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON 110	10:29 (26.03.2021)			LINE OPEN : LINE FAULT
20	30-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON 110	10:29 (26.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
21	30-Mar-21	BAGALKOT	110	SANKESHWAR-HUKKERI	STATION NOT AFFECTED SANKESHWAR 110	12:31	21:11	8:40	LINE CLEAR AVOIDED
22	30-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
23	30-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
24	30-Mar-21	BAGALKOT	110	UMMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI 110	17:52	18:24	0:32	LINE CLEAR AVOIDED
25	30-Mar-21	BAGALKOT	110	VAJJRAMATTI220-LOKAPUR	STATION NOT AFFECTED LOKAPUR 110	15:55	16:13	0:18	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
26	30-Mar-21	BAGALKOT	110	VAJJRAMATTI220-LOKAPUR	STATION NOT AFFECTED LOKAPUR 110	16:47	17:34	0:47	HAND TRIPPED
27	30-Mar-21	BAGALKOT	220	220/110, HV1	STATION NOT AFFECTED VAJJRAMATTI 220	16:40	17:19	0:39	TRANSFORMER FAULT
28	30-Mar-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI 220	12:45 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
29	30-Mar-21	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL 220	10:56 (27.03.2021)	15:26 (30.03.2021)	76:30hrs	LINE CHARGED
30	30-Mar-21	BAGALKOT	220	CHIKKODI- GHATAPRABHA1(MUGULKOD)	STATION NOT AFFECTED CHIKKODI 220	09:22	16:14	6:52	NFBC ISSUED
31	30-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
32	30-Mar-21	BAGALKOT	220	GADAG-LINGAPUR2(DHONI)	STATION NOT AFFECTED GADAG 220	14:59	15:24	0:25	LINE FAULT
33	30-Mar-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA 220	9:22	14:11	4:49	LINE CLEAR AVAILED
34	30-Mar-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI2(KUDUCHI)	STATION NOT AFFECTED GHATAPRABHA 220	09:08	14:15	5:07	LINE CLEAR AVAILED
35	30-Mar-21	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI 220	10:56 (27.03.2021)	15:26 (30.03.2021)	76:30hrs	LINE CHARGED
36	30-Mar-21	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI 220	15:58	18:27	2:29	LINE CLEAR AVAILED
37	30-Mar-21	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI 220	15:58	18:28	2:30	LINE CLEAR AVAILED
38	30-Mar-21	BAGALKOT	220	HAVERI-NARENDRA1	STATION NOT AFFECTED HAVERI 220	10:56 (27.03.2021)	12:37 (30.03.2021)	73:41 hrs	LINE CHARGED
39	30-Mar-21	BAGALKOT	220	KUDUCHI-CHIKKODI1(GHATAPRABHA)	STATION NOT AFFECTED KUDUCHI 220	9:08	15:36	6:28	NFBC ISSUED
40	30-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
41	30-Mar-21	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA 220	12:45	17:22	4:37	LINE CLEAR AVAILED
42	30-Mar-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	12:45	17:22	4:37	LINE CLEAR AVAILED
43	30-Mar-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT
44	30-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT
45	30-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
46	30-Mar-21	BAGALKOT	220	VAJJRAMATTI-BAGALKOT2	STATION NOT AFFECTED VAJJRAMATTI 220	11:44	12:50	1:06	LINE CLEAR AVAILED
47	30-Mar-21	BAGALKOT	220	VAJJRAMATTI-KUDAGI1	STATION NOT AFFECTED VAJJRAMATTI 220	18:05	18:06	0:01	LINE CLEAR AVAILED
48	30-Mar-21	BAGALKOT	220	VAJJRAMATTI-KUDAGI2	STATION NOT AFFECTED VAJJRAMATTI 220	18:12	18:13	0:01	LINE CLEAR AVAILED
49	30-Mar-21	BAGALKOT	220	VAJJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
50	30-Mar-21	BAGALKOT	220	VAJJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
51	30-Mar-21	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	13:45	13:58	00:13	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
52	30-Mar-21	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	14:50	14:59	00:09	LOAD CHANGE OVER
53	30-Mar-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	00:22	00:33	00:11	LINE FAULT
54	30-Mar-21	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:55	18:59	00:04	LOAD CHANGE OVER
55	30-Mar-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:19	18:36	00:17	LINE FAULT
56	30-Mar-21	BENGALURU	66	HV1	GUNDLU KOTTUR	13:33	14:19	00:46	LINE CLEAR AVAILED
57	30-Mar-21	BENGALURU	66	HV1	ELECTRONIC CITY	14:05	14:09	00:04	LINE CLEAR AVAILED
58	30-Mar-21	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	14:14	14:28	00:14	LINE CLEAR AVAILED
59	30-Mar-21	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	13:37	14:04	00:27	LINE CLEAR AVAILED
60	30-Mar-21	BENGALURU	66	HV2	TELECOM LAYOUT	16:02	16:25	00:23	TRANSFORMER FAULT
61	30-Mar-21	BENGALURU	66	KADUGODI - ARMY WELFARE	KONDASPURA, ARMY WELFARE	18:35	19:35	00:59	LINE FAULT
62	30-Mar-21	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	13:20	13:37	00:17	LINE CLEAR AVAILED
63	30-Mar-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	13:01	14:47	01:46	LINE CLEAR AVAILED
64	30-Mar-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:01	14:35	01:34	LINE CLEAR AVAILED
65	30-Mar-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:36	14:40	00:04	LINE CLEAR AVAILED
66	30-Mar-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, SOMAYAJANAHALLI	10:50	11:00	00:10	LINE FAULT
67	30-Mar-21	BENGALURU	66	MARALVADI - GODURU	GODURU	06:42	07:05	00:23	LINE FAULT
68	30-Mar-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	06:54	07:08	00:14	LINE FAULT
69	30-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
70	30-Mar-21	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	KIADB DB PURA 220	17:15	17:38	00:23	LINE FAULT
71	30-Mar-21	BENGALURU	220	KIADB DB PURA 220 - DB PURA 220	NO STATION AFFECTED	13:05 (29-03-2021)	15:48(30-03-2021)	26:42 hrs	LINE CHARGED
72	30-Mar-21	GULBARGA	110	HV1	KURKUNTA_110	06:30	06:45	00:15	TRANSFORMER FAULT
73	30-Mar-21	GULBARGA	110	HV1	KURKUNTA_110	8:25(30.03.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
74	30-Mar-21	GULBARGA	110	HV1	BENNUR_110	15:00	15:20	00:20	TRANSFORMER FAULT
75	30-Mar-21	GULBARGA	110	HV2	HATTI_110	10:44	11:03	00:19	TRANSFORMER FAULT
76	30-Mar-21	GULBARGA	110	HV2	MADIYAL_110	11:40	12:00	00:20	LINE CLEAR AVAILED
77	30-Mar-21	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	08:24	08:40	00:16	LINE FAULT
78	30-Mar-21	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)			LINE OPEN:LINE CLEAR AVAILED
79	30-Mar-21	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	11:28	12:40	01:12	LINE FAULT
80	30-Mar-21	GULBARGA	220	ALIPUR-RAGHALPADU	ALIPUR_220	05:55	06:37	00:42	LINE FAULT
81	30-Mar-21	GULBARGA	220	ALIPUR-RAGHALPADU	ALIPUR_220	15:15	15:56	00:41	LINE FAULT
82	30-Mar-21	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	11:28	12:40	01:12	LINE FAULT
83	30-Mar-21	GULBARGA	220	LINGASUGUR-BAGEWADI1	BAGEWADI_220	11:23	14:10	02:47	LINE CLEAR AVAILED
84	30-Mar-21	GULBARGA	400	BTPS-JSWVL	BTPS_400	12:37(28.03.2021)	11:21(30.03.2021)	46:44HRS	LINE CHARGED
85	30-Mar-21	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	06:19	06:30	00:11	LINE FAULT
86	30-Mar-21	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	10:27	11:09	00:42	LINE CLEAR AVAILED
87	30-Mar-21	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	14:50	16:21	01:31	MAIN SUPPLY FAILURE
88	30-Mar-21	HASSAN	66	HV1	ALDUR_66	18:26	18:41	00:15	TRANSFORMER FAULT
89	30-Mar-21	HASSAN	66	HV1	AREHALLI_66	14:50	16:21	01:31	MAIN SUPPLY FAILURE
90	30-Mar-21	HASSAN	66	HV1	SINGAPURA_66	06:22	06:31	00:09	MAIN SUPPLY FAILURE
91	30-Mar-21	HASSAN	66	HV2	HOLALUR_66	09:17	10:12	00:55	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
92	30-Mar-21	HASSAN	66	HV2	SINGAPURA_66	06:22	06:31	00:09	MAIN SUPPLY FAILURE
93	30-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
94	30-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
95	30-Mar-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:20	10:24	00:04	LINE FAULT
96	30-Mar-21	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	14:47	16:20	01:33	LINE CLEAR AVAILED
97	30-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	08:56	12:30	03:34	LINE CLEAR AVAILED
98	30-Mar-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	08:56	12:30	03:34	LINE CLEAR AVAILED
99	30-Mar-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	09:04	10:11	01:07	LINE FAULT
100	30-Mar-21	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	08:42	08:53	00:11	MAIN SUPPLY FAILURE
101	30-Mar-21	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	10:41(30.3.2021)			LINE OPEN:LINE CLEAR AVAILED
102	30-Mar-21	HASSAN	110	HULICA-HSNGD	HULICAL_110	11:04	12:35	01:31	LINE CLEAR AVAILED
103	30-Mar-21	HASSAN	110	HV1	PUTTUR_110	08:06	14:37	06:31	LINE CLEAR AVAILED
104	30-Mar-21	HASSAN	110	HV2	PUTTUR_110	08:06	14:37	06:31	LINE CLEAR AVAILED
105	30-Mar-21	HASSAN	110	HV2	BANTWAL_110	09:29	17:26	07:57	LINE CLEAR AVAILED
106	30-Mar-21	HASSAN	110	HV2	ESSUR_110	10:37	18:04	07:27	LINE CLEAR AVAILED
107	30-Mar-21	HASSAN	110	HV2	KUNDAPURA_110	13:39	16:31	02:52	LINE CLEAR AVAILED
108	30-Mar-21	HASSAN	110	HV3	HIRIYADKA_110	10:04	12:45	02:41	LINE CLEAR AVAILED
109	30-Mar-21	HASSAN	110	HV4	KAVOOR_220	12:10	16:10	04:00	LINE CLEAR AVAILED
110	30-Mar-21	HASSAN	110	HV5	KAVOOR_220	09:13	12:00	02:47	LINE CLEAR AVAILED
111	30-Mar-21	HASSAN	110	JOG110-MGHE	JOG_110	16:15	19:11	02:56	MAIN SUPPLY FAILURE
112	30-Mar-21	HASSAN	110	JOG-JLT3	mghejog_gen	15:58	19:10	03:12	NFBC ISSUED
113	30-Mar-21	HASSAN	110	JOG-JLT4	mghejog_gen	15:58	19:26	03:28	NFBC ISSUED
114	30-Mar-21	HASSAN	110	JOG-JST1	mghejog_gen	15:58	19:09	03:11	NFBC ISSUED
115	30-Mar-21	HASSAN	110	JOG-JST2	mghejog_gen	15:58	19:10	03:12	NFBC ISSUED
116	30-Mar-21	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	08:45	08:55	00:10	LINE FAULT
117	30-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	08:01	19:04	11:03	LINE CLEAR AVAILED
118	30-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	08:01	19:04	11:03	LINE CLEAR AVAILED
119	30-Mar-21	HASSAN	110	SAGARA-IDLE	SAGARA_110	10:18	12:13	01:55	LINE CLEAR AVAILED
120	30-Mar-21	HASSAN	110	SAGARA-JST1	SAGARA_110	16:06	19:03	02:57	LINE CLEAR AVAILED
121	30-Mar-21	HASSAN	110	SAGARA-JST2	SAGARA_110	16:06	19:03	02:57	LINE CLEAR AVAILED
122	30-Mar-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	09:50	10:20	00:30	HAND TRIPPED
123	30-Mar-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	09:51	10:30	00:39	HAND TRIPPED
124	30-Mar-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	17:24	19:08	01:44	LINE FAULT
125	30-Mar-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:25	13:44	00:19	HAND TRIPPED
126	30-Mar-21	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	13:45 (28.03.2021)			LINE OPEN:LINE CLEAR AVAILED
127	30-Mar-21	HASSAN	220	KADUR-DABUSET	KADUR_220	08:58	19:00	10:02	LINE FAULT
128	30-Mar-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	17:23(29.3.2021)	19:09(30.3.2021)	25:46hrs	LINE CHARGED
129	30-Mar-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:01	14:08	02:07	LINE CLEAR AVAILED
130	30-Mar-21	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	12:01	14:08	02:07	NFBC ISSUED
131	30-Mar-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	09:56	11:48	01:52	LINE CLEAR AVAILED
132	30-Mar-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	09:56	11:48	01:52	LINE CLEAR AVAILED
133	30-Mar-21	MYSURU	66	BOGADHI-HOOTAGALLI	NO STATION EFFECTED	10:06 (30/03/2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
134	30-Mar-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	18:01	18:06	0:04	LINE FAULT
135	30-Mar-21	MYSURU	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	13:34	14:25	0:51	LINE FAULT
136	30-Mar-21	MYSURU	66	HOOTAGALLI-ELWALA	NO STATION EFFECTED	9:08	17:18	8:10	LINE CLEAR AVAILED
137	30-Mar-21	MYSURU	66	HV1	ATTIGULIPURA_66	11:30	11:48	0:18	HAND TRIPPED
138	30-Mar-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
139	30-Mar-21	MYSURU	66	HV2	K_HONNALGERE_66	6:55	7:10	0:15	MAIN SUPPLY FAILURE
140	30-Mar-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	13:19	13:25	0:05	LINE FAULT
141	30-Mar-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	13:35	17:43	4:07	LINE FAULT
142	30-Mar-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATION EFFECTED	15:18	17:43	2:24	LINE CLEAR AVAILED
143	30-Mar-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	6:27	6:36	0:08	LINE FAULT
144	30-Mar-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
145	30-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
146	30-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADFRALLI_66	10:55	10:59	0:03	LINE FAULT
147	30-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADFRALLI_66	12:43	12:49	0:05	LINE FAULT
148	30-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADFRALLI_66	13:48	13:53	0:05	LINE FAULT
149	30-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADFRALLI_66	15:21	15:27	0:05	LINE FAULT
150	30-Mar-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:30	18:46	12:16	LINE CLEAR AVAILED
151	30-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	11:43:52 PM(29.03.2021)	12:32:46 AM(30.03.2021)	00:49	LINE CHARGED
152	30-Mar-21	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	15:06	15:21	0:14	LINE FAULT
153	30-Mar-21	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66	11:43:53 PM(29.03.2021)	12:35:50 AM(30.03.2021)	00:49	MAIN SUPPLY FAILURE
154	30-Mar-21	TUMKUR	66	TR-1	BRAHMASANDRA_66	15:59	17:24	1:24	LINE CLEAR AVAILED
155	30-Mar-21	TUMKUR	66	TR-1	KORATAGERE_66	15:48	18:29	2:40	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
156	30-Mar-21	TUMKUR	66	TR-1	LINGADAHALLI_66(TMK)	13:42	14:52	1:09	LINE CLEAR AVAILED
157	30-Mar-21	TUMKUR	66	TR-2	SASALUHALLA_66	10:18:48 AM(29.03.2021)	4:41:28 PM(30.03.2021)	06:22	TRANSFORMER CHARGED
158	30-Mar-21	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	14:08	14:44	0:36	LINE CLEAR AVAILED
159	30-Mar-21	TUMKUR	66	TR-2	LINGADAHALLI_66(TMK)	13:07	13:38	0:31	HAND TRIPPED
160	30-Mar-21	TUMKUR	66	TR-2	SANEKERE_66	12:17	12:28	0:11	LINE CLEAR AVAILED
161	30-Mar-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	14:07	14:18	0:11	TRANSFORMER FAULT
162	30-Mar-21	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	10:09	17:23	7:14	LOAD CURTAILMENT
163	31-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
164	31-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
165	31-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
166	31-Mar-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
167	31-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
168	31-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
169	31-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)	17:54 (31.03.2021)	1344:12HRS	LINE CHARGED
170	31-Mar-21	BAGALKOT	110	RAIBAG-ITNAL2	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)	20:10 (31.03.2021)	1346:28HRS	LINE CHARGED
171	31-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)	15:00 (31.03.2021)	911:50HRS	LINE CHARGED
172	31-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
173	31-Mar-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
174	31-Mar-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
175	31-Mar-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
176	31-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
177	31-Mar-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
178	31-Mar-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)			LINE OPEN:LINE CLEAR AVAILED
179	31-Mar-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)			LINE OPEN:LINE CLEAR AVAILED
180	31-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)			LINE OPEN : LINE FAULT
181	31-Mar-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)	04:16 (31.03.2021)	137:47HRS	LINE CHARGED
182	31-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
183	31-Mar-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
184	31-Mar-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	12:45 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
185	31-Mar-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT
186	31-Mar-21	BAGALKOT	110	ATHANI SUGARS-AINAPUR	STATION NOT AFFECTED AINAPUR_110	04:11	04:28	0:17	LINE FAULT
187	31-Mar-21	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	11:04	13:13	2:09	LINE CLEAR AVAILED
188	31-Mar-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED ANAND NAGAR_110	11:04	13:18	2:14	LINE CLEAR AVAILED
189	31-Mar-21	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED BAILHONGAL_110	16:58	17:16	0:18	TRANSFORMER FAULT
190	31-Mar-21	BAGALKOT	110	GADAG-SAMBAPUR ROAD	STATION NOT AFFECTED SAMBAPUR ROAD_110	12:27	14:39	2:12	LINE CLEAR AVAILED
191	31-Mar-21	BAGALKOT	110	GADAG-DAMBAL	STATION NOT AFFECTED DAMBAL_110	15:30	17:27	1:57	LINE CLEAR AVAILED
192	31-Mar-21	BAGALKOT	110	110/33KV,HV3	GADAG_110	17:15	17:30	0:15	LINE CLEAR AVAILED
193	31-Mar-21	BAGALKOT	110	HALIYAL-ALNAVAR	STATION NOT AFFECTED HALIYAL_110	11:17	19:31	8:14	LINE CLEAR AVAILED
194	31-Mar-21	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED BYADAGI_110	18:34	21:08	2:34	LINE FAULT
195	31-Mar-21	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED BYADAGI_110	22:12 (31.03.2021)			LINE OPEN : LINE FAULT
196	31-Mar-21	BAGALKOT	110	HAVERI220-HANGAL(TILUVALI)	STATION NOT AFFECTED TILUVALI_110	19:23	21:09	1:46	LINE FAULT
197	31-Mar-21	BAGALKOT	220	HAVERI220-GUTTUR1	STATION NOT AFFECTED HAVERI_220	12:07	16:30	4:23	LINE FAULT
198	31-Mar-21	BAGALKOT	220	HAVERI220-GUTTUR2	STATION NOT AFFECTED HAVERI_220	12:33	21:42	9:09	LINE FAULT
199	31-Mar-21	BAGALKOT	110	110/33KV,HV2	HANGAL_110,BOMMANALLI_33,BEL AGALPETE_33	13:02	13:20	0:18	TRANSFORMER FAULT
200	31-Mar-21	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	8:28	17:45	9:17	NFBC ISSUED
201	31-Mar-21	BAGALKOT	400	DHONI-GUTTUR	STATION NOT AFFECTED DHONI_400	15:16 (31.03.2021)			LINE OPEN:LINE CLEAR AVAILED
202	31-Mar-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ZALKI_110	17:32	17:48	0:16	LINE CLEAR AVAILED
203	31-Mar-21	BAGALKOT	110	VADAGAON-BELGAUM	STATION NOT AFFECTED VADAGAON_110	13:05	17:23	4:18	LINE FAULT
204	31-Mar-21	BAGALKOT	110	110/11KV HV1 (HV2)	STATION NOT AFFECTED TIKOTA_110	16:46	16:54	0:08	TRANSFORMER FAULT
205	31-Mar-21	BAGALKOT	110	HUBLI220-ANANDANAGAR	ANANDANAGAR_110	11:03	13:17	2:14	LINE CLEAR AVAILED
206	31-Mar-21	BAGALKOT	110	HUBLI220-KALAGHATAGI(SIRSI)	KALAGHATAGI_110	12:18	12:58	0:40	LINE FAULT
207	31-Mar-21	BAGALKOT	110	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	11:13	13:12	1:59	LINE CLEAR AVAILED
208	31-Mar-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:42	14:20	0:38	LINE FAULT
209	31-Mar-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SANKESHWAR_110	12:27	19:00	6:33	LINE CLEAR AVAILED
210	31-Mar-21	BAGALKOT	110	SAMBAPURROAD-GADAG220	STATION NOT AFFECTED SAMBAPURROAD_110	12:25	14:39	2:14	NFBC ISSUED
211	31-Mar-21	BAGALKOT	110	RAIBAG-CHIKKODI1	RAIBAG_110	17:35	17:45	0:10	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
212	31-Mar-21	BAGALKOT	110	RAIBAG-CHIKKODI2	RAIBAG_110	17:35	17:45	0:10	HAND TRIPPED
213	31-Mar-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:42	14:20	0:38	LINE FAULT
214	31-Mar-21	BAGALKOT	110	KALGHATAGI-HUBLI220	KALAGHATAGI_110	13:02	13:05	0:03	LINE FAULT
215	31-Mar-21	BAGALKOT	110	ITNAL-RAIBAG1 (HIDKAL2)	STATION NOT AFFECTED ITNAL_110	7:40 (22.03.2021)	17:52 (31.03.2021)	250:12HRS	LINE CHARGED
216	31-Mar-21	BAGALKOT	110	ITNAL-RAIBAG2	STATION NOT AFFECTED ITNAL_110	7:40 (22.03.2021)	17:52 (31.03.2021)	250:12HRS	LINE CHARGED
217	31-Mar-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI	10:25	18:05	07:40	LINE CLEAR AVOIDED
218	31-Mar-21	BENGALURU	66	HV1	SADLI	11:30	14:14	02:44	LINE CLEAR AVOIDED
219	31-Mar-21	BENGALURU	66	HV1	KAMASAMUDRA	03:33	04:00	00:26	TRANSFORMER FAULT
220	31-Mar-21	BENGALURU	66	HV2	HOSOR RAMAPURA	11:17	11:39	00:22	LINE CLEAR AVOIDED
221	31-Mar-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:18	14:31	00:12	LINE FAULT
222	31-Mar-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:36	14:05	00:28	LINE FAULT
223	31-Mar-21	BENGALURU	220	HV2	BIDADI	17:00	17:12	00:12	TRANSFORMER FAULT
224	31-Mar-21	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	17:00	17:14	00:14	LINE CLEAR AVOIDED
225	31-Mar-21	BENGALURU	66	HV2	BIDADI 220	17:00	17:13	00:13	LINE CLEAR AVOIDED
226	31-Mar-21	BENGALURU	66	HV3	BIDADI 220	17:00	17:13	00:13	LINE CLEAR AVOIDED
227	31-Mar-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, INFOSYS(EHT)	10:37	11:15	00:38	MAIN SUPPLY FAILURE
228	31-Mar-21	BENGALURU	220	HV2	EPIP 220	18:16	18:26	00:10	TRANSFORMER FAULT
229	31-Mar-21	BENGALURU	66	HV3	EPIP 220	18:16	18:29	00:13	LINE CLEAR AVOIDED
230	31-Mar-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	18:16	18:28	00:12	LINE CLEAR AVOIDED
231	31-Mar-21	BENGALURU	220	HV1	HOODY 220	17:23	19:15	01:52	TRANSFORMER FAULT
232	31-Mar-21	BENGALURU	220	HV2	HOODY 220	17:23	19:05	01:42	TRANSFORMER FAULT
233	31-Mar-21	BENGALURU	220	HV4	HOODY 220	17:23	19:12	01:49	TRANSFORMER FAULT
234	31-Mar-21	BENGALURU	66	HV1	HOODY 220	17:23	19:18	01:55	LINE CLEAR AVOIDED
235	31-Mar-21	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	17:23	19:25	02:02	LINE CLEAR AVOIDED
236	31-Mar-21	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	17:23	19:30	02:07	LINE CLEAR AVOIDED
237	31-Mar-21	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	17:23	19:55	02:32	LINE CLEAR AVOIDED
238	31-Mar-21	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK	20:46	21:34	00:48	LINE FAULT
239	31-Mar-21	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	13:14	13:19	00:05	LINE CLEAR AVOIDED
240	31-Mar-21	BENGALURU	220	HV2	YARANDANAHALLI 220	06:13	06:26	00:13	TRANSFORMER FAULT
241	31-Mar-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	06:13	07:02	00:49	LINE FAULT
242	31-Mar-21	BENGALURU	220	HV1	YARANDANAHALLI 220	10:37	10:55	00:18	TRANSFORMER FAULT
243	31-Mar-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	19:55	20:20	00:25	LINE FAULT
244	31-Mar-21	BENGALURU	66	HOODY 220 - PRESTIGE SHANTINIKETHAN	PRESTIGE SHANTINIKETHAN	17:23(31/03/2021)			LINE OPEN : LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
245	31-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
246	31-Mar-21	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	12:33	13:34	01:01	LINE FAULT
247	31-Mar-21	GULBARGA	220	LINGASUGUR-MALLAT	LINGASUGUR_220	12:40	12:49	00:09	LINE FAULT
248	31-Mar-21	GULBARGA	220	LINGASUGUR-RTPS1,2	LINGASUGUR_220	12:40	12:51	00:11	LINE FAULT
249	31-Mar-21	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	12:40	12:54	00:14	LINE FAULT
250	31-Mar-21	GULBARGA	220	LINGASUGUR-BAGEWADI1,2	BAGEWADI_220	12:40	12:55	00:15	LINE FAULT
251	31-Mar-21	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDANOOR_220	12:40	12:57	00:17	LINE FAULT
252	31-Mar-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	14:56	15:15	00:19	MAIN SUPPLY FAILURE
253	31-Mar-21	GULBARGA	220	KUSHTAGI-LINGSUGUR	LINGSUGUR_220	12:39	14:35	01:56	LINE FAULT
254	31-Mar-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KU RUGOD_110,SHATHVAHANA_IPP,AG RAWAL_IPP,SUZLON_IPP,KAMALAP UR_IPP,MATRI_110,RBNS FACTORY	01:27	01:54	00:27	LINE FAULT
255	31-Mar-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KU RUGOD_110,SHATHVAHANA_IPP,AG RAWAL_IPP,SUZLON_IPP,KAMALAP UR_IPP,MATRI_110,RBNS FACTORY	07:30	09:46	02:16	LINE CLEAR AVAILED
256	31-Mar-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110	05:51	06:08	00:17	LINE FAULT
257	31-Mar-21	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	10:00(25.03.2021)	10:15(31.3.2021)	144:15 HRS	LINE CHARGED
258	31-Mar-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	11:05(31.03.21)			LINE OPEN:LINE CLEAR AVAILED
259	31-Mar-21	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:08	12:28	00:20	LINE CLEAR AVAILED
260	31-Mar-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	13:40	19:52	06:12	LINE CLEAR AVAILED
261	31-Mar-21	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	12:40	14:05	01:25	MAIN SUPPLY FAILURE
262	31-Mar-21	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	21:15(31.03.2021)			LINE OPEN : LINE FAULT
263	31-Mar-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_100,HANUMANAL_ 110,HIREGONNAGAR_110	03:24	04:10	00:46	MAIN SUPPLY FAILURE
264	31-Mar-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_100,HANUMANAL_ 110,HIREGONNAGAR_110	12:40	14:05	01:25	MAIN SUPPLY FAILURE
265	31-Mar-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWA T_110,VALKAMDINNI_110	22:03	22:15	00:12	LINE FAULT
266	31-Mar-21	GULBARGA	110	SINDHANOOR-SIRAGUPPA	SIRAGUPPA_110	13:41	14:03	00:22	LINE FAULT
267	31-Mar-21	GULBARGA	110	HV3	KOLHAR_110	16:40	16:55	00:15	LINE CLEAR AVAILED
268	31-Mar-21	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	15:20	15:45	00:25	MAIN SUPPLY FAILURE
269	31-Mar-21	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	19:50	21:15	01:25	LINE FAULT
270	31-Mar-21	GULBARGA	66	HV1	GUDEKOTE_66	19:50(31.03.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
271	31-Mar-21	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	19:50	20:10	00:20	MAIN SUPPLY FAILURE
272	31-Mar-21	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	21:20	21:45	00:25	MAIN SUPPLY FAILURE
273	31-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
274	31-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
275	31-Mar-21	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	13:45 (28.03.2021)			LINE OPEN:LINE CLEAR AVAILED
276	31-Mar-21	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	10:41(30.3.2021)			LINE OPEN:LINE CLEAR AVAILED
277	31-Mar-21	HASSAN	220	HV3	KAVOOR_220	10:04	16:23	06:19	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
278	31-Mar-21	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	09:26	09:40	00:14	HAND TRIPPED
279	31-Mar-21	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	13:29	13:43	00:14	LINE FAULT
280	31-Mar-21	HASSAN	220	SHARAVATHY4	MRSMSG_220	10:08	12:38	02:30	LINE CLEAR AVAILED
281	31-Mar-21	HASSAN	220	SHRVTY-SHIMOGA4	sharavathy_gen	10:08	12:38	02:30	NFBC ISSUED
282	31-Mar-21	HASSAN	110	HV2	ANAVATTI_110	20:56	20:58	00:02	TRANSFORMER FAULT
283	31-Mar-21	HASSAN	110	HV1	HIRIYADKA_110	10:05	12:43	02:38	LINE CLEAR AVAILED
284	31-Mar-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	11:10	12:05	00:55	LINE CLEAR AVAILED
285	31-Mar-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	15:30	15:35	00:05	HAND TRIPPED
286	31-Mar-21	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLY_110	11:10	12:05	00:55	LINE CLEAR AVAILED
287	31-Mar-21	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLY_110	15:30	15:35	00:05	HAND TRIPPED
288	31-Mar-21	HASSAN	110	HV1	KONAJE_110	09:17	09:20	00:03	HAND TRIPPED
289	31-Mar-21	HASSAN	110	HV1	KONAJE_110	16:53	16:56	00:03	HAND TRIPPED
290	31-Mar-21	HASSAN	110	HV2	KONAJE_110	09:17	09:20	00:03	HAND TRIPPED
291	31-Mar-21	HASSAN	110	HV2	KONAJE_110	16:53	16:56	00:03	HAND TRIPPED
292	31-Mar-21	HASSAN	110	HV3	KONAJE_110	09:17	09:20	00:03	HAND TRIPPED
293	31-Mar-21	HASSAN	110	HV3	KONAJE_110	16:53	16:56	00:03	HAND TRIPPED
294	31-Mar-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	08:28	18:40	10:12	LINE CLEAR AVAILED
295	31-Mar-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	08:28	18:40	10:12	LINE CLEAR AVAILED
296	31-Mar-21	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	06:28	06:38	00:10	MAIN SUPPLY FAILURE
297	31-Mar-21	HASSAN	66	HNPR2MYSOR2	HNPR2	06:28	06:37	00:09	LINE FAULT
298	31-Mar-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	08:51	18:45	09:54	LINE CLEAR AVAILED
299	31-Mar-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	08:51	18:45	09:54	LINE CLEAR AVAILED
300	31-Mar-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:20	12:28	00:08	LINE FAULT
301	31-Mar-21	MYSURU	66	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	18:45	19:50	1:05	LINE FAULT
302	31-Mar-21	MYSURU	66	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	22:25	22:30	0:05	LINE FAULT
303	31-Mar-21	MYSURU	66	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	23:25	23:27	0:02	LINE FAULT
304	31-Mar-21	MYSURU	66	HV2	DKMAIDANA_66	7:17	12:21	5:04	TRANSFORMER FAULT
305	31-Mar-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	10:53	10:59	0:06	LINE FAULT
306	31-Mar-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	12:34	12:39	0:04	LINE FAULT
307	31-Mar-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	14:02	14:35	0:33	LINE FAULT
308	31-Mar-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:47	19:04	12:17	LINE CLEAR AVAILED
309	31-Mar-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	15:42	16:24	0:41	HAND TRIPPED
310	31-Mar-21	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATION EFFECTED	16:45	17:20	0:35	HAND TRIPPED
311	31-Mar-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	16:00	16:14	0:14	LINE FAULT
312	31-Mar-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	16:00	16:14	0:14	LINE FAULT
313	31-Mar-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	21:08	21:29	0:21	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
314	31-Mar-21	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATION EFFECTED	10:28	12:05	1:36	LINE CLEAR AVAILED
315	31-Mar-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:01	6:06	0:05	LINE FAULT
316	31-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:12	11:19	0:06	LINE FAULT
317	31-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	13:08	13:13	0:04	LINE FAULT
318	31-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	12:10	12:40	0:30	LINE CLEAR AVAILED
319	31-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	14:40	17:58	3:18	LINE CLEAR AVAILED
320	31-Mar-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	18:37	19:04	0:27	LINE FAULT
321	31-Mar-21	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATION EFFECTED	9:06	18:10	9:04	LINE CLEAR AVAILED
322	31-Mar-21	MYSURU	66	BOGADHI-HOOTAGALLI	NO STATION EFFECTED	10:06 (30/03/2021)	12:58 (31/03/2021)	26:52 HRS	LINE CHARGED
323	31-Mar-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
324	31-Mar-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
325	31-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
326	31-Mar-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	17:28	23:23	5:55	LINE FAULT
327	31-Mar-21	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	17:28	23:23	5:54	LINE FAULT
328	31-Mar-21	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	10:08	16:36	6:28	LOAD CURTAILMENT
329	31-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI (HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	1:51	2:06	0:15	LINE FAULT
330	31-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI (HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	2:27	2:34	0:07	HAND TRIPPED
331	31-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI (HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	2:37	8:30	5:52	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
332	31-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI (HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	8:30	10:03	1:33	LINE CLEAR AVAILED
333	31-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	15:28	17:00	1:31	LINE FAULT
334	31-Mar-21	TUMKUR	66	TR-2	BUKKAPATNA_66	15:41	16:29	0:48	LINE CLEAR AVAILED
335	31-Mar-21	TUMKUR	66	TR-1	DEVARAHALLI_66	19:25	19:28	0:03	TRANSFORMER FAULT
336	31-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:11	11:17	0:05	LINE FAULT
337	31-Mar-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGU NDA_66	1:51	1:57	0:05	LINE FAULT
338	31-Mar-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	8:03	8:05	0:02	TRANSFORMER FAULT
339	31-Mar-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	17:45	17:47	0:01	TRANSFORMER FAULT
340	31-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:06	12:16	0:10	LINE FAULT
341	1-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
342	1-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
343	1-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
344	1-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
345	1-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
346	1-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
347	1-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
348	1-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
349	1-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
350	1-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
351	1-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
352	1-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
353	1-Apr-21	BAGALKOT	110	RAIBAG-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:13 (14.03.2021)	19:49 (01.04.2021)	451:36hrs	LINE CHARGED
354	1-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	13:49 (19.03.2021)	17:30 (01.04.2021)	315:14hrs	LINE CHARGED
355	1-Apr-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	10:29 (26.03.2021)	18:26 (01.04.2021)	151:57hrs	LINE CHARGED
356	1-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
357	1-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
358	1-Apr-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	12:45 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
359	1-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
360	1-Apr-21	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED BYADAGI_110	22:12 (31.03.2021)	12:01 (01.04.2021)	13:49hrs	LINE CHARGED
361	1-Apr-21	BAGALKOT	400	DHONI-GUTTUR	STATION NOT AFFECTED DHONI_400	15:16 (31.03.2021)	13:37 (01.04.2021)	22:21hrs	LINE CHARGED
362	1-Apr-21	BAGALKOT	110	KUDACHI-AINAPUR	AINAPUR_110	10:40	15:55	5:15	LINE CLEAR AVAILED
363	1-Apr-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	09:53	17:24	7:31	LINE CLEAR AVAILED
364	1-Apr-21	BAGALKOT	110	AINAPUR-LIS	AINAPUR_110	09:56	16:29	6:33	LINE CLEAR AVAILED
365	1-Apr-21	BAGALKOT	110	AMBEWADI-NK1 & NK2	HALIYAL_110 & KAVALWAD_110	8:32	15:37	7:05	LINE CLEAR AVAILED
366	1-Apr-21	BAGALKOT	110	110/11KV HV3	BAILHONGAL_110	20:02(01.04.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
367	1-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	7:25	9:23	1:58	LINE CLEAR AVAILED
368	1-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	11:15	18:04	6:49	LOAD CURTAILMENT
369	1-Apr-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	15:02	15:39	0:37	LINE FAULT
370	1-Apr-21	BAGALKOT	220	BIJAPUR-INDI1	STATION NOT AFFECTED BIJAPUR_220	11:02	13:58	2:56	LINE CLEAR AVAILED
371	1-Apr-21	BAGALKOT	110	DAMBAL-SUZLON2	DAMBAL_110	19:05	19:31	0:26	LINE FAULT
372	1-Apr-21	BAGALKOT	110	DAMBAL-SUZLON1	DAMBAL_110	19:05	19:31	0:26	LINE FAULT
373	1-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	21:42 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
374	1-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED GAJENDRAGAD_110	21:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
375	1-Apr-21	BAGALKOT	110	GOPPANAKOPPA-NAVALGUND	STATION NOT AFFECTED GOPPANAKOPPA_110	6:49	12:28	5:39	LINE FAULT
376	1-Apr-21	BAGALKOT	110	110/33KV,KV4	HIDIKAL_110,ALAGAWADI_33	16:54	18:00	1:06	LINE CLEAR AVAILED
377	1-Apr-21	BAGALKOT	110	HIREHAL-RON	RON_110	21:33	21:46	0:13	LINE FAULT
378	1-Apr-21	BAGALKOT	110	110/11KV,HV2	JAMAKHANDI_110	10:31	12:07	1:36	LINE CLEAR AVAILED
379	1-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	20:29 (25.03.2021)	8:30 (01.04.2021)	156:01hrs	LINE CHARGED
380	1-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
381	1-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	8:15 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
382	1-Apr-21	BAGALKOT	110	KUDCHI220-AINAPUR(KUDCHI)	STATION NOT AFFECTED KUDCHI_220	10:29	15:21	4:52	LINE CLEAR AVAILED
383	1-Apr-21	BAGALKOT	110	KUDCHI220-AINAPUR(KUDCHI)	STATION NOT AFFECTED KUDCHI_220	15:29	15:54	0:25	LINE CLEAR AVAILED
384	1-Apr-21	BAGALKOT	110	110/33KV,HV3	LAXMESHVAR_33,SSM_33,MMCL_33	21:08	21:39	0:31	TRANSFORMER FAULT
385	1-Apr-21	BAGALKOT	110	VADAGOAN-MACHE	STATION NOT AFFECTED MACHE_110	12:05	12:20	0:15	HAND TRIPPED
386	1-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	12:25 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
387	1-Apr-21	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	18:08	18:34	0:26	LINE FAULT
388	1-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	8:25	16:27	6:43	NFBC ISSUED
389	1-Apr-21	BAGALKOT	110	MANALI SUGARS-MALGHAN	MALGHAN(S)_110	4:16	4:56	0:40	LINE FAULT
390	1-Apr-21	BAGALKOT	110	MATRIX-MUKARTIHAL	MUKARTIHAL_110	16:47	17:38	0:51	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
391	1-Apr-21	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	STATION NOT AFFECTED MK HUBLI 220	6:08	7:32	1:24	LINE CLEAR AVAILED
392	1-Apr-21	BAGALKOT	110	MK HUBLI220-BAILHONHAL	BAILHONHAL_110	6:25	7:36	1:11	LINE CLEAR AVAILED
393	1-Apr-21	BAGALKOT	110	220/110,LV2	STATION NOT AFFECTED MK HUBLI 220	6:10	7:27	1:17	LINE CLEAR AVAILED
394	1-Apr-21	BAGALKOT	110	110/33KV,HV2(HV3)	MUNDARGI_110,SINGATALUR_33	23:10 (31.03.2021)	6:45 (01.04.2021)	7:35hrs	TRANSFORMER CHARGED
395	1-Apr-21	BAGALKOT	220	VAJRAMATTI220-KUDAGI 1	STATION NOT AFFECTED VAJRAMATTI 220	20:49 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
396	1-Apr-21	BAGALKOT	220	VAJRAMATTI220-KUDAGI 2	STATION NOT AFFECTED VAJRAMATTI 220	20:49 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
397	1-Apr-21	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33,DHULKHED_33,HALASANGI_33	15:52	15:56	0:04	TRANSFORMER FAULT
398	1-Apr-21	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	10:06	16:58	6:52	LINE CLEAR AVAILED
399	1-Apr-21	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	19:51	19:57	0:06	TRANSFORMER FAULT
400	1-Apr-21	BAGALKOT	110	BELGAUM-VADAGOAN	STATION NOT AFFECTED VADAGOAN_110	12:05	12:21	0:16	MAIN SUPPLY FAILURE
401	1-Apr-21	BAGALKOT	110	110/33KV,HV3	UGARKHUD_110, STATION NOT AFFECTED MANGSULI_33,SHEDBAL_33	8:07	9:37	1:30	LINE CLEAR AVAILED
402	1-Apr-21	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	12:54	19:04	6:10	LINE CLEAR AVAILED
403	1-Apr-21	BAGALKOT	110	RON-GAJENDRAGAD 1	RON_110	21:56	22:18	0:22	LINE FAULT
404	1-Apr-21	BAGALKOT	110	RON-GAJENDRAGAD 2	RON_110	21:56	22:18	0:22	LINE FAULT
405	1-Apr-21	BAGALKOT	110	RON-GMSH	RON_110	21:56	22:11	0:15	LINE FAULT
406	1-Apr-21	BENGALURU	220	HV1	A STATION 220	06:45	07:11	00:26	TRANSFORMER FAULT
407	1-Apr-21	BENGALURU	220	HV2	A STATION 220	06:45	07:11	00:26	TRANSFORMER FAULT
408	1-Apr-21	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	06:45	07:11	00:26	LINE CLEAR AVAILED
409	1-Apr-21	BENGALURU	66	A STATION 66 - A STATION 1	A STATION 66	06:45	07:11	00:26	LINE CLEAR AVAILED
410	1-Apr-21	BENGALURU	66	A STATION 66 - A STATION 2	A STATION 66	06:45	07:11	00:26	LINE CLEAR AVAILED
411	1-Apr-21	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	06:45	07:11	00:26	LINE CLEAR AVAILED
412	1-Apr-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	11:50	12:09	00:19	MAIN SUPPLY FAILURE
413	1-Apr-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	16:32	16:34	00:02	LOAD CHANGE OVER
414	1-Apr-21	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	16:00	16:15	00:15	LOAD CHANGE OVER
415	1-Apr-21	BENGALURU	220	BRINDAVANA 220 - SRS PEENYA 220	BRINDAVANA 220	14:26	15:45	01:19	LINE CLEAR AVAILED
416	1-Apr-21	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	06:31	13:25	06:54	LINE FAULT
417	1-Apr-21	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	13:25	16:32	03:07	LINE CLEAR AVAILED
418	1-Apr-21	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	18:35	19:45	01:10	LINE CLEAR AVAILED
419	1-Apr-21	BENGALURU	220	HV1	HAL 220	06:31	06:45	00:14	TRANSFORMER FAULT
420	1-Apr-21	BENGALURU	220	HV2	HAL 220	06:31	06:48	00:17	TRANSFORMER FAULT
421	1-Apr-21	BENGALURU	66	HAL 220 - HOODY 1	KADUBISANAHALLI, CESSNO PARK	08:39	09:56	01:17	LINE FAULT
422	1-Apr-21	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	06:31	06:50	00:19	LINE CLEAR AVAILED
423	1-Apr-21	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	06:31	06:50	00:19	LINE CLEAR AVAILED
424	1-Apr-21	BENGALURU	66	HAL 220 - HOODY 1	KADUBISANAHALLI, CESSNO PARK (EHT)	06:31	06:50	00:19	LINE CLEAR AVAILED
425	1-Apr-21	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	06:31	06:50	00:19	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
426	1-Apr-21	BENGALURU	66	HV1	HAL 220	06:31	06:50	00:19	LINE CLEAR AVAILED
427	1-Apr-21	BENGALURU	66	HV2	HAL 220	06:31	06:50	00:19	LINE CLEAR AVAILED
428	1-Apr-21	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	20:25	20:40	00:15	LINE FAULT
429	1-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:10	11:22	00:12	LINE CLEAR AVAILED
430	1-Apr-21	BENGALURU	66	HV1	RAJANUKUNTE	09:24	09:30	00:06	LINE CLEAR AVAILED
431	1-Apr-21	BENGALURU	66	HV2	R R NAGAR	14:32	14:45	00:13	TRANSFORMER FAULT
432	1-Apr-21	BENGALURU	66	HV2	REMCO	11:49	12:23	00:34	MAIN SUPPLY FAILURE
433	1-Apr-21	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHABHAVATHI 220	11:50	12:21	00:31	LINE FAULT
434	1-Apr-21	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	11:50	12:21	00:31	LINE CLEAR AVAILED
435	1-Apr-21	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	11:50	12:21	00:31	LINE CLEAR AVAILED
436	1-Apr-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	13:42	14:11	00:29	LOAD CHANGE OVER
437	1-Apr-21	BENGALURU	220	HOODY 220 - MALUR 220	VIKAS TECH PARK 220, SARJAPURA 220	13:56	14:28	00:32	LINE FAULT
438	1-Apr-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:56	14:44	00:48	LINE CLEAR AVAILED
439	1-Apr-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:56	14:44	00:48	LINE CLEAR AVAILED
440	1-Apr-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:56	14:44	00:48	LINE CLEAR AVAILED
441	1-Apr-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:56	14:44	00:48	LINE CLEAR AVAILED
442	1-Apr-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:56	14:44	00:48	LINE CLEAR AVAILED
443	1-Apr-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:56	14:44	00:48	LINE CLEAR AVAILED
444	1-Apr-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:45	16:54	0:09	LINE FAULT
445	1-Apr-21	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	22:25	22:45	0:20	LINE FAULT
446	1-Apr-21	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	23:01	23:12	0:10	LINE FAULT
447	1-Apr-21	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	23:16	23:30	0:13	LINE FAULT
448	1-Apr-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	4:10	4:21	0:10	LINE FAULT
449	1-Apr-21	BENGALURU	66	HV2	VOLVO	13:27	13:45	0:17	LINE CLEAR AVAILED
450	1-Apr-21	BENGALURU	66	HV2	SARJAPURA 220	4:50	5:03	0:12	TRANSFORMER FAULT
451	1-Apr-21	BENGALURU	66	HV1	NANDIGANAHALLI	17:30	17:45	0:15	TRANSFORMER FAULT
452	1-Apr-21	BENGALURU	66	HV1	MITTEMARI 220	2:04	4:48	2:43	TRANSFORMER FAULT
453	1-Apr-21	BENGALURU	66	HV2	MAASTHI	7:17	7:26	0:09	TRANSFORMER FAULT
454	1-Apr-21	BENGALURU	66	HV1	HUKUNDA	18:07	18:11	0:03	TRANSFORMER FAULT
455	1-Apr-21	BENGALURU	66	HV1	HUKUNDA	18:22	18:30	0:07	TRANSFORMER FAULT
456	1-Apr-21	BENGALURU	66	HV1	GODUR	14:30	15:05	0:35	LINE CLEAR AVAILED
457	1-Apr-21	BENGALURU	220	HV2	BEGUR 220	16:30	17:10	0:40	LINE CLEAR AVAILED
458	1-Apr-21	BENGALURU	66	HV1	ANDERSONPET	16:40	17:03	0:23	LINE CLEAR AVAILED
459	1-Apr-21	BENGALURU	66	VIJAYPURA - CHINTAMANI 220	VIJAYAPURA, JANGAMAKOTE	11:55	12:06	0:11	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
460	1-Apr-21	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	10:30	10:40	0:10	LINE FAULT
461	1-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	9:07	9:11	0:04	LINE FAULT
462	1-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:07	9:16	0:09	LINE FAULT
463	1-Apr-21	BENGALURU	66	KOLAR 220 - NARSAPURA 1	NARASAPURA	10:54	12:26	1:32	LINE CLEAR AVAILED
464	1-Apr-21	BENGALURU	66	HV1	KOLAR 220	12:10	12:58	0:48	LINE CLEAR AVAILED
465	1-Apr-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	20:39	20:52	0:13	LINE CLEAR AVAILED
466	1-Apr-21	BENGALURU	66	HAROBELE - KANAKAPURA 220	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJAHALLI	15:00	15:30	0:30	LINE CLEAR AVAILED
467	1-Apr-21	BENGALURU	66	HOODY 220 - PRESTIGE SHANTINIKETHAN	PRESTIGE SHANTINIKETHAN	17:23(31/03/2021)	12:52(01/04/2021)	19:29HRS	LINE CHARGED
468	1-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
469	1-Apr-21	GULBARGA	400	RTPS-BTPS	BTPS_400	12:35	18:58	06:23	MAIN SUPPLY FAILURE
470	1-Apr-21	GULBARGA	220	HV1	RAICHUR_220	08:52	10:24	01:32	TRANSFORMER FAULT
471	1-Apr-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	12:17	12:36	00:19	LINE FAULT
472	1-Apr-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06	12:34	00:28	LINE FAULT
473	1-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	11:05(31.03.2021)			LINE OPEN:LINE CLEAR AVAILED
474	1-Apr-21	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA WEST_110	06:22	06:32	00:10	LOAD CHANGE OVER
475	1-Apr-21	GULBARGA	110	GULBARGA SOUTH-FARTHABAD	GULBARGA SOUTH_110	06:15	06:20	00:05	LOAD CHANGE OVER
476	1-Apr-21	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	21:15(31.03.2021)	8:20(01.04.2021)	11:05HRS	LINE CHARGED
477	1-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	05:51	06:12	00:21	LINE FAULT
478	1-Apr-21	GULBARGA	110	HV2	KAMPLI_110	08:49	08:54	00:05	TRANSFORMER FAULT
479	1-Apr-21	GULBARGA	110	HV2	NIRNA_110	06:42	06:48	00:06	TRANSFORMER FAULT
480	1-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35(1.4.21)			LINE OPEN:LINE CLEAR AVAILED
481	1-Apr-21	GULBARGA	110	HV1	SHAHAPUR_220	09:54	10:04	00:10	TRANSFORMER FAULT
482	1-Apr-21	GULBARGA	110	HV3	KAMPLI_GLB_110	18:07	18:11	00:04	LINE CLEAR AVAILED
483	1-Apr-21	GULBARGA	110	HV2	BELLARYSOUTH_110	09:28	11:35	02:07	LINE CLEAR AVAILED
484	1-Apr-21	GULBARGA	110	HV1	MANVI_110	00:38	00:45	00:07	TRANSFORMER FAULT
485	1-Apr-21	GULBARGA	110	MANVI-MALLAT	MANVI_110	05:54	06:12	00:18	MAIN SUPPLY FAILURE
486	1-Apr-21	GULBARGA	110	MANVI-MALLAT	MANVI_110	11:17	12:25	01:08	MAIN SUPPLY FAILURE
487	1-Apr-21	GULBARGA	110	HV1,HV2	MANVI_110	11:17	16:35	05:18	LINE CLEAR AVAILED
488	1-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	09:35	12:40	03:05	LINE CLEAR AVAILED
489	1-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	09:35	12:45	03:10	LINE CLEAR AVAILED
490	1-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	04:30	04:40	00:10	MAIN SUPPLY FAILURE
491	1-Apr-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWA T_110,VALKAMDINNI_110	09:23	14:40	05:17	LINE CLEAR AVAILED
492	1-Apr-21	GULBARGA	110	HV2	NIRNA_110	06:42	06:48	00:06	TRANSFORMER FAULT
493	1-Apr-21	GULBARGA	110	HV2	KOLHAR_110	18:07	18:11	00:04	LINE CLEAR AVAILED
494	1-Apr-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	11:58	16:50	04:52	NFBC ISSUED
495	1-Apr-21	GULBARGA	66	HV1	GUDEKOTE_66	19:50(31.03.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
496	1-Apr-21	GULBARGA	66	HV1	TAMBRAHALLI_66	06:40	06:45	00:05	TRANSFORMER FAULT
497	1-Apr-21	GULBARGA	66	HV1	TAMBRAHALLI_66	13:00	13:20	00:20	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
498	1-Apr-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:35	14:45	02:10	LINE FAULT
499	1-Apr-21	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	12:35	14:45	02:10	LINE FAULT
500	1-Apr-21	HASSAN	220	GOPALPU-BASTIPURA	GOPALAPURA_220	13:45 (28.03.2021)	17:03(1.04.2021)	99:18hrs	LINE CHARGED
501	1-Apr-21	HASSAN	110	JOG110-MGHE	JOG_110	10:00	22:19	12:19	LINE CLEAR AVAILED
502	1-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE	09:35	17:44	08:09	LINE CLEAR AVAILED
503	1-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE	09:35	17:44	08:09	LINE CLEAR AVAILED
504	1-Apr-21	HASSAN	110	SAGARA-JST1	SAGARA_110	10:02	21:31	11:29	LINE CLEAR AVAILED
505	1-Apr-21	HASSAN	110	SAGARA-JST2	SAGARA_110	10:02	21:54	11:52	LINE CLEAR AVAILED
506	1-Apr-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:17	16:22	00:05	LINE FAULT
507	1-Apr-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	21:52	22:10	00:18	LINE FAULT
508	1-Apr-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	12:00	12:08	00:08	LINE FAULT
509	1-Apr-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:15	13:31	00:16	LINE FAULT
510	1-Apr-21	HASSAN	66	BELUR66-HASSAN	BELUR_66	10:45	11:00	00:15	MAIN SUPPLY FAILURE
511	1-Apr-21	HASSAN	66	HV1	BELUR_66	10:45	11:00	00:15	HAND TRIPPED
512	1-Apr-21	HASSAN	66	HV2	BELUR_66	10:45	11:00	00:15	HAND TRIPPED
513	1-Apr-21	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:45	11:00	00:15	HAND TRIPPED
514	1-Apr-21	HASSAN	66	HV2	MAGGE_66	06:58	07:09	00:11	TRANSFORMER FAULT
515	1-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESHPUA_66	09:19	15:48	06:29	LINE CLEAR AVAILED
516	1-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKALESHPUA_66	09:19	15:48	06:29	LINE CLEAR AVAILED
517	1-Apr-21	HASSAN	66	SHANTI-UDYAPURA	SHANTHIGRAMA_66	15:03	15:30	00:27	LINE CLEAR AVAILED
518	1-Apr-21	HASSAN	66	TAVEREC-HONNALLI	TAVARECHATNAHALLY_66	10:55	11:18	00:23	LINE FAULT
519	1-Apr-21	MYSURU	66	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	08:46	08:49	00:03	LINE FAULT
520	1-Apr-21	MYSURU	66	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	12:09	12:14	00:04	LINE FAULT
521	1-Apr-21	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATION EFFECTED	09:30	17:05	07:35	LINE CLEAR AVAILED
522	1-Apr-21	MYSURU	66	HV1	DODDABYADARAHALLI_66	06:25	06:54	00:28	LINE CLEAR AVAILED
523	1-Apr-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATION EFFECTED	09:40	15:46	06:06	LINE CLEAR AVAILED
524	1-Apr-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	07:16	18:02	10:45	LINE CLEAR AVAILED
525	1-Apr-21	MYSURU	66	KADAKOLA-MANDAKALLI	MANDAKALLI_66	05:57	06:06	00:08	LINE FAULT
526	1-Apr-21	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	06:46	06:52	00:05	LINE FAULT
527	1-Apr-21	MYSURU	66	KUSHALNAGARA-MYSORE1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	07:23	07:32	00:09	LINE FAULT
528	1-Apr-21	MYSURU	66	KUSHALNAGARA-MYSORE2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	07:23	07:32	00:09	LINE FAULT
529	1-Apr-21	MYSURU	66	HOOTAGALLI-VIKRANTH	NO STATION EFFECTED	21:03	21:20	00:17	LINE FAULT
530	1-Apr-21	MYSURU	66	MARTALLI-COWDALLI	MARTAHALLI_66	12:10	17:39	05:29	LINE CLEAR AVAILED
531	1-Apr-21	MYSURU	66	MYSORE-HV2	MYSORESOUTH_66	18:28	18:56	00:28	LINE FAULT
532	1-Apr-21	MYSURU	66	HV2	SATHEGALA_66	19:38	19:55	00:16	TRANSFORMER FAULT
533	1-Apr-21	MYSURU	66	HV2	THALAKADU_66	18:51	18:59	00:08	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
534	1-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:43	11:50	00:07	LINE FAULT
535	1-Apr-21	MYSURU	66	VIJAYANAGARA-HOOTAGALLI	NO STATION EFFECTED	09:50	15:43	05:53	NFBC ISSUED
536	1-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
537	1-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
538	1-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
539	1-Apr-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	15:21	16:53	01:32	LINE FAULT
540	1-Apr-21	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	15:35	15:39	00:03	HAND TRIPPED
541	1-Apr-21	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	15:02	15:33	00:31	LINE CLEAR AVAILED
542	1-Apr-21	TUMKUR	220	ANTHRASANAHALLI 220kv- SHIMOGA	ANTHRASANAHALLI_220	15:51	16:12	00:21	HAND TRIPPED
543	1-Apr-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:30	12:42	00:11	LINE CLEAR AVAILED
544	1-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	01:39	01:48	00:09	LINE FAULT
545	1-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:53	19:39	04:46	LINE CLEAR AVAILED
546	1-Apr-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	15:34	15:41	00:07	HAND TRIPPED
547	1-Apr-21	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	16:20	16:38	00:17	HAND TRIPPED
548	1-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	16:28	16:43	00:15	HAND TRIPPED
549	1-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	16:23	16:28	00:05	LINE FAULT
550	1-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:15	12:19	01:04	LINE CLEAR AVAILED
551	1-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	08:07	08:10	00:02	TRANSFORMER FAULT
552	1-Apr-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:52	13:02:00	00:05	LINE FAULT
553	1-Apr-21	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON2_IPP_66	12:40(1.4.21)			LINE OPEN : LINE FAULT
554	1-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	20:19(1.4.21)			LOAD CURTAILMENT
555	1-Apr-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	16:19	16:40	00:20	MAIN SUPPLY FAILURE
556	1-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:39	12:50	00:11	LINE FAULT
557	1-Apr-21	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	23:39	23:44	00:05	MAIN SUPPLY FAILURE
558	1-Apr-21	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	16:15	16:45	00:30	MAIN SUPPLY FAILURE
559	1-Apr-21	TUMKUR	66	TR-2	SANIKERE_66	12:39	14:51	02:11	TRANSFORMER FAULT
560	1-Apr-21	TUMKUR	66	TR-2	SASALUHALLA_66	00:03	00:05	00:02	TRANSFORMER FAULT
561	1-Apr-21	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	17:17	18:04	0:47	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
562	2-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
563	2-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
564	2-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
565	2-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
566	2-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
567	2-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
568	2-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
569	2-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
570	2-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
571	2-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
572	2-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
573	2-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	18:38 (13.03.2021)			LOAD CURTAILMENT
574	2-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
575	2-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI 110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
576	2-Apr-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI 220	12:45 (30.03.2021)	16:30 (02.04.2021)	75:45hrs	LINE CHARGED
577	2-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT
578	2-Apr-21	BAGALKOT	110	110/11KV HV3	BAILHONGAL_110	20:02 (01.04.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
579	2-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD 110	21:42 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
580	2-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED GAJENDRAGAD 110	21:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
581	2-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA 110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
582	2-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI 110	8:15 (01.04.2021)	14:07 (02.01.2021)	29:52hrs	LINE CHARGED
583	2-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE 110	12:25 (01.04.2021)	6:43 (02.04.2021)	18:18hrs	LINE CHARGED
584	2-Apr-21	BAGALKOT	220	VAJRAMATTI220-KUDAGI 1	STATION NOT AFFECTED VAJRAMATTI 220	20:49 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
585	2-Apr-21	BAGALKOT	220	VAJRAMATTI220-KUDAGI 2	STATION NOT AFFECTED VAJRAMATTI 220	20:49 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
586	2-Apr-21	BAGALKOT	110	ANKOLA-ARGA(L1)	ARGA_110	14:12	15:55	1:43	LINE CLEAR AVAILED
587	2-Apr-21	BAGALKOT	110	ANKOLA-KUMATA(L2)	KUMATA_110	15:55	16:12	0:17	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
588	2-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	8:08	18:04	9:56	LOAD CURTAILMENT
589	2-Apr-21	BAGALKOT	220	CHIKKODI-MUDASHINGI	STATION NOT AFFECTED CHIKKODI_220	7:08	15:18	8:10	LINE CLEAR AVAILED
590	2-Apr-21	BAGALKOT	110	110/33KV,KV2	HANAGAL_110,BOMMANAHALLI_33, AKKIALURU_33,BELAGALPETE_33,LA XMIPURA_33	7:51	7:58	0:07	TRANSFORMER FAULT
591	2-Apr-21	BAGALKOT	110	110/33KV,KV2	HANAGAL_110	21:24	21:26	0:02	TRANSFORMER FAULT
592	2-Apr-21	BAGALKOT	110	110/11KV,KV1	KHANAPUR_110	12:35	12:59	0:24	TRANSFORMER FAULT
593	2-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	15:32 (26.03.2021)	14:12 (02.04.2021)	166:40hrs	LINE CHARGED
594	2-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
595	2-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	8:35 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
596	2-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	7:23 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
597	2-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	7:48	16:30	6:43	NFBC ISSUED
598	2-Apr-21	BAGALKOT	110	110/33KV,HV2(HV3)	MUNDARGI_110,SINGATALUR_33	14:47	19:12	4:25	LINE CLEAR AVAILED
599	2-Apr-21	BAGALKOT	110	MUGALKOD220(ITNAL)-RAIBAG	STATION NOT AFFECTED RAIBAG_110	14:03	19:46	5:43	LINE FAULT
600	2-Apr-21	BAGALKOT	110	ZALKI-CHADCHAN	ZALKI_110	13:57	14:14	0:17	LINE FAULT
601	2-Apr-21	BAGALKOT	110	ZALKI-INDI	ZALKI_110	13:57	14:14	0:17	LINE FAULT
602	2-Apr-21	BAGALKOT	110	110/11KV,HV1	ZALKI_110	13:57	14:17	0:20	TRANSFORMER FAULT
603	2-Apr-21	BAGALKOT	110	110/11KV,HV2	ZALKI_110	13:57	14:14	0:17	TRANSFORMER FAULT
604	2-Apr-21	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33	13:57	14:14	0:17	TRANSFORMER FAULT
605	2-Apr-21	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33,DHULKHED_ 33,HALASANGI_33	13:57	14:18	0:21	TRANSFORMER FAULT
606	2-Apr-21	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33,DHULKHED_ 33,HALASANGI_33	10:40	10:45	0:05	TRANSFORMER FAULT
607	2-Apr-21	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33,DHULKHED_ 33,HALASANGI_33	13:26	13:34	0:08	TRANSFORMER FAULT
608	2-Apr-21	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33,DHULKHED_ 33,HALASANGI_33	15:02	15:06	0:04	TRANSFORMER FAULT
609	2-Apr-21	BAGALKOT	110	BELGAUM-VADAGOAN	STATION NOT AFFECTED VADAGOAN_110	06:46	08:32	1:46	NFBC ISSUED
610	2-Apr-21	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	11:34	18:29	6:55	LINE CLEAR AVAILED
611	2-Apr-21	BAGALKOT	220	SOUDATTI-MLPURA	STATION NOT AFFECTED SOUDATTI_220	7:25 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
612	2-Apr-21	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:40	13:42	00:02	LOAD CHANGE OVER
613	2-Apr-21	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:17	14:19	00:02	LOAD CHANGE OVER
614	2-Apr-21	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	07:15	07:30	00:15	LOAD CHANGE OVER
615	2-Apr-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	10:15	10:20	00:05	LOAD CHANGE OVER
616	2-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	07:13	07:20	00:07	LOAD CHANGE OVER
617	2-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	10:31	10:35	00:04	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
618	2-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG 4	NO STATION AFFECTED	07:12	10:02	02:50	LINE FAULT
619	2-Apr-21	BENGALURU	66	TK HALLI 220 - SIMSHA 1	TK HALLI 220	09:39	09:48	00:09	LINE FAULT
620	2-Apr-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	7:06	7:16	0:09	LINE FAULT
621	2-Apr-21	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	6:07	6:20	0:13	LINE FAULT
622	2-Apr-21	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	6:13	6:21	0:07	LINE FAULT
623	2-Apr-21	BENGALURU	66	HV1	PATH PALYA	7:18	7:25	0:07	TRANSFORMER FAULT
624	2-Apr-21	BENGALURU	66	HV1	PATH PALYA	8:25	8:30	0:05	TRANSFORMER FAULT
625	2-Apr-21	BENGALURU	66	HV2	MAGADI 66	12:42	12:46	0:03	LINE CLEAR AVOIDED
626	2-Apr-21	BENGALURU	66	HV1	HUKUNDA	10:12	10:18	0:06	TRANSFORMER FAULT
627	2-Apr-21	BENGALURU	66	HV1	HUKUNDA	13:45	13:49	0:04	TRANSFORMER FAULT
628	2-Apr-21	BENGALURU	66	HV2	DODDABELAVANGALA	9:38	9:48	0:09	TRANSFORMER FAULT
629	2-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:15	16:20	0:05	LINE FAULT
630	2-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:15	22:22	0:07	LINE FAULT
631	2-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	22:15	22:20	0:05	LINE FAULT
632	2-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:22	16:40	0:18	LINE CLEAR AVOIDED
633	2-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	23:05	23:12	0:07	LINE FAULT
634	2-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	23:05	23:13	0:08	LINE FAULT
635	2-Apr-21	BENGALURU	66	HV1	DOMMASANDRA	16:05	16:20	0:14	LINE CLEAR AVOIDED
636	2-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
637	2-Apr-21	GULBARGA	220	LINGAPUR-GUDAHALLI1	GUDAHALLI_220	14:12	17:12	03:00	LINE FAULT
638	2-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35:00 AM(01.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
639	2-Apr-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110	04:14	04:25	00:11	LINE FAULT
640	2-Apr-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	11:20	11:45	00:25	MAIN SUPPLY FAILURE
641	2-Apr-21	GULBARGA	110	HV2	BISIHALLI_110	12:50	13:10	00:20	TRANSFORMER FAULT
642	2-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	11:05(31.03.2021)	16:55(2.4.2021)	53:50 HRS	LINE CHARGED
643	2-Apr-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	01:38	07:53	06:15	LINE FAULT
644	2-Apr-21	GULBARGA	66	HV1	GUDEKOTE_66	19:50(31.03.2021)	19:00(2.04.2021)	47:10 HRS	TRANSFORMER CHARGED
645	2-Apr-21	GULBARGA	66	HV2	GUDEKOTE_66	15:00	19:05	04:05	LINE CLEAR AVOIDED
646	2-Apr-21	GULBARGA	66	HV1	TAMBRAHALLI_66	10:10	10:40	00:30	TRANSFORMER FAULT
647	2-Apr-21	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	09:40	12:06	02:26	MAIN SUPPLY FAILURE
648	2-Apr-21	GULBARGA	66	HV1	SOVENAHALLI_66	11:00	14:10	03:10	LINE CLEAR AVOIDED
649	2-Apr-21	GULBARGA	66	HV2	SOVENAHALLI_66	11:00	11:20	00:20	LINE CLEAR AVOIDED
650	2-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	08:42	12:41	03:59	LINE CLEAR AVOIDED
651	2-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	13:49	14:53	01:04	LINE CLEAR AVOIDED
652	2-Apr-21	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	00:30	07:46	07:16	LINE FAULT
653	2-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	08:42	12:41	03:59	NFBC ISSUED
654	2-Apr-21	HASSAN	220	VARAHIKEMAR1	varahi_gen	13:49	14:53	01:04	NFBC ISSUED
655	2-Apr-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	00:30	07:54	07:24	LINE FAULT
656	2-Apr-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	00:30	00:39	00:09	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
657	2-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:01	14:18	04:17	LINE CLEAR AVAILED
658	2-Apr-21	HASSAN	110	SAGARA-TAL	SAGARA_110	10:22	11:55	01:33	LINE CLEAR AVAILED
659	2-Apr-21	HASSAN	110	TALAGU-SAGAR	TALAGUPPA_400	10:22	11:56	01:34	LINE CLEAR AVAILED
660	2-Apr-21	HASSAN	66	MRSSH-HOLUR	MRMSG_220	12:29	12:33	00:04	LINE FAULT
661	2-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESHPUA_66	08:47	18:42	09:55	LINE CLEAR AVAILED
662	2-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKALESHPUA_66	08:47	18:42	09:55	LINE CLEAR AVAILED
663	2-Apr-21	HASSAN	66	SOMNHL-GDNEHALI	SOMANAHALLI_66	17:24	19:05	01:41	LINE CLEAR AVAILED
664	2-Apr-21	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLI_66	17:05	19:02	01:57	LINE CLEAR AVAILED
665	2-Apr-21	HASSAN	66	HV2	UDAYAPURA_66	08:55	09:01	00:06	TRANSFORMER FAULT
666	2-Apr-21	MYSURU	66	BILIKERE-GVGUDI	GVGUDI_66	6:09	6:16	0:06	LINE FAULT
667	2-Apr-21	MYSURU	66	HV2	BILIKERE_66	21:46	21:52	0:06	TRANSFORMER FAULT
668	2-Apr-21	MYSURU	66	HV1	DEVANOORNGUDU_66	15:02	15:06	0:03	TRANSFORMER FAULT
669	2-Apr-21	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATION EFFECTED	11:23	18:13	6:50	LINE CLEAR AVAILED
670	2-Apr-21	MYSURU	66	HV1	DODDABYADARAHALLI_66	9:21	11:50	2:28	LINE CLEAR AVAILED
671	2-Apr-21	MYSURU	66	HOOTAGALLI-FTS 1	NO STATION EFFECTED	11:25	17:54	6:29	LINE CLEAR AVAILED
672	2-Apr-21	MYSURU	66	HOOTAGALLI-RK NAGARA	NO STATION EFFECTED	18:57	19:06	0:09	HAND TRIPPED
673	2-Apr-21	MYSURU	66	HOOTAGALLI-RBI	NO STATION EFFECTED	9:04	17:34	8:30	LINE CLEAR AVAILED
674	2-Apr-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:44	18:08	11:24	LINE CLEAR AVAILED
675	2-Apr-21	MYSURU	66	HV1	KHBCOLONY_66	16:22	16:47	0:25	LINE CLEAR AVAILED
676	2-Apr-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	6:10	6:15	0:05	LINE FAULT
677	2-Apr-21	MYSURU	66	HV1	NAGAMANGALA_66	11:29	11:35	0:06	TRANSFORMER FAULT
678	2-Apr-21	MYSURU	66	HV1	NAGAMANGALA_66	11:50	11:54	0:04	TRANSFORMER FAULT
679	2-Apr-21	MYSURU	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:34	17:49	0:14	LINE FAULT
680	2-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:23	11:29	0:05	LINE FAULT
681	2-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
682	2-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
683	2-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
684	2-Apr-21	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	17:20	17:30	0:10	MAIN SUPPLY FAILURE
685	2-Apr-21	TUMKUR	66	TR-1	THIMMASANDRA_66	14:13	14:40	0:26	LINE CLEAR AVAILED
686	2-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	9:15	9:21	0:06	TRANSFORMER FAULT
687	2-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:56	19:10	0:14	LINE FAULT
688	3-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
689	3-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
690	3-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
691	3-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
692	3-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
693	3-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
694	3-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
695	3-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
696	3-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
697	3-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
698	3-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
699	3-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
700	3-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
701	3-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
702	3-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT
703	3-Apr-21	BAGALKOT	110	110/11KV HV3	BAILHONGAL_110	20:02 (01.04.2021)	19:17 (3.4.2021)	47:15HRS	TRANSFORMER CHARGED
704	3-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	21:42 (01.04.2021)	18:00 (3.4.2021)	20:18HRS	LINE CHARGED
705	3-Apr-21	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED GAJENDRAGAD_110	21:35 (01.04.2021)	18:00 (3.4.2021)	20:25HRS	LINE CHARGED
706	3-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
707	3-Apr-21	BAGALKOT	220	VAJRAMATTI220-KUDAGI 1	STATION NOT AFFECTED VAJRAMATTI_220	20:49 (01.04.2021)	13:34 (03.04.2021)	40:45HRS	LINE CHARGED
708	3-Apr-21	BAGALKOT	220	VAJRAMATTI220-KUDAGI 2	STATION NOT AFFECTED VAJRAMATTI_220	20:49 (01.04.2021)	13:34 (03.04.2021)	40:45HRS	LINE CHARGED
709	3-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
710	3-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	8:35 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
711	3-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	7:23 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
712	3-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	7:25 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
713	3-Apr-21	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	07:44	17:41	9:57	LINE CLEAR AVAILED
714	3-Apr-21	BAGALKOT	220	BIJAPUR-INDI 2	BIJAPUR_220	13:33	15:18	1:45	LINE CLEAR AVAILED
715	3-Apr-21	BAGALKOT	220	BIJAPUR-INDI 1	BIJAPUR_220	15:21	16:07	0:46	LINE CLEAR AVAILED
716	3-Apr-21	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	6:00	13:06	7:06	LINE FAULT
717	3-Apr-21	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	19:44	19:57	0:13	LINE FAULT
718	3-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	7:32			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
719	3-Apr-21	BAGALKOT	110	HIDIKAL-RAIBAG	HIDIKAL (STATION NOT AFFECTED)	9:13(3.4.2021)			LINE OPEN:LINE CLEAR AVAILED
720	3-Apr-21	BAGALKOT	220	HAVERI-GUTTUR 1&2	HAVERI_220	17:36	20:35	2:59	LINE CLEAR AVAILED
721	3-Apr-21	BAGALKOT	110	KIRUVATTI-AMBEWADI(SIRSI)	KIRUVATTI	14:04	15:28	1:24	LINE CLEAR AVAILED
722	3-Apr-21	BAGALKOT	110	LAXMESHWAR-SHIRAHATTI	SHIRAHATTI_110	3:39	10:48	7:09	LINE FAULT
723	3-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	13:30	16:27	2:57	TRANSFORMER FAULT
724	3-Apr-21	BAGALKOT	110	ZALKI- CHADCHAN	CHADCHAN_110	16:20	16:27	0:07	LINE FAULT
725	3-Apr-21	BAGALKOT	110	INDI- ZALKI	ZALKI_110	16:20	16:27	0:07	LINE FAULT
726	3-Apr-21	BAGALKOT	110	110/11KV, HV1	ZALKI_110	16:20	16:30	0:10	TRANSFORMER FAULT
727	3-Apr-21	BAGALKOT	110	110/11KV, HV2	ZALKI_110	16:20	16:27	0:07	TRANSFORMER FAULT
728	3-Apr-21	BAGALKOT	110	110/33KV, HV3	ZALKI_110	16:20	16:27	0:07	TRANSFORMER FAULT
729	3-Apr-21	BAGALKOT	110	110/11KV, HV1	SIRSI_110	15:19	15:34	0:15	LINE CLEAR AVAILED
730	3-Apr-21	BAGALKOT	110	110/11KV, HV1	SIRSI_110	16:01	16:22	0:21	LINE CLEAR AVAILED
731	3-Apr-21	BAGALKOT	110	SHIRHATTI- LAXMESHWAR	STATION NOT AFFECTED SHIRHATTI_110	03:38	10:51	7:13	LINE FAULT
732	3-Apr-21	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	11:33	19:43	8:10	LINE CLEAR AVAILED
733	3-Apr-21	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	14:54	17:42	2:48	LINE FAULT
734	3-Apr-21	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	15:54	17:42	1:48	LINE FAULT
735	3-Apr-21	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	7:44	17:41	9:57	LINE CLEAR AVAILED
736	3-Apr-21	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	19:25	19:40	00:15	LINE FAULT
737	3-Apr-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	05:00	05:06	00:05	LINE FAULT
738	3-Apr-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:00	23:43	00:01	LINE CLEAR AVAILED
739	3-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	17:59	18:03	00:03	LINE FAULT
740	3-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	09:05	09:10	00:05	LINE FAULT
741	3-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	17:59	19:20	01:20	LINE FAULT
742	3-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	09:05	09:10	00:05	LINE FAULT
743	3-Apr-21	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	22:35	22:40	00:05	LINE CLEAR AVAILED
744	3-Apr-21	BENGALURU	66	HV1	KEMBODI	21:20	21:52	00:32	LINE CLEAR AVAILED
745	3-Apr-21	BENGALURU	66	HV1	GODUR	14:30	17:51	03:21	MAIN SUPPLY FAILURE
746	3-Apr-21	BENGALURU	66	HV2	ATTIBELE	13:16	15:20	02:04	LINE CLEAR AVAILED
747	3-Apr-21	BENGALURU	66	HV1	HUKUNDA	13:51	13:59	00:07	TRANSFORMER FAULT
748	3-Apr-21	BENGALURU	66	HV1	HUKUNDA	20:06	20:11	00:04	TRANSFORMER FAULT
749	3-Apr-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	16:30	16:47	00:17	MAIN SUPPLY FAILURE
750	3-Apr-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	18:11	18:17	00:06	LOAD CHANGE OVER
751	3-Apr-21	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	15:15	15:31	00:16	LINE CLEAR AVAILED
752	3-Apr-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	17:33	17:49	00:16	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
753	3-Apr-21	BENGALURU	66	HV1	HANUMANTHNAGARA	13:40	14:35	00:55	LINE CLEAR AVAILED
754	3-Apr-21	BENGALURU	66	HV2	HANUMANTHNAGARA	13:40	14:35	00:55	LINE CLEAR AVAILED
755	3-Apr-21	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	12:10	13:08	00:58	LINE CLEAR AVAILED
756	3-Apr-21	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220, BWSSB 220	16:30	18:08	01:38	MAIN SUPPLY FAILURE
757	3-Apr-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	16:30	18:08	01:38	LINE CLEAR AVAILED
758	3-Apr-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	16:30	18:08	01:38	LINE CLEAR AVAILED
759	3-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNIGANAHALLI	16:30	18:08	01:38	LINE CLEAR AVAILED
760	3-Apr-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:30	18:08	01:38	LINE CLEAR AVAILED
761	3-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE	16:30	18:08	01:38	LINE CLEAR AVAILED
762	3-Apr-21	BENGALURU	66	HV1	KADUBISANAHALLI	11:00	17:00	06:00	LINE CLEAR AVAILED
763	3-Apr-21	BENGALURU	66	HV2	KADUBISANAHALLI	10:13	10:16	00:03	LOAD CHANGE OVER
764	3-Apr-21	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	14:57	15:11	00:14	TRANSFORMER FAULT
765	3-Apr-21	BENGALURU	66	HV1	REMCO	17:05	17:10	00:05	LOAD CHANGE OVER
766	3-Apr-21	BENGALURU	66	HV1	REMCO	18:13	18:16	00:03	LOAD CHANGE OVER
767	3-Apr-21	BENGALURU	220	SOMANAHALLI 220 -KANAKAPURA 220	KANAKAPURA 220, BWSSB 220	16:30	18:03	01:33	LINE CLEAR AVAILED
768	3-Apr-21	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI (EHT)	TATAGUNI (EHT), VRISHBHAVATHI 220	16:30	16:59	00:29	LINE CLEAR AVAILED
769	3-Apr-21	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	16:30	16:59	00:29	LINE CLEAR AVAILED
770	3-Apr-21	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	16:30	17:05	00:35	LINE CLEAR AVAILED
771	3-Apr-21	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	16:30	17:05	00:35	LINE CLEAR AVAILED
772	3-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	06:17	06:24	00:07	LINE FAULT
773	3-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	06:17	06:24	00:07	LINE FAULT
774	3-Apr-21	BENGALURU	66	HV1	VIJAYANAGARA	16:31	16:38	00:07	LOAD CHANGE OVER
775	3-Apr-21	BENGALURU	66	HV1	VIJAYANAGARA	18:17	18:29	00:12	LOAD CHANGE OVER
776	3-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
777	3-Apr-21	GULBARGA	220	LINGAPUR-MUNIRABAD	LINGAPUR_220	01:06	11:49	10:43	LINE CLEAR AVAILED
778	3-Apr-21	GULBARGA	220	HV2	MUNIRABAD_220	00:05	11:47	11:42	LINE CLEAR AVAILED
779	3-Apr-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	10:55	11:25	00:30	LINE CLEAR AVAILED
780	3-Apr-21	GULBARGA	220	LINGAPUR-MUNIRABAD	MUNIRABAD_220	00:58	11:49	10:51	LINE CLEAR AVAILED
781	3-Apr-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,K EREHALLI_110,MALLAPUR_110	08:15	08:30	00:15	LINE CLEAR AVAILED
782	3-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35:00 AM(01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
783	3-Apr-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	08:26	08:42	00:16	MAIN SUPPLY FAILURE
784	3-Apr-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	13:42	14:00	00:18	MAIN SUPPLY FAILURE
785	3-Apr-21	GULBARGA	110	HV2	SINDHANOOR_110	13:00	13:10	00:10	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
786	3-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	04:30	04:40	00:10	LINE FAULT
787	3-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110,ALKOD_110,BYAGAWA T_110,VALKAMDINNI_110	05:33	05:48	00:15	LINE FAULT
788	3-Apr-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	00:22	00:33	00:11	LINE FAULT
789	3-Apr-21	GULBARGA	110	KAPNOOR-ALAND	KADAGANCHI_110,ALAND_110	05:34	05:46	00:12	LINE FAULT
790	3-Apr-21	GULBARGA	110	HV1	MALLAPUR_110	10:05	18:41	08:36	LINE CLEAR AVAILED
791	3-Apr-21	GULBARGA	110	MALLAPUR-KAMPLI	KAMPLI_GLB_110	10:00	13:23	03:23	LINE CLEAR AVAILED
792	3-Apr-21	GULBARGA	110	HV1	MANTHAL_110	15:50	17:30	01:40	LINE CLEAR AVAILED
793	3-Apr-21	GULBARGA	110	HV2	MANTHAL_110	16:50	19:00	02:10	LINE CLEAR AVAILED
794	3-Apr-21	GULBARGA	110	HV3	MANTHAL_110	16:40	17:10	00:30	LINE CLEAR AVAILED
795	3-Apr-21	GULBARGA	110	HV1	GURMITKAL_110	16:40	17:05	00:25	TRANSFORMER FAULT
796	3-Apr-21	GULBARGA	66	HV1	SOVENAHALLI_66	11:10	14:30	03:20	LINE CLEAR AVAILED
797	3-Apr-21	GULBARGA	66	HV2	SOVENAHALLI_66	12:30	13:35	01:05	LINE CLEAR AVAILED
798	3-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	09:05	09:10	00:05	TRANSFORMER FAULT
799	3-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	12:30	13:00	00:30	LINE CLEAR AVAILED
800	3-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
801	3-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
802	3-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:39(3.4.2021)			LOAD CURTAILMENT
803	3-Apr-21	HASSAN	220	KADUR-DABUSET	KADUR_220	09:18	21:19	12:01	LINE CLEAR AVAILED
804	3-Apr-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	09:34	12:14	02:40	NFBC ISSUED
805	3-Apr-21	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	10:31	10:56	00:25	LINE FAULT
806	3-Apr-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:13	16:56	06:43	LINE CLEAR AVAILED
807	3-Apr-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:13	16:56	06:43	LINE CLEAR AVAILED
808	3-Apr-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:20	10:27	00:07	HAND TRIPPED
809	3-Apr-21	HASSAN	110	BSHRLKP-ARANG	SHIRALKOPPA_220	11:52	11:57	00:05	HAND TRIPPED
810	3-Apr-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	09:51	10:13	00:22	HAND TRIPPED
811	3-Apr-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	09:35	12:14	02:39	LINE CLEAR AVAILED
812	3-Apr-21	HASSAN	110	HV1	BAIKAMPADY_110	10:43	11:40	00:57	LINE CLEAR AVAILED
813	3-Apr-21	HASSAN	110	JOG-JLT3	mghejog_gen	13:09	13:19	00:10	LINE CLEAR AVAILED
814	3-Apr-21	HASSAN	110	JOG-JLT4	mghejog_gen	13:08	13:15	00:07	LINE CLEAR AVAILED
815	3-Apr-21	HASSAN	110	JOG-JST1	mghejog_gen	13:11	13:18	00:07	LINE CLEAR AVAILED
816	3-Apr-21	HASSAN	110	JOG-JST2	mghejog_gen	13:11	13:18	00:07	LINE CLEAR AVAILED
817	3-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	16:04	18:01	01:57	LINE CLEAR AVAILED
818	3-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	16:06	18:01	01:55	LINE CLEAR AVAILED
819	3-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:50	13:30	00:40	LINE FAULT
820	3-Apr-21	HASSAN	66	HV1	ALDUR_66	19:22	19:31	00:09	TRANSFORMER FAULT
821	3-Apr-21	HASSAN	66	HV1	ALDUR_66	22:03	22:13	00:10	TRANSFORMER FAULT
822	3-Apr-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	12:23	14:03	01:40	LINE CLEAR AVAILED
823	3-Apr-21	HASSAN	66	BHADRA-SHMGGA 1	bhadra_gen	10:31	10:57	00:26	LINE FAULT
824	3-Apr-21	HASSAN	66	BYCHAN-HNPURA	BYACHANAHALLY_66	12:27	14:06	01:39	NFBC ISSUED
825	3-Apr-21	HASSAN	66	HV1	BYACHANAHALLY_66	12:27	14:06	01:39	NFBC ISSUED
826	3-Apr-21	HASSAN	66	HV1	HIRESAVE_66	09:33	09:39	00:06	TRANSFORMER FAULT
827	3-Apr-21	HASSAN	66	HV2	HOLEHONNUR_66	06:23	06:51	00:28	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
828	3-Apr-21	HASSAN	66	HV2	MATNAVILE_66	06:28	06:32	00:04	TRANSFORMER FAULT
829	3-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	08:52	18:36	09:44	LINE CLEAR AVAILED
830	3-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKALESH PURA_66	08:52	18:36	09:44	LINE CLEAR AVAILED
831	3-Apr-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:10	10:50	00:40	MAIN SUPPLY FAILURE
832	3-Apr-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	13:30	15:40	02:10	MAIN SUPPLY FAILURE
833	3-Apr-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	10:10	10:50	00:40	MAIN SUPPLY FAILURE
834	3-Apr-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:30	15:40	02:10	MAIN SUPPLY FAILURE
835	3-Apr-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:51	18:51	08:00	LINE CLEAR AVAILED
836	3-Apr-21	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	10:09	10:24	00:15	LINE FAULT
837	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:15	10:20	00:05	LINE FAULT
838	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:20	13:30	02:10	LINE CLEAR AVAILED
839	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:30	17:00	03:30	LINE FAULT
840	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	17:00	18:40	01:40	LINE CLEAR AVAILED
841	3-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:09	10:49	00:40	LINE FAULT
842	3-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	13:22	13:30	00:08	LINE FAULT
843	3-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	15:29	15:40	00:11	LINE FAULT
844	3-Apr-21	HASSAN	66	HV1	MALLAPURA_66	17:58	18:26	00:28	LINE CLEAR AVAILED
845	3-Apr-21	HASSAN	66	HV2	MALLAPURA_66	16:58	19:30	02:32	LINE CLEAR AVAILED
846	3-Apr-21	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
847	3-Apr-21	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
848	3-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRS MG_220	13:39(3.4.2021)			LOAD CURTAILMENT
849	3-Apr-21	HASSAN	220	KADUR-DABUSET	KADUR_220	09:18	21:19	12:01	LINE CLEAR AVAILED
850	3-Apr-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	09:34	12:14	02:40	NFBC ISSUED
851	3-Apr-21	HASSAN	66	MRSSHM-BD-1	MRS MG_220	10:31	10:56	00:25	LINE FAULT
852	3-Apr-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:13	16:56	06:43	LINE CLEAR AVAILED
853	3-Apr-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:13	16:56	06:43	LINE CLEAR AVAILED
854	3-Apr-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:20	10:27	00:07	HAND TRIPPED
855	3-Apr-21	HASSAN	110	BSHRLKP-ARANG	SHIRALKOPPA_220	11:52	11:57	00:05	HAND TRIPPED
856	3-Apr-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	09:51	10:13	00:22	HAND TRIPPED
857	3-Apr-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	09:35	12:14	02:39	LINE CLEAR AVAILED
858	3-Apr-21	HASSAN	110	HV1	BAIKAMPADY_110	10:43	11:40	00:57	LINE CLEAR AVAILED
859	3-Apr-21	HASSAN	110	JOG-JLT3	mghejog_gen	13:09	13:19	00:10	LINE CLEAR AVAILED
860	3-Apr-21	HASSAN	110	JOG-JLT4	mghejog_gen	13:08	13:15	00:07	LINE CLEAR AVAILED
861	3-Apr-21	HASSAN	110	JOG-JST1	mghejog_gen	13:11	13:18	00:07	LINE CLEAR AVAILED
862	3-Apr-21	HASSAN	110	JOG-JST2	mghejog_gen	13:11	13:18	00:07	LINE CLEAR AVAILED
863	3-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	16:04	18:01	01:57	LINE CLEAR AVAILED
864	3-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	16:06	18:01	01:55	LINE CLEAR AVAILED
865	3-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:50	13:30	00:40	LINE FAULT
866	3-Apr-21	HASSAN	66	HV1	ALDUR_66	19:22	19:31	00:09	TRANSFORMER FAULT
867	3-Apr-21	HASSAN	66	HV1	ALDUR_66	22:03	22:13	00:10	TRANSFORMER FAULT
868	3-Apr-21	HASSAN	66	BANDISH-RAMNATH PURA	BANDISHETTYHALLI_66	12:23	14:03	01:40	LINE CLEAR AVAILED
869	3-Apr-21	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	10:31	10:57	00:26	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
870	3-Apr-21	HASSAN	66	BYCHAN-HNPURA	BYACHANAHALLY_66	12:27	14:06	01:39	NFBC ISSUED
871	3-Apr-21	HASSAN	66	HV1	BYACHANAHALLY_66	12:27	14:06	01:39	NFBC ISSUED
872	3-Apr-21	HASSAN	66	HV1	HIRESAVE_66	09:33	09:39	00:06	TRANSFORMER FAULT
873	3-Apr-21	HASSAN	66	HV2	HOLEHONNUR_66	06:23	06:51	00:28	TRANSFORMER FAULT
874	3-Apr-21	HASSAN	66	HV2	MATTNAVILE_66	06:28	06:32	00:04	TRANSFORMER FAULT
875	3-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	08:52	18:36	09:44	LINE CLEAR AVAILED
876	3-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKALESH PURA_66	08:52	18:36	09:44	LINE CLEAR AVAILED
877	3-Apr-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:10	10:50	00:40	MAIN SUPPLY FAILURE
878	3-Apr-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	13:30	15:40	02:10	MAIN SUPPLY FAILURE
879	3-Apr-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	10:10	10:50	00:40	MAIN SUPPLY FAILURE
880	3-Apr-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:30	15:40	02:10	MAIN SUPPLY FAILURE
881	3-Apr-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:51	18:51	08:00	LINE CLEAR AVAILED
882	3-Apr-21	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	10:09	10:24	00:15	LINE FAULT
883	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:15	10:20	00:05	LINE FAULT
884	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:20	13:30	02:10	LINE CLEAR AVAILED
885	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:30	17:00	03:30	LINE FAULT
886	3-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	17:00	18:40	01:40	LINE CLEAR AVAILED
887	3-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:09	10:49	00:40	LINE FAULT
888	3-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	13:22	13:30	00:08	LINE FAULT
889	3-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	15:29	15:40	00:11	LINE FAULT
890	3-Apr-21	HASSAN	66	HV1	MALLAPURA_66	17:58	18:26	00:28	LINE CLEAR AVAILED
891	3-Apr-21	HASSAN	66	HV2	MALLAPURA_66	16:58	19:30	02:32	LINE CLEAR AVAILED
892	3-Apr-21	MYSURU	66	HD KOTE-TARAKA	NO STATION EFFECTED	3:02	3:35	0:32	LINE FAULT
893	3-Apr-21	MYSURU	66	KHB STATION-HOOTAGALLI	NO STATION EFFECTED	9:36	14:33	4:56	NFBC ISSUED
894	3-Apr-21	MYSURU	66	KIKKERI-KR PETE	KIKKERI_66	9:30	16:15	6:44	LINE CLEAR AVAILED
895	3-Apr-21	MYSURU	66	HV3	KRPET_66	11:27	11:52	0:24	LINE CLEAR AVAILED
896	3-Apr-21	MYSURU	220	KADAKOLA -KOZHIKODE	NO STATION EFFECTED	6:46	19:21	12:35	LINE CLEAR AVAILED
897	3-Apr-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATION EFFECTED	13:14	13:19	0:05	LINE FAULT
898	3-Apr-21	MYSURU	66	HV1	SHIVALLY_66	17:53	18:30	0:37	LINE CLEAR AVAILED
899	3-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	18:11 (3/04/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
900	3-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
901	3-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
902	3-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
903	3-Apr-21	TUMKUR	220	THALLAK 220kv- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	12:18	13:28	1:10	LINE FAULT
904	3-Apr-21	TUMKUR	220	HONNAVALLI 110-DMKURKE	DMKURKE_110	0:05	0:35	0:29	LINE FAULT
905	3-Apr-21	TUMKUR	220	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	3:47	3:56	0:08	LINE FAULT
906	3-Apr-21	TUMKUR	220	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:29	22:39	0:10	LINE FAULT
907	3-Apr-21	TUMKUR	110	TR-1	HALURAMESHWARA_66	6:02	6:09	0:07	TRANSFORMER FAULT
908	3-Apr-21	TUMKUR	110	TR-3	HARIYABBE_66	10:12	10:20	0:08	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
909	3-Apr-21	TUMKUR	110	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	9:40	11:09	1:29	LINE FAULT
910	3-Apr-21	TUMKUR	110	H D PURA- SUZLON	SUZLON-IPP	9:37	11:09	1:32	LINE FAULT
911	3-Apr-21	TUMKUR	66	TR-2	HOSADURGA_66	16:00	16:05	0:04	TRANSFORMER FAULT
912	3-Apr-21	TUMKUR	66	TR-2	HOSADURGA_66	19:34	19:38	0:03	TRANSFORMER FAULT
913	3-Apr-21	TUMKUR	66	TR-1	KUNIGAL_66	11:47	12:39	0:52	TRANSFORMER FAULT
914	3-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	0:58	1:03	0:04	LINE FAULT
915	3-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	10:21	10:38	0:17	LINE FAULT
916	3-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	11:33	11:39	0:05	LINE FAULT
917	3-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	16:51	16:55	0:04	LINE FAULT
918	3-Apr-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	6:57	7:07	0:10	LINE FAULT
919	3-Apr-21	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	12:23	13:32	1:08	LINE FAULT
920	3-Apr-21	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	12:23	13:32	1:08	LINE FAULT
921	3-Apr-21	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	12:23	13:32	1:08	LINE FAULT
922	3-Apr-21	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEI DIAMOND SOLAR_IPP_66	12:23	13:32	1:08	LINE FAULT
923	3-Apr-21	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	12:23	13:32	1:08	LINE FAULT
924	3-Apr-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:23	13:32	1:08	LINE FAULT
925	3-Apr-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	12:23	13:32	1:08	LINE FAULT
926	3-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	20:19(1.4.21)			LOAD CURTAILMENT
927	4-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
928	4-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
929	4-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
930	4-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
931	4-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
932	4-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
933	4-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
934	4-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
935	4-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
936	4-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
937	4-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
938	4-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
939	4-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
940	4-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
941	4-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT
942	4-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
943	4-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
944	4-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	8:35 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
945	4-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	7:23 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
946	4-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	7:25 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
947	4-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	7:32 (03.04.2021)			LINE OPEN:LINE CLEAR AVAILED
948	4-Apr-21	BAGALKOT	110	HIDIKAL-RAIBAG	HIDIKAL (STATION NOT AFFECTED)	9:13 (3.4.2021)	23:24 (4.4.2021)	14:11HRS	LINE CHARGED
949	4-Apr-21	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	07:38	20:58	13:20	LINE CLEAR AVAILED
950	4-Apr-21	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	14:04	15:22	1:18	LINE CLEAR AVAILED
951	4-Apr-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	6:40	7:16	0:36	LINE FAULT
952	4-Apr-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	18:04	18:06	0:02	HAND TRIPPED
953	4-Apr-21	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR-110	21:11	21:21	0:10	LINE FAULT
954	4-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	12:30	16:25	3:55	LINE CLEAR AVAILED
955	4-Apr-21	BAGALKOT	220	KUDACHI-CHIKKODI 1	KUDACHI_220	12:19	16:28	4:09	LINE CLEAR AVAILED
956	4-Apr-21	BAGALKOT	220	KUDACHI-CHIKKODI 2	KUDACHI_220	12:19	16:33	4:14	LINE CLEAR AVAILED
957	4-Apr-21	BAGALKOT	110	LAXMESHVAR-SHIRAHATTI	SHIRAHATTI_110	2:01	2:25	0:24	LINE FAULT
958	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	09:10	09:16	0:06	TRANSFORMER FAULT
959	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	11:44	11:50	0:06	TRANSFORMER FAULT
960	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	12:38	12:55	0:17	TRANSFORMER FAULT
961	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	13:13	13:21	0:08	TRANSFORMER FAULT
962	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	17:56	17:59	0:03	TRANSFORMER FAULT
963	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	21:27	21:31	0:04	TRANSFORMER FAULT
964	4-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	22:00	22:07	0:07	TRANSFORMER FAULT
965	4-Apr-21	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	12:06	12:24	0:18	TRANSFORMER FAULT
966	4-Apr-21	BAGALKOT	110	SOUDATTI- ENERCON1	SOUDATTI_110	19:05	20:13	1:08	LINE FAULT
967	4-Apr-21	BAGALKOT	110	SHIRHATTI- LAXMESHVAR	STATION NOT AFFECTED SHIRHATTI_110	02:01	02:27	0:26	LINE FAULT
968	4-Apr-21	BAGALKOT	220	NARENDRA- KANABARGI1 (BELGAUM1)	STATION NOT AFFECTED NARENDRA_220	12:32	16:19	3:47	LINE CLEAR AVAILED
969	4-Apr-21	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	7:38	20:58	13:20	LINE CLEAR AVAILED
970	4-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	STATION NOT AFFECTED RON_110	14:05	14:34	0:29	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
971	4-Apr-21	BAGALKOT	110	RON- GAMESH	STATION NOT AFFECTED RON_110	14:33	14:43	0:10	HAND TRIPPED
972	4-Apr-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:25	15:35	00:09	LINE FAULT
973	4-Apr-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:07	13:16	00:09	LINE FAULT
974	4-Apr-21	BENGALURU	66	T G HALLY - ANCHEPALYA	T G HALLY	13:03	15:19	02:16	MAIN SUPPLY FAILURE
975	4-Apr-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:09	12:45	01:35	LINE FAULT
976	4-Apr-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:04	15:15	00:11	LINE FAULT
977	4-Apr-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:25	15:31	00:05	LINE FAULT
978	4-Apr-21	BENGALURU	66	HV1	RANGANDODDI	11:27	13:38	02:10	LINE CLEAR AVOIDED
979	4-Apr-21	BENGALURU	66	HV2	RANGANDODDI	10:58	11:24	00:26	LINE CLEAR AVOIDED
980	4-Apr-21	BENGALURU	66	HV1	MAGADI 66	13:03	15:27	02:23	MAIN SUPPLY FAILURE
981	4-Apr-21	BENGALURU	66	HV2	MAGADI 66	13:03	15:27	02:23	MAIN SUPPLY FAILURE
982	4-Apr-21	BENGALURU	66	HV2	JIGANI LINK ROAD	13:06	13:10	00:03	LINE CLEAR AVOIDED
983	4-Apr-21	BENGALURU	66	HV1	HUKUNDA	07:00	07:10	00:10	TRANSFORMER FAULT
984	4-Apr-21	BENGALURU	66	HV3	BRINDAVANA	11:25	14:07	02:42	LINE CLEAR AVOIDED
985	4-Apr-21	BENGALURU	66	HV1	BRINDAVANA	14:17	15:55	01:38	LINE CLEAR AVOIDED
986	4-Apr-21	BENGALURU	66	HV2	BRINDAVANA	17:04	18:05	01:01	LINE CLEAR AVOIDED
987	4-Apr-21	BENGALURU	66	HV1	HOODY 220	23:56	23:59	00:03	TRANSFORMER FAULT
988	4-Apr-21	BENGALURU	66	HV1	KADUGODI	22:08	22:10	00:02	TRANSFORMER FAULT
989	4-Apr-21	BENGALURU	66	KORAMANGALA 220 - ADUGODI 1	NO STATION AFFECTED	20:03	20:43	00:40	LINE FAULT
990	4-Apr-21	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA	06:55	19:17	12:22	LINE CLEAR AVOIDED
991	4-Apr-21	BENGALURU	66	EPID 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	23:12(04/04/2021)			LINE OPEN:LINE CLEAR AVOIDED
992	4-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
993	4-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35:00 AM(01.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
994	4-Apr-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERAD ONA_110,SRERAMNAGAR_110,MALL APURA_110	05:18	05:28	00:10	LINE FAULT
995	4-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	21:45	21:55	00:10	LINE FAULT
996	4-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	02:28	02:40	00:12	LINE FAULT
997	4-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	21:04	21:14	00:10	LINE FAULT
998	4-Apr-21	GULBARGA	110	SEDAM-CHITAPUR	CHJITAPUR_110	12:55	13:07	00:12	LINE FAULT
999	4-Apr-21	GULBARGA	110	HV2	SHAHAPUR_110	12:58	13:15	00:17	TRANSFORMER FAULT
1000	4-Apr-21	GULBARGA	110	HV3	LADHA_110	01:40	11:05	09:25	TRANSFORMER FAULT
1001	4-Apr-21	GULBARGA	110	HALWARTHY-KOPPAL	KOPPAL_110	18:30	20:21	01:51	LINE CLEAR AVOIDED
1002	4-Apr-21	GULBARGA	110	JANAWADA-SANTAPUR	SANTAPUR_110	18:45	18:55	00:10	LINE FAULT
1003	4-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	07:40	07:45	00:05	TRANSFORMER FAULT
1004	4-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
1005	4-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
1006	4-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:39(3.4.2021)			LOAD CURTAILMENT
1007	4-Apr-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:02	12:59	02:57	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1008	4-Apr-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:17	10:35	00:18	LINE FAULT
1009	4-Apr-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:02	13:00	02:58	NFBC ISSUED
1010	4-Apr-21	HASSAN	110	HV3	PUTUR_110	17:53	18:09	00:16	TRANSFORMER FAULT
1011	4-Apr-21	HASSAN	110	HV1	BARANGI_110	22:33	23:04	00:31	LINE CLEAR AVAILED
1012	4-Apr-21	HASSAN	110	JOG-JLT3	mghejog_gen	09:30	14:07	04:37	LINE CLEAR AVAILED
1013	4-Apr-21	HASSAN	110	JOG-JLT4	mghejog_gen	09:27	14:23	04:56	LINE CLEAR AVAILED
1014	4-Apr-21	HASSAN	110	JOG-JST1	mghejog_gen	09:30	13:53	04:23	LINE CLEAR AVAILED
1015	4-Apr-21	HASSAN	110	JOG-JST2	mghejog_gen	09:30	13:53	04:23	LINE CLEAR AVAILED
1016	4-Apr-21	HASSAN	110	JOG110-MGHE	JOG_110	09:36	14:06	04:30	LINE CLEAR AVAILED
1017	4-Apr-21	HASSAN	110	SAGARA-JST1	SAGARA_110	09:41	13:52	04:11	LINE CLEAR AVAILED
1018	4-Apr-21	HASSAN	110	SAGARA-JST2	SAGARA_110	09:41	13:52	04:11	LINE CLEAR AVAILED
1019	4-Apr-21	HASSAN	66	HV1	ALDUR_66	19:59	20:05	00:06	TRANSFORMER FAULT
1020	4-Apr-21	HASSAN	66	HV2	HOLEHONNUR_66	12:52	12:57	00:05	LINE CLEAR AVAILED
1021	4-Apr-21	HASSAN	66	HV1	HOLEHONNUR_66	14:30	14:57	00:27	LINE CLEAR AVAILED
1022	4-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESHPUA_66	08:46	19:17	10:31	LINE CLEAR AVAILED
1023	4-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKALESHPUA_66	08:46	19:17	10:31	LINE CLEAR AVAILED
1024	4-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:16	11:48	01:32	LINE FAULT
1025	4-Apr-21	HASSAN	66	HV1	MALLAPURA_66	10:44	16:16	05:32	LINE CLEAR AVAILED
1026	4-Apr-21	HASSAN	66	HV2	MALLAPURA_66	10:44	16:18	05:34	LINE CLEAR AVAILED
1027	4-Apr-21	MYSURU	66	HEBBAL-HOOTAGALLI	HEBBAL_66	9:05	15:33	6:28	LINE CLEAR AVAILED
1028	4-Apr-21	MYSURU	66	HEBBAL-METAGALLY	METAGALLY_66	9:06	16:25	7:19	LINE CLEAR AVAILED
1029	4-Apr-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	10:10	10:16	0:06	LINE FAULT
1030	4-Apr-21	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA1	ALUR SIDDAPURA_66	15:26	15:37	0:10	LINE FAULT
1031	4-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1032	4-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	21:15	21:23	0:07	LINE FAULT
1033	4-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	18:11 (3/04/2021)	7:20 (4/4/2021)	13:09 HRS	TRANSFORMER CHARGED
1034	4-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1035	4-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
1036	4-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1037	4-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	10:26	17:43	7:17	LOAD CURTAILMENT
1038	4-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	6:58	7:47	0:49	LINE FAULT
1039	4-Apr-21	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	22:02	22:04	0:02	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1040	4-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	21:35	21:47	0:12	TRANSFORMER FAULT
1041	4-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	21:50	21:57	0:06	TRANSFORMER FAULT
1042	4-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	22:26	22:35	0:09	TRANSFORMER FAULT
1043	4-Apr-21	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	18:48	18:59	0:11	LINE FAULT
1044	4-Apr-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:53	19:03	0:09	LINE FAULT
1045	4-Apr-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:05	15:18	0:13	LINE FAULT
1046	4-Apr-21	TUMKUR	66	TR-1	HDPURA_66	20:28	20:35	0:06	TRANSFORMER FAULT
1047	4-Apr-21	TUMKUR	66	TR-3	HOLALKERE_66	14:34	14:45	0:11	TRANSFORMER FAULT
1048	4-Apr-21	TUMKUR	66	TR-3	HOLALKERE_66	17:42	17:51	0:08	TRANSFORMER FAULT
1049	4-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:29	15:38	0:08	HAND TRIPPED
1050	4-Apr-21	TUMKUR	66	TR-2	HOSADURGA_66	16:26	16:27	0:01	TRANSFORMER FAULT
1051	4-Apr-21	TUMKUR	66	TR-2	HULIYURDURGA_66	12:03	12:33	0:30	TRANSFORMER FAULT
1052	4-Apr-21	TUMKUR	66	TR-1	LINGDHALLI_66	7:24	7:30	0:05	TRANSFORMER FAULT
1053	4-Apr-21	TUMKUR	66	TR-1	LINGDHALLI_66	8:04	8:06	0:01	TRANSFORMER FAULT
1054	4-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	17:51	17:55	0:04	LINE FAULT
1055	4-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	18:09	18:14	0:04	LINE FAULT
1056	4-Apr-21	TUMKUR	66	TR-1	MAVINAKATTE_66	15:32	15:36	0:04	TRANSFORMER FAULT
1057	4-Apr-21	TUMKUR	66	TR-1	MAVINAKATTE_66	15:37	15:40	0:02	TRANSFORMER FAULT
1058	4-Apr-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN SOLAR 1_IPP_66	6:12	9:34	3:22	LINE FAULT
1059	4-Apr-21	TUMKUR	66	TR-1	SAVALANGA_66	11:48	15:57	4:09	MAIN SUPPLY FAILURE
1060	4-Apr-21	TUMKUR	66	TR-1	THOVINKERE_66	8:59	9:23	0:23	TRANSFORMER FAULT
1061	4-Apr-21	TUMKUR	66	TR-1	TUMKUR_66	6:58	7:21	0:23	TRANSFORMER FAULT
1062	4-Apr-21	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	18:53	19:21	0:28	LINE FAULT
1063	4-Apr-21	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	18:53	19:29	0:35	LINE FAULT
1064	4-Apr-21	TUMKUR	66	TR-1	JIDDIGERE_66	6:32	8:12	1:39	LINE CLEAR AVAILED
1065	4-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	20:19(1.4.21)			LOAD CURTAILMENT
1066	5-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1067	5-Apr-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	11:10	11:12	0:02	TRANSFORMER FAULT
1068	5-Apr-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	11:56	11:58	0:02	TRANSFORMER FAULT
1069	5-Apr-21	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	10:08	19:09	9:01	LINE CLEAR AVAILED
1070	5-Apr-21	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(B)_110	15:23	18:35	3:12	LINE CLEAR AVAILED
1071	5-Apr-21	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	18:04	18:19	0:15	TRANSFORMER FAULT
1072	5-Apr-21	BAGALKOT	110	110/11KV,HV 1	KALADAGI_110	07:32	07:36	0:04	TRANSFORMER FAULT
1073	5-Apr-21	BAGALKOT	110	110/11KV,HV 1	KALADAGI_110	09:06	09:11	0:05	TRANSFORMER FAULT
1074	5-Apr-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	14:55	15:05	0:10	TRANSFORMER FAULT
1075	5-Apr-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	15:15	15:56	0:41	LINE CLEAR AVAILED
1076	5-Apr-21	BAGALKOT	110	110/11KV,HV4	HIDIKAL_110	12:07	12:58	0:51	LINE CLEAR AVAILED
1077	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	06:27	07:03	0:36	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1078	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	07:23	07:30	0:07	TRANSFORMER FAULT
1079	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	10:27	10:29	0:02	TRANSFORMER FAULT
1080	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	10:49	10:51	0:02	TRANSFORMER FAULT
1081	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	11:17	11:20	0:03	TRANSFORMER FAULT
1082	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	15:10	15:13	0:03	TRANSFORMER FAULT
1083	5-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	15:29	15:34	0:05	TRANSFORMER FAULT
1084	5-Apr-21	BAGALKOT	110	CHIKKODI1&2- RAIBAG	RAIBAG_110	12:47	12:54	0:07	HAND TRIPPED
1085	5-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1086	5-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
1087	5-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1088	5-Apr-21	BAGALKOT	110	HIRA SUGAR1- SANKESHWAR	SANKESHWAR_110	11:23	13:51	2:28	LINE CLEAR AVAILED
1089	5-Apr-21	BAGALKOT	110	HUBLI- ANAND NAGAR	ANAND NAGAR_110	14:05	15:58	1:53	LINE FAULT
1090	5-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1091	5-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
1092	5-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1093	5-Apr-21	BAGALKOT	110	MALGHAN(S)- MANALI SUGARS	MALGHAN(S)_110	12:09	12:17	0:08	LINE FAULT
1094	5-Apr-21	BAGALKOT	110	MUGALKOD- RAIBAG	RAIBAG_110	12:47	12:57	0:10	HAND TRIPPED
1095	5-Apr-21	BAGALKOT	110	MUNDARGI- VIJAYNAGAR SUGARS	STATION NOT AFFECTED MUNDARGI_110	20:07	21:11	1:04	LINE FAULT
1096	5-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1097	5-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
1098	5-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1099	5-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	8:35 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1100	5-Apr-21	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	7:57	15:31	7:34	LINE CLEAR AVAILED
1101	5-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	CHIKKODI_220	10:31 (5.4.2021)			LINE OPEN:LINE CLEAR AVAILED
1102	5-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	7:32 (3.4.2021)	10:31 (5.4.2021)	51:09 hrs	LINE CHARGED
1103	5-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
1104	5-Apr-21	BAGALKOT	220	GADAG-HARTI2	GADAG_220	8:25	18:43	10:18	LINE CLEAR AVAILED
1105	5-Apr-21	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	14:04	18:47	4:43	LINE FAULT
1106	5-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1107	5-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	7:23 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1108	5-Apr-21	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	15:28 (5.4.2021)			LINE OPEN : LINE FAULT
1109	5-Apr-21	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	07:56	15:31	7:35	LINE CLEAR AVAILED
1110	5-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN : LINE FAULT
1111	5-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
1112	5-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1113	5-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	7:25 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1114	5-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1	STATION NOT AFFECTED VAJRAMATTI_220	10:48	10:58	0:10	HAND TRIPPED
1115	5-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1	STATION NOT AFFECTED VAJRAMATTI_220	12:03 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1116	5-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI2	STATION NOT AFFECTED VAJRAMATTI_220	10:49	10:56	0:07	HAND TRIPPED
1117	5-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI2	STATION NOT AFFECTED VAJRAMATTI_220	12:04 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1118	5-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN : LINE FAULT
1119	5-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1120	5-Apr-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	17:30	17:35	00:05	LOAD CHANGE OVER
1121	5-Apr-21	BENGALURU	66	BYADRAHALLI - T G HALLI	TAVAREKERE, KODIGEHALLI, T G HALLI	14:58	16:02	01:04	LINE FAULT
1122	5-Apr-21	BENGALURU	66	CHANDRAPPA CIRCLE - KUMBALAGODU	CHANDRAPPA CIRCLE	11:10	11:25	00:15	LOAD CHANGE OVER
1123	5-Apr-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:58	14:12	00:14	LINE FAULT
1124	5-Apr-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	23:12(04/04/2021)	00:07(05/04/2021)	00:55	LINE CHARGED
1125	5-Apr-21	BENGALURU	66	HV1	PATH PALYA	08:20	08:25	00:05	TRANSFORMER FAULT
1126	5-Apr-21	BENGALURU	66	HV1	MAASTHI	11:05	11:51	00:46	LINE CLEAR AVAILED
1127	5-Apr-21	BENGALURU	66	HV1	CHINTAMANI 66	12:19	12:25	00:05	TRANSFORMER FAULT
1128	5-Apr-21	BENGALURU	66	HV1	ISRO LAYOUT	17:20	17:30	00:10	TRANSFORMER FAULT
1129	5-Apr-21	BENGALURU	66	HV1	H GOLHALLI	18:25(5-4-2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
1130	5-Apr-21	BENGALURU	66	HV2	GUDIBANDE	10:45	12:10	01:25	LINE CLEAR AVAILED
1131	5-Apr-21	BENGALURU	66	HV2	GUDIBANDE	12:13	14:00	01:46	LINE CLEAR AVAILED
1132	5-Apr-21	BENGALURU	66	HV2	TELECOM LAYOUT	11:26	11:32	00:06	LINE CLEAR AVAILED
1133	5-Apr-21	BENGALURU	66	ITI 220 - DRDO(EHT)	DRDO(EHT)	09:57	10:54	00:57	LINE FAULT
1134	5-Apr-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:30	15:39	00:09	LINE FAULT
1135	5-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	13:22	14:03	00:41	LINE CLEAR AVAILED
1136	5-Apr-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY, BTM 4TH PHASE	17:48	18:25	00:37	LINE CLEAR AVAILED
1137	5-Apr-21	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 2	HANUMANTHNAGAR, YEDUMADU	17:48	18:30	00:42	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1138	5-Apr-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT)	17:48	18:14	00:26	LINE CLEAR AVAILED
1139	5-Apr-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	17:44	17:55	00:11	LOAD CHANGE OVER
1140	5-Apr-21	BENGALURU	66	T G HALLY - ANCHEPALYA 220	T G HALLY, BYDRAHALLY	10:30	10:45	00:15	LOAD CURTAILMENT
1141	5-Apr-21	BENGALURU	66	T G HALLY - ANCHEPALYA 220	T G HALLY, BYDRAHALLY	10:50	14:05	03:15	LOAD CURTAILMENT
1142	5-Apr-21	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	16:58	17:54	00:56	LINE FAULT
1143	5-Apr-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:13	17:34	00:21	LOAD CHANGE OVER
1144	5-Apr-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	22:41	22:46	00:05	LOAD CHANGE OVER
1145	5-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN : LINE FAULT
1146	5-Apr-21	BENGALURU	220	HV2	SOMANAHALLI 220	17:48	18:20	00:32	TRANSFORMER FAULT
1147	5-Apr-21	BENGALURU	220	YARANDANAHALLI 220 - HOSUR 220	NO STATION AFFECTED	17:13	22:20	05:07	LINE FAULT
1148	5-Apr-21	GULBARGA	66	HV1	HANASI_66	11:00	11:50	00:50	LINE CLEAR AVAILED
1149	5-Apr-21	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110	12:35	12:45	00:10	MAIN SUPPLY FAILURE
1150	5-Apr-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	12:33	12:43	00:10	LINE CLEAR AVAILED
1151	5-Apr-21	GULBARGA	110	HV2	DEODURGA_110	17:05	17:20	00:15	TRANSFORMER FAULT
1152	5-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35:00 AM(01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1153	5-Apr-21	GULBARGA	110	NALWAR-CLN SOLAR	NALWAR_110	10:55	11:30	00:35	LINE FAULT
1154	5-Apr-21	GULBARGA	110	SHAHABAD -BAGEWADI2	YEDRAMI_110,MORATAGI_110	10:34	11:44	01:10	LINE CLEAR AVAILED
1155	5-Apr-21	GULBARGA	110	SHAHABAD -BAGEWADI2	YEDRAMI_110,MORATAGI_110	13:15	14:38	01:23	LINE CLEAR AVAILED
1156	5-Apr-21	GULBARGA	110	SHAHABAD -WADI	WADI_110	13:18	13:22	00:04	LINE FAULT
1157	5-Apr-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	03:06	03:12	00:06	LINE FAULT
1158	5-Apr-21	GULBARGA	220	HV1 & HV2	KUSHTAGI_220	06:08	06:46	00:38	TRANSFORMER FAULT
1159	5-Apr-21	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	10:59	11:22	00:23	LINE FAULT
1160	5-Apr-21	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	15:41	17:47	02:06	LINE CLEAR AVAILED
1161	5-Apr-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	18:19(5.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1162	5-Apr-21	GULBARGA	220	SHAHABAD-KAPANOOR	SHAHABAD_220	10:58	11:23	00:25	LINE FAULT
1163	5-Apr-21	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	10:58	11:16	00:18	LINE FAULT
1164	5-Apr-21	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	16:39	18:09	01:30	LINE CLEAR AVAILED
1165	5-Apr-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	14:18	14:23	00:05	LINE FAULT
1166	5-Apr-21	HASSAN	66	HV1	HOLEHONNUR_66	15:33(5.4.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1167	5-Apr-21	HASSAN	66	HV1	ALDUR_66	22:16	22:37	00:21	TRANSFORMER FAULT
1168	5-Apr-21	HASSAN	66	HV1	SINGAPURA_66	16:40	18:10	01:30	MAIN SUPPLY FAILURE
1169	5-Apr-21	HASSAN	66	HV2	HALLYMYSORE_66	14:18	14:25	00:07	TRANSFORMER FAULT
1170	5-Apr-21	HASSAN	66	HV2	SALAGAME_66	12:21	12:26	00:05	TRANSFORMER FAULT
1171	5-Apr-21	HASSAN	66	HV2	SINGAPURA_66	16:40	18:10	01:30	MAIN SUPPLY FAILURE
1172	5-Apr-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	00:15	00:22	00:07	LINE FAULT
1173	5-Apr-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	08:33	08:45	00:12	LINE FAULT
1174	5-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1175	5-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1176	5-Apr-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:07	11:27	00:20	LINE FAULT
1177	5-Apr-21	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	19:58	20:55	00:57	LINE FAULT
1178	5-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	08:46	20:45	11:59	LINE CLEAR AVAILED
1179	5-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	08:46	20:45	11:59	LINE CLEAR AVAILED
1180	5-Apr-21	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	16:41	18:10	01:29	NFBC ISSUED
1181	5-Apr-21	HASSAN	110	HV1	KONAJE_110	12:56	13:00	00:04	HAND TRIPPED
1182	5-Apr-21	HASSAN	110	HV1	SHIKARIPURA_110	13:07	13:20	00:13	TRANSFORMER FAULT
1183	5-Apr-21	HASSAN	110	HV1	SORABA_110	11:58	17:46	05:48	LINE CLEAR AVAILED
1184	5-Apr-21	HASSAN	110	HV2	KONAJE_110	12:56	13:01	00:05	HAND TRIPPED
1185	5-Apr-21	HASSAN	110	HV3	KONAJE_110	12:56	13:00	00:04	HAND TRIPPED
1186	5-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:04	11:58	00:54	MAIN SUPPLY FAILURE
1187	5-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:07	13:05	02:58	LINE CLEAR AVAILED
1188	5-Apr-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:50	12:58	01:08	MAIN SUPPLY FAILURE
1189	5-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:39(3.4.2021)			LOAD CURTAILMENT
1190	5-Apr-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	CHUNCHUNKATTE_66	12:40	14:29	1:49	LINE CLEAR AVAILED
1191	5-Apr-21	MYSURU	66	CHUNCHANAKATTE-RAVANDUR	CHUNCHUNKATTE_66	12:40	14:30	1:50	LINE CLEAR AVAILED
1192	5-Apr-21	MYSURU	66	CR NAGARA-BADANKUPPE 2	BADANAGUPPE_66	15:36	16:00	0:24	LINE FAULT
1193	5-Apr-21	MYSURU	66	CR NAGARA-BADANKUPPE 2	BADANAGUPPE_66	19:07	19:38	0:31	LINE FAULT
1194	5-Apr-21	MYSURU	66	HV1	HANGLA_66	8:35	8:39	0:04	TRANSFORMER FAULT
1195	5-Apr-21	MYSURU	66	HV1	HANNUR_66	14:16	14:26	0:09	TRANSFORMER FAULT
1196	5-Apr-21	MYSURU	66	HV1	HANNUR_66	15:08	15:09	0:01	TRANSFORMER FAULT
1197	5-Apr-21	MYSURU	66	HV1	HOSURGATE_66	17:03	20:48	3:45	TRANSFORMER FAULT
1198	5-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1199	5-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1200	5-Apr-21	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66,	18:07	18:11	0:04	LINE FAULT
1201	5-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN : LINE FAULT
1202	5-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1203	5-Apr-21	MYSURU	66	KR NAGARA-CHUNCHANAKATTE	NO STATION EFFECTED	12:52	12:59	0:07	LINE FAULT
1204	5-Apr-21	MYSURU	66	TALAKADU-ADANI	NO STATION EFFECTED	6:31	6:43	0:12	LINE FAULT
1205	5-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:37	10:42	0:04	LINE FAULT
1206	5-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	21:05	21:09	0:04	LINE FAULT
1207	5-Apr-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	10:46	10:54	00:08	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1208	5-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	10:46	10:54	00:08	HAND TRIPPED
1209	5-Apr-21	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	18:48	19:00	00:11	LINE FAULT
1210	5-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:45	14:57	00:11	LINE FAULT
1211	5-Apr-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	09:27	12:10	02:43	LINE CLEAR AVAILED
1212	5-Apr-21	TUMKUR	66	H D PURA- SUZLON	SUZLON-IPP	18:33	18:49	00:16	MAIN SUPPLY FAILURE
1213	5-Apr-21	TUMKUR	66	HALURAMESHWARA-MATHOD	HALURAMESHWARA_66	13:22	13:26	00:04	LINE CLEAR AVAILED
1214	5-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66(NO STATION EFFECTED)	20:19(1.4.21)			LOAD CURTAILMENT
1215	5-Apr-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	19:53	20:02	00:09	LINE FAULT
1216	5-Apr-21	TUMKUR	66	HV1	HALURAMESHWARA_66	12:00	12:25	00:25	LINE CLEAR AVAILED
1217	5-Apr-21	TUMKUR	66	HV2	HALURAMESHWARA_66	12:00	13:28	01:27	LINE CLEAR AVAILED
1218	5-Apr-21	TUMKUR	66	HV2	HALURAMESHWARA_66	13:41	13:45	00:04	LINE CLEAR AVAILED
1219	5-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	10:50	10:52	00:01	LINE FAULT
1220	5-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	18:32	20:02	01:30	LINE CLEAR AVAILED
1221	5-Apr-21	TUMKUR	66	TR-1	BADAVANAHALLI_66	09:12	09:18	00:05	TRANSFORMER FAULT
1222	5-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	16:09	16:11	00:02	TRANSFORMER FAULT
1223	5-Apr-21	TUMKUR	66	TR-1	HDPURA_66	00:00	00:02	00:02	MAIN SUPPLY FAILURE
1224	5-Apr-21	TUMKUR	66	TR-1	KANCHIPURA_66	07:10	07:30	00:19	TRANSFORMER FAULT
1225	5-Apr-21	TUMKUR	66	TR-1	TAVAREKERE(H)_66	11:00	11:13	00:13	TRANSFORMER FAULT
1226	5-Apr-21	TUMKUR	66	TR-1	TAVAREKERE(H)_66	17:06	17:14	00:07	LINE CLEAR AVAILED
1227	5-Apr-21	TUMKUR	66	TR-1	TUMKUR_66	15:02	15:11	00:09	TRANSFORMER FAULT
1228	5-Apr-21	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	08:56	09:28	00:32	TRANSFORMER FAULT
1229	5-Apr-21	TUMKUR	66	TR-2	BALENAHALLI_66	18:35	18:49	00:13	TRANSFORMER FAULT
1230	5-Apr-21	TUMKUR	66	TR-2	CHITRADURGA_66	11:11	14:32	03:21	LINE CLEAR AVAILED
1231	5-Apr-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	09:01	09:47	00:46	TRANSFORMER FAULT
1232	5-Apr-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	11:50	11:55	00:05	TRANSFORMER FAULT
1233	5-Apr-21	TUMKUR	66	TR-2	MATHOD_66	20:02	20:09	00:06	TRANSFORMER FAULT
1234	5-Apr-21	TUMKUR	66	TR-2	SANIKERE_66	13:04	13:24	00:20	TRANSFORMER FAULT
1235	5-Apr-21	TUMKUR	66	TR-2	SASALUHALLA	22:06	22:07	00:01	TRANSFORMER FAULT
1236	5-Apr-21	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	12:06	12:28	00:22	LINE FAULT
1237	5-Apr-21	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	15:30	17:23	01:53	LINE FAULT
1238	5-Apr-21	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	10:59	12:53	01:54	LINE CLEAR AVAILED
1239	5-Apr-21	TUMKUR	110	TR-1	HUNSEGHATTA_110	13:38	14:00	00:22	LINE CLEAR AVAILED