

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 29.10.2019 TO 04.11.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	29/Oct/19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	13:57	14:07	0:10	LINE FAULT
2	29/Oct/19	BAGALKOT	220	VAJRAMATTI-MAHANLINGAPUR2	VAJRAMATTI_220	1:30	1:55	0:25	LINE FAULT
3	29/Oct/19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	0:00	8:53	8:53	LINE CLEAR AVAILED
4	29/Oct/19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	23:01	23:59	0:58	HAND TRIPPED
5	29/Oct/19	BAGALKOT	110	MAMDAPUR-BABLESHWAR	BABLESHWAR_110	13:06	13:15	0:09	LINE FAULT
6	29/Oct/19	BAGALKOT	110	110/11KV, HV1	TERDAL_110	0:32	0:40	0:08	TRANSFORMER FAULT
7	29/Oct/19	BAGALKOT	110	SOUDATTI220-YARGATTI	YARGATTI_110	18:09	18:43	0:34	LINE FAULT
8	29/Oct/19	BAGALKOT	110	MAREGUDDI-MUNDAGANUR	MUNDAGANUR_110	15:10	17:00	1:50	LINE CLEAR AVAILED
9	29/Oct/19	BAGALKOT	110	110/11KV, HV1&HV2	MUNDAGANUR_110	15:10	17:00	1:50	LINE CLEAR AVAILED
10	29/Oct/19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	16:04	23:59	7:55	LINE CLEAR AVAILED
11	29/Oct/19	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	18:24	18:34	0:10	LINE FAULT
12	29/Oct/19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	13:07	13:57	0:50	LINE FAULT
13	29/Oct/19	BAGALKOT	110	UMMACHAGI-ESALE(SIRSI)	UMMACHAGI_110	0:00	8:38	8:38	LINE CLEAR AVAILED
14	29/Oct/19	BAGALKOT	110	SIRSI220-KAVALWAD	KAVALWADA_110	15:47	16:40	0:53	LINE CLEAR AVAILED
15	29/Oct/19	BAGALKOT	220	RANEBENNUR-SHIROLKOPPA	RANEBENNUR_220	12:28	13:28	1:00	HAND TRIPPED
16	29/Oct/19	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	0:00	12:31	12:31	LINE CLEAR AVAILED
17	29/Oct/19	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	12:22	12:35	0:13	MAIN SUPPLY FAILURE
18	29/Oct/19	BAGALKOT	110	RANEBENNUR220-BYADAGI	BYADAGI_110	12:22	12:35	0:13	MAIN SUPPLY FAILURE
19	29/Oct/19	BAGALKOT	110	RANEBENNUR220-HONNATTI	HONNATTI_110	12:22	12:35	0:13	MAIN SUPPLY FAILURE
20	29/Oct/19	BAGALKOT	110	RANEBENNUR220-TUMMBINAKATTI	TUMMBINAKATTI_110	12:22	12:35	0:13	MAIN SUPPLY FAILURE
21	29/Oct/19	BAGALKOT	110	RANEBENNUR220-GUTTAL	GUTTAL_110	12:22	12:35	0:13	MAIN SUPPLY FAILURE
22	29/Oct/19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	14:42	23:59	9:17	LINE CLEAR AVAILED
23	29/Oct/19	BAGALKOT	110	BAGEWADI220-CHIMMALAGI LIS	CHIMMALAGI LIS_110	16:00	17:00	1:00	LINE CLEAR AVAILED
24	29/Oct/19	BAGALKOT	110	110/110KV,HV2	BAGEWADI_220	9:48	9:50	0:02	TRANSFORMER FAULT
25	29/Oct/19	BAGALKOT	220	GADAG-HARTI1	GADAG_220	17:35	17:37	0:02	HAND TRIPPED
26	29/Oct/19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	23:31	23:50	0:19	LINE FAULT
27	29/Oct/19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	14:52	14:55	0:03	LINE FAULT
28	29/Oct/19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	7:03	7:37	0:34	LINE FAULT
29	29/Oct/19	BENGALURU	66	EPIP 220 - CHANDAPURA	SHAMRAJ TECH PARK, KACHMARANAHALLI	3:23	3:44	0:21	MAIN SUPPLY FAILURE
30	29/Oct/19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	6:03	7:00	0:57	LINE CLEAR AVAILED
31	29/Oct/19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	6:03	7:00	0:57	LINE CLEAR AVAILED
32	29/Oct/19	BENGALURU	220	HV2	EPIP 220	23:43	23:59	0:16	TRANSFORMER FAULT
33	29/Oct/19	BENGALURU	220	HV2	EPIP 220	3:23	3:44	0:21	TRANSFORMER FAULT
34	29/Oct/19	GULBARGA	220	HV1	ITTAGI_220	7:50	8:05	0:15	TRANSFORMER FAULT
35	29/Oct/19	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	2:46	3:00	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
36	29/Oct/19	GULBARGA	220	HV2	ALIPUR_220	2:05	2:20	0:15	TRANSFORMER FAULT
37	29/Oct/19	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	14:02	14:23	0:21	LINE FAULT
38	29/Oct/19	GULBARGA	110	MALLAT-BYAGWAT2	MADALAPURA_110, MANVI_110	20:50	20:55	0:05	LINE FAULT
39	29/Oct/19	GULBARGA	66	ITTAGI-HADAGALLI2	HIREHADAGALI_66,GIRIYAPURA_110,S OVENAHALLI_66,MAGALA_66,TUNGAB HADRA_IPP	10:40	10:50	0:10	LINE FAULT
40	29/Oct/19	GULBARGA	66	LV2	ITTAGI_220	7:50	8:00	0:10	TRANSFORMER FAULT
41	29/Oct/19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	9:51	10:05	0:14	LINE CLEAR AVAILED
42	29/Oct/19	GULBARGA	66	ITTAGI-CLEANMAX2_IPP	ITTAGI_220	9:51	10:00	0:09	LINE CLEAR AVAILED
43	29/Oct/19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:52	23:59	2:07	LINE CLEAR AVAILED
44	29/Oct/19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:29	16:36	1:07	LINE FAULT
45	29/Oct/19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	5:38	11:48	6:10	LINE FAULT
46	29/Oct/19	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	5:38	11:49	6:11	LINE FAULT
47	29/Oct/19	HASSAN	220	HV2	SHIRALKOPPA_220	8:46	8:51	0:05	TRANSFORMER FAULT
48	29/Oct/19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:28	16:36	1:08	LINE FAULT
49	29/Oct/19	HASSAN	110	LV2	SHIRALKOPPA_220	8:46	8:51	0:05	TRANSFORMER FAULT
50	29/Oct/19	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	7:37	8:09	0:32	LINE FAULT
51	29/Oct/19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	7:37	8:58	1:21	LINE FAULT
52	29/Oct/19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	18:16	18:26	0:10	LINE FAULT
53	30/Oct/19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	12:43	16:01	3:18	LINE CLEAR AVAILED
54	30/Oct/19	BAGALKOT	110	VAJRAMATTI-BILAGI	BILAGI_110	6:35	6:40	0:05	LINE FAULT
55	30/Oct/19	BAGALKOT	110	220/110KV, LV1	VAJRAMATTI_220	12:55	16:20	3:25	LINE CLEAR AVAILED
56	30/Oct/19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	0:00	8:47	8:47	LINE CLEAR AVAILED
57	30/Oct/19	BAGALKOT	110	110/11KV, HV1	TERDAL_110	16:15	16:27	0:12	TRANSFORMER FAULT
58	30/Oct/19	BAGALKOT	110	110/11KV, HV1	TERDAL_110	18:50	19:00	0:10	TRANSFORMER FAULT
59	30/Oct/19	BAGALKOT	110	110/11KV, HV1	NANADI_110	2:24	2:39	0:15	TRANSFORMER FAULT
60	30/Oct/19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	6:50	6:50	LINE CLEAR AVAILED
61	30/Oct/19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	9:40	23:59	14:19	LINE CLEAR AVAILED
62	30/Oct/19	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	11:00	11:40	0:40	LINE CLEAR AVAILED
63	30/Oct/19	BAGALKOT	110	110/11KV, HV1	KAGWAD_110	12:15	13:00	0:45	LINE CLEAR AVAILED
64	30/Oct/19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:00	7:02	7:02	LINE CLEAR AVAILED
65	30/Oct/19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	23:04	23:59	0:55	HAND TRIPPED
66	30/Oct/19	BAGALKOT	110	110/33KV,HV1	MK HUBLI_110,GANDIGAWAD_33	13:41	15:03	1:22	LINE CLEAR AVAILED
67	30/Oct/19	BAGALKOT	110	INDI220-INDI	INDI_110	10:40	12:30	1:50	LINE CLEAR AVAILED
68	30/Oct/19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:00	6:52	6:52	LINE CLEAR AVAILED
69	30/Oct/19	BAGALKOT	110	110/33KV,HV2	BAGEWADI_220,TALIKOT_33,BORUKA_33	11:20	11:35	0:15	TRANSFORMER FAULT
70	30/Oct/19	BAGALKOT	220	BAGEWADI220-BALUTI LIS	BAGEWADI_220	17:15	17:40	0:25	LINE CLEAR AVAILED
71	30/Oct/19	BAGALKOT	220	GADAG-BAGALKOT1&2	GADAG_220	9:35	11:48	2:13	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
72	30/Oct/19	BENGALURU	66	HV2	BAGEPALLI	12:05	12:08	0:03	LINE CLEAR AVAILED
73	30/Oct/19	BENGALURU	66	HV2	JIGANI	12:15	12:20	0:05	LINE CLEAR AVAILED
74	30/Oct/19	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:50	23:59	1:09	LINE CLEAR AVAILED
75	30/Oct/19	GULBARGA	400	BPS-YTPS1	YTPS_400	0:00	9:53	9:53	LINE CLEAR AVAILED
76	30/Oct/19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	6:32	7:20	0:48	LINE FAULT
77	30/Oct/19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	7:20	14:25	7:05	LINE CLEAR AVAILED
78	30/Oct/19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	8:35	9:05	0:30	LINE CLEAR AVAILED
79	30/Oct/19	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	16:15	17:45	1:30	LINE CLEAR AVAILED
80	30/Oct/19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:45	23:59	8:14	LINE CLEAR AVAILED
81	30/Oct/19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	14:28	14:28	LINE CLEAR AVAILED
82	30/Oct/19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:48	23:59	2:11	LINE CLEAR AVAILED
83	30/Oct/19	HASSAN	220	HV1	KEMAR_220	12:05	14:34	2:29	LINE CLEAR AVAILED
84	30/Oct/19	HASSAN	220	HV3	KEMAR_220	12:25	14:16	1:51	LINE CLEAR AVAILED
85	30/Oct/19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:48	11:05	0:17	HAND TRIPPED
86	30/Oct/19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:20	13:11	2:51	LINE CLEAR AVAILED
87	30/Oct/19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:47	11:05	0:18	LINE CLEAR AVAILED
88	30/Oct/19	HASSAN	110	LV1	KEMAR_220	12:05	14:34	2:29	LINE CLEAR AVAILED
89	30/Oct/19	HASSAN	110	LV3	KEMAR_220	12:25	14:16	1:51	LINE CLEAR AVAILED
90	30/Oct/19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	18:11	18:18	0:07	HAND TRIPPED
91	30/Oct/19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	18:11	18:18	0:07	HAND TRIPPED
92	30/Oct/19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:58	14:35	2:37	LINE CLEAR AVAILED
93	30/Oct/19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	18:02	18:11	0:09	HAND TRIPPED
94	30/Oct/19	HASSAN	110	KADUR-YGTI	KADUR_220	1:05	1:30	0:25	LINE FAULT
95	30/Oct/19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	18:12	18:23	0:11	MAIN SUPPLY FAILURE
96	30/Oct/19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	18:13	18:19	0:06	MAIN SUPPLY FAILURE
97	30/Oct/19	HASSAN	66	HV1	HOLALUR_66	11:28	11:59	0:31	LINE CLEAR AVAILED
98	30/Oct/19	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:03	11:29	0:26	HAND TRIPPED
99	30/Oct/19	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:55	11:53	0:58	LINE CLEAR AVAILED
100	30/Oct/19	MYSORE	66	KADKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	16:39	16:44	0:05	LINE FAULT
101	30/Oct/19	MYSORE	66	HV2	JAKKANAHALLY_66	16:33	18:05	1:31	TRANSFORMER FAULT
102	30/Oct/19	MYSORE	66	HV2	KRPET_66	16:27	16:38	0:10	HAND TRIPPED
103	30/Oct/19	MYSORE	66	HV1	SUNTIKOPPA_66	14:05	16:21	2:16	LINE CLEAR AVAILED
104	30/Oct/19	MYSORE	66	HV1	THALAKADU_66	5:45	5:53	0:07	MAIN SUPPLY FAILURE
105	30/Oct/19	MYSORE	66	HV2	THALAKADU_66	5:45	5:53	0:07	MAIN SUPPLY FAILURE
106	30/Oct/19	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	16:29	16:38	0:09	LINE FAULT
107	30/Oct/19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	17:28	17:30	0:01	LINE CLEAR AVAILED
108	30/Oct/19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:33	16:46	0:13	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
109	30/Oct/19	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	16:33	16:55	0:22	TRANSFORMER FAULT
110	30/Oct/19	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	15:01	16:05	1:04	LINE CLEAR AVAILED
111	30/Oct/19	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	16:17	17:43	1:26	LINE CLEAR AVAILED
112	30/Oct/19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	19:16	19:54	0:38	LINE FAULT
113	30/Oct/19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	20:00	20:58	0:58	LINE FAULT
114	30/Oct/19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	19:16	19:58	0:41	LINE FAULT
115	30/Oct/19	TUMKUR	66	TR-1	CHITRADURGA_66	13:49	14:36	0:46	LINE CLEAR AVAILED
116	30/Oct/19	TUMKUR	66	TR-1	CHITRADURGA_66	19:04	19:20	0:16	LINE CLEAR AVAILED
117	30/Oct/19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:30	15:39	0:09	LINE FAULT
118	30/Oct/19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:40	16:44	0:04	HAND TRIPPED
119	31-Oct-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	10:34	12:20	1:46	LINE FAULT
120	31-Oct-19	BAGALKOT	220	ADPH1&2-BAGEWADI	BAGEWADI_220	10:32	10:34	0:02	HAND TRIPPED
121	31-Oct-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	9:33	19:22	9:49	LINE CLEAR AVAILED
122	31-Oct-19	BAGALKOT	110	110/33KV,HV2	HUBLI_220	10:25	12:07	1:42	LINE CLEAR AVAILED
123	31-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	23:33	23:59	0:26	LINE CLEAR AVAILED
124	31-Oct-19	BAGALKOT	220	GUTTUR -RANEENNUR	RANEENNUR_220	0:50	13:11	12:21	LINE FAULT
125	31-Oct-19	BAGALKOT	220	BALLIGAVI-RANEENNUR	RANEENNUR_220	13:15	23:59	10:44	LINE CLEAR AVAILED
126	31-Oct-19	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	11:48	13:23	1:35	LINE FAULT
127	31-Oct-19	BAGALKOT	110	110/11KV,HV3	SAVALGI_110	10:29	12:55	2:26	LINE CLEAR AVAILED
128	31-Oct-19	BAGALKOT	110	110/11KV,HV2	SAVALGI_110	13:45	13:50	0:05	LINE CLEAR AVAILED
129	31-Oct-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	12:30	13:20	0:50	LINE CLEAR AVAILED
130	31-Oct-19	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	10:45	10:50	0:05	LOAD CHANGEOVER
131	31-Oct-19	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	14:10	14:15	0:05	LOAD CHANGEOVER
132	31-Oct-19	BENGALURU	66	HV3	ADUGODI	11:58	12:16	0:18	MAIN SUPPLY FAILURE
133	31-Oct-19	BENGALURU	66	HV3	ADUGODI	15:50	16:02	0:12	LOAD CHANGEOVER
134	31-Oct-19	BENGALURU	66	HV2	TELECOM LAYOUT	13:19	16:00	2:40	LINE CLEAR AVAILED
135	31-Oct-19	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:05	12:14	12:09	LINE CLEAR AVAILED
136	31-Oct-19	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110	4:15	4:20	0:05	LINE FAULT
137	31-Oct-19	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110	6:15	6:20	0:05	LINE FAULT
138	31-Oct-19	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	6:05	6:15	0:10	LINE FAULT
139	31-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:35	7:35	LINE CLEAR AVAILED
140	31-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:40	23:59	2:19	LINE CLEAR AVAILED
141	31-Oct-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	8:45	8:45	LOAD CURTAILMENT
142	31-Oct-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	0:00	8:42	8:42	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
143	31-Oct-19	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	9:30	15:25	5:55	LINE CLEAR AVAILED
144	31-Oct-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:07	15:11	0:04	HAND TRIPPED
145	31-Oct-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	15:08	15:10	0:02	HAND TRIPPED
146	31-Oct-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	15:07	15:11	0:04	HAND TRIPPED
147	31-Oct-19	HASSAN	110	HV1	CHANDRAGUTTI_110	15:00	15:51	0:51	LINE CLEAR AVAILED
148	31-Oct-19	HASSAN	110	HV1	CHANDRAGUTTI_110	15:57	16:10	0:13	LINE CLEAR AVAILED
149	31-Oct-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	12:57	13:35	0:38	LINE FAULT
150	31-Oct-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:34	15:48	0:14	LINE FAULT
151	31-Oct-19	HASSAN	66	HV1	DUDDA_66	12:10	13:55	1:45	LINE CLEAR AVAILED
152	31-Oct-19	HASSAN	66	HV1	SAKLESH PURA_66	8:16	8:53	0:37	TRANSFORMER FAULT
153	31-Oct-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	7:55	23:59	16:04	LINE CLEAR AVAILED
154	31-Oct-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	16:54	17:01	0:07	LINE FAULT
155	31-Oct-19	TUMKUR	110	TR-1	KBCROSS_220	19:49	20:00	0:10	TRANSFORMER FAULT
156	31-Oct-19	TUMKUR	110	TR-1	SAMPIGE_110	12:47	13:06	0:18	LINE CLEAR AVAILED
157	31-Oct-19	TUMKUR	110	TR-1	SAMPIGE_110	14:18	14:28	0:09	LINE CLEAR AVAILED
158	31-Oct-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	9:05	17:17	8:11	MAIN SUPPLY FAILURE
159	31-Oct-19	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:24	11:40	1:16	MAIN SUPPLY FAILURE
160	31-Oct-19	TUMKUR	66	TR-1	DEVARAHALLI_66	10:24	11:40	1:16	MAIN SUPPLY FAILURE
161	31-Oct-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:31	15:48	0:16	HAND TRIPPED
162	31-Oct-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:08	16:27	5:18	LINE CLEAR AVAILED
163	31-Oct-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	15:32	15:47	0:15	HAND TRIPPED
164	31-Oct-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	12:23	15:48	3:25	LINE CLEAR AVAILED
165	31-Oct-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:31	15:48	0:17	HAND TRIPPED
166	31-Oct-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:33	13:35	0:01	HAND TRIPPED
167	31-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:03	15:28	2:25	LINE CLEAR AVAILED
168	31-Oct-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	13:21	14:51	1:29	LINE CLEAR AVAILED
169	31-Oct-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	13:21	14:51	1:29	LINE CLEAR AVAILED
170	31-Oct-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPUR	RANGANATHAPURA_66	13:03	15:04	2:00	LINE CLEAR AVAILED
171	31-Oct-19	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	14:42	15:32	0:50	HAND TRIPPED
172	31-Oct-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:14	10:51	0:36	LINE CLEAR AVAILED
173	31-Oct-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:19	16:38	0:18	LINE CLEAR AVAILED
174	31-Oct-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	10:14	10:52	0:37	LINE CLEAR AVAILED
175	31-Oct-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	16:19	16:38	0:19	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
176	31-Oct-19	TUMKUR	66	TR-2	HONNUDIKE_66	14:32	17:30	2:58	LINE CLEAR AVAILED
177	31-Oct-19	TUMKUR	66	HOSADURRG-MATHOD	HOSADURGA_66	11:15	16:23	5:07	LINE CLEAR AVAILED
178	31-Oct-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:10	11:29	1:19	LINE CLEAR AVAILED
179	31-Oct-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:31	16:34	0:02	LINE CLEAR AVAILED
180	31-Oct-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	11:29	16:31	5:01	LINE CLEAR AVAILED
181	31-Oct-19	TUMKUR	66	TR-1	KUNDUR_66	14:44	15:54	1:09	LINE CLEAR AVAILED
182	31-Oct-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	11:47	15:54	4:07	LINE CLEAR AVAILED
183	31-Oct-19	TUMKUR	66	TR-1	PANDARAHALLI_66	11:45	15:57	4:12	LINE CLEAR AVAILED
184	31-Oct-19	TUMKUR	66	PANDARAHALLI- SPML _WIND _IPP_66	SPML _WIND _IPP_66	11:47	16:06	4:19	LINE CLEAR AVAILED
185	31-Oct-19	TUMKUR	66	TR-1	PAVAGADA_66	8:47	9:01	0:14	TRANSFORMER FAULT
186	1-Nov-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	22:01	23:59	1:58	LINE CLEAR AVAILED
187	1-Nov-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMINGAD_33,SOLAR IPP_33	1:05	1:10	0:05	TRANSFORMER FAULT
188	1-Nov-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMINGAD_33,SOLAR IPP_33	16:45	16:51	0:06	TRANSFORMER FAULT
189	1-Nov-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	11:47	15:23	3:36	LINE CLEAR AVAILED
190	1-Nov-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	16:19	17:08	0:49	LINE CLEAR AVAILED
191	1-Nov-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	17:17	20:50	3:33	LINE CLEAR AVAILED
192	1-Nov-19	BAGALKOT	220	MAHALINGAPUR-RABKAVI	RABKAVI_110	22:04	22:12	0:08	HAND TRIPPED
193	1-Nov-19	BAGALKOT	110	110/33KV,HV1	HUBLI_220	10:18	12:25	2:07	LINE CLEAR AVAILED
194	1-Nov-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:00	6:56	6:56	LINE CLEAR AVAILED
195	1-Nov-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	23:28	23:59	0:31	LINE CLEAR AVAILED
196	1-Nov-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA, ABBIGERE	8:25	8:54	0:29	LINE FAULT
197	1-Nov-19	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	11:54	12:12	0:18	LOAD CHANGEOVER
198	1-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	19:07	19:23	0:15	LINE FAULT
199	1-Nov-19	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	8:56	12:41	3:45	LOAD CHANGEOVER
200	1-Nov-19	BENGALURU	220	HV2	HAL 220	13:25	15:30	2:05	TRANSFORMER FAULT
201	1-Nov-19	BENGALURU	66	HV1	KHODAYS 220	20:33	20:41	0:08	LINE CLEAR AVAILED
202	1-Nov-19	GULBARGA	220	HV2	LINGASUGUR_220	19:22	19:47	0:25	TRANSFORMER FAULT
203	1-Nov-19	GULBARGA	220	HV2	RAICHUR_220	11:01	11:24	0:23	LINE CLEAR AVAILED
204	1-Nov-19	GULBARGA	220	HV1	RAICHUR_220	11:36	12:01	0:25	LINE CLEAR AVAILED
205	1-Nov-19	GULBARGA	220	HV1	KUSTAGI_220	12:11	12:28	0:17	TRANSFORMER FAULT
206	1-Nov-19	GULBARGA	110	LINGASUGUR-KAREPOWER_ IPP	LINGASUGUR_220	19:22	19:50	0:28	LINE FAULT
207	1-Nov-19	GULBARGA	110	HV2	RAICHUR_220	1:41	2:20	0:39	TRANSFORMER FAULT
208	1-Nov-19	GULBARGA	110	HV1	RAICHUR_220	11:21	13:22	2:01	LINE CLEAR AVAILED
209	1-Nov-19	GULBARGA	110	HV3	BEVOORG_110	17:36	17:51	0:15	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
210	1-Nov-19	GULBARGA	110	HV3	HAGARIBOMMANAHALLI_66	11:30	11:35	0:05	TRANSFORMER FAULT
211	1-Nov-19	GULBARGA	110	RAJESHWAR-WARDHA	RAJESHWAR_110	17:58	23:05	5:07	LINE CLEAR AVAILED
212	1-Nov-19	GULBARGA	66	ITTAGI-CLEANMAX2_IPP	ITTAGI_220	13:36	13:40	0:04	LINE CLEAR AVAILED
213	1-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:44	7:44	LINE CLEAR AVAILED
214	1-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	13:09	23:59	10:50	LINE CLEAR AVAILED
215	1-Nov-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	0:00	11:07	11:07	LINE FAULT
216	1-Nov-19	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	10:05	15:27	5:22	LINE CLEAR AVAILED
217	1-Nov-19	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_110	0:00	9:49	9:49	LOAD CURTAILMENT
218	1-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	11:34	15:43	4:09	LOAD CURTAILMENT
219	1-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	16:07	16:19	0:12	LOAD CURTAILMENT
220	1-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	19:20	19:30	0:10	LOAD CURTAILMENT
221	1-Nov-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	18:30	18:39	0:09	LINE FAULT
222	1-Nov-19	MYSORE	220	HV1	CRNAGAR_220	14:47	15:07	0:20	HAND TRIPPED
223	1-Nov-19	MYSORE	66	HV1	DODDINADUVADI_66	10:48	11:27	0:38	LINE CLEAR AVAILED
224	1-Nov-19	MYSORE	66	MADHUVANAHALLI -PG PALYA	PGPALYA_66	7:00	7:06	0:06	LINE FAULT
225	1-Nov-19	MYSORE	66	MADHUVANAHALLI -MAMBALLI	MAMBALLI_66	9:13	9:17	0:04	LINE FAULT
226	1-Nov-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	1:03	1:25	0:22	LINE FAULT
227	2-Nov-19	BAGALKOT	110	ATHANI-ATHANI SUGARS	ATHANI_110	2:25	2:40	0:15	LINE FAULT
228	2-Nov-19	BAGALKOT	110	110/11KV,HV 2	ANANDNAGAR_110	15:19	15:27	0:08	TRANSFORMER FAULT
229	2-Nov-19	BAGALKOT	110	ATHANI-SATTI	SATTI_110	0:00	10:49	10:49	LINE CLEAR AVAILED
230	2-Nov-19	BAGALKOT	110	BHUTANAL-TIKOTA	TIKOTA_110	23:44	23:56	0:12	LINE FAULT
231	2-Nov-19	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY	KIADB BIJAPUR_110	9:50	10:33	0:43	LINE FAULT
232	2-Nov-19	BAGALKOT	110	110/11KV,HV 3	HIDIKAL_110	18:00	18:11	0:11	MAIN SUPPLY FAILURE
233	2-Nov-19	BAGALKOT	110	110/33KV,HV 2	HUNAGUND_110,AMINGAD, KARADI_33KV	15:24	15:28	0:04	TRANSFORMER FAULT
234	2-Nov-19	BAGALKOT	220	GMNAVAR1 (BAGEWADI1) -BIJAPUR	BIJAPUR_220	0:00	9:10	9:10	LINE CLEAR AVAILED
235	2-Nov-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	0:00	15:34	15:34	LINE CLEAR AVAILED
236	2-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	19:16	23:59	4:43	LINE CLEAR AVAILED
237	2-Nov-19	BAGALKOT	220	BELGAUM -CHIKKODI 2	BELGAUM_220	19:18	23:59	4:41	LINE CLEAR AVAILED
238	2-Nov-19	BAGALKOT	110	VAJRAMATTI-BILAGI	BILAGI_110	14:45	17:31	2:46	NFBC ISSUED
239	2-Nov-19	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	9:28	17:10	7:42	LINE CLEAR AVAILED
240	2-Nov-19	BAGALKOT	110	RANEBENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	11:31	12:22	0:51	LINE CLEAR AVAILED
241	2-Nov-19	BAGALKOT	110	RANEBENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	17:22	18:20	0:58	LINE CLEAR AVAILED
242	2-Nov-19	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	12:10	23:59	11:49	LINE CLEAR AVAILED
243	2-Nov-19	BAGALKOT	110	110/11KV, HV1	NANADI_110	7:23	7:48	0:25	TRANSFORMER FAULT
244	2-Nov-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_110	0:00	6:46	6:46	LINE CLEAR AVAILED
245	2-Nov-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_110	0:00	10:07	10:07	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
246	2-Nov-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_110	19:13	23:59	4:46	LINE CLEAR AVAILED
247	2-Nov-19	BAGALKOT	220	KUDACHI-CHIKKODI	KUDACHI_220	2:25	2:49	0:24	LINE FAULT
248	2-Nov-19	BAGALKOT	110	110/33KV, HV3	MAMDAPUR_110, DEVARGENNUR_33, LINGADALLI_33	7:48	7:54	0:06	TRANSFORMER FAULT
249	2-Nov-19	BAGALKOT	110	ATHANI-ATHANI SUGARS	ATHANI_110	2:25	2:40	0:15	LINE FAULT
250	2-Nov-19	BAGALKOT	110	110/11KV,HV 2	ANANDNAGAR_110	15:19	15:27	0:08	TRANSFORMER FAULT
251	2-Nov-19	BAGALKOT	110	ATHANI-SATTI	SATTI_110	0:00	10:49	10:49	LINE CLEAR AVAILED
252	2-Nov-19	BAGALKOT	110	BHUTANAL-TIKOTA	TIKOTA_110	23:44	23:56	0:12	LINE FAULT
253	2-Nov-19	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY	KIADB BIJAPUR_110	9:50	10:33	0:43	LINE FAULT
254	2-Nov-19	BAGALKOT	110	110/11KV,HV 3	HIDIKAL_110	18:00	18:11	0:11	MAIN SUPPLY FAILURE
255	2-Nov-19	BAGALKOT	110	110/33KV,HV 2	HUNAGUND_110,AMINGAD, KARADI_33KV	15:24	15:28	0:04	TRANSFORMER FAULT
256	2-Nov-19	BAGALKOT	220	GMNAVAR1 (BAGEWADI1) -BIJAPUR	BIJAPUR_220	0:00	9:10	9:10	LINE CLEAR AVAILED
257	2-Nov-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	0:00	15:34	15:34	LINE CLEAR AVAILED
258	2-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	19:16	23:59	4:43	LINE CLEAR AVAILED
259	2-Nov-19	BAGALKOT	220	BELGAUM -CHIKKODI 2	BELGAUM_220	19:18	23:59	4:41	LINE CLEAR AVAILED
260	2-Nov-19	BAGALKOT	110	VAJRAMATTI-BILAGI	BILAGI_110	14:45	17:31	2:46	NFBC ISSUED
261	2-Nov-19	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	9:28	17:10	7:42	LINE CLEAR AVAILED
262	2-Nov-19	BAGALKOT	110	RANEBENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	11:31	12:22	0:51	LINE CLEAR AVAILED
263	2-Nov-19	BAGALKOT	110	RANEBENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	17:22	18:20	0:58	LINE CLEAR AVAILED
264	2-Nov-19	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	12:10	23:59	11:49	LINE CLEAR AVAILED
265	2-Nov-19	BAGALKOT	110	110/11KV, HV1	NANADI_110	7:23	7:48	0:25	TRANSFORMER FAULT
266	2-Nov-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_110	0:00	6:46	6:46	LINE CLEAR AVAILED
267	2-Nov-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_110	0:00	10:07	10:07	LINE CLEAR AVAILED
268	2-Nov-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_110	19:13	23:59	4:46	LINE CLEAR AVAILED
269	2-Nov-19	BAGALKOT	220	KUDACHI-CHIKKODI	KUDACHI_220	2:25	2:49	0:24	LINE FAULT
270	2-Nov-19	BAGALKOT	110	110/33KV, HV3	MAMDAPUR_110, DEVARGENNUR_33, LINGADALLI_33	7:48	7:54	0:06	TRANSFORMER FAULT
271	2-Nov-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:50	20:35	1:45	LOAD CURTAILMENT
272	2-Nov-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	18:55	19:40	0:45	LOAD CURTAILMENT
273	2-Nov-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	20:00	21:07	1:07	LOAD CURTAILMENT
274	2-Nov-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:10	21:05	0:55	LOAD CURTAILMENT
275	2-Nov-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	20:30	21:00	0:30	LOAD CURTAILMENT
276	2-Nov-19	BENGALURU	66	HV2	NALLIMARADANAHALLI	18:00	18:17	0:17	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
277	2-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:41	18:56	0:15	MAIN SUPPLY FAILURE
278	2-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:41	18:56	0:15	MAIN SUPPLY FAILURE
279	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	19:02	19:30	0:28	MAIN SUPPLY FAILURE
280	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	12:21	12:25	0:04	LOAD CHANGEOVER
281	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	12:21	12:25	0:04	LOAD CHANGEOVER
282	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	14:44	14:52	0:08	LOAD CHANGEOVER
283	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	14:44	14:52	0:08	LOAD CHANGEOVER
284	2-Nov-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA,SANKALGERE, BEVOOR	13:05	16:11	3:06	LINE CLEAR AVAILED
285	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:27	19:01	0:33	LOAD CURTAILMENT
286	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	18:28	19:01	0:32	LOAD CURTAILMENT
287	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:31	20:05	0:33	LOAD CURTAILMENT
288	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	19:02	19:32	0:30	LOAD CURTAILMENT
289	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	21:33	21:39	0:06	LOAD CHANGEOVER
290	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:27	22:34	0:07	LINE FAULT
291	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:34	22:51	0:17	LINE FAULT
292	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:45	16:47	0:02	LOAD CHANGEOVER
293	2-Nov-19	BENGALURU	66	HV1	DODDABELAVANGALA	11:40	12:02	0:21	LINE CLEAR AVAILED
294	2-Nov-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:50	20:35	1:45	LOAD CURTAILMENT
295	2-Nov-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	18:55	19:40	0:45	LOAD CURTAILMENT
296	2-Nov-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	20:00	21:07	1:07	LOAD CURTAILMENT
297	2-Nov-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:10	21:05	0:55	LOAD CURTAILMENT
298	2-Nov-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	20:30	21:00	0:30	LOAD CURTAILMENT
299	2-Nov-19	BENGALURU	66	HV2	NALLIMARADANAHALLI	18:00	18:17	0:17	LOAD CURTAILMENT
300	2-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:41	18:56	0:15	MAIN SUPPLY FAILURE
301	2-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:41	18:56	0:15	MAIN SUPPLY FAILURE
302	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	19:02	19:30	0:28	MAIN SUPPLY FAILURE
303	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	12:21	12:25	0:04	LOAD CHANGEOVER
304	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	12:21	12:25	0:04	LOAD CHANGEOVER
305	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	14:44	14:52	0:08	LOAD CHANGEOVER
306	2-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	14:44	14:52	0:08	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
307	2-Nov-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA,SANKALGERE, BEVOOR	13:05	16:11	3:06	LINE CLEAR AVAILED
308	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:27	19:01	0:33	LOAD CURTAILMENT
309	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	18:28	19:01	0:32	LOAD CURTAILMENT
310	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:31	20:05	0:33	LOAD CURTAILMENT
311	2-Nov-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	19:02	19:32	0:30	LOAD CURTAILMENT
312	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	21:33	21:39	0:06	LOAD CHANGEOVER
313	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:27	22:34	0:07	LINE FAULT
314	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:34	22:51	0:17	LINE FAULT
315	2-Nov-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:45	16:47	0:02	LOAD CHANGEOVER
316	2-Nov-19	BENGALURU	66	HV1	DODDABELAVANGALA	11:40	12:02	0:21	LINE CLEAR AVAILED
317	2-Nov-19	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDHANOOR_220	9:19	10:05	0:46	LINE FAULT
318	2-Nov-19	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_220	5:52	6:03	0:11	LINE FAULT
319	2-Nov-19	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_220	6:07	6:21	0:14	LINE FAULT
320	2-Nov-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	9:20	9:29	0:09	LINE FAULT
321	2-Nov-19	GULBARGA	220	HV2	ITTAGI_220	15:15	16:15	1:00	LINE CLEAR AVAILED
322	2-Nov-19	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNAD_220	11:00	19:31	8:31	LINE CLEAR AVAILED
323	2-Nov-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	9:14	10:19	1:05	LINE FAULT
324	2-Nov-19	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	11:45	11:52	0:07	LINE FAULT
325	2-Nov-19	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110	18:36	18:50	0:14	LINE CLEAR AVAILED
326	2-Nov-19	GULBARGA	110	HV2	KAVITAL_110	7:45	7:55	0:10	TRANSFORMER FAULT
327	2-Nov-19	GULBARGA	110	HV2	PDHALLI_110	17:58	18:08	0:10	LOAD CURTAILMENT
328	2-Nov-19	GULBARGA	110	HV1	PDHALLI_110	18:10	18:14	0:04	LOAD CURTAILMENT
329	2-Nov-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110	16:15	16:20	0:05	LINE FAULT
330	2-Nov-19	GULBARGA	110	HV1	SHORAPUR_110	14:32	14:47	0:15	TRANSFORMER FAULT
331	2-Nov-19	GULBARGA	110	HV1	SIRWAR_110	17:55	18:05	0:10	TRANSFORMER FAULT
332	2-Nov-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	18:20	19:10	0:50	LOAD CURTAILMENT
333	2-Nov-19	GULBARGA	110	RAIHCUR-SHAHAPUR1	SHAHPUR_110	18:34	19:18	0:44	LOAD CURTAILMENT
334	2-Nov-19	GULBARGA	110	RAIHCUR-MATAMARI	MATAMARI_110	18:34	20:14	1:40	LOAD CURTAILMENT
335	2-Nov-19	GULBARGA	66	LV2	ITTAGI_220	13:22	16:15	2:53	TRANSFORMER FAULT
336	2-Nov-19	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDHANOOR_220	9:19	10:05	0:46	LINE FAULT
337	2-Nov-19	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_220	5:52	6:03	0:11	LINE FAULT
338	2-Nov-19	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_220	6:07	6:21	0:14	LINE FAULT
339	2-Nov-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	9:20	9:29	0:09	LINE FAULT
340	2-Nov-19	GULBARGA	220	HV2	ITTAGI_220	15:15	16:15	1:00	LINE CLEAR AVAILED
341	2-Nov-19	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNAD_220	11:00	19:31	8:31	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
342	2-Nov-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	9:14	10:19	1:05	LINE FAULT
343	2-Nov-19	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	11:45	11:52	0:07	LINE FAULT
344	2-Nov-19	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110	18:36	18:50	0:14	LINE CLEAR AVAILED
345	2-Nov-19	GULBARGA	110	HV2	KAVITAL_110	7:45	7:55	0:10	TRANSFORMER FAULT
346	2-Nov-19	GULBARGA	110	HV2	PDHALLI_110	17:58	18:08	0:10	LOAD CURTAILMENT
347	2-Nov-19	GULBARGA	110	HV1	PDHALLI_110	18:10	18:14	0:04	LOAD CURTAILMENT
348	2-Nov-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110	16:15	16:20	0:05	LINE FAULT
349	2-Nov-19	GULBARGA	110	HV1	SHORAPUR_110	14:32	14:47	0:15	TRANSFORMER FAULT
350	2-Nov-19	GULBARGA	110	HV1	SIRWAR_110	17:55	18:05	0:10	TRANSFORMER FAULT
351	2-Nov-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	18:20	19:10	0:50	LOAD CURTAILMENT
352	2-Nov-19	GULBARGA	110	RAIHCUR-SHAHAPUR1	SHAHPUR_110	18:34	19:18	0:44	LOAD CURTAILMENT
353	2-Nov-19	GULBARGA	110	RAIHCUR-MATAMARI	MATAMARI_110	18:34	20:14	1:40	LOAD CURTAILMENT
354	2-Nov-19	GULBARGA	66	LV2	ITTAGI_220	13:22	16:15	2:53	TRANSFORMER FAULT
355	2-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:54	7:54	LINE CLEAR AVAILED
356	2-Nov-19	HASSAN	220	KADUR-DABUSET	KADUR_220	17:32	22:25	4:53	LINE CLEAR AVAILED
357	2-Nov-19	HASSAN	220	HV1	KEMAR_220	11:53	18:36	6:43	LINE CLEAR AVAILED
358	2-Nov-19	HASSAN	110	HV1	KEMAR_220	11:20	11:23	0:03	HAND TRIPPED
359	2-Nov-19	HASSAN	110	LV1	KEMAR_220	11:51	18:36	6:45	LINE CLEAR AVAILED
360	2-Nov-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:48	18:50	7:02	LINE CLEAR AVAILED
361	2-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	22:46	23:59	1:13	LINE CLEAR AVAILED
362	2-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	22:45	23:59	1:14	LINE CLEAR AVAILED
363	2-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	22:46	23:59	1:13	LINE CLEAR AVAILED
364	2-Nov-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	10:08	17:26	7:18	LINE CLEAR AVAILED
365	2-Nov-19	HASSAN	110	HV1	DMKURKE_110	17:57	18:40	0:43	MAIN SUPPLY FAILURE
366	2-Nov-19	HASSAN	110	HV2	GANDASI_110	18:09	18:16	0:07	MAIN SUPPLY FAILURE
367	2-Nov-19	HASSAN	110	HV2	GERUMARA_110	17:57	18:14	0:17	MAIN SUPPLY FAILURE
368	2-Nov-19	HASSAN	110	HV2	KONDENALU_110	15:34	23:59	8:25	TRANSFORMER FAULT
369	2-Nov-19	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	11:49	18:51	7:02	NFBC ISSUED
370	2-Nov-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	18:32	19:13	0:41	MAIN SUPPLY FAILURE
371	2-Nov-19	HASSAN	110	HV1	BRAHMAVARA_110	17:58	18:14	0:16	MAIN SUPPLY FAILURE
372	2-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	9:20	10:52	1:32	MAIN SUPPLY FAILURE
373	2-Nov-19	HASSAN	66	HV1	HANGARANAHALLY_66	17:58	18:07	0:09	MAIN SUPPLY FAILURE
374	2-Nov-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:38	19:29	0:51	LINE CLEAR AVAILED
375	2-Nov-19	HASSAN	66	HV2	SINGAPURA_66	18:09	18:31	0:22	HAND TRIPPED
376	2-Nov-19	HASSAN	66	HV2	BASAVAGHATTA_66	17:56	18:08	0:12	MAIN SUPPLY FAILURE
377	2-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:54	7:54	LINE CLEAR AVAILED
378	2-Nov-19	HASSAN	220	KADUR-DABUSET	KADUR_220	17:32	22:25	4:53	LINE CLEAR AVAILED
379	2-Nov-19	HASSAN	220	HV1	KEMAR_220	11:53	18:36	6:43	LINE CLEAR AVAILED
380	2-Nov-19	HASSAN	110	HV1	KEMAR_220	11:20	11:23	0:03	HAND TRIPPED
381	2-Nov-19	HASSAN	110	LV1	KEMAR_220	11:51	18:36	6:45	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
382	2-Nov-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:48	18:50	7:02	LINE CLEAR AVAILED
383	2-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	22:46	23:59	1:13	LINE CLEAR AVAILED
384	2-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	22:45	23:59	1:14	LINE CLEAR AVAILED
385	2-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	22:46	23:59	1:13	LINE CLEAR AVAILED
386	2-Nov-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	10:08	17:26	7:18	LINE CLEAR AVAILED
387	2-Nov-19	HASSAN	110	HV1	DMKURKE_110	17:57	18:40	0:43	MAIN SUPPLY FAILURE
388	2-Nov-19	HASSAN	110	HV2	GANDASI_110	18:09	18:16	0:07	MAIN SUPPLY FAILURE
389	2-Nov-19	HASSAN	110	HV2	GERUMARA_110	17:57	18:14	0:17	MAIN SUPPLY FAILURE
390	2-Nov-19	HASSAN	110	HV2	KONDENALU_110	15:34	23:59	8:25	TRANSFORMER FAULT
391	2-Nov-19	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	11:49	18:51	7:02	NFBC ISSUED
392	2-Nov-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	18:32	19:13	0:41	MAIN SUPPLY FAILURE
393	2-Nov-19	HASSAN	110	HV1	BRAHMAVARA_110	17:58	18:14	0:16	MAIN SUPPLY FAILURE
394	2-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	9:20	10:52	1:32	MAIN SUPPLY FAILURE
395	2-Nov-19	HASSAN	66	HV1	HANGARANAHALLY_66	17:58	18:07	0:09	MAIN SUPPLY FAILURE
396	2-Nov-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:38	19:29	0:51	LINE CLEAR AVAILED
397	2-Nov-19	HASSAN	66	HV2	SINGAPURA_66	18:09	18:31	0:22	HAND TRIPPED
398	2-Nov-19	HASSAN	66	HV2	BASAVAGHATTA_66	17:56	18:08	0:12	MAIN SUPPLY FAILURE
399	2-Nov-19	MYSORE	66	HV2	BOOKANAKERE_66	18:09	18:19	0:10	LOAD CURTAILMENT
400	2-Nov-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	CHINAKURALI_66, BANANGADI_66 , DODDABYADARAHALLI_66, PANDAVAPURA_66	12:36	12:44	0:07	LINE FAULT
401	2-Nov-19	MYSORE	66	HV2	CHINAKURALI_66	18:09	18:25	0:16	LOAD CURTAILMENT
402	2-Nov-19	MYSORE	66	CR NAGARA-KABBALI	HARVEY_66	14:00	14:06	0:05	LINE FAULT
403	2-Nov-19	MYSORE	66	HV1	DODDINADUVADI_66	17:58	18:14	0:16	LOAD CURTAILMENT
404	2-Nov-19	MYSORE	66	DODDINADUVADI-KOTHANUR	KOTTANUR_66	6:10	6:25	0:15	LINE FAULT
405	2-Nov-19	MYSORE	66	HV2	DODDARAYAPET_66	18:00	18:30	0:30	LOAD CURTAILMENT
406	2-Nov-19	MYSORE	66	HV2	GVGUDI_66	17:57	18:01	0:04	LOAD CURTAILMENT
407	2-Nov-19	MYSORE	66	HV1	HANAGODU_66	18:09	18:22	0:12	LOAD CURTAILMENT
408	2-Nov-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	6:10	6:20	0:10	LINE FAULT
409	2-Nov-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	6:20	6:25	0:04	HAND TRIPPED
410	2-Nov-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	12:35	12:51	0:15	LINE FAULT
411	2-Nov-19	MYSORE	66	HANNUR-MADHUVANAHALLI 2	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	12:35	12:51	0:16	LINE FAULT
412	2-Nov-19	MYSORE	66	HV2	HANNUR_66	18:10	18:25	0:15	LOAD CURTAILMENT
413	2-Nov-19	MYSORE	66	HV2	JAIPUR_66	17:58	18:05	0:07	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
414	2-Nov-19	MYSORE	66	KADAKOLA-NANJANAGUDU 1	NANJANGUDU_66	22:56	23:59	1:02	LINE FAULT
415	2-Nov-19	MYSORE	66	KADAKOLA-NANJANAGUDU 2	THANDYA_66	22:56	23:11	0:14	LINE FAULT
416	2-Nov-19	MYSORE	66	HV2	KMDODDI_66	17:57	18:25	0:27	LOAD CURTAILMENT
417	2-Nov-19	MYSORE	66	HV2	KOLLEGALA_66	18:09	18:20	0:11	LOAD CURTAILMENT
418	2-Nov-19	MYSORE	66	HV1	KUSHALANAGARA_66	17:56	18:16	0:19	LOAD CURTAILMENT
419	2-Nov-19	MYSORE	66	MADHUVANAHALLI -HANNUR 2	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	6:07	6:18	0:11	LINE FAULT
420	2-Nov-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	9:39	11:33	1:53	NFBC ISSUED
421	2-Nov-19	MYSORE	66	HV1	SATHEGALA_66	18:09	18:14	0:04	LOAD CURTAILMENT
422	2-Nov-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:09	18:46	0:37	LOAD CURTAILMENT
423	2-Nov-19	MYSORE	66	HV1	VIRAJPET_66	14:37	15:03	0:25	MAIN SUPPLY FAILURE
424	2-Nov-19	MYSORE	66	HV2	VIRAJPET_66	14:37	15:03	0:26	MAIN SUPPLY FAILURE
425	2-Nov-19	MYSORE	66	HV2	BOOKANAKERE_66	18:09	18:19	0:10	LOAD CURTAILMENT
426	2-Nov-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	CHINAKURALI_66, BANANGADI_66 , DODDABYADARAHALLI_66, PANDAVAPURA_66	12:36	12:44	0:07	LINE FAULT
427	2-Nov-19	MYSORE	66	HV2	CHINAKURALI_66	18:09	18:25	0:16	LOAD CURTAILMENT
428	2-Nov-19	MYSORE	66	CR NAGARA-KABBALI	HARVEY_66	14:00	14:06	0:05	LINE FAULT
429	2-Nov-19	MYSORE	66	HV1	DODDINADUVADI_66	17:58	18:14	0:16	LOAD CURTAILMENT
430	2-Nov-19	MYSORE	66	DODDINADUVADI-KOTHANUR	KOTTANUR_66	6:10	6:25	0:15	LINE FAULT
431	2-Nov-19	MYSORE	66	HV2	DODDARAYAPET_66	18:00	18:30	0:30	LOAD CURTAILMENT
432	2-Nov-19	MYSORE	66	HV2	GVGUDI_66	17:57	18:01	0:04	LOAD CURTAILMENT
433	2-Nov-19	MYSORE	66	HV1	HANAGODU_66	18:09	18:22	0:12	LOAD CURTAILMENT
434	2-Nov-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	6:10	6:20	0:10	LINE FAULT
435	2-Nov-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	6:20	6:25	0:04	HAND TRIPPED
436	2-Nov-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	12:35	12:51	0:15	LINE FAULT
437	2-Nov-19	MYSORE	66	HANNUR-MADHUVANAHALLI 2	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	12:35	12:51	0:16	LINE FAULT
438	2-Nov-19	MYSORE	66	HV2	HANNUR_66	18:10	18:25	0:15	LOAD CURTAILMENT
439	2-Nov-19	MYSORE	66	HV2	JAIPUR_66	17:58	18:05	0:07	LOAD CURTAILMENT
440	2-Nov-19	MYSORE	66	KADAKOLA-NANJANAGUDU 1	NANJANGUDU_66	22:56	23:59	1:02	LINE FAULT
441	2-Nov-19	MYSORE	66	KADAKOLA-NANJANAGUDU 2	THANDYA_66	22:56	23:11	0:14	LINE FAULT
442	2-Nov-19	MYSORE	66	HV2	KMDODDI_66	17:57	18:25	0:27	LOAD CURTAILMENT
443	2-Nov-19	MYSORE	66	HV2	KOLLEGALA_66	18:09	18:20	0:11	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
444	2-Nov-19	MYSORE	66	HV1	KUSHALANAGARA_66	17:56	18:16	0:19	LOAD CURTAILMENT
445	2-Nov-19	MYSORE	66	MADHUVANAHALLI -HANNUR 2	BANDALLI_66 COWDALLI_66 HANNUR_66 RAMAPURA_MYS_66 MARTAHALLI_66	6:07	6:18	0:11	LINE FAULT
446	2-Nov-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	9:39	11:33	1:53	NFBC ISSUED
447	2-Nov-19	MYSORE	66	HV1	SATHEGALA_66	18:09	18:14	0:04	LOAD CURTAILMENT
448	2-Nov-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:09	18:46	0:37	LOAD CURTAILMENT
449	2-Nov-19	MYSORE	66	HV1	VIRAJPET_66	14:37	15:03	0:25	MAIN SUPPLY FAILURE
450	2-Nov-19	MYSORE	66	HV2	VIRAJPET_66	14:37	15:03	0:26	MAIN SUPPLY FAILURE
451	2-Nov-19	TUMKUR	220	ANCHEPALYA 220KV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	18:30	21:01	2:31	LINE CLEAR AVAILED
452	2-Nov-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	4:35	8:07	3:31	LINE FAULT
453	2-Nov-19	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	6:08	6:32	0:24	LINE FAULT
454	2-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	18:18	19:16	0:57	LOAD CURTAILMENT
455	2-Nov-19	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	6:02	6:37	0:34	LINE FAULT
456	2-Nov-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:11	18:24	0:12	LINE FAULT
457	2-Nov-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:08	9:22	0:14	LINE FAULT
458	2-Nov-19	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	6:05	6:09	0:03	LINE FAULT
459	2-Nov-19	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	18:30	21:01	2:31	LINE CLEAR AVAILED
460	2-Nov-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	4:35	8:07	3:31	LINE FAULT
461	2-Nov-19	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	6:08	6:32	0:24	LINE FAULT
462	2-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	18:18	19:16	0:57	LOAD CURTAILMENT
463	2-Nov-19	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	6:02	6:37	0:34	LINE FAULT
464	2-Nov-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:11	18:24	0:12	LINE FAULT
465	2-Nov-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:08	9:22	0:14	LINE FAULT
466	2-Nov-19	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	6:05	6:09	0:03	LINE FAULT
467	3-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	0:00	9:02	9:02	LINE CLEAR AVAILED
468	3-Nov-19	BAGALKOT	220	BELGAUM -CHIKKODI 2	BELGAUM_220	0:00	9:08	9:08	LINE CLEAR AVAILED
469	3-Nov-19	BAGALKOT	110	RANEENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	10:25	16:14	5:49	LINE CLEAR AVAILED
470	3-Nov-19	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	0:00	16:04	16:04	LINE CLEAR AVAILED
471	3-Nov-19	BAGALKOT	110	220/110KV, LV2	RANEENNUR_220	10:40	15:47	5:07	LINE CLEAR AVAILED
472	3-Nov-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_110	23:06	23:59	0:53	HAND TRIPPED
473	3-Nov-19	BAGALKOT	110	110/11KV,HV2	RATTIHALLI_110	13:20	14:17	0:57	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
474	3-Nov-19	BAGALKOT	110	110/33KV, HV3	RATTIHALLI_110, HALLUR_33, MAASUR_33	13:20	14:16	0:56	LINE CLEAR AVAILED
475	3-Nov-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	0:00	9:02	9:02	LINE CLEAR AVAILED
476	3-Nov-19	BAGALKOT	220	BELGAUM -CHIKKODI 2	BELGAUM_220	0:00	9:08	9:08	LINE CLEAR AVAILED
477	3-Nov-19	BAGALKOT	110	RANEBENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	10:25	16:14	5:49	LINE CLEAR AVAILED
478	3-Nov-19	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	0:00	16:04	16:04	LINE CLEAR AVAILED
479	3-Nov-19	BAGALKOT	110	220/110KV, LV2	RANEBENNUR_220	10:40	15:47	5:07	LINE CLEAR AVAILED
480	3-Nov-19	BAGALKOT	110	220/110KV, LV1	MK HUBLI_110	23:06	23:59	0:53	HAND TRIPPED
481	3-Nov-19	BAGALKOT	110	110/11KV,HV2	RATTIHALLI_110	13:20	14:17	0:57	LINE CLEAR AVAILED
482	3-Nov-19	BAGALKOT	110	110/33KV, HV3	RATTIHALLI_110, HALLUR_33, MAASUR_33	13:20	14:16	0:56	LINE CLEAR AVAILED
483	3-Nov-19	BENGALURU	66	HV1	BRIGADE METROPOLIS	10:48	10:50	0:02	LINE CLEAR AVAILED
484	3-Nov-19	BENGALURU	66	HV2	NRS	7:12	9:35	2:23	LINE CLEAR AVAILED
485	3-Nov-19	BENGALURU	66	HV1	NRS	7:36	9:13	1:37	LINE CLEAR AVAILED
486	3-Nov-19	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	14:11	14:22	0:11	LINE FAULT
487	3-Nov-19	BENGALURU	66	RMV-PEENYA	RMV	12:32	12:35	0:03	LOAD CHANGEOVER
488	3-Nov-19	BENGALURU	66	RMV-HEBBAL	RMV	14:06	14:08	0:02	LOAD CHANGEOVER
489	3-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	9:28	9:32	0:04	LOAD CHANGEOVER
490	3-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	9:28	9:32	0:04	LOAD CHANGEOVER
491	3-Nov-19	BENGALURU	66	BEGUR 220 - HIREHALLI	HIREHALLI	17:25	17:35	0:10	MAIN SUPPLY FAILURE
492	3-Nov-19	BENGALURU	66	BEGUR 220 - BIAL 1	BIAL	17:25	17:35	0:10	MAIN SUPPLY FAILURE
493	3-Nov-19	BENGALURU	66	BEGUR 220 - BIAL 2	BIAL	17:25	17:35	0:10	MAIN SUPPLY FAILURE
494	3-Nov-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	17:25	17:35	0:10	MAIN SUPPLY FAILURE
495	3-Nov-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	17:25	17:35	0:10	MAIN SUPPLY FAILURE
496	3-Nov-19	BENGALURU	220	BEGUR 220 - DB PURA 220	BEGUR 220	17:25	17:28	0:03	LINE FAULT
497	3-Nov-19	BENGALURU	66	HV1	BRIGADE METROPOLIS	10:48	10:50	0:02	LINE CLEAR AVAILED
498	3-Nov-19	BENGALURU	66	HV2	NRS	7:12	9:35	2:23	LINE CLEAR AVAILED
499	3-Nov-19	BENGALURU	66	HV1	NRS	7:36	9:13	1:37	LINE CLEAR AVAILED
500	3-Nov-19	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	14:11	14:22	0:11	LINE FAULT
501	3-Nov-19	BENGALURU	66	RMV-PEENYA	RMV	12:32	12:35	0:03	LOAD CHANGEOVER
502	3-Nov-19	BENGALURU	66	RMV-HEBBAL	RMV	14:06	14:08	0:02	LOAD CHANGEOVER
503	3-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	9:28	9:32	0:04	LOAD CHANGEOVER
504	3-Nov-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	9:28	9:32	0:04	LOAD CHANGEOVER
505	3-Nov-19	BENGALURU	66	BEGUR 220 - HIREHALLI	HIREHALLI	17:25	17:35	0:10	MAIN SUPPLY FAILURE
506	3-Nov-19	BENGALURU	66	BEGUR 220 - BIAL 1	BIAL	17:25	17:35	0:10	MAIN SUPPLY FAILURE
507	3-Nov-19	BENGALURU	66	BEGUR 220 - BIAL 2	BIAL	17:25	17:35	0:10	MAIN SUPPLY FAILURE
508	3-Nov-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	17:25	17:35	0:10	MAIN SUPPLY FAILURE
509	3-Nov-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	17:25	17:35	0:10	MAIN SUPPLY FAILURE
510	3-Nov-19	BENGALURU	220	BEGUR 220 - DB PURA 220	BEGUR 220	17:25	17:28	0:03	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
511	3-Nov-19	GULBARGA	400	BPS-YTPS1	YTPS_400	23:13	23:59	0:46	LINE FAULT
512	3-Nov-19	GULBARGA	220	HV1,HV2	ITTAGI_220	11:48	12:10	0:22	TRANSFORMER FAULT
513	3-Nov-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	9:40	9:52	0:12	LINE FAULT
514	3-Nov-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	19:35	20:10	0:35	LINE FAULT
515	3-Nov-19	GULBARGA	110	HV2	BISIHALLI_110	22:19	22:35	0:16	TRANSFORMER FAULT
516	3-Nov-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110	19:35	20:38	1:03	LINE FAULT
517	3-Nov-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:10	3:22	0:12	LINE FAULT
518	3-Nov-19	GULBARGA	110	MALLAT-MADALPUR	MADALAPUR_110	4:03	4:11	0:08	LINE FAULT
519	3-Nov-19	GULBARGA	110	MALLAT-MADALPUR	MADALAPUR_110	22:20	22:30	0:10	LINE FAULT
520	3-Nov-19	GULBARGA	110	SEDAM-MALKHED	MALKHED RAILWAY TRACTION	6:44	7:20	0:36	LINE FAULT
521	3-Nov-19	GULBARGA	400	BPS-YTPS1	YTPS_400	23:13	23:59	0:46	LINE FAULT
522	3-Nov-19	GULBARGA	220	HV1,HV2	ITTAGI_220	11:48	12:10	0:22	TRANSFORMER FAULT
523	3-Nov-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	9:40	9:52	0:12	LINE FAULT
524	3-Nov-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	19:35	20:10	0:35	LINE FAULT
525	3-Nov-19	GULBARGA	110	HV2	BISIHALLI_110	22:19	22:35	0:16	TRANSFORMER FAULT
526	3-Nov-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110	19:35	20:38	1:03	LINE FAULT
527	3-Nov-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:10	3:22	0:12	LINE FAULT
528	3-Nov-19	GULBARGA	110	MALLAT-MADALPUR	MADALAPUR_110	4:03	4:11	0:08	LINE FAULT
529	3-Nov-19	GULBARGA	110	MALLAT-MADALPUR	MADALAPUR_110	22:20	22:30	0:10	LINE FAULT
530	3-Nov-19	GULBARGA	110	SEDAM-MALKHED	MALKHED RAILWAY TRACTION	6:44	7:20	0:36	LINE FAULT
531	3-Nov-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	0:20	1:09	0:49	HAND TRIPPED
532	3-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	7:49	7:49	LINE CLEAR AVAILED
533	3-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	0:00	7:50	7:50	LINE CLEAR AVAILED
534	3-Nov-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	0:19	1:10	0:51	HAND TRIPPED
535	3-Nov-19	HASSAN	110	HV1	KEMAR_220	12:42	13:22	0:40	LINE CLEAR AVAILED
536	3-Nov-19	HASSAN	110	HV1	KEMAR_220	13:36	14:13	0:37	LINE CLEAR AVAILED
537	3-Nov-19	HASSAN	110	HV2	KEMAR_220	12:23	14:10	1:47	LINE CLEAR AVAILED
538	3-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:00	7:51	7:51	LINE CLEAR AVAILED
539	3-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	23:38	23:59	0:21	HAND TRIPPED
540	3-Nov-19	HASSAN	110	HV2	KONDENALU_110	0:00	12:46	12:46	TRANSFORMER FAULT
541	3-Nov-19	HASSAN	66	HV1	ALDUR_66	11:00	11:25	0:25	LINE CLEAR AVAILED
542	3-Nov-19	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:32	12:33	0:01	MAIN SUPPLY FAILURE
543	3-Nov-19	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:57	12:58	0:01	MAIN SUPPLY FAILURE
544	3-Nov-19	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	12:32	12:33	0:01	MAIN SUPPLY FAILURE
545	3-Nov-19	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	12:57	12:58	0:01	MAIN SUPPLY FAILURE
546	3-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	21:38	21:46	0:08	LINE FAULT
547	3-Nov-19	HASSAN	66	HV2	HNPUA_66	21:38	21:59	0:21	MAIN SUPPLY FAILURE
548	3-Nov-19	HASSAN	66	MALALI-CRPATNA	MALALI_66	16:00	16:16	0:16	MAIN SUPPLY FAILURE
549	3-Nov-19	HASSAN	66	MALALI-HASSAN	MALALI_66	0:00	16:00	16:00	MAIN SUPPLY FAILURE
550	3-Nov-19	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	9:23	9:32	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
551	3-Nov-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	15:30	16:00	0:30	LINE FAULT
552	3-Nov-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	15:27	15:57	0:30	HAND TRIPPED
553	3-Nov-19	HASSAN	66	CHANNAR-UDAYPURA	CHANNARAYAPATNA_66	15:27	15:57	0:30	HAND TRIPPED
554	3-Nov-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	0:20	1:09	0:49	HAND TRIPPED
555	3-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	7:49	7:49	LINE CLEAR AVAILED
556	3-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	0:00	7:50	7:50	LINE CLEAR AVAILED
557	3-Nov-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	0:19	1:10	0:51	HAND TRIPPED
558	3-Nov-19	HASSAN	110	HV1	KEMAR_220	12:42	13:22	0:40	LINE CLEAR AVAILED
559	3-Nov-19	HASSAN	110	HV1	KEMAR_220	13:36	14:13	0:37	LINE CLEAR AVAILED
560	3-Nov-19	HASSAN	110	HV2	KEMAR_220	12:23	14:10	1:47	LINE CLEAR AVAILED
561	3-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:00	7:51	7:51	LINE CLEAR AVAILED
562	3-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	23:38	23:59	0:21	HAND TRIPPED
563	3-Nov-19	HASSAN	110	HV2	KONDENALU_110	0:00	12:46	12:46	TRANSFORMER FAULT
564	3-Nov-19	HASSAN	66	HV1	ALDUR_66	11:00	11:25	0:25	LINE CLEAR AVAILED
565	3-Nov-19	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:32	12:33	0:01	MAIN SUPPLY FAILURE
566	3-Nov-19	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:57	12:58	0:01	MAIN SUPPLY FAILURE
567	3-Nov-19	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	12:32	12:33	0:01	MAIN SUPPLY FAILURE
568	3-Nov-19	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	12:57	12:58	0:01	MAIN SUPPLY FAILURE
569	3-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	21:38	21:46	0:08	LINE FAULT
570	3-Nov-19	HASSAN	66	HV2	HNPURA_66	21:38	21:59	0:21	MAIN SUPPLY FAILURE
571	3-Nov-19	HASSAN	66	MALALI-CRPATNA	MALALI_66	16:00	16:16	0:16	MAIN SUPPLY FAILURE
572	3-Nov-19	HASSAN	66	MALALI-HASSAN	MALALI_66	0:00	16:00	16:00	MAIN SUPPLY FAILURE
573	3-Nov-19	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	9:23	9:32	0:09	LINE FAULT
574	3-Nov-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	15:30	16:00	0:30	LINE FAULT
575	3-Nov-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	15:27	15:57	0:30	HAND TRIPPED
576	3-Nov-19	HASSAN	66	CHANNAR-UDAYPURA	CHANNARAYAPATNA_66	15:27	15:57	0:30	HAND TRIPPED
577	3-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66,HAMPAPURA(K)_6 6, HDKOTE_66, JAIPUR_66,	10:25	10:31	0:05	LINE FAULT
578	3-Nov-19	MYSORE	66	HV2	MALAVALLI_66	0:13	0:24	0:10	TRANSFORMER FAULT
579	3-Nov-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	10:25	12:46	2:20	NFBC ISSUED
580	3-Nov-19	MYSORE	66	HV1	THALAKADU_66	5:47	5:51	0:04	MAIN SUPPLY FAILURE
581	3-Nov-19	MYSORE	66	HV2	THALAKADU_66	5:47	5:51	0:04	MAIN SUPPLY FAILURE
582	3-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66,HAMPAPURA(K)_6 6, HDKOTE_66, JAIPUR_66,	10:25	10:31	0:05	LINE FAULT
583	3-Nov-19	MYSORE	66	HV2	MALAVALLI_66	0:13	0:24	0:10	TRANSFORMER FAULT
584	3-Nov-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	10:25	12:46	2:20	NFBC ISSUED
585	3-Nov-19	MYSORE	66	HV1	THALAKADU_66	5:47	5:51	0:04	MAIN SUPPLY FAILURE
586	3-Nov-19	MYSORE	66	HV2	THALAKADU_66	5:47	5:51	0:04	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
587	3-Nov-19	TUMKUR	66	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	14:37	21:54	7:17	MAIN SUPPLY FAILURE
588	3-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	9:02	9:11	0:08	LINE FAULT
589	3-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:10	13:19	0:09	LINE FAULT
590	3-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	15:20	16:04	0:44	LINE FAULT
591	3-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:17	13:23	1:06	LINE CLEAR AVAILED
592	3-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:35	17:36	2:00	LINE CLEAR AVAILED
593	3-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	20:28	21:52	1:24	LINE CLEAR AVAILED
594	3-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	8:09	8:22	0:12	LINE FAULT
595	3-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:36	21:52	8:15	LINE CLEAR AVAILED
596	3-Nov-19	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	12:49	13:03	0:13	LINE FAULT
597	3-Nov-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	14:10	14:21	0:11	LINE FAULT
598	3-Nov-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	14:10	14:14	0:04	LINE FAULT
599	3-Nov-19	TUMKUR	66	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	14:37	21:54	7:17	MAIN SUPPLY FAILURE
600	3-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	9:02	9:11	0:08	LINE FAULT
601	3-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:10	13:19	0:09	LINE FAULT
602	3-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	15:20	16:04	0:44	LINE FAULT
603	3-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:17	13:23	1:06	LINE CLEAR AVAILED
604	3-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:35	17:36	2:00	LINE CLEAR AVAILED
605	3-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	20:28	21:52	1:24	LINE CLEAR AVAILED
606	3-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	8:09	8:22	0:12	LINE FAULT
607	3-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:36	21:52	8:15	LINE CLEAR AVAILED
608	3-Nov-19	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	12:49	13:03	0:13	LINE FAULT
609	3-Nov-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	14:10	14:21	0:11	LINE FAULT
610	3-Nov-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	14:10	14:14	0:04	LINE FAULT
611	4-Nov-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	6:26	6:45	0:19	LINE FAULT
612	4-Nov-19	BAGALKOT	110	110/11KV,HV2	ANKALI_110	11:58	13:19	1:21	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
613	4-Nov-19	BAGALKOT	110	110/11KV,HV1	ANKALI_110	17:11	18:21	1:10	LINE CLEAR AVAILED
614	4-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	9:27	9:40	0:13	LINE CLEAR AVAILED
615	4-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	12:55	23:59	11:04	LINE FAULT
616	4-Nov-19	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	10:25	11:10	0:45	HAND TRIPPED
617	4-Nov-19	BAGALKOT	110	BAGEWADI220-SINDAGI	SINDAGI_110	14:45	15:00	0:15	HAND TRIPPED
618	4-Nov-19	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	10:56	11:10	0:14	HAND TRIPPED
619	4-Nov-19	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	14:47	14:55	0:08	HAND TRIPPED
620	4-Nov-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	6:26	8:05	1:39	LINE FAULT
621	4-Nov-19	BAGALKOT	220	220/110KV,HV2&LV2	CHIKKODI_220	13:28	13:42	0:14	TRANSFORMER FAULT
622	4-Nov-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	19:20	19:30	0:10	LINE FAULT
623	4-Nov-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	8:53	9:25	0:32	LINE CLEAR AVAILED
624	4-Nov-19	BAGALKOT	110	BPCL-SHIRAHATTI	SHIRAHATTI_110	7:44	8:20	0:36	LINE FAULT
625	4-Nov-19	BAGALKOT	110	INDI220-ZALKI	ZALKI_110	17:15	17:18	0:03	HAND TRIPPED
626	4-Nov-19	BAGALKOT	110	INDI220-ZALKI	ZALKI_110	22:12	22:17	0:05	LINE FAULT
627	4-Nov-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	20:50	23:59	3:09	LINE FAULT
628	4-Nov-19	BAGALKOT	110	CHIKKODI220-RAIBAG1&2	RAIBAG_110	14:20	21:16	6:56	LINE FAULT
629	4-Nov-19	BAGALKOT	110	ITNAL-RAIBAG	RAIBAG_110	14:18	14:36	0:18	HAND TRIPPED
630	4-Nov-19	BAGALKOT	110	ITNAL-RAIBAG	RAIBAG_110	21:17	23:59	2:42	LINE CLEAR AVAILED
631	4-Nov-19	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	10:59	12:31	1:32	LINE CLEAR AVAILED
632	4-Nov-19	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	14:25	15:34	1:09	LINE CLEAR AVAILED
633	4-Nov-19	BAGALKOT	220	220/110KV,LV2	MK HUBLI_220	0:00	15:18	15:18	LINE CLEAR AVAILED
634	4-Nov-19	BAGALKOT	220	220/110KV,LV2	MK HUBLI_220	0:00	6:45	6:45	LINE CLEAR AVAILED
635	4-Nov-19	BENGALURU	66	HV1	AMARJYOTHI	11:17	11:27	0:10	LOAD CHANGEVER
636	4-Nov-19	BENGALURU	66	HV1	AMARJYOTHI	13:50	13:57	0:07	LOAD CHANGEVER
637	4-Nov-19	BENGALURU	66	CHANDRA LAYOUT - NRS	CHANDRA LAYOUT	9:38	9:42	0:04	LOAD CHANGEVER
638	4-Nov-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:07	15:15	0:08	LINE FAULT
639	4-Nov-19	BENGALURU	66	HV1	YARANDANAHALLI 220	9:41	10:30	0:49	TRANSFORMER FAULT
640	4-Nov-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	9:41	10:30	0:49	LINE FAULT
641	4-Nov-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	9:41	10:30	0:49	LINE FAULT
642	4-Nov-19	BENGALURU	66	HV1	YARANDANAHALLI 220	14:54	15:08	0:14	TRANSFORMER FAULT
643	4-Nov-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	14:54	15:10	0:16	LINE FAULT
644	4-Nov-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	14:54	15:10	0:16	LINE FAULT
645	4-Nov-19	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	8:13	8:33	0:19	LINE FAULT
646	4-Nov-19	BENGALURU	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	13:09	13:15	0:06	LOAD CHANGEVER
647	4-Nov-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	16:58	17:25	0:27	LINE CLEAR AVAILED
648	4-Nov-19	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:40	19:23	0:43	LOAD CURTAILMENT
649	4-Nov-19	BENGALURU	66	HV1	RR NAGAR	6:05	6:10	0:04	LOAD CHANGEVER
650	4-Nov-19	BENGALURU	66	HV2	RR NAGAR	6:05	6:10	0:04	LOAD CHANGEVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
651	4-Nov-19	BENGALURU	66	HV1	RR NAGAR	8:55	9:00	0:05	LOAD CHANGEOVER
652	4-Nov-19	BENGALURU	66	HV2	RR NAGAR	8:55	9:00	0:05	LOAD CHANGEOVER
653	4-Nov-19	BENGALURU	66	HV1	NARASAPURA	14:00	14:16	0:16	LINE CLEAR AVAILED
654	4-Nov-19	GULBARGA	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	1:30	2:35	1:05	LINE FAULT
655	4-Nov-19	GULBARGA	220	ALIPUR-GOOTY	ALIPUR_220	11:08	12:17	1:09	LINE CLEAR AVAILED
656	4-Nov-19	GULBARGA	220	ALIPUR-BTPSG	ALIPUR_220	11:09	12:47	1:38	LINE CLEAR AVAILED
657	4-Nov-19	GULBARGA	400	BTPSG-JSWVL	BTPSG	0:00	7:48	7:48	LINE FAULT
658	4-Nov-19	GULBARGA	110	HV1,HV2	HANUMANAL_110	9:15	9:35	0:20	TRANSFORMER FAULT
659	4-Nov-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	4:40	4:51	0:11	LINE FAULT
660	4-Nov-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	5:31	5:55	0:24	LINE FAULT
661	4-Nov-19	GULBARGA	110	DHADESUGUR-VEPLSLR_IPP	DHADESUGUR_110	0:00	13:55	13:55	LINE CLEAR AVAILED
662	4-Nov-19	GULBARGA	110	HV2	KAVITAL_110	18:35	18:45	0:10	TRANSFORMER FAULT
663	4-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	6:37	19:26	12:49	LINE CLEAR AVAILED
664	4-Nov-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	12:22	12:26	0:04	LINE FAULT
665	4-Nov-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:44	14:17	4:33	LINE CLEAR AVAILED
666	4-Nov-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	18:25	23:59	5:34	LINE FAULT
667	4-Nov-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	2:54	6:45	3:51	LINE CLEAR AVAILED
668	4-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:43	6:43	6:00	LINE CLEAR AVAILED
669	4-Nov-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:44	14:17	4:33	NFBC ISSUED
670	4-Nov-19	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	18:25	23:59	5:34	LINE FAULT
671	4-Nov-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	0:49	6:47	5:58	LINE CLEAR AVAILED
672	4-Nov-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	0:43	6:45	6:02	LINE CLEAR AVAILED
673	4-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:00	6:42	6:42	LINE CLEAR AVAILED
674	4-Nov-19	HASSAN	110	HV2	KEMAR_220	10:29	10:45	0:16	LINE CLEAR AVAILED
675	4-Nov-19	HASSAN	110	HV1	CHANDRAGUTTI_110	17:25	23:59	6:34	MAIN SUPPLY FAILURE
676	4-Nov-19	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	17:25	23:59	6:34	MAIN SUPPLY FAILURE
677	4-Nov-19	HASSAN	110	HV2	KONDENALU_110	12:35	13:45	1:10	LINE CLEAR AVAILED
678	4-Nov-19	HASSAN	110	HV2	PUTTUR_110	15:21	18:23	3:02	LINE CLEAR AVAILED
679	4-Nov-19	HASSAN	110	HV3	PUTTUR_110	11:28	11:51	0:23	LINE CLEAR AVAILED
680	4-Nov-19	HASSAN	110	HV4	PUTTUR_110	11:52	12:56	1:04	LINE CLEAR AVAILED
681	4-Nov-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	0:00	11:55	11:55	LINE CLEAR AVAILED
682	4-Nov-19	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	16:20	16:25	0:05	HAND TRIPPED
683	4-Nov-19	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	10:21	11:51	1:30	NFBC ISSUED
684	4-Nov-19	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	6:22	11:01	4:39	LINE FAULT
685	4-Nov-19	MYSORE	66	DATAGALLI-RK NAGARA	RKNAGARA_66	10:35	17:35	7:00	NFBC ISSUED
686	4-Nov-19	MYSORE	66	KUSHALANAGRA 220-BYLUKUPPE	BYLUKUPPE_66	11:11	11:20	0:08	LINE FAULT
687	4-Nov-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	6:17	6:25	0:08	LINE FAULT
688	4-Nov-19	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	HANAGODU_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	11:10	11:25	0:15	LINE FAULT
689	4-Nov-19	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 2	BYLUKUPPE_66	11:10	11:32	0:22	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
690	4-Nov-19	MYSORE	66	RK NAGARA-KADAKOLA	RKNAGARA_66	10:14	17:48	7:33	NFBC ISSUED
691	4-Nov-19	MYSORE	66	HV1	SANTHEBACHALLI_66	11:15	13:25	2:10	LINE CLEAR AVAILED
692	4-Nov-19	MYSORE	66	HV2	SANTHEBACHALLI_66	13:18	14:22	1:04	LINE CLEAR AVAILED
693	4-Nov-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66, MEGALAPURA_66, TNARASIPURA_66, THUMBLA_66	7:23	7:39	0:16	LINE FAULT
694	4-Nov-19	TUMKUR	110	TR-1	GUBBI_110	15:03	18:36	3:33	TRANSFORMER FAULT
695	4-Nov-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	19:03	19:12	0:09	LOAD CURTAILMENT
696	4-Nov-19	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	19:05	19:13	0:08	LOAD CURTAILMENT
697	4-Nov-19	TUMKUR	66	TR-2	ANTHRASANAHALI_220	16:51	17:04	0:12	LINE CLEAR AVAILED
698	4-Nov-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_IPP_66	11:20	11:24	0:03	HAND TRIPPED
699	4-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALI	BEVINAHALI_66	8:41	8:53	0:11	LINE FAULT
700	4-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	7:28	7:39	0:11	LINE FAULT
701	4-Nov-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	22:32	22:34	0:01	LINE FAULT
702	4-Nov-19	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	15:48	18:28	2:40	LINE CLEAR AVAILED
703	4-Nov-19	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	10:22	17:36	7:14	LINE CLEAR AVAILED
704	4-Nov-19	TUMKUR	66	THALLAK 220kv- CHALLAKERE 1	CHALLAKERE_66, SANIKERE_66	13:07	14:15	1:08	LINE CLEAR AVAILED
705	4-Nov-19	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	1:04	1:09	0:05	LINE FAULT