

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 07.06.22 To 13.06.22

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	7-Jun-22	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	16:14	18:05	1:51	LINE CLEAR AVAILED
2	7-Jun-22	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	18:00	18:10	0:10	TRANSFORMER FAULT
3	7-Jun-22	BAGALKOT	110	110/11KV, HV2	MANTUR(B)_110	18:00	18:20	0:20	LINE CLEAR AVAILED
4	7-Jun-22	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	4:46 (06.06.2022)	12:48 (07.06.2022)	32:02 hrs	TRANSFORMER CHARGED
5	7-Jun-22	BAGALKOT	110	110/11KV, HV1	ZALKI_110	7:42	7:45	0:03	TRANSFORMER FAULT
6	7-Jun-22	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	13:18	13:42	0:24	TRANSFORMER FAULT
7	7-Jun-22	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	15:40	16:11	0:31	LINE CLEAR AVAILED
8	7-Jun-22	BAGALKOT	110	110/11KV, HV1(HV2)	NAVANAGAR(B)_110	16:14	17:29	1:15	TRANSFORMER FAULT
9	7-Jun-22	BAGALKOT	110	110/11KV, HV1A	JAMAKHANDI_110	10:45	17:53	7:08	LINE CLEAR AVAILED
10	7-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
11	7-Jun-22	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	11:22	13:17	1:55	LINE CLEAR AVAILED
12	7-Jun-22	BAGALKOT	110	110/33KV, HV1	GADAG_110, HULKOTI_33, LAKKUNDI_33	16:47	16:51	0:04	LINE CLEAR AVAILED
13	7-Jun-22	BAGALKOT	110	110/33KV, HV3	GOPANAKOPPA_110	17:05	17:07	0:02	TRANSFORMER FAULT
14	7-Jun-22	BAGALKOT	110	110/33KV, HV3	HIREKERUR_110	15:27	15:56	0:29	LINE CLEAR AVAILED
15	7-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
16	7-Jun-22	BAGALKOT	110	110/33KV, HV4	GOPANAKOPPA_110	17:10	17:13	0:03	TRANSFORMER FAULT
17	7-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
18	7-Jun-22	BAGALKOT	110	BAGEWADI- ACHANUR (MUDDEBIHAL)	STATION NOT AFFECTED BAGEWADI_220	5:54	6:09	0:15	LINE FAULT
19	7-Jun-22	BAGALKOT	110	BANAHATTI- JAMKHANDI (NAVALAGI)	STATION NOT AFFECTED BANAHATTI_110	16:53	17:32	0:39	LINE CLEAR AVAILED
20	7-Jun-22	BAGALKOT	110	CHIKKODI220- ANKALI	CHIKKODI_220	16:25	16:30	0:05	HAND TRIPPED
21	7-Jun-22	BAGALKOT	110	CHIKKODI220- BHOJ (NANADI)	CHIKKODI_220	16:25	16:30	0:05	HAND TRIPPED
22	7-Jun-22	BAGALKOT	110	HAVERI220- BYADAGI	HAVERI_220	14:05	14:30	0:25	HAND TRIPPED
23	7-Jun-22	BAGALKOT	110	HAVERI220- TILUVALLI	HAVERI_220	14:06	14:28	0:22	HAND TRIPPED
24	7-Jun-22	BAGALKOT	110	HAVERI220-HANGAL	HAVERI_220	14:05	14:32	0:27	HAND TRIPPED
25	7-Jun-22	BAGALKOT	110	HAVERI220-SAVANUR	HAVERI_220	14:05	14:24	0:19	HAND TRIPPED
26	7-Jun-22	BAGALKOT	110	MAHALINGAPUR - DAVALESHWAR	DAVALESHWAR_110	5:50	5:51	0:01	LINE FAULT
27	7-Jun-22	BAGALKOT	110	MANTUR -NIRANI SUGARS	STATION NOT AFFECTED MANTUR(B)_110	16:43	17:00	0:17	LINE CLEAR AVAILED
28	7-Jun-22	BAGALKOT	110	MK HUBLI220- MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	13:32 (06.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
29	7-Jun-22	BAGALKOT	110	MUNDAGOD- HUBLI (RAMANKOPPA)	STATION NOT AFFECTED MUNDAGOD_110	20:28 (06.06.2022)	14:13 (07.06.2022)	17:45 hrs	LINE CHARGED
30	7-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
31	7-Jun-22	BAGALKOT	110	RAMANKOPPA- SAVANUR (MUNDAGOD)	STATION NOT AFFECTED RAMANKOPPA_110	19:51 (06.06.2022)	13:50 (07.06.2022)	17:59 hrs	LINE CHARGED
32	7-Jun-22	BAGALKOT	110	SAUNDATTI220-SOUDATTI1	STATION NOT AFFECTED SOUDATTI_220	11:20	15:17	3:57	NFBC ISSUED
33	7-Jun-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LIE OPEN: LINE FAULT
34	7-Jun-22	BAGALKOT	110	SOUDATTI220-NARAGUND (RAMDURG1)	STATION NOT AFFECTED SOUDATTI_220	11:20	15:19	3:59	LINE CLEAR AVAILED
35	7-Jun-22	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	11:20	15:17	3:57	NFBC ISSUED
36	7-Jun-22	BAGALKOT	220	220/110KV, HV1	HAVERI_220	13:56	14:17	0:21	HAND TRIPPED
37	7-Jun-22	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	15:47	16:31	0:44	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
38	7-Jun-22	BAGALKOT	220	220/110KV, HV2	HAVERI_220	13:56	14:22	0:26	HAND TRIPPED
39	7-Jun-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED BELGAUM_220	21:39 (06.06.2022)	9:15 (07.06.2022)	11:36	TRANSFORMER CHARGED
40	7-Jun-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED BELGAUM_220	10:39	17:42	7:03	LINE CLEAR AVAILED
41	7-Jun-22	BAGALKOT	220	220/110KV, HV2	BELGAUM_220	17:50 (07.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
42	7-Jun-22	BAGALKOT	220	220/110KV, HV2&LV2	CHIKKODI_220	15:47	16:16	0:29	TRANSFORMER FAULT
43	7-Jun-22	BAGALKOT	220	220/110KV, HV3 & LV3	CHIKKODI_220	15:58	16:30	0:32	TRANSFORMER FAULT
44	7-Jun-22	BAGALKOT	220	220/110KV,HV3	HIDIKAL_110 MAHALINGAPUR_220	10:55	11:16	0:21	TRANSFORMER FAULT
45	7-Jun-22	BAGALKOT	220	400/220KV, ICT1 (LV)	STATION NOT AFFECTED DHONI_400	11:04	19:14	8:10	LINE CLEAR AVAILED
46	7-Jun-22	BAGALKOT	220	BELGAUM- AEQUS2(CHIKKODI2)	STATION NOT AFFECTED BELGAUM_220	11:27 (01.06.2022)	4:08 (07.06.2022)	136:41 hrs	LINE CHARGED
47	7-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1 (AEQUS1)	STATION NOT AFFECTED BELGAUM_220	22:06 (07.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
48	7-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1 (AEQUS1)	STATION NOT AFFECTED BELGAUM_220	07:35	19:38	12:03	LINE CLEAR AVAILED
49	7-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	04:46	19:27	14:41	LINE CLEAR AVAILED
50	7-Jun-22	BAGALKOT	220	BELGAUM- KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	21:38 (06.06.2022)			LIE OPEN: LINE FAULT
51	7-Jun-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	04:05	04:42	0:37	LINE FAULT
52	7-Jun-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	19:28	22:05	2:37	LINE CLEAR AVAILED
53	7-Jun-22	BAGALKOT	220	BIDNAL- HAVERI	STATION NOT AFFECTED BIDNAL_220	13:56	14:38	0:42	LINE FAULT
54	7-Jun-22	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	12:36	19:32	6:56	LINE CLEAR AVAILED
55	7-Jun-22	BAGALKOT	220	CHIKKODI- BELGAUM1 (AEQUS1)	CHIKKODI_220	15:58	16:36	0:38	LINE FAULT
56	7-Jun-22	BAGALKOT	220	CHIKKODI- BELGAUM2	CHIKKODI_220	15:47	16:36	0:49	LINE FAULT
57	7-Jun-22	BAGALKOT	220	CHIKKODI- GHATAPRABHA2 (KUDACHI2)	CHIKKODI_220	15:58	16:10	0:12	LINE FAULT
58	7-Jun-22	BAGALKOT	220	CHIKKODI- KOLAH PURA (TALANDAGE)	CHIKKODI_220	15:47	16:42	0:55	LINE FAULT
59	7-Jun-22	BAGALKOT	220	CHIKKODI- KUDACHI1	CHIKKODI_220	15:58	16:16	0:18	LINE FAULT
60	7-Jun-22	BAGALKOT	220	CHIKKODI- MUGALKHOD1	CHIKKODI_220	15:58	16:12	0:14	LINE FAULT
61	7-Jun-22	BAGALKOT	220	CHIKKODI- MUGALKHOD2	CHIKKODI_220	15:58	16:13	0:15	LINE FAULT
62	7-Jun-22	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	14:07	14:27	0:20	HAND TRIPPED
63	7-Jun-22	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	15:56	16:14	0:18	HAND TRIPPED
64	7-Jun-22	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	14:07	14:28	0:21	HAND TRIPPED
65	7-Jun-22	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	15:52	15:56	0:04	HAND TRIPPED
66	7-Jun-22	BAGALKOT	220	HAVERI- NARENDRA1(BIDNAL)	HAVERI_220	14:07	14:37	0:30	HAND TRIPPED
67	7-Jun-22	BAGALKOT	220	HAVERI- NARENDRA2 (NARENDRA)	HAVERI_220	14:06	14:15	0:09	HAND TRIPPED
68	7-Jun-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	19:41 (06.06.2022)			LIE OPEN: LINE FAULT
69	7-Jun-22	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED HUBLI_220	12:02	12:15	0:13	HAND TRIPPED
70	7-Jun-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	11:24 (07.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
71	7-Jun-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	21:37 (06.06.2022)			LIE OPEN: LINE FAULT
72	7-Jun-22	BAGALKOT	220	NARENDRA- BELGAUM2	STATION NOT AFFECTED NARENDRA_220	04:04	04:42	0:38	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
73	7-Jun-22	BAGALKOT	220	NARENDRA- BELGAUM2	STATION NOT AFFECTED NARENDRA_220	19:28	22:04	2:36	LINE CLEAR AVAILED
74	7-Jun-22	BAGALKOT	220	NARENDRA- HAVERI	STATION NOT AFFECTED NARENDRA_220	13:56	14:13	0:17	LINE FAULT
75	7-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
76	7-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
77	7-Jun-22	BAGALKOT	220	SOUNDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	12:36	19:32	6:56	NFBC ISSUED
78	7-Jun-22	BAGALKOT	400	400/220KV, ICT1 (HV)	STATION NOT AFFECTED DHONI_400	11:07	19:10	8:03	LINE CLEAR AVAILED
79	7-Jun-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	20:56	21:13	0:17	LINE FAULT
80	7-Jun-22	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	18:13	18:18	0:05	LOAD CHANGE OVER
81	7-Jun-22	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	10:15	10:24	0:09	LOAD CHANGE OVER
82	7-Jun-22	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	22:41	22:46	0:05	LOAD CHANGE OVER
83	7-Jun-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	9:20	17:19	7:59	LINE CLEAR AVAILED
84	7-Jun-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:26	17:33	0:07	LINE CLEAR AVAILED
85	7-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	19:22	19:32	0:10	LINE FAULT
86	7-Jun-22	BENGALURU	66	HV1	BOODIGERE	16:49	18:10	1:21	LINE CLEAR AVAILED
87	7-Jun-22	BENGALURU	66	HV1	CHINTAMANI 66	8:55	8:58	0:02	TRANSFORMER FAULT
88	7-Jun-22	BENGALURU	66	HV1	ANDERSONPETE	11:35	12:01	0:25	LINE CLEAR AVAILED
89	7-Jun-22	BENGALURU	66	HV2	HEBBALA 220	4:27	4:45	0:18	LINE CLEAR AVAILED
90	7-Jun-22	BENGALURU	66	HV2	HEBBALA 220	7:28	9:11	1:43	LINE CLEAR AVAILED
91	7-Jun-22	BENGALURU	66	HV2	KHODAYS 220	20:29	20:39	0:10	TRANSFORMER FAULT
92	7-Jun-22	BENGALURU	66	HV2	NRS 220	18:20	18:31	0:11	LOAD CHANGE OVER
93	7-Jun-22	BENGALURU	66	HV3	HEBBALA 220	12:45	13:19	0:34	LINE CLEAR AVAILED
94	7-Jun-22	BENGALURU	66	IIsc - NRS 220	IIsc	18:20	18:22	0:02	LOAD CHANGE OVER
95	7-Jun-22	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	8:47	8:57	0:09	LOAD CHANGE OVER
96	7-Jun-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	20:56	21:13	0:17	LINE FAULT
97	7-Jun-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	6:57	7:02	0:05	LOAD CHANGE OVER
98	7-Jun-22	BENGALURU	66	LAKSMIPURA - ADDAGAL	GOWNIPALLI, RAYALPADU, ADDAGAL	16:24	16:30	0:05	LINE CLEAR AVAILED
99	7-Jun-22	BENGALURU	66	LAKSMIPURA - SOMAJANAHALLI	SOMAJANAHALLI	13:30	14:03	0:33	LINE CLEAR AVAILED
100	7-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	16:20	16:48	0:28	MAIN SUPPLY FAILURE
101	7-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:20	16:48	0:28	MAIN SUPPLY FAILURE
102	7-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:50	19:06	0:16	LOAD CHANGE OVER
103	7-Jun-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	16:20	16:46	0:26	MAIN SUPPLY FAILURE
104	7-Jun-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	16:20	16:48	0:28	MAIN SUPPLY FAILURE
105	7-Jun-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	18:50	19:06	0:16	LOAD CHANGE OVER
106	7-Jun-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:20	16:47	0:27	MAIN SUPPLY FAILURE
107	7-Jun-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	18:50	19:06	0:16	LOAD CHANGE OVER
108	7-Jun-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	16:20	16:48	0:28	MAIN SUPPLY FAILURE
109	7-Jun-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	18:50	19:06	0:16	LOAD CHANGE OVER
110	7-Jun-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:20	16:32	0:12	MAIN SUPPLY FAILURE
111	7-Jun-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:20	16:36	0:16	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
112	7-Jun-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:20	16:30	0:10	MAIN SUPPLY FAILURE
113	7-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	18:03	18:16	0:13	LINE FAULT
114	7-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	18:16	19:14	0:58	LINE FAULT
115	7-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	19:14	21:08	1:54	LINE CLEAR AVAILED
116	7-Jun-22	BENGALURU	66	VIJAYANAGARA - NRS 220	VIJAYANAGARA	18:10	18:20	0:10	LOAD CHANGE OVER
117	7-Jun-22	BENGALURU	66	VIJAYANAGARA - REMCO	VIJAYANAGARA	10:10	10:17	0:07	LOAD CHANGE OVER
118	7-Jun-22	BENGALURU	66	VIJAYANAGARA - REMCO	VIJAYANAGARA	22:10	22:14	0:04	LOAD CHANGE OVER
119	7-Jun-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	16:20	16:33	0:13	MAIN SUPPLY FAILURE
120	7-Jun-22	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	16:20	16:33	0:13	MAIN SUPPLY FAILURE
121	7-Jun-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	16:20	16:30	0:10	MAIN SUPPLY FAILURE
122	7-Jun-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:20	16:30	0:10	MAIN SUPPLY FAILURE
123	7-Jun-22	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:20	16:34	0:14	MAIN SUPPLY FAILURE
124	7-Jun-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	20:47	21:04	0:17	LINE FAULT
125	7-Jun-22	BENGALURU	220	HV2	YARANDANAHALLI 220	20:47	21:07	0:20	TRANSFORMER FAULT
126	7-Jun-22	BENGALURU	220	HV2	MALUR 220	16:22	17:05	0:43	LINE CLEAR AVAILED
127	7-Jun-22	BENGALURU	220	HV2	MALUR 220	17:05	19:03	1:58	LINE CLEAR AVAILED
128	7-Jun-22	BENGALURU	220	LV2	MALUR 220	17:05	19:05	2:00	LINE CLEAR AVAILED
129	7-Jun-22	BENGALURU	220	MALUR 220 - HOODY	MALUR 220	16:20	16:22	0:02	LINE CLEAR AVAILED
130	7-Jun-22	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	16:20	16:22	0:02	LINE CLEAR AVAILED
131	7-Jun-22	BENGALURU	220	MALUR 220 - KOLAR 3	MALUR 220	16:20	16:22	0:02	LINE CLEAR AVAILED
132	7-Jun-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1 O/G	SARJAPURA 220, VIKAS TECH PARK 220	16:20	16:22	0:02	LINE CLEAR AVAILED
133	7-Jun-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	16:20	16:30	0:10	MAIN SUPPLY FAILURE
134	7-Jun-22	GULBARGA	66	BADELADUKU-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	14:50	16:50	2:00	LINE CLEAR AVAILED
135	7-Jun-22	GULBARGA	66	HV1,HV2	PUNABGHATA_66	9:05	9:55	0:50	LINE CLEAR AVAILED
136	7-Jun-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	6:18	6:24	0:06	LINE FAULT
137	7-Jun-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS ACC	5:40	5:50	0:10	LINE FAULT
138	7-Jun-22	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHAL_110	19:54(06.06.2022)	2:08(7.06.2022)	6:14 hrs	LINE CHARGED
139	7-Jun-22	GULBARGA	110	HV1	HUNSIGI_110	16:00	17:00	1:00	LINE CLEAR AVAILED
140	7-Jun-22	GULBARGA	110	HV1	KURKUNTA_110	7:25	7:35	0:10	TRANSFORMER FAULT
141	7-Jun-22	GULBARGA	110	HV1	VAJRABANDI_11	9:51	9:56	0:05	LINE CLEAR AVAILED
142	7-Jun-22	GULBARGA	110	HV4	DEODURGA_110	20:00(05.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
143	7-Jun-22	GULBARGA	110	HV4	DEODURGA_110	20:00(05.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
144	7-Jun-22	GULBARGA	110	HV4	YELBURGA_110	7:25	7:45	0:20	LOAD CURTAILMENT
145	7-Jun-22	GULBARGA	110	KANAKAGIRI-NAVALI	NAVALI_110	11:00	11:25	0:25	MAIN SUPPLY FAILURE
146	7-Jun-22	GULBARGA	110	KUSATGI-TAWERGERE	TAWERGERE_110	9:30	14:15	4:45	LINE CLEAR AVAILED
147	7-Jun-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110	5:15	5:50	0:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
148	7-Jun-22	GULBARGA	110	LV1	RAICHUR_220	6:24	6:50	0:26	TRANSFORMER FAULT
149	7-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	0:50	1:00	0:10	LINE FAULT
150	7-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	22:00	22:10	0:10	LINE FAULT
151	7-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:42	21:52	0:10	LINE FAULT
152	7-Jun-22	GULBARGA	110	MYLAR-GUTTAL	MYLAR_110	9:40	9:45	0:05	LINE FAULT
153	7-Jun-22	GULBARGA	110	MYLAR-GUTTAL	MYLAR_110	18:05	18:10	0:05	MAIN SUPPLY FAILURE
154	7-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	18:05	18:35	0:30	LINE FAULT
155	7-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	20:15	20:50	0:35	LINE FAULT
156	7-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	23:50	23:59:00	0:09	LINE FAULT
157	7-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_1 & 2	GABBUR_110,GOOGLE_110	16:47	16:51	0:04	LINE CLEAR AVAILED
158	7-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_1 & 2	GABBUR_110,GOOGLE_110	23:34	23:45	0:11	LINE CLEAR AVAILED
159	7-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	20:20	21:43	1:23	LINE FAULT
160	7-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:24	10:51	4:27	LINE FAULT
161	7-Jun-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	10:50	16:52	6:02	LINE CLEAR AVAILED
162	7-Jun-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	17:05	18:10	1:05	LINE CLEAR AVAILED
163	7-Jun-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	VICAT SAGAR_IPP	23:50 (6.06.2022)	00:05 (7.06.2022)	00:15 HRS	LINE CHARGED
164	7-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WAD AGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
165	7-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	13:23	13:38	0:15	LINE FAULT
166	7-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	15:28	16:05	0:37	LINE FAULT
167	7-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	16:10	17:10	1:00	LINE FAULT
168	7-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	17:25	22:43	5:18	LINE FAULT
169	7-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	23:15	23:56	0:41	LINE CLEAR AVAILED
170	7-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KHANAP UR_110,WADGERA_110	12:14	13:30	1:16	LINE CLEAR AVAILED
171	7-Jun-22	GULBARGA	110	SINDHANOOR-TURVIHAL	GANDHINAGAR_110,TURVIHAL_110	19:56(06.06.2022)	02:10(07.06.2022)	6:14HRS	LINE CHARGED
172	7-Jun-22	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110,GANDHINAGAR_110	10:38	15:40	5:02	LINE FAULT
173	7-Jun-22	GULBARGA	110	YELBURGA-PRPJ_IPP	YELBURGA_110	12:06	12:25	0:19	LOAD CURTAILMENT
174	7-Jun-22	GULBARGA	220	BTPS-GUTTUR	GUTTUR_400	04:13(06.06.2022)	13:07(07.06.2022)	32:54HRS	LINE CHARGED
175	7-Jun-22	GULBARGA	220	HV1	KUDLIGI_220	15:35	16:40	1:05	LINE CLEAR AVAILED
176	7-Jun-22	GULBARGA	220	HV1,HV2	SINDHANOOR_220	10:38	11:10	0:32	TRANSFORMER FAULT
177	7-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
178	7-Jun-22	GULBARGA	220	HV2	KUSTAGI_220	5:15	5:40	0:25	TRANSFORMER FAULT
179	7-Jun-22	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNGA_220	13:56	14:14	0:18	LINE FAULT
180	7-Jun-22	GULBARGA	220	LINGAPUR-GDHALLI2	LINGAPUR_220	15:09	17:21	2:12	LINE CLEAR AVAILED
181	7-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23 (27.05.2022)	15:16 (07.06.2022)	267:53 HRS	LINE CHARGED
182	7-Jun-22	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	7:56	19:48	11:52	LINE CLEAR AVAILED
183	7-Jun-22	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	7:29 (6.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
184	7-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
185	7-Jun-22	HASSAN	66	AREHALI-SAKLESPUR	AREHALLY_66	10:20	17:20	7:00	LINE CLEAR AVAILED
186	7-Jun-22	HASSAN	66	HNPR2-HNPR1	HNPURA_220	10:25	14:20	3:55	LINE CLEAR AVAILED
187	7-Jun-22	HASSAN	66	HNPR2-RNPR1	HNPR2	14:05	14:25	0:20	HAND TRIPPED
188	7-Jun-22	HASSAN	66	HNPURA-HASSAN	KANDLI_66	10:14	16:40	6:26	LINE CLEAR AVAILED
189	7-Jun-22	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:14	14:23	4:09	LINE CLEAR AVAILED
190	7-Jun-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	10:14	14:25	4:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
191	7-Jun-22	HASSAN	66	HV1	AREHALLY_66	17:55(07.08.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
192	7-Jun-22	HASSAN	66	HV1	AREHALLY_66	10:20	17:05	6:45	MAIN SUPPLY FAILURE
193	7-Jun-22	HASSAN	66	HV1	AREHALLY_66	17:05	17:20	0:15	LINE CLEAR AVAIED
194	7-Jun-22	HASSAN	66	HV1	CHIKMANGLUR_66	11:00	14:44	3:44	LINE CLEAR AVAIED
195	7-Jun-22	HASSAN	66	HV1	CHIKMANGLUR_66	16:07	19:12	3:05	LINE CLEAR AVAIED
196	7-Jun-22	HASSAN	66	HV1	HNPURA_66	10:13	16:40	6:27	LINE CLEAR AVAIED
197	7-Jun-22	HASSAN	66	HV1	SAKALESH PURA_66	10:00	17:05	7:05	LINE CLEAR AVAIED
198	7-Jun-22	HASSAN	66	HV1	SINGAPURA_66	9:25	21:00	11:35	LINE CLEAR AVAIED
199	7-Jun-22	HASSAN	66	HV1 CB	HETTUR_66	12:09	13:06	0:57	LINE CLEAR AVAIED
200	7-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAIED
201	7-Jun-22	HASSAN	66	HV2	AREHALLY_66	10:00	17:05	7:05	MAIN SUPPLY FAILURE
202	7-Jun-22	HASSAN	66	HV2	AREHALLY_66	18:10	18:25	0:15	LINE CLEAR AVAIED
203	7-Jun-22	HASSAN	66	HV2	CHIKMANGLUR_66	11:00	17:36	6:36	LINE CLEAR AVAIED
204	7-Jun-22	HASSAN	66	HV2	HNPURA_66	10:13	16:40	6:27	LINE CLEAR AVAIED
205	7-Jun-22	HASSAN	66	HV2	KANDLI_66	10:14	16:40	6:26	LINE CLEAR AVAIED
206	7-Jun-22	HASSAN	66	HV2	SAKALESH PURA_66	10:00	17:05	7:05	LINE CLEAR AVAIED
207	7-Jun-22	HASSAN	66	HV2	SINGAPURA_66	9:25	21:00	11:35	LINE CLEAR AVAIED
208	7-Jun-22	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	10:03	17:05	7:02	LINE CLEAR AVAIED
209	7-Jun-22	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	17:20	17:40	0:20	LINE FAULT
210	7-Jun-22	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	17:53	18:05	0:12	LINE FAULT
211	7-Jun-22	HASSAN	66	SAKALE-HASSAN1	SAKALESH PURA_66	10:00	16:55	6:55	NFBC ISSUED
212	7-Jun-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	10:00	18:05	8:05	LINE CLEAR AVAIED
213	7-Jun-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	10:00	18:05	8:05	LINE CLEAR AVAIED
214	7-Jun-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:25	21:00	11:35	LINE CLEAR AVAIED
215	7-Jun-22	HASSAN	110	ANAVATI-ANVATTI	BARANGI_110	10:45	16:10	5:25	NFBC ISSUED
216	7-Jun-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:45	16:10	5:25	LINE CLEAR AVAIED
217	7-Jun-22	HASSAN	110	BARANG-SHR220	BARANGI_110	11:26	16:03	4:37	LINE CLEAR AVAIED
218	7-Jun-22	HASSAN	110	BRAHMAVA-MANIPAL	BRAHMAVA	10:15	15:34	5:19	LINE CLEAR AVAIED
219	7-Jun-22	HASSAN	110	BRAHMAVA-NITTUR	BRAHMAVA	19:15	19:20	0:05	HAND TRIPPED
220	7-Jun-22	HASSAN	110	HALADY11-HEGGUNJE	HALADY_110	9:49	11:36	1:47	LINE CLEAR AVAIED
221	7-Jun-22	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	10:49	17:33	6:44	LINE CLEAR AVAIED
222	7-Jun-22	HASSAN	110	HGUNJE-HALADY1	HEGGUNJE_220	9:54	11:35	1:41	NFBC ISSUED
223	7-Jun-22	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	10:55	17:33	6:38	NFBC ISSUED
224	7-Jun-22	HASSAN	110	HV1	BARANGI_110	11:25	16:45	5:20	LINE CLEAR AVAIED
225	7-Jun-22	HASSAN	110	HV1	MANIPAL_110	13:20	14:05	0:45	LINE CLEAR AVAIED
226	7-Jun-22	HASSAN	110	HV1	NAVUNDA_110	10:15	10:35	0:20	TRANSFORMER FAULT
227	7-Jun-22	HASSAN	110	HV1	NAVUNDA_110	10:35	12:50	2:15	LINE CLEAR AVAIED
228	7-Jun-22	HASSAN	110	HV2	BARANGI_110	11:25	16:45	5:20	LINE CLEAR AVAIED
229	7-Jun-22	HASSAN	110	HV2	MANIPAL_110	12:02	13:20	1:18	LINE CLEAR AVAIED
230	7-Jun-22	HASSAN	110	HV2	NAVUNDA_110	10:15	10:35	0:20	TRANSFORMER FAULT
231	7-Jun-22	HASSAN	110	HV2	NAVUNDA_110	11:15	12:45	1:30	TRANSFORMER FAULT
232	7-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAIED
233	7-Jun-22	HASSAN	110	HV3	MANIPAL_110	9:50	13:30	3:40	LINE CLEAR AVAIED
234	7-Jun-22	HASSAN	110	HV3	SHIRALKOPPA_110	10:05	18:30	8:25	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
235	7-Jun-22	HASSAN	110	HV4	MANIPAL_110	10:45	13:30	2:45	LINE CLEAR AVAILED
236	7-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
237	7-Jun-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:34	14:13	2:39	LINE CLEAR AVAILED
238	7-Jun-22	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:10	17:34	0:24	LINE FAULT
239	7-Jun-22	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:10	18:24	1:14	LINE FAULT
240	7-Jun-22	HASSAN	110	LV1	KEMAR_220	17:10	17:22	0:12	TRANSFORMER FAULT
241	7-Jun-22	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:16	17:40	0:24	MAIN SUPPLY FAILURE
242	7-Jun-22	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	18:38	18:46	0:08	MAIN SUPPLY FAILURE
243	7-Jun-22	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	19:23	19:32	0:09	MAIN SUPPLY FAILURE
244	7-Jun-22	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	17:16	18:46	1:30	MAIN SUPPLY FAILURE
245	7-Jun-22	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	17:16	20:24	3:08	LINE FAULT
246	7-Jun-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	18:45(07.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
247	7-Jun-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	10:10	15:42	5:32	LINE CLEAR AVAILED
248	7-Jun-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	12:06	12:30	0:24	NFBC ISSUED
249	7-Jun-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LIE OPEN: LINE FAULT
250	7-Jun-22	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	10:15	10:35	0:20	LINE FAULT
251	7-Jun-22	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	12:10	12:40	0:30	LINE CLEAR AVAILED
252	7-Jun-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	9:53	18:57	9:04	LINE CLEAR AVAILED
253	7-Jun-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:20	15:38	5:18	LINE CLEAR AVAILED
254	7-Jun-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	15:40	15:45	0:05	HAND TRIPPED
255	7-Jun-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	16:02	16:40	0:38	LINE FAULT
256	7-Jun-22	HASSAN	220	HV1	KEMAR_220	17:10	17:22	0:12	TRANSFORMER FAULT
257	7-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
258	7-Jun-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	19:58(06.06.2022)	11:04(07.06.2022)	15:06HRS	LINE CHARGED
259	7-Jun-22	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	19:58(06.06.2022)	11:04(07.06.2022)	15:06HRS	LINE CHARGED
260	7-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
261	7-Jun-22	MYSURU	66	B G PURA-THALAKADU	NO STATIONS EFFECTED	15:20	15:28	0:08	LINE FAULT
262	7-Jun-22	MYSURU	66	BGPURA-HEBBANI	BGPURA_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	12:58	13:03	0:05	HAND TRIPPED
263	7-Jun-22	MYSURU	66	BGPURA-HEBBANI	BGPURA_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	15:20	15:28	0:08	LINE FAULT
264	7-Jun-22	MYSURU	66	BYLUKUPPE-KUSHALNAGARA	BYLUKUPPE_66	10:00	17:30	7:30	LINE CLEAR AVAILED
265	7-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED
266	7-Jun-22	MYSURU	66	HALGUR-TK HALLI	HALAGUR_66	15:00	15:05	0:05	HAND TRIPPED
267	7-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00(08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
268	7-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
269	7-Jun-22	MYSURU	66	HV1	BGPURA_66	10:42	13:50	3:08	LINE CLEAR AVAILED
270	7-Jun-22	MYSURU	66	HV1	DUNDANAHALLI_66	10:00	18:30	8:30	LINE CLEAR AVAILED
271	7-Jun-22	MYSURU	66	HV1	HANAGODU_66	10:46	11:51	1:05	LINE CLEAR AVAILED
272	7-Jun-22	MYSURU	66	HV2	DUNDANAHALLI_66	9:30	18:30	9:00	LINE CLEAR AVAILED
273	7-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
274	7-Jun-22	MYSURU	66	KUSHALNAGARA-MYSORE 2	BETTADHAPURA_66	12:50	16:54	4:04	LINE CLEAR AVAILED
275	7-Jun-22	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	15:05(07.06.22)			LINE OPEN :LINE CLEAR AAVAILED
276	7-Jun-22	MYSURU	66	SANTHESARGUR-B MATGERE	NO STATIONS EFFECTED	13:10	18:10	5:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
277	7-Jun-22	MYSURU	66	SANTHESARGUR-BEGUR	SANTHESARAGUR_66	13:10	15:35	2:25	LINE CLEAR AVAILED
278	7-Jun-22	MYSURU	66	SANTHESARGUR-HV2	SANTHESARAGUR_66	19:05	19:18	0:13	LINE CLEAR AVAILED
279	7-Jun-22	MYSURU	66	SANTHESARGUR-KADAKOLA 1	YERALLIHANDPOST_66 ANTHARSANTHE_66 HDKOTE_66	13:00	15:40	2:40	LINE CLEAR AVAILED
280	7-Jun-22	MYSURU	66	SANTHESARGUR-KADAKOLA 2	NO STATIONS EFFECTED	11:30	18:00	6:30	LINE CLEAR AVAILED
281	7-Jun-22	MYSURU	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	11:40	16:32	4:52	LINE CLEAR AVAILED
282	7-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	5:33	6:43	1:09	LINE FAULT
283	7-Jun-22	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:53	7:04	0:11	LINE FAULT
284	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- MATHOD	MATHOD_66	19:45	20:21	0:36	LOAD CURTAILMENT
285	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	19:45	20:11	0:26	LOAD CURTAILMENT
286	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	21:05	22:17	1:12	LOAD CURTAILMENT
287	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	19:45	20:03	0:18	LOAD CURTAILMENT
288	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	21:05	22:20	1:15	LOAD CURTAILMENT
289	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	19:45	20:03	0:18	LOAD CURTAILMENT
290	7-Jun-22	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	21:05	22:20	1:15	LOAD CURTAILMENT
291	7-Jun-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	19:45	20:03	0:18	LOAD CURTAILMENT
292	7-Jun-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	21:05	22:20	1:15	LOAD CURTAILMENT
293	7-Jun-22	TUMKUR	66	HIRIYUR 220KV-SIRA(HIRIYUR)	HIRIYUR_66	21:02	22:20	1:17	LOAD CURTAILMENT
294	7-Jun-22	TUMKUR	66	HIRIYUR 220KV-SIRA(HIRIYUR)	HIRIYUR_66	19:47	22:18	2:31	LOAD CURTAILMENT
295	7-Jun-22	TUMKUR	66	HOSADURRG-MATHOD	HOSADURGA_66	14:48	15:20	0:32	MAIN SUPPLY FAILURE
296	7-Jun-22	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	13:46	13:47	0:01	LINE FAULT
297	7-Jun-22	TUMKUR	66	TR-1	CHITRADURGA:66	13:58	14:07	0:09	TRANSFORMER FAULT
298	7-Jun-22	TUMKUR	66	TR-1	HOLALKERE_66	12:25	12:50	0:25	LINE CLEAR AVAILED
299	7-Jun-22	TUMKUR	66	TR-1	SANTEMNAVATTUR_66	16:07	16:51	0:44	LINE CLEAR AVAILED
300	7-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	19:45	20:15	0:30	MAIN SUPPLY FAILURE
301	7-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	21:05	22:15	1:10	MAIN SUPPLY FAILURE
302	7-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	22:50(7.6.22)			MAIN SUPPLY FAILURE
303	7-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	22:50(7.6.22)	1:40(8.6.22)	2:50	TRANSFORMER CHARGED
304	7-Jun-22	TUMKUR	66	TR-1(LV)	THALLAK_220	17:30	18:35	1:05	TRANSFORMER FAULT
305	7-Jun-22	TUMKUR	66	TR-2	HOLALKERE_66	10:35	10:40	0:05	TRANSFORMER FAULT
306	7-Jun-22	TUMKUR	66	TR-2	HOSAKERE_66	17:10	19:00	1:50	LINE CLEAR AVAILED
307	7-Jun-22	TUMKUR	66	TR-3	HOLALKERE_66	15:05	16:55	1:50	LINE CLEAR AVAILED
308	7-Jun-22	TUMKUR	220	GUTTUR 400KV- HAVERI 1 & 2	HAVERI_220	13:56	14:16	0:19	LINE FAULT
309	7-Jun-22	TUMKUR	220	TR-1	THALLAK_220	17:30	18:35	1:05	TRANSFORMER FAULT
310	7-Jun-22	TUMKUR	220	TR-2	HIRIYUR_220	19:45	19:58	0:13	TRANSFORMER FAULT
311	7-Jun-22	TUMKUR	220	TR-2	HIRIYUR_220	21:05	21:15	0:10	TRANSFORMER FAULT
312	7-Jun-22	TUMKUR	220	TR-2	THALLAK_220	15:05	18:33	3:28	LINE CLEAR AVAILED
313	8-Jun-22	BAGALKOT	110	110/11KV, HV1	ZALKI_110	20:37	22:40	2:03	TRANSFORMER FAULT
314	8-Jun-22	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	14:49	15:07	0:18	TRANSFORMER FAULT
315	8-Jun-22	BAGALKOT	110	110/11KV, HV1	MURDESHWAR_110	12:57	13:45	0:48	LINE CLEAR AVAILED
316	8-Jun-22	BAGALKOT	110	110/11KV, HV1	KUMTA_110	10:05	11:45	1:40	LINE CLEAR AVAILED
317	8-Jun-22	BAGALKOT	110	110/11KV, HV1	SIRSI_220	11:08	13:33	2:25	LINE CLEAR AVAILED
318	8-Jun-22	BAGALKOT	110	110/11KV, HV2	RANEBENNUR_220	10:14	15:54	5:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
319	8-Jun-22	BAGALKOT	110	110/11KV, HV2	RANEBENNUR_220	16:16	18:43	2:27	LINE CLEAR AVAILED
320	8-Jun-22	BAGALKOT	110	110/11KV, HV1	DEVARAGENNUR_110	1:45	6:00	4:15	TRANSFORMER FAULT
321	8-Jun-22	BAGALKOT	110	110/11KV, HV1	KALAGATAGI_110	11:01	14:41	3:40	LINE CLEAR AVAILED
322	8-Jun-22	BAGALKOT	110	110/11KV, HV1	KULAGERI CROSS_110	11:20	14:23	3:03	LINE CLEAR AVAILED
323	8-Jun-22	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	10:19	16:25	6:06	LINE CLEAR AVAILED
324	8-Jun-22	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	1:12	1:53	0:41	TRANSFORMER FAULT
325	8-Jun-22	BAGALKOT	110	110/11KV, HV1(HV2)	GULEDAGUDDA_110	19:03	19:14	0:11	TRANSFORMER FAULT
326	8-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
327	8-Jun-22	BAGALKOT	110	110/11KV, HV2	BABLESHWAR_110	6:48	7:40	0:52	LINE CLEAR AVAILED
328	8-Jun-22	BAGALKOT	110	110/11KV, HV2	DEVAGOAN_110	11:45	12:19	0:34	TRANSFORMER FAULT
329	8-Jun-22	BAGALKOT	110	110/11KV, HV2	KULAGERI CROSS_110	14:23	16:42	2:19	LINE CLEAR AVAILED
330	8-Jun-22	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	1:43	6:21	4:38	TRANSFORMER FAULT
331	8-Jun-22	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	19:54	20:01	0:07	TRANSFORMER FAULT
332	8-Jun-22	BAGALKOT	110	110/11KV, HV2	MANTUR(GHP)_110	9:43	10:10	0:27	TRANSFORMER FAULT
333	8-Jun-22	BAGALKOT	110	110/11KV, HV2(HV3)	GOPANAKOPPA_110	13:02	14:23	1:21	LINE CLEAR AVAILED
334	8-Jun-22	BAGALKOT	110	110/33KV, HV3	RANEBENNUR_220, KUPPELUR_33, GUDUR MAIDUR_33, HALGERI_33	10:12	17:39	7:27	LINE CLEAR AVAILED
335	8-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
336	8-Jun-22	BAGALKOT	110	110/33KV, HV4	RANEBENNUR_220, KUPPELUR_33, GUDUR MAIDUR_33, HALIGERI_33	10:12	17:40	7:28	LINE CLEAR AVAILED
337	8-Jun-22	BAGALKOT	110	110/33KV, HV2	TEGGI_33 BISNAL_110	19:18	19:25	0:07	TRANSFORMER FAULT
338	8-Jun-22	BAGALKOT	110	110/33KV, HV2	KERUR_33, KAROSHI_33 CHIKKODI_110	18:12	18:21	0:09	TRANSFORMER FAULT
339	8-Jun-22	BAGALKOT	110	110/33KV, HV2	JAMAKHANDI_110	12:30	18:44	6:14	LINE CLEAR AVAILED
340	8-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
341	8-Jun-22	BAGALKOT	110	ATHANI220- SATTI	ATHANI_220	20:38	20:45	0:07	LINE FAULT
342	8-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR1	STATION NOT AFFECTED BAGEWADI_220	11:30	12:45	1:15	LINE CLEAR AVAILED
343	8-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR2	STATION NOT AFFECTED BAGEWADI_220	12:39	13:54	1:15	LINE CLEAR AVAILED
344	8-Jun-22	BAGALKOT	110	BANAHATTI-JAMAKHANDI(NAVALAGI)	NAVALAGI_110	23:37	23:43	0:06	HAND TRIPPED
345	8-Jun-22	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED BIDNAL_220	10:09	14:11	4:02	NFBC ISSUED
346	8-Jun-22	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	10:09	17:10	7:01	LINE CLEAR AVAILED
347	8-Jun-22	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR_110	10:20	16:20	6:00	LINE CLEAR AVAILED
348	8-Jun-22	BAGALKOT	110	GADAG220- SAMBAPUR ROAD	GADAG_220	10:40	11:54	1:14	LINE CLEAR AVAILED
349	8-Jun-22	BAGALKOT	110	GADAG-SAMBAPUR ROAD	STATION NOT AFFECTED SAMBAPUR ROAD	10:46	11:54	1:08	NFBC ISSUED
350	8-Jun-22	BAGALKOT	110	HUNGUND-KBJNL	STATION NOT AFFECTED HUNGUND_110	20:14	20:22	0:08	LINE FAULT
351	8-Jun-22	BAGALKOT	110	HUNGUND-KBJNL	HUNGUND_110	20:22 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
352	8-Jun-22	BAGALKOT	110	KUMATA- KRCL	STATION NOT AFFECTED KUMTA_110	0:48	0:53	0:05	LINE FAULT
353	8-Jun-22	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	23:20	23:29	0:09	LINE FAULT
354	8-Jun-22	BAGALKOT	110	MK HUBLI220- MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	13:32 (06.06.2022)			LINE OPEN :LINE CLEAR AAVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
355	8-Jun-22	BAGALKOT	110	MUGALKHOD- HIDIKAL2(ITANAL2)	STATION NOT AFFECTED ITNAL_110	11:25	13:49	2:24	LINE CLEAR AVAILED
356	8-Jun-22	BAGALKOT	110	MUGALKHOD- ITANAL1	STATION NOT AFFECTED MUGALKHOD_220	11:14	13:48	2:34	LINE CLEAR AVAILED
357	8-Jun-22	BAGALKOT	110	MUGALKHOD- ITANAL2	STATION NOT AFFECTED MUGALKHOD_220	11:15	13:48	2:33	LINE CLEAR AVAILED
358	8-Jun-22	BAGALKOT	110	MUGALKHOD- RAIBAG2(ITANAL1)	STATION NOT AFFECTED ITNAL_110	11:25	13:48	2:23	LINE CLEAR AVAILED
359	8-Jun-22	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	10:34	17:06	6:32	LINE CLEAR AVAILED
360	8-Jun-22	BAGALKOT	110	NAVALGUND-BIO DHARWAD	NAVALGUND_110	10:05	18:35	8:30	LINE CLEAR AVAILED
361	8-Jun-22	BAGALKOT	110	NAVALGUND-KONNUR	NAVALGUND_110	10:03 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
362	8-Jun-22	BAGALKOT	110	NAVALGUND-NOKAR SOLAR	NAVALGUND_110	10:05	17:10	7:05	LINE CLEAR AVAILED
363	8-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
364	8-Jun-22	BAGALKOT	110	RANEENNUR- AREMALLAPUR (HONNATTI)	RANEENNUR_220	17:55	19:13	1:18	LINE CLEAR AVAILED
365	8-Jun-22	BAGALKOT	110	RANEENNUR-HOSAHONNATTI	STATION NOT AFFECTED HOSAHONNATTI_110	17:57	19:20	1:23	LINE CLEAR AVAILED
366	8-Jun-22	BAGALKOT	110	SATTI-RABAKAVI	RABKAVI_110	20:48	20:51	0:03	LINE FAULT
367	8-Jun-22	BAGALKOT	110	SHIGGOAN- RAMANAKOPPA(MUNDAGOD)	STATION NOT AFFECTED SHIGGOAN_110	11:25	12:28	1:03	LINE CLEAR AVAILED
368	8-Jun-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LIE OPEN: LINE FAULT
369	8-Jun-22	BAGALKOT	110	SOUDATTI-RAMDURGA2	STATION NOT AFFECTED RAMDURGA_110	10:54	13:44	2:50	LINE CLEAR AVAILED
370	8-Jun-22	BAGALKOT	110	SOUDATTI-SOUDATTI2	STATION NOT AFFECTED SOUDATTI_110	10:55	13:40	2:45	LINE CLEAR AVAILED
371	8-Jun-22	BAGALKOT	110	TAKKALAKI- TIKOTA	TAKKALAKI_110	7:18	8:19	1:01	NFBC ISSUED
372	8-Jun-22	BAGALKOT	110	TIKOTA- BHUTANAL (TAKKALAKI)	TIKOTA_110	7:27	8:19	0:52	NFBC ISSUED
373	8-Jun-22	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED CHIKKODI_220	12:20	13:25	1:05	LINE CLEAR AVAILED
374	8-Jun-22	BAGALKOT	220	220/110KV, HV2	BELGAUM_220	17:50 (07.06.2022)	18:33 (08.06.2022)	24:43 hrs	TRANSFORMER CHARGED
375	8-Jun-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED CHIKKODI_220	11:42	12:18	0:36	LINE CLEAR AVAILED
376	8-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1 (AEQUS1)	STATION NOT AFFECTED BELGAUM_220	22:06 (07.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
377	8-Jun-22	BAGALKOT	220	BELGAUM- KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	21:38 (06.06.2022)	11:45 (08.06.2022)	38:07 hrs	LINE CHARGED
378	8-Jun-22	BAGALKOT	220	BIDNAL-NAGJHARI	STATION NOT AFFECTED BIDNAL_220	16:22	16:27	0:05	LINE CLEAR AVAILED
379	8-Jun-22	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	10:40	15:04	4:24	LINE CLEAR AVAILED
380	8-Jun-22	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	15:50 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
381	8-Jun-22	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	9:04 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
382	8-Jun-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	19:41 (06.06.2022)	18:03 (08.06.2022)	46:22 hrs	LINE CHARGED
383	8-Jun-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	11:24 (07.06.2022)	18:05 (08.06.2022)	30:41 hrs	LINE CHARGED
384	8-Jun-22	BAGALKOT	220	KARWAR- KADRA1	STATION NOT AFFECTED KARWAR_220	09:07	18:51	9:44	NFBC ISSUED
385	8-Jun-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	21:37 (06.06.2022)	11:45 (08.06.2022)	38:08 hrs	LINE CHARGED
386	8-Jun-22	BAGALKOT	220	NARENDRA- HAVERI (BIDNAL)	STATION NOT AFFECTED NARENDRA_220	10:40	15:05	4:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
387	8-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
388	8-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
389	8-Jun-22	BAGALKOT	220	SOUDATTI220- RAMDURGA2	STATION NOT AFFECTED SOUDATTI_220	10:51	13:43	2:52	LINE CLEAR AVAILED
390	8-Jun-22	BAGALKOT	220	SOUDATTI220- SOUDATTI2	STATION NOT AFFECTED SOUDATTI_220	10:55	13:40	2:45	LINE CLEAR AVAILED
391	8-Jun-22	BAGALKOT	220	VAJRAMATTI220- MANTUR2(B)	VAJRAMATTI_220, MANTUR(B)_110, SHIROL_110, MAREGUDDI_110, MUNDAGANUR_110	10:06	15:25	5:19	LINE CLEAR AVAILED
392	8-Jun-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	BG ROAD	18:40	18:42	0:02	LOAD CHANGE OVER
393	8-Jun-22	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	15:04	15:07	0:03	LOAD CHANGE OVER
394	8-Jun-22	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	17:13	17:18	0:05	LOAD CHANGE OVER
395	8-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC(EHT)	ACC(EHT)	8:15	18:04	9:49	LINE CLEAR AVAILED
396	8-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - DB1	MANCHENAHALLI	9:12	10:47	1:35	LINE CLEAR AVAILED
397	8-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - DB2	THONDEBHAVI, GUNDAMGERE	8:15	18:02	9:47	LINE CLEAR AVAILED
398	8-Jun-22	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	7:42(08/06/2022)			LIE OPEN: LINE FAULT
399	8-Jun-22	BENGALURU	66	HV1	KOTIPURA 220	15:00	15:25	0:25	LINE CLEAR AVAILED
400	8-Jun-22	BENGALURU	66	HV1	NIMHANS 220	9:41	9:43	0:02	LINE CLEAR AVAILED
401	8-Jun-22	BENGALURU	66	HV1	GODUR	12:50	13:00	0:10	TRANSFORMER FAULT
402	8-Jun-22	BENGALURU	66	HV1	PATHPALYA	10:30	10:52	0:22	TRANSFORMER FAULT
403	8-Jun-22	BENGALURU	66	HV1	VOLVO	11:45	11:47	0:02	LINE CLEAR AVAILED
404	8-Jun-22	BENGALURU	66	HV1	JIGANI 220	18:01	18:13	0:12	TRANSFORMER FAULT
405	8-Jun-22	BENGALURU	66	HV1	Y HUNSENAHALLI	14:25	14:35	0:10	TRANSFORMER FAULT
406	8-Jun-22	BENGALURU	66	HV2	ISKON	11:07	11:10	0:03	LINE CLEAR AVAILED
407	8-Jun-22	BENGALURU	66	HV2	NRS 220	22:30	22:37	0:07	LOAD CHANGE OVER
408	8-Jun-22	BENGALURU	66	HV2	SARIJAPURA	8:19	8:31	0:12	TRANSFORMER FAULT
409	8-Jun-22	BENGALURU	66	HV2	VOLVO	13:30	13:33	0:03	LINE CLEAR AVAILED
410	8-Jun-22	BENGALURU	66	HV3	YARANDANAHALLI 220	3:15	3:43	0:28	TRANSFORMER FAULT
411	8-Jun-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	15:04	15:07	0:03	LOAD CHANGE OVER
412	8-Jun-22	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	11:30	14:26	2:56	LINE FAULT
413	8-Jun-22	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	13:42	14:26	0:44	LINE CLEAR AVAILED
414	8-Jun-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:46	13:20	2:34	LINE CLEAR AVAILED
415	8-Jun-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	10:49	18:03	7:14	LINE CLEAR AVAILED
416	8-Jun-22	BENGALURU	220	KUMBALAGODU 220 - VRISHABHAVATHI 220	NO STATION AFFECTED	16:23	18:02	1:39	LINE FAULT
417	8-Jun-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KU RUGOD_110,SHATAVAHANA_IPP,AGA RWAL_IPP,SUZLON_IPP,KAMALAPUR _110,MATR_110,RBNS FACTORY	23:19	23:26	0:07	LINE FAULT
418	8-Jun-22	GULBARGA	110	AURDA-DONGARAGOA	DONGARGOA_110	11:20	11:25	0:05	LINE FAULT
419	8-Jun-22	GULBARGA	110	CHIDRI-HUMNABAD2	CHIDRI_110	17:20	17:50	0:30	MAIN SUPPLY FAILURE
420	8-Jun-22	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	7:50	10:05	2:15	LINE CLEAR AVAILED
421	8-Jun-22	GULBARGA	110	HALBARGA-CHIDRI 1	KAMTHANA_110,HABSIKOTE_110	17:21	17:30	0:09	LINE FAULT
422	8-Jun-22	GULBARGA	110	HALBARGA-CHIDRI 1	KAMTHANA_110,HABSIKOTE_110	18:07	18:13	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
423	8-Jun-22	GULBARGA	110	HV2	SHAHAPUR_110	21:25	23:25	2:00	LINE CLEAR AVAILED
424	8-Jun-22	GULBARGA	110	HV2	NALWAR_110	20:20	20:25	0:05	TRANSFORMER FAULT
425	8-Jun-22	GULBARGA	110	HV2	CHOWDAPUR_110	13:50	14:00	0:10	TRANSFORMER FAULT
426	8-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	13:50	13:56	0:06	TRANSFORMER FAULT
427	8-Jun-22	GULBARGA	110	HV3	CHINCHOLI_110	17:40	17:48	0:08	LOAD CURTAILMENT
428	8-Jun-22	GULBARGA	110	HV3	SHAHAPUR_110	22:05	23:25	1:20	TRANSFORMER FAULT
429	8-Jun-22	GULBARGA	110	HV4	DEODURGA_110	20:00(05.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
430	8-Jun-22	GULBARGA	110	MUDAPUR-MASKI	MASKI_110	5:21	5:25	0:04	LINE FAULT
431	8-Jun-22	GULBARGA	110	MUDAPUR-SINDHANOOR	MUDAPUR_110,MASKI_110	2:43	2:50	0:07	MAIN SUPPLY FAILURE
432	8-Jun-22	GULBARGA	110	NALWAR-SHAHAPUR1	NALWAR_110	20:50	22:20	1:30	LINE FAULT
433	8-Jun-22	GULBARGA	110	NALWAR-SHAHAPUR2	NALWAR_110	20:50(08.05.2022)			LIE OPEN: LINE FAULT
434	8-Jun-22	GULBARGA	110	NALWAR-SHAHAPUR2	NALWAR_110	3:10	3:30	0:20	LINE FAULT
435	8-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_1	GABBUR_110	14:52	15:10	0:18	LINE CLEAR AVAILED
436	8-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	7:50	10:30	2:40	LINE CLEAR AVAILED
437	8-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	14:52	14:57	0:05	LINE CLEAR AVAILED
438	8-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	14:52	14:57	0:05	LINE FAULT
439	8-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	18:48	21:20	2:32	LINE CLEAR AVAILED
440	8-Jun-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	12:35	12:50	0:15	LINE CLEAR AVAILED
441	8-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WAD AGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
442	8-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	21:56	22:03	0:07	LINE CLEAR AVAILED
443	8-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110	20:48	21:24	0:36	LINE FAULT
444	8-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110	21:26	22:04	0:38	LINE CLEAR AVAILED
445	8-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KHANAP UR_110,WADGERA_110	21:58	22:18	0:20	LINE FAULT
446	8-Jun-22	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	20:28	20:40	0:12	LINE FAULT
447	8-Jun-22	GULBARGA	220	HV1	HALAWARTHI_220	15:06	17:04	1:58	LINE CLEAR AVAILED
448	8-Jun-22	GULBARGA	220	HV1&LV1	HALBARGA_220	16:30	17:13	0:43	LINE CLEAR AVAILED
449	8-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
450	8-Jun-22	GULBARGA	220	ITTAGI-NEELAGUNDA	ITTAGI_220	6:44	7:00	0:16	LINE FAULT
451	8-Jun-22	GULBARGA	220	SEDAM-HUMNABAD_1	HUMNABAD_220	19:05	22:35	3:30	LINE FAULT
452	8-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	20:28 (08.06.2022)			LIE OPEN: LINE FAULT
453	8-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	20:28	22:30	2:02	LINE FAULT
454	8-Jun-22	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	10:14	18:23	8:09	LINE CLEAR AVAILED
455	8-Jun-22	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	7:29 (6.06.2022)	18:50 (08.06.2022)	59:21 HRS	LINE CHARGED
456	8-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
457	8-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	RTPS_400	17:06 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
458	8-Jun-22	HASSAN	66	HV1	AREHALLY_66	17:55(07.08.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
459	8-Jun-22	HASSAN	66	HV1	HALEBEEDU_66	13:40	13:50	0:10	HAND TRIPPED
460	8-Jun-22	HASSAN	66	HV1	NAGARTHI_110	10:40	14:30	3:50	LINE CLEAR AVAILED
461	8-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
462	8-Jun-22	HASSAN	66	HV2	BELUR_66	11:45	12:55	1:10	LINE CLEAR AVAILED
463	8-Jun-22	HASSAN	66	HV2	HALEBEEDU_66	13:40	13:50	0:10	HAND TRIPPED
464	8-Jun-22	HASSAN	110	HV1	GURUPURA_110	10:12	11:35	1:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
465	8-Jun-22	HASSAN	110	HV1	SAGARA_110	10:00	17:15	7:15	LINE CLEAR AVAILED
466	8-Jun-22	HASSAN	110	HV2	GURUPURA_110	11:44	14:11	2:27	LINE CLEAR AVAILED
467	8-Jun-22	HASSAN	110	HV2	SAGARA_110	10:00	17:15	7:15	LINE CLEAR AVAILED
468	8-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
469	8-Jun-22	HASSAN	110	HV3	SAGARA_110	10:00	17:30	7:30	LINE CLEAR AVAILED
470	8-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
471	8-Jun-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	18:45(07.06.2022)	10:48(08.06.2022)	16:03HRS	LINE CHARGED
472	8-Jun-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LIE OPEN: LINE FAULT
473	8-Jun-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:22	13:03	3:41	LINE CLEAR AVAILED
474	8-Jun-22	HASSAN	110	SAGARA-ALKLA	SAGARA_110	11:35	12:30	0:55	LINE CLEAR AVAILED
475	8-Jun-22	HASSAN	110	SAGARA-JST1	SAGARA_110	12:35	13:15	0:40	LINE CLEAR AVAILED
476	8-Jun-22	HASSAN	110	SAGARA-JST2	SAGARA_110	13:15	13:40	0:25	LINE CLEAR AVAILED
477	8-Jun-22	HASSAN	110	SAGARA-SAGAR	SAGARA_110	10:00	17:00	7:00	LINE CLEAR AVAILED
478	8-Jun-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:25	14:41	4:16	LINE CLEAR AVAILED
479	8-Jun-22	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:56	13:49	2:53	LINE CLEAR AVAILED
480	8-Jun-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	10:58	13:45	2:47	LINE CLEAR AVAILED
481	8-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
482	8-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
483	8-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED
484	8-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
485	8-Jun-22	MYSURU	66	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	10:38	12:07	1:29	LINE CLEAR AVAILED
486	8-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
487	8-Jun-22	MYSURU	66	HOOTAGALLY-KAGGERE HAMPAPURA	KAGGERE HAMPAPURA_66	10:19	15:20	5:01	NFBC ISSUED
488	8-Jun-22	MYSURU	66	HV2	SINDHUVALLI_66	21:00	21:05	0:05	TRANSFORMER FAULT
489	8-Jun-22	MYSURU	66	HV2	SINDHUVALLI_66	21:10	21:15	0:05	TRANSFORMER FAULT
490	8-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
491	8-Jun-22	MYSURU	66	K R PETE 220-KR PETE 1	NO STATIONS EFFECTED	0:02	0:07	0:05	LINE FAULT
492	8-Jun-22	MYSURU	66	KK HALLI-SHIMSHA	NO STATIONS EFFECTED	10:47	12:10	1:23	LINE CLEAR AVAILED
493	8-Jun-22	MYSURU	66	KUSHALANAGARA-MYSORE 1	MIRLE_66	11:03	12:04	1:01	LINE CLEAR AVAILED
494	8-Jun-22	MYSURU	66	MADHUVANHALLY-KUNTUR	NO STATIONS EFFECTED	5:32	5:37	0:05	LINE FAULT
495	8-Jun-22	MYSURU	66	YARAHALLI HANDPOST-HD KOTE	ANTHARSANTHE_66 HDKOTE_66	10:00	18:20	8:20	NFBC ISSUED
496	8-Jun-22	MYSURU	220	TUBINAKERE-YELIYURU	NO STATIONS EFFECTED	10:34	13:39	3:05	LINE CLEAR AVAILED
497	8-Jun-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENAHALLI_66	8:01	8:17	0:15	LINE FAULT
498	8-Jun-22	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66	6:15	6:20	0:05	MAIN SUPPLY FAILURE
499	8-Jun-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	17:15	17:35	0:20	MAIN SUPPLY FAILURE
500	8-Jun-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	10:25	11:35	1:10	MAIN SUPPLY FAILURE
501	8-Jun-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	12:00	13:55	1:55	MAIN SUPPLY FAILURE
502	8-Jun-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	8:41	8:50	0:09	LINE FAULT
503	8-Jun-22	TUMKUR	66	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:24	9:54	0:29	HAND TRIPPED
504	8-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:24	9:53	0:29	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
505	8-Jun-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	4:46	7:52	3:05	LINE FAULT
506	8-Jun-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WLSPNSOLAR1	7:51	8:07	0:16	HAND TRIPPED
507	8-Jun-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WLSPNSOLAR2	7:51	8:07	0:16	HAND TRIPPED
508	8-Jun-22	TUMKUR	66	TR-1	CHITRAHALLI_66	0:25	0:26	0:01	TRANSFORMER FAULT
509	8-Jun-22	TUMKUR	66	TR-1	CHITRAHALLI_66	12:20	12:30	0:10	TRANSFORMER FAULT
510	8-Jun-22	TUMKUR	66	TR-1	HONNALLI_66	10:50	11:49	0:59	LINE CLEAR AVAILED
511	8-Jun-22	TUMKUR	66	TR-1	RANGANATHAPURA_66	7:51	8:05	0:13	HAND TRIPPED
512	8-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	22:50(7.6.22)	1:40(8.6.22)	2:50	TRANSFORMER CHARGED
513	8-Jun-22	TUMKUR	66	TR-2	RANGANATHAPURA_66	7:51	8:04	0:13	HAND TRIPPED
514	8-Jun-22	TUMKUR	66	TR-3	HARIYABBE_66	7:53	7:56	0:03	TRANSFORMER FAULT
515	8-Jun-22	TUMKUR	110	NITTUR 220kv- DODDAGUNI	DODDAGUNI_110	12:06	14:20	2:13	LINE CLEAR AVAILED
516	8-Jun-22	TUMKUR	110	NITTUR 220kv- GUBBI	GUBBI_110, BIDARE_110	12:06	14:20	2:13	LINE CLEAR AVAILED
517	8-Jun-22	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	12:06	14:20	2:13	LINE CLEAR AVAILED
518	8-Jun-22	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR_110	12:06	14:20	2:13	LINE CLEAR AVAILED
519	8-Jun-22	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	12:06	14:20	2:13	LINE CLEAR AVAILED
520	8-Jun-22	TUMKUR	110	NITTUR 220kv- SOMALAPURA	SOMALAPURA_66	12:06	14:20	2:13	LINE CLEAR AVAILED
521	8-Jun-22	TUMKUR	110	TR-1	NITTUR_110	12:05	12:21	0:16	LINE CLEAR AVAILED
522	8-Jun-22	TUMKUR	110	TR-1	NITTUR_110	12:06	14:10	2:03	LINE CLEAR AVAILED
523	8-Jun-22	TUMKUR	110	TR-2	NITTUR_110	12:06	14:20	2:13	LINE CLEAR AVAILED
524	8-Jun-22	TUMKUR	220	ANTHRASANAHALLI 220KV- K B CROSS_220	ANTHRASANAHALLI 220	16:22	17:04	0:42	LINE FAULT
525	8-Jun-22	TUMKUR	220	TR-2(HV & LV)	DAVANGERE_220	9:27(8.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
526	9-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
527	9-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
528	9-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
529	9-Jun-22	BAGALKOT	110	MK HUBLI220- MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	13:32 (06.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
530	9-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1 (AEQUS1)	STATION NOT AFFECTED BELGAUM_220	22:06 (07.06.2022)	17:17 (09.06.2022)	43:11 hrs	LINE CHARGED
531	9-Jun-22	BAGALKOT	110	HUNGUND-KBJNL	HUNGUND_110	20:22 (08.06.2022)	10:46 (09.06.2022)	14:24 hrs	LINE CHARGED
532	9-Jun-22	BAGALKOT	110	NAVALGUND-KONNUR	NAVALGUND_110	10:03 (08.06.2022)	18:24 (09.06.2022)	32:21 hrs	LINE CHARGED
533	9-Jun-22	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	15:50 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
534	9-Jun-22	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	9:04 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
535	9-Jun-22	BAGALKOT	110	AINAPUR-ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	9:21	18:07	8:46	LINE CLEAR AVAILED
536	9-Jun-22	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	STATION NOT AFFECTED ALBAL_110	1:56	2:05	0:09	LINE FAULT
537	9-Jun-22	BAGALKOT	110	ALBAL-RAY SOLAR	STATION NOT AFFECTED ALBAL_110	1:56	2:05	0:09	LINE FAULT
538	9-Jun-22	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	19:43	19:52	0:09	LINE CLEAR AVAILED
539	9-Jun-22	BAGALKOT	110	THORVI-BHUTNAL	STATION NOT AFFECTED THORVI_110	6:16	11:54	5:38	NFBC ISSUED
540	9-Jun-22	BAGALKOT	110	110/11KV,HV1	DEVARAGENNUR_110	9:56	13:21	3:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
541	9-Jun-22	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	10:21	16:40	6:19	LINE CLEAR AVAILED
542	9-Jun-22	BAGALKOT	110	HOSAHONNATTI-RANEENNUR	HOSAHONNATTI_110	10:35	16:40	6:05	LINE CLEAR AVAILED
543	9-Jun-22	BAGALKOT	110	HOSAHONNATTI-GUTTAL	HOSAHONNATTI_110	10:35	16:40	6:05	LINE CLEAR AVAILED
544	9-Jun-22	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	10:23	10:25	0:02	LINE CLEAR AVAILED
545	9-Jun-22	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110	10:57	18:36	7:39	LINE CLEAR AVAILED
546	9-Jun-22	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	12:34	18:32	5:58	LINE CLEAR AVAILED
547	9-Jun-22	BAGALKOT	110	KNM SOLAR(BALAJI SUGARS)- MUDEBIHAL	STATION NOT AFFECTED MUDEBIHAL_110	1:44	2:15	0:31	LINE FAULT
548	9-Jun-22	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	14:13	16:32	2:19	LINE CLEAR AVAILED
549	9-Jun-22	BAGALKOT	110	110/11KV,HV1(HV2)	RAMANAKOPPA_110	11:06	17:17	6:11	LINE CLEAR AVAILED
550	9-Jun-22	BAGALKOT	220	BIDNAL- HUBLI1	STATION NOT AFFECTED BIDNAL_220	9:41	13:31	3:50	NFBC ISSUED
551	9-Jun-22	BAGALKOT	220	BIDNAL- NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	12:22	19:52	7:30	LINE FAULT
552	9-Jun-22	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	13:57	16:26	2:29	LINE FAULT
553	9-Jun-22	BAGALKOT	220	BELGAUM- AEQUS2	STATION NOT AFFECTED BELGAUM_220	12:05	19:08	7:03	LINE CLEAR AVAILED
554	9-Jun-22	BAGALKOT	220	CHIKKODI- AEQUS2	STATION NOT AFFECTED CHIKKODI_220	12:05	19:30	7:25	NFBC ISSUED
555	9-Jun-22	BAGALKOT	220	CHIKKODI- KUDACHI2	STATION NOT AFFECTED CHIKKODI_220	12:30	12:55	0:25	LINE CLEAR AVAILED
556	9-Jun-22	BAGALKOT	220	CHIKKODI- MUGALKHOD1	STATION NOT AFFECTED CHIKKODI_220	14:30	15:50	1:20	LINE CLEAR AVAILED
557	9-Jun-22	BAGALKOT	220	CHIKKODI- AEQUS1	STATION NOT AFFECTED CHIKKODI_220	16:52	18:38	1:46	LINE CLEAR AVAILED
558	9-Jun-22	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	11:16	15:11	3:55	LINE CLEAR AVAILED
559	9-Jun-22	BAGALKOT	220	DHONI-GADAG2	STATION NOT AFFECTED DHONI_400	15:15	17:57	2:42	LINE CLEAR AVAILED
560	9-Jun-22	BAGALKOT	220	GADAG- LINGAPUR1(DHONI1)	STATION NOT AFFECTED GADAG_220	11:16	15:11	3:55	LINE CLEAR AVAILED
561	9-Jun-22	BAGALKOT	220	GADAG- LINGAPUR2(DHONI2)	STATION NOT AFFECTED GADAG_220	15:15	17:57	2:42	LINE CLEAR AVAILED
562	9-Jun-22	BAGALKOT	110	KUDACHI220- AINAPUR	STATION NOT AFFECTED KUDACHI_220	9:47	17:53	8:06	LINE CLEAR AVAILED
563	9-Jun-22	BAGALKOT	220	KUDACHI- CHIKKODI1	STATION NOT AFFECTED KUDACHI_220	11:24	11:29	0:05	LINE CLEAR AVAILED
564	9-Jun-22	BAGALKOT	220	MUGALKHOD-CHIKKODI1	STATION NOT AFFECTED MUGALKHOD_220	15:32	15:50	0:18	HAND TRIPPED
565	9-Jun-22	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	13:56	15:52	1:56	LINE FAULT
566	9-Jun-22	BAGALKOT	220	HUBLI- BIDNAL1	STATION NOT AFFECTED HUBLI_220	9:41	13:32	3:51	LINE CLEAR AVAILED
567	9-Jun-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:42	21:25	10:43	LINE FAULT
568	9-Jun-22	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	10:56	21:24	10:28	LINE CLEAR AVAILED
569	9-Jun-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED VAJRAMATTI_220	16:05	16:57	0:52	LINE CLEAR AVAILED
570	9-Jun-22	BAGALKOT	110	110/11KV, HV1	ZALKI_110	11:08	12:27	1:19	LINE CLEAR AVAILED
571	9-Jun-22	BAGALKOT	110	110/11KV, HV1	ZALKI_110	14:05	14:49	0:44	LINE CLEAR AVAILED
572	9-Jun-22	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	17:39	19:04	1:25	TRANSFORMER FAULT
573	9-Jun-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LIE OPEN: LINE FAULT
574	9-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
575	9-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
576	9-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
577	9-Jun-22	BAGALKOT	110	110/11KV, HV1	CHIKKODI_220	13:05	13:10	0:05	TRANSFORMER FAULT
578	9-Jun-22	BAGALKOT	110	110/33KV, HV3	ANKALI_110	16:25	17:15	0:50	LINE CLEAR AAVAILED
579	9-Jun-22	BAGALKOT	110	SOUDATTI-UDAKERI	STATION NOT AFFECTED SOUDATTI_220	6:57	12:03	5:06	LINE CLEAR AAVAILED
580	9-Jun-22	BAGALKOT	110	SOUDATTI-UDIKERI	UDAKERI_110	6:57	12:03	5:06	NFBC ISSUED
581	9-Jun-22	BAGALKOT	110	110/11KV,HV2	KATARKI_110	10:05	14:23	4:18	LINE CLEAR AAVAILED
582	9-Jun-22	BAGALKOT	110	VAJRAMATTI220 -SIRAGUPPI	SHIRAGUPPI_110 ,BILAGI_110, TOLAMATTI_110, BISNAL_110, GIRISAGAR_110	14:27	14:32	0:05	LINE FAULT
583	9-Jun-22	BAGALKOT	110	VAJRAMATTI-K D JAMBAGI	K.D JAMBAGI_110	17:49	18:08	0:19	LINE FAULT
584	9-Jun-22	BAGALKOT	220	CHIKKODI- KUDACHI1	STATION NOT AFFECTED CHIKKODI_220	11:25	12:30	1:05	LINE CLEAR AAVAILED
585	10-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
586	10-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
587	10-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
588	10-Jun-22	BAGALKOT	110	MK HUBLI220- MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	13:32 (06.06.2022)	17:40 (10.06.2022)	100:08 hrs	LINE CHARGED
589	10-Jun-22	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	15:50 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
590	10-Jun-22	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	9:04 (08.06.2022)	16:44 (10.06.2022)	55:40 hrs	LINE CHARGED
591	10-Jun-22	BAGALKOT	110	SHIRHATTI-BPCL-2	STATION NOT AFFECTED SHIRHATTI_110	21:25	21:28	0:03	HAND TRIPPED
592	10-Jun-22	BAGALKOT	110	KAMBAGI-TODALBAGI	STATION NOT AFFECTED KAMBAGI_110	15:57	17:26	1:29	LINE CLEAR AAVAILED
593	10-Jun-22	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	13:12	17:58	4:46	LINE CLEAR AAVAILED
594	10-Jun-22	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	14:18	14:55	0:37	LINE CLEAR AAVAILED
595	10-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1(AEQUS1)	BELGAUM_220	20:03 (10.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
596	10-Jun-22	BAGALKOT	110	NARENDRA- BELUR1	NARENDRA_220	11:03	15:04	4:01	LINE CLEAR AAVAILED
597	10-Jun-22	BAGALKOT	220	220/110KV, HV1&LV1	RANEBENNUR_220	18:57	19:02	0:05	HAND TRIPPED
598	10-Jun-22	BAGALKOT	110	110/11KV,HV1	DADDI_110	11:18	13:00	1:42	LINE CLEAR AAVAILED
599	10-Jun-22	BAGALKOT	110	110/11KV,HV1	DEVAGOAN_110	10:30	10:39	0:09	TRANSFORMER FAULT
600	10-Jun-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	1:23	1:26	0:03	TRANSFORMER FAULT
601	10-Jun-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	12:36	12:43	0:07	TRANSFORMER FAULT
602	10-Jun-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	12:54	13:00	0:06	TRANSFORMER FAULT
603	10-Jun-22	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	9:55	10:47	0:52	LINE CLEAR AAVAILED
604	10-Jun-22	BAGALKOT	110	110/11KV,HV2	DEVAR GENNUR_110	10:00	10:34	0:34	TRANSFORMER FAULT
605	10-Jun-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)	20:35 (10.06.2022)	1059:55 hrs	LINE CHARGED
606	10-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
607	10-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
608	10-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
609	10-Jun-22	BAGALKOT	110	SIRSI220- SIRSI2	SIRSI_220	10:43	18:38	7:55	NFBC ISSUED
610	10-Jun-22	BAGALKOT	110	SIRSI220- SIRSI1	SIRSI_220	18:45	19:40	0:55	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
611	10-Jun-22	BAGALKOT	110	CHIKKODI220- SADALAGA	CHIKKODI_220	14:03	15:03	1:00	LINE CLEAR AVAILED
612	10-Jun-22	BAGALKOT	110	110/11KV, HV4	ANKALI_110	8:35	9:10	0:35	TRANSFORMER FAULT
613	10-Jun-22	BAGALKOT	110	RANEBENNUR- HIREKERUR	RANEBENNUR_220	3:12	3:27	0:15	LINE FAULT
614	10-Jun-22	BAGALKOT	220	220/110KV, HV1, LV1, HV2&LV2	RANEBENNUR_220	14:21	14:54	0:33	HAND TRIPPED
615	10-Jun-22	BAGALKOT	220	RANEBENNUR- BALLIGAVI	RANEBENNUR_220	14:21	19:36	5:15	LINE FAULT
616	10-Jun-22	BAGALKOT	220	220/110KV,HV2&LV2	RANEBENNUR_220	18:57	19:02	0:05	HAND TRIPPED
617	10-Jun-22	BAGALKOT	110	110/33KV, HV1	BAGALKOT_220	10:33	14:56	4:23	LINE CLEAR AVAILED
618	10-Jun-22	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	7:30	7:35	0:05	TRANSFORMER FAULT
619	10-Jun-22	BAGALKOT	110	KUDACHI220- YELPARAHATTI	KUDACHI_220	15:20	15:45	0:25	LINE CLEAR AVAILED
620	10-Jun-22	BAGALKOT	220	KARWAR- KADRA1	KARWAR_220	15:18	16:12	0:54	HAND TRIPPED
621	10-Jun-22	BAGALKOT	110	KARWAR220-KUMTA (ARGA)	KARWAR_220	1:02	11:57	10:55	LINE FAULT
622	10-Jun-22	BAGALKOT	110	BILAGI SUGARS-GIRASAGAR	GIRASAGAR_110	8:50	8:55	0:05	HAND TRIPPED
623	10-Jun-22	BAGALKOT	110	110/33KV, HV2	BISNAL_110, TEGGI_33	12:33	12:47	0:14	TRANSFORMER FAULT
624	10-Jun-22	BAGALKOT	110	110/33KV, HV2	BISNAL_110, TEGGI_33	16:10	18:00	1:50	TRANSFORMER FAULT
625	10-Jun-22	BAGALKOT	110	110/33KV, HV2	BISNAL_110, TEGGI_33	18:20	18:50	0:30	TRANSFORMER FAULT
626	10-Jun-22	BAGALKOT	110	110/33KV, HV2	MANTUR(B)_110, GALGALI	16:55	17:05	0:10	TRANSFORMER FAULT
627	10-Jun-22	BAGALKOT	220	AMBEWADI- NARENDRA1	AMBEWADI_220	14:18	14:56	0:38	LINE CLEAR AVAILED
628	11-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
629	11-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
630	11-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
631	11-Jun-22	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	15:50 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
632	11-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1(AEQU51)	BELGAUM_220	20:03 (10.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
633	11-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	11:11	11:17	0:06	HAND TRIPPED
634	11-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	14:10	14:11	0:01	HAND TRIPPED
635	11-Jun-22	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 TAKKALAKI_110	14:10	14:11	0:01	HAND TRIPPED
636	11-Jun-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	14:11	14:13	0:02	HAND TRIPPED
637	11-Jun-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED SIRSI_110	11:33	11:52	0:19	LINE CLEAR AVAILED
638	11-Jun-22	BAGALKOT	110	SIRSI220- SIRSI2	STATION NOT AFFECTED SIRSI_110	12:00	12:20	0:20	HAND TRIPPED
639	11-Jun-22	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	20:01	20:36	0:35	LINE FAULT
640	11-Jun-22	BAGALKOT	110	110/11KV, HV-2	SADALGA_110	9:58	17:17	7:19	LINE CLEAR AVAILED
641	11-Jun-22	BAGALKOT	110	110/11KV, HV-3	SADALGA_110	9:55	17:10	7:15	LINE CLEAR AVAILED
642	11-Jun-22	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	11:02	14:53	3:51	LINE CLEAR AVAILED
643	11-Jun-22	BAGALKOT	110	ATHANI220- SATTI	ATHANI_220	19:44	19:57	0:13	LINE FAULT
644	11-Jun-22	BAGALKOT	110	SOUDATTI220-MUNAVALLI	SOUDATTI_220	10:45	19:19	8:34	LINE CLEAR AVAILED
645	11-Jun-22	BAGALKOT	110	HUBLI220- KADANKOPPA	HUBLI_220	5:58	9:55	3:57	LINE FAULT
646	11-Jun-22	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	13:35	13:46	0:11	TRANSFORMER FAULT
647	11-Jun-22	BAGALKOT	110	110/11KV,HV3	HIPPARAGI_110 JAMAKHANDI_110	14:04	18:25	4:21	LINE CLEAR AVAILED
648	11-Jun-22	BAGALKOT	110	110/11KV,HV4	HIPPARAGI_110 JAMAKHANDI_110	14:05	18:23	4:18	LINE CLEAR AVAILED
649	11-Jun-22	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	16:42	17:51	1:09	LINE FAULT
650	11-Jun-22	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	16:42	17:22	0:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
651	11-Jun-22	BAGALKOT	110	110/11KV,HV2	HIREKERUR_110	10:49	11:53	1:04	LINE CLEAR AVAILED
652	11-Jun-22	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	11:03	14:30	3:27	LINE CLEAR AVAILED
653	11-Jun-22	BAGALKOT	110	VISHWANATH SUGARS-HUKKERI	HUKKERI_110	2:34	2:54	0:20	LINE FAULT
654	11-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
655	11-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
656	11-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
657	11-Jun-22	BAGALKOT	110	SHIRAGUPPI- BILAGI	SHIRAGUPPI_110, BILAGI_110, BISNAL_110, GIRISAGAR_110, TOLAMATTI_110	6:15	6:20	0:05	LINE FAULT
658	11-Jun-22	BAGALKOT	110	110/11KV, HV1	GIRASAGAR_110	8:45	13:10	4:25	LINE CLEAR AVAILED
659	11-Jun-22	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	7:15	7:25	0:10	TRANSFORMER FAULT
660	11-Jun-22	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	11:25	12:25	1:00	LINE CLEAR AVAILED
661	11-Jun-22	BAGALKOT	110	SIRSI220- SIRSI2	SIRSI_220	11:59	12:18	0:19	HAND TRIPPED
662	12-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
663	12-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
664	12-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
665	12-Jun-22	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	15:50 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
666	12-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1(AEQU51)	BELGAUM_220	20:03 (10.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
667	12-Jun-22	BAGALKOT	110	110/33KV HV3	KALAKERI_33, SHESHGERI_33 KNNL1&2_33 STATION NOT AFFECTED TILUVALLI_110	9:45	10:45	1:00	LINE CLEAR AVAILED
668	12-Jun-22	BAGALKOT	110	TARIHAL-KIADB GAMANAGATTI	TARIHAL_110	11:30	18:41	7:11	LINE CLEAR AVAILED
669	12-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	13:04	13:08	0:04	HAND TRIPPED
670	12-Jun-22	BAGALKOT	110	MUDDEBIHAL-KNM SOLAR	KNM SOLAR_110 MUDDEBIHAL_110	19:59	20:34	0:35	LINE FAULT
671	12-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALGHAN(B)_110	8:24	8:31	0:07	TRANSFORMER FAULT
672	12-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	0:02	0:06	0:04	TRANSFORMER FAULT
673	12-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	0:06	0:13	0:07	TRANSFORMER FAULT
674	12-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	0:13	7:45	7:32	TRANSFORMER FAULT
675	12-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	7:45	11:15	3:30	TRANSFORMER FAULT
676	12-Jun-22	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	10:14	10:40	0:26	LINE FAULT
677	12-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI2(AEQU52)	BELGAUM_220	9:22	13:26	4:04	LINE CLEAR AVAILED
678	12-Jun-22	Bagalkot	220	BELGAUM- NARENDRA2	BELGAUM_220	9:30	13:05	3:35	LINE CLEAR AVAILED
679	12-Jun-22	BAGALKOT	110	BAGEWADI- ACHANUR (MUDDEBIHAL)	BAGEWADI_220	20:00	20:13	0:13	HAND TRIPPED
680	12-Jun-22	BAGALKOT	110	HUBLLI- TARIHAL2	HUBLI_220	10:18	18:26	8:08	NFBC ISSUED
681	12-Jun-22	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	18:24	18:38	0:14	LINE FAULT
682	12-Jun-22	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	18:24	19:05	0:41	LINE FAULT
683	12-Jun-22	BAGALKOT	110	BANAHATTI-JAMAKHANDI(NAVALAGI)	NAVALAGI_110	13:40	13:58	0:18	LINE FAULT
684	12-Jun-22	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	10:14	10:42	0:28	HAND TRIPPED
685	12-Jun-22	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	10:25	10:52	0:27	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
686	12-Jun-22	BAGALKOT	110	BELLATTI-LAXMESHWAR	BELLATTI_110	10:25	10:48	0:23	LINE FAULT
687	12-Jun-22	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	11:08	14:05	2:57	NFBC ISSUED
688	12-Jun-22	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	11:08	14:05	2:57	NFBC ISSUED
689	12-Jun-22	BAGALKOT	110	THORVI-BHUTNAL	THORVI_110	6:15	13:05	6:50	NFBC ISSUED
690	12-Jun-22	BAGALKOT	110	NARENDRA-GARAG	GARAG_110	11:11	14:26	3:15	NFBC ISSUED
691	12-Jun-22	BAGALKOT	110	MAMADAPUR(B)-DEVARA GENNUR	DEVAR GENNUR_110	2:49	2:59	0:10	LINE FAULT
692	12-Jun-22	BAGALKOT	110	DEVARA GENNUR-SHIRBUR	DEVAR GENNUR_110	2:49	3:00	0:11	HAND TRIPPED
693	12-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
694	12-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
695	12-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
696	12-Jun-22	BAGALKOT	110	ATHANI220- BALIGERI	ATHANI_220	5:33	5:47	0:14	LINE FAULT
697	12-Jun-22	BAGALKOT	110	110/11KV, HV1	MK HUBLI_220	9:50	10:55	1:05	LINE CLEAR AVAILED
698	13-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
699	13-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
700	13-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
701	13-Jun-22	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	15:50 (08.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
702	13-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI1(AEQU51)	BELGAUM_220	20:03 (10.06.2022)	12:02 (13.06.2022)	63:59 hrs	LINE CHARGED
703	13-Jun-22	BAGALKOT	110	BIJAPUR KIADB-BHUTANAL	STATION NOT AFFECTED BIJAPUR KIADB_110	11:00	14:44	3:44	LINE CLEAR AVAILED
704	13-Jun-22	BAGALKOT	110	110/33KV, HV3	HONUTAGI_33 NAGATHAN_33 STATION NOT AFFECTED BIJAPUR KIADB_110	15:53	16:02	0:09	LINE CLEAR AVAILED
705	13-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED ITNAL_110	8:17	8:19	0:02	TRANSFORMER FAULT
706	13-Jun-22	BAGALKOT	110	110/33KV, HV2	CHINCHALI_33 STATION NOT AFFECTED KUDACHI_110	14:22	14:35	0:13	TRANSFORMER FAULT
707	13-Jun-22	BAGALKOT	110	KUMAT-SIRSI1	STATION NOT AFFECTED KUMTA_110	14:45	19:35	4:50	LINE CLEAR AVAILED
708	13-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(B)_110	9:04	9:12	0:08	TRANSFORMER FAULT
709	13-Jun-22	BAGALKOT	110	MALAGHAN(B)-BASAVESHWAR SUGARS	BASAVESHWAR SUGARS_110 STATION NOT AFFECTED MALAGHAN(B)_110	6:55	18:25	11:30	LINE CLEAR AVAILED
710	13-Jun-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	11:25	11:32	0:07	HAND TRIPPED
711	13-Jun-22	BAGALKOT	110	VAJRAMATTI220- KATARAKI	STATION NOT AFFECTED VAJRAMATTI_220	13:38	13:43	0:05	LINE FAULT
712	13-Jun-22	BAGALKOT	110	TAKKALAKI- TORVI	TAKKALAKI_110	6:36	6:42	0:06	HAND TRIPPED
713	13-Jun-22	BAGALKOT	110	TAKKALAKI- KNS SOLAR	TAKKALAKI_110	6:36	6:42	0:06	HAND TRIPPED
714	13-Jun-22	BAGALKOT	110	TAKKALAKI- TORVI	TAKKALAKI_110	14:44	14:45	0:01	HAND TRIPPED
715	13-Jun-22	BAGALKOT	110	SIRSI- KUMATA2	STATION NOT AFFECTED SIRSI_110	14:33	19:18	4:45	LINE FAULT
716	13-Jun-22	BAGALKOT	110	110/11KV, HV1	NAVALGUND_110	12:59	13:54	0:55	LINE CLEAR AVAILED
717	13-Jun-22	BAGALKOT	110	110/11KV, HV2	MANTUR(G)_110	14:13	14:17	0:04	TRANSFORMER FAULT
718	13-Jun-22	BAGALKOT	220	BELGAUM- CHIKKODI2(AEQU52)	STATION NOT AFFECTED BELGAUM_220	12:02 (13.06.2022)			LINE OPEN :LINE CLEAR AAVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
719	13-Jun-22	BAGALKOT	220	AEQUS- CHIKKODI1	STATION NOT AFFECTED AEQUS_110	12:04 (13.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
720	13-Jun-22	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	10:36	15:04	4:28	LINE CLEAR AAVAILED
721	13-Jun-22	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	11:02	12:00	0:57	LINE CLEAR AAVAILED
722	13-Jun-22	BAGALKOT	110	GHATAPRABHA220-SHIRAGOAN	GHATAPRABHA_220	16:45	16:56	0:11	LINE FAULT
723	13-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
724	13-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN :LINE CLEAR AAVAILED
725	13-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
726	13-Jun-22	BAGALKOT	110	SIRSI- KUMATA1	STATION NOT AFFECTED SIRSI_110	14:33	19:20	4:47	LINE FAULT
727	9-Jun-22	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	12:55	14:02	1:07	LINE FAULT
728	9-Jun-22	BENGALURU	66	IIsc - HEBBALA 220	IIsc	12:36	12:41	0:05	LOAD CHANGE OVER
729	9-Jun-22	BENGALURU	66	IIsc - NRS 220	IIsc	23:05	23:10	0:05	LOAD CHANGE OVER
730	9-Jun-22	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANISATION	ARMY WELFARE ORGANISATION,ALAMIC(EHT)	13:10	13:23	0:13	LINE FAULT
731	9-Jun-22	BENGALURU	66	HV1	KADUGODI	14:24	14:28	0:04	TRANSFORMER FAULT
732	9-Jun-22	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	21:12	22:14	1:02	LINE CLEAR AAVAILED
733	9-Jun-22	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	20:26	22:14	1:48	TRANSFORMER FAULT
734	9-Jun-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	10:44	13:59	3:15	LINE CLEAR AAVAILED
735	9-Jun-22	BENGALURU	220	MYLSANDRA 400 - SOMANAHALLI 220	NO STATION AFFECTED	14:06	15:26	1:20	LINE FAULT
736	9-Jun-22	BENGALURU	66	HV2	NRS 220	17:23	17:31	0:08	LOAD CHANGE OVER
737	9-Jun-22	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:29	13:36	0:07	LOAD CHANGE OVER
738	9-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	10:17	19:32	9:15	LINE CLEAR AAVAILED
739	9-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	10:33	18:00	7:27	LINE CLEAR AAVAILED
740	9-Jun-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	0:05	0:44	0:39	LINE FAULT
741	9-Jun-22	BENGALURU	66	KANASWADI - YELAHANKA 220	KANASWADI	11:20	11:25	0:05	LOAD CHANGE OVER
742	9-Jun-22	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	18:00	18:05	0:05	LOAD CHANGE OVER
743	9-Jun-22	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	15:35	15:40	0:05	LOAD CHANGE OVER
744	9-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	15:25	15:38	0:13	LINE CLEAR AAVAILED
745	9-Jun-22	BENGALURU	66	SARIJAPURA 220 - ATTIBELE	ATTIBELE	11:05	11:14	0:09	LOAD CHANGE OVER
746	9-Jun-22	BENGALURU	66	SARIJAPURA 220 - ATTIBELE	ATTIBELE	12:42	12:49	0:06	LOAD CHANGE OVER
747	9-Jun-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	10:48	18:08	7:19	LINE CLEAR AAVAILED
748	9-Jun-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:16	11:17	0:01	LINE CLEAR AAVAILED
749	9-Jun-22	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	12:55	14:29	1:34	LINE FAULT
750	9-Jun-22	BENGALURU	66	HV1	Y HUNSENAHALLI	11:07	11:11	0:03	LOAD CHANGE OVER
751	9-Jun-22	BENGALURU	66	HV1	SARIJAPURA 220	11:07	11:11	0:03	LOAD CHANGE OVER
752	9-Jun-22	BENGALURU	66	HV1	SARIJAPURA 220	12:42	12:45	0:02	LOAD CHANGE OVER
753	9-Jun-22	BENGALURU	220	HV2	SARIJAPURA 220	11:09	12:40	1:31	LINE CLEAR AAVAILED
754	9-Jun-22	BENGALURU	220	LV2	SARIJAPURA 220	11:07	12:44	1:37	LINE CLEAR AAVAILED
755	9-Jun-22	BENGALURU	220	LV2	GOWRIBIDANUR 220	12:18	12:39	0:21	LINE CLEAR AAVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
756	9-Jun-22	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	7:42(08/06/2022)	10:38(09/06/2022)	26:56HRS	LINE CHARGED
757	10-Jun-22	BENGALURU	66	GURUVINAPURA - BV HALLI	BV HALLI	6:09	6:27	0:18	LINE FAULT
758	10-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	18:40	19:41	1:01	LINE FAULT
759	10-Jun-22	BENGALURU	66	RAMANAGARA - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE	16:28	16:49	0:21	LINE FAULT
760	10-Jun-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	20:28	20:33	0:05	LOAD CHANGE OVER
761	10-Jun-22	BENGALURU	66	BANGARPETE - KOLAR 220	BANGARPETE	11:55	12:00	0:05	LOAD CHANGE OVER
762	10-Jun-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	6:45	6:50	0:05	LOAD CHANGE OVER
763	10-Jun-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	6:45	6:50	0:05	LOAD CHANGE OVER
764	10-Jun-22	BENGALURU	66	HV2	SARIJAPURA 220	12:00	12:03	0:03	LOAD CHANGE OVER
765	10-Jun-22	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	12:00	12:04	0:04	LOAD CHANGE OVER
766	10-Jun-22	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:00	12:05	0:05	LOAD CHANGE OVER
767	10-Jun-22	BENGALURU	220	HV1	SARIJAPURA 220	11:25	11:57	0:32	LINE CLEAR AVAILED
768	10-Jun-22	BENGALURU	66	HV2	SARIJAPURA 220	11:19	11:23	0:04	LOAD CHANGE OVER
769	10-Jun-22	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	11:19	11:23	0:04	LOAD CHANGE OVER
770	10-Jun-22	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:19	11:23	0:04	LOAD CHANGE OVER
771	10-Jun-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	10:48	18:48	8:00	LINE CLEAR AVAILED
772	10-Jun-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	13:17	13:27	0:10	LINE FAULT
773	10-Jun-22	BENGALURU	66	HV1	VIJAYAPURA	15:32	15:47	0:14	TRANSFORMER FAULT
774	10-Jun-22	BENGALURU	66	HV2	CHANDAPURA	7:30	8:00	0:30	TRANSFORMER FAULT
775	10-Jun-22	BENGALURU	66	GANJIGUNTE - BURUDAGUNTE	BURUDAGUNTE	5:50	6:05	0:15	LINE FAULT
776	11-Jun-22	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	8:58	9:12	0:14	MAIN SUPPLY FAILURE
777	11-Jun-22	BENGALURU	66	ATTUR YELAHANKA - DG4	SAHAKARI NAGAR, ATTUR YELAHANKA	11:58	13:13	1:15	LINE CLEAR AVAILED
778	11-Jun-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ABBIGERE	8:57	9:12	0:15	LINE FAULT
779	11-Jun-22	BENGALURU	66	HV2	BRIGADE METROPOLIS	10:50	10:55	0:05	TRANSFORMER FAULT
780	11-Jun-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	6:03	6:16	0:13	LINE FAULT
781	11-Jun-22	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	6:26	7:11	0:45	LINE FAULT
782	11-Jun-22	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	10:15	18:10	7:55	LINE CLEAR AVAILED
783	11-Jun-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 1 220	T GOLLAHALLI 220	15:04	16:58	1:54	LINE FAULT
784	11-Jun-22	BENGALURU	220	HV2	T GOLLAHALLI 220	15:04	19:50	4:46	TRANSFORMER FAULT
785	11-Jun-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 2 220	T GOLLAHALLI 220	15:40	16:58	1:18	LINE CLEAR AVAILED
786	11-Jun-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 2 220	T GOLLAHALLI 220	16:58	18:41	1:43	LINE CLEAR AVAILED
787	11-Jun-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 1 220	T GOLLAHALLI 220	16:58	18:31	1:33	LINE CLEAR AVAILED
788	11-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	15:04	18:42	3:38	MAIN SUPPLY FAILURE
789	11-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	15:04	18:42	3:38	MAIN SUPPLY FAILURE
790	11-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	15:04	18:42	3:38	MAIN SUPPLY FAILURE
791	11-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - ANDERSONPETE	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:04	18:42	3:38	MAIN SUPPLY FAILURE
792	11-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	15:04	18:42	3:38	MAIN SUPPLY FAILURE
793	11-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	15:04	18:42	3:38	MAIN SUPPLY FAILURE
794	11-Jun-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY PH-2 SEC-2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	12:03	12:16	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
795	11-Jun-22	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPURA 220	ELECTRONIC CITY P2 S2, BIOCON(EHT)	12:02	12:17	0:15	LINE FAULT
796	11-Jun-22	BENGALURU	66	HV1	NELAMANGALA 66	8:35	8:45	0:10	LINE CLEAR AVAILED
797	11-Jun-22	BENGALURU	66	JAGANI 220 - JIGANI 66	JIGANI 66, JIGANI LINK ROAD, KIRLOSKAR (EHT)	13:39	13:42	0:03	LINE CLEAR AVAILED
798	11-Jun-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	5:12	5:24	0:12	LINE FAULT
799	11-Jun-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	5:00	5:14	0:14	LINE FAULT
800	11-Jun-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	5:00	5:14	0:14	MAIN SUPPLY FAILURE
801	11-Jun-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	5:00	5:14	0:14	MAIN SUPPLY FAILURE
802	11-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	5:00	5:14	0:14	MAIN SUPPLY FAILURE
803	11-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	5:00	5:14	0:14	MAIN SUPPLY FAILURE
804	11-Jun-22	BENGALURU	66	HV1	JIGANI 220	14:46	14:55	0:09	TRANSFORMER FAULT
805	11-Jun-22	BENGALURU	220	HV1	YELAHANKA 220	10:45	13:11	2:26	LINE CLEAR AVAILED
806	11-Jun-22	BENGALURU	220	HV2	YELAHANKA 220	13:15	15:57	2:41	LINE CLEAR AVAILED
807	11-Jun-22	BENGALURU	220	LV2	MALUR 220	5:00	5:13	0:13	TRANSFORMER FAULT
808	11-Jun-22	BENGALURU	66	HV2	SADLI	16:46	17:06	0:20	TRANSFORMER FAULT
809	11-Jun-22	BENGALURU	66	Y HUNASENAHALLI - TALAGWARA	Y HUNASENAHALLI	12:35	12:45	0:10	LINE FAULT
810	12-Jun-22	BENGALURU	66	ABBIGERE - WELCASTE	ABBIGERE	13:14	13:18	0:04	LOAD CHANGE OVER
811	12-Jun-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	10:33	12:55	2:22	LINE CLEAR AVAILED
812	12-Jun-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	10:37	10:40	0:03	LOAD CHANGE OVER
813	12-Jun-22	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	16:33	16:51	0:18	LINE CLEAR AVAILED
814	12-Jun-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	19:13	19:20	0:07	LOAD CHANGE OVER
815	12-Jun-22	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	10:24	10:27	0:03	MAIN SUPPLY FAILURE
816	12-Jun-22	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	13:54	13:56	0:02	MAIN SUPPLY FAILURE
817	12-Jun-22	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	10:24	10:27	0:03	MAIN SUPPLY FAILURE
818	12-Jun-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	10:24	10:27	0:03	MAIN SUPPLY FAILURE
819	12-Jun-22	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	10:24	10:27	0:03	MAIN SUPPLY FAILURE
820	12-Jun-22	BENGALURU	66	NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	10:24	10:28	0:04	MAIN SUPPLY FAILURE
821	12-Jun-22	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	13:54	13:56	0:02	MAIN SUPPLY FAILURE
822	12-Jun-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	13:54	13:56	0:02	MAIN SUPPLY FAILURE
823	12-Jun-22	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	13:54	13:56	0:02	MAIN SUPPLY FAILURE
824	12-Jun-22	BENGALURU	66	NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	13:54	13:56	0:02	MAIN SUPPLY FAILURE
825	12-Jun-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	12:03	12:07	0:04	LOAD CHANGE OVER
826	12-Jun-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	19:03	19:08	0:05	LOAD CHANGE OVER
827	12-Jun-22	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	13:15	13:25	0:10	LOAD CHANGE OVER
828	12-Jun-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	17:22	17:28	0:06	LOAD CHANGE OVER
829	12-Jun-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	11:17	11:20	0:03	LOAD CHANGE OVER
830	12-Jun-22	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI	11:02	13:48	2:46	LINE CLEAR AVAILED
831	12-Jun-22	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	10:24	10:27	0:03	LOAD CHANGE OVER
832	12-Jun-22	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	13:54	13:56	0:02	LOAD CHANGE OVER
833	12-Jun-22	BENGALURU	66	HV1	HUSKUR	1:55	2:35	0:40	TRANSFORMER FAULT
834	12-Jun-22	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	16:52	16:56	0:04	LOAD CHANGE OVER
835	12-Jun-22	BENGALURU	66	JAGANI 220 - JIGANI 66	JIGANI 66, JIGANI LINK ROAD, KIRLOSKAR (EHT)	10:30	11:06	0:36	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
836	12-Jun-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	10:30	11:08	0:38	MAIN SUPPLY FAILURE
837	12-Jun-22	BENGALURU	220	JIGANI 220 - MYLASANDRA 400	JIGANI 220	10:30	11:03	0:33	LINE CLEAR AVAIED
838	12-Jun-22	BENGALURU	66	YELAHANKA 220 - LINE5	KHB	9:35	9:38	0:03	LINE CLEAR AVAIED
839	12-Jun-22	BENGALURU	66	YELAHANKA 220 - LINE3	WHEELS & AXLE(EHT), ESCORTS (EHT)YHT(9), ATTUR YELAHANKA	10:38	12:35	1:57	LINE CLEAR AVAIED
840	12-Jun-22	BENGALURU	66	YELAHANKA 220 - LINE4/DG4	NO STATION AFFECTED	13:25	17:01	3:36	LINE CLEAR AVAIED
841	12-Jun-22	BENGALURU	66	KHB - SRS PEENYA 220	KHB	10:37	10:40	0:03	LOAD CHANGE OVER
842	12-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:43	15:56	0:12	LINE FAULT
843	12-Jun-22	BENGALURU	66	HV2	JIGANI 220	10:30	11:04	0:34	MAIN SUPPLY FAILURE
844	12-Jun-22	BENGALURU	66	HV2	JIGANI 220	10:30	11:04	0:34	MAIN SUPPLY FAILURE
845	12-Jun-22	BENGALURU	66	HV2	WELCAST STEEL	10:12	10:15	0:02	LINE CLEAR AVAIED
846	12-Jun-22	BENGALURU	66	HV2	SARIJAPURA 220	20:51	21:18	0:26	TRANSFORMER FAULT
847	12-Jun-22	BENGALURU	66	HV1	RANGANDODDI	9:10	11:52	2:41	LINE CLEAR AVAIED
848	12-Jun-22	BENGALURU	66	HV2	KUNDANA	7:12	8:04	0:52	LINE CLEAR AVAIED
849	12-Jun-22	BENGALURU	66	HV2	DODDABELAVANGALA	19:39	19:46	0:07	TRANSFORMER FAULT
850	13-Jun-22	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	5:37	5:40	0:03	LOAD CHANGE OVER
851	13-Jun-22	BENGALURU	220	HV2	EPIP 220	4:47	4:52	0:05	TRANSFORMER FAULT
852	13-Jun-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, ALAMIC(EHT)	4:47	4:55	0:08	MAIN SUPPLY FAILURE
853	13-Jun-22	BENGALURU	66	HV2	EPIP 220	4:57	5:04	0:07	MAIN SUPPLY FAILURE
854	13-Jun-22	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	9:23	9:54	0:31	LOAD CHANGE OVER
855	13-Jun-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	5:23	5:27	0:04	LOAD CHANGE OVER
856	13-Jun-22	BENGALURU	66	HV1	RR NAGAR	15:06	15:11	0:05	LINE CLEAR AVAIED
857	13-Jun-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:44	17:04	0:20	LINE FAULT
858	13-Jun-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	16:44	17:09	0:25	LINE FAULT
859	13-Jun-22	BENGALURU	66	HV2	WIDIA	11:23	11:25	0:02	LINE CLEAR AVAIED
860	13-Jun-22	BENGALURU	66	HV1	WIDIA	12:10	13:12	1:02	LINE CLEAR AVAIED
861	13-Jun-22	BENGALURU	66	HV1	VIJAYANAGARA	5:35	5:48	0:13	LOAD CHANGE OVER
862	13-Jun-22	BENGALURU	66	HV2	VIJAYANAGARA	5:35	5:46	0:11	LOAD CHANGE OVER
863	13-Jun-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	12:58	13:14	0:16	TRANSFORMER FAULT
864	13-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	16:46	16:53	0:07	LINE FAULT
865	13-Jun-22	BENGALURU	66	JIGANI 220 - JIGANI LINK ROAD	JIGANI LINK ROAD	15:27	15:38	0:11	LINE FAULT
866	13-Jun-22	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	15:27	15:38	0:11	LINE FAULT
867	13-Jun-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, RAYALPADU, SOMAYAJANAHALLI	16:48	17:11	0:23	LINE FAULT
868	13-Jun-22	BENGALURU	66	HV1	PALLICHERLU	19:15	20:59	1:44	LINE CLEAR AVAIED
869	13-Jun-22	BENGALURU	66	HV2	TALAGUNDA	14:10	14:35	0:25	LINE CLEAR AVAIED
870	13-Jun-22	BENGALURU	66	HV2	TALAGUNDA	13:25	14:00	0:35	LINE CLEAR AVAIED
871	13-Jun-22	BENGALURU	66	HV1	TALAGUNDA	16:55	17:40	0:45	LINE CLEAR AVAIED
872	13-Jun-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	6:43	7:00	0:17	LINE FAULT
873	13-Jun-22	BENGALURU	66	HV2	YEDUMADU	4:18	4:21	0:03	TRANSFORMER FAULT
874	13-Jun-22	BENGALURU	66	HV1	CHINTAMANI 66	10:34	14:32	3:58	LINE CLEAR AVAIED
875	9-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
876	9-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	RTPS_400	17:06 (08.06.2022)	20:44 (9.06.2022)	27:38 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
877	9-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
878	9-Jun-22	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	19:39(05.06.2022)			LIE OPEN: LINE FAULT
879	9-Jun-22	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	19:39(05.06.2022)			LIE OPEN: LINE FAULT
880	9-Jun-22	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
881	9-Jun-22	GULBARGA	220	RAICHUR-SHAHAPUR_2	GOOGLE_110	19:20	19:30	0:10	LINE FAULT
882	9-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	20:28 (08.06.2022)	12:14 (09.06.2022)	15:46 HRS	LINE IS CHARGED.TRIPPED ON DISTANCE RELAY AT DIST: 16.45 KM ,ZONE-1,PHASE-B .CHARGE DELAYED DUE TO HEAVU RAIN AND WIND AS PER LDC B'LORE INSUTRUCTION.AT 22:30 LINE TEST CHARGED BUT IMMEDIATELY TRIPPED ON TRIP CIRCUIT SUPERVISION RELAY.AT 23:30 LC NO:S-569 ISSUED TO TLM JE SEDAM FOR LINE INSPECTION WORK.NO STATION LOAD EFFECTED
883	9-Jun-22	GULBARGA	220	RTPS-SEDAM	RTPS_220	12:27	16:24	3:57	LINE CLEAR AAVAILED
884	9-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	20:11	20:14	0:03	LINE FAULT
885	9-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	20:18	20:20	0:02	LINE FAULT
886	9-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	20:22	20:48	0:26	LINE FAULT
887	9-Jun-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	13:22	14:09	0:47	LINE FAULT
888	9-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WAD AGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
889	9-Jun-22	GULBARGA	110	HV4	DEODURGA_110	20:00(05.06.2022)	20:05(09.05.2022)	96:05HRS	TRANSFORMER CHARGED
890	9-Jun-22	GULBARGA	110	HV2	CHITAGUPPA_110	11:55	12:30	0:35	LINE CLEAR AAVAILED
891	9-Jun-22	GULBARGA	110	HV1	CHORNOOR_110	6:00	6:10	0:10	TRANSFORMER FAULT
892	9-Jun-22	GULBARGA	110	HV1	MUDAPUR_110	0:10	0:20	0:10	MAIN SUPPLY FAILURE
893	9-Jun-22	GULBARGA	110	HV2	SHAHAPUR_220	8:26	9:57	1:31	TRANSFORMER FAULT
894	9-Jun-22	GULBARGA	110	NALWAR-SHAHAPUR2	NALWAR_110	20:50(08.05.2022)	12:20(09.05.2022)	15:30HRS	LINE CHARGED
895	9-Jun-22	GULBARGA	110	NALWAR-SHAHAPUR1	NALWAR_110	11:05(09.05.2022)			LIE OPEN: LINE FAULT
896	9-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	7:30	10:05	2:35	LINE CLEAR AAVAILED
897	9-Jun-22	GULBARGA	110	NALWAR-WARAD SOLAR_IPP	NALWAR_110	6:50	7:30	0:40	LINE FAULT
898	9-Jun-22	GULBARGA	110	NALWAR-WARAD SOLAR_IPP	NALWAR_110	7:40	8:10	0:30	LINE FAULT
899	9-Jun-22	GULBARGA	110	NALWAR-WARAD SOLAR_IPP	NALWAR_110	8:15	9:15	1:00	LINE FAULT
900	9-Jun-22	GULBARGA	110	NALWAR-WARAD SOLAR_IPP	NALWAR_110	9:40	12:25	2:45	LINE CLEAR AAVAILED
901	9-Jun-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	5:35	5:40	0:05	MAIN SUPPLY FAILURE
902	9-Jun-22	GULBARGA	110	YELBURGA-PRPJ_IPP	YELBURGA_110	8:06	9:01	0:55	LOAD CURTAILMENT
903	9-Jun-22	GULBARGA	110	YELBURGA-KUKUNOOR	KUKUNOOR_110	13:42	16:34	2:52	LINE CLEAR AAVAILED
904	9-Jun-22	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	19:20	19:30	0:10	LINE FAULT
905	9-Jun-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110, ADVIAMRESHWAR_110	9:30	13:05	3:35	LINE CLEAR AAVAILED
906	9-Jun-22	GULBARGA	110	NALWAR-SHAHAPUR1	NALWAR_110	11:05(09.05.2022)	10:10(10.05.2022)	23:05HRS	LINE CHARGED
907	9-Jun-22	GULBARGA	110	MUDAPUR-MASKI	MASKI_110	5:20	5:25	0:05	LINE FAULT
908	9-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	2:08	2:13	0:05	LINE FAULT
909	9-Jun-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	4:05	4:12	0:07	LINE FAULT
910	9-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:26	4:35	0:09	LINE FAULT
911	9-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:40	7:45	0:05	LINE FAULT
912	9-Jun-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	3:11	3:25	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
913	9-Jun-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	5:36	7:22	1:46	LINE FAULT
914	9-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110	21:26 (8.06.2022)	12:18 (09.06.2022)	14:52 HRS	LINE CHARGED
915	9-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	10:50	12:38	1:48	LINE CLEAR AVAILED
916	9-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KHANAPUR_110,WADGERA_110	1:05	1:17	0:12	LINE FAULT
917	9-Jun-22	GULBARGA	110	RAICHUR-SINDHANOOR_2	KURDICROSS_110,MADLAPUR_110,MANVI_110	1:55	2:00	0:05	LOAD CURTAILMENT
918	9-Jun-22	GULBARGA	66	HV1	HANASI_66	7:35	7:45	0:10	TRANSFORMER FAULT
919	9-Jun-22	GULBARGA	66	HV1	HANASI_66	9:40	10:45	1:05	LINE CLEAR AVAILED
920	9-Jun-22	GULBARGA	66	HV1	HARVI_66	8:00	8:15	0:15	LINE CLEAR AVAILED
921	9-Jun-22	GULBARGA	66	BENNEHALLI-KOTTUR	KOTTUR_66	4:40	4:45	0:05	LINE FAULT
922	9-Jun-22	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	4:30	4:35	0:05	MAIN SUPPLY FAILURE
923	9-Jun-22	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	17:35	17:45	0:10	MAIN SUPPLY FAILURE
924	10-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
925	10-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
926	10-Jun-22	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
927	10-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LIE OPEN: LINE FAULT
928	10-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	23:40 (10.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
929	10-Jun-22	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
930	10-Jun-22	GULBARGA	220	HV2	RAICHUR_220	7:23	9:28	2:05	LINE CLEAR AVAILED
931	10-Jun-22	GULBARGA	220	HV1	RAICHUR_220	10:49	13:22	2:33	LINE CLEAR AVAILED
932	10-Jun-22	GULBARGA	220	HV1,HV2	MUNIRABAD_220	10:59	11:58	0:59	MAIN SUPPLY FAILURE
933	10-Jun-22	GULBARGA	220	RAICHUR-SHAHAPUR_2	GOOGLE_110	22:35	22:40	0:05	LINE FAULT
934	10-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	22:05	22:35	0:30	LINE FAULT
935	10-Jun-22	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	19:39(05.06.2022)	15:49(10.06.2022)	116:10HRS	LINE CHARGED
936	10-Jun-22	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	19:39(05.06.2022)	15:50(10.06.2022)	116:11HRS	LINE CHARGED
937	10-Jun-22	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	10:57	11:58	1:01	LINE FAULT
938	10-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
939	10-Jun-22	GULBARGA	110	HV3&HV4	DEODURGA_110	9:30	11:20	1:50	LINE CLEAR AVAILED
940	10-Jun-22	GULBARGA	110	HV4	DEODURGA_110	15:00	15:10	0:10	TRANSFORMER FAULT
941	10-Jun-22	GULBARGA	110	HV2	DEODURGA_110	18:35	19:30	0:55	TRANSFORMER FAULT
942	10-Jun-22	GULBARGA	110	HV3	DEODURGA_110	19:45	20:20	0:35	LINE CLEAR AVAILED
943	10-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	1:47	1:54	0:07	LINE FAULT
944	10-Jun-22	GULBARGA	110	LINGASUGUR-KAREPOWER	LAREPOWER_IPP,CHAYADEVI_IPP	8:53	12:30	3:37	LINE CLEAR AVAILED
945	10-Jun-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	BPCL_IPP,VENKATGIRI_110,GANGAVATHI_110,SRNAGAR_110,KARTAGI_110	10:34	10:46	0:12	LINE FAULT
946	10-Jun-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	9:36	16:40	7:04	LINE CLEAR AVAILED
947	10-Jun-22	GULBARGA	110	SINDHANOOR-NIRLOOTI	NIRLOOTI_IPP	4:05	4:15	0:10	LINE FAULT
948	10-Jun-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMLAPUR_110,MATRI_110,RBNS FACTORY	4:35	4:45	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
949	10-Jun-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERDONA_110,BENNU_110,BTPS WATER WORKS,KAMPLI_110	10:05	10:25	0:20	LINE FAULT
950	10-Jun-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERDONA_110,BENNU_110,BTPS WATER WORKS,KAMPLI_110	17:10	17:20	0:10	LINE FAULT
951	10-Jun-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	10:10	10:20	0:10	LINE FAULT
952	10-Jun-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	6:20	6:45	0:25	LINE FAULT
953	10-Jun-22	GULBARGA	110	MALLAPUR-MUNIRABAD	MALLAPUR_110	9:05	9:15	0:10	MAIN SUPPLY FAILURE
954	10-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	4:05	7:00	2:55	LINE FAULT
955	10-Jun-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	5:16	5:26	0:10	LINE FAULT
956	10-Jun-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	5:37	5:47	0:10	LINE FAULT
957	10-Jun-22	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	23:04	23:12	0:08	LINE FAULT
958	10-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	18:45	19:00	0:15	LINE FAULT
959	10-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	20:45	20:55	0:10	LINE FAULT
960	10-Jun-22	GULBARGA	66	HV1,HV2	UJJANI_66	10:00	14:35	4:35	LINE CLEAR AVAILED
961	10-Jun-22	GULBARGA	66	HV2	MYLAR_66	10:20	17:50	7:30	LINE CLEAR AVAILED
962	10-Jun-22	GULBARGA	66	ITTAGI-RENWE_2_IPP	ITTAGI_220	15:23	15:35	0:12	LINE CLEAR AVAILED
963	10-Jun-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	5:53	6:13	0:20	LINE FAULT
964	10-Jun-22	GULBARGA	66	ITTAGI-RENWE_1_IPP	ITTAGI_220	9:50	9:55	0:05	LINE CLEAR AVAILED
965	10-Jun-22	GULBARGA	66	UJJAINI-BENNEHALLI	UJJANI_66,KOTTUR_66	10:30	14:30	4:00	LINE CLEAR AVAILED
966	10-Jun-22	GULBARGA	66	UJJAINI-BENNEHALLI	UJJANI_66,KOTTUR_66	17:25	18:06	0:41	LINE FAULT
967	10-Jun-22	GULBARGA	66	UCHCHANGIDURGA-BILCHOD	BILCHOD_66	14:30	22:45	8:15	LINE FAULT
968	10-Jun-22	GULBARGA	66	BENNEHALLI-KOTTUR	KOTTUR_66	15:50	16:00	0:10	LINE FAULT
969	11-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
970	11-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
971	11-Jun-22	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
972	11-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	23:40 (10.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
973	11-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LIE OPEN: LINE FAULT
974	11-Jun-22	GULBARGA	220	HV1	LINGASUGUR_220	7:51	7:55	0:04	LINE CLEAR AVAILED
975	11-Jun-22	GULBARGA	220	HV1,HV2	ITTAGI_220	14:01	14:15	0:14	TRANSFORMER FAULT
976	11-Jun-22	GULBARGA	220	RAICHUR-SHAHAPUR_2	GOOGLE_110	19:32	19:38	0:06	LINE FAULT
977	11-Jun-22	GULBARGA	220	RAICHUR-JURALA 1 & 2	JURALA 1 & 2_IPP	11:40	21:10	9:30	LINE CLEAR AVAILED
978	11-Jun-22	GULBARGA	220	BADELADUKU(KUDLIGI)-HIREMALLANHALLI_2	HIREMALLANHALLI_220	10:50	11:00	0:10	LINE CLEAR AVAILED
979	11-Jun-22	GULBARGA	220	BADELADUKU(KUDLIGI)-HIREMALLANHALLI_2	HIREMALLANHALLI_220	18:40	18:50	0:10	LINE CLEAR AVAILED
980	11-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
981	11-Jun-22	GULBARGA	110	HV2	GHATTARGA_110	13:40	13:45	0:05	TRANSFORMER FAULT
982	11-Jun-22	GULBARGA	110	HV2	GHATTARGA_110	15:00	15:05	0:05	TRANSFORMER FAULT
983	11-Jun-22	GULBARGA	110	HV1	GURUMITKAL_110	10:00	18:00	8:00	LINE CLEAR AVAILED
984	11-Jun-22	GULBARGA	110	HV1	MATAMARI_110	21:20	21:35	0:15	TRANSFORMER FAULT
985	11-Jun-22	GULBARGA	110	HV1	DEODURGA_110	11:30	11:40	0:10	LINE CLEAR AVAILED
986	11-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	17:02	17:25	0:23	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
987	11-Jun-22	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVITHAL_110,SOMANMARDI_IPP,GAMESHA_IPP	5:30	5:36	0:06	LINE FAULT
988	11-Jun-22	GULBARGA	110	LINGASUGUR-KAREPOWER,CHAYADEVI	KAREPOER_IPP,CHAYADEVI_IPP	7:48	9:24	1:36	LINE CLEAR AVAILED
989	11-Jun-22	GULBARGA	110	LINGASUGUR-GURGUNTA	GURGUNTA_110,KHEL_IPP,LJVL_IPP	7:48	9:24	1:36	LINE CLEAR AVAILED
990	11-Jun-22	GULBARGA	110	LINGASUGUR-LATUR GAMESHA	LATUR GAMESHA_IPP	7:48	9:24	1:36	LINE CLEAR AVAILED
991	11-Jun-22	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	8:04	8:14	0:10	LINE FAULT
992	11-Jun-22	GULBARGA	110	KAPANOOR-ALAND	ALAND_110,KADGANCHI_110	20:12	20:23	0:11	LINE FAULT
993	11-Jun-22	GULBARGA	110	YELBURGA-PRPJ_IPP	YELBURGA_110	22:50	23:14	0:24	LINE FAULT
994	11-Jun-22	GULBARGA	110	YELBURGA-PRPJ_IPP	YELBURGA_110	23:52(11.06.2022)			LIE OPEN: LINE FAULT
995	11-Jun-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	14:07	14:12	0:05	LINE FAULT
996	11-Jun-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	19:50	20:00	0:10	MAIN SUPPLY FAILURE
997	11-Jun-22	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH1	GULBARGASOUTH_110	5:32	6:30	0:58	LINE FAULT
998	11-Jun-22	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH1	GULBARGASOUTH_110	5:32	14:04	8:32	LINE FAULT
999	11-Jun-22	GULBARGA	110	VAJRABANDI-YELABURGA	YELABURGA_110	22:25	22:45	0:20	LINE FAULT
1000	11-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	4:05	4:15	0:10	LINE FAULT
1001	11-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	21:09	21:17	0:08	LINE FAULT
1002	11-Jun-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	20:14	20:16	0:02	LINE FAULT
1003	11-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	22:17	22:25	0:08	LINE FAULT
1004	11-Jun-22	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	22:34	22:41	0:07	LINE FAULT
1005	11-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KHANAPUR_110,WADGERA_110	4:55	5:00	0:05	LINE FAULT
1006	11-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	19:52	19:57	0:05	LINE FAULT
1007	11-Jun-22	GULBARGA	66	HV1	HARAPANAHALLI_66	14:25	14:40	0:15	TRANSFORMER FAULT
1008	11-Jun-22	GULBARGA	66	HV2	BENNEHALLI_66	6:25	6:30	0:05	TRANSFORMER FAULT
1009	11-Jun-22	GULBARGA	66	HV2	BENNEHALLI_66	14:00	14:05	0:05	TRANSFORMER FAULT
1010	11-Jun-22	GULBARGA	66	ITTAGI-HIREHADAGALI_1	HIREHADAGALI_66	8:21	8:26	0:05	LINE FAULT
1011	11-Jun-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	10:35	10:45	0:10	LINE FAULT
1012	11-Jun-22	GULBARGA	66	PUNABGHATA-UCHCHANGI DURGA	UCHCHANGIDURGA_66	15:35	17:35	2:00	LINE CLEAR AVAILED
1013	11-Jun-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCHCHANGIDURGA_66,BILCHOD_66	16:25	17:25	1:00	LINE CLEAR AVAILED
1014	12-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
1015	12-Jun-22	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
1016	12-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	23:40 (10.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
1017	12-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LIE OPEN: LINE FAULT
1018	12-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1019	12-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
1020	12-Jun-22	GULBARGA	110	HV3	VALKAMDINNI_110	10:02	10:07	0:05	TRANSFORMER FAULT
1021	12-Jun-22	GULBARGA	110	HV1	MUDDAPUR_110	23:14(12.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1022	12-Jun-22	GULBARGA	110	HV1	ALIPUR_220	8:10	8:36	0:26	TRANSFORMER FAULT
1023	12-Jun-22	GULBARGA	110	YELBURGA-PRPJ_IPP	YELBURGA_110	23:52(11.06.2022)	5:13(12.06.2022)	5:21 hrs	LINE FAULT
1024	12-Jun-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	1:45	1:55	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1025	12-Jun-22	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	22:20	22:25	0:05	LINE FAULT
1026	12-Jun-22	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	22:20	22:27	0:07	LINE FAULT
1027	12-Jun-22	GULBARGA	110	MADIYAL-NSLSUGAR_IPP	MADIYAL_110	22:20	22:25	0:05	LINE FAULT
1028	12-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	1:12	1:18	0:06	LINE FAULT
1029	12-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	1:29	13:43	12:14	LINE FAULT
1030	12-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KHANAPUR_110,WADGERA_110	22:26	22:31	0:05	LINE FAULT
1031	12-Jun-22	GULBARGA	66	HV1	HANSI_110	16:20	16:50	0:30	TRANSFORMER FAULT
1032	12-Jun-22	GULBARGA	66	ITTAGI-RENWE_1_IPP	ITTAGI_220	16:00	16:02	0:02	LINE CLEAR AVAILED
1033	12-Jun-22	GULBARGA	66	HANSI-KUDALIGI_220	HANSI_110	4:00	4:10	0:10	MAIN SUPPLY FAILURE
1034	13-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LIE OPEN: LINE FAULT
1035	13-Jun-22	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)			LINE OPEN :LINE CLEAR AAVAILED
1036	13-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LIE OPEN: LINE FAULT
1037	13-Jun-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1038	13-Jun-22	GULBARGA	220	HV1	KUSTAGI_220	15:30	15:45	0:15	TRANSFORMER FAULT
1039	13-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	0:30	0:52	0:22	LINE FAULT
1040	13-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	1:04	8:04	7:00	LINE FAULT
1041	13-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	23:40 (10.06.2022)	12:14 (13.06.2022)	68:34 HRS	LINE CHARGED
1042	13-Jun-22	GULBARGA	220	SHAHAPUR-RTPS_1	SHAHAPUR_220	14:14	20:32	6:18	LINE CLEAR AVAILED
1043	13-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AAVAILED
1044	13-Jun-22	GULBARGA	110	HV1	MUDDAPUR_110	23:14(12.06.2022)	00:20(13.06.2022)	1:06 hrs	TRANSFORMER CHARGED
1045	13-Jun-22	GULBARGA	110	HV2	MYLAR_110	11:10	15:10	4:00	LINE CLEAR AVAILED
1046	13-Jun-22	GULBARGA	110	HV2	SREERAMANAGAR_110	3:00	3:07	0:07	TRANSFORMER FAULT
1047	13-Jun-22	GULBARGA	110	HV3	HATTI_110	9:18	9:22	0:04	TRANSFORMER FAULT
1048	13-Jun-22	GULBARGA	110	HV3	HATTI_110	16:02	16:07	0:05	TRANSFORMER FAULT
1049	13-Jun-22	GULBARGA	110	HV1	GULBARGA WEST_110	9:30	14:05	4:35	LINE CLEAR AVAILED
1050	13-Jun-22	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	20:13	20:16	0:03	LINE FAULT
1051	13-Jun-22	GULBARGA	110	MUDAGAL-LINGSUGUR	MUDAGAL_110	12:30	12:45	0:15	LINE CLEAR AVAILED
1052	13-Jun-22	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	5:17	6:03	0:46	LINE FAULT
1053	13-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	19:10	22:53	3:43	LINE CLEAR AVAILED
1054	13-Jun-22	GULBARGA	110	BYAGAWATH-MALLAT	BYAGWAT_110, VALKAMDINNI_110	21:20	22:55	1:35	LINE FAULT
1055	13-Jun-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110,BEN NUR_110,BTPAS WATER WORKS,KAMPLI_110	3:17	3:23	0:06	LINE FAULT
1056	13-Jun-22	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	22:00	22:15	0:15	LINE FAULT
1057	13-Jun-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	21:03	21:13	0:10	LINE FAULT
1058	13-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:43	23:56	0:13	LINE FAULT
1059	13-Jun-22	GULBARGA	110	SHAHABAD-CHITAPUR	KORWAR TEMPLE_110	5:30	5:35	0:05	LINE FAULT
1060	13-Jun-22	GULBARGA	66	HV2	UJJAINI_66	17:53	18:00	0:07	TRANSFORMER FAULT
1061	13-Jun-22	GULBARGA	66	HV2	UJJAINI_66	18:12	18:21	0:09	TRANSFORMER FAULT
1062	13-Jun-22	GULBARGA	66	HV2	UJJAINI_66	17:25	17:30	0:05	TRANSFORMER FAULT
1063	13-Jun-22	GULBARGA	66	HV2	HANSI_66	16:10	16:35	0:25	LINE CLEAR AVAILED
1064	13-Jun-22	GULBARGA	66	HV2	HANSI_66	17:45	18:50	1:05	LINE CLEAR AVAILED
1065	13-Jun-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	16:45	16:56	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1066	13-Jun-22	GULBARGA	66	NEELGUNDA-TELIGI	TELAGI_66,KURBHAHALI_66,YEREGU NTA_66	16:31	16:43	0:12	LINE FAULT
1067	13-Jun-22	GULBARGA	66	BENNEHALLI-KOTTUR	KOTTUR_66	5:05	5:10	0:05	LINE FAULT
1068	13-Jun-22	GULBARGA	66	ITTAGI-CLEAN MAX SOLAR_IPP	ITTAGI_220	19:54	23:50	3:56	LINE CLEAR AVAILED
1069	9-Jun-22	MYSURU	66	HV1	CHUNCHUNKATTE_66	1:45	2:21	0:35	TRANSFORMER FAULT
1070	9-Jun-22	MYSURU	66	JAKKANANAHALLY-NAGAMANGLA	G MALLIGERE_66	3:31	3:38	0:07	LINE FAULT
1071	9-Jun-22	MYSURU	66	HV1	K_HONNALGERE_66	19:13	19:18	0:04	TRANSFORMER FAULT
1072	9-Jun-22	MYSURU	66	KIRUGAVALU-MALIYURU	MALIYURU_66	9:30	9:45	0:15	HAND TRIPPED
1073	9-Jun-22	MYSURU	66	HV1	KIRUGAVALU_66	9:45	18:10	8:24	LINE CLEAR AVAILED
1074	9-Jun-22	MYSURU	66	HV2	KIRUGAVALU_66	9:45	18:10	8:24	LINE CLEAR AVAILED
1075	9-Jun-22	MYSURU	66	MEGALAPURA-VAJAMANGALA	NO STATIONS EFFECTED	9:57	15:51	5:53	LINE CLEAR AVAILED
1076	9-Jun-22	MYSURU	66	HOOTAGALLI-BANNIMANTAPA 1	BANNIMANTAP_66	6:26	6:45	0:19	LINE FAULT
1077	9-Jun-22	MYSURU	66	HOOTAGALLI-BANNIMANTAPA 2	NO STATIONS EFFECTED	6:26	6:45	0:19	LINE FAULT
1078	9-Jun-22	MYSURU	66	NAGAMANGALA 220-NAGAMANGALA	NAGAMANGALA_66	10:21	16:50	6:29	LINE CLEAR AVAILED
1079	9-Jun-22	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:00	13:25	2:25	LINE CLEAR AVAILED
1080	9-Jun-22	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	18:54	18:59	0:05	LINE FAULT
1081	9-Jun-22	MYSURU	66	HEBBANI-SHIMSHA	HADLI_66 MALAVALLI_66	0:04	0:31	0:27	LINE FAULT
1082	9-Jun-22	MYSURU	220	HV1	VAJAMANGALA_220	10:26	15:30	5:04	LINE CLEAR AVAILED
1083	9-Jun-22	MYSURU	66	HV2	THANDYA_66	11:30	14:23	2:53	LINE CLEAR AVAILED
1084	9-Jun-22	MYSURU	66	HV1	THANDYA_66	14:23	14:26	0:03	TRANSFORMER FAULT
1085	9-Jun-22	MYSURU	66	HARADANAHALLY-KADAVINAKOTE	HARADANAHALLI_66	10:00	14:15	4:15	LINE CLEAR AVAILED
1086	9-Jun-22	MYSURU	66	HV2	CHIKKA_MANDYA_66	10:55	11:45	0:50	LINE CLEAR AVAILED
1087	9-Jun-22	MYSURU	66	HV2	SINDHUVALLI_66	8:00	8:45	0:45	TRANSFORMER FAULT
1088	9-Jun-22	MYSURU	66	HV2	SINDHUVALLI_66	12:05	13:05	1:00	LINE CLEAR AVAILED
1089	9-Jun-22	MYSURU	66	HV2	BYLUKUPPE_66	14:50	14:55	0:05	TRANSFORMER FAULT
1090	9-Jun-22	MYSURU	66	HV1	RAVANDUR_66	10:20	19:00	8:40	LINE CLEAR AVAILED
1091	9-Jun-22	MYSURU	66	HV2	RAVANDUR_66	10:20	19:00	8:40	LINE CLEAR AVAILED
1092	9-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED
1093	9-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1094	9-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
1095	9-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
1096	10-Jun-22	MYSURU	66	HV1	DATTAGALLY_66	10:17	17:21	7:04	LINE CLEAR AVAILED
1097	10-Jun-22	MYSURU	66	THALAKADU-PARINAMIPURA	PARINAMIPURA_66	5:54	6:00	0:05	LINE FAULT
1098	10-Jun-22	MYSURU	220	C R NAGARA-BEGUR 2	NO STATIONS EFFECTED	13:04	14:44	1:40	LINE CLEAR AVAILED
1099	10-Jun-22	MYSURU	220	KADAKOLA-BEGUR 1	NO STATIONS EFFECTED	10:48	12:50	2:02	NFBC ISSUED
1100	10-Jun-22	MYSURU	66	KADAKOLA-SARGUR 1	HAMPAPURA(K)_66 JAIPUR_66	18:57	19:04	0:07	LINE FAULT
1101	10-Jun-22	MYSURU	66	MADHUVANAHALLI-DODDINDUVADI	NO STATIONS EFFECTED	19:10	19:36	0:26	LINE FAULT
1102	10-Jun-22	MYSURU	66	HV1	HALAGUR_66	9:05	15:25	6:20	LINE CLEAR AVAILED
1103	10-Jun-22	MYSURU	66	HV1	HALAGUR_66	16:25	17:45	1:20	LINE CLEAR AVAILED
1104	10-Jun-22	MYSURU	66	HV2	HALAGUR_66	14:30	20:25	5:55	LINE CLEAR AVAILED
1105	10-Jun-22	MYSURU	66	GUDDENAHALLI-NAGAMANGALA	GUDDENAHALLI_66	10:00	18:20	8:20	LINE CLEAR AVAILED
1106	10-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1107	10-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1108	10-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
1109	10-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
1110	11-Jun-22	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLY	LOKKANAHALLI_66 PGPALYA_66	9:38	9:42	0:04	LINE FAULT
1111	11-Jun-22	MYSURU	66	BEGUR 220-HARAVE	NO STATIONS EFFECTED	12:24	13:14	0:50	LINE CLEAR AAVAILED
1112	11-Jun-22	MYSURU	66	BEGUR 220-SINDHUVALLI	NO STATIONS EFFECTED	13:19	14:18	0:59	LINE CLEAR AAVAILED
1113	11-Jun-22	MYSURU	66	HV2	SHEELUNERE_66	16:00	16:05	0:05	TRANSFORMER FAULT
1114	11-Jun-22	MYSURU	66	HV1	BEGUR_66	9:05	14:45	5:40	LINE CLEAR AAVAILED
1115	11-Jun-22	MYSURU	66	HV2	BEGUR_66	9:05	14:45	5:40	LINE CLEAR AAVAILED
1116	11-Jun-22	MYSURU	66	HV2	BGNAGARA_66	11:15	11:59	0:44	LINE CLEAR AAVAILED
1117	11-Jun-22	MYSURU	66	HV1	KIRUGAVALU_66	14:20	17:18	2:58	LINE CLEAR AAVAILED
1118	11-Jun-22	MYSURU	66	HV1	MADDUR_66	9:47	18:26	8:39	LINE CLEAR AAVAILED
1119	11-Jun-22	MYSURU	66	HV2	MADDUR_66	9:54	18:24	8:30	LINE CLEAR AAVAILED
1120	11-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED
1121	11-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1122	11-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
1123	11-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
1124	12-Jun-22	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	5:26	18:44	13:18	LINE CLEAR AAVAILED
1125	12-Jun-22	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	6:05	18:25	12:20	LINE CLEAR AAVAILED
1126	12-Jun-22	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	6:05	18:26	12:21	LINE CLEAR AAVAILED
1127	12-Jun-22	MYSURU	66	HV2	KADAKOLA_220	12:21	16:28	4:07	LINE CLEAR AAVAILED
1128	12-Jun-22	MYSURU	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	5:11	18:08	12:57	LINE CLEAR AAVAILED
1129	12-Jun-22	MYSURU	66	HOOTAGALLI-BARC-2	NO STATIONS EFFECTED	5:09	18:08	12:59	LINE CLEAR AAVAILED
1130	12-Jun-22	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	5:34	17:59	12:25	LINE CLEAR AAVAILED
1131	12-Jun-22	MYSURU	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	5:34	17:59	12:25	LINE CLEAR AAVAILED
1132	12-Jun-22	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66JAKKANAHALL Y_66G MALLIGERE_66	12:47	12:51	0:03	LINE FAULT
1133	12-Jun-22	MYSURU	66	HV1	ANTHARSANTHE_66	11:30	12:20	0:50	LINE CLEAR AAVAILED
1134	12-Jun-22	MYSURU	66	HV2	ANTHARSANTHE_66	11:30	12:20	0:50	LINE CLEAR AAVAILED
1135	12-Jun-22	MYSURU	66	HV2	BESAGARAHALLI_66	15:47	16:31	0:44	HAND TRIPPED
1136	12-Jun-22	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	15:18	15:23	0:05	LINE FAULT
1137	12-Jun-22	MYSURU	66	HV-1	CRNAGAR_220	10:55	11:15	0:20	LINE CLEAR AAVAILED
1138	12-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED
1139	12-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1140	12-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
1141	12-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
1142	13-Jun-22	MYSURU	66	HARADANAHALLI (JAK)-LAXJEET	NO STATIONS EFFECTED	19:01	19:06	0:05	LINE FAULT
1143	13-Jun-22	MYSURU	66	HV1	K_HONNALGERE_66	21:50	22:03	0:13	TRANSFORMER FAULT
1144	13-Jun-22	MYSURU	66	HV1	HURA_66	13:15	13:40	0:25	LINE CLEAR AAVAILED
1145	13-Jun-22	MYSURU	66	KIADB SOMANAHALLI-MADDUR	SOMANAHALLI_66	8:47	8:55	0:08	LINE FAULT
1146	13-Jun-22	MYSURU	66	HV1	K_HONNALGERE_66	16:40	17:10	0:30	MAIN SUPPLY FAILURE
1147	13-Jun-22	MYSURU	220	HV2	HEBBANI_220	16:47	16:52	0:05	HAND TRIPPED
1148	13-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN :LINE CLEAR AAVAILED
1149	13-Jun-22	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1150	13-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN :LINE CLEAR AAVAILED
1151	13-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN :LINE CLEAR AAVAILED
1152	9-Jun-22	TUMKUR	220	TR-2(HV & LV)	DAVANGERE_220	9:27(8.06.2022)	13:33(9.6.22)	1day 4hrs	LINE CLEAR AVAILED
1153	9-Jun-22	TUMKUR	220	TR-3	CHITRADURGA_220	9:35	15:24	5:49	LINE CLEAR AVAILED
1154	9-Jun-22	TUMKUR	220	TR-1 & TR-2	PAVAGADA_220	6:15	6:30	0:15	TRANSFORMER FAULT
1155	9-Jun-22	TUMKUR	110	AMMASANDRA 110-K B CROSS	AMMASANDRA_110, SAMPIGE_110	19:35	21:55	2:20	MAIN SUPPLY FAILURE
1156	9-Jun-22	TUMKUR	110	KB CROSS 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	19:35	21:55	2:20	LINE FAULT
1157	9-Jun-22	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110, SAMPIGE_110	7:40	10:00	2:20	MAIN SUPPLY FAILURE
1158	9-Jun-22	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110, SAMPIGE_110	20:10	21:57	1:47	LINE CLEAR AVAILED
1159	9-Jun-22	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	9:35	15:24	5:49	LINE CLEAR AVAILED
1160	9-Jun-22	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	9:35	15:24	5:49	LINE CLEAR AVAILED
1161	9-Jun-22	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	4:05	4:10	0:05	LINE FAULT
1162	9-Jun-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:50	12:30	0:40	LINE CLEAR AVAILED
1163	9-Jun-22	TUMKUR	66	HOSADURRG-MATHOD	HOSADURGA_66	13:35	14:00	0:25	HAND TRIPPED
1164	9-Jun-22	TUMKUR	66	HONNALLI-HONNALLI	HONNALLI_66, KATTIGE_66	5:34	5:46	0:12	LINE FAULT
1165	9-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	4:10	6:50	2:40	LINE FAULT
1166	9-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	19:26	20:00	0:33	LINE FAULT
1167	9-Jun-22	TUMKUR	66	TR-1	CHITRAHALLI_66	0:05	0:13	0:07	TRANSFORMER FAULT
1168	9-Jun-22	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	18:21	18:30	0:09	LINE FAULT
1169	9-Jun-22	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	19:13	19:24	0:10	LINE FAULT
1170	9-Jun-22	TUMKUR	66	TR-2	LINGADAHALLI_66	12:04	13:23	1:18	LINE CLEAR AVAILED
1171	9-Jun-22	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	6:18	6:49	0:31	MAIN SUPPLY FAILURE
1172	9-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	11:41	12:06	0:25	LINE CLEAR AVAILED
1173	9-Jun-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1 & 2	WLSPNSOLAR1 & 2	11:41	12:06	0:25	LINE CLEAR AVAILED
1174	9-Jun-22	TUMKUR	66	TR-1 & TR-2	RANGANATHAPURA_66	14:26	14:46	0:19	LINE CLEAR AVAILED
1175	9-Jun-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1 & 2	WLSPNSOLAR1 & 2	14:26	14:48	0:21	LINE CLEAR AVAILED
1176	9-Jun-22	TUMKUR	66	TR-1	SANTEMNAVATTUR_66	12:48	12:55	0:07	TRANSFORMER FAULT
1177	9-Jun-22	TUMKUR	66	TR-1	THIPPUR_66	17:44	18:43	0:59	LINE CLEAR AVAILED
1178	10-Jun-22	TUMKUR	220	GUTTUR 400KV- RANIBENNUR 220	GUTTUR_400	14:20	14:52	0:32	LINE FAULT
1179	10-Jun-22	TUMKUR	220	ANANTHRASANAHALI_220- 220KV SHIVMOGA LINE	ANTHRASANAHALI_220	11:44	18:45	7:01	LINE CLEAR AVAILED
1180	10-Jun-22	TUMKUR	110	KB CROSS 220kV-AMMASANDRA_66	AMMASANDRA_110,SAMPIGE_110	11:31	14:25	2:54	LINE CLEAR AVAILED
1181	10-Jun-22	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL66	KUNIGAL	12:06	12:16	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1182	10-Jun-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAKERE_66,ANKASANDRA_66	5:48	6:02	0:14	LINE FAULT
1183	10-Jun-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJHALLI_66	10:50	16:16	5:26	LINE CLEAR AVAILED
1184	10-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53(10.06.22)			LIE OPEN: LINE FAULT
1185	10-Jun-22	TUMKUR	66	CTA LINE-1	DAVANGERE_SRS_220	11:02	11:12	0:10	LINE FAULT
1186	10-Jun-22	TUMKUR	66	TR1 AND TR2	HDPURA_66	15:36	15:45	0:09	MAIN SUPPLY FAILURE
1187	10-Jun-22	TUMKUR	66	TR2	HIRIYUR_66	10:15	12:20	2:05	MAIN SUPPLY FAILURE
1188	10-Jun-22	TUMKUR	66	TR1 AND TR2	HIRIYUR_66	12:30	14:30	2:00	MAIN SUPPLY FAILURE
1189	10-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:19	6:35	0:16	LINE FAULT
1190	10-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:25	11:30	0:05	LINE FAULT
1191	10-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:45	12:20	0:35	LINE FAULT
1192	10-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:35	12:45	0:10	LINE FAULT
1193	10-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:15	13:25	0:10	LINE FAULT
1194	10-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:20	14:35	0:15	LINE FAULT
1195	10-Jun-22	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66	5:40	6:00	0:20	MAIN SUPPLY FAILURE
1196	10-Jun-22	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	5:40	6:15	0:35	LINE FAULT
1197	11-Jun-22	TUMKUR	66	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	10:12	16:05	5:53	LINE CLEAR AVAILED
1198	11-Jun-22	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:05	18:21	3:16	LINE CLEAR AVAILED
1199	11-Jun-22	TUMKUR	66	TR1(BBL)	DAVANGERE_SRS_220	10:03	15:18	5:15	LINE CLEAR AVAILED
1200	11-Jun-22	TUMKUR	66	TR2(NGEF)	DAVANGERE_SRS_220	10:03	15:18	5:15	LINE CLEAR AVAILED
1201	11-Jun-22	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:15	11:21	0:06	LINE FAULT
1202	11-Jun-22	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	11:15	11:22	0:07	LINE FAULT
1203	11-Jun-22	TUMKUR	66	HONNALI66-HONNALLI220	HONNALI_66	16:51	16:59	0:08	LINE FAULT
1204	11-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:55	6:00	0:05	LINE FAULT
1205	11-Jun-22	TUMKUR	66	TR1	KUNDUR_66	4:55	5:40	0:45	LINE CLEAR AVAILED
1206	11-Jun-22	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	3:20	6:10	2:50	LINE CLEAR AVAILED
1207	11-Jun-22	TUMKUR	66	PD KOTE-SOLITAIRE	SOLITAIRE	9:50	10:00	0:10	LINE FAULT
1208	11-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53:00 AM(10.06.2022)			LIE OPEN: LINE FAULT
1209	12-Jun-22	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	15:00	16:00	1:00	LINE FAULT
1210	12-Jun-22	TUMKUR	66	TR1 AND TR2	HDPURA_66	11:46	11:51	0:05	TRANSFORMER FAULT
1211	12-Jun-22	TUMKUR	66	TR3	HARIYABBE_66	8:35	8:40	0:05	TRANSFORMER FAULT
1212	12-Jun-22	TUMKUR	66	TR1 AND TR2	HARIYABBE_66	15:50	16:05	0:15	MAIN SUPPLY FAILURE
1213	12-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:20	10:35	0:15	LINE FAULT
1214	12-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:05	17:20	0:15	LINE FAULT
1215	12-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:05	18:40	0:35	LINE FAULT
1216	12-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	18:05	18:35	0:30	LINE FAULT
1217	12-Jun-22	TUMKUR	66	TR1 AND TR2	PD KOTE_66	15:50	16:04	0:14	MAIN SUPPLY FAILURE
1218	12-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53:00 AM(10.06.2022)			LIE OPEN: LINE FAULT
1219	13-Jun-22	TUMKUR	220	THALLAK_220-220KV HM HOLE LINE-2	THALLAK_220	12:09	13:00	0:51	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1220	13-Jun-22	TUMKUR	220	THALLAK_220-220KV BARC LINE -1	THALLAK_220	13:02	13:17	0:15	LINE FAULT
1221	13-Jun-22	TUMKUR	220	THALLAK_220-220KV SVIPL LINE-1	THALLAK_220	14:36	14:37	0:01	LINE FAULT
1222	13-Jun-22	TUMKUR	220	THALLAK_220-220KV SVIPL LINE-1	THALLAK_220	14:48	14:49	0:01	LINE FAULT
1223	13-Jun-22	TUMKUR	220	THALLAK_220-220KV SVIPL LINE-2	THALLAK_220	14:23	14:34	0:11	LINE FAULT
1224	13-Jun-22	TUMKUR	220	THALLAK_220-220KV BARC LINE -1	THALLAK_220	13:36	13:44	0:08	LINE FAULT
1225	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-1	GUTTUR_220	12:08	12:37	0:29	LINE FAULT
1226	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-2	GUTTUR_220	12:39	12:41	0:02	LINE FAULT
1227	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-2	GUTTUR_220	13:09	13:23	0:14	LINE FAULT
1228	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-2	GUTTUR_220	15:18	15:23	0:05	LINE FAULT
1229	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-2	GUTTUR_220	15:34	15:37	0:03	LINE FAULT
1230	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-1	GUTTUR_220	16:01	16:09	0:08	LINE FAULT
1231	13-Jun-22	TUMKUR	220	TR1	GUTTUR_220	16:03	16:09	0:06	TRANSFORMER FAULT
1232	13-Jun-22	TUMKUR	220	220KV GUTTUR LINE-2	GUTTUR_220	16:11	16:13	0:02	LINE FAULT
1233	13-Jun-22	TUMKUR	220	TR2	GUTTUR_220	16:11	16:13	0:02	TRANSFORMER FAULT
1234	13-Jun-22	TUMKUR	220	TR2(LV SIDE)	GUTTUR_220	16:12	16:13	0:01	TRANSFORMER FAULT
1235	13-Jun-22	TUMKUR	220	TR1(HV SIDE AND LV SIDE)	GUTTUR_220	16:14	16:16	0:02	TRANSFORMER FAULT
1236	13-Jun-22	TUMKUR	220	220 BUS COUPLER	GUTTUR_220	16:25	16:30	0:05	TRANSFORMER FAULT
1237	13-Jun-22	TUMKUR	220	GUTTUR_220-66KV DITTURU LINE	GUTTUR_220	16:26	16:27	0:01	LINE FAULT
1238	13-Jun-22	TUMKUR	220	66KV BUS COUPLER	GUTTUR_220	16:28	17:31	1:03	LINE FAULT
1239	13-Jun-22	TUMKUR	110	NITTUR_220-110KV SOMLAPURA	NITTUR_220	16:48	17:15	0:27	LINE FAULT
1240	13-Jun-22	TUMKUR	66	TR1	NITTUR_220	16:48	17:18	0:30	TRANSFORMER FAULT
1241	13-Jun-22	TUMKUR	66	THALLAK 220kv- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	13:22	13:49	0:27	LINE FAULT
1242	13-Jun-22	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66,JAVAGONDANAHALLI_66,DASUDI_66	19:15	19:25	0:10	LINE FAULT
1243	13-Jun-22	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	14:48	14:49	0:01	LINE FAULT
1244	13-Jun-22	TUMKUR	66	DASUDI66-HIRIYUR220	DASUDI_66	19:15	19:45	0:30	LINE FAULT
1245	13-Jun-22	TUMKUR	66	PD KOTE--CLEAN SOLAR	PD KOTE_66	11:15	11:20	0:05	LINE FAULT
1246	13-Jun-22	TUMKUR	66	TR2	AVAREGERE_66	12:27	13:10	0:43	LINE CLEAR AVAILED
1247	13-Jun-22	TUMKUR	66	MADHUGIRI_220 -BADAVANHALLI_66	BADAVANAHALLI_66	12:20	13:55	1:35	LINE CLEAR AVAILED
1248	13-Jun-22	TUMKUR	66	TR1	BADAVANAHALLI_66	12:20	13:55	1:35	LINE CLEAR AVAILED
1249	13-Jun-22	TUMKUR	66	TR2	BADAVANAHALLI_66	11:55	13:55	2:00	LINE CLEAR AVAILED
1250	13-Jun-22	TUMKUR	66	TR3	HARIYABBE_66	18:40	18:45	0:05	TRANSFORMER FAULT
1251	13-Jun-22	TUMKUR	66	TR1	HONNALI_66	22:10	22:45	0:35	TRANSFORMER FAULT
1252	13-Jun-22	TUMKUR	66	TR1	NEERGUNDA_66	6:00	6:15	0:15	TRANSFORMER FAULT
1253	13-Jun-22	TUMKUR	66	TR1	NEERGUNDA_66	13:05	13:35	0:30	LINE CLEAR AVAILED
1254	13-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53:00 AM(10.06.2022)			LIE OPEN: LINE FAULT
1255	13-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53:00 AM(10.06.2022)			LIE OPEN: LINE FAULT
1256	9-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1257	9-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1258	9-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1259	9-Jun-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LIE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1260	9-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1261	9-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1262	9-Jun-22	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1263	9-Jun-22	HASSAN	66	HV1	AREHALLI_66	17:55(07.08.2022)	17:35(9.08.02022)	47:39 hrs	TRANSFORMER CHARGED
1264	9-Jun-22	HASSAN	110	HV2	KADUR_220	10:45	13:39	2:54	LINE CLEAR AVAILED
1265	9-Jun-22	HASSAN	110	HV1	KALLUSADARAHALLI_110	10:30	16:32	6:02	LINE CLEAR AVAILED
1266	9-Jun-22	HASSAN	110	Manipal1	KEMAR_220	13:46	15:47	2:01	LINE CLEAR AVAILED
1267	9-Jun-22	HASSAN	110	Manipal2	KEMAR_220	11:22	13:47	2:25	LINE CLEAR AVAILED
1268	9-Jun-22	HASSAN	110	NANDHIKUR2	KEMAR_220	10:32	13:50	3:18	LINE CLEAR AVAILED
1269	9-Jun-22	HASSAN	110	MANJESWARG	KONAJE_110	12:26	17:44	5:18	LINE CLEAR AVAILED
1270	9-Jun-22	HASSAN	110	KEMAR1	MANIPAL_110	13:46	15:47	2:01	NFBC ISSUED
1271	9-Jun-22	HASSAN	110	KEMAR2	MANIPAL_110	11:22	13:47	2:25	NFBC ISSUED
1272	9-Jun-22	HASSAN	110	BADRAVATY2	MRSMSG_220	9:45	12:48	3:03	LINE CLEAR AVAILED
1273	9-Jun-22	HASSAN	66	HV1	AREHALLI_66	11:43	14:58	3:15	LINE CLEAR AVAILED
1274	9-Jun-22	HASSAN	66	HV1	AREHALLI_66	15:35	17:35	2:00	LINE CLEAR AVAILED
1275	9-Jun-22	HASSAN	66	SAKLESPUR	AREHALLI_66	11:41	12:00	0:19	LINE CLEAR AVAILED
1276	9-Jun-22	HASSAN	66	HV1	BAGUR_66	10:30	16:45	6:15	LINE CLEAR AVAILED
1277	9-Jun-22	HASSAN	66	HV2	BAGUR_66	10:30	16:45	6:15	LINE CLEAR AVAILED
1278	9-Jun-22	HASSAN	66	RAMAPUR	BAGUR_66	14:40	16:40	2:00	LINE CLEAR AVAILED
1279	9-Jun-22	HASSAN	66	UDAYAPUR	BAGUR_66	14:40	16:40	2:00	LINE CLEAR AVAILED
1280	9-Jun-22	HASSAN	66	BEGUR	RAMPURA_66	12:24	15:17	2:53	LINE CLEAR AVAILED
1281	9-Jun-22	HASSAN	66	HV1	RAMPURA_66	11:22	15:17	3:55	LINE CLEAR AVAILED
1282	9-Jun-22	HASSAN	66	HV2	RAMPURA_66	12:24	15:17	2:53	LINE CLEAR AVAILED
1283	9-Jun-22	HASSAN	66	IPCL1	SAKALESH PURA_66	12:21	14:48	2:27	LINE CLEAR AVAILED
1284	9-Jun-22	HASSAN	66	IPCL2	SAKALESH PURA_66	12:21	14:48	2:27	LINE CLEAR AVAILED
1285	10-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1286	10-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1287	10-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1288	10-Jun-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LIE OPEN: LINE FAULT
1289	10-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1290	10-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1291	10-Jun-22	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1292	10-Jun-22	HASSAN	220	SHRAVITY-SHIMOGA1	gen_sharavaty	11:07	12:36	1:29	LINE CLEAR AVAILED
1293	10-Jun-22	HASSAN	220	KEMAR-VARAH1	KEMAR_220	11:30	16:03	4:33	NFBC ISSUED
1294	10-Jun-22	HASSAN	220	VARAH1-KEMAR1	gen_varahi	11:30	16:03	4:33	LINE CLEAR AVAILED
1295	10-Jun-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	20:20	20:50	0:30	LINE FAULT
1296	10-Jun-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	8:00	8:13	0:13	LINE FAULT
1297	10-Jun-22	HASSAN	110	JOG110-AMBTR1	JOG_110	8:25	16:25	8:00	LINE CLEAR AVAILED
1298	10-Jun-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	20:20	20:50	0:30	LINE FAULT
1299	10-Jun-22	HASSAN	110	HV1	SHIRALKOPPA_220	14:48	15:23	0:35	LINE CLEAR AVAILED
1300	11-Jun-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)	15:24(11.6.2022)	457:18 hrs	LINE CHARGED
1301	11-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1302	11-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1303	11-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1304	11-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1305	11-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1306	11-Jun-22	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1307	11-Jun-22	HASSAN	220	GERSOPA-SHIMOGA	gen_gersoppa	18:35	19:35	1:00	LINE FAULT
1308	11-Jun-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:13	16:13	5:00	NFBC ISSUED
1309	11-Jun-22	HASSAN	220	MRSSHM-STRP	MRSMG_220	18:35	19:27	0:52	LINE FAULT
1310	11-Jun-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	gen_sharavathy	10:04	16:23	6:19	LINE CLEAR AAVAILED
1311	11-Jun-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:03	16:22	6:19	LINE CLEAR AAVAILED
1312	11-Jun-22	HASSAN	220	VARAHI-KEMAR2	VARAHI	11:12	16:13	5:01	LINE CLEAR AAVAILED
1313	11-Jun-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	11:50	15:24	3:34	LINE CLEAR AAVAILED
1314	12-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1315	12-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1316	12-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1317	12-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1318	12-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1319	12-Jun-22	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1320	12-Jun-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:34(12.6.2022)			LINE OPEN :LINE CLEAR AAVAILED
1321	12-Jun-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	9:31	20:06	10:35	LINE CLEAR AAVAILED
1322	12-Jun-22	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	5:32	6:22	0:50	LINE FAULT
1323	12-Jun-22	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	16:01	17:26	1:25	LINE FAULT
1324	12-Jun-22	HASSAN	110	JOG-JST2	JOG_110	14:46	16:19	1:33	LINE FAULT
1325	12-Jun-22	HASSAN	110	HV2	KONAJE_110	21:01	22:18	1:17	TRANSFORMER FAULT
1326	12-Jun-22	HASSAN	110	SAGARA-ALKLA	SAGARA_110	16:01	17:26	1:25	LINE FAULT
1327	12-Jun-22	HASSAN	110	SAGARA-JST2	SAGARA_110	14:46	16:18	1:32	LINE FAULT
1328	12-Jun-22	HASSAN	66	HNPR2-BANDISHETTIHALLI	HOLENARASIPURA_220	18:36	18:42	0:06	LINE FAULT
1329	12-Jun-22	HASSAN	66	MALALI-CRPATNA	MALALI_66	5:47	6:16	0:29	LINE FAULT
1330	13-Jun-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1331	13-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AAVAILED
1332	13-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1333	13-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1334	13-Jun-22	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)			TRANSFORMER OPEN :LINE CLEAR AAVAILED
1335	13-Jun-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:34(12.6.2022)			LINE OPEN :LINE CLEAR AAVAILED
1336	13-Jun-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)	12:30(13.06.2022)	304:35hrs	TRANSFORMER CHARGED
1337	13-Jun-22	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:16	13:02	2:46	LINE CLEAR AAVAILED
1338	13-Jun-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:26	13:07	2:41	LINE CLEAR AAVAILED
1339	13-Jun-22	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	9:43	12:53	3:10	NFBC ISSUED
1340	13-Jun-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	10:16	13:02	2:46	NFBC ISSUED
1341	13-Jun-22	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	16:48	16:56	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1342	13-Jun-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:36	15:04	4:28	LINE CLEAR AVAILED
1343	13-Jun-22	HASSAN	220	VARAHI-KEMAR3	varahi_gen	14:18	17:07	2:49	LINE CLEAR AVAILED
1344	13-Jun-22	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	9:43	12:53	3:10	LINE CLEAR AVAILED
1345	13-Jun-22	HASSAN	110	HV1	BARANGI_110	11:10	16:30	5:20	LINE CLEAR AVAILED
1346	13-Jun-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:27	13:07	2:40	NFBC ISSUED
1347	13-Jun-22	HASSAN	110	HV1	HALADY_110	10:17	13:00	2:43	LINE CLEAR AVAILED
1348	13-Jun-22	HASSAN	110	HV2	HALADY_110	14:10	15:31	1:21	LINE CLEAR AVAILED
1349	13-Jun-22	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	12:02	12:17	0:15	HAND TRIPPED
1350	13-Jun-22	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	12:27	12:57	0:30	HAND TRIPPED
1351	13-Jun-22	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	12:00	13:01	1:01	LINE CLEAR AVAILED
1352	13-Jun-22	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLY_110	10:20	15:20	5:00	LINE CLEAR AVAILED
1353	13-Jun-22	HASSAN	110	HV	KITTADAHALLY_110	15:00	16:20	1:20	LINE CLEAR AVAILED
1354	13-Jun-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:20	15:11	4:51	LINE CLEAR AVAILED
1355	13-Jun-22	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_220	16:47	16:57	0:10	LINE FAULT
1356	13-Jun-22	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_220	16:47	16:57	0:10	LINE FAULT
1357	13-Jun-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	16:47	16:57	0:10	LINE FAULT
1358	13-Jun-22	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	16:47	16:57	0:10	LINE FAULT
1359	13-Jun-22	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:32	13:57	3:25	LINE CLEAR AVAILED
1360	13-Jun-22	HASSAN	66	HV1	RAMPURA_66	16:50	17:00	0:10	MAIN SUPPLY FAILURE
1361	13-Jun-22	HASSAN	66	HV2	RAMPURA_66	16:50	17:00	0:10	MAIN SUPPLY FAILURE
1362	13-Jun-22	HASSAN	66	HV1	SINGAPURA_66	10:43	11:40	0:57	LINE CLEAR AVAILED
1363	13-Jun-22	HASSAN	66	HV2	SINGAPURA_66	11:36	12:40	1:04	LINE CLEAR AVAILED