

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 07.05.2019 to 13.05.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	7-May-19	BAGALKOT	220	BIDNAL-SOUNDATTI	BIDNAL_220	16:38	23:04	6:26	LINE FAULT
2	7-May-19	BAGALKOT	220	CHIKKODI-MUDASHINGI (KOLHAPUR 2)	CHIKKODI_220	10:57	15:10	4:13	LINE CLEAR AVAILED
3	7-May-19	BAGALKOT	400	400/1220KV ICT2(HV&LV)	DHONI_400	6:22	7:28	1:06	TRANSFORMER FAULT
4	7-May-19	BAGALKOT	400	400/220KV GUDADALLI (TIE BREAKER2)	DHONI_400	6:22	7:52	1:30	LINE FAULT
5	7-May-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	9:11	16:09	6:58	LINE CLEAR AVAILED
6	7-May-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	22:26	22:27	0:01	TRANSFORMER FAULT
7	7-May-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	22:10	22:40	0:30	MAIN SUPPLY FAILURE
8	7-May-19	BENGALURU	66	WELCAST - BMRL (EHT)	BMRL (EHT)	17:27	17:47	0:20	MAIN SUPPLY FAILURE
9	7-May-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:27	16:52	1:25	MAIN SUPPLY FAILURE
10	7-May-19	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	20:48	21:55	1:07	LINE CLEAR AVAILED
11	7-May-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	17:38	18:10	0:32	LINE FAULT
12	7-May-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	18:10	22:24	4:13	LINE FAULT
13	7-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:34	17:57	0:23	LINE FAULT
14	7-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:34	17:57	0:23	LINE FAULT
15	7-May-19	BENGALURU	66	HV2	GOWRIBIDANUR 220	15:42	15:47	0:05	TRANSFORMER FAULT
16	7-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	20:00	21:13	1:13	LINE FAULT
17	7-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	21:13	22:10	0:57	LINE FAULT
18	7-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	22:10	23:00	0:50	LINE FAULT
19	7-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	23:00	23:59	0:59	LINE FAULT
20	7-May-19	BENGALURU	66	HV2	MALLASANDRA	19:02	19:29	0:26	TRANSFORMER FAULT
21	7-May-19	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	17:27	17:40	0:13	LINE FAULT
22	7-May-19	BENGALURU	220	NELAMANGALA 400 - YELAHANKA 220	YELAHANKA 220	17:15	23:59	6:43	LINE FAULT
23	7-May-19	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 2	SRS PEENYA 220	17:15	17:48	0:32	LINE FAULT
24	7-May-19	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	17:15	18:08	0:53	LINE FAULT
25	7-May-19	BENGALURU	220	KOLAR 220 - RAILWAYS 1 (EHT)	BANGARPET RAILWAYS (EHT)	20:54	21:58	1:04	LINE FAULT
26	7-May-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:53	21:53	1:00	LINE FAULT
27	7-May-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	20:43	21:50	1:07	LINE FAULT
28	7-May-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:27	16:52	1:25	LINE FAULT
29	7-May-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:34	16:52	1:18	LINE FAULT
30	7-May-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	15:45	16:52	1:07	LINE FAULT
31	7-May-19	BENGALURU	220	LV1	MALUR 220	15:27	16:52	1:25	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
32	7-May-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:19	17:31	0:12	LINE FAULT
33	7-May-19	GULBARGA	110	HV2	KAMPLI_GLB_110	14:30	14:50	0:20	TRANSFORMER FAULT
34	7-May-19	GULBARGA	220	LINGAPUR-JVSWL	JSWVL_220	10:22	14:53	4:31	NFBC ISSUED
35	7-May-19	GULBARGA	110	HV1	SIRWAR_110	23:50	23:59	0:09	LINE CLEAR AVAILED
36	7-May-19	GULBARGA	66	HV2	TAMBRAHALLI_66	9:30	11:25	1:55	LINE CLEAR AVAILED
37	7-May-19	GULBARGA	220	KUSTAGI- LINGAPUR	LINGAPUR_220	8:37	9:00	0:23	LINE FAULT
38	7-May-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:11	16:32	0:21	LINE FAULT
39	7-May-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:11	16:33	0:22	LINE FAULT
40	7-May-19	HASSAN	110	HV1	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
41	7-May-19	HASSAN	110	HV2	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
42	7-May-19	HASSAN	110	HV3	MRSMG_220	13:21	13:47	0:26	TRANSFORMER FAULT
43	7-May-19	HASSAN	110	HV4	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
44	7-May-19	HASSAN	66	LV1	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
45	7-May-19	HASSAN	66	LV2	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
46	7-May-19	HASSAN	66	LV3	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
47	7-May-19	HASSAN	66	LV4	MRSMG_220	13:26	13:50	0:24	TRANSFORMER FAULT
48	7-May-19	HASSAN	66	MRSSHM-BD-2	MRSMG_220	13:26	13:50	0:24	HAND TRIPPED
49	7-May-19	HASSAN	66	MRSSHM-DVG2	MRSMG_220	13:26	13:50	0:24	HAND TRIPPED
50	7-May-19	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	13:26	13:50	0:24	HAND TRIPPED
51	7-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	8:05	19:05	11:00	LINE CLEAR AVAILED
52	7-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	8:05	19:05	11:00	LINE CLEAR AVAILED
53	7-May-19	HASSAN	66	HV1	TAVARECHATNAHALLY_66	6:38	6:45	0:07	TRANSFORMER FAULT
54	7-May-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:11	16:32	0:21	MAIN SUPPLY FAILURE
55	7-May-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:11	16:33	0:22	MAIN SUPPLY FAILURE
56	7-May-19	MYSORE	66	BILIKERE -GV GUDI	GVGUDI_66	10:02	10:38	0:35	LINE CLEAR AVAILED
57	7-May-19	MYSORE	66	KUSHALNAGARA -BYLKUPPE	BYLUKUPPE_66	5:54	6:04	0:10	LINE FAULT
58	7-May-19	MYSORE	66	HV2	SALIGRAMA_66	11:23	11:28	0:05	TRANSFORMER FAULT
59	7-May-19	MYSORE	66	HV5	SFCSHIVA_66	6:15	17:57	11:42	LINE CLEAR AVAILED
60	7-May-19	MYSORE	66	TUBINKERE-MC-2	MANDYA_66	10:24	10:36	0:11	HAND TRIPPED
61	7-May-19	MYSORE	66	VAJMANGALA-KADAKOLA1	AYRALLI_66 MARADIHUNDI_66	16:02	17:09	1:06	LINE FAULT
62	7-May-19	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	9:58	14:58	5:00	LINE CLEAR AVAILED
63	7-May-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	14:07	14:47	0:40	LINE FAULT
64	7-May-19	TUMKUR	110	TR-2	TURUVEKERE_110	18:52	19:00	0:08	TRANSFORMER FAULT
65	7-May-19	TUMKUR	66	TR-1	CHANNAGIRI_66	20:09	20:18	0:09	TRANSFORMER FAULT
66	7-May-19	TUMKUR	66	TR-1	CHANNAGIRI_66	21:01	21:57	0:55	TRANSFORMER FAULT
67	7-May-19	TUMKUR	66	TR-2	CHITRADURGA_220	6:03	12:03	6:00	TRANSFORMER FAULT
68	7-May-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:41	7:07	0:25	LINE FAULT
69	7-May-19	TUMKUR	66	TR-2	GUTTUR_66	6:41	7:07	0:26	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
70	7-May-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	19:21	19:47	0:25	LINE FAULT
71	7-May-19	TUMKUR	66	TR-2	SANIKERE_66	16:06	16:18	0:11	TRANSFORMER FAULT
72	7-May-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:40	13:29	2:48	LINE FAULT
73	8-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	5:44	6:14	0:30	LINE FAULT
74	8-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	11:09	14:48	3:39	LINE CLEAR AVAILED
75	8-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	16:02	23:59	7:57	LINE CLEAR AVAILED
76	8-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	16:02	19:17	3:15	LINE CLEAR AVAILED
77	8-May-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	16:03	19:16	3:13	LINE CLEAR AVAILED
78	8-May-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:43	6:02	0:19	LINE FAULT
79	8-May-19	BAGALKOT	110	110/33KV,HV3	GADAG_110,KAPPAH GUDDA_IPP,PIONEER_IPP,NAGAVI _33,MALASAMUDRA_33	14:50	16:20	1:30	LINE CLEAR AVAILED
80	8-May-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	7:15	7:20	0:05	TRANSFORMER FAULT
81	8-May-19	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	16:30	17:38	1:08	LINE CLEAR AVAILED
82	8-May-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	20:11	20:15	0:04	TRANSFORMER FAULT
83	8-May-19	BAGALKOT	220	KUDUCHI-CHIKKODI	KUDUCHI_220	5:43	6:12	0:29	LINE FAULT
84	8-May-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINAKOPPA_110	17:16	20:26	3:10	LINE FAULT
85	8-May-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	14:25	19:10	4:45	LINE CLEAR AVAILED
86	8-May-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	17:49	18:54	1:05	TRANSFORMER FAULT
87	8-May-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	17:27	17:44	0:17	LINE CLEAR AVAILED
88	8-May-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_110	11:06	13:29	2:23	NFBC ISSUED
89	8-May-19	BAGALKOT	220	SIRSI-SHARAVATHI2	SIRSI_220	9:10	14:03	4:53	LINE CLEAR AVAILED
90	8-May-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	11:08	12:10	1:02	LINE CLEAR AVAILED
91	8-May-19	BAGALKOT	110	PG HUNSHYAL-NAGANUR	NAGANUR_110	4:33	4:41	0:08	LINE FAULT
92	8-May-19	BAGALKOT	110	SATTI SUGAR-P G HUNSHYAL	P G HUNSHYAL_110	11:49	12:06	0:17	LINE CLEAR AVAILED
93	8-May-19	BENGALURU	66	SRS PEENYA 220 - BMRCL (EHT)	BMRCL (EHT)	0:00	5:50	5:50	LINE FAULT
94	8-May-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	0:00	0:44	0:44	LINE FAULT
95	8-May-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	1:35	1:38	0:03	LOAD CHANGEVOER
96	8-May-19	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	15:52	15:55	0:03	LOAD CHANGEVOER
97	8-May-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	14:40	15:13	0:33	MAIN SUPPLY FAILURE
98	8-May-19	BENGALURU	66	IISC - NRS 220	IISC	5:35	5:44	0:09	LOAD CHANGEVOER
99	8-May-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	13:30	13:50	0:20	LINE FAULT
100	8-May-19	BENGALURU	66	HV2	HEJJALA	0:03	0:15	0:12	TRANSFORMER FAULT
101	8-May-19	BENGALURU	66	CHANDRA LAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	12:58	13:38	0:40	LINE CLEAR AVAILED
102	8-May-19	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	16:07	16:10	0:03	LOAD CHANGEVOER
103	8-May-19	BENGALURU	66	ABBIGERE - DG3	ABBIGERE	14:41	15:12	0:31	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
104	8-May-19	BENGALURU	66	ANJANAPURA	HV1	18:21	18:28	0:06	LINE FAULT
105	8-May-19	BENGALURU	66	BTM 4TH PHASE	HV1	15:25	15:30	0:04	LINE CLEAR AVAILED
106	8-May-19	BENGALURU	66	HAL 220	HV1	16:46	17:29	0:43	LINE CLEAR AVAILED
107	8-May-19	BENGALURU	66	VIJAYANAGAR	HV2	12:56	13:41	0:45	LINE CLEAR AVAILED
108	8-May-19	BENGALURU	66	YERANDANAHALLI 2200	HV23	16:24	16:38	0:14	LINE FAULT
109	8-May-19	BENGALURU	66	TAVAREKERE	HV1	12:09	12:21	0:12	LINE FAULT
110	8-May-19	BENGALURU	66	PRESTIGE SHANTINIKETHAN	HV1	12:02	13:08	1:05	LINE CLEAR AVAILED
111	8-May-19	BENGALURU	66	KHODAYS 220	HV1	11:01	12:39	1:37	LINE CLEAR AVAILED
112	8-May-19	BENGALURU	66	HEJJALA	HV2	11:15	12:06	0:51	LINE CLEAR AVAILED
113	8-May-19	BENGALURU	66	HEJJALA	HV2	16:49	16:58	0:09	LINE FAULT
114	8-May-19	BENGALURU	66	HV1	CHANNAPATNA	10:32	10:38	0:06	LINE CLEAR AVAILED
115	8-May-19	BENGALURU	66	HV1	CHANNAPATNA	12:13	12:16	0:03	LINE CLEAR AVAILED
116	8-May-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	13:30	14:11	0:40	LINE CLEAR AVAILED
117	8-May-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	12:34	12:53	0:18	LINE CLEAR AVAILED
118	8-May-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	7:03	8:01	0:57	LINE CLEAR AVAILED
119	8-May-19	BENGALURU	66	HV1	DEVANAHALLI	16:36	17:33	0:57	LINE CLEAR AVAILED
120	8-May-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	10:08	10:10	0:01	LINE CLEAR AVAILED
121	8-May-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:08	12:00	1:51	LINE CLEAR AVAILED
122	8-May-19	BENGALURU	66	HV2	GOWRIBIDANUR 220	18:00	18:20	0:20	TRANSFORMER FAULT
123	8-May-19	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	5:17	5:27	0:10	LOAD CHANGEVOER
124	8-May-19	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	14:50	14:55	0:05	LOAD CHANGEVOER
125	8-May-19	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	16:01	16:20	0:19	LOAD CHANGEVOER
126	8-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS(EHT)	0:00	0:30	0:30	LINE FAULT
127	8-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS(EHT)	0:31	0:37	0:06	LINE CLEAR AVAILED
128	8-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:27	15:03	0:35	LINE CLEAR AVAILED
129	8-May-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	0:50	0:52	0:02	LOAD CHANGEVOER
130	8-May-19	BENGALURU	66	YELAHANKA 220 - LINE 3	ESCORTS (EHT)	14:41	14:55	0:13	LINE FAULT
131	8-May-19	BENGALURU	220	NELAMANGALA 400 - YELAHANKA 220	YELAHANKA 220	0:00	7:18	7:18	LINE FAULT
132	8-May-19	BENGALURU	66	HV2	NELAMANGALA 66	0:00	0:12	0:12	TRANSFORMER FAULT
133	8-May-19	GULBARGA	400	YTPS-BTPS2	BTPS_400	15:21	17:20	1:59	LINE FAULT
134	8-May-19	GULBARGA	220	LINGAPUR-KUSHTAGI	LINGAPUR_220	12:31	20:22	7:51	LINE CLEAR AVAILED
135	8-May-19	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	17:42	23:59	6:17	LINE CLEAR AVAILED
136	8-May-19	GULBARGA	110	PD_HALLI-BASAI	BASAI	17:05	17:07	0:02	LINE CLEAR AVAILED
137	8-May-19	GULBARGA	110	SINDHNOOR-PGLR_WIND	PGLR_WIND_IPP	4:21	4:50	0:29	LINE FAULT
138	8-May-19	GULBARGA	110	SINDHNOOR_MUNIRABAD2	MUNIRABAD_110	11:45	11:59	0:14	LINE FAULT
139	8-May-19	GULBARGA	66	HV1	HANASI_66	10:56	11:39	0:43	LINE CLEAR AVAILED
140	8-May-19	GULBARGA	66	HV1	ITTAGI_220	11:10	11:20	0:10	TRANSFORMER FAULT
141	8-May-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPP_400	11:45	14:42	2:57	LINE CLEAR AVAILED
142	8-May-19	HASSAN	110	PUTTUR-VITALA	PUTTUR_220	1:47	1:59	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
143	8-May-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:20	14:12	4:52	NFBC ISSUED
144	8-May-19	HASSAN	110	HV3	BANTWAL_!110	10:29	12:13	1:44	LINE CLEAR AVAILED
145	8-May-19	HASSAN	110	HV1	KONAJE_110	11:43	13:25	1:42	LINE CLEAR AVAILED
146	8-May-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	1:49	2:09	0:20	MAIN SUPPLY FAILURE
147	8-May-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	1:57	2:00	0:03	MAIN SUPPLY FAILURE
148	8-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:43	10:50	0:07	LINE FAULT
149	8-May-19	HASSAN	66	BYARAPU-BAGUR	K_BYARAPURA_66	16:20	16:50	0:30	MAIN SUPPLY FAILURE
150	8-May-19	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	16:00	16:59	0:59	LINE FAULT
151	8-May-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	16:55	17:05	0:10	MAIN SUPPLY FAILURE
152	8-May-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	18:05	18:35	0:30	MAIN SUPPLY FAILURE
153	8-May-19	HASSAN	66	HV1	DODDAKADANUR_66	17:00	17:05	0:05	MAIN SUPPLY FAILURE
154	8-May-19	HASSAN	66	HV1	DODDAKADANUR_66	18:08	18:33	0:25	MAIN SUPPLY FAILURE
155	8-May-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	18:06	18:38	0:32	LINE FAULT
156	8-May-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	16:19	18:18	1:59	MAIN SUPPLY FAILURE
157	8-May-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	16:56	17:04	0:08	LINE FAULT
158	8-May-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	18:07	18:33	0:26	LINE FAULT
159	8-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	8:05	14:45	6:40	LINE CLEAR AVAILED
160	8-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	8:05	14:45	6:40	LINE CLEAR AVAILED
161	8-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	15:09	16:10	1:01	LINE CLEAR AVAILED
162	8-May-19	MYSORE	66	HV2	DEVANOORNGUDU_66	10:53	23:59	13:05	TRANSFORMER FAULT
163	8-May-19	MYSORE	66	HV1	HEBBAL_66	13:21	14:43	1:21	LINE CLEAR AVAILED
164	8-May-19	MYSORE	66	HV2	HEBBAL_66	11:50	13:20	1:29	LINE CLEAR AVAILED
165	8-May-19	MYSORE	66	HV2	JAKKANAHALLY_66	8:25	9:08	0:42	TRANSFORMER FAULT
166	8-May-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	19:16	19:26	0:09	LINE FAULT
167	8-May-19	MYSORE	66	HV1	K_HONNALGERE_66	13:19	13:24	0:05	HAND TRIPPED
168	8-May-19	MYSORE	66	HV2	K_HONNALGERE_66	13:19	13:24	0:04	HAND TRIPPED
169	8-May-19	MYSORE	66	HV2	KMDODDI_66	6:21	6:28	0:07	TRANSFORMER FAULT
170	8-May-19	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66 DMG_HALLI_66 GVGUDI_66	18:07	18:19	0:11	LINE FAULT
171	8-May-19	MYSORE	66	KR NAGARA-HN PURA	BHERYA_66	17:00	17:10	0:10	LINE FAULT
172	8-May-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	5:58	6:07	0:08	LINE FAULT
173	8-May-19	TUMKUR	220	TR-2(HV SIDE)	NITTUR_220	13:24	13:45	0:21	LINE CLEAR AVAILED
174	8-May-19	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	13:46	14:03	0:16	LINE CLEAR AVAILED
175	8-May-19	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	13:46	14:03	0:17	LINE CLEAR AVAILED
176	8-May-19	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	13:23	13:45	0:22	LINE CLEAR AVAILED
177	8-May-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	13:16	13:24	0:08	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
178	8-May-19	TUMKUR	66	TR-1	HARIHAR_66	0:21	0:33	0:12	TRANSFORMER FAULT
179	8-May-19	TUMKUR	66	TR-1	HARIHAR_66	15:17	21:44	6:27	TRANSFORMER FAULT
180	8-May-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	4:56	5:37	0:41	HAND TRIPPED
181	8-May-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	18:57	19:10	0:12	LINE FAULT
182	8-May-19	TUMKUR	66	TR-1	MATHOD_66	6:20	6:23	0:03	TRANSFORMER FAULT
183	8-May-19	TUMKUR	66	TR-2	RANGANATHAPURA_66	9:06	13:37	4:30	LINE CLEAR AVAILED
184	8-May-19	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:37	17:18	3:40	LINE CLEAR AVAILED
185	8-May-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	18:33	18:55	0:21	TRANSFORMER FAULT
186	9-May-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	1:44	1:58	0:14	LINE FAULT
187	9-May-19	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,KAMATAGI_3 3	13:20	13:49	0:29	HAND TRIPPED
188	9-May-19	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	13:59	15:29	1:30	LINE CLEAR AVAILED
189	9-May-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	1:45	1:51	0:06	LINE FAULT
190	9-May-19	BAGALKOT	110	AMBEWADI 220-KIRUVATTI	KIRUVATTI_110	11:15	12:02	0:47	LINE FAULT
191	9-May-19	BAGALKOT	110	AMBEWADI 220-KIRUVATTI	KIRUVATTI_110	23:18	23:59	0:41	HAND TRIPPED
192	9-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	1:37	8:52	7:15	LINE FAULT
193	9-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	1:37	18:20	16:43	LINE FAULT
194	9-May-19	BAGALKOT	220	KADRA 1&2-KARWARA	KARWAR_220	13:20	18:16	4:56	LINE CLEAR AVAILED
195	9-May-19	BAGALKOT	110	220/110KV,HV1&LV1	KARWAR_220,KUMTA_110,BINAG A_110,KARWARA_110	13:20	18:16	4:56	LINE CLEAR AVAILED
196	9-May-19	BAGALKOT	110	KARWARA 220-BINAGA	BINAGA_110	9:00	19:44	10:44	LINE CLEAR AVAILED
197	9-May-19	BAGALKOT	110	KARWARA 220-KUMTA	KUMTA_110	9:00	18:21	9:21	LINE CLEAR AVAILED
198	9-May-19	BAGALKOT	220	220/110KV,HV1&2,LV1&2	KUDUCHI_220,TERDAL_110,KUDU CHI_110,UGAR KHUD_110,MORAB_110,AINAPUR _110,YELLAPARATTI_110	1:37	1:40	0:03	TRANSFORMER FAULT
199	9-May-19	BAGALKOT	110	SIRSI-KUMTA	KUMTA_110	18:39	23:59	5:20	LINE CLEAR AVAILED
200	9-May-19	BAGALKOT	110	110/11KV,HV2	PG HUNSYAL_110	13:20	13:43	0:23	LINE CLEAR AVAILED
201	9-May-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	0:17	0:27	0:10	TRANSFORMER FAULT
202	9-May-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	1:32	1:34	0:02	TRANSFORMER FAULT
203	9-May-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	6:35	6:37	0:02	TRANSFORMER FAULT
204	9-May-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	2:02	2:13	0:11	TRANSFORMER FAULT
205	9-May-19	BAGALKOT	220	SIRSI-SHARAVATHI 2	SIRSI_220	8:08	15:10	7:02	LINE CLEAR AVAILED
206	9-May-19	BAGALKOT	220	SIRSI-SHARAVATHI 2	SIRSI_220	15:21	16:08	0:47	LINE CLEAR AVAILED
207	9-May-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	0:20	7:10	6:50	LOAD CURTAILMENT
208	9-May-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	11:18	12:01	0:43	LINE FAULT
209	9-May-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	23:19	23:59	0:40	LOAD CURTAILMENT
210	9-May-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	17:44	17:47	0:03	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
211	9-May-19	BAGALKOT	220	HUBLI-NAGHJARI 3	HUBLI_220, RAMANKOPPA_110, KADANKOPPA_110, KALGHATAGI_110	10:43	11:14	0:31	LINE CLEAR AVAILED
212	9-May-19	BAGALKOT	220	HUBLI-NAGHJARI 3	HUBLI_220, RAMANKOPPA_110, KADANKOPPA_110, KALGHATAGI_110	11:39	12:06	0:27	LINE CLEAR AVAILED
213	9-May-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:43	18:07	0:24	LINE CLEAR AVAILED
214	9-May-19	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	0:29	0:35	0:06	TRANSFORMER FAULT
215	9-May-19	BAGALKOT	110	RAIBAG-ITNAL1	ITNAL_110	10:58	13:05	2:07	LINE CLEAR AVAILED
216	9-May-19	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	10:58	12:33	1:35	LINE CLEAR AVAILED
217	9-May-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	SUBRAMANYAPURA 66, ISKON	19:05	19:54	0:49	LINE FAULT
218	9-May-19	BENGALURU	66	MEI LAYOUT	HV2	10:40	10:45	0:05	LINE CLEAR AVAILED
219	9-May-19	BENGALURU	66	KHODAYS 220	HV2	11:20	11:30	0:10	LINE CLEAR AVAILED
220	9-May-19	BENGALURU	66	MEI LAYOUT	HV1	9:28	9:30	0:01	LINE CLEAR AVAILED
221	9-May-19	BENGALURU	66	KADUGODI	HV2	4:17	10:15	5:58	LINE FAULT
222	9-May-19	BENGALURU	66	KADUGODI	HV2	10:18	11:06	0:48	LINE CLEAR AVAILED
223	9-May-19	BENGALURU	66	KADUGODI	HV2	11:10	12:38	1:28	LINE CLEAR AVAILED
224	9-May-19	BENGALURU	66	HOODY 220	HV1	6:00	11:30	5:29	LINE FAULT
225	9-May-19	BENGALURU	66	ELECTRONIC CITY P2 S2	HV2	16:51	16:58	0:07	LINE FAULT
226	9-May-19	BENGALURU	66	BOODIGERE	HV1	13:45	13:58	0:13	LINE FAULT
227	9-May-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTH NAGAR, YEDUMADU	14:13	14:49	0:35	LINE FAULT
228	9-May-19	BENGALURU	220	KIADB DB PURA 220 - GOWRIBIDANUR 220	KIADB DB PURA 220	14:31	14:35	0:04	LOAD CHANGEVOER
229	9-May-19	BENGALURU	220	KIADB DB PURA 220 - DB PURA 220	KIADB DB PURA 220	15:55	16:05	0:10	LOAD CHANGEVOER
230	9-May-19	BENGALURU	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	14:31	14:35	0:04	MAIN SUPPLY FAILURE
231	9-May-19	BENGALURU	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	15:55	16:05	0:10	MAIN SUPPLY FAILURE
232	9-May-19	BENGALURU	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	14:31	14:35	0:04	MAIN SUPPLY FAILURE
233	9-May-19	BENGALURU	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	15:55	16:05	0:10	MAIN SUPPLY FAILURE
234	9-May-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	17:15	17:30	0:14	LINE FAULT
235	9-May-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 1	MANCHENAHALLI, GUNDAMGERE	17:15	17:30	0:14	LINE FAULT
236	9-May-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	17:15	17:30	0:14	LINE FAULT
237	9-May-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI	6:13	6:26	0:13	LINE FAULT
238	9-May-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	6:13	6:32	0:19	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
239	9-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:06	13:12	1:06	LINE CLEAR AVAILED
240	9-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI	17:16	17:22	0:06	LINE FAULT
241	9-May-19	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	0:00	12:39	12:39	LINE CLEAR AVAILED
242	9-May-19	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	5:13	14:05	8:52	LINE FAULT
243	9-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	5:13	7:30	2:17	LINE FAULT
244	9-May-19	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	5:13	6:41	1:28	LINE FAULT
245	9-May-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	5:13	7:17	2:04	LINE FAULT
246	9-May-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	11:37	18:06	6:29	LINE CLEAR AVAILED
247	9-May-19	GULBARGA	110	HV3	HATTI_110	15:35	23:59	8:24	TRANSFORMER FAULT
248	9-May-19	GULBARGA	400	RTPS-MUNIRABAD400	MUNIRABAD_400	13:09	20:36	7:27	LINE CLEAR AVAILED
249	9-May-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:05	14:18	3:13	LINE CLEAR AVAILED
250	9-May-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:30	14:29	2:59	LINE CLEAR AVAILED
251	9-May-19	HASSAN	220	HV1	KEMAR_220	9:02	18:42	9:40	LINE CLEAR AVAILED
252	9-May-19	HASSAN	110	LV1	KEMAR_220	9:02	18:42	9:40	LINE CLEAR AVAILED
253	9-May-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	11:06	14:19	3:13	LINE CLEAR AVAILED
254	9-May-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	8:30	15:08	6:38	NFBC ISSUED
255	9-May-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:29	14:28	2:59	LINE CLEAR AVAILED
256	9-May-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	6:15	6:30	0:15	LINE FAULT
257	9-May-19	HASSAN	110	HV1	ANANDPURA_110	15:04	17:07	2:03	LINE CLEAR AVAILED
258	9-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:01	13:20	1:19	LINE CLEAR AVAILED
259	9-May-19	HASSAN	110	HV1	GURUVAYANAKERE_110	8:57	9:10	0:13	TRANSFORMER FAULT
260	9-May-19	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	9:05	11:43	2:38	LINE CLEAR AVAILED
261	9-May-19	HASSAN	110	HV2	KULASHEKARA_110	11:21	13:48	2:27	LINE CLEAR AVAILED
262	9-May-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	9:40	13:19	3:39	LINE CLEAR AVAILED
263	9-May-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:16	14:24	0:08	LINE FAULT
264	9-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	8:30	8:38	0:08	LINE FAULT
265	9-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:44	13:51	0:07	LINE FAULT
266	9-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:10	14:21	0:11	LINE FAULT
267	9-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:00	15:25	0:25	LINE FAULT
268	9-May-19	HASSAN	66	BYARAPU-BAGUR	K_BYARAPURA_66	7:50	8:00	0:10	MAIN SUPPLY FAILURE
269	9-May-19	HASSAN	66	HV1	HOLALUR_66	12:38	13:24	0:46	LINE CLEAR AVAILED
270	9-May-19	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	3:53	4:02	0:09	LINE FAULT
271	9-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:55	19:25	9:30	LINE CLEAR AVAILED
272	9-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:55	19:25	9:30	LINE CLEAR AVAILED
273	9-May-19	HASSAN	66	HV2	SAKLESHPURA_66	2:35	3:10	0:35	TRANSFORMER FAULT
274	9-May-19	HASSAN	66	HV2	SATHENAHALLY_66	4:28	4:42	0:14	TRANSFORMER FAULT
275	9-May-19	HASSAN	66	HV2	SATHENAHALLY_66	8:14	8:20	0:06	TRANSFORMER FAULT
276	9-May-19	MYSORE	66	KR NAGARA-KUSHALANAGARA	BHERYA_66 KRNAGARA_66	6:09	7:50	1:41	LINE CLEAR AVAILED
277	9-May-19	MYSORE	66	KR NAGARA-CHUCHUNKATTE	BHERYA_66 KRNAGARA_66	7:00	7:50	0:50	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
278	9-May-19	MYSORE	66	KR NAGARA-HN PURA	BHERYA_66 KRNAGARA_66	7:00	8:05	1:05	LINE CLEAR AVAILED
279	9-May-19	MYSORE	66	KR NAGARA-BILIKERE	BHERYA_66 KRNAGARA_66	6:57	7:50	0:52	LINE CLEAR AVAILED
280	9-May-19	MYSORE	66	HV2	KRPET_66	9:38	23:59	14:21	LINE CLEAR AVAILED
281	9-May-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	5:44	6:02	0:18	LINE FAULT
282	9-May-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	11:06	13:32	2:26	LINE CLEAR AVAILED
283	9-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	11:47	13:34	1:46	LINE CLEAR AVAILED
284	9-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	13:50	14:42	0:52	LINE CLEAR AVAILED
285	9-May-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	13:59	14:26	0:26	LINE CLEAR AVAILED
286	9-May-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:50	13:37	1:47	LINE FAULT
287	9-May-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:50	12:03	0:12	HAND TRIPPED
288	9-May-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:58	12:12	0:13	LINE FAULT
289	9-May-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:51	12:03	0:12	HAND TRIPPED
290	9-May-19	TUMKUR	66	TR-1	HARIHAR_66	11:39	12:23	0:43	LINE CLEAR AVAILED
291	9-May-19	TUMKUR	66	HONNALLI 220KV-NALLUR	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	5:52	5:59	0:06	LINE FAULT
292	9-May-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	17:36	17:50	0:14	LINE CLEAR AVAILED
293	9-May-19	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	14:57	17:44	2:46	LINE CLEAR AVAILED
294	9-May-19	TUMKUR	66	TR-2	THOVINAKERE_66	6:23	6:32	0:08	TRANSFORMER FAULT
295	10-May-19	BAGALKOT	66	66/33KV,HV4	HARIHAR HOSPET_66	17:35	22:04	4:29	LOAD CURTAILMENT
296	10-May-19	BAGALKOT	110	110/11KV,HV1 &HV2	AINAPUR_110	17:38	17:45	0:07	LOAD CURTAILMENT
297	10-May-19	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	8:01	9:53	1:52	LINE CLEAR AVAILED
298	10-May-19	BAGALKOT	110	110/11KV,HV2	ANAND NAGAR_110	10:05	12:09	2:04	LINE CLEAR AVAILED
299	10-May-19	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	15:54	16:05	0:11	LINE CLEAR AVAILED
300	10-May-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:40	17:57	0:17	LOAD CURTAILMENT
301	10-May-19	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	12:08	12:10	0:02	HAND TRIPPED
302	10-May-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI(RAMPUR)	NIDAGUNDI_110	12:04	12:10	0:06	LINE CLEAR AVAILED
303	10-May-19	BAGALKOT	220	BIDNAL-SOUNDATTI	BIDNAL_220	18:18	23:37	5:19	LINE FAULT
304	10-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	10:52	16:35	5:43	LINE CLEAR AVAILED
305	10-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	16:37	19:43	3:06	LINE CLEAR AVAILED
306	10-May-19	BAGALKOT	110	110/33KV,HV2	BELGAUM_110	10:33	23:59	13:26	LINE CLEAR AVAILED
307	10-May-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	5:40	5:44	0:04	TRANSFORMER FAULT
308	10-May-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	2:04	2:20	0:16	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
309	10-May-19	BAGALKOT	110	110/11KV,HV1	UGARKHUD_110	12:35	14:35	2:00	LINE CLEAR AVAILED
310	10-May-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINKOPPA_110	11:01	16:58	5:57	LINE CLEAR AVAILED
311	10-May-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	12:12	13:06	0:54	LINE CLEAR AVAILED
312	10-May-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	18:18	23:10	4:52	LINE FAULT
313	10-May-19	BAGALKOT	110	110/11KV,HV1	HUBLI_220	11:42	12:02	0:20	TRANSFORMER FAULT
314	10-May-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	9:05	13:11	4:06	LINE CLEAR AVAILED
315	10-May-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	0:00	7:03	7:03	LINE CLEAR AVAILED
316	10-May-19	BAGALKOT	110	PG HUNSHYAL -NAGANUR	NAGANUR_110	12:34	15:05	2:31	LINE CLEAR AVAILED
317	10-May-19	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,KOLAR WATER SUPPLY_33KV,KARJOL_33KV,NTPC L_33KV	12:05	12:10	0:05	TRANSFORMER FAULT
318	10-May-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	17:20	17:25	0:05	TRANSFORMER FAULT
319	10-May-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	17:40	17:50	0:10	TRANSFORMER FAULT
320	10-May-19	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	17:39	17:55	0:16	LOAD CURTAILMENT
321	10-May-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	0:00	9:06	9:06	LINE CLEAR AVAILED
322	10-May-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	20:42	23:59	3:17	LINE CLEAR AVAILED
323	10-May-19	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	12:04	20:32	8:28	LINE CLEAR AVAILED
324	10-May-19	BAGALKOT	110	KARWAR-KUMTA	KUMTA_110	9:05	18:46	9:41	LINE CLEAR AVAILED
325	10-May-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	0:00	9:00	9:00	LINE CLEAR AVAILED
326	10-May-19	BAGALKOT	110	110/33KV,HV3	SINDAGI_110,KALKERI_33KV,MYT RA_33KV	17:20	17:45	0:25	LINE CLEAR AVAILED
327	10-May-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNIGANAHALLI	11:55	12:06	0:11	LINE CLEAR AVAILED
328	10-May-19	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 1	SUBRAMANYAPURA 66, ISKON	0:29	0:40	0:10	LOAD CHANGEVOER
329	10-May-19	BENGALURU	66	HV2	HEJJALA	8:37	8:41	0:03	TRANSFORMER FAULT
330	10-May-19	BENGALURU	66	HV2	HEJJALA	11:36	11:41	0:04	TRANSFORMER FAULT
331	10-May-19	BENGALURU	66	HV1	KORMANGALA	15:47	16:00	0:13	LINE CLEAR AVAILED
332	10-May-19	BENGALURU	220	HV2	HSR LAYOUT 220	14:16	14:30	0:14	TRANSFORMER FAULT
333	10-May-19	BENGALURU	220	HV2	HSR LAYOUT 220	15:43	16:49	1:05	TRANSFORMER FAULT
334	10-May-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	12:38	13:39	1:00	LINE FAULT
335	10-May-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:45	12:14	0:29	LINE FAULT
336	10-May-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	12:44	13:40	0:55	LINE FAULT
337	10-May-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	14:55	17:16	2:20	LINE FAULT
338	10-May-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	23:21	23:29	0:08	LOAD CHANGEVOER
339	10-May-19	BENGALURU	66	HV2	YERANDANAHALLI 220	8:10	8:26	0:16	TRANSFORMER FAULT
340	10-May-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	14:17	14:31	0:13	MAIN SUPPLY FAILURE
341	10-May-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	15:44	17:00	1:16	MAIN SUPPLY FAILURE
342	10-May-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	1:32	1:44	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
343	10-May-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	1:45	2:03	0:18	LINE FAULT
344	10-May-19	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	12:25	14:20	1:54	LINE CLEAR AVAILED
345	10-May-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	12:39	14:25	1:45	LINE CLEAR AVAILED
346	10-May-19	BENGALURU	66	HV2	KEMBODI	12:10	12:25	0:15	LINE CLEAR AVAILED
347	10-May-19	GULBARGA	220	HV1	KAPNOOR_220	22:30	23:59	1:29	TRANSFORMER FAULT
348	10-May-19	GULBARGA	220	HUMNABAD-KAPNOOR2	KAPNOOR_220	22:30	22:50	0:20	LINE FAULT
349	10-May-19	GULBARGA	220	HV2,LV2	HALBURGA_220	22:30	22:53	0:23	TRANSFORMER FAULT
350	10-May-19	GULBARGA	110	HV3	HATTI_110	0:00	10:26	10:26	TRANSFORMER FAULT
351	10-May-19	GULBARGA	110	HV1	HANUMASAGAR_110	8:45	11:45	3:00	LINE CLEAR AVAILED
352	10-May-19	GULBARGA	110	GURGUNTA-LJVL_IPP	LJVL_IPP	6:58	7:21	0:23	LINE FAULT
353	10-May-19	GULBARGA	110	HV3,HV4	YELBURGA_110	17:35	18:07	0:32	MAIN SUPPLY FAILURE
354	10-May-19	GULBARGA	110	HV2	VENKATGIRI_110	13:00	13:10	0:10	TRANSFORMER FAULT
355	10-May-19	GULBARGA	110	HV1	TEKALKOTE_110	17:35	17:45	0:10	TRANSFORMER FAULT
356	10-May-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	17:40	18:10	0:30	MAIN SUPPLY FAILURE
357	10-May-19	GULBARGA	110	KOLHAR-SHAHI_SLR IPP	KOLHAR_110	16:39	18:20	1:41	LINE CLEAR AVAILED
358	10-May-19	GULBARGA	110	HV1	KEMBHAVI_110	17:40	17:45	0:05	MAIN SUPPLY FAILURE
359	10-May-19	GULBARGA	110	HV1	AFZALPUR_110	10:05	10:20	0:15	TRANSFORMER FAULT
360	10-May-19	GULBARGA	110	CHICKSUGUR-SHAKTI NAGAR	CHICKSUGUR_110	8:34	9:52	1:18	LINE CLEAR AVAILED
361	10-May-19	GULBARGA	66	HV2	CJHALLI_66	7:58	9:00	1:02	LINE CLEAR AVAILED
362	10-May-19	GULBARGA	66	HV1	SOVENHALLI_66	17:39	18:10	0:31	MAIN SUPPLY FAILURE
363	10-May-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	9:05	11:39	2:34	LINE CLEAR AVAILED
364	10-May-19	HASSAN	110	KADUR-YGTI	KADUR_220	19:19	19:45	0:26	MAIN SUPPLY FAILURE
365	10-May-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:20	23:59	10:39	LINE FAULT
366	10-May-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	9:05	13:57	4:52	NFBC ISSUED
367	10-May-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	13:20	23:59	10:39	LINE FAULT
368	10-May-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:45	12:52	0:07	LINE FAULT
369	10-May-19	HASSAN	110	HV1	HALADY_110	17:36	17:56	0:20	MAIN SUPPLY FAILURE
370	10-May-19	HASSAN	110	HV1	ANANDAPURA_110	16:29	17:29	1:00	LINE CLEAR AVAILED
371	10-May-19	HASSAN	66	HV1	HADAVANAHALLY_66	11:45	13:00	1:15	LINE CLEAR AVAILED
372	10-May-19	HASSAN	66	HV1	KALASAPURA_66	11:31	14:08	2:37	LINE CLEAR AVAILED
373	10-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:34	20:00	12:26	LINE CLEAR AVAILED
374	10-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:34	20:00	12:26	LINE CLEAR AVAILED
375	10-May-19	HASSAN	66	HV2	SINGAPURA_66	8:22	18:52	10:30	LINE CLEAR AVAILED
376	10-May-19	MYSORE	66	HV1	BESAGARAHALLI_66	17:38	17:45	0:06	LOAD CURTAILMENT
377	10-May-19	MYSORE	66	HV2	BOOKANAKERE_66	17:38	23:59	6:20	LOAD CURTAILMENT
378	10-May-19	MYSORE	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	12:52	12:57	0:05	LINE FAULT
379	10-May-19	MYSORE	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	12:57	16:42	3:45	LINE FAULT
380	10-May-19	MYSORE	66	HV2	KRPET_66	20:03	20:17	0:13	HAND TRIPPED
381	10-May-19	MYSORE	66	HV2	KRPET_66	20:18	23:59	3:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
382	10-May-19	MYSORE	66	HV3	KRPET_66	8:07	9:04	0:56	LINE CLEAR AVAILED
383	10-May-19	MYSORE	220	HV2	KRPET_220	10:07	16:37	6:30	LINE CLEAR AVAILED
384	10-May-19	MYSORE	66	HV5	SFCSHIVA_66	0:18	6:55	6:37	LINE CLEAR AVAILED
385	10-May-19	MYSORE	66	HV5	SFCSHIVA_66	12:55	13:18	0:23	HAND TRIPPED
386	10-May-19	MYSORE	66	HV1	THALAKADU_66	12:10	13:25	1:15	LINE CLEAR AVAILED
387	10-May-19	MYSORE	66	HV2	THALAKADU_66	13:22	14:41	1:19	LINE CLEAR AVAILED
388	10-May-19	MYSORE	66	VIJAYANAGARA-HOOTAGALLY	VIJAYANAGRAMYS_66	13:53	14:14	0:20	LINE CLEAR AVAILED
389	10-May-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	MADHUGIRI 220kV	15:31	15:38	0:07	HAND TRIPPED
390	10-May-19	TUMKUR	66	TR-1	BENKIKERE_66	17:30	18:14	0:44	LINE CLEAR AVAILED
391	10-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:40	6:51	0:11	LINE FAULT
392	10-May-19	TUMKUR	66	TR-1	SAVALANGA_66	19:23	20:04	0:40	MAIN SUPPLY FAILURE
393	10-May-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	14:03	14:06	0:03	TRANSFORMER FAULT
394	10-May-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:36	10:47	0:10	LINE FAULT
395	11-May-19	BAGALKOT	220	AMBEWADI -XELDOM (PONDA 1)	AMBEWADI_220	8:40	15:04	6:24	LINE CLEAR AVAILED
396	11-May-19	BAGALKOT	220	BAGEWADI-NANDIHAL 1&2 (BIJAPUR1&2)	BAGEWADI_220	19:12	19:47	0:35	LINE FAULT
397	11-May-19	BAGALKOT	110	110/11KV,HV1	YELPARHATTI_110	6:58	11:30	4:32	TRANSFORMER FAULT
398	11-May-19	BAGALKOT	110	110/11KV,HV2	KALGHATAGI_110	6:57	11:15	4:18	LINE CLEAR AVAILED
399	11-May-19	BENGALURU	66	HV2	BRIGADE METROPOLIS	16:42	16:49	0:07	TRANSFORMER FAULT
400	11-May-19	BENGALURU	66	HV2	BRIGADE METROPOLIS	19:20	19:30	0:10	TRANSFORMER FAULT
401	11-May-19	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	12:47	15:03	2:16	LINE CLEAR AVAILED
402	11-May-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	12:04	15:03	2:59	MAIN SUPPLY FAILURE
403	11-May-19	BENGALURU	66	EDC 220 - BMTC	BMTC	12:03	15:21	3:17	MAIN SUPPLY FAILURE
404	11-May-19	BENGALURU	66	EDC 220 - B STATION	B STATION	12:04	15:03	2:59	MAIN SUPPLY FAILURE
405	11-May-19	BENGALURU	220	EDC 220 - HAL 220	EDC 220	12:02	15:01	2:59	LINE CLEAR AVAILED
406	11-May-19	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	12:02	15:02	2:59	MAIN SUPPLY FAILURE
407	11-May-19	BENGALURU	66	HAL 220 - B STATION	B STATION	11:59	15:35	3:36	MAIN SUPPLY FAILURE
408	11-May-19	BENGALURU	66	HAL 220 - B STATION	B STATION	11:59	15:35	3:36	MAIN SUPPLY FAILURE
409	11-May-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:03	15:08	3:05	MAIN SUPPLY FAILURE
410	11-May-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:57	14:59	3:01	MAIN SUPPLY FAILURE
411	11-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	15:35	16:18	0:43	LINE CLEAR AVAILED
412	11-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	17:01	17:12	0:11	LINE CLEAR AVAILED
413	11-May-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	12:03	15:04	3:01	MAIN SUPPLY FAILURE
414	11-May-19	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	0:24	0:34	0:10	LOAD CHANGEVOER
415	11-May-19	BENGALURU	66	NATIONAL COLLEGE - BMTC	NATIONAL COLLEGE	12:02	13:05	1:02	MAIN SUPPLY FAILURE
416	11-May-19	BENGALURU	66	NATIONAL COLLEGE - VICTORIA	NATIONAL COLLEGE	15:10	15:25	0:15	LOAD CHANGEVOER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
417	11-May-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:09	13:18	3:08	LINE CLEAR AVAILED
418	11-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:43	9:54	0:10	LINE FAULT
419	11-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:43	9:53	0:09	LINE FAULT
420	11-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:28	11:35	1:06	LINE CLEAR AVAILED
421	11-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:07	19:32	0:24	LINE FAULT
422	11-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:26	19:32	0:06	LINE FAULT
423	11-May-19	BENGALURU	220	HOODY 400 - HAL 1	HAL 220, EDC 220	12:02	14:41	2:38	LINE CLEAR AVAILED
424	11-May-19	BENGALURU	220	HOODY 400 - HAL 2	HAL 220, EDC 220	12:01	14:41	2:39	LINE CLEAR AVAILED
425	11-May-19	BENGALURU	66	HV1	BOODIGERE	15:51	16:07	0:15	TRANSFORMER FAULT
426	11-May-19	BENGALURU	220	HV1	EDC 220	12:01	15:06	3:05	LINE CLEAR AVAILED
427	11-May-19	BENGALURU	220	HV1	EDC 220	12:03	15:02	2:58	LINE CLEAR AVAILED
428	11-May-19	BENGALURU	220	HV2	EDC 220	12:03	15:02	2:58	LINE CLEAR AVAILED
429	11-May-19	BENGALURU	66	HV1	NANDINI LAYOUT	8:43	8:45	0:01	LINE CLEAR AVAILED
430	11-May-19	BENGALURU	66	HV2	NANDINI LAYOUT	10:25	10:30	0:04	LINE CLEAR AVAILED
431	11-May-19	BENGALURU	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	8:11	8:37	0:25	LINE FAULT
432	11-May-19	BENGALURU	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	8:09	8:24	0:14	LOAD CHANGEVOER
433	11-May-19	BENGALURU	66	HV2	KIADB DB PURA 220	8:11	8:12	0:01	LOAD CHANGEVOER
434	11-May-19	BENGALURU	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	13:01	14:25	1:24	MAIN SUPPLY FAILURE
435	11-May-19	BENGALURU	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	13:01	14:25	1:24	MAIN SUPPLY FAILURE
436	11-May-19	BENGALURU	66	HV1	KIADB DB PURA 220	13:01	14:25	1:24	MAIN SUPPLY FAILURE
437	11-May-19	BENGALURU	66	HV2	KIADB DB PURA 220	13:01	14:25	1:24	MAIN SUPPLY FAILURE
438	11-May-19	BENGALURU	220	HV1	KIADB DB PURA 220	13:01	14:25	1:24	LINE CLEAR AVAILED
439	11-May-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	14:31	14:45	0:13	LINE FAULT
440	11-May-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:07	16:08	2:00	LINE CLEAR AVAILED
441	11-May-19	BENGALURU	66	HV2	HONNIGANAHALLI	17:48	17:58	0:09	TRANSFORMER FAULT
442	11-May-19	GULBARGA	220	LINGASUGUR-RTPS3	LINGASUGUR_220	13:21	13:45	0:24	LINE FAULT
443	11-May-19	GULBARGA	110	KAPNOOR-GULBARGAWEST_110	GULBARAG_WEST_110	13:01	13:07	0:06	LINE CLEAR AVAILED
444	11-May-19	GULBARGA	110	PDHALLI-ALIPURA	PDHALLI_110	2:37	2:53	0:16	LINE FAULT
445	11-May-19	GULBARGA	110	PDHALLI-JANAKI_IPP	PDHALLI_110	2:37	3:00	0:23	LINE FAULT
446	11-May-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110, SAIDAPUR_GLB_110, WADAGERA_110,SANNATI_IPP, COREGREEN_IPP, NALWAR_110	3:31	7:23	3:52	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
447	11-May-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	12:57	13:40	0:43	NFBC ISSUED
448	11-May-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	20:05	21:35	1:30	LINE FAULT
449	11-May-19	GULBARGA	110	HV1	KEMBHAVI_110	11:00	11:05	0:05	TRANSFORMER FAULT
450	11-May-19	GULBARGA	66	HV2	KOTTUR_66	18:25	19:25	1:00	LINE CLEAR AVAILED
451	11-May-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:00	0:14	0:14	LINE FAULT
452	11-May-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:00	0:15	0:15	LINE FAULT
453	11-May-19	MYSORE	66	HV2	BETTADHAPURA_66	12:24	13:15	0:50	LINE CLEAR AVAILED
454	11-May-19	MYSORE	66	HV1	BETTADHAPURA_66	11:25	12:20	0:55	LINE CLEAR AVAILED
455	11-May-19	MYSORE	66	HV1	BEGUR_66	10:23	10:36	0:13	LINE CLEAR AVAILED
456	11-May-19	MYSORE	66	HV1	HANNUR_66	12:42	13:37	0:55	LINE CLEAR AVAILED
457	11-May-19	MYSORE	66	HV2	HONNALLY_MYS_66	12:42	13:11	0:29	HAND TRIPPED
458	11-May-19	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66	19:08	20:12	1:03	LINE FAULT
459	11-May-19	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	9:44	9:55	0:11	HAND TRIPPED
460	11-May-19	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	10:31	11:45	1:13	NFBC ISSUED
461	11-May-19	MYSORE	66	HV2	KRPET_66	15:47	16:05	0:17	HAND TRIPPED
462	11-May-19	MYSORE	66	HV3	KRPET_66	13:42	14:44	1:02	LINE CLEAR AVAILED
463	11-May-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	15:41	15:55	0:13	LINE FAULT
464	11-May-19	MYSORE	66	MEGHALAPURA-SFC	CHIDRAVALI_66 THUMLA_66	19:10	19:20	0:10	LINE FAULT
465	11-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	14:24	14:33	0:09	TRANSFORMER FAULT
466	11-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	19:00	19:16	0:15	TRANSFORMER FAULT
467	11-May-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	5:39	5:47	0:07	LINE FAULT
468	11-May-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	15:18	15:24	0:05	LINE FAULT
469	12-May-19	BAGALKOT	220	AMBEWADI -NARENDRA 2	AMBEWADI_220	10:05	11:38	1:33	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
470	12-May-19	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 2	BAGEWADI_220	10:33	21:25	10:52	LINE CLEAR AVAILED
471	12-May-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	5:24	13:33	8:09	LINE FAULT
472	12-May-19	BAGALKOT	110	110/33KV,HV2	BELGAUM_110	0:00	13:29	13:29	LINE CLEAR AVAILED
473	12-May-19	BAGALKOT	110	110/11KV,HV2	GOKAK_110	22:27	22:39	0:12	TRANSFORMER FAULT
474	12-May-19	BAGALKOT	110	NARAGUND(BIDNAL-NAVALGUND)-GOPANAKOPPA	GOPANAKOPPA_110	5:36	11:35	5:59	LINE FAULT
475	12-May-19	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	13:44	15:52	2:08	LINE FAULT
476	12-May-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	13:37	14:39	1:02	LINE FAULT
477	12-May-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	13:45	17:23	3:38	LINE FAULT
478	12-May-19	BAGALKOT	220	220/110KV, HV1	SIRSI_220	13:44	14:03	0:19	TRANSFORMER FAULT
479	12-May-19	BAGALKOT	110	110/11KV,HV1	SHIROL_110	12:03	12:25	0:22	LINE CLEAR AVAILED
480	12-May-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	13:30	15:00	1:30	LINE CLEAR AVAILED
481	12-May-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	5:53	5:55	0:02	TRANSFORMER FAULT
482	12-May-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	18:51	18:55	0:04	TRANSFORMER FAULT
483	12-May-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	19:12	19:21	0:09	TRANSFORMER FAULT
484	12-May-19	BAGALKOT	110	220/110KV ,LV2	MK HUBLI_220	18:17	22:27	4:10	LINE CLEAR AVAILED
485	12-May-19	BAGALKOT	110	110/33KV,HV3	MACHE_110,AKP-ALUKAS_33KV,ASHOK IRON PLANT_33KV	11:26	15:29	4:03	LINE CLEAR AVAILED
486	12-May-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	11:05	11:09	0:03	LOAD CHANGEVOER
487	12-May-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	9:54	9:58	0:04	LOAD CHANGEVOER
488	12-May-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	10:33	10:40	0:06	LINE CLEAR AVAILED
489	12-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	10:51	11:31	0:39	LINE CLEAR AVAILED
490	12-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	13:34	16:06	2:32	LINE CLEAR AVAILED
491	12-May-19	BENGALURU	66	HV1	YERANDANAHALLI 220	9:32	9:35	0:03	LOAD CHANGEVOER
492	12-May-19	BENGALURU	66	HV1	YERANDANAHALLI 220	18:40	18:43	0:03	LOAD CHANGEVOER
493	12-May-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	23:54	23:59	0:05	LINE FAULT
494	12-May-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	8:15	8:52	0:37	MAIN SUPPLY FAILURE
495	12-May-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	15:05	15:22	0:17	LOAD CHANGEVOER
496	12-May-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	8:15	8:50	0:35	MAIN SUPPLY FAILURE
497	12-May-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:05	15:25	0:20	LOAD CHANGEVOER
498	12-May-19	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	7:20	8:00	0:40	LOAD CHANGEVOER
499	12-May-19	BENGALURU	66	HV2	BAGEPALLI	15:45	16:30	0:45	TRANSFORMER FAULT
500	12-May-19	BENGALURU	66	HV2	BAGEPALLI	18:58	19:00	0:02	LOAD CHANGEVOER
501	12-May-19	BENGALURU	66	HV2	DODDABELAVANGALA	14:36	15:52	1:16	TRANSFORMER FAULT
502	12-May-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:36	14:51	0:15	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
503	12-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:46	14:55	0:09	LINE FAULT
504	12-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:46	14:55	0:09	LINE FAULT
505	12-May-19	BENGALURU	66	HV3	DEVANAHALLI	14:20	14:25	0:05	TRANSFORMER FAULT
506	12-May-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	8:15	9:21	1:06	LINE FAULT
507	12-May-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	9:24	15:00	5:36	LINE CLEAR AVAILED
508	12-May-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	8:15	9:45	1:30	MAIN SUPPLY FAILURE
509	12-May-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:15	8:44	0:29	MAIN SUPPLY FAILURE
510	12-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	8:15	9:35	1:20	MAIN SUPPLY FAILURE
511	12-May-19	BENGALURU	66	HV1	SARJAPURA 220	8:15	9:27	1:12	MAIN SUPPLY FAILURE
512	12-May-19	BENGALURU	66	HV2	SARJAPURA 220	8:15	9:27	1:12	MAIN SUPPLY FAILURE
513	12-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:08	15:24	0:16	LOAD CHANGEVOER
514	12-May-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	15:08	15:24	0:16	LOAD CHANGEVOER
515	12-May-19	BENGALURU	66	HV1	SARJAPURA 220	15:08	15:24	0:16	LOAD CHANGEVOER
516	12-May-19	BENGALURU	66	HV2	SARJAPURA 220	15:08	15:24	0:16	LOAD CHANGEVOER
517	12-May-19	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	15:16	15:20	0:04	LOAD CHANGEVOER
518	12-May-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	15:29	15:35	0:05	LOAD CHANGEVOER
519	12-May-19	GULBARGA	220	HV1	KAPNOOR_220	0:00	17:35	17:35	TRANSFORMER FAULT
520	12-May-19	GULBARGA	110	HUMNABAD220-HUMNABAD1	HUMNABAD_110	15:45	15:50	0:05	LINE CLEAR AVAILED
521	12-May-19	GULBARGA	110	HV1	RAICHUR_220	9:25	9:28	0:03	TRANSFORMER FAULT
522	12-May-19	GULBARGA	110	HV1	RAICHUR_220	21:09	21:41	0:32	LINE CLEAR AVAILED
523	12-May-19	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR-110,RAJESHSHREE CEMENTS	0:05	0:20	0:15	LINE FAULT
524	12-May-19	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR-110,RAJESHSHREE CEMENTS	0:25	0:32	0:07	LINE FAULT
525	12-May-19	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	12:18	15:15	2:57	NFBC ISSUED
526	12-May-19	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	18:40	19:30	0:50	LINE FAULT
527	12-May-19	GULBARGA	110	HV2	TEKALKOTE_110	13:10	13:15	0:05	TRANSFORMER FAULT
528	12-May-19	GULBARGA	110	HV2	VENKATGIRI_110	22:40	22:50	0:10	TRANSFORMER FAULT
529	12-May-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110, KURUGOD_110, SHATAVANA_IPP, AGARWAL_IPP, SUZLON_IPP, KAMALAPUR_110	4:43	4:58	0:15	LINE FAULT
530	12-May-19	GULBARGA	110	HV3	HATTI_110	13:25	17:58	4:33	LINE CLEAR AVAILED
531	12-May-19	GULBARGA	110	MASKI-RNWSLR	MASKI_110	13:04	13:09	0:05	LINE FAULT
532	12-May-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	17:35	17:56	0:21	LINE FAULT
533	12-May-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	21:55	23:50	1:55	LINE FAULT
534	12-May-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	23:50	23:59	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
535	12-May-19	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	21:57	23:59	2:02	LINE FAULT
536	12-May-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	13:44	14:42	0:58	LINE CLEAR AVAILED
537	12-May-19	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	13:44	14:42	0:58	LINE CLEAR AVAILED
538	12-May-19	HASSAN	220	GOPALAP-HNPUR21	GOPALPURA_220	18:26	20:05	1:39	LINE FAULT
539	12-May-19	HASSAN	110	HV1	MANIPAL_110	19:39	20:09	0:30	LINE CLEAR AVAILED
540	12-May-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	21:42	22:29	0:47	LINE FAULT
541	12-May-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	19:12	19:29	0:17	LINE FAULT
542	12-May-19	HASSAN	66	BAGUR	K_BYRAPURA_66	8:20	8:35	0:15	MAIN SUPPLY FAILURE
543	12-May-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	21:43	21:58	0:15	LINE FAULT
544	12-May-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	18:25	20:35	2:10	MAIN SUPPLY FAILURE
545	12-May-19	HASSAN	66	HV1	HARIHARAPURA_66	18:05	20:34	2:29	LINE CLEAR AVAILED
546	12-May-19	HASSAN	66	HV1	HARIHARAPURA_66	20:35	21:03	0:28	HAND TRIPPED
547	12-May-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	18:28	23:59	5:31	LINE FAULT
548	12-May-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	18:26	19:09	0:43	LINE FAULT
549	12-May-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	18:26	19:09	0:43	LINE FAULT
550	12-May-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	16:45	16:55	0:10	LINE FAULT
551	12-May-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:35	19:29	0:54	LINE FAULT
552	12-May-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	19:49	19:55	0:06	LINE FAULT
553	12-May-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	19:39	23:59	4:20	MAIN SUPPLY FAILURE
554	12-May-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	16:46	16:55	0:09	LINE FAULT
555	12-May-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	18:35	19:35	1:00	LINE FAULT
556	12-May-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	19:35	23:59	4:24	LINE FAULT
557	12-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:15	18:29	11:14	LINE CLEAR AVAILED
558	12-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:15	18:29	11:14	LINE CLEAR AVAILED
559	12-May-19	MYSORE	66	ELAVALA-HUNSUR	GAVADAGERE_66	5:45	23:59	18:13	LINE FAULT
560	12-May-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	0:01	0:09	0:08	LINE FAULT
561	12-May-19	MYSORE	66	HV1	KOLLEGALA_66	12:35	14:00	1:25	LINE CLEAR AVAILED
562	12-May-19	MYSORE	66	HV2	KOLLEGALA_66	11:00	13:55	2:55	LINE CLEAR AVAILED
563	12-May-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	MAMBALLI_66 YELANDUR_66	16:00	16:06	0:06	LINE FAULT
564	12-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	3:29	4:14	0:44	TRANSFORMER FAULT
565	12-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	20:10	20:21	0:11	TRANSFORMER FAULT
566	12-May-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:29	7:57	0:27	LINE CLEAR AVAILED
567	12-May-19	MYSORE	66	HV5	SFCSHIVA_66	18:24	23:59	5:34	LINE CLEAR AVAILED
568	12-May-19	MYSORE	66	RK NAGARA-DATAGALLI	RKNAGARA_66	14:36	14:41	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
569	12-May-19	TUMKUR	66	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	20:58	21:10	0:12	HAND TRIPPED
570	12-May-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	6:53	7:07	0:13	LINE FAULT
571	12-May-19	TUMKUR	220	GUTUR_220-DAVANGERE SRS1	DAVANGERE_SRS_220	21:29	22:01	0:32	LINE FAULT
572	12-May-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	20:35	20:46	0:11	TRANSFORMER FAULT
573	12-May-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	21:00	23:06	2:06	LINE CLEAR AVAILED
574	12-May-19	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	15:19	15:21	0:01	LINE FAULT
575	13-May-19	BAGALKOT	220	PONDA1(XELDOM)-AMBEWADI	AMBEWADI_220	12:01	12:42	0:41	LINE FAULT
576	13-May-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	11:37	15:09	3:32	LINE CLEAR AVAILED
577	13-May-19	BAGALKOT	110	110/11KV, HV2	BELGAUM_110	10:42	10:49	0:07	LINE CLEAR AVAILED
578	13-May-19	BAGALKOT	220	FORTUNEFIVE1-BAGEWADI	BAGEWADI_220	10:37	18:18	7:41	LINE CLEAR AVAILED
579	13-May-19	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	4:41	4:53	0:12	LINE FAULT
580	13-May-19	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	5:01	5:35	0:34	LINE FAULT
581	13-May-19	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	12:08	16:08	4:00	LINE CLEAR AVAILED
582	13-May-19	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	0:46	23:59	23:13	LINE CLEAR AVAILED
583	13-May-19	BAGALKOT	400	DHONI-LINGAPUR1	DHONI_400	16:49	23:59	7:10	LINE CLEAR AVAILED
584	13-May-19	BAGALKOT	110	110/11KV, HV2	GOKAK_110	23:14	23:29	0:15	TRANSFORMER FAULT
585	13-May-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	11:56	12:34	0:38	LINE CLEAR AVAILED
586	13-May-19	BAGALKOT	110	KUD DHARWAD-LAKMANAHALLI	LAKMANAHALLI_110	10:15	17:25	7:10	LINE CLEAR AVAILED
587	13-May-19	BAGALKOT	110	110/11KV, HV2	LAKMANAHALLI_110	10:03	17:32	7:29	LINE CLEAR AVAILED
588	13-May-19	BAGALKOT	110	110/11KV, HV1	LAKMANAHALLI_110	10:04	17:29	7:25	LINE CLEAR AVAILED
589	13-May-19	BAGALKOT	110	110/11KV, HV1	MKHUBLI_220	16:10	16:49	0:39	LINE CLEAR AVAILED
590	13-May-19	BAGALKOT	110	TARIHAL -TADASINAKOPPA +NAVANAGAR(IDLE)	NAVANAGR_110 (TARIHAL NOT INTERRUPTED)	10:01	10:14	0:13	HAND TRIPPED
591	13-May-19	BAGALKOT	110	TARIHAL -TADASINAKOPPA +NAVANAGAR (IDLE)	NAVANAGR_110 (TARIHAL NOT INTERRUPTED)	18:18	18:25	0:07	HAND TRIPPED
592	13-May-19	BAGALKOT	220	220/110 ,HV1	HUBLI_220	15:05	16:06	1:01	TRANSFORMER FAULT
593	13-May-19	BAGALKOT	110	220/110 ,LV1	HUBLI_220	15:05	16:14	1:09	TRANSFORMER FAULT
594	13-May-19	BAGALKOT	110	HUBLI 220-RAMANKOPPA	RAMANKOPPA_110	11:10	13:46	2:36	LINE CLEAR AVAILED
595	13-May-19	BAGALKOT	110	110/11KV, HV1	SIRSI_220	9:54	17:25	7:31	LINE CLEAR AVAILED
596	13-May-19	BAGALKOT	110	SIRSI -KUMATA 2	SIRSI_110(KUMATA_110)	0:00	16:25	16:25	LINE CLEAR AVAILED
597	13-May-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	18:10	18:17	0:07	TRANSFORMER FAULT
598	13-May-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	0:00	0:34	0:34	LINE FAULT
599	13-May-19	BENGALURU	220	HV2	HSR LAYOUT 220	15:02	16:00	0:58	TRANSFORMER FAULT
600	13-May-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	15:02	16:00	0:58	MAIN SUPPLY FAILURE
601	13-May-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	17:02	17:06	0:03	LOAD CHANGEVOER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
602	13-May-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	10:11	10:15	0:04	LOAD CHANGEVOER
603	13-May-19	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	15:27	16:36	1:09	MAIN SUPPLY FAILURE
604	13-May-19	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	17:23	17:33	0:09	LOAD CHANGEVOER
605	13-May-19	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NAGNATHPURA 220	15:26	15:42	0:15	LINE FAULT
606	13-May-19	BENGALURU	220	HAL 220 - HOODY 1	HAL 220, EDC 220	15:27	16:21	0:54	MAIN SUPPLY FAILURE
607	13-May-19	BENGALURU	220	HAL 220 - HOODY 2	HAL 220, EDC 220	15:27	16:21	0:54	MAIN SUPPLY FAILURE
608	13-May-19	BENGALURU	220	EPIP 220 - ITPL(EHT) 220	EPIP 220	15:27	16:23	0:56	MAIN SUPPLY FAILURE
609	13-May-19	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	15:27	16:38	1:11	MAIN SUPPLY FAILURE
610	13-May-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	15:27	16:58	1:31	MAIN SUPPLY FAILURE
611	13-May-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	15:27	16:45	1:18	MAIN SUPPLY FAILURE
612	13-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	15:26	16:48	1:21	MAIN SUPPLY FAILURE
613	13-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	15:26	16:48	1:21	MAIN SUPPLY FAILURE
614	13-May-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	15:26	16:47	1:20	MAIN SUPPLY FAILURE
615	13-May-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:46	10:49	0:03	LOAD CHANGEVOER
616	13-May-19	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:46	10:50	0:03	LOAD CHANGEVOER
617	13-May-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	17:01	17:09	0:08	LINE FAULT
618	13-May-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	17:09	19:50	2:40	LINE FAULT
619	13-May-19	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	15:27	16:57	1:30	MAIN SUPPLY FAILURE
620	13-May-19	BENGALURU	66	HOODY 220 - ITI	ITI	15:27	16:45	1:18	MAIN SUPPLY FAILURE
621	13-May-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:27	16:59	1:32	MAIN SUPPLY FAILURE
622	13-May-19	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	15:27	16:49	1:22	MAIN SUPPLY FAILURE
623	13-May-19	BENGALURU	220	HEBBAL 220 - HOODY 200	HEBBAL 220	15:27	16:30	1:03	MAIN SUPPLY FAILURE
624	13-May-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	15:27	16:40	1:13	MAIN SUPPLY FAILURE
625	13-May-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	15:27	16:40	1:13	MAIN SUPPLY FAILURE
626	13-May-19	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	15:27	16:40	1:13	MAIN SUPPLY FAILURE
627	13-May-19	BENGALURU	66	HEBBAL 220 - C STATION 2	C STATION	15:27	16:40	1:13	MAIN SUPPLY FAILURE
628	13-May-19	BENGALURU	66	HAL 220 - B STATION	B STATION	15:27	16:39	1:12	MAIN SUPPLY FAILURE
629	13-May-19	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	15:27	17:01	1:34	MAIN SUPPLY FAILURE
630	13-May-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	15:27	16:41	1:14	MAIN SUPPLY FAILURE
631	13-May-19	BENGALURU	66	EDC 220 - BMTC	BMTC	15:27	18:55	3:28	MAIN SUPPLY FAILURE
632	13-May-19	BENGALURU	66	EDC 220 - B STATION	B STATION	15:27	16:39	1:12	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
633	13-May-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	10:17	10:19	0:01	LOAD CHANGEVOER
634	13-May-19	BENGALURU	400	HV1	HOODY 400	15:27	16:14	0:47	TRANSFORMER FAULT
635	13-May-19	BENGALURU	400	HV3	HOODY 400	15:27	18:52	3:25	TRANSFORMER FAULT
636	13-May-19	BENGALURU	220	HV1	HAL 220	15:27	16:24	0:57	MAIN SUPPLY FAILURE
637	13-May-19	BENGALURU	220	HV2	HAL 220	15:27	16:24	0:57	MAIN SUPPLY FAILURE
638	13-May-19	BENGALURU	220	HV1	EPIP 220	15:27	16:30	1:03	MAIN SUPPLY FAILURE
639	13-May-19	BENGALURU	220	HV1	EDC 220	15:27	16:39	1:12	MAIN SUPPLY FAILURE
640	13-May-19	BENGALURU	220	HV2	EDC 220	15:27	16:39	1:12	MAIN SUPPLY FAILURE
641	13-May-19	BENGALURU	66	HV2	TELECOM LAYOUT	13:43	14:27	0:43	LINE CLEAR AVAIED
642	13-May-19	BENGALURU	66	HV1	SOLDEVANAHALLI	10:17	10:21	0:03	LINE CLEAR AVAIED
643	13-May-19	BENGALURU	66	HV2	SOLDEVANAHALLI	11:46	11:55	0:09	LINE CLEAR AVAIED
644	13-May-19	BENGALURU	220	HV1	NAGNATHPURA 220	15:37	16:28	0:51	MAIN SUPPLY FAILURE
645	13-May-19	BENGALURU	220	HV2	NAGNATHPURA 220	15:37	16:43	1:06	MAIN SUPPLY FAILURE
646	13-May-19	BENGALURU	66	HV1	NAGNATHPURA 220	15:26	16:46	1:19	MAIN SUPPLY FAILURE
647	13-May-19	BENGALURU	66	HV2	NAGNATHPURA 220	15:26	16:31	1:04	MAIN SUPPLY FAILURE
648	13-May-19	BENGALURU	66	HV1	KHODAYS 220	10:46	10:50	0:03	LOAD CHANGEVOER
649	13-May-19	BENGALURU	66	HV2	KHODAYS 220	10:46	10:50	0:03	LOAD CHANGEVOER
650	13-May-19	BENGALURU	220	HV2	HOODY 220	15:27	16:23	0:56	MAIN SUPPLY FAILURE
651	13-May-19	BENGALURU	220	HV1	HEBBAL 220	15:27	16:30	1:03	MAIN SUPPLY FAILURE
652	13-May-19	BENGALURU	220	HV2	HEBBAL 220	15:27	16:30	1:03	MAIN SUPPLY FAILURE
653	13-May-19	BENGALURU	66	HV3	EPIP 220	15:27	17:00	1:33	MAIN SUPPLY FAILURE
654	13-May-19	BENGALURU	66	HV1	EDC 220	15:27	16:43	1:16	MAIN SUPPLY FAILURE
655	13-May-19	BENGALURU	66	HV2	EDC 220	15:27	16:40	1:13	MAIN SUPPLY FAILURE
656	13-May-19	BENGALURU	66	HV1	BOODIGERE	22:34	22:43	0:08	TRANSFORMER FAULT
657	13-May-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	5:29	5:43	0:14	LINE FAULT
658	13-May-19	BENGALURU	66	HV2	ATTIBELE	16:40	18:35	1:55	TRANSFORMER FAULT
659	13-May-19	BENGALURU	66	HV2	ATTIBELE	19:36	20:20	0:43	LINE CLEAR AVAIED
660	13-May-19	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	21:04	21:11	0:07	LINE FAULT
661	13-May-19	BENGALURU	66	HV1	CHAKAVELU	21:04	21:13	0:09	MAIN SUPPLY FAILURE
662	13-May-19	BENGALURU	66	HV2	CHAKAVELU	21:04	21:12	0:07	MAIN SUPPLY FAILURE
663	13-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	2:06	2:17	0:11	LINE FAULT
664	13-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	2:56	3:01	0:04	LINE FAULT
665	13-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	3:43	3:46	0:02	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
666	13-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:23	5:30	0:07	LINE FAULT
667	13-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:49	5:50	0:01	LINE FAULT
668	13-May-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:27	19:36	0:08	LINE FAULT
669	13-May-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	20:25	20:45	0:20	LINE FAULT
670	13-May-19	BENGALURU	66	HV2	GUNDAMGERE	12:10	12:44	0:34	LINE CLEAR AVAILED
671	13-May-19	BENGALURU	66	HV2	HONNIGANAHALLI	14:39	14:47	0:07	TRANSFORMER FAULT
672	13-May-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	20:31	20:41	0:09	LINE FAULT
673	13-May-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:40	14:13	0:33	LINE CLEAR AVAILED
674	13-May-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:22	23:11	1:49	LINE CLEAR AVAILED
675	13-May-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	6:55	7:06	0:11	LINE FAULT
676	13-May-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:38	17:58	0:20	LINE FAULT
677	13-May-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:58	21:17	3:19	LINE FAULT
678	13-May-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:17	23:12	1:55	LINE FAULT
679	13-May-19	BENGALURU	66	HV1	NARASAPURA	11:52	12:06	0:13	TRANSFORMER FAULT
680	13-May-19	BENGALURU	220	YELAHANKA 220 - KPCL 1	KPCL	14:56	15:35	0:39	LINE FAULT
681	13-May-19	BENGALURU	66	DALASNUR - SRINIVASPURA	DALASNUR	11:42	11:51	0:09	LINE CLEAR AVAILED
682	13-May-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:11	6:23	0:12	LINE FAULT
683	13-May-19	BENGALURU	66	HV2	VOLVO	7:09	7:11	0:01	TRANSFORMER FAULT
684	13-May-19	BENGALURU	66	HV2	T BEGUR	10:55	11:39	0:43	LINE CLEAR AVAILED
685	13-May-19	BENGALURU	66	HV1	MELEHALLI	17:40	18:15	0:35	TRANSFORMER FAULT
686	13-May-19	GULBARGA	220	RTPS-SHAHPUR2	SHAHPUR_220	19:52	21:43	1:51	LINE FAULT
687	13-May-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	19:36	19:49	0:13	LINE FAULT
688	13-May-19	GULBARGA	110	SEDAM-VASAVDATTA_IPP	SEDAM_220	23:15	23:35	0:20	LINE FAULT
689	13-May-19	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	12:40	14:50	2:10	LINE CLEAR AVAILED
690	13-May-19	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	14:50	20:00	5:10	LINE CLEAR AVAILED
691	13-May-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	17:10	19:50	2:40	LINE CLEAR AVAILED
692	13-May-19	GULBARGA	110	HV1	RAICHUR_110	8:20	10:33	2:13	LINE CLEAR AVAILED
693	13-May-19	GULBARGA	110	HV1	MANDEWAL_110	10:22	18:20	7:58	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
694	13-May-19	GULBARGA	66	HV2	CHORNOOR_66	17:21	18:10	0:49	LINE CLEAR AVAILED
695	13-May-19	GULBARGA	66	HV1	HAMPASAGAR_66	8:35	8:39	0:04	TRANSFORMER FAULT
696	13-May-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	0:00	9:11	9:11	LINE FAULT
697	13-May-19	HASSAN	220	MRSSHM-KADUR	MRSMG_220	0:00	9:12	9:12	LINE FAULT
698	13-May-19	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	10:53	11:48	0:55	LINE FAULT
699	13-May-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:54	11:47	0:53	LINE FAULT
700	13-May-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	9:31	9:33	0:02	HAND TRIPPED
701	13-May-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	5:38	6:05	0:27	LINE FAULT
702	13-May-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:50	10:55	0:05	LINE FAULT
703	13-May-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	9:31	9:32	0:01	HAND TRIPPED
704	13-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:10	9:15	0:05	LINE FAULT
705	13-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:27	10:38	0:11	LINE FAULT
706	13-May-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	0:00	11:40	11:40	LINE FAULT
707	13-May-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	0:00	1:47	1:47	MAIN SUPPLY FAILURE
708	13-May-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	0:00	1:52	1:52	LINE FAULT
709	13-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:22	19:07	11:45	LINE CLEAR AVAILED
710	13-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:22	19:07	11:45	LINE CLEAR AVAILED
711	13-May-19	HASSAN	66	HV1	TAVARECHANAHALLI_66	14:00	17:10	3:10	LINE CLEAR AVAILED
712	13-May-19	MYSORE	66	HV2	ADDIHALLI_66	17:54	18:30	0:35	HAND TRIPPED
713	13-May-19	MYSORE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	10:12	23:59	13:46	LINE CLEAR AVAILED
714	13-May-19	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	20:07	20:14	0:07	LINE FAULT
715	13-May-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	16:45	16:50	0:04	LINE FAULT
716	13-May-19	MYSORE	66	HOOTAGALLI-FTS 1	FTS_66	20:28	21:14	0:46	LINE FAULT
717	13-May-19	MYSORE	66	HOOTAGALLI-FTS 2	FTS_66	20:28	21:14	0:46	LINE FAULT
718	13-May-19	MYSORE	66	SOMANAHALLI-K HONNALAGERE	K_HONNALGERE_66	18:30	23:59	5:29	LINE FAULT
719	13-May-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66 TUMBKERE_66	19:12	19:51	0:38	LINE FAULT
720	13-May-19	MYSORE	66	HV1	RAMAPURA_MYS_66	16:33	16:40	0:07	TRANSFORMER FAULT
721	13-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	14:50	14:59	0:09	TRANSFORMER FAULT
722	13-May-19	MYSORE	66	HV5	SFCSHIVA_66	10:24	23:59	13:34	LINE CLEAR AVAILED
723	13-May-19	MYSORE	220	HV2	VAJAMANGALA_220	9:40	23:59	14:18	LINE CLEAR AVAILED
724	13-May-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	9:23	9:34	0:10	HAND TRIPPED
725	13-May-19	MYSORE	66	VIJAYANAGARA-BANNIMANTAPA	BANNIMANTAP_66	10:10	16:18	6:07	NFBC ISSUED
726	13-May-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	9:38	14:06	4:28	LINE CLEAR AVAILED
727	13-May-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	9:37	14:00	4:22	LINE CLEAR AVAILED
728	13-May-19	TUMKUR	220	TR-2	MADHUGIRI_220	17:53	19:08	1:14	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
729	13-May-19	TUMKUR	110	TR-1	TURUVEKERE_110	15:03	15:08	0:05	TRANSFORMER FAULT
730	13-May-19	TUMKUR	110	TR-1	KBCROSS_220	16:03	17:36	1:32	LINE CLEAR AVAILED
731	13-May-19	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	9:53	13:11	3:17	LINE CLEAR AVAILED
732	13-May-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	7:44	8:07	0:23	LINE FAULT
733	13-May-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:10	12:36	1:26	LINE CLEAR AVAILED
734	13-May-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAG UNDA_66	10:30	12:18	1:47	LINE CLEAR AVAILED
735	13-May-19	TUMKUR	66	TR-2	HULIYURDURGA_66	18:07	18:18	0:10	TRANSFORMER FAULT
736	13-May-19	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	17:53	19:08	1:14	LINE CLEAR AVAILED
737	13-May-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	17:53	19:08	1:14	LINE CLEAR AVAILED
738	13-May-19	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	17:53	19:08	1:14	LINE CLEAR AVAILED
739	13-May-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI2	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	17:53	19:08	1:14	LINE CLEAR AVAILED
740	13-May-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	19:08	19:12	0:03	HAND TRIPPED
741	13-May-19	TUMKUR	66	MADHUGIRI 220kV- RANGANATHAPURA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	19:08	19:10	0:02	HAND TRIPPED
742	13-May-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	11:20	12:29	1:09	TRANSFORMER FAULT
743	13-May-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:37	11:42	2:04	LINE FAULT
744	13-May-19	TUMKUR	66	TR-1	TUMKUR_66	11:10	11:18	0:07	HAND TRIPPED