

# 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 11.06.2019 TO 17.06.2019

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	11-Jun-19	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	5:37	5:40	0:03	LINE FAULT
2	11-Jun-19	BAGALKOT	110	AINAPUR-ATHANI SUGARS	ATHANI_110	5:37	5:49	0:12	LINE FAULT
3	11-Jun-19	BAGALKOT	110	AINAPUR-ATHANI SUGARS	ATHANI_110	12:05	13:26	1:21	LINE CLEAR AVAILED
4	11-Jun-19	BAGALKOT	110	110/11KV,HV2	BHUTANAL_110	16:54	16:58	0:04	TRANSFORMER FAULT
5	11-Jun-19	BAGALKOT	110	RAIBAG-ITANAL	ITANAL_110	19:06	19:18	0:12	LINE FAULT
6	11-Jun-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	4:25	4:40	0:15	MAIN SUPPLY FAILURE
7	11-Jun-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110,RUSTUMPUR_33,WATER SUPPLY_33	16:39	16:47	0:08	TRANSFORMER FAULT
8	11-Jun-19	BAGALKOT	220	GHATAPRABHA-NARENDRA 1	GHATAPRABHA_220	11:30	15:46	4:16	LINE CLEAR AVAILED
9	11-Jun-19	BAGALKOT	220	GHATAPRABHA-NARENDRA 2	GHATAPRABHA_220	11:33	15:38	4:05	LINE CLEAR AVAILED
10	11-Jun-19	BAGALKOT	110	KARWAR 220-KUMTA	KUMTA_110	13:01	13:56	0:55	LINE FAULT
11	11-Jun-19	BAGALKOT	110	KARWAR 220-KUMTA	KUMTA_110	14:01	14:59	0:58	LINE FAULT
12	11-Jun-19	BAGALKOT	110	KARWAR 220-KUMTA	KUMTA_110	15:13	17:50	2:37	LINE FAULT
13	11-Jun-19	BAGALKOT	110	KARWAR 220-KUMTA	KUMTA_110	18:57	23:59	5:02	LINE FAULT
14	11-Jun-19	BAGALKOT	220	220/110KV,HV1&2,LV1&2	KUDUCHI_220,AINAPUR_110,MORAB_110,YELLAPARATTI_110,TERDAL_110,KUDUCHI_110,UGARKHUD_110	4:26	4:33	0:07	TRANSFORMER FAULT
15	11-Jun-19	BAGALKOT	110	KUDACHI 220-AINAPUR	AINAPUR_110	4:25	5:35	1:10	LINE FAULT
16	11-Jun-19	BAGALKOT	110	KUDACHI 220-AINAPUR	AINAPUR_110	12:25	13:23	0:58	LINE CLEAR AVAILED
17	11-Jun-19	BAGALKOT	110	MY FAIR-HIREHAL	HIREHAL_110	8:34	9:00	0:26	LINE CLEAR AVAILED
18	11-Jun-19	BAGALKOT	400	GUTTUR-DHONI	DHONI_400	17:23	18:03	0:40	LINE FAULT
19	11-Jun-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADAWAD_33, VANTAGOD_33	11:24	17:09	5:45	TRANSFORMER FAULT
20	11-Jun-19	BAGALKOT	110	110/33KV, HV2	TILUVALI_110,KALKERI_33,KNL_33	13:30	13:39	0:09	LINE CLEAR AVAILED
21	11-Jun-19	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	20:15	23:59	3:44	LINE FAULT
22	11-Jun-19	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	10:41	19:26	8:45	LINE CLEAR AVAILED
23	11-Jun-19	BAGALKOT	110	110/33KV,HV1	SOUDATTI_110	16:48	17:25	0:37	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
24	11-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1	SOUDATTI_220	12:43	16:39	3:56	LINE CLEAR AVAILED
25	11-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	SOUDATTI_220	17:00	17:07	0:07	TRANSFORMER FAULT
26	11-Jun-19	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	15:49	16:41	0:52	LINE CLEAR AVAILED
27	11-Jun-19	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	9:08	17:14	8:06	LINE CLEAR AVAILED
28	11-Jun-19	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	9:20	17:02	7:42	LINE CLEAR AVAILED
29	11-Jun-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	10:22	15:25	5:03	LINE CLEAR AVAILED
30	11-Jun-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	16:30	16:48	0:18	LINE FAULT
31	11-Jun-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	13:44	13:49	0:05	HAND TRIPPED
32	11-Jun-19	BAGALKOT	110	110/11KV,HV2	SAVANUR_110	22:33	22:50	0:17	TRANSFORMER FAULT
33	11-Jun-19	BAGALKOT	110	110/11KV,HV2	NAVANAGAR(B)_110	14:21	14:29	0:08	TRANSFORMER FAULT
34	11-Jun-19	BAGALKOT	110	110/11KV,HV1	MURDESHWAR_110	19:49	19:51	0:02	HAND TRIPPED
35	11-Jun-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	8:38	16:31	7:53	LINE CLEAR AVAILED
36	11-Jun-19	BAGALKOT	110	TODALBAGI-MAMADAPUR	MAMADAPUR(B)_110	0:00	14:02	14:02	LINE CLEAR AVAILED
37	11-Jun-19	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	19:15	19:24	0:09	LOAD CHANGE OVER
38	11-Jun-19	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	19:15	19:25	0:09	LOAD CHANGE OVER
39	11-Jun-19	BENGALURU	66	HV1	BOODIGERE	9:47	9:57	0:10	TRANSFORMER FAULT
40	11-Jun-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	17:17	18:01	0:43	LINE FAULT
41	11-Jun-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO(EHT), KADUBEESANAHALLI	18:28	19:02	0:34	LINE FAULT
42	11-Jun-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, GODUR	9:49	10:12	0:22	LINE FAULT
43	11-Jun-19	BENGALURU	220	HV2	KHODAYS 220	1:29	2:05	0:35	TRANSFORMER FAULT
44	11-Jun-19	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	1:29	2:18	0:48	MAIN SUPPLY FAILURE
45	11-Jun-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	1:29	2:07	0:38	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
46	11-Jun-19	BENGALURU	66	HV1	KUMBALGODU	5:57	6:30	0:32	TRANSFORMER FAULT
47	11-Jun-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	2:14	2:20	0:05	LOAD CHANGE OVER
48	11-Jun-19	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	12:38	12:46	0:08	LOAD CHANGE OVER
49	11-Jun-19	BENGALURU	66	YELAHANKA 220 - SOLDEVANAHALLI	SOLDEVANAHALLI	8:51	9:36	0:45	LINE FAULT
50	11-Jun-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	16:00	16:17	0:16	LINE CLEAR AVAILED
51	11-Jun-19	BENGALURU	66	HV2	JANGAMKOTE	8:30	9:33	1:03	LINE CLEAR AVAILED
52	11-Jun-19	BENGALURU	66	HV2	JANGAMKOTE	10:02	10:30	0:28	LINE CLEAR AVAILED
53	11-Jun-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	9:20	9:31	0:11	LOAD CHANGE OVER
54	11-Jun-19	BENGALURU	66	HV1	DODDABELAVANGALA	14:53	18:18	3:24	LINE CLEAR AVAILED
55	11-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST JOHNS WOOD	ST JOHNS WOOD	14:42	15:00	0:18	LINE FAULT
56	11-Jun-19	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	17:23	19:00	1:37	LINE FAULT
57	11-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	8:54	9:07	0:13	TRANSFORMER FAULT
58	11-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	14:47	15:03	0:16	TRANSFORMER FAULT
59	11-Jun-19	GULBARGA	220	SEDAM-CLNMAX	SEDAM_220	12:59	13:21	0:22	LINE FAULT
60	11-Jun-19	GULBARGA	220	SEDAM-CLNMAX	SEDAM_220	19:37	19:47	0:10	LINE FAULT
61	11-Jun-19	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	15:56	16:09	0:13	LINE FAULT
62	11-Jun-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	0:17	0:23	0:06	LINE FAULT
63	11-Jun-19	GULBARGA	110	HV1	SHAKTINAGAR_110	17:38	18:28	0:50	TRANSFORMER FAULT
64	11-Jun-19	GULBARGA	66	ITTAGI-RENWSLR2	ITTAGI_220	8:42	9:06	0:24	LINE CLEAR AVAILED
65	11-Jun-19	GULBARGA	66	ITTAGI-RENWSLR2	ITTAGI_220	9:50	9:59	0:09	LINE CLEAR AVAILED
66	11-Jun-19	HASSAN	220	HV3	KAVOOR_220	10:00	15:37	5:37	LINE CLEAR AVAILED
67	11-Jun-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	20:14	20:49	0:35	LINE FAULT
68	11-Jun-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	20:14	23:59	3:45	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
69	11-Jun-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	20:48	21:00	0:12	LINE FAULT
70	11-Jun-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	20:48	21:00	0:12	LINE FAULT
71	11-Jun-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	20:50	21:09	0:19	LINE FAULT
72	11-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	19:15	23:59	4:44	LINE FAULT
73	11-Jun-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	20:14	20:46	0:32	LINE FAULT
74	11-Jun-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	20:14	23:59	3:45	LINE FAULT
75	11-Jun-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	19:15	23:59	4:44	LINE FAULT
76	11-Jun-19	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	11:57	13:03	1:06	LINE CLEAR AVAILED
77	11-Jun-19	HASSAN	220	SHRAVTY-TALAGUPA2	sharavathy_gen	8:51	23:59	15:08	LINE CLEAR AVAILED
78	11-Jun-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	12:00	13:03	1:03	LINE CLEAR AVAILED
79	11-Jun-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	8:50	23:59	15:09	LINE CLEAR AVAILED
80	11-Jun-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	20:47	20:59	0:12	LINE FAULT
81	11-Jun-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	20:47	20:59	0:12	LINE FAULT
82	11-Jun-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	20:50	21:09	0:19	LINE FAULT
83	11-Jun-19	HASSAN	110	HV2	GANDSI_110	4:15	4:19	0:04	TRANSFORMER FAULT
84	11-Jun-19	HASSAN	110	HV2	GANDSI_110	7:51	8:00	0:09	TRANSFORMER FAULT
85	11-Jun-19	HASSAN	110	HV1	KONAJE_110	15:44	15:47	0:03	LOAD CHANGE OVER
86	11-Jun-19	HASSAN	110	HV1	KONAJE_110	9:11	9:13	0:02	LOAD CHANGE OVER
87	11-Jun-19	HASSAN	110	HV2	KONAJE_110	15:44	15:47	0:03	LOAD CHANGE OVER
88	11-Jun-19	HASSAN	110	HV2	KONAJE_110	9:11	9:13	0:02	LOAD CHANGE OVER
89	11-Jun-19	HASSAN	110	HV3	KONAJE_110	15:44	15:47	0:03	LOAD CHANGE OVER
90	11-Jun-19	HASSAN	110	HV3	KONAJE_110	9:11	9:13	0:02	LOAD CHANGE OVER
91	11-Jun-19	HASSAN	110	HV2	KUNDAPURA_110	16:47	17:55	1:08	LINE CLEAR AVAILED
92	11-Jun-19	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	8:15	21:40	13:25	NFBC ISSUED
93	11-Jun-19	HASSAN	66	HV1	DODDAKADANUR_66	15:53	16:07	0:14	TRANSFORMER FAULT
94	11-Jun-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	8:15	21:43	13:28	LINE CLEAR AVAILED
95	11-Jun-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:20	12:59	0:39	LINE FAULT
96	11-Jun-19	HASSAN	66	HV2	MAGGE_66	13:41	23:59	10:18	TRANSFORMER FAULT
97	11-Jun-19	HASSAN	66	HV2	RAMPURA_66	15:36	16:37	1:01	LINE CLEAR AVAILED
98	11-Jun-19	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	12:30	13:06	0:36	LINE CLEAR AVAILED
99	11-Jun-19	HASSAN	66	SAALE-IPCL1	SAKLESHPURA_66	7:37	19:27	11:50	LINE CLEAR AVAILED
100	11-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:37	19:27	11:50	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
101	11-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	21:22	21:50	0:28	LINE FAULT
102	11-Jun-19	MYSORE	66	HV2	BETTADHAPURA_66	11:09	13:58	2:49	LINE CLEAR AVAILED
103	11-Jun-19	MYSORE	66	HV1	BETTADHAPURA_66	11:10	23:59	12:49	LINE CLEAR AVAILED
104	11-Jun-19	MYSORE	66	HV2	BOOKANAKERE_66	14:17	14:30	0:13	TRANSFORMER FAULT
105	11-Jun-19	MYSORE	66	HV2	BOOKANAKERE_66	16:45	17:01	0:16	TRANSFORMER FAULT
106	11-Jun-19	MYSORE	66	HANAGODU-HUNSURU	HUNSUR_66	10:19	18:10	7:51	LINE CLEAR AVAILED
107	11-Jun-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66 HUNSUR_66	10:52	16:34	5:42	LINE CLEAR AVAILED
108	11-Jun-19	MYSORE	66	HV2	HULLAHALLI_66	12:16	13:07	0:51	LINE CLEAR AVAILED
109	11-Jun-19	MYSORE	66	HV1	JAIPUR_66	12:25	13:48	1:23	LINE CLEAR AVAILED
110	11-Jun-19	MYSORE	66	HV2	JAIPUR_66	11:27	13:13	1:45	LINE CLEAR AVAILED
111	11-Jun-19	MYSORE	66	HV1	KIKKERI_66	11:30	14:58	3:28	LINE CLEAR AVAILED
112	11-Jun-19	MYSORE	66	HV2	KIKKERI_66	16:54	17:10	0:15	LINE CLEAR AVAILED
113	11-Jun-19	MYSORE	66	HV2	KIKKERI_66	19:58	20:20	0:22	LINE CLEAR AVAILED
114	11-Jun-19	MYSORE	66	HV3	KIKKERI_66	10:00	11:30	1:30	LINE CLEAR AVAILED
115	11-Jun-19	MYSORE	66	MEGHALAPURA-SFC	CHIDRAVALLI_66 THUMLA_66	14:00	14:05	0:05	HAND TRIPPED
116	11-Jun-19	MYSORE	66	HV1	PGPALYA_66	13:10	14:50	1:40	LINE CLEAR AVAILED
117	11-Jun-19	MYSORE	66	HV2	PGPALYA_66	12:00	13:40	1:40	LINE CLEAR AVAILED
118	11-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	8:21	15:59	7:37	LINE CLEAR AVAILED
119	11-Jun-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:55	16:17	0:22	LINE FAULT
120	11-Jun-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA _220	14:04	14:18	0:13	LINE FAULT
121	11-Jun-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA _220	15:54	16:36	0:41	LINE FAULT
122	11-Jun-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	15:54	17:39	1:45	LINE CLEAR AVAILED
123	11-Jun-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	18:02	19:37	1:34	LINE CLEAR AVAILED
124	11-Jun-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	12:56	13:05	0:08	LINE FAULT
125	11-Jun-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:49	14:00	0:10	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
126	11-Jun-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	22:44	23:14	0:29	LINE FAULT
127	11-Jun-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	22:44	23:14	0:30	LINE FAULT
128	11-Jun-19	TUMKUR	66	TR-2	SHYLAPURA_66	13:21	13:34	0:13	LINE CLEAR AVAILED
129	11-Jun-19	TUMKUR	66	TR-1	SASALUHALLA_66	15:48	17:03	1:14	TRANSFORMER FAULT
130	11-Jun-19	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	13:27	17:53	4:26	LINE CLEAR AVAILED
131	12-Jun-19	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	16:15	16:40	0:25	LINE CLEAR AVAILED
132	12-Jun-19	BAGALKOT	110	110/11KV,HV2	BHUTANAL_110	11:52	11:55	0:03	TRANSFORMER FAULT
133	12-Jun-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110&WIND 1&2_33	12:07	13:00	0:53	TRANSFORMER FAULT
134	12-Jun-19	BAGALKOT	110	110/33KV,HV3	KUMATA_110	13:00	13:39	0:39	LINE CLEAR AVAILED
135	12-Jun-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	11:46	13:35	1:49	LINE CLEAR AVAILED
136	12-Jun-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	11:20	11:53	0:33	TRANSFORMER FAULT
137	12-Jun-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	13:05	13:56	0:51	LINE FAULT
138	12-Jun-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	13:59	23:59	10:00	LINE FAULT
139	12-Jun-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	13:04	13:49	0:45	LINE FAULT
140	12-Jun-19	BAGALKOT	220	KADRA1-KARAWAR	KARAWAR_220	9:55	14:05	4:10	LINE FAULT
141	12-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	1:10	15:51	14:41	LINE FAULT
142	12-Jun-19	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	16:25	16:45	0:20	LINE CLEAR AVAILED
143	12-Jun-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	13:40	17:25	3:45	TRANSFORMER FAULT
144	12-Jun-19	BAGALKOT	110	110/11KV, HV2	UDYAMBAG_110	11:47	12:18	0:31	TRANSFORMER FAULT
145	12-Jun-19	BAGALKOT	110	110/11KV, HV2	UDYAMBAG_110	12:38	23:59	11:21	TRANSFORMER FAULT
146	12-Jun-19	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	0:00	15:23	15:23	LINE CLEAR AVAILED
147	12-Jun-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TARIHAL_110	13:42	13:45	0:03	LOAD CHANGE OVER
148	12-Jun-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TARIHAL_110	17:40	17:48	0:08	LOAD CHANGE OVER
149	12-Jun-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINKOPPA_110	13:49	17:46	3:57	LINE CLEAR AVAILED
150	12-Jun-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	1:10	15:50	14:40	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
151	12-Jun-19	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	14:05	14:15	0:10	HAND TRIPPED
152	12-Jun-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	14:07	14:25	0:18	TRANSFORMER FAULT
153	12-Jun-19	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	14:38	17:30	2:52	TRANSFORMER FAULT
154	12-Jun-19	BAGALKOT	110	HUBLI220-PH COMPOUND	PH COMPOUND_110	11:45	16:37	4:52	LINE CLEAR AVAILED
155	12-Jun-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	8:11	12:23	4:12	LINE FAULT
156	12-Jun-19	BAGALKOT	110	SIRSI220(1)-SIRSI	SIRSI_110	8:11	8:25	0:14	LINE FAULT
157	12-Jun-19	BAGALKOT	110	SIRSI220(2)-SIRSI	SIRSI_110	8:11	8:25	0:14	LINE FAULT
158	12-Jun-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	8:25	8:34	0:09	HAND TRIPPED
159	12-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	10:35	12:50	2:15	LINE CLEAR AVAILED
160	12-Jun-19	BENGALURU	66	HV2	BUDIGERE	11:40	12:32	0:52	LINE CLEAR AVAILED
161	12-Jun-19	BENGALURU	66	HV2	ITI	11:52	11:54	0:02	TRANSFORMER FAULT
162	12-Jun-19	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	14:00	14:50	0:50	LINE CLEAR AVAILED
163	12-Jun-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	12:15	12:22	0:07	LOAD CHANGE OVER
164	12-Jun-19	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	11:10	11:20	0:10	LINE CLEAR AVAILED
165	12-Jun-19	BENGALURU	66	AGALAKOTE - MATHIKERE	MATHIKERE	10:13	11:48	1:34	LINE CLEAR AVAILED
166	12-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:59	6:07	0:08	LINE FAULT
167	12-Jun-19	BENGALURU	66	HV1	HOSKOTE 220	13:15	13:20	0:05	TRANSFORMER FAULT
168	12-Jun-19	BENGALURU	66	HV2	MAASTHI	0:03	0:08	0:05	TRANSFORMER FAULT
169	12-Jun-19	BENGALURU	66	HV1	MAASTHI	0:00	0:30	0:30	TRANSFORMER FAULT
170	12-Jun-19	BENGALURU	66	HV2	SULIBELE	9:11	9:27	0:16	TRANSFORMER FAULT
171	12-Jun-19	BENGALURU	66	YELAHANKA 220 - LINE 3	ESCORTS (EHT)	10:37	10:47	0:09	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
172	12-Jun-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	10:37	10:53	0:15	MAIN SUPPLY FAILURE
173	12-Jun-19	BENGALURU	66	ATTUR YELAHANKA - ABBIGERE	ABBIGERE	10:37	11:15	0:37	MAIN SUPPLY FAILURE
174	12-Jun-19	BENGALURU	66	ATTUR YELAHANKA - MANYATA TECH PARK	MANYATA TECH PARK	10:37	12:02	1:24	MAIN SUPPLY FAILURE
175	12-Jun-19	BENGALURU	66	ABBIGERE - WELCAST STEEL	ABBIGERE	12:10	12:13	0:03	LOAD CHANGE OVER
176	12-Jun-19	GULBARGA	220	HV1	RAICHUR_220	9:58	10:50	0:52	LINE CLEAR AVAILED
177	12-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	9:50	10:00	0:10	TRANSFORMER FAULT
178	12-Jun-19	GULBARGA	220	HV1	ITTAGI_220	18:01	18:30	0:29	TRANSFORMER FAULT
179	12-Jun-19	GULBARGA	220	HV2	ITTAGI_220	18:01	18:38	0:37	TRANSFORMER FAULT
180	12-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	12:40	12:48	0:08	LINE FAULT
181	12-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	10:30	10:35	0:05	LINE FAULT
182	12-Jun-19	GULBARGA	110	HV3	BEVOOR_110	15:12	15:54	0:42	TRANSFORMER FAULT
183	12-Jun-19	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110	10:12	16:25	6:13	LINE CLEAR AVAILED
184	12-Jun-19	GULBARGA	110	HV3	BEVOOR_110	18:14	18:17	0:03	TRANSFORMER FAULT
185	12-Jun-19	GULBARGA	110	HV2	SHORAPUR_110	9:18	9:27	0:09	TRANSFORMER FAULT
186	12-Jun-19	GULBARGA	110	HV2	SHORAPUR_110	16:25	16:53	0:28	TRANSFORMER FAULT
187	12-Jun-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110, BTPS WATER WORKS	23:47	23:59	0:12	LINE FAULT
188	12-Jun-19	GULBARGA	110	SHAHAPUR-SHAHABAD1	GOOGLE_110, NALWAR_110	18:30	19:30	1:00	LINE CLEAR AVAILED
189	12-Jun-19	GULBARGA	110	HV1	SHAHPUR_220	18:33	18:45	0:12	TRANSFORMER FAULT
190	12-Jun-19	GULBARGA	110	HV2	HANUMASAGAR_110	16:40	16:58	0:18	LINE CLEAR AVAILED
191	12-Jun-19	GULBARGA	110	BHALKI-HALBURGA	BHALKI_110,LADHA_110	17:15	18:20	1:05	LINE CLEAR AVAILED
192	12-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	14:30	14:40	0:10	TRANSFORMER FAULT
193	12-Jun-19	GULBARGA	66	HANASI-MUNIRABAD	HANASI_66	12:00	12:45	0:45	LINE CLEAR AVAILED



Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
194	12-Jun-19	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANASI_66	11:34	14:04	2:30	LINE CLEAR AVAILED
195	12-Jun-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANAVEKAL_66,CHORNOOR_66	12:15	13:02	0:47	LINE FAULT
196	12-Jun-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPASAGAR_66,MORAGERE_66,TAMBRAHALLI_66	18:01	18:50	0:49	LINE FAULT
197	12-Jun-19	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJANI_66,BENNEHALLI_66	18:01	18:40	0:39	LINE FAULT
198	12-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	20:18	20:20	0:02	TRANSFORMER FAULT
199	12-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:24	20:45	2:21	LINE CLEAR AVAILED
200	12-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	14:50	23:59	9:09	LINE CLEAR AVAILED
201	12-Jun-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	7:50	17:50	10:00	LINE FAULT
202	12-Jun-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	15:50	15:50	LINE FAULT
203	12-Jun-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	21:46	22:21	0:35	LINE FAULT
204	12-Jun-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	21:46	22:20	0:34	LINE FAULT
205	12-Jun-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	21:46	22:32	0:46	LINE FAULT
206	12-Jun-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	21:47	22:31	0:44	LINE FAULT
207	12-Jun-19	HASSAN	110	LV1	KEMAR_220	21:46	22:44	0:58	TRANSFORMER FAULT
208	12-Jun-19	HASSAN	110	KEMAR-MANIPAL2	KEMAR_220	9:50	13:53	4:03	LINE CLEAR AVAILED
209	12-Jun-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	7:47	17:50	10:03	LINE FAULT
210	12-Jun-19	HASSAN	220	HV1	PUTTUR_220	22:19	22:24	0:05	HAND TRIPPED
211	12-Jun-19	HASSAN	220	HV2	PUTTUR_220	22:19	22:24	0:05	HAND TRIPPED
212	12-Jun-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	21:46	23:03	1:17	MAIN SUPPLY FAILURE
213	12-Jun-19	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	21:46	22:01	0:15	LINE FAULT
214	12-Jun-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	12:11	12:27	0:16	LINE FAULT
215	12-Jun-19	HASSAN	110	HV1	BAIKAMPADI_110	18:59	19:04	0:05	MAIN SUPPLY FAILURE
216	12-Jun-19	HASSAN	110	HV3	BAIKAMPADI_110	18:59	19:04	0:05	MAIN SUPPLY FAILURE
217	12-Jun-19	HASSAN	110	HV5	BAIKAMPADI_110	10:38	11:12	0:34	TRANSFORMER FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
218	12-Jun-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	21:47	22:31	0:44	MAIN SUPPLY FAILURE
219	12-Jun-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	21:47	22:31	0:44	MAIN SUPPLY FAILURE
220	12-Jun-19	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	8:59	14:40	5:41	LINE CLEAR AVAILED
221	12-Jun-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	18:44	18:57	0:13	LINE FAULT
222	12-Jun-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	22:02	22:29	0:27	LINE FAULT
223	12-Jun-19	HASSAN	110	HV2	NAVUNDA_110	8:33	9:15	0:42	TRANSFORMER FAULT
224	12-Jun-19	HASSAN	110	LV1	PUTTUR_220	22:19	23:04	0:45	HAND TRIPPED
225	12-Jun-19	HASSAN	110	LV2	PUTTUR_220	22:19	23:42	1:23	LINE CLEAR AVAILED
226	12-Jun-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	21:52	23:05	1:13	LINE CLEAR AVAILED
227	12-Jun-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	21:52	23:05	1:13	LINE CLEAR AVAILED
228	12-Jun-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:50	23:59	12:09	LINE CLEAR AVAILED
229	12-Jun-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	13:35	14:03	0:28	LINE FAULT
230	12-Jun-19	HASSAN	66	HV2	MAGGE_66	9:45	13:27	3:42	LINE CLEAR AVAILED
231	12-Jun-19	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	13:35	14:04	0:29	LINE FAULT
232	12-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	8:07	17:00	8:53	LINE CLEAR AVAILED
233	12-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	17:54	23:02	5:08	LINE CLEAR AVAILED
234	12-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	0:12	0:25	0:13	LINE FAULT
235	12-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:09	7:21	0:12	LINE FAULT
236	12-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	8:07	17:00	8:53	LINE CLEAR AVAILED
237	12-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	17:54	22:45	4:51	LINE CLEAR AVAILED
238	12-Jun-19	MYSORE	66	HV2	BOOKANAKERE_66	12:39	12:45	0:05	TRANSFORMER FAULT
239	12-Jun-19	MYSORE	66	HV2	KIKKERI_66	12:04	12:55	0:50	LINE CLEAR AVAILED
240	12-Jun-19	MYSORE	66	MADDUR-K.HONNALGERE	MIRLE_66	12:02	17:15	5:12	LINE CLEAR AVAILED
241	12-Jun-19	MYSORE	66	MIRLE-KR NAGARA	MIRLE_66	10:12	17:00	6:47	LINE CLEAR AVAILED
242	12-Jun-19	MYSORE	66	HV1	SANTHESARAGUR_66	11:10	12:20	1:10	LINE CLEAR AVAILED
243	12-Jun-19	MYSORE	66	HV2	SANTHESARAGUR_66	11:10	13:41	2:31	LINE CLEAR AVAILED
244	12-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	0:54	23:59	23:04	LINE CLEAR AVAILED
245	12-Jun-19	MYSORE	66	HV2	TUBINAKERE_220	12:43	14:13	1:30	LINE CLEAR AVAILED
246	12-Jun-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	7:22	7:36	0:13	LINE FAULT
247	12-Jun-19	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	10:04	10:40	0:36	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
248	12-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	13:47	13:48	0:01	LINE FAULT
249	12-Jun-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	12:38	14:18	1:40	LINE CLEAR AVAILED
250	12-Jun-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	12:38	14:02	1:23	LINE CLEAR AVAILED
251	12-Jun-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:38	14:02	1:23	LINE CLEAR AVAILED
252	12-Jun-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:21	15:23	0:01	LINE CLEAR AVAILED
253	12-Jun-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	12:38	14:02	1:23	LINE CLEAR AVAILED
254	12-Jun-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	15:21	15:23	0:01	LINE CLEAR AVAILED
255	12-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	8:22	8:25	0:03	TRANSFORMER FAULT
256	12-Jun-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	12:24	13:41	1:17	LINE CLEAR AVAILED
257	12-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	15:42	15:45	0:02	LINE FAULT
258	12-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:29	12:37	0:07	HAND TRIPPED
259	12-Jun-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	9:41	9:48	0:07	LINE FAULT
260	12-Jun-19	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	10:03	10:40	0:37	LINE CLEAR AVAILED
261	12-Jun-19	TUMKUR	66	TR-&TR-2(LV SIDE)	MADHUGIRI_220	10:04	10:40	0:36	LINE CLEAR AVAILED
262	12-Jun-19	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	10:03	10:40	0:37	LINE CLEAR AVAILED
263	12-Jun-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	10:03	10:40	0:37	LINE CLEAR AVAILED
264	12-Jun-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	GULIGENAHALLI_66,SIRA_66	10:03	10:42	0:38	LINE CLEAR AVAILED
265	12-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA _220	17:26	17:58	0:32	LINE FAULT
266	12-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	17:26	17:58	0:32	LINE FAULT
267	13-Jun-19	BAGALKOT	110	110/11KV, HV1&HV2	BABLESHWAR_110	17:43	18:03	0:20	HAND TRIPPED
268	13-Jun-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	14:00	14:43	0:43	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
269	13-Jun-19	BAGALKOT	220	220/110KV, HV1,HV2,LV1&LV2	KUDACHI_220, KUDACHI_110, TERDAL_110, UGARKHUD_110, MORAB_110, AINAPUR_110, YELPARATTI_110	12:59	13:09	0:10	TRANSFORMER FAULT
270	13-Jun-19	BAGALKOT	220	KUDACHI-CHIKKODI	KUDACHI_220	12:59	13:08	0:09	LINE FAULT
271	13-Jun-19	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	12:59	13:09	0:10	LINE FAULT
272	13-Jun-19	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	12:59	13:11	0:12	TRANSFORMER FAULT
273	13-Jun-19	BAGALKOT	110	110/33KV, HV3	LAXMESHWAR_33, SSM_33, MMCL_33	6:45	7:20	0:35	TRANSFORMER FAULT
274	13-Jun-19	BAGALKOT	220	220/110KV, HV1&LV1	RANEBENNUR_220	10:58	19:10	8:12	LINE CLEAR AVAILED
275	13-Jun-19	BAGALKOT	110	110/11KV, HV1	RANEBENNUR_220	10:35	19:10	8:35	LINE CLEAR AVAILED
276	13-Jun-19	BAGALKOT	110	110/33KV, HV3	RANEBENNUR_220, RSNG_33, KUPPELUR_33	10:23	19:10	8:47	LINE CLEAR AVAILED
277	13-Jun-19	BAGALKOT	110	110/33KV, HV3	RANEBENNUR_220, GUDUR MAIDUR_33, HALGERI_33	10:22	19:10	8:48	LINE CLEAR AVAILED
278	13-Jun-19	BAGALKOT	110	RANEBENNUR220-TUMMINKATTI(RATTIHALLI)	TUMMINKATTI_110	10:32	19:24	8:52	LINE CLEAR AVAILED
279	13-Jun-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	13:28	13:50	0:22	LINE FAULT
280	13-Jun-19	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220, SIRSI_110	13:38	14:11	0:33	TRANSFORMER FAULT
281	13-Jun-19	BAGALKOT	110	SIRIS220-KAVALWADA	KAVALWADA_110	13:23	13:55	0:32	LINE CLEAR AVAILED
282	13-Jun-19	BAGALKOT	110	DAMBAL1-MUNDARGI	MUNDARGI_110	11:22	13:30	2:08	LINE CLEAR AVAILED
283	13-Jun-19	BAGALKOT	110	110/33KV, HV3	SALAHALLI_110, HULKUND_33	16:06	16:17	0:11	LINE CLEAR AVAILED
284	13-Jun-19	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	10:05	23:59	13:54	LINE CLEAR AVAILED
285	13-Jun-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	16:05	16:12	0:07	TRANSFORMER FAULT
286	13-Jun-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	21:18	21:39	0:21	LINE FAULT
287	13-Jun-19	BAGALKOT	220	220/110KV,HV2	VAJRAMATTI_220	15:49	17:11	1:22	LINE CLEAR AVAILED
288	13-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	17:22	18:28	1:06	LINE CLEAR AVAILED
289	13-Jun-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	7:06	7:09	0:03	TRANSFORMER FAULT
290	13-Jun-19	BAGALKOT	220	220/110KV,HV3,LV3	HUBLI_220,RAMANKOPPA_110,KA DANKOPPA_110	13:31	14:07	0:36	TRANSFORMER FAULT
291	13-Jun-19	BAGALKOT	110	110/11KV,HV2	UDYAMBAG_110	0:00	17:16	17:16	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
292	13-Jun-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	13:31	14:20	0:49	LINE FAULT
293	13-Jun-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	13:31	18:08	4:37	LINE FAULT
294	13-Jun-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	13:31	14:14	0:43	LINE FAULT
295	13-Jun-19	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	12:13	12:27	0:14	HAND TRIPPED
296	13-Jun-19	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	12:45	12:47	0:02	HAND TRIPPED
297	13-Jun-19	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	14:57	15:10	0:13	HAND TRIPPED
298	13-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	1:41	2:25	0:44	LINE FAULT
299	13-Jun-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	11:43	15:26	3:43	LINE CLEAR AVAILED
300	13-Jun-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	17:17	19:00	1:42	LINE FAULT
301	13-Jun-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	13:18	13:38	0:19	LINE FAULT
302	13-Jun-19	BENGALURU	66	HV1	ATTIBELE	14:18	14:31	0:12	TRANSFORMER FAULT
303	13-Jun-19	BENGALURU	66	HV1	DABUSPET 220	11:01	11:41	0:39	LINE CLEAR AVAILED
304	13-Jun-19	BENGALURU	66	HV2	DABUSPET 220	11:48	12:47	0:59	LINE CLEAR AVAILED
305	13-Jun-19	BENGALURU	66	HV2	GANJIGUNTE	10:36	10:54	0:17	TRANSFORMER FAULT
306	13-Jun-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	BTM 4TH PHASE, SOUTH CITY	14:12	14:26	0:14	LINE FAULT
307	13-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	16:18	18:45	2:27	LINE CLEAR AVAILED
308	13-Jun-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	16:18	18:47	2:28	LINE CLEAR AVAILED
309	13-Jun-19	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	12:52	13:48	0:56	LINE CLEAR AVAILED
310	13-Jun-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	11:59	12:11	0:12	LINE CLEAR AVAILED
311	13-Jun-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	17:17	19:00	1:42	LINE FAULT
312	13-Jun-19	BENGALURU	66	POTTERY ROAD - HBR LAYOUT	POTTERY ROAD	12:49	12:55	0:05	LOAD CHANGE OVER
313	13-Jun-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	13:18	13:38	0:19	LINE FAULT
314	13-Jun-19	BENGALURU	66	HV1	ATTIBELE	14:18	14:31	0:12	TRANSFORMER FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
315	13-Jun-19	BENGALURU	66	HV1	DABUSPET 220	11:01	11:41	0:39	LINE CLEAR AVAILED
316	13-Jun-19	BENGALURU	66	HV2	DABUSPET 220	11:48	12:47	0:59	LINE CLEAR AVAILED
317	13-Jun-19	BENGALURU	66	HV2	GANJIGUNTE	10:36	10:54	0:17	TRANSFORMER FAULT
318	13-Jun-19	BENGALURU	66	HV2	MAASTHI	13:49	14:00	0:10	LINE CLEAR AVAILED
319	13-Jun-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	BTM 4TH PHASE, SOUTH CITY	14:12	14:26	0:14	LINE FAULT
320	13-Jun-19	BENGALURU	66	JANGAMKOTE - MELUR	JANGAMKOTE	18:30	18:50	0:20	LOAD CHANGE OVER
321	13-Jun-19	BENGALURU	66	HV2	VIJAYAPURA	14:15	15:00	0:45	LINE CLEAR AVAILED
322	13-Jun-19	BENGALURU	66	VIJAYAPURA - JANGAMKOTE	JANGAMKOTE	15:30	15:45	0:15	LINE CLEAR AVAILED
323	13-Jun-19	GULBARGA	220	HV1	ITTAGI_220	10:40	11:40	1:00	LINE CLEAR AVAILED
324	13-Jun-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110, BTPS WATER WORKS	0:00	0:05	0:05	LINE FAULT
325	13-Jun-19	GULBARGA	110	HV1	HANUMASAGAR_110	8:30	10:05	1:35	LINE CLEAR AVAILED
326	13-Jun-19	GULBARGA	110	RAICHUR-SHAHABAD2	GOOGLE_110	11:05	11:20	0:15	LINE CLEAR AVAILED
327	13-Jun-19	GULBARGA	110	RAICHUR-SHAHABAD2	GOOGLE_110	11:20	11:50	0:30	NFBC ISSUED
328	13-Jun-19	GULBARGA	110	RAICHUR-SINDHNOOR2	KURUDICROSS_110	13:13	13:21	0:08	LINE FAULT
329	13-Jun-19	GULBARGA	110	RAICHUR-SINDHNOOR2	KURUDICROSS_110	13:21	13:51	0:30	LINE FAULT
330	13-Jun-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110, MADLAPUR_110	4:13	8:11	3:58	LINE FAULT
331	13-Jun-19	GULBARGA	110	SHAHPUR-SHAHABAD1	KEMBHAVI_110, UGARSUGAR_IPP	18:45	23:59	5:14	LINE FAULT
332	13-Jun-19	GULBARGA	66	ITTAGI-BANAVEKAL	BANAVEKAL_66	10:40	12:00	1:20	LINE CLEAR AVAILED
333	13-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	15:55	16:00	0:05	TRANSFORMER FAULT
334	13-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	16:05	16:10	0:05	TRANSFORMER FAULT
335	13-Jun-19	GULBARGA	66	ITTAGI-SUZLON1	ITTAGI_220	1:01	1:15	0:14	LINE FAULT
336	13-Jun-19	GULBARGA	66	ITTAGI-SUZLON1,2	ITTAGI_220	10:30	11:57	1:27	LINE CLEAR AVAILED
337	13-Jun-19	GULBARGA	66	KOGALI-ATRS LR_IPP	KOGALI_66	10:40	12:00	1:20	LINE CLEAR AVAILED
338	13-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:03	7:02	5:59	LINE CLEAR AVAILED
339	13-Jun-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	23:37	23:59	0:22	LINE FAULT
340	13-Jun-19	HASSAN	110	KAOOR-EMAR	KAVOOR_220	17:05	23:59	6:54	LINE CLEAR AVAILED
341	13-Jun-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	15:28	18:57	3:29	LINE FAULT
342	13-Jun-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	11:01	11:47	0:46	LINE CLEAR AVAILED
343	13-Jun-19	HASSAN	220	KEMAR-Kavoor3	KEMAR_220	23:36	23:59	0:23	LINE FAULT
344	13-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:00	14:35	0:35	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
345	13-Jun-19	HASSAN	220	MRSSHM-VARAH13	MRS MG_220	9:41	13:06	3:25	LINE CLEAR AVAILED
346	13-Jun-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:00	11:48	0:48	NFBC ISSUED
347	13-Jun-19	HASSAN	220	VARAH1-KEMAR1	varahi_gen	13:46	14:34	0:48	LINE FAULT
348	13-Jun-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	9:41	13:06	3:25	LINE CLEAR AVAILED
349	13-Jun-19	HASSAN	110	HV1	NITTUR_110	11:19	11:53	0:34	LINE CLEAR AVAILED
350	13-Jun-19	HASSAN	110	HV1	BAIKAMPADI_110	9:16	9:41	0:25	MAIN SUPPLY FAILURE
351	13-Jun-19	HASSAN	110	HV3	BAIKAMPADI_110	9:16	9:41	0:25	MAIN SUPPLY FAILURE
352	13-Jun-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	16:18	18:59	2:41	MAIN SUPPLY FAILURE
353	13-Jun-19	HASSAN	110	HV1	KONAJE_110	15:03	15:17	0:14	MAIN SUPPLY FAILURE
354	13-Jun-19	HASSAN	110	HV1	KONAJE_110	15:24	15:40	0:16	MAIN SUPPLY FAILURE
355	13-Jun-19	HASSAN	110	HV1	KONAJE_110	16:08	18:56	2:48	MAIN SUPPLY FAILURE
356	13-Jun-19	HASSAN	110	HV2	KONAJE_110	15:03	15:17	0:14	MAIN SUPPLY FAILURE
357	13-Jun-19	HASSAN	110	HV2	KONAJE_110	15:24	15:40	0:16	MAIN SUPPLY FAILURE
358	13-Jun-19	HASSAN	110	HV2	KONAJE_110	16:08	18:56	2:48	MAIN SUPPLY FAILURE
359	13-Jun-19	HASSAN	110	HV3	KONAJE_110	15:03	15:17	0:14	MAIN SUPPLY FAILURE
360	13-Jun-19	HASSAN	110	HV3	KONAJE_110	15:24	15:40	0:16	MAIN SUPPLY FAILURE
361	13-Jun-19	HASSAN	110	HV3	KONAJE_110	16:08	18:56	2:48	MAIN SUPPLY FAILURE
362	13-Jun-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:03	15:17	0:14	MAIN SUPPLY FAILURE
363	13-Jun-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:24	15:40	0:16	MAIN SUPPLY FAILURE
364	13-Jun-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	16:08	18:56	2:48	MAIN SUPPLY FAILURE
365	13-Jun-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:08	10:01	0:53	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
366	13-Jun-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	9:08	10:01	0:53	LINE CLEAR AVAILED
367	13-Jun-19	HASSAN	110	HV2	NAVUNDA_110	12:15	16:02	3:47	LINE CLEAR AVAILED
368	13-Jun-19	HASSAN	66	HV1	HOLALUR_66	10:10	10:48	0:38	LINE CLEAR AVAILED
369	13-Jun-19	HASSAN	66	HV2	HOLEHONNUR_66	16:12	16:50	0:38	LINE CLEAR AVAILED
370	13-Jun-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:37	11:43	0:06	HAND TRIPPED
371	13-Jun-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	12:45	15:15	2:30	LINE CLEAR AVAILED
372	13-Jun-19	HASSAN	66	HV1	SINGAPURA_66	12:45	15:15	2:30	LINE CLEAR AVAILED
373	13-Jun-19	HASSAN	66	HV2	SINGAPURA_66	12:45	15:15	2:30	LINE CLEAR AVAILED
374	13-Jun-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:15	17:30	5:15	LINE CLEAR AVAILED
375	13-Jun-19	MYSORE	66	HV1	BOOKANAKERE_66	15:41	16:02	0:21	LINE CLEAR AVAILED
376	13-Jun-19	MYSORE	66	ELAVALA-HOOTAGALLY	ELAVALA_66	9:51	17:51	7:59	LINE CLEAR AVAILED
377	13-Jun-19	MYSORE	66	ELAVALA-HUNSUR	GAVADAGERE_66	9:55	18:03	8:07	LINE CLEAR AVAILED
378	13-Jun-19	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	11:43	14:22	2:39	LINE CLEAR AVAILED
379	13-Jun-19	MYSORE	66	KADAKOLA-SARAGURU 2	ANTHARSANTHE_66 B MATKERE_66 DOORA_66 HAMPAPURA(K)_66 HDKOTE_66 HULLAHALLI_66 HURA_66 JAIPUR_66 SANTHESARAGUR_66	17:09	17:26	0:17	HAND TRIPPED
380	13-Jun-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66 B MATKERE_66 DOORA_66 HAMPAPURA(K)_66 HDKOTE_66 HULLAHALLI_66 HURA_66 JAIPUR_66 SANTHESARAGUR_66	17:09	17:26	0:17	HAND TRIPPED
381	13-Jun-19	MYSORE	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	17:22	17:25	0:03	HAND TRIPPED
382	13-Jun-19	MYSORE	66	HV1	K_HONNALGERE_66	13:19	13:38	0:18	HAND TRIPPED
383	13-Jun-19	MYSORE	66	K HONNALAGERE-HV2	K_HONNALGERE_66	13:19	13:38	0:18	HAND TRIPPED
384	13-Jun-19	MYSORE	66	HV2	KMDODDI_66	11:47	11:52	0:05	TRANSFORMER FAULT
385	13-Jun-19	MYSORE	220	HV2	VAJAMANGALA_220	9:46	23:59	14:12	LINE CLEAR AVAILED
386	13-Jun-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66,MARADIHUNDI_66	9:21	9:40	0:19	LOAD CHANGE OVER
387	13-Jun-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66 MEGHALAPURA_66 THUMLA_66	9:35	9:36	0:01	LOAD CHANGE OVER
388	13-Jun-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:24	12:09	1:44	LINE CLEAR AVAILED



Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
389	13-Jun-19	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66	1:38	1:42	0:04	LINE FAULT
390	13-Jun-19	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	11:12	13:14	2:01	LINE CLEAR AVAILED
391	14-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:15	5:21	0:06	LINE FAULT
392	14-Jun-19	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	5:15	5:20	0:05	LINE FAULT
393	14-Jun-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	17:52	18:44	0:52	LINE CLEAR AVAILED
394	14-Jun-19	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	6:15	6:29	0:14	LOAD CURTAILMENT
395	14-Jun-19	BAGALKOT	110	BAGEWADI-ATHARGA	ATHARGA_110	6:45	6:54	0:09	HAND TRIPPED
396	14-Jun-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	6:20	6:46	0:26	HAND TRIPPED
397	14-Jun-19	BAGALKOT	110	110/33KV, HV3	BAGALKOT_220, KATAGERI_33, GADDANKERI_33	6:15	6:57	0:42	LOAD CURTAILMENT
398	14-Jun-19	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	10:33	11:05	0:32	HAND TRIPPED
399	14-Jun-19	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	11:09	11:58	0:49	HAND TRIPPED
400	14-Jun-19	BAGALKOT	110	110/11KV, HV1&H2	HANGAL_110	6:15	6:27	0:12	LOAD CURTAILMENT
401	14-Jun-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	10:15	13:58	3:43	LINE CLEAR AVAILED
402	14-Jun-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	15:22	17:29	2:07	NFBC ISSUED
403	14-Jun-19	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	10:39	10:46	0:07	HAND TRIPPED
404	14-Jun-19	BAGALKOT	110	110/11KV, HV1	KUD DHARWAD_110	13:11	14:30	1:19	LINE CLEAR AVAILED
405	14-Jun-19	BAGALKOT	220	220/110KV, HV1,HV2,LV1&LV2	KUDACHI_220, KUDACHI_110, TERDAL_110, UGARKHUD_110, MORAB_110, AINAPUR_110, YELPARATTI_110	5:08	5:12	0:04	TRANSFORMER FAULT
406	14-Jun-19	BAGALKOT	110	110/33KV, HV3	KULIGOD_110, ARALIMATTI_33, TIGADI_33	6:15	6:25	0:10	LOAD CURTAILMENT
407	14-Jun-19	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	6:15	6:41	0:26	LOAD CURTAILMENT
408	14-Jun-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1&2	MANTUR_110	10:32	11:40	1:08	LINE CLEAR AVAILED
409	14-Jun-19	BAGALKOT	110	110/33KV, HV3	RANEENNUR_220, HALGERI_33, GUDURMAIDUR_33	6:15	6:47	0:32	LOAD CURTAILMENT
410	14-Jun-19	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	6:15	6:20	0:05	LOAD CURTAILMENT
411	14-Jun-19	BAGALKOT	110	110/11KV, HV1	TILUVALI_110	6:13	7:24	1:11	LOAD CURTAILMENT
412	14-Jun-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	11:02	13:39	2:37	LINE CLEAR AVAILED
413	14-Jun-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	6:13	6:30	0:17	LOAD CURTAILMENT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
414	14-Jun-19	BAGALKOT	110	RANNABELAGALI-MUDHOL(UTTUR)	UTTUR_110	5:45	6:30	0:45	LINE FAULT
415	14-Jun-19	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220	10:32	10:39	0:07	TRANSFORMER FAULT
416	14-Jun-19	BAGALKOT	220	220/110KV, HV2&LV2	VAJRAMATTI_220	10:32	20:02	9:30	TRANSFORMER FAULT
417	14-Jun-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	17:08	17:27	0:19	LINE FAULT
418	14-Jun-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	18:45	18:57	0:11	LOAD CHANGE OVER
419	14-Jun-19	BENGALURU	66	HV1	NANDINI LAYOUT	11:40	11:44	0:04	LINE CLEAR AVAILED
420	14-Jun-19	BENGALURU	66	HV2	NRS 220	17:08	17:26	0:18	MAIN SUPPLY FAILURE
421	14-Jun-19	BENGALURU	66	HV2	NRS 220	18:52	18:58	0:05	LOAD CHANGE OVER
422	14-Jun-19	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	2:00	2:57	0:57	LINE FAULT
423	14-Jun-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	2:00	4:01	2:01	LINE FAULT
424	14-Jun-19	GULBARGA	220	SEDAM-CLNMAX	SEDAM_220	1:59	4:10	2:11	LINE FAULT
425	14-Jun-19	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	1:59	3:18	1:19	LINE FAULT
426	14-Jun-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	1:59	3:45	1:46	LINE FAULT
427	14-Jun-19	GULBARGA	220	SEDAM-HUMNABAD1,2	HUMNABAD_220	1:59	3:11	1:12	LINE FAULT
428	14-Jun-19	GULBARGA	220	HV1	SEDAM_220	1:59	3:25	1:26	TRANSFORMER FAULT
429	14-Jun-19	GULBARGA	110	HV1	YADAGIR_110	6:30	6:40	0:10	TRANSFORMER FAULT
430	14-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	12:55	13:03	0:08	LINE FAULT
431	14-Jun-19	GULBARGA	110	HUMNABAD220-MARAGUTTI	MARAGUTTI_110	0:00	13:10	13:10	LINE CLEAR AVAILED
432	14-Jun-19	GULBARGA	110	SHAHPUR220-SHAHPUR1	SHAHPUR_110	10:24	10:28	0:04	LINE CLEAR AVAILED
433	14-Jun-19	GULBARGA	110	HV1	SHAHPUR_220	15:15	15:36	0:21	TRANSFORMER FAULT
434	14-Jun-19	GULBARGA	110	HV1	ALIPUR_220	10:35	12:40	2:05	LINE CLEAR AVAILED
435	14-Jun-19	GULBARGA	110	HV1	BISIHALLI_110	6:40	7:38	0:58	LINE CLEAR AVAILED
436	14-Jun-19	GULBARGA	110	HV1	HAMPASAGAR_66	13:17	13:20	0:03	TRANSFORMER FAULT
437	14-Jun-19	GULBARGA	220	HUMNABAD220-HALBARGA2	HUMNABAD_220	1:59	3:20	1:21	LINE FAULT
438	14-Jun-19	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	1:59	3:05	1:06	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
439	14-Jun-19	GULBARGA	110	HUMNABAD220-HALBARGA2	HUMNABAD_220	3:20	3:35	0:15	LINE FAULT
440	14-Jun-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	5:28	5:40	0:12	LINE FAULT
441	14-Jun-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	6:10	11:14	5:04	LINE CLEAR AVAILED
442	14-Jun-19	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110, HABSIKOTE_110	15:10	16:35	1:25	NFBC ISSUED
443	14-Jun-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	10:10	16:41	6:31	NFBC ISSUED
444	14-Jun-19	GULBARGA	110	HV4	YELBURGA_110	6:26	6:40	0:14	LOAD CURTAILMENT
445	14-Jun-19	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66,UPA NAYAKANAHALLI_66	9:30	16:05	6:35	LINE CLEAR AVAILED
446	14-Jun-19	GULBARGA	66	ITTAGI-CLEANMAX1	ITTAGI_220	13:05	13:15	0:10	HAND TRIPPED
447	14-Jun-19	GULBARGA	66	ITTAGI-RENWSLR1 &2	ITTAGI_220	14:54	15:10	0:16	HAND TRIPPED
448	14-Jun-19	GULBARGA	66	ITTAGI-SUZLON1&2	ITTAGI_220	15:10	15:16	0:06	HAND TRIPPED
449	14-Jun-19	GULBARGA	110	HUMNABAD220-MANEKHALLI	MANEKHALLI_110	18:45	23:59	5:14	NFBC ISSUED
450	14-Jun-19	HASSAN	400	HASSAN40-UPCL2	HASSAN_400	16:05	23:59	7:54	LINE CLEAR AVAILED
451	14-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:05	23:59	7:54	LINE CLEAR AVAILED
452	14-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:16	15:56	0:40	LINE FAULT
453	14-Jun-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:11	13:33	0:22	LINE FAULT
454	14-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	17:38	18:03	0:25	LINE FAULT
455	14-Jun-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	8:34	19:29	10:55	LINE CLEAR AVAILED
456	14-Jun-19	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	8:34	23:59	15:25	LINE CLEAR AVAILED
457	14-Jun-19	HASSAN	220	VARAH1-KEMAR1	varahi_gen	15:16	15:56	0:40	LINE FAULT
458	14-Jun-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	8:34	19:30	10:56	NFBC ISSUED
459	14-Jun-19	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	8:34	23:59	15:25	NFBC ISSUED
460	14-Jun-19	HASSAN	110	HV2	KUNDAPURA_110	9:10	16:20	7:10	LINE CLEAR AVAILED
461	14-Jun-19	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	16:27	16:46	0:19	LINE FAULT
462	14-Jun-19	HASSAN	110	HV2	MSEZ_220	15:39	16:27	0:48	LINE CLEAR AVAILED
463	14-Jun-19	HASSAN	66	HV2	BELUR_66	16:05	16:15	0:10	LINE CLEAR AVAILED
464	14-Jun-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	16:14	16:15	0:01	LINE CLEAR AVAILED
465	14-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	16:10	18:10	2:00	LINE CLEAR AVAILED
466	14-Jun-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	10:12	15:45	5:33	LINE CLEAR AVAILED
467	14-Jun-19	HASSAN	66	HASSN220-SKPURA	HASSAN_220	11:00	15:58	4:58	LINE CLEAR AVAILED
468	14-Jun-19	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	15:45	17:46	2:01	LINE CLEAR AVAILED
469	14-Jun-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	11:25	13:10	1:45	LINE FAULT
470	14-Jun-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	12:45	16:00	3:15	NFBC ISSUED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
471	14-Jun-19	HASSAN	66	HV1	SHRAVANABELAGOLA_66	17:44	17:51	0:07	LINE CLEAR AVAILED
472	14-Jun-19	HASSAN	66	HV2	SHRAVANABELAGOLA_66	17:51	18:01	0:10	LINE CLEAR AVAILED
473	14-Jun-19	HASSAN	66	KAVOOR-HASSAN1	UDDURKOPLU_66	15:45	17:46	2:01	NFBC ISSUED
474	14-Jun-19	HASSAN	220	KAVOOR-Kavoor3	KEMAR_220	0:00	0:08	0:08	LINE FAULT
475	14-Jun-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	0:00	0:09	0:09	LINE FAULT
476	14-Jun-19	HASSAN	110	KAVOOR-EMAR	KAVOOR_220	0:00	10:30	10:30	LINE CLEAR AVAILED
477	14-Jun-19	MYSORE	66	HV2	ADDIHALLI_66	6:23	6:30	0:06	LOAD CURTAILMENT
478	14-Jun-19	MYSORE	66	HV1	BILIKERE_66	6:24	23:59	17:34	LOAD CURTAILMENT
479	14-Jun-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	BANANGADI_66 CHINAKURALI_66	12:56	18:40	5:43	LINE CLEAR AVAILED
480	14-Jun-19	MYSORE	66	CHUNCHUNKATTE-KR NAGARA	CHUNCHUNKATTE_66	10:30	18:53	8:23	LINE CLEAR AVAILED
481	14-Jun-19	MYSORE	66	HV1	DUNDANAHALLI_66	10:00	19:00	9:00	LINE CLEAR AVAILED
482	14-Jun-19	MYSORE	66	HV2	DUNDANAHALLI_66	10:00	19:00	9:00	LINE CLEAR AVAILED
483	14-Jun-19	MYSORE	66	HV2	ELAVALA_66	6:30	6:45	0:15	LOAD CURTAILMENT
484	14-Jun-19	MYSORE	66	HV2	ELAVALA_66	16:44	16:54	0:10	LOAD CURTAILMENT
485	14-Jun-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66	9:49	16:24	6:35	NFBC ISSUED
486	14-Jun-19	MYSORE	66	HV2	HDKOTE_66	6:25	6:50	0:25	LOAD CURTAILMENT
487	14-Jun-19	MYSORE	66	HV2	JYOTHINAGARA_66	11:29	13:13	1:44	LINE CLEAR AVAILED
488	14-Jun-19	MYSORE	66	HV2	KMDODDI_66	6:24	6:45	0:21	LOAD CURTAILMENT
489	14-Jun-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	10:33	18:09	7:36	LINE CLEAR AVAILED
490	14-Jun-19	TUMKUR	110	TR-1	HONNAVALLI_110	15:20	16:51	1:31	LINE CLEAR AVAILED
491	14-Jun-19	TUMKUR	66	TR-1	CHANNAGIRI_66	10:31	13:15	2:43	LINE CLEAR AVAILED
492	14-Jun-19	TUMKUR	66	TR-2	CHANNAGIRI_66	13:04	15:26	2:22	LINE CLEAR AVAILED
493	14-Jun-19	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:55	16:14	0:19	LINE FAULT
494	14-Jun-19	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA_220	15:54	16:16	0:21	LINE FAULT
495	14-Jun-19	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66	22:05	22:12	0:07	HAND TRIPPED
496	14-Jun-19	TUMKUR	66	MAYAKONDA- ANGODU	MAYAKONDA_66, SASALUHALLA_66, CHIKKAJAJUR_66	16:35	16:44	0:08	LINE FAULT
497	15-Jun-19	BAGALKOT	110	KUDUCHI220-AINAPUR	AINAPUR_110	12:21	15:30	3:09	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
498	15-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	15:44	15:50	0:06	LINE CLEAR AVAILED
499	15-Jun-19	BAGALKOT	110	BIDNAL220-GADAG ROAD	GADAG ROAD_110	11:29	16:05	4:36	LINE CLEAR AVAILED
500	15-Jun-19	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	11:29	15:19	3:50	LINE CLEAR AVAILED
501	15-Jun-19	BAGALKOT	110	110/11KV,HV2	DAVALESHWARA_110	11:29	12:08	0:39	LINE CLEAR AVAILED
502	15-Jun-19	BAGALKOT	110	GADAG 220-SHIRAHATTI	SHIRAHATTI_110	11:29	18:48	7:19	LINE CLEAR AVAILED
503	15-Jun-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	11:11	16:46	5:35	LINE CLEAR AVAILED
504	15-Jun-19	BAGALKOT	110	110/11KV,HV1	HATTARGI_110	11:28	14:39	3:11	LINE CLEAR AVAILED
505	15-Jun-19	BAGALKOT	110	110/11KV,HV2	HATTARGI_110	11:28	14:40	3:12	LINE CLEAR AVAILED
506	15-Jun-19	BAGALKOT	110	M K HUBLI 220-BAILAHONGAL	BAILAHONGAL_110	11:29	15:02	3:33	LINE CLEAR AVAILED
507	15-Jun-19	BAGALKOT	110	110/33KV,HV1	BAILAHONGAL_110,SAMPAGAOV_33,NEGANAL_33,MURGOD_33	14:52	16:43	1:51	LINE CLEAR AVAILED
508	15-Jun-19	BAGALKOT	110	110/11KV,HV4	BAILAHONGAL_110	11:28	15:09	3:41	LINE CLEAR AVAILED
509	15-Jun-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	18:01	18:09	0:08	LINE CLEAR AVAILED
510	15-Jun-19	BAGALKOT	110	110/11KV,HV2	ZALKI_110	18:01	18:09	0:08	LINE CLEAR AVAILED
511	15-Jun-19	BAGALKOT	110	VAJRAMATTI-MANTUR 1&2	MANTUR_110	15:54	16:04	0:10	LINE CLEAR AVAILED
512	15-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	SOUDATTI_220	11:28	17:25	5:57	LINE CLEAR AVAILED
513	15-Jun-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	10:34	13:53	3:19	LINE CLEAR AVAILED
514	15-Jun-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	11:28	18:50	7:22	LINE CLEAR AVAILED
515	15-Jun-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	16:46	17:37	0:51	LINE CLEAR AVAILED
516	15-Jun-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	17:45	17:53	0:08	LINE CLEAR AVAILED
517	15-Jun-19	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	10:15	18:48	8:33	LINE CLEAR AVAILED
518	15-Jun-19	BAGALKOT	110	JAMKHANDI-SHIROL	SHIROL_110	11:29	23:59	12:30	LINE CLEAR AVAILED
519	15-Jun-19	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	11:29	18:59	7:30	LINE CLEAR AVAILED
520	15-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	17:24	17:35	0:11	LINE CLEAR AVAILED
521	15-Jun-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	MAHALINGAPUR_220	17:36	17:44	0:08	LINE CLEAR AVAILED
522	15-Jun-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	11:45	14:41	2:56	LINE CLEAR AVAILED
523	15-Jun-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	11:29	14:56	3:27	LINE CLEAR AVAILED
524	15-Jun-19	BAGALKOT	110	110/33KV,HV3	KUMATA_110, ANKOLA_33, HONNAVAR_33	17:06	17:16	0:10	HAND TRIPPED
525	15-Jun-19	BAGALKOT	110	SHIRHATTI-LAXMESHWAR	LAXMESHWAR_110	11:28	17:28	6:00	LINE CLEAR AVAILED
526	15-Jun-19	BAGALKOT	66	66/11KV, HV2	HARIHAR HOSPET_66	11:32	17:33	6:01	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
527	15-Jun-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	12:29	13:03	0:34	TRANSFORMER FAULT
528	15-Jun-19	BENGALURU	66	ADUGODI - HAL 1	AMARJYOTHI	21:05	21:35	0:30	LINE FAULT
529	15-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	SJ JOHNS	21:02	21:15	0:13	MAIN SUPPLY FAILURE
530	15-Jun-19	BENGALURU	66	ITI - HOODY 2	BANASWADI	12:30	13:40	1:10	LINE CLEAR AVAILED
531	15-Jun-19	BENGALURU	66	ST JOHNS - ADUGODI	SJ JOHNS	8:05	8:12	0:07	LOAD CHANGE OVER
532	15-Jun-19	BENGALURU	66	BOMMASANDRA I/A - ELECTRONIC CITY	BOMMASANDRA I/A	18:45	18:50	0:05	LOAD CHANGE OVER
533	15-Jun-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	11:26	12:05	0:39	LINE CLEAR AVAILED
534	15-Jun-19	BENGALURU	66	EDC 220 - B STATION	B STATION	10:00	17:16	7:15	LINE CLEAR AVAILED
535	15-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	21:13	21:15	0:01	MAIN SUPPLY FAILURE
536	15-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	21:02	21:39	0:37	LINE FAULT
537	15-Jun-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	18:10	18:30	0:20	LINE CLEAR AVAILED
538	15-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	12:09	13:57	1:47	LINE CLEAR AVAILED
539	15-Jun-19	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI	11:10	13:06	1:55	MAIN SUPPLY FAILURE
540	15-Jun-19	BENGALURU	66	HV1	ELITA PROMENEDE	9:13	9:21	0:08	TRANSFORMER FAULT
541	15-Jun-19	BENGALURU	220	HV2	HSR LAYOUT 220	21:02	21:14	0:12	TRANSFORMER FAULT
542	15-Jun-19	BENGALURU	66	BAGMANE TECH PARK - HAL 220	BAGMANE TECH PARK, GTRE (EHT)	10:00	16:05	6:05	LINE CLEAR AVAILED
543	15-Jun-19	BENGALURU	66	HV1	KORMANGALA	13:00	14:12	1:11	TRANSFORMER FAULT
544	15-Jun-19	BENGALURU	66	HV1	VTG DODDI	15:12	16:28	1:15	MAIN SUPPLY FAILURE
545	15-Jun-19	GULBARGA	220	HV2	KUSHTAGI_220	9:05	9:15	0:10	TRANSFORMER FAULT
546	15-Jun-19	GULBARGA	110	HV3	BEVOOR_110	7:47	8:00	0:13	TRANSFORMER FAULT
547	15-Jun-19	GULBARGA	110	ITTAGI-CLNMAX2	CLNMAX_IPP	11:55	11:58	0:03	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
548	15-Jun-19	GULBARGA	110	ITTAGI-RNWSLR2	RNWSLR_IPP	15:25	15:30	0:05	HAND TRIPPED
549	15-Jun-19	GULBARGA	110	LV2	KUSHTAGI_220	9:05	9:15	0:10	TRANSFORMER FAULT
550	15-Jun-19	GULBARGA	110	KUSHTAGI-KUSHTAGI_IPP	KUSHTAGISLR_IPP	10:30	11:00	0:30	LINE FAULT
551	15-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOR_110	1:58	2:08	0:10	LINE FAULT
552	15-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOR_110	2:52	3:03	0:11	LINE FAULT
553	15-Jun-19	GULBARGA	110	HV1	BYAGAWAT_110	13:15	15:40	2:25	LINE CLEAR AVAILED
554	15-Jun-19	GULBARGA	110	HV2	KOLHAR_110	6:05	6:10	0:05	TRANSFORMER FAULT
555	15-Jun-19	GULBARGA	110	HV3	KOLHAR_110	11:05	13:45	2:40	TRANSFORMER FAULT
556	15-Jun-19	GULBARGA	110	HV2	ALIPUR_220	15:15	15:30	0:15	TRANSFORMER FAULT
557	15-Jun-19	GULBARGA	110	HV2	ALIPUR_220	15:30	19:40	4:10	LINE CLEAR AVAILED
558	15-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:07	23:59	0:52	HAND TRIPPED
559	15-Jun-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	12:29	15:50	3:21	LINE CLEAR AVAILED
560	15-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	8:02	8:14	0:12	LINE FAULT
561	15-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:27	12:37	0:10	LINE FAULT
562	15-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:55	14:00	0:05	LINE FAULT
563	15-Jun-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	7:34	20:01	12:27	LINE CLEAR AVAILED
564	15-Jun-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	7:33	20:01	12:28	NFBC ISSUED
565	15-Jun-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	9:59	15:14	5:15	LINE CLEAR AVAILED
566	15-Jun-19	HASSAN	110	HV3	BAIKAMPADY_110	14:07	14:12	0:05	TRANSFORMER FAULT
567	15-Jun-19	HASSAN	110	HV1	KONAJE_110	14:31	14:35	0:04	HAND TRIPPED
568	15-Jun-19	HASSAN	110	HV2	KONAJE_110	14:31	14:35	0:04	HAND TRIPPED
569	15-Jun-19	HASSAN	110	HV3	KONAJE_110	14:31	14:35	0:04	HAND TRIPPED
570	15-Jun-19	HASSAN	110	HV3	KONAJE_110	16:52	19:36	2:44	TRANSFORMER FAULT
571	15-Jun-19	HASSAN	110	HV3	PUTTUR_220	11:02	14:21	3:19	LINE CLEAR AVAILED
572	15-Jun-19	HASSAN	110	SAGARA-JST1	SAGARA_110	5:21	5:40	0:19	LINE FAULT
573	15-Jun-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	14:26	23:59	9:33	LINE CLEAR AVAILED
574	15-Jun-19	HASSAN	66	HV1	HOLALUR_66	9:35	18:00	8:25	LINE CLEAR AVAILED
575	15-Jun-19	HASSAN	66	HV2	HOLALUR_66	9:35	18:00	8:25	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
576	15-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	15:11	15:25	0:14	LINE FAULT
577	15-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	15:11	15:25	0:14	LINE FAULT
578	15-Jun-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	CHINAKURALI_66	8:32	21:35	13:02	NFBC ISSUED
579	15-Jun-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:06	23:59	12:52	LINE CLEAR AVAILED
580	15-Jun-19	MYSORE	66	HV2	DODDABYADARAHALLI_66	10:02	14:40	4:38	LINE CLEAR AVAILED
581	15-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	7:56	8:01	0:05	TRANSFORMER FAULT
582	15-Jun-19	MYSORE	66	HV1	MADDUR_66	9:50	14:55	5:05	LINE CLEAR AVAILED
583	15-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	16:43	23:59	7:15	LINE CLEAR AVAILED
584	15-Jun-19	MYSORE	66	HV2	THANDYA_66	11:40	13:20	1:40	LINE CLEAR AVAILED
585	15-Jun-19	MYSORE	66	HV1	THANDYA_66	13:57	14:55	0:57	HAND TRIPPED
586	15-Jun-19	TUMKUR	220	TR-1	ANCHEPALYA_220	10:25	12:22	1:56	LINE CLEAR AVAILED
587	15-Jun-19	TUMKUR	220	TR-2	ANCHEPALYA_220	13:12	15:28	2:16	LINE CLEAR AVAILED
588	15-Jun-19	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	12:31	15:50	3:19	LINE CLEAR AVAILED
589	15-Jun-19	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	14:20	16:34	2:13	LINE CLEAR AVAILED
590	15-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	14:30	16:05	1:34	LINE CLEAR AVAILED
591	15-Jun-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	11:09	13:08	1:58	LINE CLEAR AVAILED
592	15-Jun-19	TUMKUR	66	TR-1(LV SIDE )	ANCHEPALYA_220	10:25	12:23	1:57	LINE CLEAR AVAILED
593	15-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	12:28	13:54	1:26	LINE CLEAR AVAILED
594	15-Jun-19	TUMKUR	66	TR-2	BEVINAHALLI_66	16:23	16:30	0:07	TRANSFORMER FAULT
595	15-Jun-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	16:22	16:38	0:16	LINE FAULT
596	15-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:12	16:28	1:15	LINE FAULT
597	15-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66, CHITRADURGA_220	15:12	16:29	1:17	LINE FAULT
598	15-Jun-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:10	16:32	6:22	LINE CLEAR AVAILED
599	15-Jun-19	TUMKUR	66	TR-1	SASALUHALLA_66	9:14	19:01	9:47	LINE CLEAR AVAILED



Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
600	15-Jun-19	TUMKUR	66	TR-2	THALLAKK_220	12:26	12:27	0:01	TRANSFORMER FAULT
601	15-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	12:27	12:31	0:03	LINE FAULT
602	15-Jun-19	TUMKUR	66	TR-2	THIMMASANDRA_66	13:25	13:33	0:08	LINE CLEAR AVAILED
603	16-Jun-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	9:33	9:35	0:02	LINE CLEAR AVAILED
604	16-Jun-19	BAGALKOT	110	BELGAUM 220-UCHAGAON	UCHAGAON_110	7:22	11:18	3:56	LINE CLEAR AVAILED
605	16-Jun-19	BAGALKOT	110	110/33KV,HV3	GAHTAPRABHA_110 ,KOLLALI_33, GOKAK MILLS_33	10:05	10:29	0:24	LINE CLEAR AVAILED
606	16-Jun-19	BAGALKOT	110	GHATAPRABHA 220-P G HUNSYAL	P G HUNSYAL_110	5:35	5:47	0:12	LINE FAULT
607	16-Jun-19	BAGALKOT	110	GHATAPRABHA 220-P G HUNSYAL	P G HUNSYAL_110	6:06	6:11	0:05	HAND TRIPPED
608	16-Jun-19	BAGALKOT	110	GHATAPRABHA 220-P G HUNSYAL	P G HUNSYAL_110	12:58	14:21	1:23	LINE CLEAR AVAILED
609	16-Jun-19	BAGALKOT	110	HIDIKAL2-ITANAL	ITANAL_110	10:05	14:37	4:32	LINE CLEAR AVAILED
610	16-Jun-19	BAGALKOT	110	RAIBAG2-ITANAL	ITANAL_110	10:05	14:37	4:32	LINE CLEAR AVAILED
611	16-Jun-19	BAGALKOT	110	ICPL-UTTUR	UTTUR_110	12:40	13:14	0:34	NFBC ISSUED
612	16-Jun-19	BAGALKOT	110	BPCL-SHIRAHATTI	SHIRAHATTI_110	0:26	0:55	0:29	LINE FAULT
613	16-Jun-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,KANAGAL_33K V,HEBBAL_33KV	15:55	16:01	0:06	HAND TRIPPED
614	16-Jun-19	BAGALKOT	110	110/33KV,HV3(HV2)	RANEENNUR_220	11:39	12:21	0:42	LINE CLEAR AVAILED
615	16-Jun-19	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	12:04	15:53	3:49	LINE CLEAR AVAILED
616	16-Jun-19	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	15:30	15:31	0:01	LINE CLEAR AVAILED
617	16-Jun-19	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGNUR)	MUDALAGI_110	12:04	15:30	3:26	LINE CLEAR AVAILED
618	16-Jun-19	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	10:35	10:50	0:14	LOAD CHANGE OVER
619	16-Jun-19	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	14:32	14:40	0:08	LOAD CHANGE OVER
620	16-Jun-19	BENGALURU	66	HV2	HOODY 400	19:19	20:50	1:30	TRANSFORMER FAULT
621	16-Jun-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	8:20	8:35	0:15	LOAD CHANGE OVER
622	16-Jun-19	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	17:12	17:30	0:18	LOAD CHANGE OVER
623	16-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	19:19	19:52	0:33	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
624	16-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	19:19	19:52	0:33	MAIN SUPPLY FAILURE
625	16-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	22:02	22:15	0:13	LOAD CHANGE OVER
626	16-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	22:02	22:15	0:13	LOAD CHANGE OVER
627	16-Jun-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	8:40	8:53	0:13	LOAD CHANGE OVER
628	16-Jun-19	BENGALURU	66	HBR LAYOUT - HEBBAL	HBR LAYOUT	11:02	11:12	0:10	LOAD CHANGE OVER
629	16-Jun-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	16:20	16:30	0:10	LOAD CHANGE OVER
630	16-Jun-19	BENGALURU	66	HBR LAYOUT - HEBBAL	HBR LAYOUT	18:05	18:10	0:05	LOAD CHANGE OVER
631	16-Jun-19	BENGALURU	66	HV1	EPIP 220	19:19	21:02	1:42	MAIN SUPPLY FAILURE
632	16-Jun-19	BENGALURU	66	HV3	EPIP 220	19:19	21:02	1:42	MAIN SUPPLY FAILURE
633	16-Jun-19	BENGALURU	220	HV1	EPIP 220	19:19	21:08	1:49	MAIN SUPPLY FAILURE
634	16-Jun-19	BENGALURU	220	HV2	EPIP 220	19:19	21:08	1:49	MAIN SUPPLY FAILURE
635	16-Jun-19	BENGALURU	66	HV1	GOKULA	0:23	2:30	2:06	TRANSFORMER FAULT
636	16-Jun-19	BENGALURU	220	HV2	HOODY 220	19:45	21:11	1:26	MAIN SUPPLY FAILURE
637	16-Jun-19	BENGALURU	220	HV3	HOODY 220	19:45	21:11	1:26	MAIN SUPPLY FAILURE
638	16-Jun-19	BENGALURU	66	HV1	ITI	21:57	22:03	0:06	TRANSFORMER FAULT
639	16-Jun-19	BENGALURU	66	ABBIGERE - DG 3	ABBIGERE	17:40	17:43	0:03	LOAD CHANGE OVER
640	16-Jun-19	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	7:50	7:55	0:05	LOAD CHANGE OVER
641	16-Jun-19	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	19:19	21:02	1:43	MAIN SUPPLY FAILURE
642	16-Jun-19	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	19:45	21:14	1:29	MAIN SUPPLY FAILURE
643	16-Jun-19	BENGALURU	66	HOODY 220 - ITI	ITI	19:45	21:20	1:35	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
644	16-Jun-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	19:45	21:30	1:45	MAIN SUPPLY FAILURE
645	16-Jun-19	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	19:56	21:14	1:17	MAIN SUPPLY FAILURE
646	16-Jun-19	BENGALURU	66	KONDASPURA - HOSKOTE	KONDASPURA	21:20	21:25	0:05	LOAD CHANGE OVER
647	16-Jun-19	GULBARGA	220	HV1	HALBARGA_220	0:02	0:22	0:20	LINE CLEAR AVAILED
648	16-Jun-19	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	13:09	13:47	0:38	MAIN SUPPLY FAILURE
649	16-Jun-19	GULBARGA	110	HV2	KEMBHAVI_110	15:30	15:40	0:10	TRANSFORMER FAULT
650	16-Jun-19	GULBARGA	110	HV2	KEMBHAVI_110	16:20	16:25	0:05	TRANSFORMER FAULT
651	16-Jun-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	2:10	2:17	0:07	LINE FAULT
652	16-Jun-19	GULBARGA	110	HV2	KUSHTAGI_220	13:05	13:25	0:20	TRANSFORMER FAULT
653	16-Jun-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:27	23:59	10:32	LINE CLEAR AVAILED
654	16-Jun-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	13:27	23:59	10:32	NFBC ISSUED
655	16-Jun-19	HASSAN	110	HV2	KARAYA_110	10:09	10:59	0:50	LINE CLEAR AVAILED
656	16-Jun-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	8:10	14:15	6:05	LINE CLEAR AVAILED
657	16-Jun-19	MYSORE	66	BANNANGADI-HUYGONAHALLY	BANANGADI_66	16:14	17:43	1:29	LINE CLEAR AVAILED
658	16-Jun-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	CHINAKURALI_66	6:47	7:30	0:42	NFBC ISSUED
659	16-Jun-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	CHINAKURALI_66	9:20	18:14	8:54	NFBC ISSUED
660	16-Jun-19	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	10:38	14:25	3:47	NFBC ISSUED
661	16-Jun-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE_66, BHERYA_66, DMG_HALLI_66, GVGUDI_66, MIRLE_66, KR NAGARA_66	5:11	5:18	0:06	LINE FAULT
662	16-Jun-19	MYSORE	66	HV1	KRPET_220	17:05	17:15	0:10	TRANSFORMER FAULT
663	16-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	15:13	22:25	7:11	LINE CLEAR AVAILED
664	16-Jun-19	MYSORE	66	TUBINAKERE-MC-2	BESAGARAHALLI_66, CHIKKA_MANDYA_66, HAMPAPURA_66, KOPPA_66, MANDYA_66	6:39	6:55	0:16	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
665	16-Jun-19	MYSORE	66	TUBINAKERE-MC-4	MALAVALLI_66, HADLI_66	6:39	6:53	0:14	LINE FAULT
666	16-Jun-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	16:13	16:14	0:01	LINE FAULT
667	16-Jun-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	13:43	15:01	1:17	LINE CLEAR AVAILED
668	16-Jun-19	TUMKUR	66	TR-1	MYLANAHALLI_66	17:17	18:51	1:34	LINE CLEAR AVAILED
669	16-Jun-19	TUMKUR	66	NEELAGUNDA 220kV- HULUVAGALU	HALUVAGALU_66	15:26	15:41	0:15	LINE FAULT
670	16-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:40	13:46	6:06	LINE FAULT
671	16-Jun-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKK E_66	9:55	10:41	0:46	LINE CLEAR AVAILED
672	17-Jun-19	BAGALKOT	110	GADAG-ANNIGERI	ANNIGER_110	9:33	15:41	6:08	LINE CLEAR AVAILED
673	17-Jun-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGER_110	10:04	15:11	5:07	LINE CLEAR AVAILED
674	17-Jun-19	BAGALKOT	220	MUDASHINGI-CHIKKODI	CHIKKODI_220	10:05	23:59	13:54	NFBC ISSUED
675	17-Jun-19	BAGALKOT	110	CHIKKODI 220-CHIKKODI	CHIKKODI_110	15:59	16:49	0:50	LINE CLEAR AVAILED
676	17-Jun-19	BAGALKOT	110	CHIKKODI 220-NIPPANI	NIPPANI_110	16:41	17:37	0:56	LINE CLEAR AVAILED
677	17-Jun-19	BAGALKOT	110	110/11KV,HV1	BIJAPUR CITY_110	10:32	11:07	0:35	LINE CLEAR AVAILED
678	17-Jun-19	BAGALKOT	110	KUDUCHI220-TERDAL	TERDAL_110	14:35	23:59	9:24	NFBC ISSUED
679	17-Jun-19	BAGALKOT	110	BPCL-SHIRAHATTI	SHIRAHATTI_110	15:15	16:32	1:17	LINE CLEAR AVAILED
680	17-Jun-19	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	18:03	18:05	0:02	TRANSFORMER FAULT
681	17-Jun-19	BAGALKOT	220	220/110KV,LV3	MAHALINGAPUR_220	10:12	23:59	13:47	LINE CLEAR AVAILED
682	17-Jun-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	10:10	23:59	13:49	LINE CLEAR AVAILED
683	17-Jun-19	BAGALKOT	220	GADAG-HARTHI 1	GADAG_220	14:35	15:05	0:30	LINE CLEAR AVAILED
684	17-Jun-19	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	10:51	14:30	3:39	LINE CLEAR AVAILED
685	17-Jun-19	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,RSNG_33KV,KU PELLUR_33KV	10:56	11:04	0:08	LINE CLEAR AVAILED
686	17-Jun-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	7:40	7:50	0:10	LOAD CHANGE OVER
687	17-Jun-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	12:33	12:38	0:05	LOAD CHANGE OVER
688	17-Jun-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	12:35	12:39	0:04	LOAD CHANGE OVER
689	17-Jun-19	BENGALURU	66	DEVARBISANAHALLI - CESSNO TECH PARK	DEVARBISANAHALLI	0:18	0:22	0:04	LOAD CHANGE OVER
690	17-Jun-19	BENGALURU	220	HV1	SRS PEENYA 220	9:52	10:14	0:22	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
691	17-Jun-19	BENGALURU	220	HV2	SRS PEENYA 220	9:52	10:16	0:24	MAIN SUPPLY FAILURE
692	17-Jun-19	BENGALURU	220	HV3	SRS PEENYA 220	9:52	10:17	0:25	MAIN SUPPLY FAILURE
693	17-Jun-19	BENGALURU	220	HV4	SRS PEENYA 220	9:52	10:18	0:26	MAIN SUPPLY FAILURE
694	17-Jun-19	BENGALURU	66	HV2	SRS PEENYA 220	9:52	10:20	0:28	MAIN SUPPLY FAILURE
695	17-Jun-19	BENGALURU	66	HV1	AMARJYOTHI	7:36	7:40	0:03	LOAD CHANGE OVER
696	17-Jun-19	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	10:06	10:40	0:33	LOAD CHANGE OVER
697	17-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:59	11:22	0:23	LINE CLEAR AVAILED
698	17-Jun-19	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	0:15	0:51	0:35	LINE FAULT
699	17-Jun-19	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	9:52	10:12	0:20	LINE FAULT
700	17-Jun-19	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA 220	9:52	10:12	0:20	LINE FAULT
701	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	9:52	11:00	1:08	MAIN SUPPLY FAILURE
702	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	9:52	10:36	0:44	MAIN SUPPLY FAILURE
703	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	9:52	10:05	0:13	MAIN SUPPLY FAILURE
704	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	9:52	10:21	0:29	MAIN SUPPLY FAILURE
705	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	9:52	10:36	0:44	MAIN SUPPLY FAILURE
706	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	9:52	10:05	0:13	MAIN SUPPLY FAILURE
707	17-Jun-19	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	11:00	11:05	0:05	LOAD CHANGE OVER
708	17-Jun-19	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	15:35	15:40	0:05	LOAD CHANGE OVER
709	17-Jun-19	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	9:52	10:16	0:24	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
710	17-Jun-19	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	9:52	10:15	0:23	MAIN SUPPLY FAILURE
711	17-Jun-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	9:52	10:36	0:44	MAIN SUPPLY FAILURE
712	17-Jun-19	BENGALURU	66	HV2	NRS 220	9:52	10:36	0:44	MAIN SUPPLY FAILURE
713	17-Jun-19	GULBARGA	220	HV2	ALIPUR_220	9:05	10:19	1:14	TRANSFORMER FAULT
714	17-Jun-19	GULBARGA	220	HV2	ALIPUR_220	12:31	12:34	0:03	LINE CLEAR AVAILED
715	17-Jun-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	12:42	20:15	7:33	LINE FAULT
716	17-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	11:33	11:45	0:12	TRANSFORMER FAULT
717	17-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	12:42	13:55	1:13	LINE CLEAR AVAILED
718	17-Jun-19	GULBARGA	220	KUSTAGI-SUZLON1	KUSTAGI_220	13:45	20:40	6:55	LINE CLEAR AVAILED
719	17-Jun-19	GULBARGA	110	HV2	BISIHALLI_110	22:38	22:46	0:08	TRANSFORMER FAULT
720	17-Jun-19	GULBARGA	110	HV4	YELBURGA_110	23:13	23:37	0:24	LOAD CURTAILMENT
721	17-Jun-19	GULBARGA	110	SHAHPUR220-YADGIR	YADAGIR_110	12:18	12:51	0:33	LINE CLEAR AVAILED
722	17-Jun-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	11:07	11:12	0:05	HAND TRIPPED
723	17-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	15:43	15:46	0:03	TRANSFORMER FAULT
724	17-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	17:14	17:17	0:03	TRANSFORMER FAULT
725	17-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	9:19	9:19	LINE CLEAR AVAILED
726	17-Jun-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	8:33	19:32	10:59	LINE CLEAR AVAILED
727	17-Jun-19	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	0:00	19:32	19:32	LINE CLEAR AVAILED
728	17-Jun-19	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	8:34	19:32	10:58	NFBC ISSUED
729	17-Jun-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	0:00	19:32	19:32	NFBC ISSUED
730	17-Jun-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	10:18	14:39	4:21	LINE CLEAR AVAILED
731	17-Jun-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:05	14:01	3:56	NFBC ISSUED
732	17-Jun-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:05	14:02	3:57	LINE CLEAR AVAILED
733	17-Jun-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:16	10:25	0:09	HAND TRIPPED
734	17-Jun-19	HASSAN	110	HV1	HIRENALLUR_110	12:00	14:00	2:00	LINE CLEAR AVAILED
735	17-Jun-19	HASSAN	66	HV2	BASAVAGHATTA_66	13:25	13:50	0:25	LINE CLEAR AVAILED
736	17-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	9:15	9:20	0:05	TRANSFORMER FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
737	17-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	13:00	13:05	0:05	HAND TRIPPED
738	17-Jun-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:50	12:50	1:00	LINE CLEAR AVAILED
739	17-Jun-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	14:40	14:53	0:13	LINE FAULT
740	17-Jun-19	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	11:52	12:51	0:59	NFBC ISSUED
741	17-Jun-19	MYSORE	66	HOOTAGALLI-ELAVALA	BANNIKUPPE_66, ELAVALA_66, GAVADAGERE_66, HOSURGATE_66, HUNSUR_66	7:05	7:16	0:11	HAND TRIPPED
742	17-Jun-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66, ELAVALA_66, GAVADAGERE_66, HOSURGATE_66, HUNSUR_66	7:05	23:59	16:54	LINE CLEAR AVAILED
743	17-Jun-19	MYSORE	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66	9:28	13:50	4:21	NFBC ISSUED
744	17-Jun-19	MYSORE	66	HV2	MYSORESOUTH_66	12:43	13:26	0:43	LINE CLEAR AVAILED
745	17-Jun-19	MYSORE	66	HV1	MYSORESOUTH_66	12:43	13:56	1:13	LINE CLEAR AVAILED
746	17-Jun-19	MYSORE	66	KUNTHUR DR PETE	KUNTHUR_66	10:40	14:00	3:20	LINE CLEAR AVAILED
747	17-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	6:27	8:35	2:07	LINE CLEAR AVAILED
748	17-Jun-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	5:41	5:55	0:14	LINE FAULT
749	17-Jun-19	TUMKUR	110	TR-1	KEREKODI_110	9:38	10:12	0:33	LINE CLEAR AVAILED
750	17-Jun-19	TUMKUR	66	TR-2	CHANNAGIRI_66	11:09	11:11	0:01	TRANSFORMER FAULT
751	17-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	9:50	9:56	0:06	HAND TRIPPED
752	17-Jun-19	TUMKUR	66	TR-2	MALEBENNUR_66	11:08	11:15	0:06	TRANSFORMER FAULT