

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 13.11.2018 to 19.11.2018

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	13-Nov-18	BAGALKOT	220	AMBEWADI-NERENDRA 2	AMBEWADI_220	10:31	11:37	1:06	LINE CLEAR AVAILED
2	13-Nov-18	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	16:25	16:44	0:19	LINE FAULT
3	13-Nov-18	BAGALKOT	110	DAMBAL-GADAG2(L4)	SAMBAPUR ROAD_110	16:52	23:59	7:07	LINE FAULT
4	13-Nov-18	BAGALKOT	110	110/11KV,HV-1	DAMBAL_110	19:12	19:56	0:44	MAIN SUPPLY FAILURE
5	13-Nov-18	BAGALKOT	110	110/11KV,HV-1	DAMBAL_110	20:22	20:46	0:24	MAIN SUPPLY FAILURE
6	13-Nov-18	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	19:23	19:59	0:36	MAIN SUPPLY FAILURE
7	13-Nov-18	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	20:41	21:09	0:28	MAIN SUPPLY FAILURE
8	13-Nov-18	BAGALKOT	110	DAMBAL-SUZLON(2&3)	DAMBAL_110	19:23	19:59	0:36	MAIN SUPPLY FAILURE
9	13-Nov-18	BAGALKOT	110	DAMBAL-SUZLON(2&3)	DAMBAL_110	20:41	20:46	0:05	MAIN SUPPLY FAILURE
10	13-Nov-18	BAGALKOT	110	GADAG-DAMBAL 2	DAMBAL_110	19:12	19:49	0:37	HAND TRIPPED
11	13-Nov-18	BAGALKOT	110	GAJENDRAGAD-RON1&2	RON_110	6:01	12:00	5:59	LINE FAULT
12	13-Nov-18	BAGALKOT	110	110/33KV,HV-4	HIDIKAL_110	4:07	4:13	0:06	TRANSFORMER FAULT
13	13-Nov-18	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	16:18	16:25	0:07	LINE FAULT
14	13-Nov-18	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	17:02	18:43	1:41	LINE FAULT
15	13-Nov-18	BAGALKOT	110	HUKKERI-KOTABAGI LIS	HUKKERI_110	18:08	19:27	1:19	LINE FAULT
16	13-Nov-18	BAGALKOT	110	NAVALAGUND-KONNUR	KONNUR_110	17:21	17:32	0:11	HAND TRIPPED
17	13-Nov-18	BAGALKOT	110	KONNUR-ANANT SOLAR	KONNUR_110	17:29	18:05	0:36	HAND TRIPPED
18	13-Nov-18	BAGALKOT	220	SHARAVATY2-SIRSI	SIRSI_220	14:16	16:36	2:20	HAND TRIPPED
19	13-Nov-18	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	17:19	17:26	0:07	TRANSFORMER FAULT
20	13-Nov-18	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110	10:50	10:59	0:09	HAND TRIPPED
21	13-Nov-18	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	16:31	16:59	0:28	MAIN SUPPLY FAILURE
22	13-Nov-18	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	17:31	17:35	0:04	TRANSFORMER FAULT
23	13-Nov-18	BAGALKOT	110	BETAGERI-NARAGAL	NARAGAL_110	6:00	6:33	0:33	LINE FAULT
24	13-Nov-18	BAGALKOT	110	NARAGAL-RON	RON_110	6:00	6:46	0:46	LINE FAULT
25	13-Nov-18	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	6:00	8:26	2:26	MAIN SUPPLY FAILURE
26	13-Nov-18	BAGALKOT	110	RON-GAJENDRAGAD2	GAJENDRAGAD_110	6:00	7:16	1:16	MAIN SUPPLY FAILURE
27	13-Nov-18	BAGALKOT	110	RON-GAJENDRAGAD1	GAJENDRAGAD_110	6:57	7:16	0:19	MAIN SUPPLY FAILURE
28	13-Nov-18	BAGALKOT	110	GAMESH-RON	RON_110	6:52	6:55	0:03	MAIN SUPPLY FAILURE
29	13-Nov-18	BAGALKOT	110	110/11KV,HV2	MUNDARGI_110	20:58	21:06	0:08	MAIN SUPPLY FAILURE
30	13-Nov-18	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	20:58	21:01	0:03	MAIN SUPPLY FAILURE
31	13-Nov-18	BAGALKOT	110	110/11KV,HV1	KUDACHI_220	11:54	17:14	5:20	HAND TRIPPED
32	13-Nov-18	BAGALKOT	110	220/110KV,LV1	KARAWAR_220	17:28	18:14	0:46	HAND TRIPPED
33	13-Nov-18	BAGALKOT	110	KARAWAR220-KUMTA	KUMTA_110	18:14	18:18	0:04	HAND TRIPPED
34	13-Nov-18	BAGALKOT	110	KARAWAR220-BINAGA	BINAGA_110	17:28	18:21	0:53	HAND TRIPPED
35	13-Nov-18	BAGALKOT	220	KADRA1-KARAWAR	KARAWAR_220	12:05	23:59	11:54	LINE FAULT
36	13-Nov-18	BAGALKOT	220	KADRA2-KARAWAR	KARAWAR_220	17:28	18:11	0:43	LINE FAULT
37	13-Nov-18	BAGALKOT	220	BIDNAL-SOUDATTI	SOUDATTI_220	10:03	17:08	7:05	NBFC ISSUED
38	14-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	4:39	14:48	10:09	LINE FAULT
39	14-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	15:05	23:59	8:54	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
40	14-Nov-18	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	10:32	16:30	5:58	HAND TRIPPED
41	14-Nov-18	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	10:33	16:26	5:53	HAND TRIPPED
42	14-Nov-18	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	16:47	16:57	0:10	LINE CLEAR AVAILED
43	14-Nov-18	BAGALKOT	110	HIDIKAL-ANKALAGI	ANKALAGI_110	10:19	23:59	13:40	HAND TRIPPED
44	14-Nov-18	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	18:06	18:17	0:11	HAND TRIPPED
45	14-Nov-18	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	11:05	12:45	1:40	LINE CLEAR AVAILED
46	14-Nov-18	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	9:34	23:59	14:25	LINE CLEAR AVAILED
47	14-Nov-18	BAGALKOT	220	220/110KV, HV2	BELGAUM_220, BELGAUM_110, ANKALAGI_110, HUKKERI_110	3:27	4:36	1:09	TRANSFORMER FAULT
48	14-Nov-18	BAGALKOT	220	220/110KV, HV1	BELGAUM_220, BELGAUM_110, ANKALAGI_110, HUKKERI_110	3:41	4:42	1:01	HAND TRIPPED
49	14-Nov-18	BAGALKOT	220	CHIKKODI-BELAGUM2	CHIKKODI_220	3:28	12:54	9:26	LINE FAULT
50	14-Nov-18	BAGALKOT	220	CHIKKODI-BELAGUM1	CHIKKODI_220	3:28	12:55	9:27	LINE FAULT
51	14-Nov-18	BAGALKOT	110	ENERCON-DAMBAL	DAMBAL_110	11:53	13:18	1:25	LOAD CURTAILMENT
52	14-Nov-18	BAGALKOT	110	SUZLON1&2-DAMBAL	DAMBAL_110	11:53	13:10	1:17	LOAD CURTAILMENT
53	14-Nov-18	BAGALKOT	110	DAMBAL-SAMBAPUR ROAD	SAMBAPUR ROAD_110	0:00	12:58	12:58	LINE CLEAR AVAILED
54	14-Nov-18	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	11:44	12:32	0:48	HAND TRIPPED
55	14-Nov-18	BAGALKOT	110	MRUTHUNJAY NAGAR1&2- GOPPANAKOPPA	GOPPANAKOPPA_110	5:15	5:22	0:07	LOAD CURTAILMENT
56	14-Nov-18	BAGALKOT	110	GADAG ROAD-GOPPANAKOPPA	GOPPANAKOPPA_110	5:23	9:52	4:29	HAND TRIPPED
57	14-Nov-18	BAGALKOT	110	VISHWANATH SUGARS-HUKKERI	HUKKERI_110	12:04	12:28	0:24	LINE CLEAR AVAILED
58	14-Nov-18	BAGALKOT	110	HUKKERI-KOTTAWAGI LIS	HUKKERI_110	12:05	12:35	0:30	LINE CLEAR AVAILED
59	14-Nov-18	BAGALKOT	110	110/11KV, HV3	HUKKERI_110	17:01	18:05	1:04	LINE CLEAR AVAILED
60	14-Nov-18	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	7:36	7:58	0:22	LINE CLEAR AVAILED
61	14-Nov-18	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	12:23	16:06	3:43	LINE CLEAR AVAILED
62	14-Nov-18	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	0:00	16:09	16:09	LINE CLEAR AVAILED
63	14-Nov-18	BAGALKOT	110	220/110KV, LV1	KARWAR_220, ARGAL_110, BINAGA	12:23	16:11	3:48	LOAD CURTAILMENT
64	14-Nov-18	BAGALKOT	110	GSML2-MAHALINGAPUR	MAHALINGAPUR_220	17:53	17:58	0:05	LINE CLEAR AVAILED
65	14-Nov-18	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	22:31	23:59	1:28	LINE FAULT
66	14-Nov-18	BAGALKOT	110	DODDANAVAR-NANADI	NANADI_110	13:40	14:32	0:52	LINE CLEAR AVAILED
67	14-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	8:19	9:22	1:03	TRANSFORMER FAULT
68	14-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	11:00	11:08	0:08	TRANSFORMER FAULT
69	14-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	11:36	12:43	1:07	TRANSFORMER FAULT
70	14-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	14:32	14:38	0:06	TRANSFORMER FAULT
71	14-Nov-18	BAGALKOT	110	110/11KV,HV-1	TODALABAGI_110	8:30	8:37	0:07	TRANSFORMER FAULT
72	14-Nov-18	BAGALKOT	110	SOUDATTI-NARAGUND	RAMDURGA_110	7:09	7:45	0:36	LINE FAULT
73	14-Nov-18	BAGALKOT	110	SIRSI 220-IDLE 2	KAVALAWAD_110	10:34	10:41	0:07	HAND TRIPPED
74	14-Nov-18	BAGALKOT	110	110/11KV,HV-2	SHIROL_110	22:20	22:54	0:34	HAND TRIPPED
75	14-Nov-18	BAGALKOT	110	110/11KV,HV-3	SAVALAGI_110	10:44	11:18	0:34	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
76	14-Nov-18	BAGALKOT	110	110/33KV,HV-3	SALAHALLI_110	13:06	13:30	0:24	HAND TRIPPED
77	14-Nov-18	BAGALKOT	220	NARENDRA-AMBEWADI 1	NARENDRA_220	5:17	14:49	9:32	HAND TRIPPED
78	14-Nov-18	BAGALKOT	220	220/110KV,HV-1&LV-1	NARENDRA_220	5:17	7:56	2:39	TRANSFORMER FAULT
79	14-Nov-18	BAGALKOT	110	NARENDRA-BELUR1&2	BELUR_110	5:17	5:18	0:01	MAIN SUPPLY FAILURE
80	14-Nov-18	BAGALKOT	110	NARENDRA-MRITYUNJAYANAGAR 2	MRITYUNJAYANAGAR_110	5:17	5:37	0:20	MAIN SUPPLY FAILURE
81	14-Nov-18	BAGALKOT	110	NARENDTA-KUD 1	KUD_110	5:17	5:21	0:04	MAIN SUPPLY FAILURE
82	14-Nov-18	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	11:33	13:40	2:07	MAIN SUPPLY FAILURE
83	14-Nov-18	BAGALKOT	110	110/11KV,HV-1	MUDHOL_110	11:25	12:54	1:29	HAND TRIPPED
84	15-Nov-18	BAGALKOT	110	110/11KV,HV-3	BAILHONGAL_110	17:01	18:05	1:04	HAND TRIPPED
85	15-Nov-18	BAGALKOT	110	MK HUBLI-BAILHONGAL	BAILHONGAL_110	17:53	18:04	0:11	HAND TRIPPED
86	15-Nov-18	BAGALKOT	110	110/11KV,HV-2	ANAND NAGAR_110	6:51	7:18	0:27	HAND TRIPPED
87	15-Nov-18	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	0:00	17:38	17:38	LINE CLEAR AVAILED
88	15-Nov-18	BAGALKOT	110	110/33KV,HV-4	HIDIKAL_110	2:30	2:35	0:05	TRANSFORMER FAULT
89	15-Nov-18	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	15:21	15:39	0:18	HAND TRIPPED
90	15-Nov-18	BAGALKOT	110	MUNDARAGI-VIJANAGAR SUGAR	MUNDARAGI_110	0:00	17:18	17:18	LINE CLEAR AVAILED
91	15-Nov-18	BAGALKOT	110	110/11KV,HV-1	NIDAGUNDI_110	21:34	21:45	0:11	TRANSFORMER FAULT
92	15-Nov-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	10:33	13:50	3:17	LINE CLEAR AVAILED
93	15-Nov-18	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	16:34	23:59	7:25	LINE FAULT
94	15-Nov-18	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	6:21	6:27	0:06	LINE FAULT
95	16-Nov-18	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	9:42	9:46	0:04	HAND TRIPPED
96	16-Nov-18	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	18:08	18:15	0:07	HAND TRIPPED
97	16-Nov-18	BAGALKOT	110	110/11KV, HV3	BAILHONGAL_110	17:32	17:48	0:16	LINE CLEAR AVAILED
98	16-Nov-18	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	12:10	12:20	0:10	LINE FAULT
99	16-Nov-18	BAGALKOT	110	BELGAUM SOLAR-MAMDAPUR	MAMDAPUR(G)_110	11:50	13:29	1:39	LINE CLEAR AVAILED
100	16-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	10:02	10:15	0:13	TRANSFORMER FAULT
101	16-Nov-18	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	8:27	10:05	1:38	TRANSFORMER FAULT
102	16-Nov-18	BAGALKOT	220	MKHUBLI-NARENDRA1	MKHUBLI_220	10:26	23:59	13:33	LINE CLEAR AVAILED
103	16-Nov-18	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	9:24	19:33	10:09	LINE CLEAR AVAILED
104	16-Nov-18	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	0:00	16:45	16:45	LINE CLEAR AVAILED
105	16-Nov-18	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_220	9:23	19:32	10:09	HAND TRIPPED
106	16-Nov-18	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:42	18:15	8:33	HAND TRIPPED
107	16-Nov-18	BAGALKOT	110	110/11KV, HV1	SIRSI_220	9:55	18:26	8:31	HAND TRIPPED
108	16-Nov-18	BAGALKOT	110	SIRSI-UMACHAGI	UMACHAGI_110	9:51	18:25	8:34	NBFC ISSUED
109	16-Nov-18	BAGALKOT	220	SRS HUBLI-NARENDRA1	SRS HUBLI_220	11:57	15:20	3:23	LINE CLEAR AVAILED
110	16-Nov-18	BAGALKOT	110	SRS HUBLI-TARIHAL 1&2	TARIHAL_110	10:29	16:08	5:39	LINE CLEAR AVAILED
111	17-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	15:07	15:07	LINE CLEAR AVAILED
112	17-Nov-18	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	2:58	3:11	0:13	LINE FAULT
113	17-Nov-18	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	15:39	16:36	0:57	HAND TRIPPED
114	17-Nov-18	BAGALKOT	110	110/33KV,HV3	GUTTAL_110	17:44	17:50	0:06	HAND TRIPPED
115	17-Nov-18	BAGALKOT	110	110/33KV,HV-4	HIDIKAL_110	2:47	2:53	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
116	17-Nov-18	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	4:13	13:10	8:57	LINE FAULT
117	17-Nov-18	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	13:15	14:23	1:08	HAND TRIPPED
118	17-Nov-18	BAGALKOT	110	VAJRAMATTI-MANTUR1	VAJRAMATTI_220	18:42	19:01	0:19	LINE FAULT
119	17-Nov-18	BAGALKOT	110	110/33KV,HV3	ZALKI_110	7:31	7:46	0:15	TRANSFORMER FAULT
120	17-Nov-18	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	22:01	22:04	0:03	TRANSFORMER FAULT
121	17-Nov-18	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	10:19	15:14	4:55	LINE CLEAR AVAILED
122	17-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	11:59	14:24	2:25	LINE CLEAR AVAILED
123	17-Nov-18	BAGALKOT	220	MK HUBLI-NARENDRA1	MK HUBLI_220	0:00	10:27	10:27	LINE CLEAR AVAILED
124	17-Nov-18	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	10:27	15:48	5:21	LINE CLEAR AVAILED
125	17-Nov-18	BAGALKOT	66	BANUVALLY-HARIHAR HOSPET	HARIHAR HOSPET_66	9:28	9:44	0:16	LINE FAULT
126	18-Nov-18	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	18:15	23:59	5:44	LINE FAULT
127	18-Nov-18	BAGALKOT	110	110/11KV,HV2	BABLESHWARA_110	11:45	12:15	0:30	HAND TRIPPED
128	18-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	11:54	12:38	0:44	LINE FAULT
129	18-Nov-18	BAGALKOT	220	CHIKKODI2-BELGAUM	BELGAUM_220	12:13	12:38	0:25	LINE FAULT
130	18-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	19:24	23:59	4:35	HAND TRIPPED
131	18-Nov-18	BAGALKOT	220	CHIKKODI2-BELGAUM	BELGAUM_220	19:46	23:59	4:13	HAND TRIPPED
132	18-Nov-18	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	11:55	12:21	0:26	TRANSFORMER FAULT
133	18-Nov-18	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	11:26	17:44	6:18	HAND TRIPPED
134	18-Nov-18	BAGALKOT	110	110/33KV,HV3	GUTTAL_110	11:26	11:33	0:07	TRANSFORMER FAULT
135	18-Nov-18	BAGALKOT	110	110/11KV,HV2	SHIROL_110	5:27	7:13	1:46	TRANSFORMER FAULT
136	18-Nov-18	BAGALKOT	110	110/33KV,HV4	ZALKI_110	12:48	12:52	0:04	TRANSFORMER FAULT
137	18-Nov-18	BAGALKOT	110	110/11KV,HV1	ZALKI_110	17:40	17:45	0:05	TRANSFORMER FAULT
138	18-Nov-18	BAGALKOT	110	110/11KV,HV2	UDYAMBAG_110	10:27	13:51	3:24	LINE CLEAR AVAILED
139	18-Nov-18	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	10:13	10:19	0:06	TRANSFORMER FAULT
140	18-Nov-18	BAGALKOT	110	SUVARNA SOUDA- MACHE	SUVARNA SOUDA_110	16:37	23:59	7:22	HAND TRIPPED
141	18-Nov-18	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGOAN_110	17:57	19:04	1:07	LINE FAULT
142	18-Nov-18	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGOAN_110	21:07	21:44	0:37	LINE FAULT
143	18-Nov-18	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGOAN_110	21:44	23:59	2:15	LINE FAULT
144	18-Nov-18	BAGALKOT	110	ATHANI 220-SATTI	SATTI_110	18:39	23:59	5:20	LINE FAULT
145	18-Nov-18	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	9:46	19:07	9:21	HAND TRIPPED
146	18-Nov-18	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	9:47	19:08	9:21	HAND TRIPPED
147	18-Nov-18	BAGALKOT	220	SIRSI-SHARAVATHI2	SIRSI_220	9:50	19:11	9:21	HAND TRIPPED
148	18-Nov-18	BAGALKOT	110	110/11KV,HV1	NIPPANI_110	10:47	18:12	7:25	HAND TRIPPED
149	18-Nov-18	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	8:02	8:08	0:06	TRANSFORMER FAULT
150	18-Nov-18	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	8:10	8:15	0:05	TRANSFORMER FAULT
151	18-Nov-18	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	17:17	23:59	6:42	LINE FAULT
152	18-Nov-18	BAGALKOT	110	HONNAVAR-MURDESHWAR	MURDESHWAR_110	22:05	23:59	1:54	MAIN SUPPLY FAILURE
153	18-Nov-18	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	1:28	1:43	0:15	LINE FAULT
154	18-Nov-18	BAGALKOT	110	MKHUBLI220-KHANAPUR	KHANAPUR_110	0:49	1:29	0:40	LINE FAULT
155	18-Nov-18	BAGALKOT	110	110/33KV, HV3	LOKAPUR_110	8:35	9:32	0:57	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
156	18-Nov-18	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	7:57	8:49	0:52	TRANSFORMER FAULT
157	18-Nov-18	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	19:15	20:20	1:05	TRANSFORMER FAULT
158	18-Nov-18	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	20:48	23:59	3:11	TRANSFORMER FAULT
159	18-Nov-18	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	20:13	23:59	3:46	HAND TRIPPED
160	19-Nov-18	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	0:00	7:21	7:21	LINE CLEAR AVAILED
161	19-Nov-18	BAGALKOT	110	110/11KV,HV2	ANAND NAGAR_110	6:52	7:05	0:13	TRANSFORMER FAULT
162	19-Nov-18	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	18:05	23:59	5:54	LINE FAULT
163	19-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	0:00	0:49	0:49	HAND TRIPPED
164	19-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	3:04	23:59	20:55	LINE CLEAR AVAILED
165	19-Nov-18	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	3:01	5:40	2:39	HAND TRIPPED
166	19-Nov-18	BAGALKOT	110	NARAGUND-GOPANAKOPPA	GOPANAKOPPA_110	17:17	23:59	6:42	LINE FAULT
167	19-Nov-18	BAGALKOT	110	UMMACHAGI-SIRSI	SIRSI_110	18:37	21:07	2:30	NBFC ISSUED
168	19-Nov-18	BAGALKOT	110	UGAR KHUD-KAGWAD	KAGWAD_110	21:56	22:10	0:14	LINE FAULT
169	19-Nov-18	BAGALKOT	110	SIRSI 220-SIRSI	SIRSI_110	9:59	12:50	2:51	HAND TRIPPED
170	19-Nov-18	BAGALKOT	220	NAGZARI1-HUBLI	HUBLI_220	19:01	19:12	0:11	LINE FAULT
171	19-Nov-18	BAGALKOT	110	110/11KV,HV2	SIRSI_110	2:13	4:04	1:51	HAND TRIPPED
172	19-Nov-18	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	0:00	18:57	18:57	LINE CLEAR AVAILED
173	19-Nov-18	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	15:55	17:00	1:05	TRANSFORMER FAULT
174	19-Nov-18	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	0:00	10:00	10:00	HAND TRIPPED
175	13-Nov-18	BANGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMMAMPALLI, SOMANATHAPURA	14:35	14:47	0:12	MAIN SUPPLY FAILURE
176	13-Nov-18	BANGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	14:35	14:47	0:12	MAIN SUPPLY FAILURE
177	13-Nov-18	BANGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMMAMPALLI, SOMANATHAPURA	13:55	14:25	0:30	MAIN SUPPLY FAILURE
178	13-Nov-18	BANGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	13:55	14:25	0:30	MAIN SUPPLY FAILURE
179	13-Nov-18	BANGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	9:55	10:24	0:29	LOAD CHANGE OVER
180	13-Nov-18	BANGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	19:31	19:51	0:20	LOAD CHANGE OVER
181	13-Nov-18	BANGALURU	66	HV2	CHIKKABALLPURA URBAN	15:17	15:50	0:33	LINE CLEAR AVAILED
182	13-Nov-18	BANGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	9:54	18:41	8:46	LINE CLEAR AVAILED
183	13-Nov-18	BANGALURU	220	HV1	SARJAPURA 220	10:10	17:08	6:58	LINE CLEAR AVAILED
184	13-Nov-18	BANGALURU	220	HV2	SARJAPURA 220	10:10	19:49	9:39	LINE CLEAR AVAILED
185	13-Nov-18	BANGALURU	66	HV1	SARJAPURA 220	10:10	17:09	6:59	LINE CLEAR AVAILED
186	13-Nov-18	BANGALURU	66	HV2	SARJAPURA 220	10:10	19:59	9:49	LINE CLEAR AVAILED
187	13-Nov-18	BANGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	9:53	19:01	9:07	LINE CLEAR AVAILED
188	13-Nov-18	BANGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:12	10:21	0:08	LINE FAULT
189	13-Nov-18	BANGALURU	66	HV2	KEMBODI	12:14	13:57	1:42	LINE CLEAR AVAILED
190	13-Nov-18	BANGALURU	66	HV2	KEMBODI	15:48	16:22	0:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
191	13-Nov-18	BANGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:27	10:30	0:02	LOAD CHANGEOVER
192	13-Nov-18	BANGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:57	18:00	0:02	LOAD CHANGEOVER
193	13-Nov-18	BANGALURU	66	HV1	NELAMANGALA 66	10:20	10:30	0:10	LOAD CHANGEOVER
194	13-Nov-18	BANGALURU	66	ALUR - SRS PEENYA 220	ALUR	10:20	17:58	7:38	LINE CLEAR AVAILED
195	13-Nov-18	BANGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	13:54	14:04	0:09	LOAD CHANGEOVER
196	13-Nov-18	BANGALURU	66	ADUGODI - HSR LAYOUT 1	ADUGODI, BOSCH (EHT)	15:56	16:06	0:09	LOAD CHANGEOVER
197	13-Nov-18	BANGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	20:38	20:48	0:09	LOAD CHANGEOVER
198	13-Nov-18	BANGALURU	66	HV1	AMARJYOTHI	8:12	8:18	0:05	LINE CLEAR AVAILED
199	13-Nov-18	BANGALURU	66	HV1	BRINDAVANA	13:48	13:54	0:06	TRANSFORMER FAULT
200	13-Nov-18	BANGALURU	66	HV3	BRINDAVANA	11:50	12:00	0:10	TRANSFORMER FAULT
201	13-Nov-18	BANGALURU	66	HV1	EPIP 220	14:03	14:36	0:32	LINE CLEAR AVAILED
202	13-Nov-18	BANGALURU	66	HV1	EPIP 220	15:41	15:54	0:13	LINE CLEAR AVAILED
203	13-Nov-18	BANGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE, AMARJYOTHI	10:36	10:38	0:02	LOAD CHANGEOVER
204	13-Nov-18	BANGALURU	66	HV2	HAL 220	10:40	10:45	0:05	LOAD CHANGEOVER
205	13-Nov-18	BANGALURU	66	HV1	HAL 220	11:02	11:10	0:07	LINE CLEAR AVAILED
206	13-Nov-18	BANGALURU	66	HSR LAYOUT 220 - KORMANGALA	K&C VALLY, NAL (EHT)	17:08	20:48	3:40	LINE FAULT
207	13-Nov-18	BANGALURU	66	HV1	KORMANGALA	17:08	17:22	0:13	MAIN SUPPLY FAILURE
208	13-Nov-18	BANGALURU	66	HV1	SOUTH CITY	12:47	13:48	1:00	TRANSFORMER FAULT
209	13-Nov-18	BANGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	6:25	7:08	0:43	LINE FAULT
210	13-Nov-18	BANGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	20:20	21:09	0:49	LINE FAULT
211	13-Nov-18	BANGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	20:20	20:52	0:32	MAIN SUPPLY FAILURE
212	13-Nov-18	BANGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	12:35	12:43	0:08	LINE CLEAR AVAILED
213	13-Nov-18	BANGALURU	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD	14:14	14:21	0:06	LOAD CHANGEOVER
214	13-Nov-18	BANGALURU	66	POTTERY ROAD - ITC (EHT)	ITC (EHT)	12:35	14:23	1:48	MAIN SUPPLY FAILURE
215	14-Nov-18	BANGALURU	66	HV1	AMARJYOTHI	16:12	16:19	0:07	LOAD CHANGEOVER
216	14-Nov-18	BANGALURU	66	ELECTRONIC CITY PH 2 SEC 2 - BIOCON (EHT)	BIOCON (EHT)	13:12	14:07	0:54	LINE CLEAR AVAILED
217	14-Nov-18	BANGALURU	66	GOLF LINKS - ADUGODI 2	GOLF LINKS	11:16	11:25	0:09	LOAD CHANGEOVER
218	14-Nov-18	BANGALURU	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	13:10	13:27	0:17	LOAD CHANGEOVER
219	14-Nov-18	BANGALURU	66	HV1	HOODY 220	1:34	1:56	0:22	TRANSFORMER FAULT
220	14-Nov-18	BANGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	12:15	12:26	0:11	LINE FAULT
221	14-Nov-18	BANGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	12:15	12:27	0:11	LOAD CURTAILMENT
222	14-Nov-18	BANGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	14:45	14:48	0:03	LOAD CHANGEOVER
223	14-Nov-18	BANGALURU	66	HV2	ISRO LAYOUT	11:09	11:12	0:03	TRANSFORMER FAULT
224	14-Nov-18	BANGALURU	66	HV1	KADUGODI	10:39	10:46	0:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
225	14-Nov-18	BANGALURU	66	HV1	KUMBALAGODU	14:25	15:30	1:05	LINE CLEAR AVAILED
226	14-Nov-18	BANGALURU	66	HV2	KUMBALAGODU	12:02	14:21	2:19	LINE CLEAR AVAILED
227	14-Nov-18	BANGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	0:33	0:40	0:06	LOAD CHANGEOVER
228	14-Nov-18	BANGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	6:01	6:07	0:06	LOAD CHANGEOVER
229	14-Nov-18	BANGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	11:45	12:21	0:36	MAIN SUPPLY FAILURE
230	14-Nov-18	BANGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:45	12:21	0:36	MAIN SUPPLY FAILURE
231	14-Nov-18	BANGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	11:45	12:21	0:36	MAIN SUPPLY FAILURE
232	14-Nov-18	BANGALURU	66	HV1	VIKAS TECH PARK 220	11:45	12:21	0:36	MAIN SUPPLY FAILURE
233	14-Nov-18	BANGALURU	66	HV2	VIKAS TECH PARK 220	11:45	12:21	0:36	MAIN SUPPLY FAILURE
234	14-Nov-18	BANGALURU	220	HV1	VIKAS TECH PARK 220	11:45	12:21	0:36	MAIN SUPPLY FAILURE
235	14-Nov-18	BANGALURU	220	HV2	VIKAS TECH PARK 220	11:45	12:11	0:26	MAIN SUPPLY FAILURE
236	14-Nov-18	BANGALURU	66	HV1	ALUR	18:10	18:55	0:45	TRANSFORMER FAULT
237	14-Nov-18	BANGALURU	66	HV1	ALUR	19:08	19:18	0:10	TRANSFORMER FAULT
238	14-Nov-18	BANGALURU	66	HV1	ALUR	19:38	19:50	0:12	TRANSFORMER FAULT
239	14-Nov-18	BANGALURU	66	HV1	LEELA VENTURE	15:35	15:45	0:10	LINE CLEAR AVAILED
240	14-Nov-18	BANGALURU	66	HAL 220 - ADUGODI 2	AMARJYOTHI	11:16	13:03	1:46	LINE CLEAR AVAILED
241	14-Nov-18	BANGALURU	66	HV1	AMARJYOTHI	11:16	11:35	0:18	MAIN SUPPLY FAILURE
242	14-Nov-18	BANGALURU	66	HV2	AMARJYOTHI	11:16	13:18	2:02	MAIN SUPPLY FAILURE
243	14-Nov-18	BANGALURU	66	HV1	CB PURA URBAN	13:46	14:18	0:32	LINE CLEAR AVAILED
244	14-Nov-18	BANGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	10:10	18:52	8:41	LINE CLEAR AVAILED
245	14-Nov-18	BANGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	10:11	18:38	8:27	LINE CLEAR AVAILED
246	14-Nov-18	BANGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	10:10	18:22	8:11	LINE CLEAR AVAILED
247	14-Nov-18	BANGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	10:10	18:23	8:12	LINE CLEAR AVAILED
248	14-Nov-18	BANGALURU	66	HV1	DABUSPET 220	10:10	18:34	8:23	LINE CLEAR AVAILED
249	14-Nov-18	BANGALURU	66	HV2	DABUSPET 220	10:10	18:39	8:28	LINE CLEAR AVAILED
250	14-Nov-18	BANGALURU	220	HV1	DABUSPET 220	10:10	18:36	8:25	LINE CLEAR AVAILED
251	14-Nov-18	BANGALURU	220	HV2	DABUSPET 220	10:10	18:20	8:10	LINE CLEAR AVAILED
252	14-Nov-18	BANGALURU	220	NELAMANGALA 400 - DABUSPET 220	DABUSPET 220	10:10	18:03	7:52	LINE CLEAR AVAILED
253	14-Nov-18	BANGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI, ANDERSONPET, DODDKARI	20:04	20:14	0:09	LINE FAULT
254	14-Nov-18	BANGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI, ANDERSONPET, DODDKARI	20:35	22:49	2:13	LINE FAULT
255	14-Nov-18	BANGALURU	66	KGF - BEML (EHT)	BEML (EHT)	20:35	22:49	2:13	LINE FAULT
256	14-Nov-18	BANGALURU	66	KGF - BEML (EHT)	BEML (EHT)	20:04	20:18	0:13	LINE FAULT
257	14-Nov-18	BANGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	20:04	22:44	2:39	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
258	14-Nov-18	BANGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	20:43	22:45	2:02	LINE CLEAR AVAILED
259	14-Nov-18	BANGALURU	66	HV2	KOLAR 220	15:55	16:30	0:35	LINE CLEAR AVAILED
260	14-Nov-18	BANGALURU	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	4:02	4:10	0:08	LINE FAULT
261	14-Nov-18	BANGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	15:10	15:15	0:05	LINE FAULT
262	14-Nov-18	BANGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	12:57	14:27	1:29	LOAD CURTAILMENT
263	14-Nov-18	BANGALURU	66	MALUR 220 -SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	11:45	12:11	0:26	LINE FAULT
264	14-Nov-18	BANGALURU	66	HV2	TEMAGONDALU	6:52	6:56	0:03	TRANSFORMER FAULT
265	14-Nov-18	BANGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:45	12:28	0:42	MAIN SUPPLY FAILURE
266	14-Nov-18	BANGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:45	12:20	0:34	MAIN SUPPLY FAILURE
267	14-Nov-18	BANGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:45	12:11	0:26	MAIN SUPPLY FAILURE
268	14-Nov-18	BANGALURU	220	HV1	SARJAPURA 220	11:45	12:11	0:26	MAIN SUPPLY FAILURE
269	14-Nov-18	BANGALURU	220	HV2	SARJAPURA 220	11:45	12:11	0:26	MAIN SUPPLY FAILURE
270	15-Nov-18	BANGALURU	66	ADUGODI - HAL 2	KORAMANGALA, K&C VALLEY, NAL (EHT)	9:18	10:10	0:52	LINE FAULT
271	15-Nov-18	BANGALURU	66	ADUGODI - HAL 2	KORAMANGALA, K&C VALLEY, NAL (EHT)	10:10	10:29	0:18	LINE FAULT
272	15-Nov-18	BANGALURU	66	HV1	ANJANAPURA	16:41	16:50	0:08	TRANSFORMER FAULT
273	15-Nov-18	BANGALURU	66	HV1	EPIP 220	22:29	23:05	0:35	LINE CLEAR AVAILED
274	15-Nov-18	BANGALURU	66	HV1	EPIP 220	23:31	23:59	0:27	LINE CLEAR AVAILED
275	15-Nov-18	BANGALURU	66	HV1	ANDERSONPET	16:37	17:22	0:45	LINE CLEAR AVAILED
276	15-Nov-18	BANGALURU	66	HV2	ANDERSONPET	17:14	21:03	3:49	LINE CLEAR AVAILED
277	15-Nov-18	BANGALURU	66	HV2	DODDABELAVANGALA	3:10	3:22	0:11	TRANSFORMER FAULT
278	15-Nov-18	BANGALURU	66	HV2	DODDABELAVANGALA	15:46	15:52	0:06	TRANSFORMER FAULT
279	15-Nov-18	BANGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI	7:48	7:55	0:06	LOAD CHANGEOVER
280	15-Nov-18	BANGALURU	66	HV1	KOLAR 220	13:10	14:09	0:58	LINE CLEAR AVAILED
281	15-Nov-18	BANGALURU	66	HV2	KOLAR 220	13:10	14:09	0:58	LINE CLEAR AVAILED
282	15-Nov-18	BANGALURU	66	KOLAR 220 - MULBAGAL	MULBAGAL, AVANI	4:02	4:10	0:08	LINE FAULT
283	15-Nov-18	BANGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR	11:16	11:39	0:22	LINE CLEAR AVAILED
284	15-Nov-18	BANGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	5:34	5:40	0:06	LINE FAULT
285	15-Nov-18	BANGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:45	8:47	0:02	LOAD CHANGEOVER
286	15-Nov-18	BANGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:13	10:15	0:02	LOAD CHANGEOVER
287	15-Nov-18	BANGALURU	66	HV1	YELAHANKA 220	11:08	11:15	0:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
288	15-Nov-18	BANGALURU	66	HV2	YELAHANKA 220	13:44	13:50	0:06	LINE CLEAR AVAILED
289	16-Nov-18	BANGALURU	66	HV1	HENNUR CROSS	11:15	16:30	5:15	LINE CLEAR AVAILED
290	16-Nov-18	BANGALURU	66	HV2	HENNUR CROSS	11:15	16:32	5:17	LINE CLEAR AVAILED
291	16-Nov-18	BANGALURU	66	HENNUR CROSS - SAHAKARINAGAR	HENNUR CROSS	21:05	21:08	0:03	LOAD CHANGE OVER
292	16-Nov-18	BANGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	11:17	20:43	9:25	LINE CLEAR AVAILED
293	16-Nov-18	BANGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	11:15	20:38	9:23	LINE CLEAR AVAILED
294	16-Nov-18	BANGALURU	66	VIDYANAGAR - HOSKOTE 220	VIDYANAGAR	11:17	20:00	8:42	LINE CLEAR AVAILED
295	16-Nov-18	BANGALURU	66	VIDYANAGAR - HENNUR CROSS	VIDYANAGAR	20:45	20:50	0:05	LOAD CHANGE OVER
296	16-Nov-18	BANGALURU	66	HV1	HOSKOTE 220	12:25	20:24	7:59	LINE CLEAR AVAILED
297	16-Nov-18	BANGALURU	220	HV1	HOSKOTE 220	12:26	20:24	7:58	LINE CLEAR AVAILED
298	16-Nov-18	BANGALURU	220	HV2	HOSKOTE 220	12:25	20:29	8:03	LINE CLEAR AVAILED
299	16-Nov-18	BANGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:20	20:20	9:00	LINE CLEAR AVAILED
300	16-Nov-18	BANGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	11:00	22:10	11:10	LINE CLEAR AVAILED
301	16-Nov-18	BANGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:00	22:10	11:10	LINE CLEAR AVAILED
302	16-Nov-18	BANGALURU	66	HOSKOTE 220 - BEGUR 220	HOSKOTE 220	12:27	20:08	7:41	LINE CLEAR AVAILED
303	16-Nov-18	BANGALURU	66	HV1	HULLENAHALLI	11:27	12:00	0:32	LINE CLEAR AVAILED
304	16-Nov-18	BANGALURU	66	HV1	KEMBODI	12:48	13:05	0:16	LINE CLEAR AVAILED
305	16-Nov-18	BANGALURU	66	HV1	KYALANUR	15:01	15:10	0:08	LINE CLEAR AVAILED
306	16-Nov-18	BANGALURU	66	HV2	KYALANUR	17:20	17:25	0:04	LINE CLEAR AVAILED
307	16-Nov-18	BANGALURU	66	HV1	SULIBELE	11:02	22:16	11:13	LINE CLEAR AVAILED
308	16-Nov-18	BANGALURU	66	HV2	SULIBELE	11:02	22:16	11:13	LINE CLEAR AVAILED
309	16-Nov-18	BANGALURU	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT)	15:49	15:53	0:03	LINE FAULT
310	16-Nov-18	BANGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	12:25	16:55	4:30	LINE CLEAR AVAILED
311	16-Nov-18	BANGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	20:50	21:00	0:10	LOAD CHANGE OVER
312	16-Nov-18	BANGALURU	66	HV1	BOODIGERE	8:58	9:10	0:12	TRANSFORMER FAULT
313	16-Nov-18	BANGALURU	66	HV2	CHANDRA LAYOUT	14:28	14:31	0:02	LINE CLEAR AVAILED
314	16-Nov-18	BANGALURU	66	HV1	EPIP 220	0:00	0:13	0:13	LINE CLEAR AVAILED
315	16-Nov-18	BANGALURU	66	HV2	DEVARABISANAHALLI	17:30	17:41	0:10	LINE CLEAR AVAILED
316	16-Nov-18	BANGALURU	66	HV2	DEVARABISANAHALLI	20:12	20:21	0:08	LINE CLEAR AVAILED
317	16-Nov-18	BANGALURU	66	HV2	DEVARABISANAHALLI	20:23	20:30	0:06	LINE CLEAR AVAILED
318	16-Nov-18	BANGALURU	66	HV2	DEVARABISANAHALLI	22:39	22:52	0:12	LINE CLEAR AVAILED
319	16-Nov-18	BANGALURU	66	HV1	MAHALAKSHMI LAYOUT	10:23	10:29	0:05	LINE CLEAR AVAILED
320	16-Nov-18	BANGALURU	66	HV2	MAHALAKSHMI LAYOUT	12:26	12:32	0:05	LINE CLEAR AVAILED
321	16-Nov-18	BANGALURU	66	HV2	TELECOM LAYOUT	2:10	2:16	0:06	TRANSFORMER FAULT
322	16-Nov-18	BANGALURU	66	HV1	AMARJYOTHI	16:05	16:10	0:05	LOAD CHANGE OVER
323	16-Nov-18	BANGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	11:06	11:14	0:08	LOAD CURTAILMENT
324	16-Nov-18	BANGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	11:05	23:59	12:53	LINE FAULT
325	16-Nov-18	BANGALURU	66	ADUGODI - HSR LAYOUT 2	ADUGODI, BOSCH (EHT)	11:05	15:18	4:12	LINE FAULT
326	16-Nov-18	BANGALURU	66	ADUGODI - HSR LAYOUT 1	ADUGODI, BOSCH (EHT)	11:47	11:53	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
327	16-Nov-18	BANGALURU	66	ADUGODI - HAL 2	KORMANGALA, K & C VALLEY, NAL (EHT)	11:06	11:16	0:09	LINE CLEAR AVAILED
328	16-Nov-18	BANGALURU	66	ADUGODI - HSR LAYOUT 1	ADUGODI, BOSCH (EHT)	13:03	13:08	0:05	LOAD CHANGEOVER
329	16-Nov-18	BANGALURU	66	ADUGODI - HAL 2	KORMANGALA, K & C VALLEY, NAL (EHT)	13:03	13:15	0:12	LINE CLEAR AVAILED
330	17-Nov-18	BANGALURU	66	HV2	DODDABELAVANGALA	12:05	12:11	0:06	TRANSFORMER FAULT
331	17-Nov-18	BANGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:07	10:41	0:34	LOAD CHANGEOVER
332	17-Nov-18	BANGALURU	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	9:25	9:30	0:05	LOAD CHANGEOVER
333	17-Nov-18	BANGALURU	66	HV1	JIGANI LINK ROAD	10:43	11:10	0:27	LINE CLEAR AVAILED
334	17-Nov-18	BANGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:26	21:30	0:04	LINE FAULT
335	17-Nov-18	BANGALURU	66	LAKKUR - MALUR 220	LAKKUR, DEVANGONDHI	12:20	13:30	1:10	LINE CLEAR AVAILED
336	17-Nov-18	BANGALURU	66	NELAMANGALA 66 - SRS PEENYA 220	NELAMANGALA 66	9:17	9:26	0:09	LOAD CHANGEOVER
337	17-Nov-18	BANGALURU	66	NELAMANGALA 66 - SRS PEENYA 220	NELAMANGALA 66	11:48	11:54	0:06	LOAD CHANGEOVER
338	17-Nov-18	BANGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	0:11	0:36	0:25	LINE CLEAR AVAILED
339	17-Nov-18	BANGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	0:11	0:38	0:26	LINE CLEAR AVAILED
340	17-Nov-18	BANGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	0:11	0:37	0:25	LINE CLEAR AVAILED
341	17-Nov-18	BANGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	0:11	0:38	0:26	LINE CLEAR AVAILED
342	17-Nov-18	BANGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	0:11	0:38	0:26	LINE CLEAR AVAILED
343	17-Nov-18	BANGALURU	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	0:11	0:37	0:25	LINE CLEAR AVAILED
344	17-Nov-18	BANGALURU	66	HV1	HOSKOTE 220	0:14	0:36	0:22	LINE CLEAR AVAILED
345	17-Nov-18	BANGALURU	66	HV1	HOSKOTE 220	0:15	0:36	0:21	LINE CLEAR AVAILED
346	17-Nov-18	BANGALURU	220	HV2	HOSKOTE 220	0:15	0:36	0:21	LINE CLEAR AVAILED
347	17-Nov-18	BANGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	12:33	12:36	0:02	LINE CLEAR AVAILED
348	17-Nov-18	BANGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:33	12:41	0:07	LINE CLEAR AVAILED
349	17-Nov-18	BANGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	12:25	12:40	0:15	LINE CLEAR AVAILED
350	17-Nov-18	BANGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:25	12:40	0:15	LINE CLEAR AVAILED
351	17-Nov-18	BANGALURU	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	12:25	12:39	0:14	LINE CLEAR AVAILED
352	17-Nov-18	BANGALURU	220	HV2	HOSKOTE 220	12:33	12:38	0:04	LINE CLEAR AVAILED
353	17-Nov-18	BANGALURU	66	HV1	JIGANI LINK ROAD	11:52	12:20	0:27	LINE CLEAR AVAILED
354	17-Nov-18	BANGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	12:10	12:20	0:09	LINE CLEAR AVAILED
355	17-Nov-18	BANGALURU	66	HV1	HBR LAYOUT	9:30	10:40	1:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
356	17-Nov-18	BANGALURU	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	9:25	9:34	0:08	LOAD CHANGEOVER
357	17-Nov-18	BANGALURU	66	APPAREL PARK - DB PURA 220	APPAREL PARK	10:05	10:15	0:10	LINE FAULT
358	17-Nov-18	BANGALURU	66	APPAREL PARK - DB PURA 220	APPAREL PARK	18:05	18:11	0:06	LOAD CHANGEOVER
359	17-Nov-18	BANGALURU	66	HV3	AUSTIN TOWN	11:45	12:28	0:42	LINE CLEAR AVAILED
360	17-Nov-18	BANGALURU	66	HV1	BOODIGERE	10:30	10:35	0:05	TRANSFORMER FAULT
361	17-Nov-18	BANGALURU	66	HV1	CHANDRAPPA CIRCLE	15:33	16:09	0:36	LINE CLEAR AVAILED
362	17-Nov-18	BANGALURU	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, BIJJALLI, HUNSENAHALLI, HUKUNDA	8:07	9:32	1:25	LINE CLEAR AVAILED
363	17-Nov-18	BANGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, DODDALAHALLI	10:58	13:02	2:04	LINE CLEAR AVAILED
364	17-Nov-18	BANGALURU	66	HV2	NANDINI LAYOUT	10:42	10:45	0:02	LINE CLEAR AVAILED
365	17-Nov-18	BANGALURU	66	HV1	NGEF	10:01	16:28	6:27	LINE CLEAR AVAILED
366	17-Nov-18	BANGALURU	66	HV2	NGEF	9:59	16:27	6:28	LINE CLEAR AVAILED
367	17-Nov-18	BANGALURU	66	SRS PEENYA 220 - DG 2	ALUR	9:17	9:26	0:08	LINE CLEAR AVAILED
368	17-Nov-18	BANGALURU	66	ALUR - NELAMANGALA 66	ALUR	11:46	11:51	0:05	LOAD CHANGEOVER
369	17-Nov-18	BANGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	11:37	11:47	0:09	LOAD CHANGEOVER
370	17-Nov-18	BANGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI	14:40	14:46	0:06	LOAD CHANGEOVER
371	18-Nov-18	BANGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	13:35	13:37	0:02	LOAD CHANGEOVER
372	18-Nov-18	BANGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:35	13:38	0:03	LOAD CHANGEOVER
373	18-Nov-18	BANGALURU	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE	13:45	13:55	0:10	LOAD CHANGEOVER
374	18-Nov-18	BANGALURU	66	KGF - KYASAMBALLI	ANDERSONPET, KYASAMBALLI, DODDAKARI	5:29	5:39	0:09	LINE FAULT
375	18-Nov-18	BANGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	5:56	6:05	0:08	LINE FAULT
376	18-Nov-18	BANGALURU	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	11:26	11:46	0:19	LINE CLEAR AVAILED
377	18-Nov-18	BANGALURU	66	CHANDRA LAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	16:04	16:08	0:04	LOAD CHANGEOVER
378	18-Nov-18	BANGALURU	66	CHANDRA LAYOUT - NRS 2	CHANDRA LAYOUT	20:31	20:35	0:04	LOAD CHANGEOVER
379	18-Nov-18	BANGALURU	66	HV2	C STATION	11:20	11:24	0:04	LOAD CHANGEOVER
380	18-Nov-18	BANGALURU	66	HV2	C STATION	14:08	14:10	0:02	LOAD CHANGEOVER
381	18-Nov-18	BANGALURU	66	IISC - HEBBAL 220	IISC	12:55	13:01	0:06	LOAD CHANGEOVER
382	18-Nov-18	BANGALURU	66	IISC - NRS 220	IISC	15:09	15:12	0:03	LOAD CHANGEOVER
383	18-Nov-18	BANGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	0:01	0:17	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
384	18-Nov-18	BANGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	10:55	16:46	5:51	LINE CLEAR AVAILED
385	18-Nov-18	BANGALURU	66	HV2	VIJAYANAGARA	10:41	12:30	1:48	LINE CLEAR AVAILED
386	18-Nov-18	BANGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	6:30	6:48	0:18	LINE FAULT
387	18-Nov-18	BANGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI, DODDALAHALLI	9:50	10:05	0:15	LOAD CHANGEOVER
388	18-Nov-18	BANGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	7:05	7:08	0:03	LOAD CHANGEOVER
389	18-Nov-18	BANGALURU	66	WELCAST STEEL - ABBIGERE	WELCAST STEEL	10:45	10:48	0:03	LOAD CHANGEOVER
390	18-Nov-18	BANGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HAROBEL, HUKUNDA, BIJJALLI, KODIHALLI, HUNSENAHALLI	3:01	3:18	0:17	LINE FAULT
391	18-Nov-18	BANGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HAROBEL, HUKUNDA, BIJJALLI, KODIHALLI, HUNSENAHALLI	14:39	15:14	0:35	LINE FAULT
392	18-Nov-18	BANGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HAROBEL, HUKUNDA, BIJJALLI, KODIHALLI, HUNSENAHALLI	16:09	16:17	0:08	LINE CLEAR AVAILED
393	18-Nov-18	BANGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HAROBEL, HUKUNDA, BIJJALLI, KODIHALLI, HUNSENAHALLI	16:45	17:58	1:12	LINE CLEAR AVAILED
394	18-Nov-18	BANGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	14:39	15:16	0:37	LINE FAULT
395	18-Nov-18	BANGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:27	10:37	0:10	LOAD CHANGEOVER
396	18-Nov-18	BANGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	10:55	11:05	0:10	LOAD CHANGEOVER
397	18-Nov-18	BANGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	11:55	12:08	0:13	LOAD CHANGEOVER
398	18-Nov-18	BANGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	15:05	15:15	0:10	LOAD CHANGEOVER
399	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	11:35	11:38	0:03	LOAD CHANGEOVER
400	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	15:24	15:27	0:03	LOAD CHANGEOVER
401	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	15:24	15:27	0:03	LOAD CHANGEOVER
402	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	15:24	15:27	0:03	LOAD CHANGEOVER
403	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	15:24	15:27	0:03	LOAD CHANGEOVER
404	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	19:00	19:10	0:10	LOAD CHANGEOVER
405	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	19:00	19:10	0:10	LOAD CHANGEOVER
406	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:00	19:10	0:10	LOAD CHANGEOVER
407	19-Nov-18	BANGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	19:00	19:10	0:10	LOAD CHANGEOVER
408	19-Nov-18	BANGALURU	66	HV2	KIADB DB PURA 220	7:25	7:49	0:24	TRANSFORMER FAULT
409	19-Nov-18	BANGALURU	66	SRINIVASPURA - KOLAR 220	SRINIVASPURA	17:35	17:40	0:05	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
410	19-Nov-18	BANGALURU	66	HV1	TELECOM LAYOUT	14:43	14:51	0:08	TRANSFORMER FAULT
411	19-Nov-18	BANGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	6:22	6:38	0:16	LINE FAULT
412	19-Nov-18	BANGALURU	66	HV2	NELEKADIRENAHALLI	18:18	18:55	0:36	TRANSFORMER FAULT
413	19-Nov-18	BANGALURU	66	HV1	LEELA VENTURE	14:24	14:51	0:27	LINE CLEAR AVAILED
414	19-Nov-18	BANGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, BIJJALLI, HUNSENAHALLI, HAROBELE	9:27	9:42	0:15	LINE FAULT
415	19-Nov-18	BANGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, BIJJALLI, HUNSENAHALLI, HAROBELE	14:18	14:22	0:04	LINE CLEAR AVAILED
416	19-Nov-18	BANGALURU	66	HOODY 220 - ITI	ITI	11:45	12:20	0:35	LOAD CHANGEOVER
417	19-Nov-18	BANGALURU	66	HOODY 220 - ITI	ITI	16:49	17:18	0:29	LOAD CHANGEOVER
418	19-Nov-18	BANGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:45	12:20	0:35	LOAD CHANGEOVER
419	19-Nov-18	BANGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	16:49	17:23	0:34	LOAD CHANGEOVER
420	19-Nov-18	BANGALURU	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	11:45	12:20	0:35	LOAD CHANGEOVER
421	19-Nov-18	BANGALURU	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	16:49	17:19	0:30	LOAD CHANGEOVER
422	19-Nov-18	BANGALURU	66	HV2	HOODY 220	11:45	12:20	0:35	LOAD CHANGEOVER
423	19-Nov-18	BANGALURU	66	HV2	HOODY 220	16:49	17:20	0:31	LOAD CHANGEOVER
424	19-Nov-18	BANGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	14:45	15:20	0:35	LINE FAULT
425	19-Nov-18	BANGALURU	66	HV3	ADUGODI	12:17	12:25	0:08	LOAD CHANGEOVER
426	19-Nov-18	BANGALURU	66	HV1	HEBBAL 220	12:19	12:23	0:04	LINE CLEAR AVAILED
427	19-Nov-18	BANGALURU	66	HV1	EPIP 220	1:46	2:09	0:23	TRANSFORMER FAULT
428	13-Nov-18	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	11:03	17:38	6:35	LINE CLEAR AVAILED
429	13-Nov-18	GULBARGA	110	HV1	MASKI_110	12:13	13:29	1:16	LINE CLEAR AVAILED
430	13-Nov-18	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	18:07	18:23	0:16	LINE FAULT
431	13-Nov-18	GULBARGA	110	HV1	BETAGERA_110	10:10	10:40	0:30	LINE CLEAR AVAILED
432	13-Nov-18	GULBARGA	66	ITTAGI-HADAGALLI-2	HIREHADAGALI_66,GIRIYAPURA_66, SOVENAHALLI_66,MAGALA_66,TUN GABHADRA_IPP	13:58	15:46	1:48	LINE CLEAR AVAILED
433	13-Nov-18	GULBARGA	66	MUNIRABAD-MSD LINE	HANASI_66	8:19	18:41	10:22	LINE CLEAR AVAILED
434	14-Nov-18	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	9:47	23:59	14:12	NBFC ISSUED
435	14-Nov-18	GULBARGA	110	BANAVEKAL-SLRYS	BANAVEKAL_110	11:00	11:55	0:55	LINE CLEAR AVAILED
436	14-Nov-18	GULBARGA	110	BANAVEKAL-SLRYS	BANAVEKAL_110	12:50	13:15	0:25	LINE CLEAR AVAILED
437	14-Nov-18	GULBARGA	110	HATTI-GMSH	HATTI_110	11:38	15:05	3:27	LINE CLEAR AVAILED
438	14-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	6:49	7:00	0:11	LINE FAULT
439	14-Nov-18	GULBARGA	110	PDHALLI-CLNSLR	PDHALLI_110	11:50	11:54	0:04	LINE CLEAR AVAILED
440	14-Nov-18	GULBARGA	110	PDHALLI-CLNSLR	PDHALLI_110	12:59	13:17	0:18	LINE CLEAR AVAILED
441	14-Nov-18	GULBARGA	110	HV2	KUSTAGI_220	14:15	14:52	0:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
442	14-Nov-18	GULBARGA	110	SIRIGUPPA-TEKKALKOTE	TEKKALAKOTE_110,DHADESUGUR_110	10:25	17:11	6:46	LINE CLEAR AVAIED
443	14-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_110,SIRWAR_110,BYAGAWAT_110,VALKAMDINNI_110	12:10	13:36	1:26	LINE CLEAR AVAIED
444	14-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_110,SIRWAR_110,BYAGAWAT_110,VALKAMDINNI_110	19:15	19:20	0:05	LINE FAULT
445	14-Nov-18	GULBARGA	110	HV1	BYAGAWAT_110	18:05	18:26	0:21	LINE CLEAR AVAIED
446	14-Nov-18	GULBARGA	66	HV1	HANASI_66	10:48	11:24	0:36	LINE CLEAR AVAIED
447	14-Nov-18	GULBARGA	66	ITTAGI-HADAGALLI-2	HIREHADAGALI_66,GIRIYAPURA_66,SOVENAHALLI_66,MAGALA_66,TUNGABHADRA_IPP	6:11	6:17	0:06	LINE FAULT
448	15-Nov-18	GULBARGA	220	BMMISPAT-LINGAPUR	LINGAPUR_220	13:50	16:30	2:40	LINE CLEAR AVAIED
449	15-Nov-18	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	0:00	17:18	17:18	NBFC ISSUED
450	15-Nov-18	GULBARGA	110	HV1	ALIPUR_220	8:14	9:27	1:13	LINE CLEAR AVAIED
451	15-Nov-18	GULBARGA	110	HV1	ALIPUR_220	9:27	9:33	0:06	TRANSFORMER FAULT
452	15-Nov-18	GULBARGA	110	HV1	HANUMANAL_110	7:40	9:10	1:30	LINE CLEAR AVAIED
453	15-Nov-18	GULBARGA	110	HV3	HANUMASAGAR_110	11:20	12:18	0:58	LINE CLEAR AVAIED
454	15-Nov-18	GULBARGA	110	HV2	KAMPLI_GLB_110	16:27	16:32	0:05	TRANSFORMER FAULT
455	15-Nov-18	GULBARGA	110	HV1	KURKUNTA_110	13:15	13:35	0:20	LINE CLEAR AVAIED
456	15-Nov-18	GULBARGA	110	SINDHANOOR-PGLR_WIND	SIDHANOOR_220	20:33	20:51	0:18	LINE FAULT
457	15-Nov-18	GULBARGA	110	SINDHANOOR-PGLR_WIND	SIDHANOOR_220	23:00	23:59	0:55	LINE CLEAR AVAIED
458	15-Nov-18	GULBARGA	110	HALBARGA-ACMVSLR	HALBURGA_220	18:47	19:04	0:17	LINE FAULT
459	15-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	8:23	16:19	7:56	LINE CLEAR AVAIED
460	16-Nov-18	GULBARGA	110	HV2	HANUMANAL_110	8:20	9:40	1:20	LINE CLEAR AVAIED
461	16-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_WATER_WORKS	12:46	12:57	0:11	LINE FAULT
462	16-Nov-18	GULBARGA	110	HV2	YELBURGA_110	12:26	12:35	0:09	TRANSFORMER FAULT
463	16-Nov-18	GULBARGA	110	SINDHANOOR220-PGLR_WIND	SIDHANOOR_220	0:00	0:11	0:11	LINE CLEAR AVAIED
464	16-Nov-18	GULBARGA	110	HV3	BEVOOR_110	11:41	12:09	0:28	LINE CLEAR AVAIED
465	16-Nov-18	GULBARGA	66	HV1	CHORNOOR_66	7:26	7:34	0:08	TRANSFORMER FAULT
466	17-Nov-18	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	18:57	19:10	0:13	LINE FAULT
467	17-Nov-18	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRERAMANAGAR_110,VENKATAGIRI_110,GANGAVATHI_110	10:50	13:43	2:53	LINE CLEAR AVAIED
468	17-Nov-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	10:50	12:36	1:46	LINE CLEAR AVAIED
469	17-Nov-18	GULBARGA	110	SINDHANOOR-PGLR_WIND	SIDHANOOR_220	11:25	13:20	1:55	LINE CLEAR AVAIED
470	17-Nov-18	GULBARGA	110	HV1	MASKI_110	11:26	12:14	0:48	LINE CLEAR AVAIED
471	17-Nov-18	GULBARGA	110	LINGASUGUR-LATUR_WIND	LINGASUGUR_220	12:30	15:07	2:37	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
472	17-Nov-18	GULBARGA	110	HV1	KURKUNTA_110	10:40	10:55	0:15	TRANSFORMER FAULT
473	17-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:23	12:00	0:37	LINE FAULT
474	17-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	15:14	15:22	0:08	LINE FAULT
475	17-Nov-18	GULBARGA	110	HV2	BETAGERA_110	11:58	12:05	0:07	TRANSFORMER FAULT
476	17-Nov-18	GULBARGA	110	MASKI-HATTI	HATTI_110	19:10	23:59	4:49	LINE FAULT
477	17-Nov-18	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	21:15	21:39	0:24	LINE FAULT
478	18-Nov-18	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	0:52	1:09	0:17	LINE FAULT
479	18-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:55	11:45	0:50	LINE FAULT
480	18-Nov-18	GULBARGA	110	MASKI-HATTI	HATTI_110	0:00	11:34	11:34	LINE FAULT
481	18-Nov-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPSWATER WORKS,MUKUNDA_110,KAMPLI_110	5:47	5:57	0:10	LINE FAULT
482	18-Nov-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPSWATER WORKS,MUKUNDA_110,KAMPLI_110	18:56	19:03	0:07	LINE FAULT
483	18-Nov-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPSWATER WORKS,MUKUNDA_110,KAMPLI_110	20:46	21:34	0:48	LINE FAULT
484	18-Nov-18	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	11:15	11:20	0:05	LINE FAULT
485	18-Nov-18	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	12:45	12:50	0:05	LINE FAULT
486	18-Nov-18	GULBARGA	66	HV1	TAMBRAHALLI_66	23:20	23:59	0:39	LINE CLEAR AVAILED
487	18-Nov-18	GULBARGA	66	HV2	TAMBRAHALLI_66	23:20	23:59	0:39	TRANSFORMER FAULT
488	18-Nov-18	GULBARGA	66	HV1	TAMBRAHALLI_66	0:00	0:15	0:15	LINE CLEAR AVAILED
489	19-Nov-18	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	2:38	23:59	21:21	LINE FAULT
490	19-Nov-18	GULBARGA	220	HV1	HALBURGA_220	2:19	2:44	0:25	TRANSFORMER FAULT
491	19-Nov-18	GULBARGA	220	HV2	HALBURGA_220	2:19	2:44	0:25	TRANSFORMER FAULT
492	19-Nov-18	GULBARGA	220	HV1	ITTAGI_220	9:15	10:40	1:25	LINE CLEAR AVAILED
493	19-Nov-18	GULBARGA	220	HV2	ITTAGI_220	10:45	11:20	0:35	LINE CLEAR AVAILED
494	19-Nov-18	GULBARGA	220	HV1	MALLAT_220	11:58	12:20	0:22	LINE CLEAR AVAILED
495	19-Nov-18	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	22:49	23:17	0:28	LINE FAULT
496	19-Nov-18	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	10:27	23:59	13:32	NBFC ISSUED
497	19-Nov-18	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	22:49	23:59	1:10	LINE FAULT
498	19-Nov-18	GULBARGA	110	HV2	BETAGERA_110	4:07	4:13	0:06	TRANSFORMER FAULT
499	19-Nov-18	GULBARGA	110	HALBARGA-CHIDRI1	HABSIKOTE_110,KAMTHANA_110	2:54	3:02	0:08	LINE FAULT
500	19-Nov-18	GULBARGA	110	HATTI-SOMANAMARDI	HATTI_110	3:06	3:18	0:12	LINE FAULT
501	19-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MARGUTTI_110,MAHAGOAN_110	1:07	1:15	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
502	19-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MARGUTTI_110,MAHAGOAN_110	11:20	11:55	0:35	LINE FAULT
503	19-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MARGUTTI_110,MAHAGOAN_110	9:59	10:06	0:07	LINE FAULT
504	19-Nov-18	GULBARGA	110	BHALKI-HALBURGA	BHALKI_110	2:10	2:55	0:45	LINE FAULT
505	19-Nov-18	GULBARGA	110	HALBURGA-KOLHAR1	KOLHAR_110,JANAWADA_110,NSSK_SUGAR_FACTORY	16:30	16:59	0:29	LINE CLEAR AVAILED
506	19-Nov-18	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110	23:33	23:40	0:07	LINE FAULT
507	19-Nov-18	GULBARGA	66	ITTAGGI-TBHALLI	HAMPASAGAR_66,MORAGERE_66,TAMBRAHALLI_66	11:15	11:30	0:15	LINE CLEAR AVAILED
508	19-Nov-18	GULBARGA	66	ITTAGGI-RNWSLR1,2	ITTAGI_220	10:44	11:20	0:36	LINE CLEAR AVAILED
509	19-Nov-18	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJANI_66,BENNEHALLI_66	9:25	23:59	14:34	LINE CLEAR AVAILED
510	13-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	6:12	6:38	0:26	LINE FAULT
511	13-Nov-18	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:08	12:47	0:39	LINE FAULT
512	13-Nov-18	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:08	12:46	0:38	LINE FAULT
513	13-Nov-18	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	14:15	16:35	2:20	LINE CLEAR AVAILED
514	13-Nov-18	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	21:36	22:05	0:29	LINE FAULT
515	13-Nov-18	HASSAN	110	HV1	ARASIKERE_110	12:03	12:35	0:32	HAND TRIPPED
516	13-Nov-18	HASSAN	110	HV1	HALADY_110	11:44	12:39	0:55	LINE CLEAR AVAILED
517	13-Nov-18	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	10:51	12:30	1:39	LINE CLEAR AVAILED
518	13-Nov-18	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	9:18	17:01	7:43	LINE CLEAR AVAILED
519	13-Nov-18	HASSAN	66	HV2	ARAKALGUD_66	12:43	13:14	0:31	LINE CLEAR AVAILED
520	13-Nov-18	HASSAN	66	HV2	BELUR_66	10:06	10:14	0:08	TRANSFORMER FAULT
521	13-Nov-18	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	11:25	12:00	0:35	LINE FAULT
522	13-Nov-18	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	18:31	23:59	5:28	LINE CLEAR AVAILED
523	13-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	7:56	8:11	0:15	LINE CLEAR AVAILED
524	13-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	13:57	14:08	0:11	LINE CLEAR AVAILED
525	13-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	14:30	14:35	0:05	LINE CLEAR AVAILED
526	13-Nov-18	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	8:23	9:36	1:13	NBFC ISSUED
527	13-Nov-18	HASSAN	66	HV1	DODDAKADANUR_66	8:23	9:37	1:14	TRANSFORMER FAULT
528	13-Nov-18	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	9:17	9:37	0:20	HAND TRIPPED
529	13-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	11:26	12:07	0:41	LINE FAULT
530	13-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	18:52	23:59	5:07	LINE CLEAR AVAILED
531	13-Nov-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	18:52	23:59	5:07	LINE CLEAR AVAILED
532	13-Nov-18	HASSAN	66	HV1	HARIHARAPURA_66	12:10	12:34	0:24	LOAD CURTAILMENT
533	13-Nov-18	HASSAN	66	HNPR2MYSOR1	HOLENARASIPURA_220	8:45	9:40	0:55	LINE CLEAR AVAILED
534	13-Nov-18	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	8:45	9:40	0:55	LINE CLEAR AVAILED
535	13-Nov-18	HASSAN	66	HV2	HNPURA_66	15:46	17:38	1:52	LINE CLEAR AVAILED
536	13-Nov-18	HASSAN	66	HNPURA-MYSORE1	HNPURA_66	7:19	17:38	10:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
537	13-Nov-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	7:19	7:21	0:02	LINE FAULT
538	14-Nov-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	4:00	10:11	6:11	NBFC ISSUED
539	14-Nov-18	HASSAN	220	KADUR-DABUSET	KADUR_220	9:59	18:08	8:09	LINE CLEAR AVAILED
540	14-Nov-18	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	9:34	14:01	4:27	LINE CLEAR AVAILED
541	14-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	mrsmg_220	10:14	13:10	2:56	LINE CLEAR AVAILED
542	14-Nov-18	HASSAN	220	MRSSHM-VARAH1	mrsmg_220	1:36	9:47	8:11	LINE FAULT
543	14-Nov-18	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	1:36	9:54	8:18	LINE FAULT
544	14-Nov-18	HASSAN	220	KEMAR-KAVOOR3	KEMAR_220	9:32	13:20	3:48	NBFC ISSUED
545	14-Nov-18	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:33	11:14	0:41	LINE CLEAR AVAILED
546	14-Nov-18	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:24	11:12	0:48	LINE CLEAR AVAILED
547	14-Nov-18	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:23	11:12	0:49	NBFC ISSUED
548	14-Nov-18	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	0:00	0:58	0:58	LINE CLEAR AVAILED
549	14-Nov-18	HASSAN	66	HV1	CHIKMAGALUR_66	11:19	11:34	0:15	HAND TRIPPED
550	14-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	0:00	0:58	0:58	LINE CLEAR AVAILED
551	14-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	13:20	13:25	0:05	LOAD CURTAILMENT
552	14-Nov-18	HASSAN	66	HV1	GENDEHALLY_66	13:20	13:25	0:05	LOAD CURTAILMENT
553	14-Nov-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	0:00	0:59	0:59	LINE CLEAR AVAILED
554	14-Nov-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	13:20	13:25	0:05	LOAD CURTAILMENT
555	14-Nov-18	HASSAN	66	GORUR-HASSAN	GORUR_66	12:19	12:31	0:12	LOAD CURTAILMENT
556	14-Nov-18	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	11:40	12:07	0:27	LINE CLEAR AVAILED
557	14-Nov-18	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	12:10	12:32	0:22	LINE CLEAR AVAILED
558	14-Nov-18	HASSAN	66	HASSN220-BELUR	HASSAN_220	13:23	13:34	0:11	LINE CLEAR AVAILED
559	14-Nov-18	HASSAN	66	HASSN220-CRP2	HASSAN_220	13:11	13:22	0:11	LINE CLEAR AVAILED
560	14-Nov-18	HASSAN	66	HASSN220-HASSAN	HASSAN_220	13:34	13:51	0:17	LINE CLEAR AVAILED
561	14-Nov-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:47	11:52	1:05	LINE FAULT
562	15-Nov-18	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	9:32	17:31	7:59	LINE CLEAR AVAILED
563	15-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	10:43	23:59	13:16	LINE CLEAR AVAILED
564	15-Nov-18	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:32	17:30	7:58	NBFC ISSUED
565	15-Nov-18	HASSAN	110	JOG-NK2	mghe_gen	10:35	19:07	8:32	LINE CLEAR AVAILED
566	15-Nov-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:17	18:47	8:30	LINE CLEAR AVAILED
567	15-Nov-18	HASSAN	66	MRSSHM-BD-1	MRSMG_220	8:37	23:59	15:22	LINE CLEAR AVAILED
568	15-Nov-18	HASSAN	66	HV3	BALEHONNUR_66	9:24	10:21	0:57	LINE CLEAR AVAILED
569	15-Nov-18	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	8:29	23:59	15:30	NBFC ISSUED
570	15-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	8:52	8:57	0:05	HAND TRIPPED
571	15-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	11:30	11:34	0:04	HAND TRIPPED
572	15-Nov-18	HASSAN	66	HV2	SATHENAHALLI_66	10:27	10:38	0:11	TRANSFORMER FAULT
573	16-Nov-18	HASSAN	400	TALAGU-NELAMANG2	TALAGUPPA_400	10:52	17:16	6:24	LINE CLEAR AVAILED
574	16-Nov-18	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	11:25	17:03	5:38	LINE FAULT
575	16-Nov-18	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	11:26	17:02	5:36	LINE FAULT
576	16-Nov-18	HASSAN	220	HV1	GOPALPURA_220	12:12	14:15	2:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
577	16-Nov-18	HASSAN	220	HV2	GOPALPURA_220	14:38	16:46	2:08	LINE CLEAR AVAILED
578	16-Nov-18	HASSAN	110	HV1	MRSMSG_220	10:01	13:36	3:35	LINE CLEAR AVAILED
579	16-Nov-18	HASSAN	66	HV2	BELUR_66	7:44	7:55	0:11	TRANSFORMER FAULT
580	16-Nov-18	HASSAN	66	HV1	CHIKMAGALUR_66	12:38	18:38	6:00	LINE CLEAR AVAILED
581	16-Nov-18	HASSAN	66	LV1	MRSMSG_220	10:01	13:37	3:36	LINE CLEAR AVAILED
582	16-Nov-18	HASSAN	66	HV1	SIGEBAGE_66	12:47	13:17	0:30	LINE CLEAR AVAILED
583	16-Nov-18	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	0:00	18:07	18:07	LINE CLEAR AVAILED
584	16-Nov-18	HASSAN	66	HV1	SATHENAHALLI_66	17:28	18:20	0:52	LINE CLEAR AVAILED
585	17-Nov-18	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	0:47	0:56	0:09	LINE FAULT
586	17-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	0:00	16:43	16:43	LINE CLEAR AVAILED
587	17-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	17:24	23:59	6:35	NBFC ISSUED
588	17-Nov-18	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:32	16:51	7:19	NBFC ISSUED
589	17-Nov-18	HASSAN	110	KADUR-AJAMPURA	KADUR_220	13:02	13:30	0:28	LINE FAULT
590	17-Nov-18	HASSAN	66	HV2	BELUR_66	18:42	18:59	0:17	TRANSFORMER FAULT
591	17-Nov-18	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	0:00	9:49	9:49	NBFC ISSUED
592	17-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	14:40	15:00	0:20	HAND TRIPPED
593	17-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	16:50	16:52	0:02	HAND TRIPPED
594	17-Nov-18	HASSAN	66	SAKALE-HANBAL	SAKALESHAPURA_66	21:46	21:58	0:12	LINE FAULT
595	17-Nov-18	HASSAN	66	HV1	MALLAPURA_66	18:05	18:18	0:13	HAND TRIPPED
596	18-Nov-18	HASSAN	220	KEMAR-Varahi3	KEMAR_220	19:47	23:59	4:12	LINE FAULT
597	18-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	0:00	20:23	20:23	NBFC ISSUED
598	18-Nov-18	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	21:00	23:59	2:59	LINE FAULT
599	18-Nov-18	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	9:50	19:12	9:22	LINE CLEAR AVAILED
600	18-Nov-18	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:50	19:12	9:22	LINE CLEAR AVAILED
601	18-Nov-18	HASSAN	220	VARAHI-KEMAR3	varahi_gen	19:46	23:59	4:13	LINE FAULT
602	18-Nov-18	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	19:46	20:01	0:15	LINE FAULT
603	18-Nov-18	HASSAN	110	HV2	NAVUNDA_110	19:46	20:03	0:17	TRANSFORMER FAULT
604	18-Nov-18	HASSAN	110	SAGARA-ALKLA	SAGARA_110	15:30	15:50	0:20	LINE FAULT
605	18-Nov-18	HASSAN	110	SAGARA-ALKLA	SAGARA_110	16:40	18:09	1:29	HAND TRIPPED
606	18-Nov-18	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	17:50	23:59	6:09	LINE FAULT
607	18-Nov-18	HASSAN	110	SORABA-SHR220	SORABA_110	17:50	23:59	6:09	LOAD CURTAILMENT
608	18-Nov-18	HASSAN	66	HASSN22-MALLALI	HASSAN_220	22:56	23:05	0:09	LINE FAULT
609	19-Nov-18	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	18:23	20:42	2:19	LINE FAULT
610	19-Nov-18	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	0:00	8:30	8:30	LINE FAULT
611	19-Nov-18	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:10	17:38	2:28	NBFC ISSUED
612	19-Nov-18	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	18:22	20:41	2:19	LINE FAULT
613	19-Nov-18	HASSAN	110	HV2	MRSMSG_220	11:10	17:04	5:54	LINE CLEAR AVAILED
614	19-Nov-18	HASSAN	110	MSEZ-SORAB	SHIRALKOPPA_220	0:00	14:44	14:44	LINE FAULT
615	19-Nov-18	HASSAN	110	HV2	SORABA_110	7:57	8:45	0:48	TRANSFORMER FAULT
616	19-Nov-18	HASSAN	110	HV2	VITLA_110	18:33	18:45	0:12	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
617	19-Nov-18	HASSAN	66	LV2	MRSMSG_220	11:09	17:04	5:55	LINE CLEAR AVAILED
618	19-Nov-18	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:25	10:31	0:06	HAND TRIPPED
619	19-Nov-18	HASSAN	66	HV1	MAGGE_66	0:34	0:56	0:22	TRANSFORMER FAULT
620	13-Nov-18	MYSORE	66	HV1	AKKIHEBBAL_66	12:10	12:33	0:22	LINE CLEAR AVAILED
621	13-Nov-18	MYSORE	66	ATTIGULIPURA-HONNALLY	ATTIGULIPURA_66	13:09	13:15	0:05	LINE CLEAR AVAILED
622	13-Nov-18	MYSORE	66	HV1	DODDABYADARAHALLI_66	10:40	12:33	1:52	LINE CLEAR AVAILED
623	13-Nov-18	MYSORE	66	HV1	DUNDANAHALLI_66	15:25	17:16	1:51	LINE CLEAR AVAILED
624	13-Nov-18	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	7:58	18:19	10:21	LINE CLEAR AVAILED
625	13-Nov-18	MYSORE	66	HV2	PERIYAPATNA_66	9:48	9:55	0:07	TRANSFORMER FAULT
626	14-Nov-18	MYSORE	66	HV2	BOMMALAPURA_66	12:59	13:18	0:18	LINE CLEAR AVAILED
627	14-Nov-18	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	18:02	18:10	0:08	LINE FAULT
628	14-Nov-18	MYSORE	66	HV1	HULLAHALLI_66	11:15	13:31	2:16	LINE CLEAR AVAILED
629	14-Nov-18	MYSORE	66	HV2	HULLAHALLI_66	12:30	14:05	1:35	LINE CLEAR AVAILED
630	14-Nov-18	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	12:09	12:16	0:06	LINE FAULT
631	14-Nov-18	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	12:02	12:14	0:11	LINE FAULT
632	14-Nov-18	MYSORE	66	KADAKOLA-SARGUR 1	HURA_66, HULLAHALLI_66, DOORA_66 JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	12:23	12:59	0:35	LINE FAULT
633	14-Nov-18	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	12:23	12:59	0:35	LINE FAULT
634	14-Nov-18	MYSORE	66	HV2	SANTHESARAGUR_66	12:25	23:59	11:34	TRANSFORMER FAULT
635	14-Nov-18	MYSORE	66	HV1	SANTHESARAGUR_66	12:30	13:19	0:49	HAND TRIPPED
636	14-Nov-18	MYSORE	66	HV1	KHBCOLONY_66	12:55	13:47	0:51	LINE CLEAR AVAILED
637	14-Nov-18	MYSORE	66	HV1	K_HONNALGERE_66	2:55	13:21	10:25	TRANSFORMER FAULT
638	14-Nov-18	MYSORE	66	HV1	KIKKERI_66	16:57	17:31	0:33	LINE CLEAR AVAILED
639	14-Nov-18	MYSORE	66	HV2	KIKKERI_66	15:31	16:01	0:30	LINE CLEAR AVAILED
640	14-Nov-18	MYSORE	66	HV2	KIKKERI_66	17:00	17:31	0:30	LINE CLEAR AVAILED
641	14-Nov-18	MYSORE	66	HV2	KRPET_66	16:55	17:24	0:29	LINE CLEAR AVAILED
642	14-Nov-18	MYSORE	66	HV2	KRPET_66	17:32	17:49	0:16	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
643	14-Nov-18	MYSORE	66	HV1	KUSHALNAGARA_220	13:00	13:20	0:19	LINE CLEAR AVAILED
644	14-Nov-18	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	18:01	18:07	0:06	LINE FAULT
645	14-Nov-18	MYSORE	66	HV1	MADIKERI_66	12:09	13:06	0:56	LINE CLEAR AVAILED
646	14-Nov-18	MYSORE	66	HV1	RAVANDUR_66	15:20	16:16	0:55	LINE CLEAR AVAILED
647	14-Nov-18	MYSORE	66	HV1	TUBINAKERE_220	13:10	16:15	3:05	LINE CLEAR AVAILED
648	14-Nov-18	MYSORE	66	HV2	TUBINAKERE_220	11:16	12:51	1:34	LINE CLEAR AVAILED
649	15-Nov-18	MYSORE	66	HV2	BOGADHI_66	13:54	15:58	2:03	LINE CLEAR AVAILED
650	15-Nov-18	MYSORE	66	HV1	DEVANOORNGUDU_66	17:25	19:47	2:22	LINE CLEAR AVAILED
651	15-Nov-18	MYSORE	66	HV1	HARVEY_66	12:16	13:55	1:39	LINE CLEAR AVAILED
652	15-Nov-18	MYSORE	66	HV2	HARVEY_66	13:58	15:24	1:26	LINE CLEAR AVAILED
653	15-Nov-18	MYSORE	66	HV1	KIADBMANDYA_66	12:37	13:30	0:53	LINE CLEAR AVAILED
654	15-Nov-18	MYSORE	66	HV2	KIADBMANDYA_66	12:38	13:31	0:53	LINE CLEAR AVAILED
655	15-Nov-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	22:40	22:45	0:05	LINE FAULT
656	15-Nov-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	0:12	0:22	0:10	LINE FAULT
657	15-Nov-18	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	2:14	2:30	0:16	LINE FAULT
658	16-Nov-18	MYSORE	66	HV1	DEVANOORNGUDU_66	12:40	13:43	1:03	LINE CLEAR AVAILED
659	16-Nov-18	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	7:58	18:50	10:51	LINE CLEAR AVAILED
660	16-Nov-18	MYSORE	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	10:57	16:49	5:52	LINE CLEAR AVAILED
661	16-Nov-18	MYSORE	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	10:57	16:50	5:53	LINE CLEAR AVAILED
662	16-Nov-18	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 BASARALU_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66	11:37	11:44	0:07	LINE FAULT
663	16-Nov-18	MYSORE	66	TUBINAKERE-NAGAMAGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	0:03	0:14	0:10	LINE FAULT
664	17-Nov-18	MYSORE	66	HV1	KIADBMANDYA_66	9:53	11:23	1:30	LINE CLEAR AVAILED
665	17-Nov-18	MYSORE	66	HV2	PONNAMPET_66	2:01	2:06	0:05	TRANSFORMER FAULT
666	17-Nov-18	MYSORE	66	HV2	PONNAMPET_66	7:47	7:52	0:05	TRANSFORMER FAULT
667	17-Nov-18	MYSORE	66	HV2	SANTHESARAGUR_66	16:15	16:49	0:33	LINE CLEAR AVAILED
668	18-Nov-18	MYSORE	66	HV2	KALAMANDIR_66	12:04	12:06	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
669	18-Nov-18	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 MADDUR_66 KIADBMANDYA_66 KOLKARANADODDI_66	3:00	3:13	0:13	LINE FAULT
670	18-Nov-18	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	4:29	6:50	2:20	NBFC ISSUED
671	18-Nov-18	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 BILIKERE_66 GVGUDI_66 KRNAGARA_66 BHERYA_66	13:52	14:02	0:09	LINE FAULT
672	18-Nov-18	MYSORE	66	MYSORE SOUTH-BOGADHI	MYSORESOUTH_66	10:06	12:04	1:58	LINE CLEAR AVAILED
673	18-Nov-18	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	10:07	11:50	1:43	LINE CLEAR AVAILED
674	18-Nov-18	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	9:52	11:19	1:27	LINE FAULT
675	19-Nov-18	MYSORE	66	HV2	HDKOTE_66	14:55	15:05	0:10	TRANSFORMER FAULT
676	19-Nov-18	MYSORE	66	HUNSUR-HOOTAGALLY	HOSURGATE_66	11:45	13:10	1:25	HAND TRIPPED
677	19-Nov-18	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 KRNAGARA_66 BHERYA_66 BILIKERE_66 GVGUDI_66	14:09	14:25	0:16	LINE FAULT
678	19-Nov-18	MYSORE	66	MAHADESHWARAPURA-KR PETE	MADESWARAPURA_66	18:25	19:25	1:00	LINE FAULT
679	19-Nov-18	MYSORE	66	MAHADESHWARAPURA-JAKKANAHALLI	JAKKANAHALLY_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	18:25	23:59	5:34	LINE FAULT
680	19-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	3:53	6:26	2:32	TRANSFORMER FAULT
681	19-Nov-18	MYSORE	66	SANTHE SARGUR-B MATAKERE	B MATKERE_66	7:10	7:23	0:13	LINE FAULT
682	19-Nov-18	MYSORE	66	SANTHE SARGUR-B MATAKERE	B MATKERE_66	12:05	12:15	0:10	LINE FAULT
683	19-Nov-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 TNARASIPURA_66 THUMBLA_66 MEGALAPURA_66	15:00	15:10	0:10	LINE FAULT
684	13-Nov-18	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	6:12	6:38	0:26	LINE FAULT
685	13-Nov-18	TUMKUR	220	TR-2	HONNALLI_220	16:09	16:45	0:36	HAND TRIPPED
686	13-Nov-18	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	10:27	17:26	6:58	LINE CLEAR AVAILED
687	13-Nov-18	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	10:27	17:29	7:01	HAND TRIPPED
688	13-Nov-18	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110, TIPTUR_110, HONNAVALLI_110, HALKURKE_110	7:30	18:02	10:31	LINE CLEAR AVAILED
689	13-Nov-18	TUMKUR	110	HONNAVALLI- ADAN SOLAR	ADANSOLAR_IPP_66	7:04	7:27	0:22	HAND TRIPPED
690	13-Nov-18	TUMKUR	110	HONNAVALLI 110- DMKURKE	DMKURKE_110	15:42	15:45	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
691	13-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	11:57	12:12	0:15	LINE FAULT
692	13-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	12:16	12:34	0:18	LINE FAULT
693	13-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	9:42	19:20	9:37	LINE CLEAR AVAILED
694	13-Nov-18	TUMKUR	66	TR-2	BEVINAHALLI_66	10:01	10:32	0:30	TRANSFORMER FAULT
695	13-Nov-18	TUMKUR	66	TR-2	CHELURU_66	13:39	16:36	2:56	LINE CLEAR AVAILED
696	13-Nov-18	TUMKUR	66	CHIKKABANAGERE- GLOBAL IPP	GLOBALTECHPARK_IPP_66	13:45	14:00	0:14	MAIN SUPPLY FAILURE
697	13-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:15	17:38	9:22	HAND TRIPPED
698	13-Nov-18	TUMKUR	66	TR-2	GARAGA_66	12:41	15:11	2:29	LINE CLEAR AVAILED
699	13-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	16:05	16:43	0:37	MAIN SUPPLY FAILURE
700	13-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:04	16:42	0:37	MAIN SUPPLY FAILURE
701	13-Nov-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	16:04	16:41	0:37	MAIN SUPPLY FAILURE
702	13-Nov-18	TUMKUR	66	TR-1	DAVANGERE_SRS_220	16:04	16:37	0:32	MAIN SUPPLY FAILURE
703	13-Nov-18	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:04	16:43	0:38	MAIN SUPPLY FAILURE
704	13-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:05	16:42	0:37	MAIN SUPPLY FAILURE
705	13-Nov-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:36	10:44	0:07	MAIN SUPPLY FAILURE
706	13-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:15	17:38	9:22	HAND TRIPPED
707	13-Nov-18	TUMKUR	66	TR-2	GARAGA_66	12:41	15:11	2:29	LINE CLEAR AVAILED
708	13-Nov-18	TUMKUR	66	TR-1 & TR-2 (HV & LV)	HONNALI_66	16:04	17:18	1:13	HAND TRIPPED
709	13-Nov-18	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	16:04	17:17	1:13	HAND TRIPPED
710	13-Nov-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	16:04	16:51	0:47	HAND TRIPPED
711	13-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	3:15	3:24	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
712	13-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:04	16:51	0:47	HAND TRIPPED
713	13-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:55	18:08	0:13	HAND TRIPPED
714	13-Nov-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	16:04	17:16	1:11	HAND TRIPPED
715	13-Nov-18	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	17:20	18:08	0:48	LINE CLEAR AVAILED
716	13-Nov-18	TUMKUR	66	I D HALLI- KODIGENAHALLI	KODIGENAHALLI_66	17:21	18:07	0:45	LINE CLEAR AVAILED
717	13-Nov-18	TUMKUR	66	TR-1 & 2	IDHALLY_66	17:21	18:07	0:46	LINE CLEAR AVAILED
718	13-Nov-18	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	BEVINAHALLI_66	10:09	10:28	0:19	LINE FAULT
719	13-Nov-18	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	11:29	11:46	0:16	LINE FAULT
720	13-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:20	12:30	0:10	LINE FAULT
721	13-Nov-18	TUMKUR	66	TR-1	MALLASANDRA_66	15:20	16:06	0:45	LINE CLEAR AVAILED
722	13-Nov-18	TUMKUR	66	TR-2	MALLASANDRA_66	15:43	16:06	0:22	LINE CLEAR AVAILED
723	13-Nov-18	TUMKUR	66	TR-1	SAVALANGA_66	16:58	17:49	0:50	LINE CLEAR AVAILED
724	13-Nov-18	TUMKUR	66	SAVALANGA- HONNALLI	SAVALANGA_66	17:00	17:49	0:48	LINE CLEAR AVAILED
725	14-Nov-18	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	16:55	18:20	1:24	LINE CLEAR AVAILED
726	14-Nov-18	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	10:14	13:10	2:56	NBFC ISSUED
727	14-Nov-18	TUMKUR	220	TR-1(HV-1)	CHITRADURGA_220	15:11	18:39	3:27	HAND TRIPPED
728	14-Nov-18	TUMKUR	220	TR-3(HV-3)	CHITRADURGA_220	8:00	8:25	0:25	TRANSFORMER FAULT
729	14-Nov-18	TUMKUR	66	TR-2	ANCHEPALYA_220	11:18	12:10	0:51	LINE CLEAR AVAILED
730	14-Nov-18	TUMKUR	66	TR-1(LV-1)	ANTHRASANAHALLI_220	16:55	18:20	1:24	LINE CLEAR AVAILED
731	14-Nov-18	TUMKUR	66	TR-1(LV-1)	CHITRADURGA_220	15:11	18:40	3:28	HAND TRIPPED
732	14-Nov-18	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	8:00	8:40	0:40	LINE FAULT
733	14-Nov-18	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66	8:24	8:39	0:14	LINE FAULT
734	14-Nov-18	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	8:08	8:28	0:20	LINE FAULT
735	14-Nov-18	TUMKUR	66	TR-1	DAVANGERE_SRS_220	5:03	5:21	0:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
736	14-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TM2_66	8:38	18:09	9:31	LOAD CURTAILMENT
737	14-Nov-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	7:12	8:02	0:49	TRANSFORMER FAULT
738	14-Nov-18	TUMKUR	66	HIREHALLI - BADDIHALLI(HONNUDIKE)	BADDIHALLI_66	18:58	19:06	0:07	LOAD CURTAILMENT
739	14-Nov-18	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:54	9:09	0:15	LINE FAULT
740	14-Nov-18	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	22:03	22:20	0:16	LINE FAULT
741	14-Nov-18	TUMKUR	66	TR-2	MALLASANDRA_66	15:17	16:44	1:26	LINE CLEAR AVAILED
742	14-Nov-18	TUMKUR	66	NEELAGUNDA 220KV- HALUVAGALU	HALUVAGALU_66	15:23	15:33	0:10	LINE FAULT
743	14-Nov-18	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	0:50	0:54	0:03	TRANSFORMER FAULT
744	14-Nov-18	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	18:02	18:05	0:03	HAND TRIPPED
745	14-Nov-18	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	9:21	14:15	4:54	LINE CLEAR AVAILED
746	15-Nov-18	TUMKUR	220	TR-2(100MVA)	DAVANGERE_SRS_220	11:00	12:37	1:37	LINE CLEAR AVAILED
747	15-Nov-18	TUMKUR	66	ANCHEPALYA 66- ANCHEPALYA	ANCHEPALYA_66	4:00	4:40	0:40	LINE FAULT
748	15-Nov-18	TUMKUR	66	TR-3	AVAREGERE_66	15:11	20:02	4:50	TRANSFORMER FAULT
749	15-Nov-18	TUMKUR	66	TR-1 &2	CHANNAGIRI_66	4:25	6:37	2:12	HAND TRIPPED
750	15-Nov-18	TUMKUR	66	TR-2	CHANNAGIRI_66	13:25	13:28	0:02	TRANSFORMER FAULT
751	15-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	6:45	7:16	0:30	HAND TRIPPED
752	15-Nov-18	TUMKUR	66	TR-2	HARAPPANAHALLI_66	11:51	11:54	0:03	TRANSFORMER FAULT
753	15-Nov-18	TUMKUR	66	HARAPANAHALLI- ITTAGI	HARAPPANAHALLI_66	17:35	17:44	0:09	LINE FAULT
754	15-Nov-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	11:50	11:52	0:02	LOAD CURTAILMENT
755	15-Nov-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:03	14:09	1:05	LINE CLEAR AVAILED
756	15-Nov-18	TUMKUR	66	TR-1(HV SIDE)	HONNALLI_220	13:03	14:09	1:05	LINE CLEAR AVAILED
757	15-Nov-18	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	10:38	11:33	0:55	LINE CLEAR AVAILED
758	15-Nov-18	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:37	14:57	3:20	LINE FAULT
759	15-Nov-18	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	9:44	10:13	0:29	LINE CLEAR AVAILED
760	15-Nov-18	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	3:25	9:41	6:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
761	15-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66, SHYAGALE_66	16:13	17:15	1:01	LINE CLEAR AVAILED
762	15-Nov-18	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	6:39	6:47	0:07	LINE FAULT
763	15-Nov-18	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	9:59	15:10	5:11	LINE CLEAR AVAILED
764	15-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	4:00	4:14	0:14	LINE FAULT
765	15-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	16:23	18:00	1:36	LINE CLEAR AVAILED
766	15-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	9:15	12:01	2:46	LINE CLEAR AVAILED
767	15-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	4:00	4:14	0:14	LINE FAULT
768	16-Nov-18	TUMKUR	110	TR-1(HV SIDE)	KEREKODI_110	13:21	14:07	0:45	LINE CLEAR AVAILED
769	16-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	12:58	13:06	0:07	LINE FAULT
770	16-Nov-18	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	11:49	12:44	0:55	HAND TRIPPED
771	16-Nov-18	TUMKUR	66	TR-2	DAVANAGERE_66	20:15	20:51	0:35	LINE CLEAR AVAILED
772	16-Nov-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	6:55	7:14	0:19	LINE FAULT
773	16-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:59	17:38	9:38	LINE FAULT
774	16-Nov-18	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	CHIKKABANAGERE_66	15:38	18:24	2:46	LINE CLEAR AVAILED
775	16-Nov-18	TUMKUR	66	TR-2	HINDASGHATTA_66	11:29	12:57	1:27	LINE CLEAR AVAILED
776	16-Nov-18	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	8:39	8:44	0:05	LINE FAULT
777	16-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:11	11:19	0:07	LINE FAULT
778	16-Nov-18	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	6:03	6:07	0:03	HAND TRIPPED
779	16-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:30	10:36	2:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
780	16-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	3:40	3:54	0:14	LINE FAULT
781	16-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:10	8:34	0:24	LINE FAULT
782	17-Nov-18	TUMKUR	220	TR-1	ANCHEPALYA_220	16:02	17:23	1:20	LINE CLEAR AVAILED
783	17-Nov-18	TUMKUR	220	TR-1& TR-2,TR-3	ANTHRASANAHALLI_220	18:25	19:33	1:08	HAND TRIPPED
784	17-Nov-18	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	11:08	14:08	3:00	LINE CLEAR AVAILED
785	17-Nov-18	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	11:09	14:21	3:11	MAIN SUPPLY FAILURE
786	17-Nov-18	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	16:02	17:23	1:20	LINE CLEAR AVAILED
787	17-Nov-18	TUMKUR	66	TR2	BADAVANAHALLI_66	17:27	20:22	2:54	TRANSFORMER FAULT
788	17-Nov-18	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	19:37	21:15	1:37	HAND TRIPPED
789	17-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:13	13:26	0:13	LINE FAULT
790	17-Nov-18	TUMKUR	66	DAVANGERE SRS- H- HOSPET	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:20	10:35	0:15	LINE FAULT
791	17-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:07	17:31	9:23	HAND TRIPPED
792	17-Nov-18	TUMKUR	66	TR-2	HARAPPANAHALLI_66	19:51	20:09	0:17	TRANSFORMER FAULT
793	17-Nov-18	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	CHIKKABANAGERE_66	16:29	18:18	1:48	LINE CLEAR AVAILED
794	17-Nov-18	TUMKUR	66	HIREHALLI - ANTHRASANAHALLI	HIREHALLY_66	17:05	17:25	0:19	HAND TRIPPED
795	17-Nov-18	TUMKUR	66	HIREHALLI - ANTHRASANAHALLI	HIREHALLY_66	20:09	20:48	0:38	HAND TRIPPED
796	17-Nov-18	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:25	11:59	0:33	LINE CLEAR AVAILED
797	17-Nov-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	11:25	11:59	0:33	LINE CLEAR AVAILED
798	17-Nov-18	TUMKUR	66	TR-2	HONNALI_66	10:40	11:39	0:59	TRANSFORMER FAULT
799	17-Nov-18	TUMKUR	66	TR-2	HONNALI_66	14:08	14:27	0:18	TRANSFORMER FAULT
800	17-Nov-18	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR SIRA	JAVAGONDANAHALLI_66, BEVINAHALLI_66	15:51	18:47	2:56	LINE CLEAR AVAILED
801	17-Nov-18	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	14:34	14:38	0:03	LINE FAULT
802	17-Nov-18	TUMKUR	66	TR-1 & TR-2	MALLASANDRA_66	13:02	14:29	1:27	HAND TRIPPED
803	17-Nov-18	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	12:26	14:21	1:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
804	17-Nov-18	TUMKUR	66	TAVAREKERE (H)- PATTNAYAKANAHALLI	PATTANAYAKANAHALLI_66	15:35	18:51	3:16	LINE CLEAR AVAIED
805	17-Nov-18	TUMKUR	66	TR-1	TUMKUR_66	19:46	19:55	0:09	HAND TRIPPED
806	17-Nov-18	TUMKUR	66	TR-1	YNHOSKOTE_66	13:41	14:19	0:38	LINE CLEAR AVAIED
807	18-Nov-18	TUMKUR	220	HIRIYUR 220kV- AZURE SOLAR	AZURESOLAR_IPP_66	18:59	20:00	1:01	LINE FAULT
808	18-Nov-18	TUMKUR	220	TR-3(HV-3)	HIRIYUR_220	6:04	6:26	0:21	TRANSFORMER FAULT
809	18-Nov-18	TUMKUR	220	TR-3(HV-3)	HIRIYUR_220	18:14	20:01	1:47	TRANSFORMER FAULT
810	18-Nov-18	TUMKUR	220	TR-3(HV-3)	HIRIYUR_220	22:45	23:42	0:57	TRANSFORMER FAULT
811	18-Nov-18	TUMKUR	220	KB CROSS 220kV- SHIMOGA	MRSMSG_220	21:01	21:23	0:22	LINE FAULT
812	18-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	7:44	8:25	0:41	LINE CLEAR AVAIED
813	18-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	7:43	8:28	0:44	LINE FAULT
814	18-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:33	17:46	7:12	MAIN SUPPLY FAILURE
815	18-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	20:07	21:30	1:22	MAIN SUPPLY FAILURE
816	18-Nov-18	TUMKUR	66	TR-1	DEVARAHALLI_66	10:33	17:46	7:12	MAIN SUPPLY FAILURE
817	18-Nov-18	TUMKUR	66	TR-1	DEVARAHALLI_66	20:07	21:30	1:22	MAIN SUPPLY FAILURE
818	18-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:54	11:08	0:14	LINE FAULT
819	18-Nov-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:49	12:01	0:12	LINE FAULT
820	18-Nov-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:34	12:47	0:13	LINE FAULT
821	18-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:10	17:33	9:22	HAND TRIPPED
822	18-Nov-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	8:37	10:50	2:13	LINE CLEAR AVAIED
823	18-Nov-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	11:15	12:16	1:00	TRANSFORMER FAULT
824	18-Nov-18	TUMKUR	66	TR-2	HARAPPANAHALLI_66	8:39	10:50	2:11	LINE CLEAR AVAIED
825	18-Nov-18	TUMKUR	66	HARAPANAHALLI- ITTAGI	HARAPPANAHALLI_66	8:38	10:50	2:12	LINE CLEAR AVAIED
826	18-Nov-18	TUMKUR	66	HARAPANAHALLI- SUZLON1	SUZLON1_IPP_66	8:39	10:50	2:11	LINE CLEAR AVAIED
827	18-Nov-18	TUMKUR	66	HARAPANAHALLI- SUZLON2	SUZLON1_IPP_66	8:39	10:50	2:11	LINE CLEAR AVAIED
828	18-Nov-18	TUMKUR	66	HIREHALLI - BADDIHALLI(HONNUDIKE)	BADDIHALLI_66	10:12	10:30	0:17	HAND TRIPPED
829	18-Nov-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:08	6:30	0:21	HAND TRIPPED
830	18-Nov-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:18	21:16	2:57	HAND TRIPPED
831	18-Nov-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	6:12	6:29	0:16	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
832	18-Nov-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	18:19	20:04	1:44	HAND TRIPPED
833	18-Nov-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	22:51	23:46	0:54	HAND TRIPPED
834	18-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:13	6:29	0:16	HAND TRIPPED
835	18-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP2_IPP_66	18:22	20:36	2:14	HAND TRIPPED
836	18-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP1_IPP_66	6:13	6:29	0:16	HAND TRIPPED
837	18-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	18:22	20:36	2:14	HAND TRIPPED
838	18-Nov-18	TUMKUR	66	TR-2	HONNALI_66	16:26	17:11	0:44	TRANSFORMER FAULT
839	18-Nov-18	TUMKUR	66	TR-2	HONNALI_66	20:50	21:14	0:24	TRANSFORMER FAULT
840	18-Nov-18	TUMKUR	66	HONNALI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:00	19:17	9:17	LINE CLEAR AVAILED
841	18-Nov-18	TUMKUR	66	TR-2	HOSADURGA_66	10:27	10:37	0:10	TRANSFORMER FAULT
842	18-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:48	15:16	0:28	LINE FAULT
843	18-Nov-18	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	23:09	23:33	0:23	LINE FAULT
844	18-Nov-18	TUMKUR	66	TR-2	MANGALWADA_66	18:34	19:01	0:27	TRANSFORMER FAULT
845	18-Nov-18	TUMKUR	66	TR-1	MATHOD_66	15:28	17:37	2:09	LINE CLEAR AVAILED
846	18-Nov-18	TUMKUR	66	TR-1	MAVINAKATTE_66	19:43	19:47	0:03	TRANSFORMER FAULT
847	18-Nov-18	TUMKUR	66	TR-1 & TR-2	MAVINAKATTE_66	21:28	21:41	0:13	TRANSFORMER FAULT
848	18-Nov-18	TUMKUR	66	MAVINAKATTE- LINGADAHALLI	MAVINAKATTE_66	19:47	21:36	1:49	LINE FAULT
849	18-Nov-18	TUMKUR	66	TR-1	NEELAGUNDA_220	13:38	13:43	0:04	TRANSFORMER FAULT
850	18-Nov-18	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	6:57	8:47	1:49	LINE FAULT
851	18-Nov-18	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	20:13	20:21	0:07	LINE FAULT
852	19-Nov-18	TUMKUR	220	KB CROSS 220kV- SHIMOGA	MRSMG_220	17:16	17:38	0:21	LINE FAULT
853	19-Nov-18	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	17:16	17:35	0:18	HAND TRIPPED
854	19-Nov-18	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:16	17:36	0:20	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
855	19-Nov-18	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	17:34	17:41	0:07	HAND TRIPPED
856	19-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	0:43	0:55	0:12	LINE FAULT
857	19-Nov-18	TUMKUR	66	DYAVARANAHALI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	17:36	17:44	0:08	HAND TRIPPED
858	19-Nov-18	TUMKUR	66	GUTTUR 66kV- DAVANGERE	GUTTUR_66	9:59	11:27	1:27	LINE CLEAR AVAILED
859	19-Nov-18	TUMKUR	66	TR-1	HIRIYUR_66	7:21	7:32	0:11	TRANSFORMER FAULT
860	19-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	0:45	8:05	7:19	HAND TRIPPED
861	19-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP2_IPP_66	0:45	8:05	7:19	HAND TRIPPED