

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 13.10.2020 TO 19.10.2020

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
1	13-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
2	13-Oct-20	BAGALKOT	110	110/11KV HV2	SANKESHWER_110	17:45	17:50	0:05	HAND TRIPPED
3	13-Oct-20	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:37	14:05	0:28	HAND TRIPPED
4	13-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
5	13-Oct-20	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	12:04	12:30	0:26	LINE CLEAR AVAILED
6	13-Oct-20	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	12:50	12:55	0:05	LINE CLEAR AVAILED
7	13-Oct-20	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED MALGHAN(S)_110	13:35	14:05	0:30	LINE CLEAR AVAILED
8	13-Oct-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	15:20	16:40	1:20	TRANSFORMER FAULT
9	13-Oct-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	17:00	17:55	0:55	TRANSFORMER FAULT
10	13-Oct-20	BAGALKOT	110	110/33KV HV3	SANKESHWER_110, HEBBAL_33, KANAGALA_33	17:35	17:43	0:08	HAND TRIPPED
11	13-Oct-20	BAGALKOT	110	110/33KV, HV1	SAVALAGI_110, KALABILAGI_33, TUNGAL LIS_33, HIRAPADASALAGI LIS_33	11:45	12:21	0:36	LINE CLEAR AVAILED
12	13-Oct-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	20:44 (12.10.2020)	09:05 (13.10.2020)	12:21hrs	TRANSFORMER CHARGED
13	13-Oct-20	BAGALKOT	110	ATHANI2-HALIYAL LIS	STATION NOT AFFECTED HALIYAL LIS_110	16:55	17:12	0:17	LINE FAULT
14	13-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
15	13-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
16	13-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
17	13-Oct-20	BAGALKOT	110	HATTARGI-DADDI	DADDI_110	16:20	16:50	0:30	LINE FAULT
18	13-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
19	13-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.10.2020)			LINE OPEN: LINE CLEAR AVAILED
20	13-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
21	13-Oct-20	BAGALKOT	110	KSSKN-ATHANI220	STATION NOT AFFECTED ATHANI_220	16:56	17:47	0:51	LINE FAULT
22	13-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
23	13-Oct-20	BAGALKOT	110	MAHALINGAPUR-GSML1	STATION NOT AFFECTED MAHALINGAPUR_220	9:29	10:48	1:19	LINE FAULT
24	13-Oct-20	BAGALKOT	110	NAVALAGUND-DHARAWAD BIO	NAVALGUND_110	13:10	13:29	0:19	LINE FAULT
25	13-Oct-20	BAGALKOT	110	RAMANAKOPPA-MUNDAGOD	STATION NOT AFFECTED MUNDAGOD_110	6:20	6:51	0:31	LINE CLEAR AVAILED
26	13-Oct-20	BAGALKOT	110	SANKESHWER-HUKKERI	STATION NOT AFFECTED HUKKERI_110	12:40	16:50	4:10	HAND TRIPPED
27	13-Oct-20	BAGALKOT	220	220/110KV,HV1	BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
28	13-Oct-20	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED MAHALINGAPUR 220	9:29	16:50	7:21	TRANSFORMER FAULT
29	13-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
30	13-Oct-20	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL 220	2:00	13:02	11:02	LINE FAULT
31	13-Oct-20	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL 220	18:17 (13.10.2020)			LINE OPEN : LINE FAULT
32	13-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
33	13-Oct-20	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI 220	18:18 (13.10.2020)			LINE OPEN : LINE FAULT
34	13-Oct-20	BAGALKOT	220	HAVERI-NARENDRA2	STATION NOT AFFECTED HAVERI 220	3:53	12:12	8:19	LINE FAULT
35	13-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI 220	20:49 (12.10.2020)	8:11 (13.10.2020)	11:22hrs	LINE CHARGED
36	13-Oct-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI 220	20:49 (12.10.2020)	8:05 (13.10.2020)	11:16hrs	LINE CHARGED
37	13-Oct-20	BAGALKOT	220	MK HUBLI-NARENDRA1	MK HUBLI_220	18:05	19:54	1:49	LINE FAULT
38	13-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	13:19 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
39	13-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	13:20 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
40	13-Oct-20	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	2:46	3:49	1:03	MAIN SUPPLY FAILURE
41	13-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
42	13-Oct-20	BENGALURU	66	HV1	SIDDLAGATTA	7:50	15:02	7:12	LINE CLEAR AVAILED
43	13-Oct-20	BENGALURU	66	HV1	YELAHANKA 220	2:46	4:43	1:57	TRANSFORMER FAULT
44	13-Oct-20	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	2:46	3:35	0:49	MAIN SUPPLY FAILURE
45	13-Oct-20	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	4:45	4:50	0:05	MAIN SUPPLY FAILURE
46	13-Oct-20	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	10:05	10:10	0:05	LOAD CHANGE OVER
47	13-Oct-20	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	8:05	8:10	0:05	LOAD CHANGE OVER
48	13-Oct-20	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	2:46	3:35	0:49	MAIN SUPPLY FAILURE
49	13-Oct-20	BENGALURU	66	SOLADEVANAHALLI - SRS PEENYA 220	SOLADEVANAHALLI	4:11	4:22	0:11	LOAD CHANGE OVER
50	13-Oct-20	BENGALURU	66	SOLADEVANAHALLI - YELAHANKA 220	SOLADEVANAHALLI	2:46	3:27	0:41	MAIN SUPPLY FAILURE
51	13-Oct-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	T K HALLI 220	4:44	4:57	0:13	LINE FAULT
52	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE3	ESCORTS (EHT), MANYATHA TECH PARK, ABBIGERE, ATTUR YELAHANKA	2:46	3:48	1:02	LINE FAULT
53	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	2:46	3:48	1:01	LINE FAULT
54	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	4:40	4:57	0:17	LINE FAULT
55	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE5	KHB	2:46	3:49	1:02	LINE FAULT
56	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	2:46	3:48	1:01	LINE FAULT
57	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	2:46	3:49	1:02	LINE FAULT
58	13-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	2:46	3:48	1:02	LINE FAULT
59	13-Oct-20	BENGALURU	220	HV1	YELAHANKA 220	2:46	3:43	0:57	TRANSFORMER FAULT
60	13-Oct-20	BENGALURU	220	HV2	YELAHANKA 220	2:46	3:43	0:57	TRANSFORMER FAULT
61	13-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
62	13-Oct-20	GULBARGA	110	HV2	YELBURGA_110	4:45	10:16	5:31	TRANSFORMER FAULT
63	13-Oct-20	GULBARGA	110	KUSHTAGI-INR_SLR	KUSHTAGI_220	8:26	11:00	2:34	LINE FAULT
64	13-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
65	13-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	4:31	4:36	0:05	LINE FAULT
66	13-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	10:07	11:54	1:47	LINE FAULT
67	13-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
68	13-Oct-20	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	4:45	5:15	0:30	LINE FAULT
69	13-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.20)			LINE OPEN: LINE CLEAR AVAILED
70	13-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	21:08(12/10/2020)	9:14(13/10/2020)	12:06hrs	LINE CHARGED
71	13-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	22:12(13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
72	13-Oct-20	GULBARGA	220	KAPNOOR-MADIYAL_110	MADIYAL_110	4:15	4:25	0:10	LINE FAULT
73	13-Oct-20	GULBARGA	220	KAPNOOR-MADIYAL_110	MADIYAL_110	6:33	6:40	0:07	LINE FAULT
74	13-Oct-20	GULBARGA	220	KUSHTAGI-OPDWIND_IPP	KUSHTAGI_220	8:26	11:00	2:34	LINE FAULT
75	13-Oct-20	GULBARGA	220	KUSHTAGI-SUZLON WIND1_IPP	KUSHTAGI_220	8:26	11:05	2:39	LINE FAULT
76	13-Oct-20	GULBARGA	220	KUSHTAGI-SUZLON WIND2_IPP	KUSHTAGI_220	22:35(10.10.2020)	16:42(13.10.2020)	66:07 HRS	LINE CHARGED
77	13-Oct-20	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	10:38(12.10.2020)	13:15(13.10.2020)	26:37 HRS	LINE CHARGED
78	13-Oct-20	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	2:51	3:05	0:14	LINE FAULT
79	13-Oct-20	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	0:09	0:25	0:16	LINE FAULT
80	13-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	21:06(12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
81	13-Oct-20	GULBARGA	220	SHAHPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR IPP,HUNASGI_110,ASKI_110	3:40	3:54	0:14	LINE FAULT
82	13-Oct-20	GULBARGA	220	SHAHPUR-LINGSUGUR	LINGSUGUR_220	2:38	3:06	0:28	LINE FAULT
83	13-Oct-20	GULBARGA	220	SHAHPUR-RTPS2	SHAHAPUR2_220	3:12	3:25	0:13	LINE FAULT
84	13-Oct-20	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:32	13:13	0:41	TRANSFORMER FAULT
85	13-Oct-20	HASSAN	66	HV1	SAKLESHPURA_66	17:00	17:12	0:12	TRANSFORMER FAULT
86	13-Oct-20	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:58	14:56	1:58	LINE CLEAR AVAILED
87	13-Oct-20	HASSAN	66	HV2	HOLALUR_66	13:40	14:20	0:40	TRANSFORMER FAULT
88	13-Oct-20	HASSAN	66	HV2	HOLALUR_66	15:40	15:45	0:05	TRANSFORMER FAULT
89	13-Oct-20	HASSAN	66	HV2	HOLALUR_66	21:30	21:50	0:20	TRANSFORMER FAULT
90	13-Oct-20	HASSAN	66	HV2	HOLALUR_66	23:20	23:35	0:15	TRANSFORMER FAULT
91	13-Oct-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	10:33	10:42	0:09	LINE FAULT
92	13-Oct-20	HASSAN	110	ANMAVATI-BARNGI	ANAVATTI_110	11:09	11:47	0:38	LINE CLEAR AVAILED
93	13-Oct-20	HASSAN	110	HV1	GANDSI_110	11:36	11:50	0:14	LINE CLEAR AVAILED
94	13-Oct-20	HASSAN	110	HV1	JOG_110	9:30	17:53	8:23	LINE CLEAR AVAILED
95	13-Oct-20	HASSAN	110	HV1	KONAJE_110	4:50	4:55	0:05	LOAD CHANGE OVER
96	13-Oct-20	HASSAN	110	HV1	KONAJE_110	15:04	15:08	0:04	LOAD CHANGE OVER
97	13-Oct-20	HASSAN	110	HV1	SHIVPURA_110	14:40	14:57	0:17	LINE CLEAR AVAILED
98	13-Oct-20	HASSAN	110	HV2	GANDSI_110	11:36	11:50	0:14	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
99	13-Oct-20	HASSAN	110	HV2	JOG_110	15:15	20:30	5:15	LINE CLEAR AVAILED
100	13-Oct-20	HASSAN	110	HV2	KONAJE_110	4:50	4:57	0:07	LOAD CHANGE OVER
101	13-Oct-20	HASSAN	110	HV2	KONAJE_110	15:04	15:11	0:07	LOAD CHANGE OVER
102	13-Oct-20	HASSAN	110	HV3	KONAJE_110	4:50	4:55	0:05	LOAD CHANGE OVER
103	13-Oct-20	HASSAN	110	HV3	KONAJE_110	15:04	15:09	0:05	LOAD CHANGE OVER
104	13-Oct-20	HASSAN	110	JOG110-AMBTR1	JOG_110	11:45	13:15	1:30	HAND TRIPPED
105	13-Oct-20	HASSAN	110	JOG110-AMBTR2	JOG_110	11:45	13:25	1:40	HAND TRIPPED
106	13-Oct-20	HASSAN	110	JOG110-LPH	JOG_110	12:00	13:15	1:15	HAND TRIPPED
107	13-Oct-20	HASSAN	110	JOG110-MGHE	JOG_110	12:00	13:15	1:15	HAND TRIPPED
108	13-Oct-20	HASSAN	110	JOG-JLT3	mghejog_gen	11:57	13:15	1:18	HAND TRIPPED
109	13-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
110	13-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
111	13-Oct-20	HASSAN	110	LV1	KADUR_220	11:05	11:40	0:35	HAND TRIPPED
112	13-Oct-20	HASSAN	110	LV2	MRSMSG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
113	13-Oct-20	HASSAN	110	LV2	KADUR_220	12:00	12:50	0:50	HAND TRIPPED
114	13-Oct-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:07	16:51	7:44	LINE CLEAR AVAILED
115	13-Oct-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	18:08	18:18	0:10	HAND TRIPPED
116	13-Oct-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	9:09	9:17	0:08	HAND TRIPPED
117	13-Oct-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	18:12	18:17	0:05	HAND TRIPPED
118	13-Oct-20	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	9:10	18:05	8:55	LINE CLEAR AVAILED
119	13-Oct-20	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	10:21	16:02	5:41	LINE CLEAR AVAILED
120	13-Oct-20	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	17:58	18:20	0:22	HAND TRIPPED
121	13-Oct-20	HASSAN	220	GERSOPA-MRS	gerusoppa_gen	9:45	15:40	5:55	LINE CLEAR AVAILED
122	13-Oct-20	HASSAN	220	HV2	MRSMSG_220	9:30 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
123	13-Oct-20	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	3:48	4:22	0:34	LINE FAULT
124	13-Oct-20	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	9:45	15:40	5:55	NFBC ISSUED
125	13-Oct-20	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	3:48	4:26	0:38	LINE FAULT
126	13-Oct-20	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	3:48	4:25	0:37	LINE FAULT
127	13-Oct-20	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:39	14:18	2:39	NFBC ISSUED
128	13-Oct-20	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:39	14:18	2:39	LINE CLEAR AVAILED
129	13-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
130	13-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
131	13-Oct-20	MYSURU	66	HV1	HADLI_66	20:30	20:50	0:20	TRANSFORMER FAULT
132	13-Oct-20	MYSURU	66	HV1	HADLI_66	21:52	22:14	0:22	TRANSFORMER FAULT
133	13-Oct-20	MYSURU	66	KUSHALNAGARA-BYLUKUPPE	BYLUKUPPE_66	15:56	16:01	0:05	LINE FAULT
134	13-Oct-20	MYSURU	66	KUSHALNAGARA-MERCERA-1	MADIKERI_66	11:22	11:32	0:10	LINE FAULT
135	13-Oct-20	MYSURU	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	11:20(13.10.20)			LINE OPEN : LINE FAULT
136	13-Oct-20	MYSURU	66	SFC SIVA-10MW	NO STATION EFFECTED	4:45	6:22	1:37	LINE FAULT
137	13-Oct-20	MYSURU	66	SFC SIVA-5MW	NO STATION EFFECTED	4:45	6:25	1:40	LINE FAULT
138	13-Oct-20	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	4:44	4:47	0:03	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
139	13-Oct-20	MYSURU	66	SINDHUVALLY-BEGUR	SINDHUVALLI_66	9:35	13:30	3:55	NFBC ISSUED
140	13-Oct-20	MYSURU	66	SUNTIKOPPA-MADIKERI	MADIKERI_66	11:15	12:06	0:51	LINE FAULT
141	13-Oct-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALI_66 VADERALLI_66	0:12	0:16	0:04	LINE FAULT
142	13-Oct-20	MYSURU	66	VAJMANGALA -BANNUR	BANNUR_66	8:28	8:39	0:11	LINE FAULT
143	13-Oct-20	MYSURU	220	MADHUVANAHALLI-HEBBANI 2	NO STATION EFFECTED	10:07	15:35	5:28	NFBC ISSUED
144	13-Oct-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:42	11:00	0:18	LINE FAULT
145	13-Oct-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:42	10:59	0:17	LINE FAULT
146	13-Oct-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:04	11:13	0:09	LINE FAULT
147	13-Oct-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:49	12:02	0:12	LINE FAULT
148	13-Oct-20	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	11:11	11:21	0:09	LINE FAULT
149	13-Oct-20	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	12:28	12:39	0:10	LINE FAULT
150	13-Oct-20	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	15:06	15:16	0:10	LINE FAULT
151	13-Oct-20	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	RANGENAHALLI_66	15:06	15:16	0:09	LINE FAULT
152	13-Oct-20	TUMKUR	66	TELAGI- VESTAS IPP	VESTAS_IPP_66	11:11	11:25	0:14	LINE FAULT
153	13-Oct-20	TUMKUR	66	TR-1	MYLANAHALLI_66	6:53	7:02	0:09	TRANSFORMER FAULT
154	13-Oct-20	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	14:15	14:37	0:22	TRANSFORMER FAULT
155	13-Oct-20	TUMKUR	66	TR-2	HONNALLI_220	11:13	13:40	2:26	LINE CLEAR AVAILED
156	13-Oct-20	TUMKUR	66	TR-2	HOSADURGA_66	12:03	12:20	0:17	HAND TRIPPED
157	13-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	11:26	11:30	0:03	LINE CLEAR AVAILED
158	13-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	17:49	18:13	0:24	LINE CLEAR AVAILED
159	13-Oct-20	TUMKUR	66	TR-2	TELAGI_66	15:19	16:50	1:30	LINE CLEAR AVAILED
160	13-Oct-20	TUMKUR	110	TR-1	BANDIHALLI_110	12:51	15:44	2:53	LINE CLEAR AVAILED
161	13-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
162	14-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
163	14-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
164	14-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
165	14-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
166	14-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
167	14-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
168	14-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
169	14-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
170	14-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
171	14-Oct-20	BAGALKOT	220	220/110KV,HV1	BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
172	14-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
173	14-Oct-20	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	18:17 (13.10.2020)	11:26 (14.10.2020)	17:09hrs	LINE CHARGED
174	14-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
175	14-Oct-20	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	18:18 (13.10.2020)	11:23 (14.10.2020)	17:05hrs	LINE CHARGED
176	14-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:19 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
177	14-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
178	14-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
179	14-Oct-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	5:44	5:53	0:09	LINE FAULT
180	14-Oct-20	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK	13:05	14:20	1:15	LINE CLEAR AVOIDED
181	14-Oct-20	BENGALURU	66	ITI 220 - DRDO	DRDO(EHT)	13:05	14:20	1:15	LINE CLEAR AVOIDED
182	14-Oct-20	BENGALURU	66	ITI 220 - ITI	ITI	13:05	14:20	1:15	LINE CLEAR AVOIDED
183	14-Oct-20	BENGALURU	66	ITI 220 - NGEF	NGEF,NGEF(EHT)	13:05	14:20	1:15	LINE CLEAR AVOIDED
184	14-Oct-20	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	9:24	12:21	2:57	LINE FAULT
185	14-Oct-20	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	14:18	14:23	0:05	LINE CLEAR AVOIDED
186	14-Oct-20	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	13:05	13:15	0:10	MAIN SUPPLY FAILURE
187	14-Oct-20	BENGALURU	220	ITI 220 - HOODY 220	ITI 220	13:05	14:14	1:09	LINE FAULT
188	14-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
189	14-Oct-20	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	3:43	4:12	0:29	LINE FAULT
190	14-Oct-20	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	6:06	6:20	0:14	LINE FAULT
191	14-Oct-20	GULBARGA	110	HUMNABAD_220	HV1	2:58	13:25	10:27	LINE CLEAR AVOIDED
192	14-Oct-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITGUPPA_110	8:12	8:25	0:13	LINE FAULT
193	14-Oct-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITGUPPA_110	8:35	9:08	0:33	LINE FAULT
194	14-Oct-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITGUPPA_110	9:28	9:43	0:15	LINE FAULT
195	14-Oct-20	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	11:32	19:05	7:33	HAND TRIPPED
196	14-Oct-20	GULBARGA	110	HUMNABAD-MNAAEKHALI	MANEKHALI_110	10:26	11:07	0:41	HAND TRIPPED
197	14-Oct-20	GULBARGA	110	HUMNABAD-SEDAM1	SEDAM_220	8:41	10:10	1:29	LINE CLEAR AVOIDED
198	14-Oct-20	GULBARGA	110	HUMNABAD-SEDAM2	SEDAM_220	3:19	8:16	4:57	LINE CLEAR AVOIDED
199	14-Oct-20	GULBARGA	110	HV1	SHAHAPUR_220	9:43	10:03	0:20	TRANSFORMER FAULT
200	14-Oct-20	GULBARGA	110	HV1	SHAHAPUR_220	10:10	11:05	0:55	TRANSFORMER FAULT
201	14-Oct-20	GULBARGA	110	HV2	HATTI_110	2:37	2:41	0:04	TRANSFORMER FAULT
202	14-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
203	14-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	21:48	22:01	0:13	LINE CLEAR AVOIDED
204	14-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	22:40	23:46	1:06	LINE CLEAR AVOIDED
205	14-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	23:46(14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
206	14-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	13:37	13:45	0:08	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
207	14-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_110	17:38	17:48	0:10	LINE FAULT
208	14-Oct-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRERAMNAGAR_110,MALLAPURA_110	12:05	12:45	0:40	LINE CLEAR AVAILED
209	14-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
210	14-Oct-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	0:00	8:32	8:32	LINE CLEAR AVAILED
211	14-Oct-20	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	18:25	18:31	0:06	LINE FAULT
212	14-Oct-20	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	19:07	19:15	0:08	LINE FAULT
213	14-Oct-20	GULBARGA	220	HV2	SHAHAPUR_220	4:42	7:28	2:46	TRANSFORMER FAULT
214	14-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	22:12(13.10.2020)	8:38(14.10.2020)	10:26HRS	LINE CHARGED
215	14-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06(14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
216	14-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	21:06(12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
217	14-Oct-20	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	13:05	16:18	3:13	LINE CLEAR AVAILED
218	14-Oct-20	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	6:25	6:30	0:05	LINE FAULT
219	14-Oct-20	HASSAN	66	HV1	HANBALU_66	13:05	16:18	3:13	LINE CLEAR AVAILED
220	14-Oct-20	HASSAN	66	HV1	HOLALUR_66	7:20	7:53	0:33	LINE CLEAR AVAILED
221	14-Oct-20	HASSAN	66	HV2	HOLALUR_66	0:02	0:39	0:37	TRANSFORMER FAULT
222	14-Oct-20	HASSAN	66	HV2	HOLALUR_66	7:20	14:05	6:45	LINE CLEAR AVAILED
223	14-Oct-20	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	9:42	13:31	3:49	LINE CLEAR AVAILED
224	14-Oct-20	HASSAN	110	HV1	MRMG_220	11:50	14:43	2:53	HAND TRIPPED
225	14-Oct-20	HASSAN	110	HV1	ANAVATTI_110	13:15	13:32	0:17	LINE CLEAR AVAILED
226	14-Oct-20	HASSAN	110	HV2	MRMG_220	11:50	14:43	2:53	HAND TRIPPED
227	14-Oct-20	HASSAN	110	HV2	ANAVATTI_110	13:15	13:32	0:17	LINE CLEAR AVAILED
228	14-Oct-20	HASSAN	110	HV2	MANIPAL_110	8:43	9:17	0:34	LINE CLEAR AVAILED
229	14-Oct-20	HASSAN	110	HV2	NERALAKERE_110	10:02	13:51	3:49	LINE CLEAR AVAILED
230	14-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
231	14-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
232	14-Oct-20	HASSAN	110	LV2	MRSMG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
233	14-Oct-20	HASSAN	110	MRSSHM-BADRAVATY1	MRMG_220	9:43	11:48	2:05	HAND TRIPPED
234	14-Oct-20	HASSAN	220	HASSN220-Shomoga	HASSN220	11:09	15:00	3:51	LINE CLEAR AVAILED
235	14-Oct-20	HASSAN	220	HV2	MRMG_220	9:30 (13.10.2020)	14:19 (14.10.2020)	18:48 hrs	TRANSFORMER CHARGED
236	14-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
237	14-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:05 (14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
238	14-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
239	14-Oct-20	MYSURU	66	ADDIHALLI-TUBINKERE	ADDIHALLI_66	9:30	17:45	8:15	LINE CLEAR AVAILED
240	14-Oct-20	MYSURU	66	HARADANAHALLI-TUBINKERE	HARADANAHALLI(JAK)_66	15:00	17:15	2:15	NFBC ISSUED
241	14-Oct-20	MYSURU	66	HARADANAHALLI-TUBINKERE	HARADANAHALLI(JAK)_66	9:30	13:00	3:30	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
242	14-Oct-20	MYSURU	66	HD KOTE-TARAKA	NO STATION EFFECTED	9:42	15:25	5:42	LINE CLEAR AVAILED
243	14-Oct-20	MYSURU	66	KADAKOLA-THANDYA	NO STATION EFFECTED	11:32	13:12	1:40	LINE CLEAR AVAILED
244	14-Oct-20	MYSURU	66	KESALGERE-TUBINKERE	KESLAGERE_66	9:30	15:00	5:30	LINE CLEAR AVAILED
245	14-Oct-20	MYSURU	66	KESALGERE-TUBINKERE	KESLAGERE_66	15:15	17:15	2:00	NFBC ISSUED
246	14-Oct-20	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	12:22	12:52	0:29	LINE FAULT
247	14-Oct-20	MYSURU	66	KIADB MANDYA-TK HALLY	KIADBMANDYA_66 TUMBEKERE_66	12:22	13:50	1:27	LINE FAULT
248	14-Oct-20	MYSURU	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	19:45	19:52	0:07	LINE FAULT
249	14-Oct-20	MYSURU	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	11:20 (13/10/2020)			LINE OPEN : LINE FAULT
250	14-Oct-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:25	12:56	1:31	LINE CLEAR AVAILED
251	14-Oct-20	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	9:51	17:15	7:23	HAND TRIPPED
252	14-Oct-20	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	9:51	17:15	7:23	HAND TRIPPED
253	14-Oct-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66	9:27	15:15	5:48	HAND TRIPPED
254	14-Oct-20	MYSURU	220	HV1	TUBINAKERE_220	10:25	17:07	6:42	LINE CLEAR AVAILED
255	14-Oct-20	MYSURU	220	HV2	TUBINAKERE_220	10:31	17:08	6:37	LINE CLEAR AVAILED
256	14-Oct-20	MYSURU	220	TUBINKERE-BASTIPURA	NO STATION EFFECTED	10:36	17:01	6:25	LINE CLEAR AVAILED
257	14-Oct-20	MYSURU	220	TUBINKERE-HUYGONAHALLI	NO STATION EFFECTED	10:33	16:50	6:17	LINE CLEAR AVAILED
258	14-Oct-20	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	6:22	6:31	0:08	LINE FAULT
259	14-Oct-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	17:03	17:24	0:20	HAND TRIPPED
260	14-Oct-20	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:03	17:24	0:20	HAND TRIPPED
261	14-Oct-20	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON_1_IPP_66	18:34	19:34	0:59	LINE CLEAR AVAILED
262	14-Oct-20	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON_1_IPP_66	18:34	19:34	0:59	LINE CLEAR AVAILED
263	14-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:34	12:46	0:12	HAND TRIPPED
264	14-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:55	17:14	0:19	LINE FAULT
265	14-Oct-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	11:23	12:44	1:21	MAIN SUPPLY FAILURE
266	14-Oct-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:18	12:27	0:08	HAND TRIPPED
267	14-Oct-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:17	12:36	0:18	HAND TRIPPED
268	14-Oct-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:21	11:29	0:07	LINE FAULT
269	14-Oct-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:16	12:29	0:12	HAND TRIPPED
270	14-Oct-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:18	12:27	0:09	HAND TRIPPED
271	14-Oct-20	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:18	12:27	0:09	HAND TRIPPED
272	14-Oct-20	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	RANGENAHALLI_66	11:17	12:45	1:28	MAIN SUPPLY FAILURE
273	14-Oct-20	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	10:02	10:27	0:24	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
274	14-Oct-20	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	12:43	17:14	4:30	LINE CLEAR AVAILED
275	14-Oct-20	TUMKUR	66	TR-1	NYAMATHI_66	20:16	20:37	0:21	TRANSFORMER FAULT
276	14-Oct-20	TUMKUR	66	TR-1	SAVALANGA_66	10:00	10:27	0:26	LINE CLEAR AVAILED
277	14-Oct-20	TUMKUR	66	TR-1	SAVALANGA_66	12:43	17:14	4:30	LINE CLEAR AVAILED
278	14-Oct-20	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	11:17	11:27	0:10	TRANSFORMER FAULT
279	14-Oct-20	TUMKUR	66	TR-2	HALUVAGALU_66	13:49	15:26	1:36	TRANSFORMER FAULT
280	14-Oct-20	TUMKUR	66	TR-3	HARIYABBE_66	14:35	14:50	0:15	LINE CLEAR AVAILED
281	14-Oct-20	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	14:48	17:11	2:23	TRANSFORMER FAULT
282	14-Oct-20	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	13:11	14:05	0:53	LINE CLEAR AVAILED
283	14-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
284	14-Oct-20	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	14:06	14:37	0:31	LINE CLEAR AVAILED
285	14-Oct-20	TUMKUR	220	TR-1	HIRIYUR_220	11:17	11:27	0:09	TRANSFORMER FAULT
286	14-Oct-20	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	13:11	14:04	0:52	LINE CLEAR AVAILED
287	14-Oct-20	TUMKUR	220	TR-2(HV SIDE)	NITTUR_220	14:06	14:37	0:31	LINE CLEAR AVAILED
288	14-Oct-20	TUMKUR	220	TR-3	CHITRADURGA_220	14:48	17:03	2:15	TRANSFORMER FAULT
289	14-Oct-20	TUMKUR	220	TR-3	HIRIYUR_220	12:16	12:25	0:09	TRANSFORMER FAULT
290	15-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
291	15-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
292	15-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
293	15-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
294	15-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
295	15-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
296	15-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
297	15-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
298	15-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
299	15-Oct-20	BAGALKOT	110	MK HUBLI220-MK HUBLI	MK HUBLI_110	22:04	22:26	0:22	LINE CLEAR AVAILED
300	15-Oct-20	BAGALKOT	220	220/110KV,HV1	BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
301	15-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
302	15-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
303	15-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:19 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
304	15-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
305	15-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
306	15-Oct-20	BENGALURU	66	HV1	KOTIPURA 220	15:16	15:25	0:09	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
307	15-Oct-20	BENGALURU	66	HV1	T K HALLI 220	3:29	3:32	0:03	TRANSFORMER FAULT
308	15-Oct-20	BENGALURU	66	HV1	T K HALLI 220	10:50	10:53	0:03	TRANSFORMER FAULT
309	15-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	6:19	6:38	0:19	LINE FAULT
310	15-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:16	15:25	0:09	LOAD CHANGE OVER
311	15-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
312	15-Oct-20	GULBARGA	110	HV3	HATTI_110	14:00	14:17	0:17	TRANSFORMER FAULT
313	15-Oct-20	GULBARGA	110	HV3	HATTI_110	22:12	22:28	0:16	TRANSFORMER FAULT
314	15-Oct-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	0:20	0:30	0:10	LINE FAULT
315	15-Oct-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	5:16	5:26	0:10	LINE FAULT
316	15-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVALIED
317	15-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	23:46(14.10.2020)	0:15(15.10.2020)	0:29 HRS	LINE CHARGED
318	15-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	1:02	1:33	0:31	LINE FAULT
319	15-Oct-20	GULBARGA	110	SHAHABAD-CHTAPUR	CHITAPUR_110,KORWAR TEMPLE_110	2:30	3:00	0:30	LINE FAULT
320	15-Oct-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SREERAMANAGAR_110, GANGAVATHI_110,VENKATAGIRI_110	15:58	16:10	0:12	LINE FAULT
321	15-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVALIED
322	15-Oct-20	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOOR_220	5:00	5:10	0:10	LINE FAULT
323	15-Oct-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	0:28	9:37	9:09	LINE CLEAR AVALIED
324	15-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			LINE OPEN: LINE CLEAR AVALIED
325	15-Oct-20	GULBARGA	220	SHAHABAD-KAPNOOR	SHAHABAD_220	6:12	7:33	1:21	LINE FAULT
326	15-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06(14.10.2020)			LINE OPEN: LINE CLEAR AVALIED
327	15-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	21:06(12.10.2020)			LINE OPEN: LINE CLEAR AVALIED
328	15-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:40	13:50	0:10	LINE FAULT
329	15-Oct-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	12:42	12:47	0:05	LINE FAULT
330	15-Oct-20	HASSAN	66	HNPUA-RAMNATHPURA	HNPUA_66	12:45	12:48	0:03	MAIN SUPPLY FAILURE
331	15-Oct-20	HASSAN	66	HV1	HNPUA_66	12:43	12:48	0:05	MAIN SUPPLY FAILURE
332	15-Oct-20	HASSAN	66	HV1	KUDLIGERE_66	9:36	9:42	0:06	TRANSFORMER FAULT
333	15-Oct-20	HASSAN	66	HV1	KUDLIGERE_66	11:36	11:59	0:23	TRANSFORMER FAULT
334	15-Oct-20	HASSAN	66	HV1	SAKLESHPUA_66	12:20	12:26	0:06	TRANSFORMER FAULT
335	15-Oct-20	HASSAN	66	HV2	HNPUA_66	12:43	12:48	0:05	MAIN SUPPLY FAILURE
336	15-Oct-20	HASSAN	110	HV1	GANDASI_110	12:35	13:30	0:55	LINE CLEAR AVALIED
337	15-Oct-20	HASSAN	110	HV1	GANDASI_110	16:00	16:05	0:05	TRANSFORMER FAULT
338	15-Oct-20	HASSAN	110	HV1	GANDASI_110	16:10	16:50	0:40	TRANSFORMER FAULT
339	15-Oct-20	HASSAN	110	HV1	SHIVAPURA_110	10:40	14:17	3:37	LINE CLEAR AVALIED
340	15-Oct-20	HASSAN	110	HV2	GANDASI_110	12:35	13:10	0:35	LINE CLEAR AVALIED
341	15-Oct-20	HASSAN	110	HV2	GANDASI_110	16:00	16:05	0:05	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
342	15-Oct-20	HASSAN	110	HV2	GANDASI_110	16:10	16:30	0:20	TRANSFORMER FAULT
343	15-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
344	15-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
345	15-Oct-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	4:55	5:41	0:46	LINE CLEAR AVAILED
346	15-Oct-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:40	12:05	1:25	LINE CLEAR AVAILED
347	15-Oct-20	HASSAN	110	LV2	MRSMSG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
348	15-Oct-20	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	3:54	17:19	13:25	LINE FAULT
349	15-Oct-20	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:51	15:19	3:28	HAND TRIPPED
350	15-Oct-20	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:51	15:20	3:29	HAND TRIPPED
351	15-Oct-20	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	3:54	17:19	13:25	LINE FAULT
352	15-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
353	15-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:05 (14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
354	15-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
355	15-Oct-20	MYSURU	66	HV2	FTS_66	8:33	17:12	8:39	LINE CLEAR AVAILED
356	15-Oct-20	MYSURU	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	11:20 (13/10/2020)			LINE OPEN : LINE FAULT
357	15-Oct-20	MYSURU	220	KADAKOLA-BEGUR-1	NO STATION EFFECTED	9:29	18:31	9:02	LINE CLEAR AVAILED
358	15-Oct-20	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	8:50	17:18	8:28	LINE CLEAR AVAILED
359	15-Oct-20	TUMKUR	66	CHITRADURGA 66KV- MEGMICON 1	MEGMICON 1_IPP_66	8:49	18:14	9:24	LINE CLEAR AVAILED
360	15-Oct-20	TUMKUR	66	CHITRADURGA 66KV- MEGMICON 2	MEGMICON 1_IPP_66	8:49	18:14	9:24	LINE CLEAR AVAILED
361	15-Oct-20	TUMKUR	66	DYAVARANAHALI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	6:00	6:13	0:13	LINE FAULT
362	15-Oct-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	5:03	15:24	10:21	LINE CHARGED
363	15-Oct-20	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	19:13	19:22	0:09	LINE FAULT
364	15-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:44	9:54	0:09	LINE FAULT
365	15-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:05	14:16	0:10	LINE FAULT
366	15-Oct-20	TUMKUR	66	MATHOD- PANCHANAHALI	PANCHANAHALI_66, GARAGA_66	18:13	18:19	0:05	LINE FAULT
367	15-Oct-20	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	0:47	0:54	0:07	LINE FAULT
368	15-Oct-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:02	12:28	0:25	LINE FAULT
369	15-Oct-20	TUMKUR	66	TR-1	BELADARA_66	12:18	12:32	0:13	LINE CLEAR AVAILED
370	15-Oct-20	TUMKUR	66	TR-1	KATTIGE_66	12:45	18:09	5:24	LINE CLEAR AVAILED
371	15-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	23:00	23:03	0:02	TRANSFORMER FAULT
372	15-Oct-20	TUMKUR	66	TR-2	BUKKAPATNA_66	12:34	13:47	1:12	LINE CLEAR AVAILED
373	15-Oct-20	TUMKUR	66	TR-2	HOLALKERE_66	13:28	13:39	0:11	LINE CLEAR AVAILED
374	15-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
375	15-Oct-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	18:04	18:09	0:05	TRANSFORMER FAULT
376	15-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	14:03	16:28	2:25	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
377	15-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	16:58	17:40	0:42	HAND TRIPPED
378	15-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	10:49	11:40	0:50	HAND TRIPPED
379	16-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVALIED
380	16-Oct-20	BAGALKOT	110	110/11KV, HV1	KAGAWAD_110	16:07	17:05	0:58	LINE CLEAR AVALIED
381	16-Oct-20	BAGALKOT	110	110/11KV, HV1	VAJJRAMATTI_110	9:10	11:29	2:19	HAND TRIPPED
382	16-Oct-20	BAGALKOT	110	110/11KV, HV1	VAJJRAMATTI_110	17:30	17:40	0:10	HAND TRIPPED
383	16-Oct-20	BAGALKOT	110	110/11KV, HV2	VAJJRAMATTI_110	18:45 (15.10.2020)	16:30 (16.10.2020)	21:45	TRANSFORMER FAULT
384	16-Oct-20	BAGALKOT	110	110/11KV, HV2	VAJJRAMATTI_110	17:30	17:40	0:10	HAND TRIPPED
385	16-Oct-20	BAGALKOT	110	110/11KV, HV2	VAJJRAMATTI_110	18:35	19:00	0:25	TRANSFORMER FAULT
386	16-Oct-20	BAGALKOT	110	110/11KV, HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
387	16-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVALIED
388	16-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVALIED
389	16-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVALIED
390	16-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVALIED
391	16-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVALIED
392	16-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
393	16-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVALIED
394	16-Oct-20	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED CHIKKODI_220	7:45	11:40	3:55	TRANSFORMER FAULT
395	16-Oct-20	BAGALKOT	220	220/110KV, HV1, LV1	BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVALIED
396	16-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVALIED
397	16-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVALIED
398	16-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVALIED
399	16-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVALIED
400	16-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:19 (12.10.2020)			LINE OPEN: LINE CLEAR AVALIED
401	16-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (12.10.2020)			LINE OPEN: LINE CLEAR AVALIED
402	16-Oct-20	BAGALKOT	220	VAJJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI_220	1:15	15:03	13:48	LINE FAULT
403	16-Oct-20	BAGALKOT	220	VAJJRAMATTI- MAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI_220	11:05	15:05	4:00	LINE CLEAR AVALIED
404	16-Oct-20	BENGALURU	66	AGALKOTE - KEMPANAHALLI	MATHIKERE_BGR, AGALKOTE	14:34	15:50	1:16	LINE CLEAR AVALIED
405	16-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
406	16-Oct-20	BENGALURU	66	HALAGUR - HONNIGANAHALLI	HALAGUR	12:45	12:50	0:05	LOAD CHANGEOVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
407	16-Oct-20	BENGALURU	66	HALAGUR - TK HALLI 220	HALAGUR	11:30	11:40	0:10	LOAD CHANGEOVER
408	16-Oct-20	BENGALURU	66	HV1	HAL 220	14:40	14:42	0:02	LINE CLEAR AVAILED
409	16-Oct-20	BENGALURU	66	HV1	KOTIPURA 220	15:59	16:05	0:06	LOAD CHANGE OVER
410	16-Oct-20	BENGALURU	66	HV2	KADUGODI	15:15	16:05	0:50	TRANSFORMER FAULT
411	16-Oct-20	BENGALURU	66	HV3	NELEMANGALA 66	12:52	13:36	0:44	LINE CLEAR AVAILED
412	16-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:59	16:05	0:06	LOAD CHANGE OVER
413	16-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	17:37	17:44	0:07	LINE FAULT
414	16-Oct-20	BENGALURU	66	MATHIKERE_BGR - AGALAKOTE	MATHIKERE_BGR	14:34	15:54	1:20	MAIN SUPPLY FAILURE
415	16-Oct-20	BENGALURU	66	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	15:58	16:18	0:20	LINE FAULT
416	16-Oct-20	BENGALURU	220	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	17:25	17:30	0:05	LINE FAULT
417	16-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
418	16-Oct-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPUR_110,MANVI_110	20:35	20:49	0:14	LINE FAULT
419	16-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
420	16-Oct-20	GULBARGA	110	PDHALLI-BASAI	BASAI_IPP	11:16	12:27	1:11	LINE FAULT
421	16-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:33	3:40	0:07	LINE FAULT
422	16-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	11:26	11:36	0:10	LINE FAULT
423	16-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	14:05	14:43	0:38	LINE FAULT
424	16-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	15:43	16:11	0:28	LINE FAULT
425	16-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	17:49	18:36	0:47	LINE CLEAR AVAILED
426	16-Oct-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDA PUR_110,CORE GREEN SUGAR IPP,SANNATHI IPP	20:20	20:27	0:07	LINE FAULT
427	16-Oct-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,KONKAL_110	23:07	23:32	0:25	LINE FAULT
428	16-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
429	16-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
430	16-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	21:29(16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
431	16-Oct-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	19:52	20:23	0:31	LINE FAULT
432	16-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06(14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
433	16-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	20:53(16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
434	16-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	21:06(12.10.2020)	11:26(16.10.2020)	86:20 HRS	LINE CHARGED
435	16-Oct-20	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	5:20	5:35	0:15	MAIN SUPPLY FAILURE
436	16-Oct-20	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	12:48	14:40	1:52	NFBC ISSUED
437	16-Oct-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	6:03	6:08	0:05	LINE FAULT
438	16-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	5:20	5:35	0:15	MAIN SUPPLY FAILURE
439	16-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	12:48	14:40	1:52	NFBC ISSUED
440	16-Oct-20	HASSAN	66	HV1	KUDLIGERE_66	12:30	14:26	1:56	LINE CLEAR AVAILED
441	16-Oct-20	HASSAN	66	HV1	RAMPURA_66	11:51	14:09	2:18	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
442	16-Oct-20	HASSAN	66	HV2	RAMPURA_66	11:51	14:09	2:18	LINE CLEAR AVAILED
443	16-Oct-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	5:19	5:32	0:13	LINE FAULT
444	16-Oct-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	12:43	14:36	1:53	LINE CLEAR AVAILED
445	16-Oct-20	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	11:51	13:58	2:07	LINE CLEAR AVAILED
446	16-Oct-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	12:40	14:37	1:57	MAIN SUPPLY FAILURE
447	16-Oct-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:24	11:40	1:16	LINE CLEAR AVAILED
448	16-Oct-20	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	9:17	18:14	8:57	LINE CLEAR AVAILED
449	16-Oct-20	HASSAN	110	HV2	NAVUNDA_110	12:30	13:02	0:32	LINE CLEAR AVAILED
450	16-Oct-20	HASSAN	110	HV2	SORABA_110	15:15	15:30	0:15	LINE CLEAR AVAILED
451	16-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
452	16-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
453	16-Oct-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	16:48	17:12	0:24	LINE CLEAR AVAILED
454	16-Oct-20	HASSAN	110	LV1	SHIRALKOPPA_220	10:50	12:02	1:12	HAND TRIPPED
455	16-Oct-20	HASSAN	110	LV2	MRSMSG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
456	16-Oct-20	HASSAN	110	LV2	SHIRALKOPPA_220	10:50	12:02	1:12	HAND TRIPPED
457	16-Oct-20	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:24	11:30	0:06	HAND TRIPPED
458	16-Oct-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:14	11:20	0:06	HAND TRIPPED
459	16-Oct-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:25	11:30	0:05	HAND TRIPPED
460	16-Oct-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:52	11:08	0:16	HAND TRIPPED
461	16-Oct-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:24	11:30	0:06	HAND TRIPPED
462	16-Oct-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	9:40	10:15	0:35	HAND TRIPPED
463	16-Oct-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:02	12:30	0:28	HAND TRIPPED
464	16-Oct-20	HASSAN	110	SORABA-SHR220	SORABA_110	12:30	12:40	0:10	LOAD CHANGE OVER
465	16-Oct-20	HASSAN	110	SORABA-SHR220	SORABA_110	9:50	10:05	0:15	LOAD CHANGE OVER
466	16-Oct-20	HASSAN	220	HV1	SHIRALKOPPA_220	10:50	12:02	1:12	HAND TRIPPED
467	16-Oct-20	HASSAN	220	HV2	SHIRALKOPPA_220	10:50	12:02	1:12	HAND TRIPPED
468	16-Oct-20	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:17	11:07	0:50	HAND TRIPPED
469	16-Oct-20	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:12	12:13	1:01	HAND TRIPPED
470	16-Oct-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:17	11:07	0:50	HAND TRIPPED
471	16-Oct-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:12	12:05	0:53	HAND TRIPPED
472	16-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
473	16-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:34 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
474	16-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:05 (14.10.2020)	8:41 (16.10.2020)	35:36hrs	LINE CHARGED
475	16-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
476	16-Oct-20	MYSURU	66	KOPPA -NSL	NO STATION EFFECTED	11:16	12:45	1:28	LINE CLEAR AVAILED
477	16-Oct-20	MYSURU	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	11:20 (13/10/2020)			LINE OPEN : LINE FAULT
478	16-Oct-20	MYSURU	66	VAJMANGALA-JYOTHINAGARA	NO STATION EFFECTED	9:50	15:26	5:36	LINE CLEAR AVAILED
479	16-Oct-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:49	14:55	0:06	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
480	16-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:29	11:40	0:11	LINE FAULT
481	16-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:40	15:00	0:20	LINE FAULT
482	16-Oct-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:40	14:56	0:16	LINE FAULT
483	16-Oct-20	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	8:38	8:40	0:01	LINE FAULT
484	16-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	4:58	5:05	0:07	LINE FAULT
485	16-Oct-20	TUMKUR	66	TR-1	BELADARA_66	11:07	16:07	5:00	LINE CLEAR AVAILED
486	16-Oct-20	TUMKUR	66	TR-1	BENKIKERE_66	12:08	12:50	0:41	LINE CLEAR AVAILED
487	16-Oct-20	TUMKUR	66	TR-1	SHYLAPURA_66	13:38	15:14	1:36	LINE CLEAR AVAILED
488	16-Oct-20	TUMKUR	66	TR-2	BELLAVI_66	9:31	11:17	1:45	LINE CLEAR AVAILED
489	16-Oct-20	TUMKUR	66	TR-2	HARAPPANAHALLI_66	11:01	11:27	0:26	TRANSFORMER FAULT
490	16-Oct-20	TUMKUR	66	TR-2	HARAPPANAHALLI_66	12:59	13:09	0:09	TRANSFORMER FAULT
491	16-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	8:02	8:10	0:07	TRANSFORMER FAULT
492	16-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	12:51	13:08	0:17	TRANSFORMER FAULT
493	16-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	13:12	13:18	0:06	TRANSFORMER FAULT
494	16-Oct-20	TUMKUR	66	TR-2	MANGALWADA_66	17:04	17:10	0:05	TRANSFORMER FAULT
495	16-Oct-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:18	14:27	0:08	TRANSFORMER FAULT
496	16-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
497	16-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	14:43	17:16	2:32	HAND TRIPPED
498	17-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
499	17-Oct-20	BAGALKOT	110	11/11KV,HV1A	JAMAKHANDI_110	15:00	16:23	1:23	LINE CLEAR AVAILED
500	17-Oct-20	BAGALKOT	110	11/11KV,HV2A	JAMAKHANDI_110	15:00	16:23	1:23	LINE CLEAR AVAILED
501	17-Oct-20	BAGALKOT	110	11/11KV,HV3	JAMAKHANDI_110	15:00	16:22	1:22	LINE CLEAR AVAILED
502	17-Oct-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	9:19	12:45	3:26	TRANSFORMER FAULT
503	17-Oct-20	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	9:19	18:00	8:41	TRANSFORMER FAULT
504	17-Oct-20	BAGALKOT	110	110/11KV, HV2	RON_110	13:58	14:48	0:50	TRANSFORMER FAULT
505	17-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
506	17-Oct-20	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	16:01	17:39	1:38	LINE CLEAR AVAILED
507	17-Oct-20	BAGALKOT	110	110/33KV,HV3	KULIGOD_110 & ALLIMATTI_33,TIGADI_33	9:30	10:02	0:32	TRANSFORMER FAULT
508	17-Oct-20	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	6:24	6:53	0:29	LINE FAULT
509	17-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
510	17-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
511	17-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
512	17-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
513	17-Oct-20	BAGALKOT	110	HUDLI-BSPL	HUDLI_110	11:53	15:38	3:45	LINE CLEAR AVAILED
514	17-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
515	17-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
516	17-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
517	17-Oct-20	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	13:58	14:50	0:52	LINE FAULT
518	17-Oct-20	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	9:19	11:29	2:10	LINE FAULT
519	17-Oct-20	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
520	17-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
521	17-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA 1	BELAGAUM_220	0:18	7:43	7:25	LOAD CURTAILMENT
522	17-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
523	17-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
524	17-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
525	17-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	6:09 (17.10.2020)			LOAD CURTAILMENT
526	17-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	6:09 (17.10.2020)			LOAD CURTAILMENT
527	17-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:19 (12.10.2020)	0:12 (17.10.2020)	10:53 hrs	LINE CHARGED
528	17-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (12.10.2020)	0:12 (17.10.2020)	10:52 hrs	LINE CHARGED
529	17-Oct-20	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	8:30	8:34	0:04	LINE CLEAR AVAILED
530	17-Oct-20	BENGALURU	66	A STATION 220 - C STATION	C STATION	8:30	8:36	0:06	LINE CLEAR AVAILED
531	17-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
532	17-Oct-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	8:34	8:40	0:06	LOAD CHANGE OVER
533	17-Oct-20	BENGALURU	66	HV1	KHB	9:53	9:55	0:02	LINE CLEAR AVAILED
534	17-Oct-20	BENGALURU	66	HV1	ATTIBELE	12:51	13:25	0:33	TRANSFORMER FAULT
535	17-Oct-20	BENGALURU	66	HV2	KHB	11:54	11:56	0:02	LINE CLEAR AVAILED
536	17-Oct-20	BENGALURU	66	HV2	NRS 220	11:17	11:26	0:09	LOAD CHANGE OVER
537	17-Oct-20	BENGALURU	66	HV2	NRS 220	15:51	15:55	0:04	LOAD CHANGE OVER
538	17-Oct-20	BENGALURU	66	HV2	VIJAYANAGARA	11:32	11:36	0:04	MAIN SUPPLY FAILURE
539	17-Oct-20	BENGALURU	66	HV2	VIJAYANAGARA	16:07	16:10	0:03	MAIN SUPPLY FAILURE
540	17-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	9:10	10:14	1:04	LINE CLEAR AVAILED
541	17-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	17:38	18:50	1:12	LINE CLEAR AVAILED
542	17-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:19	19:20	3:01	LINE FAULT
543	17-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	13:11	13:14	0:03	LINE FAULT
544	17-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
545	17-Oct-20	GULBARGA	110	HALBARGA-SANTAPUR	SANTHAPUR_110, DONGARGOA_110, KAMALNAGAR_110	21:43	23:37	1:54	LINE FAULT
546	17-Oct-20	GULBARGA	110	HV1	DEODURGA_110	10:55	11:40	0:45	LINE CLEAR AVAILED
547	17-Oct-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGWAT_110,VALKAMDINNI_110	5:14	5:29	0:15	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
548	17-Oct-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	2:43	2:56	0:13	LINE FAULT
549	17-Oct-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	2:43	2:56	0:13	LINE FAULT
550	17-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
551	17-Oct-20	GULBARGA	110	RAICHUR-SINDANOOR1	SIRWAR_110,VALKAMDINNI_110	6:18	6:25	0:07	LINE FAULT
552	17-Oct-20	GULBARGA	110	RAICHUR-SINDANOOR1	SIRWAR_110,VALKAMDINNI_110	23:22	23:31	0:09	LINE FAULT
553	17-Oct-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORWARTEMPLE_110	20:55	21:10	0:15	HAND TRIPPED
554	17-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	13:08	14:42	1:34	LINE CLEAR AVAILED
555	17-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:44	18:52	0:08	LINE FAULT
556	17-Oct-20	GULBARGA	110	SEDAM-VICTASAGAR CEMENTS_IPP	VICTASAGAR CEMENTS_IPP	6:30	6:35	0:05	LINE FAULT
557	17-Oct-20	GULBARGA	110	SEDAM-VICTASAGAR CEMENTS_IPP	VICTASAGAR CEMENTS_IPP	7:08(17.10.2020)			LINE OPEN : LINE FAULT
558	17-Oct-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRERAMNAGAR_110,MALLAPURA 110	20:10	20:20	0:10	LINE CLEAR AVAILED
559	17-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
560	17-Oct-20	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110,SIRWAR_110	5:15	5:25	0:10	MAIN SUPPLY FAILURE
561	17-Oct-20	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110,SIRWAR_110	21:20	21:25	0:05	MAIN SUPPLY FAILURE
562	17-Oct-20	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110,SIRWAR_110	21:55	22:00	0:05	MAIN SUPPLY FAILURE
563	17-Oct-20	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110,SIRWAR_110	22:25	22:40	0:15	MAIN SUPPLY FAILURE
564	17-Oct-20	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110,SIRWAR_110	22:55	23:00	0:05	MAIN SUPPLY FAILURE
565	17-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
566	17-Oct-20	GULBARGA	220	HV1	LINGASUGUR_220	21:18	22:25	1:07	TRANSFORMER FAULT
567	17-Oct-20	GULBARGA	220	HV2	ITTAGGI_220	15:31	15:37	0:06	TRANSFORMER FAULT
568	17-Oct-20	GULBARGA	220	HV2	LINGASUGUR_220	21:18	22:15	0:57	TRANSFORMER FAULT
569	17-Oct-20	GULBARGA	220	HV2	SEDAM_220	19:39	21:00	1:21	TRANSFORMER FAULT
570	17-Oct-20	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNDA_220	15:31	17:34	2:03	LINE FAULT
571	17-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	21:29(16.10.2020)	6:30(17.10.2020)	9:00HRS	LINE CHARGED
572	17-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	22:30(17.10.2020)			LINE OPEN: LINE CLEAR AVAILED
573	17-Oct-20	GULBARGA	220	LINGASUGUR-BAGEWADI1	B.BAGEWADI_220	23:32(17.10.2020)			LINE OPEN: LINE CLEAR AVAILED
574	17-Oct-20	GULBARGA	220	LINGASUGUR-BAGEWADI2	B.BAGEWADI_220	21:18	22:29	1:11	LINE FAULT
575	17-Oct-20	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSHTAGI_220	21:18	22:10	0:52	LINE FAULT
576	17-Oct-20	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	21:18	22:03	0:45	LINE FAULT
577	17-Oct-20	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	21:18	22:05	0:47	LINE FAULT
578	17-Oct-20	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	21:18	22:05	0:47	LINE FAULT
579	17-Oct-20	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHAPUR_220	21:18	22:22	1:04	LINE FAULT
580	17-Oct-20	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDHANOOR_220	21:18	22:20	1:02	LINE FAULT
581	17-Oct-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	21:18	22:13	0:55	MAIN SUPPLY FAILURE
582	17-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06(14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
583	17-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	17:31	17:45	0:14	LINE FAULT
584	17-Oct-20	HASSAN	66	HV1	HOLALUR_66	11:28	11:58	0:30	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
585	17-Oct-20	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	12:51	12:59	0:08	LINE FAULT
586	17-Oct-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	18:25	18:51	0:26	LINE FAULT
587	17-Oct-20	HASSAN	110	ALKOLA-MRS	ALKOLA_110	11:11	13:40	2:29	NFBC ISSUED
588	17-Oct-20	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	10:05	17:56	7:51	LINE CLEAR AVAILED
589	17-Oct-20	HASSAN	110	BARANG-ANVATTI	BARANGI_110	21:40	21:50	0:10	LINE FAULT
590	17-Oct-20	HASSAN	110	BARANG-SHR220	BARANGI_110	21:40	21:50	0:10	LINE FAULT
591	17-Oct-20	HASSAN	110	HV1	BARANGI_110	21:40	21:50	0:10	TRANSFORMER FAULT
592	17-Oct-20	HASSAN	110	HV1	KONDENAU_110	11:59	13:52	1:53	LINE CLEAR AVAILED
593	17-Oct-20	HASSAN	110	HV1	KULASHEKARA_110	13:26	14:10	0:44	LINE CLEAR AVAILED
594	17-Oct-20	HASSAN	110	HV2	ANANDPURA_110	10:05	17:56	7:51	LINE CLEAR AVAILED
595	17-Oct-20	HASSAN	110	HV2	BARANGI_110	21:40	21:50	0:10	TRANSFORMER FAULT
596	17-Oct-20	HASSAN	110	HV2	KONDENAU_110	11:59	13:52	1:53	LINE CLEAR AVAILED
597	17-Oct-20	HASSAN	110	HV2	KULASHEKARA_110	14:12	16:46	2:34	LINE CLEAR AVAILED
598	17-Oct-20	HASSAN	110	HV3	MRSMSG_220	12:47	13:35	0:48	HAND TRIPPED
599	17-Oct-20	HASSAN	110	HV4	MRSMSG_220	11:12	13:41	2:29	HAND TRIPPED
600	17-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
601	17-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
602	17-Oct-20	HASSAN	110	KONDENA-KADUR-ARSIKERE	KONDENAU_110	11:59	13:51	1:52	LINE CLEAR AVAILED
603	17-Oct-20	HASSAN	110	LV1	KEMAR_220	10:20	12:33	2:13	LINE CLEAR AVAILED
604	17-Oct-20	HASSAN	110	LV2	MRSMSG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
605	17-Oct-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:43	17:10	7:27	LINE CLEAR AVAILED
606	17-Oct-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	9:54	11:08	1:14	HAND TRIPPED
607	17-Oct-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	9:25	9:27	0:02	LOAD CHANGE OVER
608	17-Oct-20	HASSAN	220	HV1	KEMAR_220	10:20	12:32	2:12	LINE CLEAR AVAILED
609	17-Oct-20	HASSAN	220	KADUR-DABUSET	KADUR_220	19:45 (17.10.2020)			LINE OPEN : LINE FAULT
610	17-Oct-20	HASSAN	220	KADUR-DABUSET	KADUR_220	17:38	19:45	2:07	LINE FAULT
611	17-Oct-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:00	13:26	0:26	LINE FAULT
612	17-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:03 (17.10.2020)			LINE OPEN: LINE CLEAR AVAILED
613	17-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)	17:50 (17.10.2020)	162:42hrs	LINE CHARGED
614	17-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:34 (17.10.2020)			LINE OPEN: LINE CLEAR AVAILED
615	17-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:34 (16.10.2020)	9:17 (17.10.2020)	11:43hrs	LINE CHARGED
616	17-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
617	17-Oct-20	MYSURU	66	HARADANALLY(JAK) -LAXJEET	NO STATION EFFECTED	6:56	7:00	0:03	LINE FAULT
618	17-Oct-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATION EFFECTED	13:57	14:07	0:09	LINE FAULT
619	17-Oct-20	MYSURU	66	HV1	KHBCOLONY_66	12:35	13:51	1:16	LINE CLEAR AVAILED
620	17-Oct-20	MYSURU	66	HV1	CHANDRAVADI_66	15:41	16:55	1:14	TRANSFORMER FAULT
621	17-Oct-20	MYSURU	66	HV1	CHINAKURALI_66	10:23	18:00	7:36	LINE CLEAR AVAILED
622	17-Oct-20	MYSURU	66	HV1	SATHEGALA_66	12:00	18:16	6:15	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
623	17-Oct-20	MYSURU	66	HV1	TNARASIPURA_66	16:24	17:26	1:01	HAND TRIPPED
624	17-Oct-20	MYSURU	66	HV2	BGPURA_66	11:38	14:06	2:28	HAND TRIPPED
625	17-Oct-20	MYSURU	66	HV2	CHANDRAVADI_66	15:41	16:04	0:23	HAND TRIPPED
626	17-Oct-20	MYSURU	66	HV2	CHINAKURALI_66	10:23	18:00	7:36	LINE CLEAR AVAILED
627	17-Oct-20	MYSURU	66	HV2	SANTHEBACHALLI_66	13:29	15:49	2:20	LINE CLEAR AVAILED
628	17-Oct-20	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATION EFFECTED	17:57	18:03	0:05	LINE FAULT
629	17-Oct-20	MYSURU	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	11:20 (13/10/2020)	12:20 (17/10/2020)	97:00 HRS	LINE CHARGED
630	17-Oct-20	MYSURU	66	TN PURA-THAYURU	NO STATION EFFECTED	16:28	17:25	0:56	HAND TRIPPED
631	17-Oct-20	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	14:45	14:59	0:13	LINE FAULT
632	17-Oct-20	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	11:43	12:19	0:35	LINE FAULT
633	17-Oct-20	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	11:26	11:46	0:19	HAND TRIPPED
634	17-Oct-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	12:35	12:41	0:06	HAND TRIPPED
635	17-Oct-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	16:39	16:47	0:08	LINE CLEAR AVAILED
636	17-Oct-20	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	10:32	14:33	4:00	LINE CLEAR AVAILED
637	17-Oct-20	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:13	18:22	0:08	LINE FAULT
638	17-Oct-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:34	8:44	0:09	HAND TRIPPED
639	17-Oct-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:31	9:40	0:09	HAND TRIPPED
640	17-Oct-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:40	13:03	0:23	HAND TRIPPED
641	17-Oct-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:17	9:26	0:09	HAND TRIPPED
642	17-Oct-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:31	9:40	0:09	HAND TRIPPED
643	17-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:38	13:04	4:26	LINE CLEAR AVAILED
644	17-Oct-20	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	8:28	8:33	0:05	HAND TRIPPED
645	17-Oct-20	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	12:55	13:02	0:07	HAND TRIPPED
646	17-Oct-20	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66, GUDEKOTE_66	11:22	11:45	0:23	HAND TRIPPED
647	17-Oct-20	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	11:26	11:43	0:16	HAND TRIPPED
648	17-Oct-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	11:26	11:46	0:19	HAND TRIPPED
649	17-Oct-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:16	11:58	1:41	LINE CLEAR AVAILED
650	17-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:39	9:46	0:06	HAND TRIPPED
651	17-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:26	11:37	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
652	17-Oct-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDUR GA_66,PALLAGATTE_66, SOKKE_66	22:13	22:19	0:05	LINE FAULT
653	17-Oct-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDUR GA_66,PALLAGATTE_66, SOKKE_66	23:46	23:53	0:07	LINE FAULT
654	17-Oct-20	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	15:31	15:50	0:19	LINE FAULT
655	17-Oct-20	TUMKUR	66	TR-1	LINGADAHALLI_66(SHIMOGA)	10:13	18:46	8:32	LINE CLEAR AVAILED
656	17-Oct-20	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	9:23	13:02	3:38	LINE CLEAR AVAILED
657	17-Oct-20	TUMKUR	66	TR-2	HARAPPANAHALLI_66	14:17	14:24	0:07	TRANSFORMER FAULT
658	17-Oct-20	TUMKUR	66	TR-2	HOSADURGA_66	11:20	12:40	1:19	LINE CLEAR AVAILED
659	17-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	18:30	19:10	0:39	TRANSFORMER FAULT
660	17-Oct-20	TUMKUR	110	TR-1	MAYASANDRA_110	10:44	16:20	5:36	LINE CLEAR AVAILED
661	17-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
662	17-Oct-20	TUMKUR	110	TR-2	MAYASANDRA_110	10:43	16:20	5:36	LINE CLEAR AVAILED
663	17-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	12:19	13:05	0:46	HAND TRIPPED
664	17-Oct-20	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	12:20	13:06	0:45	HAND TRIPPED
665	17-Oct-20	TUMKUR	220	GUTUR_400-DAVANGERE SRS3	DAVANGERE_SRS_220	15:57	16:48	0:51	LINE CLEAR AVAILED
666	17-Oct-20	TUMKUR	220	NEELAGUNDA220kV- ITTAGI 220kV	NEELAGUNDA_220	15:31	17:27	1:56	LINE FAULT
667	17-Oct-20	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	9:23	13:02	3:38	LINE CLEAR AVAILED
668	18-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
669	18-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
670	18-Oct-20	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	9:05	14:16	5:11	LINE CLEAR AVAILED
671	18-Oct-20	BAGALKOT	110	110/11KV,HV2	HATTARAGI_110	9:05	14:16	5:11	LINE CLEAR AVAILED
672	18-Oct-20	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110	13:10	13:15	0:05	TRANSFORMER FAULT
673	18-Oct-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINAGAD_33, KARADI_33	12:04	12:10	0:06	TRANSFORMER FAULT
674	18-Oct-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED MK HUBLI_220	9:19	15:11	5:52	LOAD CHANGE OVER
675	18-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	0:45	6:35	5:50	HAND TRIPPED
676	18-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	9:19 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
677	18-Oct-20	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	4:53	6:56	2:03	HAND TRIPPED
678	18-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
679	18-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
680	18-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
681	18-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
682	18-Oct-20	BAGALKOT	110	HAVERI-HANAGAL(TILUVALLI)	HANAGAL_110	18:19	18:34	0:15	LINE FAULT
683	18-Oct-20	BAGALKOT	110	HIREBEVANUR-RODAGI(INDI-LACHAYAN)	RODAGI_110	16:44	19:33	2:49	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
684	18-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
685	18-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
686	18-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
687	18-Oct-20	BAGALKOT	110	MKHUBLI220- BAILHONGAL	BAILHONGAL_110	10:12	16:34	6:22	LINE CLEAR AVOIDED
688	18-Oct-20	BAGALKOT	110	MKHUBLI220- MKHUBLI2	MK HUBLI_110	14:00	16:53	2:53	LINE CLEAR AVOIDED
689	18-Oct-20	BAGALKOT	110	MKHUBLI220- MKHUBLI2	MK HUBLI_110	19:34	20:15	0:41	LINE CLEAR AVOIDED
690	18-Oct-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MK HUBLI_220	9:43	15:07	5:24	LINE CLEAR AVOIDED
691	18-Oct-20	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED MK HUBLI_220	9:43	18:08	8:25	LINE CLEAR AVOIDED
692	18-Oct-20	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
693	18-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
694	18-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
695	18-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
696	18-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
697	18-Oct-20	BAGALKOT	220	MKHUBLI- NARENDRA1	MK HUBLI_220	9:40	15:02	5:22	LINE CLEAR AVOIDED
698	18-Oct-20	BAGALKOT	220	MKHUBLI- NARENDRA2	MK HUBLI_220	9:41	15:04	5:23	LINE CLEAR AVOIDED
699	18-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:09 (17.10.2020)			LOAD CURTAILMENT
700	18-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:09 (17.10.2020)			LOAD CURTAILMENT
701	18-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
702	18-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH 2 SEC 2	12:43	12:45	0:02	TRANSFORMER FAULT
703	18-Oct-20	BENGALURU	66	HV1	NGEF	0:55	4:10	3:15	TRANSFORMER FAULT
704	18-Oct-20	BENGALURU	66	HV1	ATTIBELE	15:56	16:45	0:49	LINE CLEAR AVOIDED
705	18-Oct-20	BENGALURU	66	HV1	SURYANAGAR	10:45	11:15	0:29	LINE CLEAR AVOIDED
706	18-Oct-20	BENGALURU	66	HV2	NGEF	0:55	6:10	5:15	TRANSFORMER FAULT
707	18-Oct-20	BENGALURU	66	HV2	THAYALUR	1:30	1:34	0:04	TRANSFORMER FAULT
708	18-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	14:58	15:03	0:05	LINE FAULT
709	18-Oct-20	BENGALURU	66	RAJANUKUNTE - YELAHANAKA 220	RAJANUKUNTE	15:00	15:30	0:30	MAIN SUPPLY FAILURE
710	18-Oct-20	BENGALURU	66	T K HALLI 220 - LIMBAVALI	NO STATION AFFECTED	14:44	20:46	6:02	LINE CLEAR AVOIDED
711	18-Oct-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	14:44	15:03	0:19	LINE CLEAR AVOIDED
712	18-Oct-20	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	14:44	15:03	0:19	LINE CLEAR AVOIDED
713	18-Oct-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:44	15:03	0:19	LINE CLEAR AVOIDED
714	18-Oct-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:44	15:03	0:19	LINE CLEAR AVOIDED
715	18-Oct-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO RELAY OPERATED	14:44	15:03	0:19	LINE CLEAR AVOIDED
716	18-Oct-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	14:44	15:07	0:23	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
717	18-Oct-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HONNIGANAHALLI	14:44	15:13	0:29	LINE CLEAR AVAILED
718	18-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE1	NO STATION AFFECTED	6:05	8:44	2:38	LINE FAULT
719	18-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	14:55	15:28	0:32	LINE FAULT
720	18-Oct-20	BENGALURU	220	HOODY 220 - RAILWAYS 1	NO STATION AFFECTED	6:25	12:41	6:16	LINE FAULT
721	18-Oct-20	BENGALURU	220	HV2	T K HALLI	14:44	14:57	0:13	TRANSFORMER FAULT
722	18-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	13:12	13:27	0:15	LINE FAULT
723	18-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
724	18-Oct-20	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	8:01	8:06	0:05	LINE FAULT
725	18-Oct-20	GULBARGA	110	HV1	DEODURGA_110	11:45	14:15	2:30	LINE CLEAR AVAILED
726	18-Oct-20	GULBARGA	110	HV2	DEODURGA_110	12:30	14:30	2:00	LINE CLEAR AVAILED
727	18-Oct-20	GULBARGA	110	KAPNOOR-MADIYAL_110	MADIYAL_110	6:10	6:15	0:05	LINE FAULT
728	18-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
729	18-Oct-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORWARTEMPLE_110	16:20	17:30	1:10	LINE CLEAR AVAILED
730	18-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:15	13:10	0:55	LINE CLEAR AVAILED
731	18-Oct-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SREERAMNAGAR_110,MALLAPURA_110	21:05	21:15	0:10	LINE CLEAR AVAILED
732	18-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
733	18-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
734	18-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	22:30(17.10.2020)	7:01(18.10.2020)	8:31HRS	LINE CHARGED
735	18-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	23:19(18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
736	18-Oct-20	GULBARGA	220	LINGASUGUR-BAGEWADI1	B.BAGEWADI_220	23:32(17.10.2020)	14:05(18.10.2020)	14:33HRS	LINE CHARGED
737	18-Oct-20	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	3:20	21:57	18:37	MAIN SUPPLY FAILURE
738	18-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06(14.10.2020)			LINE OPEN: LINE CLEAR AVAILED
739	18-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:47	15:50	5:03	MAIN SUPPLY FAILURE
740	18-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	15:59	16:00	0:01	MAIN SUPPLY FAILURE
741	18-Oct-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:31	11:03	0:32	LINE FAULT
742	18-Oct-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:36	15:47	4:11	LINE FAULT
743	18-Oct-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	16:36	16:54	0:18	HAND TRIPPED
744	18-Oct-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:56	17:01	1:05	MAIN SUPPLY FAILURE
745	18-Oct-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:56	16:54	0:58	MAIN SUPPLY FAILURE
746	18-Oct-20	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	16:01	17:00	0:59	MAIN SUPPLY FAILURE
747	18-Oct-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	15:55	16:56	1:01	MAIN SUPPLY FAILURE
748	18-Oct-20	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	16:07	16:52	0:45	MAIN SUPPLY FAILURE
749	18-Oct-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	15:55	16:53	0:58	MAIN SUPPLY FAILURE
750	18-Oct-20	HASSAN	110	HV1	KEMAR_220	15:59	16:46	0:47	MAIN SUPPLY FAILURE
751	18-Oct-20	HASSAN	110	HV1	BIRUR_110	13:00	14:18	1:18	LINE CLEAR AVAILED
752	18-Oct-20	HASSAN	110	HV2	KEMAR_220	15:58	16:46	0:48	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
753	18-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
754	18-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
755	18-Oct-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:58	17:01	1:03	MAIN SUPPLY FAILURE
756	18-Oct-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:54	16:54	1:00	MAIN SUPPLY FAILURE
757	18-Oct-20	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	15:54	16:50	0:56	MAIN SUPPLY FAILURE
758	18-Oct-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	15:58	16:52	0:54	MAIN SUPPLY FAILURE
759	18-Oct-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	15:58	16:55	0:57	MAIN SUPPLY FAILURE
760	18-Oct-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	15:58	16:56	0:58	MAIN SUPPLY FAILURE
761	18-Oct-20	HASSAN	110	LV1	KEMAR_220	15:54 (18.10.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
762	18-Oct-20	HASSAN	110	LV2	MRSMG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
763	18-Oct-20	HASSAN	110	LV2	KEMAR_220	15:55	16:44	0:49	TRANSFORMER FAULT
764	18-Oct-20	HASSAN	110	LV3	KEMAR_220	15:55	16:44	0:49	TRANSFORMER FAULT
765	18-Oct-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:57	16:55	0:58	MAIN SUPPLY FAILURE
766	18-Oct-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	16:00	17:07	1:07	MAIN SUPPLY FAILURE
767	18-Oct-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:04	16:52	0:48	MAIN SUPPLY FAILURE
768	18-Oct-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	15:59	16:18	0:19	MAIN SUPPLY FAILURE
769	18-Oct-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	16:18	17:10	0:52	MAIN SUPPLY FAILURE
770	18-Oct-20	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:57	16:19	0:22	MAIN SUPPLY FAILURE
771	18-Oct-20	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	15:57	16:19	0:22	MAIN SUPPLY FAILURE
772	18-Oct-20	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	15:55	17:18	1:23	MAIN SUPPLY FAILURE
773	18-Oct-20	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	15:55	16:59	1:04	MAIN SUPPLY FAILURE
774	18-Oct-20	HASSAN	220	HV1	KEMAR_220	15:54 (18.10.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
775	18-Oct-20	HASSAN	220	HV2	KEMAR_220	15:54	16:41	0:47	TRANSFORMER FAULT
776	18-Oct-20	HASSAN	220	HV3	KEMAR_220	15:55	16:43	0:48	TRANSFORMER FAULT
777	18-Oct-20	HASSAN	220	KADUR-DABUSET	KADUR_220	19:45 (17.10.2020)	10:20 (18.10.2020)	14:35hrs	LINE CHARGED
778	18-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
779	18-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:03 (17.10.2020)	9:02 (18.10.2020)	14:59hrs	LINE CHARGED
780	18-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:54 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
781	18-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:34 (17.10.2020)	7:47 (18.10.2020)	9:13hrs	LINE CHARGED
782	18-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
783	18-Oct-20	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	14:01	14:10	0:08	LINE FAULT
784	18-Oct-20	MYSURU	66	HV1	HALAGUR_66	14:41	15:08	0:26	HAND TRIPPED
785	18-Oct-20	MYSURU	66	HV1	MADDUR_66	14:41	15:05	0:24	HAND TRIPPED
786	18-Oct-20	MYSURU	66	HV1	SATHEGALA_66	11:58	17:58	5:59	LINE CLEAR AVAILED
787	18-Oct-20	MYSURU	66	HV2	MADDUR_66	14:41	15:05	0:24	HAND TRIPPED
788	18-Oct-20	MYSURU	66	HV4	SFCSHIVA_66	15:06	15:17	0:11	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
789	18-Oct-20	MYSURU	66	MADHUVANAHALLI-HABBANI	NO STATION EFFECTED	9:54	10:03	0:08	LINE FAULT
790	18-Oct-20	MYSURU	66	MADHUVANAHALLI-HABBANI	NO STATION EFFECTED	11:40	11:55	0:15	LINE FAULT
791	18-Oct-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP 66	GOLDEN HATCHERIES_IPP_66	17:14	18:47	1:33	LINE CLEAR AVAILED
792	18-Oct-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	9:48	10:00	0:11	LINE FAULT
793	18-Oct-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:48	9:57	0:09	LINE FAULT
794	18-Oct-20	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	5:47	5:57	0:09	LINE FAULT
795	18-Oct-20	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	6:27	6:43	0:16	LINE FAULT
796	18-Oct-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	5:56	6:08	0:12	LINE FAULT
797	18-Oct-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	7:25	7:33	0:08	HAND TRIPPED
798	18-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	9:53	10:04	0:10	LINE FAULT
799	18-Oct-20	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	6:10	6:17	0:06	LINE FAULT
800	18-Oct-20	TUMKUR	66	NEELAGUNDA 220kv- HARAPANAHALLI-1	HARAPPANAHALLI_66	6:00	6:10	0:09	LINE FAULT
801	18-Oct-20	TUMKUR	66	TR-1	CHAWANAKUPPE_66	8:10	8:38	0:28	LINE CLEAR AVAILED
802	18-Oct-20	TUMKUR	66	TR-1	MAYAKONDA_66	9:49	13:21	3:31	MAIN SUPPLY FAILURE
803	18-Oct-20	TUMKUR	66	TR-2	TELAGI_66	7:38	8:31	0:53	LINE CLEAR AVAILED
804	18-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
805	18-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	2:19:30 PM(18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
806	18-Oct-20	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	7:44	10:36	2:51	LINE CLEAR AVAILED
807	19-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
808	19-Oct-20	BAGALKOT	110	110/11KV, HV1&HV2	KULIGOD_110	13:50	14:30	0:40	LINE CLEAR AVAILED
809	19-Oct-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:14	14:00	1:46	LINE CLEAR AVAILED
810	19-Oct-20	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	12:04	12:56	0:52	LINE CLEAR AVAILED
811	19-Oct-20	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	10:50	11:36	0:46	LINE CLEAR AVAILED
812	19-Oct-20	BAGALKOT	110	110/11KV, HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
813	19-Oct-20	BAGALKOT	110	110/11KV, HV3	KIADB BIJAPUR_110	10:07	10:17	0:10	TRANSFORMER FAULT
814	19-Oct-20	BAGALKOT	110	110/33KV, HV1	HUNGUND_110 & AMINAGAD, KARADI_33	10:06	10:12	0:06	TRANSFORMER FAULT
815	19-Oct-20	BAGALKOT	110	110/33KV, HV1	HUNGUND_110 & AMINAGAD, KARADI_33	12:48	12:55	0:07	TRANSFORMER FAULT
816	19-Oct-20	BAGALKOT	110	110/33KV, HV4	KULIGOD_110, TIGADI_33, ALLIMATTI_33	13:30	14:05	0:35	LINE CLEAR AVAILED
817	19-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	9:19 (18.10.2020)	8:55 (19.10.2020)	23:36hrs	TRANSFORMER CHARGED
818	19-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
819	19-Oct-20	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	10:46	18:35	7:49	LINE CLEAR AVAILED
820	19-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
821	19-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
822	19-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
823	19-Oct-20	BAGALKOT	110	KARAWAR-SOLARIS	STATION NOT AFFECTED KARAWAR_220	4:59	12:30	7:31	LINE FAULT
824	19-Oct-20	BAGALKOT	110	KARAWAR-SOLARIS	STATION NOT AFFECTED KARAWAR_220	10:06	12:30	2:24	LINE CLEAR AVAILED
825	19-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
826	19-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
827	19-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
828	19-Oct-20	BAGALKOT	110	RANEENNUR- HIREKERUR	HIREKERUR_110	10:38	10:44	0:06	LINE FAULT
829	19-Oct-20	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
830	19-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
831	19-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:28	16:02	5:34	NFBC ISSUED
832	19-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	21:46 (19.10.2020)			LOAD CURTAILMENT
833	19-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
834	19-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
835	19-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
836	19-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:09 (17.10.2020)	5:00 (19.10.2020)	46:51hrs	LOAD CURTAILMENT
837	19-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	5:43 (19.10.2020)			LOAD CURTAILMENT
838	19-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:09 (17.10.2020)	5:00 (19.10.2020)	46:51hrs	LOAD CURTAILMENT
839	19-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	5:43 (19.10.2020)			LOAD CURTAILMENT
840	19-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
841	19-Oct-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC1	ELECTRONIC CITY, INFOSYS (EHT)	8:34	8:40	0:06	LOAD CHANGE OVER
842	19-Oct-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	6:01	6:12	0:11	LINE FAULT
843	19-Oct-20	BENGALURU	66	HV1	Y HUNSENAHALLI	11:20	11:45	0:25	LINE CLEAR AVAILED
844	19-Oct-20	BENGALURU	66	HV1	NATIONAL COLLEGE	11:55	12:10	0:15	LINE CLEAR AVAILED
845	19-Oct-20	BENGALURU	66	HV2	SARIAPURA	11:48	11:50	0:02	LINE CLEAR AVAILED
846	19-Oct-20	BENGALURU	66	HV2	Y HUNSENAHALLI	11:20	11:45	0:25	LINE CLEAR AVAILED
847	19-Oct-20	BENGALURU	66	HV3	CHIKKABALLAPURA IND AREA	11:00	12:36	1:36	LINE CLEAR AVAILED
848	19-Oct-20	BENGALURU	66	HV3	BANASHANKARI	10:09	10:12	0:03	LINE CLEAR AVAILED
849	19-Oct-20	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMENAHALLI	4:57	5:04	0:07	LINE FAULT
850	19-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	10:55	12:10	1:15	LINE CLEAR AVAILED
851	19-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	16:15	16:26	0:11	LINE FAULT
852	19-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
853	19-Oct-20	GULBARGA	110	HALBARGA-KAMTHANA_110	KAMTHANA_110,HABSIKOTE_110	12:10	12:18	0:08	LINE FAULT
854	19-Oct-20	GULBARGA	110	HV1	RAJESHWAR_110	8:50	11:20	2:30	LINE CLEAR AVAILED
855	19-Oct-20	GULBARGA	110	HV2	NIRNA_110	11:25	11:30	0:05	LINE CLEAR AVAILED
856	19-Oct-20	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	13:15	13:20	0:05	LINE FAULT
857	19-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
858	19-Oct-20	GULBARGA	110	PDHALLI-BASAI_IPP	PDHALLI_110	5:50	6:05	0:15	LINE FAULT
859	19-Oct-20	GULBARGA	110	SEDAM-VICTASAGAR CEMENTS_IPP	VICTASAGAR CEMENTS_IPP	7:08(17.10.2020)	12:24(19.10.2020)	53:16HRS	LINE CHARGED
860	19-Oct-20	GULBARGA	110	SINDNOOR-CHITGUPPA_110	CHITGUPPA_110	11:40	11:50	0:10	LINE FAULT
861	19-Oct-20	GULBARGA	110	SINDNOOR-CHITGUPPA_110	CHITGUPPA_110	21:20	21:30	0:10	LINE FAULT
862	19-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			LINE OPEN: LINE CLEAR AVAILED
863	19-Oct-20	GULBARGA	220	HV2	SHAHAPUR_220	3:02	3:28	0:26	TRANSFORMER FAULT
864	19-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	23:19(18.10.2020)	07:36(19.10.2020)	8:17HRS	LINE CHARGED
865	19-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	2:35	6:37	4:02	LINE CLEAR AVAILED
866	19-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	18:30(19.10.2020)			LINE OPEN : LINE FAULT
867	19-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:06(14.10.2020)	18:30(19.10.2020)	127:04HRS	LINE CLEAR AVAILED
868	19-Oct-20	GULBARGA	220	SINDNOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)	13:10(19.10.2020)	600:20HRS	LINE CLEAR AVAILED
869	19-Oct-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	10:12	10:44	0:32	LINE FAULT
870	19-Oct-20	HASSAN	66	HASSN220-HN PURA	HASSAN_220	10:28	16:07	5:39	LINE CLEAR AVAILED
871	19-Oct-20	HASSAN	66	HV2	HOLALUR_66	22:26 (19.10.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
872	19-Oct-20	HASSAN	66	HV2	MAGGE_66	11:15	12:10	0:55	LINE CLEAR AVAILED
873	19-Oct-20	HASSAN	66	HV2	RAMPURA_66	11:00	18:20	7:20	LINE CLEAR AVAILED
874	19-Oct-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:30	10:35	0:05	HAND TRIPPED
875	19-Oct-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:30	10:35	0:05	HAND TRIPPED
876	19-Oct-20	HASSAN	110	HV1	PUTTUR_110	10:17	16:01	5:44	LINE CLEAR AVAILED
877	19-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
878	19-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
879	19-Oct-20	HASSAN	110	LV1	KEMAR_220	15:54 (18.10.2020)	14:35 (19.10.2020)	22:31hrs	LINE CHARGED
880	19-Oct-20	HASSAN	110	LV1	SHIRALKOPPA_220	9:35	11:03	1:28	HAND TRIPPED
881	19-Oct-20	HASSAN	110	LV2	MRSMG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
882	19-Oct-20	HASSAN	220	HV1	KEMAR_220	15:54 (18.10.2020)	14:35 (19.10.2020)	22:31hrs	LINE CHARGED
883	19-Oct-20	HASSAN	220	HV1	SHIRALKOPPA_220	9:35	11:03	1:28	HAND TRIPPED
884	19-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	8:56	12:06	3:10	LINE FAULT
885	19-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	12:11	15:46	3:35	HAND TRIPPED
886	19-Oct-20	HASSAN	220	SHRAVTY-SHIMOAGA3	sharavathy_gen	8:56	15:46	6:50	LINE FAULT
887	19-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REMARKS
888	19-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:54 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
889	19-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:14 (13.10.2020)	9:28 (19.10.2020)	152:14hrs	HAND TRIPPED
890	19-Oct-20	MYSURU	66	HV1	MADIKERI_66	11:50	12:40	0:50	LINE CLEAR AVAILED
891	19-Oct-20	MYSURU	66	JAKKANALLI-MADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 M NAGAMANGALA_66	10:25	15:10	4:45	LINE CLEAR AVAILED
892	19-Oct-20	MYSURU	66	JAKKANALLI-NAGAMANGLA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 M NAGAMANGALA_66	10:25	15:10	4:45	LINE CLEAR AVAILED
893	19-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	13:08	13:18	0:10	LINE FAULT
894	19-Oct-20	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	6:21	6:28	0:07	LINE FAULT
895	19-Oct-20	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	15:46	16:09	0:23	HAND TRIPPED
896	19-Oct-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	15:46	16:06	0:20	LINE FAULT
897	19-Oct-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	6:38	7:03	0:24	MAIN SUPPLY FAILURE
898	19-Oct-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	19:50	20:06	0:16	MAIN SUPPLY FAILURE
899	19-Oct-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	20:18	20:23	0:05	MAIN SUPPLY FAILURE
900	19-Oct-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:40	11:52	0:11	LINE FAULT
901	19-Oct-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:10	18:19	0:08	LINE FAULT
902	19-Oct-20	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	19:31	20:18	0:46	LINE FAULT
903	19-Oct-20	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	19:47	20:01	0:14	LINE FAULT
904	19-Oct-20	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	16:49	17:02	0:12	LINE FAULT
905	19-Oct-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAGIRI_66	12:01	12:16	0:14	HAND TRIPPED
906	19-Oct-20	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	RANGENAHALLI_66	19:31	19:34	0:02	LINE FAULT
907	19-Oct-20	TUMKUR	66	THALLAK 220KV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	23:34	23:38	0:04	HAND TRIPPED
908	19-Oct-20	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	23:35	23:41	0:06	HAND TRIPPED
909	19-Oct-20	TUMKUR	66	TR-1	KUKKAWADA_66	16:19	17:33	1:13	LINE CLEAR AVAILED
910	19-Oct-20	TUMKUR	66	TR-1	LINGDHALLI_66	6:46	6:51	0:05	TRANSFORMER FAULT
911	19-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	15:18	15:21	0:02	TRANSFORMER FAULT
912	19-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	15:56	16:00	0:04	TRANSFORMER FAULT
913	19-Oct-20	TUMKUR	66	TR-1(LV SIDE)	THALLAK_220	23:26	23:57	0:31	TRANSFORMER FAULT
914	19-Oct-20	TUMKUR	66	TR-2	AVAREGERE_66	15:46	16:09	0:23	HAND TRIPPED
915	19-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
916	19-Oct-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	14:19:30 (18.10.2020)	13:22:55(19.10 .2020)	23:03hrs	HAND TRIPPED