

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:12.05.2020 TO 18.05.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	12-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN, LINE FAULT
2	12-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED HIDIKAL DAM_110	16:19 (08.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
3	12-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	21:56 (10.05.2020)	18:08	44:12hrs	LINE CHARGED
4	12-May-2020	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
5	12-May-2020	BAGALKOT	110	SANKESHWAR-CHIKKODI	NO STATION EFFECTED SANKESHWAR_110	11:43 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
6	12-May-2020	BAGALKOT	110	HIDIKAL-ITNAL(RAIBAG)	NO STATION EFFECTED ITNAL_110	20:13 (11.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
7	12-May-2020	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	22:43 (11.05.2020)	15:42	16:12hrs	LINE CHARGED
8	12-May-2020	BAGALKOT	220	RANEENNUR-SHIRALKOPPA	NO STATION EFFECTED RANEENNUR_220	20:33 (11.05.2020)			LINE IS OPEN, LINE FAULT
9	12-May-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	22:19 (11.05.2020)	15:58	17:39	LINE CHARGED
10	12-May-2020	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	12:21	12:44	0:23	LINE CLEAR AVAILED
11	12-May-2020	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	12:04	13:08	1:04	LINE FAULT
12	12-May-2020	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	7:31	18:29	10:58	LINE CLEAR AVAILED
13	12-May-2020	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	18:20	18:45	0:25	TRANSFORMER FAULT
14	12-May-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	16:57	17:14	0:17	LINE FAULT
15	12-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	16:42	17:38	0:56	LINE CLEAR AVAILED
16	12-May-2020	BAGALKOT	220	NARENDRA2-BELGAUM	BELGAUM_220	16:42	17:30	0:48	LINE FAULT
17	12-May-2020	BAGALKOT	220	GADAG-HARTHI1&2	GADAG_220	10:50 (04.05.2020)	21:49	202:29hrs	LINE CHARGED
18	12-May-2020	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	10:13	15:58	5:45	LINE CLEAR AVAILED
19	12-May-2020	BAGALKOT	110	SOUDATTI220-RAMDURG1	RAMDURG_110	10:14	15:58	5:44	LINE CLEAR AVAILED
20	12-May-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	7:40	8:23	0:43	LINE CLEAR AVAILED
21	12-May-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:35	15:58	3:23	LINE CLEAR AVAILED
22	12-May-2020	BAGALKOT	110	HUKKERI-SANKESHWAR	SANKESHWAR_110	9:15	10:14	0:59	LINE CLEAR AVAILED
23	12-May-2020	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	20:33	20:42	0:09	TRANSFORMER FAULT
24	12-May-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(S)_110	10:39	11:54	1:15	TRANSFORMER FAULT
25	12-May-2020	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEVARGENNUR_33, LINGADALI(LIS)_33	12:25	14:55	2:30	LINE CLEAR AVAILED
26	12-May-2020	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	9:38(12.5.20)			LINE IS OPEN, LINE FAULT
27	12-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	19:44	20:27	0:43	LINE CLEAR AVAILED
28	12-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	19:44	20:27	0:43	LINE CLEAR AVAILED
29	12-May-2020	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	19:44	20:27	0:43	LINE CLEAR AVAILED
30	12-May-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	19:44	20:27	0:43	LINE CLEAR AVAILED
31	12-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	19:44	20:27	0:43	LINE CLEAR AVAILED
32	12-May-2020	BENGALURU	220	HOSKOTE 220 - BIAL 220	HOSKOTE 220	22:43	22:56	0:13	LINE CLEAR AVAILED
33	12-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	22:43	22:56	0:13	LINE CLEAR AVAILED
34	12-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	22:43	22:56	0:13	LINE CLEAR AVAILED
35	12-May-2020	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	22:43	22:56	0:13	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
36	12-May-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	22:43	22:56	0:13	LINE CLEAR AVAILED
37	12-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	22:43	22:56	0:13	LINE CLEAR AVAILED
38	12-May-2020	BENGALURU	66	HV2	BAGEPALLI	11:00	12:00	1:00	LINE CLEAR AVAILED
39	12-May-2020	BENGALURU	66	HV1	BAGEPALLI	12:00	12:50	0:50	LINE CLEAR AVAILED
40	12-May-2020	BENGALURU	66	SRINIVASAPURA - DALSANUR	SRINIVASAPURA	15:25	15:35	0:10	LINE CLEAR AVAILED
41	12-May-2020	BENGALURU	220	KIADB DB PURA 220 - GOWRIBIDANUR	KIADB DB PURA 220	14:20	14:45	0:25	LINE CLEAR AVAILED
42	12-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:01	6:11	0:10	LINE FAULT
43	12-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:01	6:11	0:10	LINE FAULT
44	12-May-2020	BENGALURU	66	HV2	TEMAGONDALU	10:33	16:05	5:31	TRANSFORMER FAULT
45	12-May-2020	BENGALURU	220	HV3	HOODY 220	11:45	17:45	6:00	LINE CLEAR AVAILED
46	12-May-2020	BENGALURU	220	HV4	HOODY 220	9:33	17:28	7:55	LINE CLEAR AVAILED
47	12-May-2020	BENGALURU	66	HV1	GOKULA	2:55	9:10	6:15	TRANSFORMER FAULT
48	12-May-2020	BENGALURU	66	HV2	BRIGADE METRO POLIS	13:55	14:04	0:09	LINE CLEAR AVAILED
49	12-May-2020	BENGALURU	66	KIADB DEVANAHALLI HARDWARE PARK 220 - SHELL(EHT)	SHELL(EHT)	19:45	21:06	1:21	MAIN SUPPLY FAILURE
50	12-May-2020	BENGALURU	66	KIADB DEVANAHALLI HARDWARE PARK 220 - BPH MINI IRRIGATION(EHT)	BPH MINI IRRIGATION(EHT)	19:45	21:06	1:21	MAIN SUPPLY FAILURE
51	12-May-2020	BENGALURU	220	HOSKOTE 220 - KIADB DEVANAHALLI HARDWARE PARK 220	HOSKOTE 220	19:44:00(12.5.2020)			LINE IS OPEN, LINE FAULT
52	12-May-2020	BENGALURU	220	HOSKOTE 220 - BIAL 220	NO STATION AFFECTED	19:44:00(12.5.2020)	2:17	5:33HRS	LINE CHARGED
53	12-May-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	22:46:00(12.5.2020)			LINE IS OPEN, LINE CLEAR AVAILED
54	12-May-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	KIADB DEVANAHALLI HARDWARE PARK 220	19:44:02(12.05.2020)			LINE IS OPEN, LINE FAULT
55	12-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
56	12-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
57	12-May-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	19:05(11.5.20)	16:21	21:00hrs	LINE CHARGED
58	12-May-2020	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	13:45	15:45	2:00	LINE CLEAR AVAILED
59	12-May-2020	GULBARGA	110	RAICHUR-SHAHPUR1	DEODURGA_110, GABUR_110	21:10	21:50	0:40	LINE FAULT
60	12-May-2020	GULBARGA	110	HV3	DEODURGA_110	18:32	18:41	0:09	TRANSFORMER FAULT
61	12-May-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	21:21	21:30	0:09	LINE FAULT
62	12-May-2020	GULBARGA	110	HV2	HALLIKHED_110	16:00	19:55	3:55	LINE CLEAR AVAILED
63	12-May-2020	GULBARGA	110	SINDHANOOR220-NIRLOOTI_IPP	SIDHANOOR_220	2:45	2:55	0:10	LINE FAULT
64	12-May-2020	GULBARGA	110	HV2	SHAHAPUR_220	8:50	8:58	0:08	TRANSFORMER FAULT
65	12-May-2020	GULBARGA	110	HV2	SHAHAPUR_220	9:41	9:52	0:11	TRANSFORMER FAULT
66	12-May-2020	GULBARGA	110	HV2	SHAHAPUR_220	18:38	18:50	0:12	TRANSFORMER FAULT
67	12-May-2020	GULBARGA	110	HV2	MANVI_110	11:48	12:46	0:58	LINE CLEAR AVAILED
68	12-May-2020	HASSAN	400	UPCL-HASSAN2	NO STATION AFFECTED	18:13 (11.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
69	12-May-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	0:25	1:07	0:42	LINE FAULT
70	12-May-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:25	1:12	0:47	LINE FAULT
71	12-May-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	0:18	12:23	12:05	LINE FAULT
72	12-May-2020	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	11:37	14:20	2:43	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
73	12-May-2020	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	11:37	14:20	2:43	LINE CLEAR AVAILED
74	12-May-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	0:17	1:17	1:00	LINE FAULT
75	12-May-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:17	1:13	0:56	LINE FAULT
76	12-May-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	0:18	12:27	12:09	LINE FAULT
77	12-May-2020	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	0:33	1:16	0:43	LINE FAULT
78	12-May-2020	HASSAN	110	KEMAR-MOODABIDRE	KEMAR_220	0:33	1:27	0:54	LINE FAULT
79	12-May-2020	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	10:08	12:09	2:01	LINE CLEAR AVAILED
80	12-May-2020	HASSAN	110	KEMAR-BELMAN	KEMAR_220	10:54	10:59	0:05	LINE FAULT
81	12-May-2020	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	0:11	1:50	1:39	LINE FAULT
82	12-May-2020	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	0:34	1:20	0:46	MAIN SUPPLY FAILURE
83	12-May-2020	HASSAN	110	HV1	HALADY_110	10:05	12:34	2:29	LINE CLEAR AVAILED
84	12-May-2020	HASSAN	110	HV1	BAIKAMPADI_110	11:32	13:42	2:10	LINE CLEAR AVAILED
85	12-May-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	0:33	1:19	0:46	MAIN SUPPLY FAILURE
86	12-May-2020	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	0:33	1:18	0:45	MAIN SUPPLY FAILURE
87	12-May-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	0:33	1:20	0:47	MAIN SUPPLY FAILURE
88	12-May-2020	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	0:48	0:52	0:04	HAND TRIPPED
89	12-May-2020	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	10:33	10:37	0:04	HAND TRIPPED
90	12-May-2020	HASSAN	110	HV1	KUNDAPURA_110	11:08	14:10	3:02	LINE CLEAR AVAILED
91	12-May-2020	HASSAN	110	HV2	KUNDAPURA_110	9:24	14:10	4:46	LINE CLEAR AVAILED
92	12-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:54	9:58	0:04	HAND TRIPPED
93	12-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	12:11	12:38	0:27	HAND TRIPPED
94	12-May-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	0:38	1:32	0:54	MAIN SUPPLY FAILURE
95	12-May-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	0:38	1:32	0:54	MAIN SUPPLY FAILURE
96	12-May-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_110	12:03	13:53	1:50	LINE CLEAR AVAILED
97	12-May-2020	HASSAN	110	HV1	SHIRALKOPPA_110	11:05	11:35	0:30	LINE CLEAR AVAILED
98	12-May-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:43	11:21	0:38	LINE FAULT
99	12-May-2020	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	17:29	18:00	0:31	LINE CLEAR AVAILED
100	12-May-2020	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	10:04	14:56	4:52	MAIN SUPPLY FAILURE
101	12-May-2020	HASSAN	66	HV1	DODDAKADANUR_66	10:04	14:59	4:55	MAIN SUPPLY FAILURE
102	12-May-2020	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	10:04	15:02	4:58	MAIN SUPPLY FAILURE
103	12-May-2020	HASSAN	66	HV1	HALLIMYSORE_66	9:58	14:59	5:01	MAIN SUPPLY FAILURE
104	12-May-2020	HASSAN	66	HV1	SINGAPURA_66	7:28	7:38	0:10	HAND TRIPPED
105	12-May-2020	HASSAN	66	HV2	SINGAPURA_66	7:29	7:38	0:09	HAND TRIPPED
106	12-May-2020	MYSURU	66	BANNUR-MALIYUR	MALIYURU_66	10:00	16:19	6:19	NFBC ISSUED
107	12-May-2020	MYSURU	66	BASARALU-HAMPAPURA	NO STATIONS	12:00	16:08	4:08	HAND TRIPPED
108	12-May-2020	MYSURU	66	HV2	COWDALLI_66	11:39	11:46	0:07	TRANSFORMER FAULT
109	12-May-2020	MYSURU	66	HV2	COWDALLI_66	12:30	12:41	0:11	TRANSFORMER FAULT
110	12-May-2020	MYSURU	66	DB HALLI-TUBINAKERE	DODDABYADARAHALLI_66	10:20	17:06	6:46	LINE CLEAR AVAILED
111	12-May-2020	MYSURU	66	KIRUGAVLU-MALIYUR	MALIYURU_66	10:02	16:27	6:25	NFBC ISSUED
112	12-May-2020	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBKERE_66	6:01	6:10	0:09	LINE FAULT
113	12-May-2020	MYSURU	66	HV5	SFCSHIVA_66	13:54	18:27	4:33	HAND TRIPPED
114	12-May-2020	MYSURU	66	TALAKADU-ADANI	NO STATIONS	9:28	17:04	7:36	LINE CLEAR AVAILED
115	12-May-2020	MYSURU	66	TALAKADU-PARINAMIPURA	THALAKADU_66	9:28	16:53	7:25	LINE CLEAR AVAILED
116	12-May-2020	MYSURU	66	TALAKADU-CHANDALLY	NO STATIONS	9:28	17:04	7:36	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
117	12-May-2020	MYSURU	66	TN PURA-THAYUR	TNARASIPURA_66	13:03	13:45	0:41	LINE CLEAR AVAILED
118	12-May-2020	MYSURU	66	TUBINAKERE-PANDAVAPURA	NO STATIONS	10:28	11:50	1:21	LINE CLEAR AVAILED
119	12-May-2020	MYSURU	66	TUBINAKERE-SR PATNA	NO STATIONS	11:53	14:30	2:37	LINE CLEAR AVAILED
120	12-May-2020	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	16:04	16:23	0:18	LINE FAULT
121	12-May-2020	TUMKUR	220	CHITRADURGA 220kV-THALLAK	CHITRADURGA_220	10:37	11:40	1:02	LINE FAULT
122	12-May-2020	TUMKUR	220	CHITRADURGA 220kV-THALLAK	CHITRADURGA_220	18:55	18:57	0:01	LINE FAULT
123	12-May-2020	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	10:02	10:34	0:32	LINE FAULT
124	12-May-2020	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	11:23	15:57	4:34	LINE CLEAR AVAILED
125	12-May-2020	TUMKUR	220	THALLAK 220kV-CHITRADURGA	THALLAKK_220	10:37	11:54	1:17	LINE FAULT
126	12-May-2020	TUMKUR	220	THALLAK 220kV-CHITRADURGA	THALLAKK_220	15:20	18:54	3:34	LINE CLEAR AVAILED
127	12-May-2020	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	6:50	18:24	11:33	LINE CLEAR AVAILED
128	12-May-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	16:22	18:59	2:36	HAND TRIPPED
129	12-May-2020	TUMKUR	110	TR-2	KADEHALLI_110	0:12	0:31	0:18	TRANSFORMER FAULT
130	12-May-2020	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	11:44	12:31	0:46	LINE CLEAR AVAILED
131	12-May-2020	TUMKUR	66	TR-1	BRAHMASANDRA_66	11:26	12:03	0:37	LINE CLEAR AVAILED
132	12-May-2020	TUMKUR	66	TR-2	BRAHMASANDRA_66	12:06	12:36	0:30	LINE CLEAR AVAILED
133	12-May-2020	TUMKUR	66	TR-1	CHAWANAKUPPE_66	5:39	5:49	0:10	TRANSFORMER FAULT
134	12-May-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	1:34	1:46	0:12	LINE FAULT
135	12-May-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:00	12:16	0:15	HAND TRIPPED
136	12-May-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	12:06	12:33	0:27	LINE CLEAR AVAILED
137	12-May-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66	12:00	12:09	0:09	LINE FAULT
138	12-May-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66	14:09	14:18	0:09	LINE FAULT
139	12-May-2020	TUMKUR	66	TR-1	KALAMARANAHALLI_66	6:28	7:16	0:47	LINE CLEAR AVAILED
140	12-May-2020	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	9:30	9:36	0:05	HAND TRIPPED
141	12-May-2020	TUMKUR	66	TR-1	PAVAGADA_220	3:12	3:16	0:04	TRANSFORMER FAULT
142	12-May-2020	TUMKUR	66	THALLAK 220kV-CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	8:01	12:44	4:43	LINE CLEAR AVAILED
143	12-May-2020	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	10:37	10:59	0:22	TRANSFORMER FAULT
144	12-May-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1 & 2	WELSPUNSOLAR1_IPP_66	10:37	11:04	0:27	LINE FAULT
145	12-May-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:09	15:54	4:45	LINE CLEAR AVAILED
146	13-May-2020	BAGALKOT	220	BIDNAL-HARTHI1	BIDNAL_220	9:50:00 PM(13.5.20)			LINE IS OPEN, LINE FAULT
147	13-May-2020	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	10:49:00 PM(13.5.20)			LINE IS OPEN, LINE FAULT
148	13-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	9:40:00 AM(13.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
149	13-May-2020	BAGALKOT	110	SOUDATTI-RAMDURG2	RAMDURG_110	11:07	15:53	4:46	LINE CLEAR AVAILED
150	13-May-2020	BAGALKOT	110	SOUDATTI-SOUDATTI2	SOUDATTI_110	11:11	16:01	4:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	13-May-2020	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	9:41	13:43	4:02	LINE CLEAR AVAILED
152	13-May-2020	BAGALKOT	220	220/110KV, HV2&LV2	RANEENNUR_220	13:09	13:14	0:05	LINE CLEAR AVAILED
153	13-May-2020	BAGALKOT	110	RANEENNUR- HONNATTI	HONNATTI_110	11:26	13:23	1:57	LINE CLEAR AVAILED
154	13-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	3:08:00 PM(13.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
155	13-May-2020	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	11:33	11:56	0:23	LINE CLEAR AVAILED
156	13-May-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	17:28	17:33	0:05	TRANSFORMER FAULT
157	13-May-2020	BAGALKOT	220	KARWAR-KADRA1	KARWAR_220	9:41:00 AM(13.5.20)			LINE IS OPEN, LINE FAULT
158	13-May-2020	BAGALKOT	110	SHIRGUPPI SUGARS- KAGAWAD	KAGAWAD_110	4:40	4:47	0:07	LINE FAULT
159	13-May-2020	BAGALKOT	110	110/133KV, HV2	GULEDAGUDDA_110, KAMATAGI_33, SHIRUR_33	19:18	19:25	0:07	TRANSFORMER FAULT
160	13-May-2020	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	11:49	13:15	1:26	LINE CLEAR AVAILED
161	13-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	11:41	12:51	1:10	LINE FAULT
162	13-May-2020	BENGALURU	220	HV1	HOODY 220	10:50	15:30	4:40	LINE CLEAR AVAILED
163	13-May-2020	BENGALURU	220	HV2	HOODY 220	9:40	15:59	6:19	LINE CLEAR AVAILED
164	13-May-2020	BENGALURU	220	BEGUR 220 - HODDY 220	NO STATION AFFECTED	11:41	12:51	1:10	LINE FAULT
165	13-May-2020	BENGALURU	220	HV1	KIADB	11:15	13:02	1:47	LINE CLEAR AVAILED
166	13-May-2020	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	13:43	13:58	0:15	LINE FAULT
167	13-May-2020	BENGALURU	66	HV1	DODDABELAVANGALA	9:30	10:38	1:08	LINE CLEAR AVAILED
168	13-May-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	2:33	2:40	0:07	LOAD CHANGE OVER
169	13-May-2020	BENGALURU	66	HV1	HAROBEL	5:41	6:08	0:27	TRANSFORMER FAULT
170	13-May-2020	BENGALURU	66	HV2	HAROBEL	5:41	6:08	0:27	TRANSFORMER FAULT
171	13-May-2020	BENGALURU	66	HAROBEL - CHUNCHIDODDI	NO STATION AFFECTED	5:40	7:05	1:25	LINE FAULT
172	13-May-2020	BENGALURU	66	ANCHEPALYA - TG HALLI	HOSPALYA, VG DODDI, MAGADI, SOLUR, TG HALLI	11:03	15:35	4:32	LINE CLEAR AVAILED
173	13-May-2020	BENGALURU	66	HV1	MUDIYANUR	14:15	14:19	0:03	LINE CLEAR AVAILED
174	13-May-2020	BENGALURU	66	HV2	MUDIYANUR	14:20	14:30	0:10	LINE CLEAR AVAILED
175	13-May-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	7:27	7:40	0:13	LINE FAULT
176	13-May-2020	BENGALURU	220	HOSKOTE 220 - BIAL 220	NO STATION AFFECTED	19:44:00(12.5.2020)	2:17	6:32HRS	LINE CHARGED
177	13-May-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	22:46:00(12.5.2020)	2:34	3:48HRS	LINE CHARGED
178	13-May-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	19:44:02(12.05.2020)	2:17	6:32 HRS	LINE CHARGED
179	13-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
180	13-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
181	13-May-2020	GULBARGA	110	HV1	MADIYAL_110	7:45	8:20	0:35	LINE CLEAR AVAILED
182	13-May-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	4:22	4:32	0:10	LINE FAULT
183	13-May-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	4:56	5:17	0:21	LINE FAULT
184	13-May-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	SIRUGUPPA_110, TEKKALKOTE_110, DHAHDESUGUR_110, NSL SUGARS_IPP	20:55	21:05	0:10	LINE FAULT
185	13-May-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110	1:58	2:06	0:08	LINE FAULT
186	13-May-2020	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	1:58	10:50	8:52	LINE FAULT
187	13-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:55	23:05	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
188	13-May-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:13 (11.05.2020)	13:54	43:40Hrs	LINE CHARGED
189	13-May-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:46 (13.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
190	13-May-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:53	13:11	0:18	LINE FAULT
191	13-May-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:49	13:03	0:14	LINE FAULT
192	13-May-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:18	18:02	0:44	LINE FAULT
193	13-May-2020	HASSAN	220	HV2	PUTTUR_220	10:26	12:01	1:35	LINE CLEAR AVAILED
194	13-May-2020	HASSAN	110	LV2	PUTTUR_220	10:26	12:02	1:36	LINE CLEAR AVAILED
195	13-May-2020	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	10:54	13:14	2:20	LINE CLEAR AVAILED
196	13-May-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	15:28	15:38	0:10	LINE FAULT
197	13-May-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:45	12:05	0:20	LINE CLEAR AVAILED
198	13-May-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:37	14:35	0:58	HAND TRIPPED
199	13-May-2020	HASSAN	110	HV1	ANAVATTI_110	12:05	14:35	2:30	LINE CLEAR AVAILED
200	13-May-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	11:51	12:12	0:21	LINE CLEAR AVAILED
201	13-May-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:17	12:12	1:55	NFBC ISSUED
202	13-May-2020	HASSAN	110	HV2	HOSANGADI_110	9:31	13:41	4:10	LINE CLEAR AVAILED
203	13-May-2020	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	17:05	19:47	2:42	LINE FAULT
204	13-May-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:17	12:12	1:55	LINE CLEAR AVAILED
205	13-May-2020	HASSAN	110	HV3	KONAJE_110	10:00	14:06	4:06	LINE CLEAR AVAILED
206	13-May-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:05	17:37	0:32	MAIN SUPPLY FAILURE
207	13-May-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:36	19:17	5:41	LINE FAULT
208	13-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:00	17:43	8:43	LINE CLEAR AVAILED
209	13-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	17:43	18:00	0:17	LINE FAULT
210	13-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	18:00	21:35	3:35	LINE CLEAR AVAILED
211	13-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	21:35 (13.05.2020)			LINE IS OPEN, LINE FAULT
212	13-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:00	17:43	8:43	LINE CLEAR AVAILED
213	13-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	19:11	21:35	2:24	LINE CLEAR AVAILED
214	13-May-2020	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66 & MALIYURU_66	10:10	11:08	0:58	HAND TRIPPED
215	13-May-2020	MYSURU	66	VAJMANGALA-KADKOLA 1	AYRALLI_66 & MARADIHUNDI_66	10:10	11:02	0:52	HAND TRIPPED
216	13-May-2020	MYSURU	66	VAJMANGALA-KADKOLA 2	AYRALLI_66 & MARADIHUNDI_66	10:10	11:04	0:54	HAND TRIPPED
217	13-May-2020	MYSURU	66	VAJMANGALA-MEGALAPURA	NO STATIONS EFFECTED	10:10	11:03	0:53	HAND TRIPPED
218	13-May-2020	MYSURU	66	BG PURA -CHANDALLI	CHANDALLI_66	9:55	16:00	6:05	NFBC ISSUED
219	13-May-2020	MYSURU	66	MANDYA -KK HALLI	KADKOTHANAHALLI_66, MALAVALLI_66 & HADLI_66	16:10	16:20	0:10	LINE FAULT
220	13-May-2020	MYSURU	66	HEBBANI -MEGALAPURA	MEGALAPURA_66, THUMBLA_66, CHIDRAVALLI_66, VYASRAJPURA_66 , BGPURA_66 & GARGESHWARI_66	10:28	10:45	0:17	LINE FAULT
221	13-May-2020	MYSURU	66	HEBBANI -MEGALAPURA	MEGALAPURA_66, THUMBLA_66, CHIDRAVALLI_66, VYASRAJPURA_66 , BGPURA_66 & GARGESHWARI_66	10:15	10:25	0:10	LINE FAULT
222	13-May-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	18:58	20:24	1:25	LINE FAULT
223	13-May-2020	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	6:50	17:42	10:51	LINE CLEAR AVAILED
224	13-May-2020	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	11:22	18:57	7:35	LINE CLEAR AVAILED
225	13-May-2020	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	11:22	18:58	7:36	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
226	13-May-2020	TUMKUR	220	TR-2	NEELAGUNDA_220	13:15	13:56	0:40	LINE CLEAR AVAILED
227	13-May-2020	TUMKUR	110	TR-1	BIDARE_110	22:12	22:16	0:04	TRANSFORMER FAULT
228	13-May-2020	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:45	19:08	1:22	LINE FAULT
229	13-May-2020	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	17:45	18:56	1:10	LINE FAULT
230	13-May-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:46	18:55	1:08	LINE FAULT
231	13-May-2020	TUMKUR	110	TR-2	SAMPIGE_110	20:28	20:49	0:21	TRANSFORMER FAULT
232	13-May-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	18:53	19:05	0:11	LINE FAULT
233	13-May-2020	TUMKUR	66	TR-1	BELADARA_66	10:50	18:03	7:13	LINE CLEAR AVAILED
234	13-May-2020	TUMKUR	66	TR-1	BENKIKERE_66	11:20	12:12	0:52	LINE CLEAR AVAILED
235	13-May-2020	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	12:11	12:39	0:28	HAND TRIPPED
236	13-May-2020	TUMKUR	66	TR-1	HANAGAL_66	5:28(13.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
237	13-May-2020	TUMKUR	66	TR-1	HANAGAL_66	15:34	17:22	1:47	LINE CLEAR AVAILED
238	13-May-2020	TUMKUR	66	TR-1	HARIHAR_66	19:20	19:34	0:13	TRANSFORMER FAULT
239	13-May-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	14:18	14:23	0:04	LINE CLEAR AVAILED
240	13-May-2020	TUMKUR	66	KUNDUR- RSOLAR	RENEW WIND ENERGY_IPP_66	9:45	17:01	7:15	LINE CLEAR AVAILED
241	13-May-2020	TUMKUR	66	TR-2	MATHOD_66	6:47	6:59	0:12	TRANSFORMER FAULT
242	13-May-2020	TUMKUR	66	TR-2	MATHOD_66	7:15	7:23	0:08	TRANSFORMER FAULT
243	13-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAM AGIRI_66	12:23	12:36	0:13	LINE FAULT
244	14-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN, LINE FAULT
245	14-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED HIDIKAL DAM_110	16:19 (08.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
246	14-May-2020	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
247	14-May-2020	BAGALKOT	110	SANKESHWAR-CHIKKODI	NO STATION EFFECTED SANKESHWAR_110	11:43 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
248	14-May-2020	BAGALKOT	110	HIDIKAL-ITNAL(RAIBAG)	NO STATION EFFECTED ITNAL_110	20:13 (11.05.2020)	20:20	72:07hrs	LINE CHARGED
249	14-May-2020	BAGALKOT	220	BIDNAL-HARTHI1	NO STATION EFFECTED BIDNAL_220	21:50 (13.05.2020)			LINE IS OPEN, LINE FAULT
250	14-May-2020	BAGALKOT	220	BIDNAL-SOUDATTI	NO STATION EFFECTED BIDNAL_220	22:49 (13.05.2020)	9:48	10:59hrs	LINE CHARGED
251	14-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	9:40 (13.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
252	14-May-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	15:08 (13.05.2020)	23:24	32:16hrs	LINE CLEAR AVAILED
253	14-May-2020	BAGALKOT	220	KARWAR-KADRA1	NO STATION EFFECTED KARWAR_220	9:41 (13.05.2020)	16:11	35:30hrs	LINE CHARGED
254	14-May-2020	BAGALKOT	110	SIGIKERI-ACHANUR	ACHANUR_110	9:15	14:26	5:11	HAND TRIPPED
255	14-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	ACHANUR_110	2:26(14.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
256	14-May-2020	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	6:59(14.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
257	14-May-2020	BAGALKOT	220	AMBEWADI-NAGJHARI1	AMBEWADI_220	18:32(14.5.20)			LINE IS OPEN, LINE FAULT
258	14-May-2020	BAGALKOT	110	AMBEWADI- (NK2)KAVALWADA	KAVALWADA_110	17:14	17:32	0:18	LINE FAULT
259	14-May-2020	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	22:21	22:29	0:08	TRANSFORMER FAULT
260	14-May-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	8:50	14:18	5:28	LINE CLEAR AVAILED
261	14-May-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	9:00	14:18	5:18	LINE CLEAR AVAILED
262	14-May-2020	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:03	18:05	1:02	LINE CLEAR AVAILED
263	14-May-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	9:34	10:03	0:29	LINE FAULT
264	14-May-2020	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR_110	5:34	5:44	0:10	LINE FAULT
265	14-May-2020	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	15:30	15:56	0:26	LINE FAULT
266	14-May-2020	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	14:22	15:20	0:58	LINE CLEAR AVAILED
267	14-May-2020	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	16:50(14.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
268	14-May-2020	BAGALKOT	220	GADAG-HARTHI1&2	GADAG_220	11:47(14.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
269	14-May-2020	BAGALKOT	220	220/110KV,HV3&LV3	GADAG_220	16:49	18:44	1:55	HAND TRIPPED
270	14-May-2020	BAGALKOT	220	KARWAR-KADRA2	KARWAR_220	12:20	16:10	3:50	LINE CLEAR AVAILED
271	14-May-2020	BAGALKOT	110	SOLARIS-KARWAR	KARWAR_220	12:20	16:14	3:54	HAND TRIPPED
272	14-May-2020	BAGALKOT	110	220/110KV,LV1	KARWAR_220	12:18	16:13	3:55	HAND TRIPPED
273	14-May-2020	BAGALKOT	110	KARWAR-ARGA	ARGA_110	12:18	12:19	0:01	HAND TRIPPED
274	14-May-2020	BAGALKOT	110	KARWAR-ARGA	ARGA_110	16:10	16:20	0:10	HAND TRIPPED
275	14-May-2020	BAGALKOT	110	110/11KV, HV1	ZALKI_110	14:10	14:17	0:07	HAND TRIPPED
276	14-May-2020	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	17:59	21:01	3:02	LINE FAULT
277	14-May-2020	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	9:29	19:04	9:35	LINE CLEAR AVAILED
278	14-May-2020	BAGALKOT	110	110/33KV, HV3	RON_110, MUSIGERI_33	14:05	15:55	1:50	LINE CLEAR AVAILED
279	14-May-2020	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	9:27	10:28	1:01	LINE CLEAR AVAILED
280	14-May-2020	BAGALKOT	110	NARENDRA1-MRUTHYUNJAY NAGAR	MRUTHYUN JAY NAGAR_110	10:15	16:15	6:00	LINE CLEAR AVAILED
281	14-May-2020	BAGALKOT	110	HUNGUND -KUDALSANGAM	KUDALSANGAM_110	5:53	6:05	0:12	MAIN SUPPLY FAILURE
282	14-May-2020	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	13:39	16:42	3:03	LINE CLEAR AVAILED
283	14-May-2020	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	18:12	18:20	0:08	TRANSFORMER FAULT
284	14-May-2020	BAGALKOT	110	SAVANUR- RAMANKOPPA (SHIGGOAN)	SHIGGOAN_110	23:35(14.5.20)			LINE IS OPEN, LINE FAULT
285	14-May-2020	BENGALURU	66	HV2	B G ROAD	13:40	13:45	0:05	LINE CLEAR AVAILED
286	14-May-2020	BENGALURU	66	HV2	B G ROAD	17:21	17:25	0:04	LOAD CHANGE OVER
287	14-May-2020	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	17:53	23:15	5:22	LINE FAULT
288	14-May-2020	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	23:15	23:29	0:14	LINE FAULT
289	14-May-2020	BENGALURU	66	HV1	HAROBEL	14:38	15:01	0:23	LINE CLEAR AVAILED
290	14-May-2020	BENGALURU	66	HV1	ISRO LAYOUT	10:20	10:25	0:05	LINE CLEAR AVAILED
291	14-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	16:58	17:23	0:25	LINE FAULT
292	14-May-2020	BENGALURU	66	HV1	SM MANGALA	11:30	13:41	2:11	LINE CLEAR AVAILED
293	14-May-2020	BENGALURU	66	HV2	SM MANGALA	11:30	13:42	2:12	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
294	14-May-2020	BENGALURU	66	HV2	NARASAPURA	15:08	15:39	0:30	TRANSFORMER FAULT
295	14-May-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:18	18:20	0:01	LOAD CHANGE OVER
296	14-May-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	1:52	2:02	0:09	LINE FAULT
297	14-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
298	14-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
299	14-May-2020	GULBARGA	220	HUMNABAD-HALBURGA	HALBURGA_220	16:15	17:37	1:22	LINE FAULT
300	14-May-2020	GULBARGA	220	LINGAPUR-GDHALLI2	LINGAPUR_220	10:35	17:50	7:15	NFBC ISSUED
301	14-May-2020	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	19:27(14.5.20)			LINE IS OPEN, LINE FAULT
302	14-May-2020	GULBARGA	220	SHAHABAD-BAGEWADI2	BAGEWADI_220	10:48	14:47	3:59	LINE FAULT
303	14-May-2020	GULBARGA	220	SHAHABAD-SHAHPUR	SHAHABAD_220	19:30	19:55	0:25	LINE FAULT
304	14-May-2020	GULBARGA	220	SEDAM-SHAHPUR	SHAHAPUR_220	19:28	21:12	1:44	LINE FAULT
305	14-May-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	19:27	20:10	0:43	LINE FAULT
306	14-May-2020	GULBARGA	110	HV2	DEODURGA_110	20:29	20:48	0:19	TRANSFORMER FAULT
307	14-May-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:50	16:59	0:09	LINE FAULT
308	14-May-2020	GULBARGA	110	HV2	RAICHUR_220	10:16	11:06	0:50	LINE CLEAR AVAILED
309	14-May-2020	GULBARGA	110	HV1	MANVI_110	11:20	14:40	3:20	LINE CLEAR AVAILED
310	14-May-2020	GULBARGA	110	HV2	MANVI_110	11:20	16:25	5:05	LINE CLEAR AVAILED
311	14-May-2020	GULBARGA	110	SHAHABAD-GLBUNIVERSITY2	GULUNI_110	15:35	15:40	0:05	LINE FAULT
312	14-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	18:12	18:22	0:10	LINE FAULT
313	14-May-2020	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110, KONKAL_110	0:48	0:56	0:08	LINE FAULT
314	14-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	8:04	8:10	0:06	LINE FAULT
315	14-May-2020	GULBARGA	110	HV1	SHAHAPUR_220	1:04	1:50	0:46	TRANSFORMER FAULT
316	14-May-2020	GULBARGA	110	HV1	SHAHAPUR_220	2:45	2:50	0:05	TRANSFORMER FAULT
317	14-May-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_110	10:10	12:05	1:55	TRANSFORMER FAULT
318	14-May-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_110	12:10	12:15	0:05	HAND TRIPPED
319	14-May-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	17:53	23:14	5:21	LINE FAULT
320	14-May-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:37	13:03	2:26	NFBC ISSUED
321	14-May-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	20:54	21:00	0:06	HAND TRIPPED
322	14-May-2020	HASSAN	220	KEMARVarahi1	KEMAR_220	18:11	19:33	1:22	LINE CLEAR AVAILED
323	14-May-2020	HASSAN	220	KEVarahi2	KEMAR_220	18:11	19:34	1:23	LINE CLEAR AVAILED
324	14-May-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:32	13:13	0:41	HAND TRIPPED
325	14-May-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	14:18	16:10	1:52	LINE FAULT
326	14-May-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	18:34	19:02	0:28	LINE FAULT
327	14-May-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	9:04	12:18	3:14	LINE CLEAR AVAILED
328	14-May-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	13:25	14:47	1:22	LINE FAULT
329	14-May-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	18:34	19:03	0:29	LINE FAULT
330	14-May-2020	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	12:45	13:13	0:28	LINE CLEAR AVAILED
331	14-May-2020	HASSAN	220	AHRAVITY-SHIMOGA4	sharavathy_gen	14:18	16:10	1:52	LINE FAULT
332	14-May-2020	HASSAN	220	AHRAVITY-SHIRALKOPPA	sharavathy_gen	23:15 (14.05.2020)			LINE IS OPEN, LINE FAULT
333	14-May-2020	HASSAN	220	SHRLKP-SGS	SHRLKP	23:15 (14.05.2020)			LINE IS OPEN, LINE FAULT
334	14-May-2020	HASSAN	220	VARAH1-KEMAR1	varahi_gen	16:24	16:32	0:08	LINE FAULT
335	14-May-2020	HASSAN	220	VARAH1-KEMAR1	varahi_gen	16:58	19:38	2:40	LINE FAULT
336	14-May-2020	HASSAN	220	VARAH1-KEMAR2	varahi_gen	16:24	19:38	3:14	LINE FAULT
337	14-May-2020	HASSAN	220	VARAH1-KEMAR2	varahi_gen	16:58	19:39	2:41	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
338	14-May-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	16:59	19:40	2:41	LINE FAULT
339	14-May-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	18:34	19:02	0:28	LINE FAULT
340	14-May-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:04	12:17	3:13	LINE CLEAR AVAILED
341	14-May-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:25	14:47	1:22	LINE FAULT
342	14-May-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	18:34	19:03	0:29	LINE FAULT
343	14-May-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:05	15:40	0:35	LINE FAULT
344	14-May-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:05	15:13	0:08	LINE FAULT
345	14-May-2020	HASSAN	110	KEMAR-KARKALA	KEMAR_220	17:28	17:44	0:16	LINE FAULT
346	14-May-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	11:35	11:52	0:17	HAND TRIPPED
347	14-May-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:18	13:38	0:20	HAND TRIPPED
348	14-May-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	10:01	18:02	8:01	LINE CLEAR AVAILED
349	14-May-2020	HASSAN	110	HV2	HALADY_110	20:13	20:22	0:09	TRANSFORMER FAULT
350	14-May-2020	HASSAN	110	HV2	ANAVATTI_110	22:41	23:43	1:02	TRANSFORMER FAULT
351	14-May-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:05	15:41	0:36	MAIN SUPPLY FAILURE
352	14-May-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:06	15:14	0:08	MAIN SUPPLY FAILURE
353	14-May-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	17:33	17:50	0:17	MAIN SUPPLY FAILURE
354	14-May-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:28	17:49	0:21	LINE FAULT
355	14-May-2020	HASSAN	110	HV1	HOSANGADI_110	10:11	15:41	5:30	LINE CLEAR AVAILED
356	14-May-2020	HASSAN	110	HV2	HOSANGADI_110	12:28	15:59	3:31	LINE CLEAR AVAILED
357	14-May-2020	HASSAN	110	JST1	mghejog_gen	13:20	13:45	0:25	TRANSFORMER FAULT
358	14-May-2020	HASSAN	110	HV2	KARAYA_110	20:10	21:20	1:10	TRANSFORMER FAULT
359	14-May-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	20:11	20:36	0:25	MAIN SUPPLY FAILURE
360	14-May-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:51	18:02	0:11	HAND TRIPPED
361	14-May-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	17:51	18:01	0:10	HAND TRIPPED
362	14-May-2020	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	10:01	18:02	8:01	LINE CLEAR AVAILED
363	14-May-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	20:10	20:28	0:18	MAIN SUPPLY FAILURE
364	14-May-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	20:12	20:28	0:16	MAIN SUPPLY FAILURE
365	14-May-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	20:12	20:26	0:14	MAIN SUPPLY FAILURE
366	14-May-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	20:12	20:35	0:23	MAIN SUPPLY FAILURE
367	14-May-2020	HASSAN	110	SAGARA-IDLE	SAGARA_110	11:08	12:04	0:56	LINE CLEAR AVAILED
368	14-May-2020	HASSAN	66	HASSN22-BELUR	HASSAN_220	12:08	14:55	2:47	LINE CLEAR AVAILED
369	14-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	5:59	6:08	0:09	LINE FAULT
370	14-May-2020	HASSAN	66	HV1	RAMPURA_66	6:28	6:49	0:21	TRANSFORMER FAULT
371	14-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	21:35(13.05.2020)	11:30	13:54hrs	LINE CHARGED
372	14-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	11:43	13:10	1:27	LINE CLEAR AVAILED
373	14-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	8:00	13:48	5:48	LINE CLEAR AVAILED
374	14-May-2020	HASSAN	66	SAKALE- UDDUR	UDDURKOPLU_66	10:12	14:58	4:46	LINE CLEAR AVAILED
375	14-May-2020	MYSURU	66	HV1	ANEGOLAL_66	13:32	14:54	1:22	LINE CLEAR AVAILED
376	14-May-2020	MYSURU	66	HV2	ANEGOLAL_66	10:40	15:00	4:20	LINE CLEAR AVAILED
377	14-May-2020	MYSURU	66	HV1	BOOKANAKERE_66	9:00	14:18	5:18	LINE CLEAR AVAILED
378	14-May-2020	MYSURU	66	HV2	BOOKANAKERE_66	9:00	14:18	5:18	LINE CLEAR AVAILED
379	14-May-2020	MYSURU	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66	18:50	18:59	0:08	LINE FAULT
380	14-May-2020	MYSURU	66	HV1	DKMAIDANA_66	10:00	16:35	6:35	LINE CLEAR AVAILED
381	14-May-2020	MYSURU	66	HV2	DKMAIDANA_66	10:00	16:35	6:35	LINE CLEAR AVAILED
382	14-May-2020	MYSURU	66	HV1	GANJIGERE_66	13:15	15:15	2:00	LINE CLEAR AVAILED
383	14-May-2020	MYSURU	66	HV1	HOOTAGALLY_220	13:14	14:04	0:50	LINE CLEAR AVAILED
384	14-May-2020	MYSURU	66	HV2	HOOTAGALLY_220	10:06	14:06	4:00	LINE CLEAR AVAILED
385	14-May-2020	MYSURU	66	HV1	KIADBMANDYA_66	15:21	16:13	0:52	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
386	14-May-2020	MYSURU	220	HV1	TNARASIPURA_66	23:12	23:28	0:16	TRANSFORMER FAULT
387	14-May-2020	MYSURU	220	HV2	KRPET_220	23:10	23:49	0:39	TRANSFORMER FAULT
388	14-May-2020	MYSURU	66	HV1	KRPET_220	23:12	23:40	0:28	HAND TRIPPED
389	14-May-2020	MYSURU	66	HV2	KRPET_220	23:12	23:55	0:43	HAND TRIPPED
390	14-May-2020	MYSURU	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE_66 6 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	17:32	17:45	0:12	LINE FAULT
391	14-May-2020	MYSURU	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	17:38	17:45	0:06	LINE FAULT
392	14-May-2020	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS	8:21	8:26	0:05	LINE FAULT
393	14-May-2020	MYSURU	66	MANDYA-CHIKK MANDYA	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66	3:14	3:22	0:08	LINE FAULT
394	14-May-2020	MYSURU	66	HV5	SFCSHIVA_66	13:26 (14.05.20)			TRANSFORMER IS OPEN LINE CLEAR AVAILED
395	14-May-2020	MYSURU	66	HV2	TUBINAKERE_220	0:50	0:57	0:07	TRANSFORMER FAULT
396	14-May-2020	MYSURU	66	HV2	TUBINAKERE_220	1:00	1:06	0:06	TRANSFORMER FAULT
397	14-May-2020	MYSURU	66	HV2	TUBINAKERE_220	8:48	8:56	0:08	TRANSFORMER FAULT
398	14-May-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	14:48	14:53	0:04	LINE FAULT
399	14-May-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	14:55	14:58	0:02	HAND TRIPPED
400	14-May-2020	MYSURU	66	HV1	VADERALLI_66	10:30	16:45	6:15	LINE CLEAR AVAILED
401	14-May-2020	MYSURU	66	HV1	VAJAMANGALA_220	10:13	16:45	6:32	LINE CLEAR AVAILED
402	14-May-2020	MYSURU	66	HV2	VAJAMANGALA_220	10:14	16:54	6:40	LINE CLEAR AVAILED
403	14-May-2020	TUMKUR	220	ANCHEPALYA 220kV- MAGADI	ANCHEPALYA_220	11:59	18:41	6:42	LINE CLEAR AVAILED
404	14-May-2020	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	21:12	22:56	1:44	LINE CLEAR AVAILED
405	14-May-2020	TUMKUR	110	TR-2	SAMPIGE_110	11:39	13:30	1:51	LINE CLEAR AVAILED
406	14-May-2020	TUMKUR	66	TR-1	BADAVANAHALLI_66	10:02	17:36	7:34	TRANSFORMER FAULT
407	14-May-2020	TUMKUR	66	TR-1	BAGUR_TMK_66	15:40	16:15	0:35	LINE CLEAR AVAILED
408	14-May-2020	TUMKUR	66	TR-1	HONNALI_66	12:47	13:47	0:59	LINE CLEAR AVAILED
409	14-May-2020	TUMKUR	66	TR-1	HONNALLI_220	16:27	17:24	0:57	LINE CLEAR AVAILED
410	14-May-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	5:39	18:55	13:16	LINE FAULT
411	14-May-2020	TUMKUR	66	TR-1	SHYLAPURA_66	5:56	6:05	0:09	TRANSFORMER FAULT
412	14-May-2020	TUMKUR	66	TR-2	SHYLAPURA_66	14:27	14:32	0:05	TRANSFORMER FAULT
413	14-May-2020	TUMKUR	66	TR-2	TAVAREKERE(H)_66	16:58	17:29	0:30	LINE CLEAR AVAILED
414	14-May-2020	TUMKUR	66	TR-1	YEDIYUR_66	8:14	8:20	0:05	TRANSFORMER FAULT
415	14-May-2020	TUMKUR	66	TR-1	YEDIYUR_66	8:30	8:56	0:26	TRANSFORMER FAULT
416	14-May-2020	TUMKUR	66	TR-1	HANAGAL_66	28:54 PM(13.05.2020)	13:04	19:34hrs	LINE CLEAR AVAILED
417	15-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN, LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
418	15-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED HIDIKAL DAM_110	16:19 (08.05.2020)	17:14	168:55hrs	LINE CLEAR AVAILED
419	15-May-2020	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
420	15-May-2020	BAGALKOT	110	SANKESHWAR-CHIKKODI	NO STATION EFFECTED SANKESHWAR_110	11:43 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
421	15-May-2020	BAGALKOT	220	BIDNAL-HARTHI1	NO STATION EFFECTED BIDNAL_220	21:50 (13.05.2020)			LINE IS OPEN, LINE FAULT
422	15-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	9:40 (13.05.2020)	11:06	49:26hrs	HAND TRIPPED
423	15-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
424	15-May-2020	BAGALKOT	220	AMBEWADI-NARENDRA1	NO STATION EFFECTED AMBEWADI_220	18:59 (14.05.2020)	14:15	19:16	HAND TRIPPED
425	15-May-2020	BAGALKOT	220	AMBEWADI-NAGJHARI1	NO STATION EFFECTED AMBEWADI_220	18:32 (14.05.2020)	14:09	19:37	LINE CHARGED
426	15-May-2020	BAGALKOT	220	GADAG-BAGALKOT1	NO STATION EFFECTED GADAG_220	16:50 (14.05.2020)	18:04	25:14hrs	HAND TRIPPED
427	15-May-2020	BAGALKOT	220	GADAG-HARTHI1&2	NO STATION EFFECTED GADAG_220	11:47 (14.05.2020)	18:07	30:20hrs	HAND TRIPPED
428	15-May-2020	BAGALKOT	110	SAVANUR- RAMANKOPPA (SHIGGOAN)	NO STATION EFFECTED SHIGGOAN_110	23:35 (14.05.2020)	0:13	o:38hrs	LINE CHARGED
429	15-May-2020	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	18:46	18:57	0:11	HAND TRIPPED
430	15-May-2020	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	17:22(15.5.20)			LINE IS OPEN, LINE FAULT
431	15-May-2020	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	18:33	19:13	0:40	HAND TRIPPED
432	15-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	23:27(15.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
433	15-May-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	15:47	21:23	5:36	LINE FAULT
434	15-May-2020	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	15:47	21:22	5:35	LINE FAULT
435	15-May-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	11:59(15.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
436	15-May-2020	BAGALKOT	110	DAMBAL-SAMBAPUR ROAD	DAMBAL_110	16:07	16:58	0:51	LINE FAULT
437	15-May-2020	BAGALKOT	110	110/33KV, HV2	GULEDAGUDDA_110, KAMATAGI_33, SHIRUR_33	10:42	11:09	0:27	LINE CLEAR AVAILED
438	15-May-2020	BAGALKOT	110	110/33KV, HV2	GULEDAGUDDA_110, KAMATAGI_33, SHIRUR_33	12:44	12:47	0:03	HAND TRIPPED
439	15-May-2020	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	10:15	18:04	7:49	LINE CLEAR AVAILED
440	15-May-2020	BAGALKOT	110	ITANAL(RAIBAG)-HIDIKAL	HIDIKAL_110	6:30	22:36	16:06	HAND TRIPPED
441	15-May-2020	BAGALKOT	110	110/11KV, HV4	HIDIKAL_110	18:04	18:18	0:14	TRANSFORMER FAULT
442	15-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	21:54(15.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
443	15-May-2020	BAGALKOT	110	110/11KV, HV2	ITANAL_110	22:50	23:00	0:10	TRANSFORMER FAULT
444	15-May-2020	BAGALKOT	110	ITANAL-RAIBAG	ITANAL_110	15:27	15:52	0:25	LINE CLEAR AVAILED
445	15-May-2020	BAGALKOT	110	JAMKHANDI-MAHALINGAPUR (SIDDAPUR)	JAMKHANDI_110	21:26(15.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
446	15-May-2020	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	20:30(15.5.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
447	15-May-2020	BAGALKOT	110	110/11KV, HV1	KUDACHI_110	12:29	14:54	2:25	LINE CLEAR AVAILED
448	15-May-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	2:58	3:32	0:34	LINE FAULT
449	15-May-2020	BAGALKOT	110	110/11KV, HV1	ZALKI_110	2:03	2:06	0:03	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
450	15-May-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	6:53	7:03	0:10	TRANSFORMER FAULT
451	15-May-2020	BAGALKOT	110	PG HUNSHYAL (NAGNUR)- MUDALGI	MUDALGI_110	4:11	5:31	1:20	LINE FAULT
452	15-May-2020	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_220	2:45	9:59	7:14	LINE FAULT
453	15-May-2020	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	2:37(15.5.20)			LINE IS OPEN, LINE FAULT
454	15-May-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	16:53	18:21	1:28	LINE FAULT
455	15-May-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:35	18:22	0:47	LINE FAULT
456	15-May-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	18:42	20:00	1:18	LINE FAULT
457	15-May-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	7:12(15.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
458	15-May-2020	BAGALKOT	110	SIDDAPUR(JOG1)-SIRSI	SIRSI_110	17:16	18:21	1:05	LINE FAULT
459	15-May-2020	BAGALKOT	110	JOG2-SIRSI2	SIRSI_110	0:33	12:08	11:35	LINE FAULT
460	15-May-2020	BAGALKOT	110	JOG2-SIRSI2	SIRSI_110	17:16	18:35	1:19	LINE FAULT
461	15-May-2020	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	15:56	21:01	5:05	LINE FAULT
462	15-May-2020	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:46(15.5.20)			LINE IS OPEN, LINE FAULT
463	15-May-2020	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	0:56(15.5.20)			LINE IS OPEN, LINE FAULT
464	15-May-2020	BAGALKOT	220	220/110KV,HV1	SIRSI_220	7:10	7:25	0:15	TRANSFORMER FAULT
465	15-May-2020	BAGALKOT	220	220/110KV,HV1	SIRSI_220	18:05	18:35	0:30	HAND TRIPPED
466	15-May-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	21:42	21:52	0:10	TRANSFORMER FAULT
467	15-May-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110	17:35 (04.05.2020)	3:56	250:21hrs	LINE CLEAR AVAILED
468	15-May-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110	15:38	17:08	1:30	HAND TRIPPED
469	15-May-2020	BAGALKOT	110	110/11KV,HV1 &HV2	SHIRGOAN_110	10:01	15:29	5:28	HAND TRIPPED
470	15-May-2020	BAGALKOT	110	SATISH SUGARS-PG HUNSHYAL	PG HUNSHYAL_110	6:28	6:37	0:09	HAND TRIPPED
471	15-May-2020	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	18:17	18:28	0:11	TRANSFORMER FAULT
472	15-May-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	18:37	20:10	1:33	TRANSFORMER FAULT
473	15-May-2020	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	2:14	2:24	0:10	TRANSFORMER FAULT
474	15-May-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	11:19	13:35	2:16	HAND TRIPPED
475	15-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	14:53(15.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
476	15-May-2020	BAGALKOT	110	DODDANAVAR-NANADI	NANADI_110	23:29(15.5.20)			LINE IS OPEN, LINE FAULT
477	15-May-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	15:28	15:48	0:20	HAND TRIPPED
478	15-May-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	5:18	6:28	1:10	HAND TRIPPED
479	15-May-2020	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,HIDIKAL_11 O,ITNAL_110	6:32	6:41	0:09	HAND TRIPPED
480	15-May-2020	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	12:16	12:26	0:10	TRANSFORMER FAULT
481	15-May-2020	BAGALKOT	110	220/110KV,LV1&LV2	MAHALINGAPUR_220,BABALESHW AR_110,BANAHATTI_110,GSML1& 2_110,RABKAVI_110,TERDAL_110	7:05	8:30	1:25	HAND TRIPPED
482	15-May-2020	BAGALKOT	110	110/11KV,HV3&HV4	MAHALINGAPUR_220	7:00	8:37	1:37	HAND TRIPPED
483	15-May-2020	BAGALKOT	110	110/33KV,HV1	MAHALINGAPUR_220,JAGADAL_3 3,DEMPODAIRY_33	7:00	9:00	2:00	HAND TRIPPED
484	15-May-2020	BAGALKOT	110	110/33KV,HV2	MAHALINGAPUR_220,HALLUR_33, MALALI_33	7:00	9:05	2:05	HAND TRIPPED
485	15-May-2020	BAGALKOT	110	110/11KV,HV3	MUDHOL_110	8:04	8:06	0:02	HAND TRIPPED
486	15-May-2020	BENGALURU	66	HV1	AVANI	15:12	17:32	2:20	LINE CLEAR AVAILED
487	15-May-2020	BENGALURU	220	HV2	NIMHANS 220	10:28	16:20	5:51	LINE CLEAR AVAILED
488	15-May-2020	BENGALURU	66	HV2	KHODAYS 220	11:44	17:21	5:36	LINE CLEAR AVAILED
489	15-May-2020	BENGALURU	220	HV1	EDC 220	9:07	17:16	8:09	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
490	15-May-2020	BENGALURU	66	HV2	EDC 220	9:07	17:38	8:31	LINE CLEAR AVAILED
491	15-May-2020	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	12:55	12:59	0:04	LINE CLEAR AVAILED
492	15-May-2020	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	13:35	13:40	0:05	LINE CLEAR AVAILED
493	15-May-2020	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	14:13	14:19	0:06	LINE CLEAR AVAILED
494	15-May-2020	BENGALURU	66	NRS 220 - A STATION 1	NO STATION AFFECTED	12:21	14:01	1:40	LINE CLEAR AVAILED
495	15-May-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	23:22	23:28	0:06	LINE CLEAR AVAILED
496	15-May-2020	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	NO STATION AFFECTED	14:02	18:49	4:46	LINE CLEAR AVAILED
497	15-May-2020	BENGALURU	66	HV2	PADMANABHANAGAR	11:08	16:40	5:32	LINE CLEAR AVAILED
498	15-May-2020	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	14:16	14:22	0:06	LOAD CHANGE OVER
499	15-May-2020	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	16:10	16:14	0:04	LOAD CHANGE OVER
500	15-May-2020	BENGALURU	220	HV2	HAL 220	15:56	16:10	0:13	TRANSFORMER FAULT
501	15-May-2020	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HALAGUR	22:05	22:32	0:27	LINE FAULT
502	15-May-2020	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	9:18	13:50	4:31	LINE FAULT
503	15-May-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	22:31	23:06	0:35	LINE FAULT
504	15-May-2020	BENGALURU	66	KORMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	16:39	17:20	0:40	LINE FAULT
505	15-May-2020	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
506	15-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
507	15-May-2020	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	19:27(14.5.2020)	13:13	17:45	LINE FAULT
508	15-May-2020	GULBARGA	220	HV1	KUSTAGI_220	12:55	13:07	0:12	TRANSFORMER FAULT
509	15-May-2020	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	12:35	12:43	0:08	LINE CLEAR AVAILED
510	15-May-2020	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110	12:55	13:15	0:20	MAIN SUPPLY FAILURE
511	15-May-2020	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	12:55	13:25	0:30	MAIN SUPPLY FAILURE
512	15-May-2020	GULBARGA	110	HV3	DEODURGA_110	13:10	13:45	0:35	TRANSFORMER FAULT
513	15-May-2020	GULBARGA	110	HV2	DEODURGA_110	22:55	23:10	0:15	TRANSFORMER FAULT
514	15-May-2020	GULBARGA	110	SHAHABAD-GLBUNIVERSITY2	GULUNI_110	16:25(15.5.20)			LINE IS OPEN, LINE FAULT
515	15-May-2020	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110, KONKAL_110	0:48	0:56	0:08	LINE FAULT
516	15-May-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	14:27	14:37	0:10	LINE FAULT
517	15-May-2020	GULBARGA	66	TAMBRAHALLI-ITTAGI	TAMBRAHALLI_66	10:10	10:30	0:20	LINE FAULT
518	15-May-2020	GULBARGA	66	HV1	TAMBRAHALLI_66	8:05	8:25	0:20	LINE CLEAR AVAILED
519	15-May-2020	GULBARGA	66	HV1	CHORNOOR_110	9:40	11:25	1:45	LINE CLEAR AVAILED
520	15-May-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:00	8:32	6:32	LINE FAULT
521	15-May-2020	HASSAN	220	TALAGU-ST3	TALAGUPPA_400	0:18	12:08	11:50	LINE FAULT
522	15-May-2020	HASSAN	220	TALAGU-ST1	TALAGUPPA_400	0:33	18:55	18:22	LINE FAULT
523	15-May-2020	HASSAN	220	TALAGU-ST2	TALAGUPPA_400	0:35	15:28	14:53	LINE FAULT
524	15-May-2020	HASSAN	220	TALAG-SGS1	TALAGUPPA_400	16:53	17:45	0:52	HAND TRIPPED
525	15-May-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:46 (13.05.2020)	9:32	9:45hrs	LINE CHARGED
526	15-May-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:05 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
527	15-May-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:18	11:45	11:27	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
528	15-May-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	0:15	14:24	14:09	LINE FAULT
529	15-May-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	9:29	9:39	0:10	HAND TRIPPED
530	15-May-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	0:18	11:45	11:27	LINE FAULT
531	15-May-2020	HASSAN	220	SHRAVTY-SS2	sharavathy_gen	0:47 (15.05.2020)			LINE IS OPEN, LINE FAULT
532	15-May-2020	HASSAN	220	SHRAVTY-SS1	sharavathy_gen	0:46 (15.05.2020)			LINE IS OPEN, LINE FAULT
533	15-May-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	0:15	14:24	14:09	LINE FAULT
534	15-May-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	23:15	14:29	8:46	LINE FAULT
535	15-May-2020	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	0:35	15:29	14:54	LINE FAULT
536	15-May-2020	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	16:54	17:46	0:52	HAND TRIPPED
537	15-May-2020	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	0:18	12:08	11:50	LINE FAULT
538	15-May-2020	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	0:31	18:56	18:25	LINE FAULT
539	15-May-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	23:15 (14.05.2020)	14:12	14:58hrs	LINE CHARGED
540	15-May-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:34	12:07	0:33	LINE FAULT
541	15-May-2020	HASSAN	110	HV1	ARASIKERE_110	9:36	17:24	7:48	LINE CLEAR AVAILED
542	15-May-2020	HASSAN	110	HV2	ARASIKERE_110	9:36	17:35	7:59	LINE CLEAR AVAILED
543	15-May-2020	HASSAN	110	HV2	ARASIKERE_110	18:14	18:50	0:36	MAIN SUPPLY FAILURE
544	15-May-2020	HASSAN	110	HV2	ARASIKERE_110	18:50	23:49	4:59	TRANSFORMER FAULT
545	15-May-2020	HASSAN	110	HV2	ARASIKERE_110	23:53 (15.05.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
546	15-May-2020	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	10:47	16:21	5:34	LINE CLEAR AVAILED
547	15-May-2020	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	17:15	17:25	0:10	HAND TRIPPED
548	15-May-2020	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	18:08	18:12	0:04	LINE FAULT
549	15-May-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:07	16:57	0:50	MAIN SUPPLY FAILURE
550	15-May-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:05	16:41	0:36	LINE FAULT
551	15-May-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	18:14	18:47	0:33	LINE FAULT
552	15-May-2020	HASSAN	110	JOG-JLT3	mghejog_gen	0:20	0:50	0:30	LINE FAULT
553	15-May-2020	HASSAN	110	JOG-JST1	mghejog_gen	0:10	0:57	0:47	LINE FAULT
554	15-May-2020	HASSAN	110	JOG-NK1	mghejog_gen	0:30	12:23	11:53	LINE FAULT
555	15-May-2020	HASSAN	110	JOG-NK2	mghejog_gen	0:00	12:15	12:15	LINE FAULT
556	15-May-2020	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:45	15:45	5:00	LINE CLEAR AVAILED
557	15-May-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:05	16:55	0:50	LINE FAULT
558	15-May-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:05	16:55	0:50	LINE FAULT
559	15-May-2020	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	9:20	14:47	5:27	NFBC ISSUED
560	15-May-2020	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	18:14	18:47	0:33	LINE FAULT
561	15-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	17:44 (15.05.2020)			LINE IS OPEN, LINE FAULT
562	15-May-2020	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	9:32	15:05	5:33	LINE CLEAR AVAILED
563	15-May-2020	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	9:25	15:26	6:01	LINE CLEAR AVAILED
564	15-May-2020	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	9:20	15:40	6:20	LINE CLEAR AVAILED
565	15-May-2020	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	9:25	18:06	8:41	LINE CLEAR AVAILED
566	15-May-2020	HASSAN	110	SAGARA-ALKLA	SAGARA_110	5:46	6:19	0:33	LINE FAULT
567	15-May-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	0:13	0:48	0:35	LINE FAULT
568	15-May-2020	HASSAN	110	SAGARA-LST3	SAGARA_110	0:15	0:45	0:30	LINE FAULT
569	15-May-2020	HASSAN	110	SAGARA-LST4	SAGARA_110	0:13	0:40	0:27	LINE FAULT
570	15-May-2020	HASSAN	110	HV1	SALATHUR_110	13:46	14:06	0:20	LINE CLEAR AVAILED
571	15-May-2020	HASSAN	110	HV2	SORABA_110	0:10	1:22	1:12	LINE CLEAR AVAILED
572	15-May-2020	HASSAN	110	HV2	SORABA_110	11:46	12:21	0:35	LINE CLEAR AVAILED
573	15-May-2020	HASSAN	110	HV2	SORABA_110	20:40	21:26	0:46	LINE CLEAR AVAILED
574	15-May-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:48	10:55	0:07	LINE FAULT
575	15-May-2020	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	11:18	13:27	2:09	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
576	15-May-2020	HASSAN	66	HV1	DODDAKADANUR_66	0:00	0:07	0:07	MAIN SUPPLY FAILURE
577	15-May-2020	HASSAN	66	HV1	MATTNIVILE_66	20:50	21:05	0:15	MAIN SUPPLY FAILURE
578	15-May-2020	HASSAN	66	HV1	MATTNIVILE_66	22:05	22:25	0:20	MAIN SUPPLY FAILURE
579	15-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	9:00	17:59	8:59	LINE CLEAR AVAILED
580	15-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	9:00	18:00	9:00	LINE CLEAR AVAILED
581	15-May-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	9:53	10:39	0:46	LINE CLEAR AVAILED
582	15-May-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	11:17	13:27	2:10	LINE CLEAR AVAILED
583	15-May-2020	HASSAN	66	HV2	UDAYAPURA_66	11:34	12:09	0:35	LINE CLEAR AVAILED
584	15-May-2020	MYSURU	66	HV5	SFCSHIVA_66	13:26 (14.05.20)	1:45	12:18hrs	TRANSFORMER CHARGED
585	15-May-2020	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS	12:24	13:36	1:11	HAND TRIPPED
586	15-May-2020	MYSURU	66	HV2	HDKOTE_66	12:23	13:00	0:36	LINE CLEAR AVAILED
587	15-May-2020	MYSURU	66	HOOTAGALLI-BARC2	NO STATIONS	10:26	13:31	3:04	LINE CLEAR AVAILED
588	15-May-2020	MYSURU	220	HV2	KADAKOLA_220	10:25	13:22	2:56	LINE CLEAR AVAILED
589	15-May-2020	MYSURU	66	K HONNALAGERE-IGGLUR	K_HONNALGERE_66, YETHAMBADI_66	22:33	23:06	0:33	HAND TRIPPED
590	15-May-2020	MYSURU	66	KUNTHUR-DODDRAIPETE	NO STATIONS	4:25	4:35	0:09	LINE FAULT
591	15-May-2020	MYSURU	66	HV1	MADIKERI_66	15:47	15:53	0:06	LINE CLEAR AVAILED
592	15-May-2020	MYSURU	66	HOOTAGALLI-BELAGOLA	BELAGOLA_66	9:37	17:35	7:58	LINE CLEAR AVAILED
593	15-May-2020	MYSURU	66	MEGHALAPURA-HEBBANI	MEGALAPURA_66, THUMBLA_66, CHIDRAVALLI_66, BGPURA_66, GARGESHWARI_66 & VYASRAJPURA_66	11:00	17:00	6:00	NFBC ISSUED
594	15-May-2020	MYSURU	66	MEGHALAPURA- VAJAMANGALA	MEGALAPURA_66, THUMBLA_66, CHIDRAVALLI_66, BGPURA_66, GARGESHWARI_66 & VYASRAJPURA_66	11:00	17:00	6:00	NFBC ISSUED
595	15-May-2020	MYSURU	66	HALAGUR-HONNAGANAHALLI	HALAGUR_66	22:05	22:34	0:29	HAND TRIPPED
596	15-May-2020	MYSURU	66	HV1	SANTHEBACHALLI_66	10:45	15:45	5:00	LINE CLEAR AVAILED
597	15-May-2020	MYSURU	66	HV2	SANTHEBACHALLI_66	10:45	15:45	5:00	LINE CLEAR AVAILED
598	15-May-2020	MYSURU	66	HV2	KOLKARANADODDI_66	10:45	10:50	0:05	TRANSFORMER FAULT
599	15-May-2020	MYSURU	66	HV2	KOLKARANADODDI_66	10:50	15:35	4:45	LINE CLEAR AVAILED
600	15-May-2020	MYSURU	66	HV1	KRPET_220	11:12	15:50	4:38	LINE CLEAR AVAILED
601	15-May-2020	MYSURU	66	HV2	KRPET_220	11:25	15:20	3:55	LINE CLEAR AVAILED
602	15-May-2020	MYSURU	66	HV5	SFCSHIVA_66	13:06(15.05.2020)			TRANSFORMER IS OPEN LINE CLEAR AVAILED
603	15-May-2020	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	9:31	18:02	8:30	LINE CLEAR AVAILED
604	15-May-2020	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	9:32	18:04	8:32	LINE CLEAR AVAILED
605	15-May-2020	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	6:13	18:01	11:48	LINE CLEAR AVAILED
606	15-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	8:38	9:39	1:01	LINE CLEAR AVAILED
607	15-May-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:07	9:37	0:29	LINE FAULT
608	15-May-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	7:23	7:42	0:18	MAIN SUPPLY FAILURE
609	15-May-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	13:08:27(15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
610	15-May-2020	TUMKUR	66	TR-2	HANAGAL_66	11:23	11:46	0:23	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
611	15-May-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:52	17:44	10:51	LINE CLEAR AVAILED
612	15-May-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	6:52	17:44	10:51	LINE CLEAR AVAILED
613	15-May-2020	TUMKUR	66	TR-2	HONNUDIKE_66	4:23	5:12	0:49	LINE CLEAR AVAILED
614	15-May-2020	TUMKUR	66	TR-2	HONNUDIKE_66	16:21	17:37	1:16	LINE CLEAR AVAILED
615	15-May-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	12:13	14:12	1:58	LINE CLEAR AVAILED
616	15-May-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:44	13:46	0:02	LINE FAULT
617	15-May-2020	TUMKUR	66	TR-2	KUKKAWADA_66	22:56	23:53	0:57	TRANSFORMER FAULT
618	15-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAM AGIRI_66	11:38	11:59	0:21	LINE FAULT
619	15-May-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:11	17:46	9:35	HAND TRIPPED
620	15-May-2020	TUMKUR	66	TR-2	SANIKERE_66	14:53	14:59	0:05	LINE CLEAR AVAILED
621	15-May-2020	TUMKUR	66	TR-1	TUMKUR_66	8:31	8:36	0:05	HAND TRIPPED
622	15-May-2020	TUMKUR	66	TR-1	TUMKUR_66	9:42	9:45	0:03	HAND TRIPPED
623	15-May-2020	TUMKUR	66	TR-2	TUMKUR_66	8:31	8:36	0:05	HAND TRIPPED
624	15-May-2020	TUMKUR	66	TR-2	TUMKUR_66	9:42	9:45	0:03	HAND TRIPPED
625	15-May-2020	TUMKUR	66	RANGANATHAPURA- WSPNSOLAR1	RANGANATHAPURA_66	7:22	7:51	0:29	LINE FAULT
626	15-May-2020	TUMKUR	66	RANGANATHAPURA- WSPNSOLAR2	RANGANATHAPURA_66	7:22	10:09	2:46	LINE FAULT
627	15-May-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	13:08:27(15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
628	16-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN, LINE FAULT
629	16-May-2020	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
630	16-May-2020	BAGALKOT	110	SANKESHWAR-CHIKKODI	NO STATION EFFECTED SANKESHWAR_110	11:43 (10.05.2020)	7:45	140:02hrs	HAND TRIPPED
631	16-May-2020	BAGALKOT	220	BIDNAL-HARTHI1	NO STATION EFFECTED BIDNAL_220	21:50 (13.05.2020)			LINE IS OPEN, LINE FAULT
632	16-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
633	16-May-2020	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	17:22 (15.05.2020)	12:36	19:14hrs	LINE CHARGED
634	16-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	23:39 (15.05.2020)	6:52	7:19hrs	HAND TRIPPED
635	16-May-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	23:39 (15.05.2020)	6:50	6:51hrs	HAND TRIPPED
636	16-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	21:54 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
637	16-May-2020	BAGALKOT	110	JAMKHANDI-MAHALINGAPUR (SIDDAPUR)	JAMKHANDI_110	21:26 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
638	16-May-2020	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	20:30 (15.05.2020)	12:44	16:14hrs	LINE CHARGED
639	16-May-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	19:15 (15.05.2020)	17:47	22:35hrs	HAND TRIPPED
640	16-May-2020	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	23:37 (15.05.2020)			LINE IS OPEN, LINE FAULT
641	16-May-2020	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:48 (15.05.2020)	13:56	37:10hrs	LINE CHARGED
642	16-May-2020	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	0:58 (15.05.2020)	14:08	37:10hrs	LINE CHARGED
643	16-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	14:33 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
644	16-May-2020	BAGALKOT	110	DODDANAVAR-NANADI	NANADI_110	23:29 (15.05.2020)	0:31	1:01hrs	LINE CHARGED
645	16-May-2020	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	7:00	15:07	8:07	LINE CLEAR AVAILED
646	16-May-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	15:56	17:45	1:49	HAND TRIPPED
647	16-May-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	11:54	17:45	5:51	LINE CLEAR AVAILED
648	16-May-2020	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	21:15	21:27	0:12	LINE CLEAR AVAILED
649	16-May-2020	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	11:30	17:49	6:19	LINE CLEAR AVAILED
650	16-May-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	16:21	17:10	0:49	LINE FAULT
651	16-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:25(16.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
652	16-May-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	13:40	15:18	1:38	LINE CLEAR AVAILED
653	16-May-2020	BAGALKOT	220	MUDASHINGI(KOLAHPUR2)-CHIKKODI	CHIKKODI_220	9:44	10:57	1:13	LINE CLEAR AVAILED
654	16-May-2020	BAGALKOT	220	CHIKKODI -GHATP2 (KUDACHI)	CHIKKODI_220	11:05	16:45	5:40	LINE CLEAR AVAILED
655	16-May-2020	BAGALKOT	110	CHIKKODI220 -SANKESHWAR	SANKESHWAR_110	7:46	7:58	0:12	HAND TRIPPED
656	16-May-2020	BAGALKOT	110	BIJAPUR220- BIJAPUR CITY	BIJAPUR CITY_110	12:50(16.5.20)			LINE IS OPEN, LINE FAULT
657	16-May-2020	BAGALKOT	110	GHATAPRABHA-BELGAUM	GHATAPRABHA_110	6:02	7:15	1:13	LINE FAULT
658	16-May-2020	BAGALKOT	110	GHATAPRABHA220 -GHATPR1	GHATAPRABHA_110	6:44	7:45	1:01	LINE CLEAR AVAILED
659	16-May-2020	BAGALKOT	110	110/33KV,HV3	GHATAPRABHA_110	7:32	8:11	0:39	HAND TRIPPED
660	16-May-2020	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	7:34	8:10	0:36	HAND TRIPPED
661	16-May-2020	BAGALKOT	110	110/11KV,HV5	GHATAPRABHA_110	7:46	7:52	0:06	HAND TRIPPED
662	16-May-2020	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	1:34	1:40	0:06	LINE FAULT
663	16-May-2020	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA1	GHATAPRABHA_110	5:15	7:07	1:52	LINE FAULT
664	16-May-2020	BAGALKOT	220	220/110,HV1	HAVERI_220	15:31	17:23	1:52	LINE CLEAR AVAILED
665	16-May-2020	BAGALKOT	110	HAVERI 220-TILUVALI	TILUVALI_110	10:23	17:56	7:33	LINE CLEAR AVAILED
666	16-May-2020	BAGALKOT	110	HIDIKAL-ITANAL	HIDIKAL_110	7:28(16.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
667	16-May-2020	BAGALKOT	110	110/33KV ,HV2	HUNAGUND_110	10:03	10:06	0:03	TRANSFORMER FAULT
668	16-May-2020	BAGALKOT	110	KUDACHI 220-MORAB(TERDAL)	MORAB_110	14:50	16:26	1:36	LINE CLEAR AVAILED
669	16-May-2020	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	16:52	17:35	0:43	LINE CLEAR AVAILED
670	16-May-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	TARIHAL_110	13:07	13:22	0:15	HAND TRIPPED
671	16-May-2020	BAGALKOT	110	HUBLI-TARIHAL1&2	TARIHAL_110	13:27	17:37	4:10	LINE CLEAR AVAILED
672	16-May-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	TARIHAL_110	18:25(16.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
673	16-May-2020	BAGALKOT	110	110/11KV,HV1	YELPHARATTI_110	12:02	12:42	0:40	LINE CLEAR AVAILED
674	16-May-2020	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	11:05	14:37	3:32	LINE CLEAR AVAILED
675	16-May-2020	BAGALKOT	110	CHIKKODI220 -SANKESHWAR	SANKESHWAR_110	8:17	9:11	0:54	HAND TRIPPED
676	16-May-2020	BAGALKOT	110	110/33KV ,HV3	RANEENNUR_220&HALAGERI_33 , GUDUR MAIDUR_33	10:47	11:41	0:54	HAND TRIPPED
677	16-May-2020	BAGALKOT	110	CHIKKODI -RAIBAG	RAIBAG_110	6:03	10:26	4:23	LINE FAULT
678	16-May-2020	BAGALKOT	110	110/11KV,HV 2	NANADI_110	12:33	13:39	1:06	HAND TRIPPED
679	16-May-2020	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	1:12	8:32	7:20	HAND TRIPPED
680	16-May-2020	BENGALURU	66	HV2	HOSKOTE 220	13:25	14:45	1:20	TRANSFORMER FAULT
681	16-May-2020	BENGALURU	66	HV2	HOSKOTE 220	14:10	14:20	0:10	TRANSFORMER FAULT
682	16-May-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	17:42	17:51	0:08	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
683	16-May-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:48	21:08	1:19	LINE CLEAR AVAILED
684	16-May-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	20:08	21:10	1:02	LINE CLEAR AVAILED
685	16-May-2020	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	17:08	17:15	0:07	LOAD CHANGE OVER
686	16-May-2020	BENGALURU	220	EPIP 220 - HOODY 400	EPIP 220	12:57	13:46	0:49	MAIN SUPPLY FAILURE
687	16-May-2020	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	12:57	14:48	1:51	LINE FAULT
688	16-May-2020	BENGALURU	66	EPIP 220 - SHAMARAJU TECH PARK	SHAMARAJU TECH PARK, KACHMARANAHALLI	12:57	13:46	0:49	MAIN SUPPLY FAILURE
689	16-May-2020	BENGALURU	66	EPIP 220 - KADUGODI	ARMY WELFARE ORGANIZATION, KONDA SPURA	12:57	13:46	0:49	MAIN SUPPLY FAILURE
690	16-May-2020	BENGALURU	220	HOODY 400 - HAL 220	NO STATION AFFECTED	13:06	14:43	1:37	LINE FAULT
691	16-May-2020	BENGALURU	220	HOODY 400 - ITPL 220	EPIP 220	12:57	13:42	0:45	LINE FAULT
692	16-May-2020	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	10:35	16:55	6:20	LINE CLEAR AVAILED
693	16-May-2020	BENGALURU	66	HV2	KORAMANGALA	10:30	10:33	0:03	LINE CLEAR AVAILED
694	16-May-2020	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	11:45	11:52	0:07	LOAD CHANGE OVER
695	16-May-2020	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	13:05	13:10	0:05	LOAD CHANGE OVER
696	16-May-2020	BENGALURU	66	HV2	PLATINUM CITY	13:00	14:05	1:05	LINE CLEAR AVAILED
697	16-May-2020	BENGALURU	66	SRINIVASPURA - DALASNUR	SRINIVASPURA	20:45	21:00	0:15	LOAD CHANGE OVER
698	16-May-2020	BENGALURU	66	SRINIVASPURA - CHINTAMANI	SRINIVASPURA	21:15	21:20	0:05	LOAD CHANGE OVER
699	16-May-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:21	11:28	0:07	LINE CLEAR AVAILED
700	16-May-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:21	11:28	0:07	LINE CLEAR AVAILED
701	16-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:21	11:28	0:07	LINE CLEAR AVAILED
702	16-May-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:22	16:30	0:08	LINE CLEAR AVAILED
703	16-May-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:22	16:30	0:08	LINE CLEAR AVAILED
704	16-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:22	16:30	0:08	LINE CLEAR AVAILED
705	16-May-2020	BENGALURU	66	HV1	NARASAPURA	16:50	17:09	0:19	LINE CLEAR AVAILED
706	16-May-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	NO STATION AFFECTED	12:00	16:09	4:08	LINE CLEAR AVAILED
707	16-May-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	12:49	14:03	1:14	LINE CLEAR AVAILED
708	16-May-2020	GULBARGA	220	KAPNOOR-SHAH BAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
709	16-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
710	16-May-2020	GULBARGA	220	SEDAM-SHAHPUR	SHAHAPUR_220	11:53	15:39	3:46	LINE CLEAR AVAILED
711	16-May-2020	GULBARGA	220	SEDAM-ORIENT	ORIENT_IPP	12:31	15:41	3:10	LINE CLEAR AVAILED
712	16-May-2020	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	18:53	19:50	0:57	LINE FAULT
713	16-May-2020	GULBARGA	220	ALIPUR-BTPS	BTPS_220	18:53	23:18	4:25	LINE FAULT
714	16-May-2020	GULBARGA	220	HV1	ALIPUR_220	18:53	19:53	1:00	TRANSFORMER FAULT
715	16-May-2020	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	5:12	5:26	0:14	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
716	16-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	13:20	13:35	0:15	LINE FAULT
717	16-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	21:00	21:20	0:20	LINE FAULT
718	16-May-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	SIRUGUPPA_110, TEKKALKOTE_110, DHAHDESUGUR_110, NSL SUGARS_IPP	23:10	23:25	0:15	LINE FAULT
719	16-May-2020	GULBARGA	110	SHAHABAD-GLBUNIVERSITY2	GULUNI_110	16:25(15.5.2020)	13:36	37:36hrs	LINE CHARGED
720	16-May-2020	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	23:49(16.5.20)			LINE IS OPEN, LINE FAULT
721	16-May-2020	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	21:40	21:50	0:10	LINE FAULT
722	16-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:15	6:23	0:08	LINE FAULT
723	16-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:56	7:20	0:24	LINE FAULT
724	16-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	7:58	8:25	0:27	LINE FAULT
725	16-May-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	12:58	13:36	0:38	LINE FAULT
726	16-May-2020	GULBARGA	110	HV2	HATTI_110	19:50	19:55	0:05	TRANSFORMER FAULT
727	16-May-2020	GULBARGA	110	HV2	HATTI_110	20:10	20:18	0:08	TRANSFORMER FAULT
728	16-May-2020	GULBARGA	110	HATTI-GAMESHAWIND_IPP	HATTI_110	16:29	16:45	0:16	LINE FAULT
729	16-May-2020	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110	18:50	20:25	1:35	MAIN SUPPLY FAILURE
730	16-May-2020	GULBARGA	110	HV1	KUDITINI_110	20:10	20:35	0:25	LINE CLEAR AVAILED
731	16-May-2020	GULBARGA	110	HV3	BEVOOR_110	22:20	22:59	0:39	TRANSFORMER FAULT
732	16-May-2020	GULBARGA	110	HALLIKHED-HUMNABAD	HALLIKHED_110	14:00	19:15	5:15	LINE CLEAR AVAILED
733	16-May-2020	HASSAN	220	SHRAVITY-SS2	sharavathy_gen	0:47 (15.05.2020)	14:08	14:55hrs	LINE CHARGED
734	16-May-2020	HASSAN	220	SHRAVITY-SS1	sharavathy_gen	0:46 (15.05.2020)	13:56	14:42hrs	LINE CHARGED
735	16-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	18:05 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
736	16-May-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:39	12:42	2:03	LINE CLEAR AVAILED
737	16-May-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:24	18:17	4:53	NFBC ISSUED
738	16-May-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	15:24	16:01	0:37	LINE FAULT
739	16-May-2020	HASSAN	220	VARAH1-KEMAR1	varahi_gen	10:39	12:42	2:03	NFBC ISSUED
740	16-May-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	13:24	18:17	4:53	LINE CLEAR AVAILED
741	16-May-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	15:24	16:01	0:37	LINE FAULT
742	16-May-2020	HASSAN	110	HV2	ARASIKERE_110	23:53 (15.05.2020)	0:47	0:54hrs	TRANSFORMER CHARGED
743	16-May-2020	HASSAN	110	HV2	ARASIKERE_110	0:54	11:34	10:40	TRANSFORMER FAULT
744	16-May-2020	HASSAN	110	HV2	ARASIKERE_110	12:14	14:11	1:57	LINE CLEAR AVAILED
745	16-May-2020	HASSAN	110	HV2	ARASIKERE_110	14:23	14:42	0:19	LINE CLEAR AVAILED
746	16-May-2020	HASSAN	110	HV2	BAIKAMPADI_110	9:44	10:42	0:58	LINE CLEAR AVAILED
747	16-May-2020	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	9:27	12:51	3:24	LINE CLEAR AVAILED
748	16-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	17:44 (15.05.2020)	9:29	15:44hrs	LINE CHARGED
749	16-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:05	13:19	3:14	NFBC ISSUED
750	16-May-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	9:20	12:27	3:07	LINE CLEAR AVAILED
751	16-May-2020	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	9:21	12:48	3:27	LINE CLEAR AVAILED
752	16-May-2020	HASSAN	110	PUTUR-KARAYA	PUTTUR_220	9:21	12:48	3:27	LINE CLEAR AVAILED
753	16-May-2020	HASSAN	110	HV2	SAGARA_110	16:01	17:36	1:35	LINE CLEAR AVAILED
754	16-May-2020	HASSAN	110	HV4	SHIRALKOPPA_110	9:35	14:40	5:05	LINE CLEAR AVAILED
755	16-May-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	9:33	14:40	5:07	LINE CLEAR AVAILED
756	16-May-2020	HASSAN	110	HV2	SORABA_110	13:05	13:54	0:49	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
757	16-May-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	3:46	4:01	0:15	LINE FAULT
758	16-May-2020	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	10:50	13:20	2:30	MAIN SUPPLY FAILURE
759	16-May-2020	HASSAN	66	HV1	KANDLI_66	11:26	13:04	1:38	LINE CLEAR AVAILED
760	16-May-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:27	12:32	0:05	LINE FAULT
761	16-May-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:43	10:56	0:13	LINE CLEAR AVAILED
762	16-May-2020	HASSAN	66	HV1	KUDLIGERE_66	11:24	12:25	1:01	LINE CLEAR AVAILED
763	16-May-2020	HASSAN	66	HV1	MAGGE_66	12:27	12:35	0:08	MAIN SUPPLY FAILURE
764	16-May-2020	HASSAN	66	HV2	MAGGE_66	12:27	12:43	0:16	MAIN SUPPLY FAILURE
765	16-May-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	12:27	13:03	0:36	LINE FAULT
766	16-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:01	18:43	9:42	LINE CLEAR AVAILED
767	16-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:01	18:43	9:42	LINE CLEAR AVAILED
768	16-May-2020	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	13:22	13:44	0:22	LINE CLEAR AVAILED
769	16-May-2020	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	3:42	4:02	0:20	LINE FAULT
770	16-May-2020	HASSAN	66	HV2	KIADB_66	11:56	12:41	0:45	LINE CLEAR AVAILED
771	16-May-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	11:13	11:28	0:15	HAND TRIPPED
772	16-May-2020	MYSURU	66	BASARALU-HAMPAPURA	NO STATIONS	11:51 (16.05.20)			LINE IS OPEN, LINE CLEAR AVAILED
773	16-May-2020	MYSURU	66	KADAKOLA-MYSORE SOUTH	KALAMANDIRA_66 MYSORESOUTH_66	5:48	5:56	0:08	LINE FAULT
774	16-May-2020	MYSURU	66	PARINAMIPURA-TALAKADU	CHANDALLI_66 THALAKADU_66	18:58	19:03	0:05	LINE FAULT
775	16-May-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	2:46	3:01	0:15	LINE FAULT
776	16-May-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	2:46	3:01	0:15	LINE FAULT
777	16-May-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	3:02	3:30	0:28	LINE FAULT
778	16-May-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	3:02	3:30	0:28	LINE FAULT
779	16-May-2020	MYSURU	66	TUBINAKERE-MC-2	NO STATIONS	3:43	7:10	3:26	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
780	16-May-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	3:43	3:46	0:02	HAND TRIPPED
781	16-May-2020	MYSURU	66	TUBINAKERE- NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI _66 BASARALU_66	17:44	17:50	0:05	LINE FAULT
782	16-May-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	13:08:27(15.05.2020)	15:25	21:43hrs	LINE CHARGED
783	16-May-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	0:01	8:48	8:47	HAND TRIPPED
784	16-May-2020	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	14:21	14:51	0:30	HAND TRIPPED
785	16-May-2020	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	14:21	14:51	0:30	HAND TRIPPED
786	16-May-2020	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	15:21	16:21	1:00	LINE FAULT
787	16-May-2020	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	7:43	18:40	10:56	LINE CLEAR AVAILED
788	16-May-2020	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	9:49	17:54	8:04	LINE CLEAR AVAILED
789	16-May-2020	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	3:54	18:54	15:00	LINE FAULT
790	16-May-2020	TUMKUR	220	THALLAK 220kV- CHITRADURGA	THALLAKK_220	15:21	16:23	1:01	LINE FAULT
791	16-May-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	7:39	18:48	11:08	LINE CLEAR AVAILED
792	16-May-2020	TUMKUR	110	TR-1	TURUVEKERE_110	5:56	6:15	0:18	TRANSFORMER FAULT
793	16-May-2020	TUMKUR	110	TR-1	BIDARE_110	12:05	12:09	0:04	TRANSFORMER FAULT
794	16-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	14:51	17:51	2:59	HAND TRIPPED
795	16-May-2020	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	14:51	15:17	0:25	HAND TRIPPED
796	16-May-2020	TUMKUR	66	TR-2(HV SIDE )	ANTHRASANAHALLI_220	14:51	15:17	0:25	HAND TRIPPED
797	16-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	14:51	15:01	0:09	HAND TRIPPED
798	16-May-2020	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	14:21	14:51	0:30	HAND TRIPPED
799	16-May-2020	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	14:21	14:51	0:30	HAND TRIPPED
800	16-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	14:51	14:52	0:01	HAND TRIPPED
801	16-May-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:17	14:26	0:08	LINE FAULT
802	16-May-2020	TUMKUR	66	TR-1	KORATAGERE_66	0:17	0:36	0:19	TRANSFORMER FAULT
803	16-May-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:35	14:01	1:26	LINE CLEAR AVAILED
804	16-May-2020	TUMKUR	66	TR-2	KUKKAWADA_66	15:39	16:50	1:10	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
805	16-May-2020	TUMKUR	66	TR-2	MATHOD_66	14:48	14:53	0:05	TRANSFORMER FAULT
806	16-May-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:53	10:54	0:01	HAND TRIPPED
807	16-May-2020	TUMKUR	66	TR-1	PULAMG_66	12:42	14:56	2:14	LINE CLEAR AVAILED
808	16-May-2020	TUMKUR	66	TR-2	PULAMG_66	12:42	14:56	2:14	LINE CLEAR AVAILED
809	16-May-2020	TUMKUR	66	PULAMGHATTA66-MADHUGIRI 220kV	PULAMG_66	14:24	14:56	0:31	LINE CLEAR AVAILED
810	16-May-2020	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	14:33	14:46	0:12	LINE FAULT
811	16-May-2020	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	15:21	15:46	0:25	TRANSFORMER FAULT
812	16-May-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:21	15:45	1:23	LINE FAULT
813	16-May-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	14:21	15:21	0:59	LINE FAULT
814	16-May-2020	TUMKUR	66	TR-2	TUMKUR_66	14:24	14:48	0:23	MAIN SUPPLY FAILURE
815	16-May-2020	TUMKUR	66	TR-1	TUMKUR_66	14:24	14:49	0:24	MAIN SUPPLY FAILURE
816	17-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN, LINE FAULT
817	17-May-2020	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
818	17-May-2020	BAGALKOT	220	BIDNAL-HARTHI1	NO STATION EFFECTED BIDNAL_220	21:50 (13.05.2020)	8:13	82:23hrs	LINE CHARGED
819	17-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
820	17-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	21:54 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
821	17-May-2020	BAGALKOT	110	JAMKHANDI-MAHALINGAPUR (SIDAPUR)	JAMKHANDI_110	21:26 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
822	17-May-2020	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	2:37 (15.05.2020)			LINE IS OPEN, LINE FAULT
823	17-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	14:53 (15.05.2020)	8:05	17:12hrs	HAND TRIPPED
824	17-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	15:08 (15.05.2020)	18:04	23:39hrs	HAND TRIPPED
825	17-May-2020	BAGALKOT	110	BIJAPUR220- BIJAPUR CITY	BIJAPUR CITY_110	15:30 (16.05.2020)			LINE IS OPEN, LINE FAULT
826	17-May-2020	BAGALKOT	110	HIDIKAL-ITANAL	HIDIKAL_110	16:05 (16.05.2020)	19:41	60:13hrs	HAND TRIPPED
827	17-May-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	TARIHAL_110	18:23 (16.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
828	17-May-2020	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	15:10	15:38	0:28	HAND TRIPPED
829	17-May-2020	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	14:49	15:37	0:48	LINE FAULT
830	17-May-2020	BAGALKOT	110	CHIKKODI220 -NIPPANI	NIPPANI_110	11:31	12:45	1:14	LINE CLEAR AVAILED
831	17-May-2020	BAGALKOT	110	110/33KV ,HV2	HUNAGUND_110	18:47	18:53	0:06	TRANSFORMER FAULT
832	17-May-2020	BAGALKOT	220	220/110KV,HV1,LV1	SOUDATTI_220	9:40	16:02	6:22	LINE CLEAR AVAILED
833	17-May-2020	BAGALKOT	110	SOUDATTI220-SOUDATTI1&2	SOUDATTI_110	9:16	16:17	7:01	LINE CLEAR AVAILED
834	17-May-2020	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	9:21	17:21	8:00	LINE CLEAR AVAILED
835	17-May-2020	BAGALKOT	110	110/11KV,HV1	SOUDATTI_220	9:38	12:27	2:49	LINE CLEAR AVAILED
836	17-May-2020	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	15:26	16:18	0:52	LINE FAULT
837	17-May-2020	BAGALKOT	110	SIRSI220-SIRSI3	SIRSI_110	15:31	15:43	0:12	LINE FAULT
838	17-May-2020	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	15:30(17.5.20)			LINE IS OPEN, LINE FAULT
839	17-May-2020	BAGALKOT	220	SHIRALKOPPA-RANEENNUR	RANEENNUR_220	8:05	13:49	5:44	HAND TRIPPED
840	17-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	13:49(17.5.20)			LINE IS OPEN, LINE CLEAR AVAILED
841	17-May-2020	BAGALKOT	110	SAVADATTI-MUNAVALLI	MUNAVALLI_110	9:20	18:01	8:41	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
842	17-May-2020	BAGALKOT	110	110/11KV,HV1	MK HUBLI_220	9:13	14:35	5:22	HAND TRIPPED
843	17-May-2020	BAGALKOT	110	110/11KV,HV1	MK HUBLI_110	14:10	16:15	2:05	HAND TRIPPED
844	17-May-2020	BAGALKOT	110	110/11KV,HV4	MK HUBLI_110	8:58	16:11	7:13	HAND TRIPPED
845	17-May-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	14:46	14:49	0:03	HAND TRIPPED
846	17-May-2020	BENGALURU	220	HV1	DABUSPET 220	8:17	14:12	5:54	LINE CLEAR AVAILED
847	17-May-2020	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	8:10	14:46	6:36	LINE CLEAR AVAILED
848	17-May-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:19	15:22	0:03	LINE CLEAR AVAILED
849	17-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	7:06	7:17	0:11	LINE FAULT
850	17-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:19	18:45	0:26	LINE FAULT
851	17-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:45	19:05	0:20	LINE FAULT
852	17-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	19:05	22:15	3:10	LINE FAULT
853	17-May-2020	BENGALURU	220	HV3	KOLAR 220	6:53	7:47	0:54	TRANSFORMER FAULT
854	17-May-2020	BENGALURU	220	LV3	KOLAR 220	6:53	7:47	0:54	LINE FAULT
855	17-May-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	6:53	7:48	0:55	MAIN SUPPLY FAILURE
856	17-May-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	6:53	7:49	0:56	MAIN SUPPLY FAILURE
857	17-May-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	6:53	7:49	0:56	MAIN SUPPLY FAILURE
858	17-May-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	6:53	7:51	0:58	MAIN SUPPLY FAILURE
859	17-May-2020	BENGALURU	66	HV2	THAYALUR	18:00	18:05	0:04	TRANSFORMER FAULT
860	17-May-2020	BENGALURU	66	HV1	KYALANUR	13:06	13:18	0:11	TRANSFORMER FAULT
861	17-May-2020	BENGALURU	66	HV1	KYALANUR	13:50	13:58	0:08	TRANSFORMER FAULT
862	17-May-2020	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	5:59	6:29	0:29	LINE FAULT
863	17-May-2020	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	14:49	18:47	3:58	LINE FAULT
864	17-May-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	6:46	6:48	0:01	LINE CLEAR AVAILED
865	17-May-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	17:20	17:52	0:32	LINE FAULT
866	17-May-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	18:16	18:30	0:14	LINE FAULT
867	17-May-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	18:30	22:46	4:16	LINE FAULT
868	17-May-2020	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	11:15	11:20	0:05	LOAD CHANGE OVER
869	17-May-2020	BENGALURU	66	KUMBALAGODU - KENGRI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:30	13:40	0:10	LOAD CHANGE OVER
870	17-May-2020	BENGALURU	66	NELAKADRINAHALLI - SRS 220	NELAKADRINAHALLI	9:28	10:44	1:16	MAIN SUPPLY FAILURE
871	17-May-2020	BENGALURU	66	NELAKADRINAHALLI - BRINDAVANA	NELAKADRINAHALLI	13:39	13:51	0:12	LOAD CHANGE OVER
872	17-May-2020	BENGALURU	66	SRS 220 - NELAKADRINAHALLI	NO STATION AFFECTED	9:28	13:50	4:22	LINE CLEAR AVAILED
873	17-May-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	14:12	14:16	0:04	LOAD CHANGE OVER



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
874	17-May-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	18:01	18:05	0:04	LOAD CHANGE OVER
875	17-May-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	22:13	22:30	0:17	LOAD CHANGE OVER
876	17-May-2020	BENGALURU	66	SOLADEVANAHALLI - YELAHANKA 220	SOLADEVANAHALLI	5:59	6:19	0:20	MAIN SUPPLY FAILURE
877	17-May-2020	BENGALURU	66	SOLADEVANAHALLI - SRS PEENYA 220	SOLADEVANAHALLI	6:38	6:45	0:07	LOAD CHANGE OVER
878	17-May-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	NO STATION AFFECTED	22:14	22:52	0:38	LINE FAULT
879	17-May-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	NO STATION AFFECTED	22:14	22:47	0:33	LINE FAULT
880	17-May-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	14:11	14:18	0:07	LOAD CHANGE OVER
881	17-May-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:54	18:00	0:06	LOAD CHANGE OVER
882	17-May-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	22:12	22:30	0:18	LOAD CHANGE OVER
883	17-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:01	18:54	2:53	LINE FAULT
884	17-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:10	19:35	0:25	LINE CLEAR AVAILED
885	17-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:54	20:02	0:08	LOAD CHANGE OVER
886	17-May-2020	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATIONS AFFECTED	17:25	17:45	0:20	LINE FAULT
887	17-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:05	17:26	1:21	LINE FAULT
888	17-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:34	18:41	1:07	LINE FAULT
889	17-May-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	23:17	23:30	0:12	LINE FAULT
890	17-May-2020	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	6:38 (17-5-2020)			LINE IS OPEN, LINE FAULT
891	17-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:15(17-5-2020)			LINE IS OPEN, LINE FAULT
892	17-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	NO STATION AFFECTED	18:41(17.05.2020)			LINE IS OPEN, LINE FAULT
893	17-May-2020	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATIONS AFFECTED	17:45(17.05.2020)			LINE IS OPEN, LINE FAULT
894	17-May-2020	BENGALURU	66	VOLVO - NANDAGUDI	NANDAGUDI	6:19 (17.05.2020)			LINE IS OPEN, LINE FAULT
895	17-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
896	17-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
897	17-May-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	0:50	2:24	1:34	LINE FAULT
898	17-May-2020	GULBARGA	220	HV1	KUSTAGI_220	11:27	11:35	0:08	TRANSFORMER FAULT
899	17-May-2020	GULBARGA	220	HV1	KUSTAGI_220	11:50	12:00	0:10	TRANSFORMER FAULT
900	17-May-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	4:40	4:50	0:10	LINE FAULT
901	17-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	10:05	10:50	0:45	LINE FAULT
902	17-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	21:16	21:26	0:10	LINE FAULT
903	17-May-2020	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	23:49(16.5.2020)	12:10	0:20hrs	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
904	17-May-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, HUNSAGI_110, ASKI_110	0:12	0:19	0:07	LINE FAULT
905	17-May-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	5:15	5:26	0:11	LINE FAULT
906	17-May-2020	GULBARGA	110	HV3	BEVOOR_110	15:32	15:40	0:08	TRANSFORMER FAULT
907	17-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	18:05 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVALIED
908	17-May-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:39 (17.05.2020)			LINE IS OPEN, LINE FAULT
909	17-May-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	18:39 (17.05.2020)			LINE IS OPEN, LINE FAULT
910	17-May-2020	HASSAN	220	HV2	KAVOOR_220	9:28	11:55	2:27	LINE CLEAR AVALIED
911	17-May-2020	HASSAN	110	LV2	KAVOOR_220	9:27	11:55	2:28	LINE CLEAR AVALIED
912	17-May-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:23	18:22	0:59	LINE FAULT
913	17-May-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:23	18:30	1:07	LINE FAULT
914	17-May-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	18:17 (17.05.2020)			LINE IS OPEN, LINE FAULT
915	17-May-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	16:57	17:18	0:21	LINE FAULT
916	17-May-2020	HASSAN	110	MRSSHM-MPM	MRSMSG_220	15:32	16:45	1:13	LINE FAULT
917	17-May-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	18:50	20:52	2:02	LINE FAULT
918	17-May-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	18:17 (17.05.2020)			LINE IS OPEN, LINE FAULT
919	17-May-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	16:57	17:19	0:22	LINE FAULT
920	17-May-2020	HASSAN	110	HV1	GANDASI_110	22:45 (17.05.2020)			LINE IS OPEN, LINE CLEAR AVALIED
921	17-May-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:25	18:23	0:58	MAIN SUPPLY FAILURE
922	17-May-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:25	18:30	1:05	MAIN SUPPLY FAILURE
923	17-May-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:25	18:25	1:00	MAIN SUPPLY FAILURE
924	17-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	19:42 (17.05.2020)			LINE IS OPEN, LINE FAULT
925	17-May-2020	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	20:03	21:04	1:01	LINE FAULT
926	17-May-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:57	18:34	0:37	LINE FAULT
927	17-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:00	19:12	9:12	LINE CLEAR AVALIED
928	17-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:59	19:13	9:14	LINE CLEAR AVALIED
929	17-May-2020	HASSAN	66	HV2	UDAYAPURA_66	4:05	4:11	0:06	TRANSFORMER FAULT
930	17-May-2020	HASSAN	66	HV2	UDAYAPURA_66	4:17	4:20	0:03	TRANSFORMER FAULT
931	17-May-2020	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	19:24	20:30	1:06	LINE FAULT
932	17-May-2020	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	19:24	20:28	1:04	LINE FAULT
933	17-May-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	19:27	20:31	1:04	HAND TRIPPED
934	17-May-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	19:25	20:31	1:06	HAND TRIPPED
935	17-May-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	19:25	20:31	1:06	HAND TRIPPED
936	17-May-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	19:27	20:29	1:02	HAND TRIPPED
937	17-May-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	19:37	19:51	0:14	LINE FAULT
938	17-May-2020	MYSURU	66	HV5	SFCSHIVA_66	13:06(15.05.2020)			TRANSFORMER IS OPEN LINE CLEAR AVALIED
939	17-May-2020	MYSURU	66	BASARALU-HAMPAPURA	NO STATIONS	11:51 (16.05.20)	19:48	7:57	LINE CHARGED
940	17-May-2020	MYSURU	66	HV1	BOOKANAKERE	13:05	13:11	0:06	HAND TRIPPED
941	17-May-2020	MYSURU	66	HV2	BOOKANAKERE-	13:16	13:24	0:07	HAND TRIPPED
942	17-May-2020	MYSURU	66	HV1	CHUNCHUNKATTE_66	13:45	14:17	0:32	TRANSFORMER FAULT
943	17-May-2020	MYSURU	66	CR NAGARA-DR PETE 1	DODDARAYAPET_66	11:33	15:37	4:04	NFBC ISSUED
944	17-May-2020	MYSURU	66	CR NAGARA-DR PETE 2	DODDARAYAPET_66	11:33	16:39	5:06	NFBC ISSUED
945	17-May-2020	MYSURU	66	CR NAGARA-GUNDLUPETE	TERAKANAMBE_66	10:05	15:35	5:30	NFBC ISSUED
946	17-May-2020	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS	17:54	18:06	0:11	LINE FAULT
947	17-May-2020	MYSURU	220	CR NAGARA-MADHUVANAHALLI-2	NO STATIONS	16:53	18:02	1:09	LINE FAULT
948	17-May-2020	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATIONS	10:01	17:50	7:49	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
949	17-May-2020	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATIONS	19:40(17.5.20)			LINE IS OPEN, LINE FAULT
950	17-May-2020	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66	13:04	13:12	0:07	LINE FAULT
951	17-May-2020	MYSURU	66	HOOTAGALLI-FTS 1	FTS_66	10:05	17:14	7:08	NFBC ISSUED
952	17-May-2020	MYSURU	66	JYOTHINAGARA-FTS	NO STATIONS	6:36	18:02	11:26	NFBC ISSUED
953	17-May-2020	MYSURU	220	KADAKOLA-CR NAGARA 1	NO STATIONS	12:12	12:38	0:25	LINE FAULT
954	17-May-2020	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS	15:59	16:35	0:36	LINE FAULT
955	17-May-2020	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	16:58	17:30	0:32	LINE FAULT
956	17-May-2020	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	18:53	19:48	0:54	HAND TRIPPED
957	17-May-2020	MYSURU	66	HV2	KOPPA_66	7:36	7:42	0:05	TRANSFORMER FAULT
958	17-May-2020	MYSURU	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 TNARASIPURA_66 THAYURU_66	18:02	18:10	0:07	LINE FAULT
959	17-May-2020	MYSURU	66	HV2	MANDYA_66	17:53	18:55	1:02	TRANSFORMER FAULT
960	17-May-2020	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS	18:39	18:46	0:07	LINE FAULT
961	17-May-2020	MYSURU	66	MADHUVANAHALLY-PG PALYA	PGPALYA_66	23:06	23:28	0:21	LINE FAULT
962	17-May-2020	MYSURU	66	HV1	PANDAVAPURA_66	10:00	17:15	7:15	LINE CLEAR AVAILED
963	17-May-2020	MYSURU	66	HV2	PANDAVAPURA_66	10:00	16:19	6:19	LINE CLEAR AVAILED
964	17-May-2020	MYSURU	66	HV2	PANDAVAPURA_66	20:20	21:20	0:59	TRANSFORMER FAULT
965	17-May-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	6:12	6:20	0:08	LINE FAULT
966	17-May-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	6:12	6:20	0:08	LINE FAULT
967	17-May-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66 BASARALU_66	12:16	12:23	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
968	17-May-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI _66 BASARALU_66	14:49	14:57	0:08	LINE FAULT
969	17-May-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI _66 BASARALU_66	18:05	18:12	0:06	LINE FAULT
970	17-May-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY _66	19:30	19:35	0:05	LINE FAULT
971	17-May-2020	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	14:46	16:10	1:24	LINE CLEAR AVAILED
972	17-May-2020	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	20:35	20:41	0:06	LINE FAULT
973	17-May-2020	TUMKUR	220	TR-1	ANCHEPALYA_220	19:09	20:15	1:06	HAND TRIPPED
974	17-May-2020	TUMKUR	220	TR-2	ANCHEPALYA_220	19:09	20:15	1:06	HAND TRIPPED
975	17-May-2020	TUMKUR	220	ANCHEPALYA 220kV-NELMANGALA 1	ANCHEPALYA_220	19:09	20:14	1:05	HAND TRIPPED
976	17-May-2020	TUMKUR	220	ANCHEPALYA 220kV- MAGADI	ANCHEPALYA_220	19:09	20:14	1:05	HAND TRIPPED
977	17-May-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	9:12	10:27	1:14	LINE CLEAR AVAILED
978	17-May-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	17:43	17:57	0:14	TRANSFORMER FAULT
979	17-May-2020	TUMKUR	110	TR-2	SAMPIGE_110	11:03	11:25	0:21	LINE CLEAR AVAILED
980	17-May-2020	TUMKUR	66	AMRUTHUR-ANCHEPALYA	AMRUTHUR_66	7:07:44 PM(17.5.20)			MAIN SUPPLY FAILURE
981	17-May-2020	TUMKUR	66	ANCHEPALYA 220kV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	19:07	20:23	1:16	HAND TRIPPED
982	17-May-2020	TUMKUR	66	ANCHEPALYA 220kV-ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	19:07	20:23	1:16	HAND TRIPPED
983	17-May-2020	TUMKUR	66	ANCHEPALYA 220kV-HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	19:07	20:23	1:16	HAND TRIPPED
984	17-May-2020	TUMKUR	66	ANCHEPALYA 220kV-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	19:07	20:23	1:16	HAND TRIPPED
985	17-May-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGODODDI_66	19:07	20:23	1:16	HAND TRIPPED
986	17-May-2020	TUMKUR	66	ANCHEPALYA 220kV-YEDIYUR(BG NAGAR)	YEDIYUR_66	19:07	20:23	1:16	HAND TRIPPED
987	17-May-2020	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:17	14:27	0:10	LINE FAULT
988	17-May-2020	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	BEVINAHALLI_66	20:25	20:50	0:25	LINE FAULT
989	17-May-2020	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON1_IPP_66	19:55	22:50	2:55	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
990	17-May-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	15:30	15:40	0:09	LINE FAULT
991	17-May-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	2:40	2:45	0:05	LINE FAULT
992	17-May-2020	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	16:42	16:48	0:06	LINE FAULT
993	17-May-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LI NGDHALLI_66,MANGALWADA_66	23:15(17.5.20)			LINE IS OPEN, LINE FAULT
994	18-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN, LINE FAULT
995	18-May-2020	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
996	18-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
997	18-May-2020	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED HIDIKAL DAM_110	21:54 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
998	18-May-2020	BAGALKOT	220	HUBLI-NARENDRA2	NO STATION EFFECTED HUBLI_220	2:37 (15.05.2020)	17:49	39:12hrs	LINE CHARGED
999	18-May-2020	BAGALKOT	110	BIJAPUR220- BIJAPUR CITY	NO STATION EFFECTED BIJAPUR CITY_110	12:50 (16.05.2020)			LINE IS OPEN, LINE FAULT
1000	18-May-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	NO STATION EFFECTED TARIHAL_110	18:25 (16.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1001	18-May-2020	BAGALKOT	110	SIRSI220-KAVALWADA	NO STATION EFFECTED KAVALWADA_110	15:30 (17.05.2020)			LINE IS OPEN, LINE FAULT
1002	18-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	NO STATION EFFECTED RANEENNUR_220	13:49 (17.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1003	18-May-2020	BAGALKOT	220	HARTI1&2-GADAG	GADAG_220	22:43 (17.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1004	18-May-2020	BAGALKOT	220	AMBEWSDI-NARENDRA1	AMBEWADI_220	2:18	17:38	15:20	HAND TRIPPED
1005	18-May-2020	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	11:07	11:37	0:30	LINE CLEAR AVAILED
1006	18-May-2020	BAGALKOT	110	ANKOLA-KUMTA2	ANKOLA_110	20:04 (18.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1007	18-May-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	12:22	12:25	0:03	TRANSFORMER FAULT
1008	18-May-2020	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	10:11	10:42	0:31	LINE FAULT
1009	18-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	0:01	0:03	0:02	TRANSFORMER FAULT
1010	18-May-2020	BAGALKOT	110	HUNGUND-KUDALASANGAM	HUNGUND_110	5:38	5:41	0:03	LINE FAULT
1011	18-May-2020	BAGALKOT	110	110/11KV,HV2	MALAGHAN(B)_110	0:42	0:47	0:05	TRANSFORMER FAULT
1012	18-May-2020	BAGALKOT	110	110/11KV,HV2	MALAGHAN(B)_110	11:21	11:24	0:03	TRANSFORMER FAULT
1013	18-May-2020	BAGALKOT	110	110/11KV,HV2	MALAGHAN(S)_110	7:32	13:11	5:39	TRANSFORMER FAULT
1014	18-May-2020	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	10:54	11:07	0:13	HAND TRIPPED
1015	18-May-2020	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	12:09	12:13	0:04	TRANSFORMER FAULT
1016	18-May-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:16	17:43	7:27	LINE CLEAR AVAILED
1017	18-May-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	17:36 (18.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1018	18-May-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	17:39 (18.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1019	18-May-2020	BAGALKOT	110	RANNABELAGALI-MUDHOL (UTTUR)	UTTUR_110	12:26	12:31	0:05	HAND TRIPPED
1020	18-May-2020	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	13:53	14:06	0:13	TRANSFORMER FAULT
1021	18-May-2020	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	15:45	21:35	5:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1022	18-May-2020	BAGALKOT	110	NAREGAL-BETAGERI	NAREGAL_110	11:09 (18.05.2020)			LINE IS OPEN, LINE CLEAR AVAILED
1023	18-May-2020	BAGALKOT	110	BALAGI SUGARS- MUDDEBIHAL	MUDDEBIHAL_110	16:10	16:23	0:13	LINE FAULT
1024	18-May-2020	BAGALKOT	110	BALAGI SUGARS- MUDDEBIHAL	MUDDEBIHAL_110	17:24	18:50	1:26	HAND TRIPPED
1025	18-May-2020	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	6:38 (17-5-2020)			LINE IS OPEN, LINE FAULT
1026	18-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:15(17-5-2020)			LINE IS OPEN, LINE FAULT
1027	18-May-2020	BENGALURU	66	VOLVO - NANDAGUDI	NANDAGUDI	6:19 (17.05.2020)			LINE IS OPEN, LINE FAULT
1028	18-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	NO STATIONS AFFECTED	18:41(17.05.2020)	11:15	15:34hrs	LINE CHARGED
1029	18-May-2020	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATIONS AFFECTED	17:45:00(17.05.2020)	13:30	18:45hrs	LINE CHARGED
1030	18-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:15	8:39	0:24	LINE FAULT
1031	18-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:25	11:40	0:15	LINE CLEAR AVAILED
1032	18-May-2020	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA	11:58	13:27	1:29	LINE CLEAR AVAILED
1033	18-May-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	5:45	5:50	0:05	LOAD CHANGE OVER
1034	18-May-2020	BENGALURU	66	HV1	V G DODDI	9:03	9:10	0:07	TRANSFORMER FAULT
1035	18-May-2020	BENGALURU	66	GANIJUGUNTE - CHINTAMANI 1	NO STATION AFFECTED	14:57	15:00	0:02	LINE FAULT
1036	18-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	16:45	16:57	0:11	LINE FAULT
1037	18-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:08	20:24	2:16	LINE FAULT
1038	18-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	0:00	0:20	0:20	LINE IS OPEN, LINE FAULT
1039	18-May-2020	BENGALURU	66	HV1	DEVANAHALLI	12:50	15:10	2:20	LINE CLEAR AVAILED
1040	18-May-2020	BENGALURU	66	HV2	GANJIGUNTE	14:52	15:05	0:12	TRANSFORMER FAULT
1041	18-May-2020	BENGALURU	66	HV1	KENGERI SATELLITE	10:49	10:54	0:04	LINE CLEAR AVAILED
1042	18-May-2020	BENGALURU	66	HV2	KENGERI SATELLITE	12:34	12:39	0:05	LINE CLEAR AVAILED
1043	18-May-2020	BENGALURU	66	TADIGOLU CROSS - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:20	18:35	0:15	LINE FAULT
1044	18-May-2020	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	14:32	14:35	0:03	LOAD CHANGE OVER
1045	18-May-2020	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	15:10	15:15	0:05	LOAD CHANGE OVER
1046	18-May-2020	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	0:00	8:38	8:38	LINE IS OPEN, LINE FAULT
1047	18-May-2020	BENGALURU	66	VOLVO - NANDAGUDI	NANDAGUDI	0:00	0:20	0:20	LINE IS OPEN, LINE FAULT
1048	18-May-2020	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
1049	18-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN, LINE FAULT
1050	18-May-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	3:15	3:25	0:10	LINE FAULT
1051	18-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	8:40	8:56	0:16	LINE FAULT
1052	18-May-2020	GULBARGA	110	SINDHANOR220- SINDHANOOR1	MASKI_110, MUDDAPUR_110	23:20	23:30	0:10	LINE FAULT
1053	18-May-2020	GULBARGA	110	HV3	HANUMASAGAR_110	2:15	4:15	2:00	TRANSFORMER FAULT
1054	18-May-2020	GULBARGA	110	HV3	HANUMASAGAR_110	8:15	8:40	0:25	TRANSFORMER FAULT
1055	18-May-2020	GULBARGA	110	HV3	HANUMASAGAR_110	9:10	9:15	0:05	TRANSFORMER FAULT
1056	18-May-2020	GULBARGA	110	HV3	HANUMASAGAR_110	9:20	21:50	12:30	LINE CLEAR AVAILED
1057	18-May-2020	GULBARGA	110	HV1	YELBURGA_110	8:25	8:34	0:09	TRANSFORMER FAULT
1058	18-May-2020	GULBARGA	110	HV1	YELBURGA_110	9:10	17:35	8:25	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1059	18-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	18:05 (15.05.2020)			LINE IS OPEN, LINE CLEAR AVOIDED
1060	18-May-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	18:39 (17.05.2020)	8:47	14:07hrs	LINE CHARGED
1061	18-May-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	18:17 (17.05.2020)	10:07	11:00hrs	LINE CHARGED
1062	18-May-2020	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	18:17 (17.05.2020)	10:08	11:22hrs	LINE CHARGED
1063	18-May-2020	HASSAN	110	MANIPAL-HIRIYADKA	NO STATION AFFECTED	19:42 (17.05.2020)			LINE IS OPEN, LINE FAULT
1064	18-May-2020	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	18:17 (17.05.2020)	10:08	11:22hrs	LINE CHARGED
1065	18-May-2020	HASSAN	110	HV2	HALADY_110	21:48 (18.05.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
1066	18-May-2020	HASSAN	110	HV1	GANDASI_110	22:45 (17.05.2020)	0:04	1:18hrs	LINE CLEAR AVOIDED
1067	18-May-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	1:49	2:02	0:13	LINE FAULT
1068	18-May-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	7:24	10:27	3:03	HAND TRIPPED
1069	18-May-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	7:01	9:32	2:31	LINE FAULT
1070	18-May-2020	HASSAN	66	LV1	MRSMSG_220	22:55	23:41	0:46	HAND TRIPPED
1071	18-May-2020	HASSAN	66	LV2	MRSMSG_220	22:55	23:40	0:45	HAND TRIPPED
1072	18-May-2020	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:08	15:28	4:20	LINE CLEAR AVOIDED
1073	18-May-2020	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:08	15:28	4:20	LINE CLEAR AVOIDED
1074	18-May-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	7:02	9:34	2:32	LINE FAULT
1075	18-May-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	1:38	2:24	0:46	LINE FAULT
1076	18-May-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	5:12	7:24	2:12	LINE FAULT
1077	18-May-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:27	13:03	0:36	HAND TRIPPED
1078	18-May-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	1:38	2:23	0:45	LINE FAULT
1079	18-May-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	5:12	6:02	0:50	LINE FAULT
1080	18-May-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	12:48	13:15	0:27	LINE FAULT
1081	18-May-2020	HASSAN	110	HV3	BANTWALA_110	1:56	2:47	0:51	TRANSFORMER FAULT
1082	18-May-2020	HASSAN	110	HV3	BANTWALA_110	11:46	12:14	0:28	LINE CLEAR AVOIDED
1083	18-May-2020	HASSAN	110	BARANG-SHR220	BARANGI_110	12:37	13:16	0:39	LINE CLEAR AVOIDED
1084	18-May-2020	HASSAN	110	HV1	GANDASI_110	8:56	11:26	2:30	LINE CLEAR AVOIDED
1085	18-May-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	1:38	2:23	0:45	LINE FAULT
1086	18-May-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	5:13	7:24	2:11	LINE FAULT
1087	18-May-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:27	13:03	0:36	HAND TRIPPED
1088	18-May-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	1:38	2:22	0:44	LINE FAULT
1089	18-May-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	5:12	6:02	0:50	LINE FAULT
1090	18-May-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	1:40	2:23	0:43	MAIN SUPPLY FAILURE
1091	18-May-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	5:13	6:03	0:50	MAIN SUPPLY FAILURE
1092	18-May-2020	HASSAN	110	JOG-JLT3	mghejog_gen	14:03	15:18	1:15	NFBC ISSUED
1093	18-May-2020	HASSAN	110	JOG110-AMBTR2	JOG_110	14:01	15:20	1:19	LINE CLEAR AVOIDED
1094	18-May-2020	HASSAN	110	JOG110-LPH	JOG_110	14:07	15:19	1:12	LINE CLEAR AVOIDED
1095	18-May-2020	HASSAN	110	JOG110-MGHE	JOG_110	14:02	15:17	1:15	LINE CLEAR AVOIDED
1096	18-May-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	7:27	7:48	0:21	MAIN SUPPLY FAILURE
1097	18-May-2020	HASSAN	110	HV2	KULASHEKARA_110	11:59	14:00	2:01	TRANSFORMER FAULT
1098	18-May-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	2:07	2:42	0:35	LINE FAULT
1099	18-May-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:08	13:09	1:01	LINE CLEAR AVOIDED
1100	18-May-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	1:00	1:46	0:46	LINE FAULT
1101	18-May-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	3:46	4:19	0:33	LINE FAULT
1102	18-May-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	13:12	14:46	1:34	LINE CLEAR AVOIDED
1103	18-May-2020	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	13:09	14:48	1:39	LINE CLEAR AVOIDED
1104	18-May-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	3:19	3:38	0:19	LINE FAULT
1105	18-May-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_110	14:27	14:49	0:22	HAND TRIPPED
1106	18-May-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:29	14:11	0:42	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1107	18-May-2020	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	0:18	0:55	0:37	MAIN SUPPLY FAILURE
1108	18-May-2020	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	13:05	14:50	1:45	NFBC ISSUED
1109	18-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:04	16:43	6:39	LINE CLEAR AVAILED
1110	18-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:04	16:17	6:13	LINE CLEAR AVAILED
1111	18-May-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	13:44	14:12	0:28	MAIN SUPPLY FAILURE
1112	18-May-2020	MYSURU	66	HV5	SFCSHIVA_66	13:05 (15.05.2020)			TRANSFORMER IS OPEN LINE CLEAR AVAILED
1113	18-May-2020	MYSURU	220	MADHUVANAHALLI- WARDASOLAR	NO STATIONS EFFECTED	43 (17.05.2020)	19:40 (17.05.2020)	1:41hrs	LINE CHARGED
1114	18-May-2020	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	12:54	13:30 (18.05.2020)	19:50hrs	LINE CHARGED
1115	18-May-2020	MYSURU	66	HV1	CHUNCHUNKATTE_66	12:54	13:55	1:00	LINE CLEAR AVAILED
1116	18-May-2020	MYSURU	66	HV1	HANNUR_66	10:30	17:00	6:30	LINE CLEAR AVAILED
1117	18-May-2020	MYSURU	66	HANNUR-HV2	HANNUR_66	10:30	17:00	6:30	LINE CLEAR AVAILED
1118	18-May-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66, COWDALLI_66, RAMAPURA_MYS_66 & MARTAHALLI_66 STATIONS INTERRUPTED	16:00	17:20	1:20	LINE CLEAR AVAILED
1119	18-May-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66, COWDALLI_66, RAMAPURA_MYS_66 & MARTAHALLI_66 STATIONS INTERRUPTED	18:00	18:15	0:15	LINE CLEAR AVAILED
1120	18-May-2020	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATIONS EFFECTED	13:38	16:35	2:57	LINE CLEAR AVAILED
1121	18-May-2020	MYSURU	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	11:00	12:14	1:13	LINE CLEAR AVAILED
1122	18-May-2020	MYSURU	66	KADAKOLA-SARGUR 2	JAIPUR_66, HAMPAPURA_66, HDKOTE_66, ANTHARSANTHE_66, DOORA_66, HULLAHALLI_66, HURA_66, CHANDAKAVADI_66, SANTHESARAGUR_66 & B MATKERE_66	11:56	11:59	0:03	LINE FAULT
1123	18-May-2020	MYSURU	66	HV3	KUSHALNAGARA_66	10:34	10:46	0:12	TRANSFORMER FAULT
1124	18-May-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	12:51	13:38	0:46	LINE CLEAR AVAILED
1125	18-May-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	13:23	14:06	0:43	LINE CLEAR AVAILED
1126	18-May-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:52	14:39	0:47	LINE CLEAR AVAILED
1127	18-May-2020	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	11:11	12:16	1:05	LINE CLEAR AVAILED
1128	18-May-2020	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	12:24	13:25	1:01	LINE CLEAR AVAILED
1129	18-May-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:51	12:46	0:55	LINE CLEAR AVAILED
1130	18-May-2020	MYSURU	66	SANTESARGUR-KALSON	NO STATIONS EFFECTED	8:20	18:45	10:25	NFBC ISSUED
1131	18-May-2020	MYSURU	66	SANTESARGUR-MARUTI	NO STATIONS EFFECTED	8:20	18:45	10:25	NFBC ISSUED
1132	18-May-2020	MYSURU	66	TUBINKERE-M-2	NO STATIONS EFFECTED	15:00	15:15	0:15	LINE FAULT
1133	18-May-2020	MYSURU	66	KIADB MANDYA -TK HALLI	KIADBMANDYA_66, TUMBKERE_66, KOLKARANADODDI_66 & KMDODDI_66	8:14	8:39	0:25	HAND TRIPPED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1134	18-May-2020	MYSURU	66	HV1	KIADBMANDYA_66	9:32	14:30	4:58	LINE CLEAR AVAILED
1135	18-May-2020	MYSURU	66	HV2	KIADBMANDYA_66	9:32	14:30	4:58	LINE CLEAR AVAILED
1136	18-May-2020	MYSURU	66	KK HALLI-MALAVALLI	MALAVALLI_66 & HADLI_66	14:00	14:10	0:10	LINE FAULT
1137	18-May-2020	MYSURU	66	KK HALLI-MALAVALLI	MALAVALLI_66 & HADLI_66	15:00	15:15	0:15	LINE FAULT
1138	18-May-2020	MYSURU	66	HV2	NAGAMANGALA_66	8:00	8:15	0:15	LINE CLEAR AVAILED
1139	18-May-2020	MYSURU	66	HV2	NAGAMANGALA_66	12:00	14:10	2:10	LINE CLEAR AVAILED
1140	18-May-2020	TUMKUR	66	AMRUTHUR-ANCHEPALYA	AMRUTHUR_66	7:07(17.5.20)			MAIN SUPPLY FAILURE
1141	18-May-2020	TUMKUR	220	ANTHRASANAHALI 220KV-SHIMOGA	ANTHRASANAHALI_220	10:42	10:55	0:13	LOAD CURTAILMENT
1142	18-May-2020	TUMKUR	220	ANTHRASANAHALI 220KV-VASANTHNARASAPURA 1	ANTHRASANAHALI_220	10:42	10:55	0:13	LINE FAULT
1143	18-May-2020	TUMKUR	220	ANTHRASANAHALI 220KV-VASANTHNARASAPURA 2	ANTHRASANAHALI_220	10:43	12:05	1:21	LINE CLEAR AVAILED
1144	18-May-2020	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	1:58	6:00	4:02	LINE FAULT
1145	18-May-2020	TUMKUR	220	HONNALLI 220KV- SUZLON1	SUZLON_IPP_66	10:51	13:00	2:08	LINE CLEAR AVAILED
1146	18-May-2020	TUMKUR	110	KB CROSS 220KV-TURUVEKERE110	TURUVEKERE_110	2:03	2:50	0:46	LINE FAULT
1147	18-May-2020	TUMKUR	110	KB CROSS 220KV-TURUVEKERE110	TURUVEKERE_110	8:20	10:55	2:35	LINE CLEAR AVAILED
1148	18-May-2020	TUMKUR	66	TR-1	YEDIYUR_66	10:45	11:05	0:19	TRANSFORMER FAULT
1149	18-May-2020	TUMKUR	66	TR-1	TUMKUR_66	10:46	10:58	0:11	MAIN SUPPLY FAILURE
1150	18-May-2020	TUMKUR	66	TR-2	TUMKUR_66	10:46	10:58	0:11	MAIN SUPPLY FAILURE
1151	18-May-2020	TUMKUR	66	THALLAK 220KV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	18:43	18:49	0:06	LINE CLEAR AVAILED
1152	18-May-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	11:15	0:36	10:38	MAIN SUPPLY FAILURE
1153	18-May-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LI NGDHALLI_66,MANGALWADA_66	23:15(17.05.2020)	0:32	25:16hrs	LINE CHARGED
1154	18-May-2020	TUMKUR	66	PAVAGADA-PAVAGADA2	PAVAGADA_66	4:01	6:03	2:02	LINE FAULT
1155	18-May-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	1:46	1:49	0:02	LINE FAULT
1156	18-May-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	1:20	1:45	0:25	LINE FAULT
1157	18-May-2020	TUMKUR	66	CHITRADURGA 220KV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	11:55(18.05.2020)	1:41(19.05.202)	24:10hrs	LINE CHARGED