

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 07.01.2020 TO 13.01.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	7-Jan-2020	BAGALKOT	220	PONDA 1-AMBEWADI	AMBEWADI_220	12:27	20:11	7:44	LINE CLEAR AVAILED
2	7-Jan-2020	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	16:06	16:38	0:32	LINE CLEAR AVAILED
3	7-Jan-2020	BAGALKOT	110	110/11KV,HV 2	ANKALI_110	11:43	12:17	0:34	HAND TRIPPED
4	7-Jan-2020	BAGALKOT	110	ATHANI -KSSKN	ATHANI_220	1:18	1:31	0:13	LINE FAULT
5	7-Jan-2020	BAGALKOT	110	ATHANI -KSSKN	ATHANI_220	2:03	2:17	0:14	LINE FAULT
6	7-Jan-2020	BAGALKOT	110	110/11KV HV1	BYADAGI_110	13:58	14:27	0:29	TRANSFORMER FAULT
7	7-Jan-2020	BAGALKOT	220	BIDNAL-HUBLI 3	BIDNAL_220	10:08	14:03	3:55	NFBC ISSUED
8	7-Jan-2020	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	11:11	13:37	2:26	LINE FAULT
9	7-Jan-2020	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	16:04	16:17	0:13	HAND TRIPPED
10	7-Jan-2020	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	16:20	16:25	0:05	HAND TRIPPED
11	7-Jan-2020	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	16:28	16:38	0:10	HAND TRIPPED
12	7-Jan-2020	BAGALKOT	220	BIDNAL-NAGJHARI 2	BIDNAL_220	16:41	16:48	0:07	HAND TRIPPED
13	7-Jan-2020	BAGALKOT	220	HARTHI1&2-GADAG	GADAG_220	11:18	16:48	5:30	LINE CLEAR AVAILED
14	7-Jan-2020	BAGALKOT	110	110/11KV,HV2	GAJENDRAGAD_110	20:24	20:36	0:12	HAND TRIPPED
15	7-Jan-2020	BAGALKOT	110	110/33KV,HV3	GAJENDRAGAD_110,WIND1&2_33	20:25	20:37	0:12	HAND TRIPPED
16	7-Jan-2020	BAGALKOT	110	110/33KV,HV4	GAJENDRAGAD_110,WIND3&4_33	20:24	20:31	0:07	HAND TRIPPED
17	7-Jan-2020	BAGALKOT	110	110/33KV,HV2	HANGAL_110	8:31	8:43	0:12	TRANSFORMER FAULT
18	7-Jan-2020	BAGALKOT	110	VAJARAMATTI220-MANTUR(MUDHOL)	MUDHOL_110	12:42	12:57	0:15	LINE CLEAR AVAILED
19	7-Jan-2020	BAGALKOT	220	HUBLI-BIDNAL2	HUBLI_220	10:08	14:13	4:05	LINE CLEAR AVAILED
20	7-Jan-2020	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	10:25	16:42	6:17	LINE CLEAR AVAILED
21	7-Jan-2020	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	10:18	18:24	8:06	NFBC ISSUED
22	7-Jan-2020	BAGALKOT	110	110/11KV, HV2	SIRSI_110	18:03	18:10	0:07	LINE CLEAR AVAILED
23	7-Jan-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	18:13	18:19	0:06	LINE CLEAR AVAILED
24	7-Jan-2020	BAGALKOT	110	RON-GAJENDRAGAD1	GAJENDRAGAD_110	20:00	20:29	0:29	LINE FAULT
25	7-Jan-2020	BAGALKOT	110	RON-GAJENDRAGAD2	GAJENDRAGAD_110	20:00	23:59	3:59	LINE FAULT
26	7-Jan-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	9:09	9:15	0:06	TRANSFORMER FAULT
27	7-Jan-2020	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	11:47	18:06	6:19	NFBC ISSUED
28	7-Jan-2020	BAGALKOT	220	220/110KV, HV1&LV1	MAHALINGAPUR_220	10:35	23:59	13:24	NFBC ISSUED
29	7-Jan-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:15	17:18	4:03	LINE FAULT
30	7-Jan-2020	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	18:29	18:36	0:07	LINE FAULT
31	7-Jan-2020	BAGALKOT	220	220/110KV,HV1	RANEENNUR_220	15:14	17:30	2:16	LINE CLEAR AVAILED
32	7-Jan-2020	BAGALKOT	110	110/11KV,HV2,HV3&HV4	RANEENNUR_220	15:08	15:20	0:12	HAND TRIPPED
33	7-Jan-2020	BAGALKOT	110	110/33KV,HV1	RANEENNUR_220,RSNG_33,PUTTELLUR_33	15:10	15:20	0:10	HAND TRIPPED
34	7-Jan-2020	BAGALKOT	110	110/33KV,HV2	RANEENNUR_220,GUDUR MAIDUR_33KV,HALIGERI_33	15:10	15:20	0:10	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
35	7-Jan-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	17:02	23:59	6:57	LINE CLEAR AVAILED
36	7-Jan-2020	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	10:25	17:02	6:37	LINE CLEAR AVAILED
37	7-Jan-2020	BAGALKOT	110	RANEENNUR220-AREMALLAPUR(HONNATTI)	HONNATTI_110	15:05	18:43	3:38	LINE CLEAR AVAILED
38	7-Jan-2020	BAGALKOT	110	RANEENNUR220-BYADAGI(GUTTAL)	GUTTAL_110	15:05	17:53	2:48	LINE CLEAR AVAILED
39	7-Jan-2020	BAGALKOT	110	RANEENNUR220-RATTIHALLI(TUMMINAKATTI)	TUMMINAKATTI_110	17:27	17:41	0:14	HAND TRIPPED
40	7-Jan-2020	BENGALURU	66	MALLASANDRA - DALASANUR	DALASANUR	9:45	9:50	0:05	LOAD CURTAILMENT
41	7-Jan-2020	BENGALURU	66	HV1	VIJAYANAGARA	9:50	9:55	0:05	MAIN SUPPLY FAILURE
42	7-Jan-2020	BENGALURU	66	HV1	VIJAYANAGARA	10:50	10:55	0:05	LOAD CHANGE OVER
43	7-Jan-2020	BENGALURU	66	HV3	ELECTRONIC CITY P2 S1	11:10	14:05	2:55	LINE CLEAR AVAILED
44	7-Jan-2020	BENGALURU	66	ELECTRONIC CITY - YARANADANAHALLI 220	ELECTRONIC CITY P2 S1, ELECTRONIC CITY	9:02	9:19	0:17	LINE FAULT
45	7-Jan-2020	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	10:15	18:54	8:39	LINE CLEAR AVAILED
46	7-Jan-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	6:24	7:13	0:49	LINE FAULT
47	7-Jan-2020	GULBARGA	220	HV1	LINGASUGUR_220	6:25	6:40	0:15	TRANSFORMER FAULT
48	7-Jan-2020	GULBARGA	220	HV2	LINGASUGUR_220	6:25	6:40	0:15	TRANSFORMER FAULT
49	7-Jan-2020	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	6:40	7:05	0:25	LINE FAULT
50	7-Jan-2020	GULBARGA	220	HV2	SEDAM_220	10:42	23:59	13:17	LINE CLEAR AVAILED
51	7-Jan-2020	GULBARGA	220	SEDAM-CLEAN MAX IPP	SEDAM_220	17:08	23:50	6:42	LINE CLEAR AVAILED
52	7-Jan-2020	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	6:25	6:35	0:10	LINE FAULT
53	7-Jan-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	6:40	6:48	0:08	LINE FAULT
54	7-Jan-2020	GULBARGA	110	LINGASUGUR-KPRL	KPRL_IPP	7:00	13:15	6:15	LINE CLEAR AVAILED
55	7-Jan-2020	GULBARGA	110	HV2	HATTI_110	9:20	9:35	0:15	TRANSFORMER FAULT
56	7-Jan-2020	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	10:52	10:57	0:05	LINE FAULT
57	7-Jan-2020	GULBARGA	110	HV4	LINGASUGUR_220	11:50	14:05	2:15	LINE CLEAR AVAILED
58	7-Jan-2020	GULBARGA	110	HV1	LINGASUGUR_220	12:20	12:30	0:10	TRANSFORMER FAULT
59	7-Jan-2020	GULBARGA	110	HV2	LINGASUGUR_220	12:20	12:30	0:10	TRANSFORMER FAULT
60	7-Jan-2020	GULBARGA	110	MALLAT-LINGASUGUR	MALLAT_220	6:40	7:05	0:25	LINE FAULT
61	7-Jan-2020	GULBARGA	110	LADHA-RENEW SOLAR IPP	LADHA_110	18:40	21:40	3:00	LINE CLEAR AVAILED
62	7-Jan-2020	GULBARGA	110	BYAGAWAT-SINDHANOOR	BYAGAWAT_110	8:40	11:00	2:20	MAIN SUPPLY FAILURE
63	7-Jan-2020	GULBARGA	110	KAVITHAL-MALLAT	KAVITHAL_110	9:45	12:34	2:49	MAIN SUPPLY FAILURE
64	7-Jan-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:36	13:52	3:16	LINE CLEAR AVAILED
65	7-Jan-2020	HASSAN	110	HV2	KEMAR_220	9:50	17:02	7:12	LINE CLEAR AVAILED
66	7-Jan-2020	HASSAN	110	LV1	KEMAR_220	9:49	17:04	7:15	LINE CLEAR AVAILED
67	7-Jan-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	19:19	20:38	1:19	LINE CLEAR AVAILED
68	7-Jan-2020	HASSAN	66		MRSMSG_220	7:43	7:46	0:03	LINE FAULT
69	7-Jan-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	10:36	13:52	3:16	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
70	7-Jan-2020	HASSAN	110	HV2	ESSUR_110	16:59	17:27	0:28	LINE CLEAR AVAILED
71	7-Jan-2020	HASSAN	110	HV1	HALADY_110	14:27	17:13	2:46	LINE CLEAR AVAILED
72	7-Jan-2020	HASSAN	110	HV2	HALADY_110	14:27	17:13	2:46	LINE CLEAR AVAILED
73	7-Jan-2020	HASSAN	110	HV1	HIRIYADKA_110	10:03	12:41	2:38	LINE CLEAR AVAILED
74	7-Jan-2020	HASSAN	110	JOG110-AMBTR2	JOG_110	15:45	16:25	0:40	LINE CLEAR AVAILED
75	7-Jan-2020	HASSAN	110	JOG110-MGHE	JOG_110	11:20	11:40	0:20	HAND TRIPPED
76	7-Jan-2020	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	15:33	16:39	1:06	LINE CLEAR AVAILED
77	7-Jan-2020	HASSAN	110	HV3	MANIPAL_110	12:21	13:57	1:36	LINE CLEAR AVAILED
78	7-Jan-2020	HASSAN	110	HV4	MANIPAL_110	10:06	16:38	6:32	LINE CLEAR AVAILED
79	7-Jan-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	6:36	6:38	0:02	HAND TRIPPED
80	7-Jan-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	7:16	18:37	11:21	LINE CLEAR AVAILED
81	7-Jan-2020	HASSAN	110	HV2	NERALAKERE_110	15:36	23:45	8:09	LINE CLEAR AVAILED
82	7-Jan-2020	HASSAN	110	HV1	NITUR_110	9:30	16:38	7:08	LINE CLEAR AVAILED
83	7-Jan-2020	HASSAN	110	HV1	TOGARSI_110	12:14	17:47	5:33	LINE CLEAR AVAILED
84	7-Jan-2020	HASSAN	66	HV1	ALDUR_66	17:51	17:55	0:04	TRANSFORMER FAULT
85	7-Jan-2020	HASSAN	66	HV2	BELUR_66	14:25	14:45	0:20	LINE CLEAR AVAILED
86	7-Jan-2020	HASSAN	66	HV1	BELUR_66	12:40	15:15	2:35	LINE CLEAR AVAILED
87	7-Jan-2020	HASSAN	66	HV1	HANGARAHALLY_66	10:47	14:18	3:31	LINE CLEAR AVAILED
88	7-Jan-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:19	10:23	0:04	HAND TRIPPED
89	7-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	9:05	9:11	0:06	TRANSFORMER FAULT
90	7-Jan-2020	MYSORE	66	HV1	DODDINADUVADI_66	11:41	13:51	2:09	LINE CLEAR AVAILED
91	7-Jan-2020	MYSORE	66	HV2	DODDINADUVADI_66	14:06	16:23	2:17	LINE CLEAR AVAILED
92	7-Jan-2020	MYSORE	66	HV1	HALAGUR_66	15:42	16:25	0:43	HAND TRIPPED
93	7-Jan-2020	MYSORE	66	HALAGURU-TK HALLI	HALAGUR_66	12:41	13:11	0:30	NFBC ISSUED
94	7-Jan-2020	MYSORE	66	HALAGURU-TK HALLI	HALAGUR_66	13:35	13:52	0:16	NFBC ISSUED
95	7-Jan-2020	MYSORE	66	HV2	HONNALLY_MYS_66	11:46	14:06	2:20	LINE CLEAR AVAILED
96	7-Jan-2020	MYSORE	66	JAKKANAHALLI-NAGMANGALA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	16:30	16:35	0:05	LINE FAULT
97	7-Jan-2020	MYSORE	66	HV3	KUSHALANAGARA_66	5:17	5:32	0:14	TRANSFORMER FAULT
98	7-Jan-2020	MYSORE	66	HV2	SFCSHIVA_66	9:18	23:59	14:40	LINE CLEAR AVAILED
99	7-Jan-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 BASARALU_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	23:02	23:09	0:07	LINE FAULT
100	7-Jan-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	7:38	7:43	0:04	LINE FAULT
101	7-Jan-2020	MYSORE	66	VAJMANGALA -KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	6:34	6:39	0:05	LINE FAULT
102	7-Jan-2020	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	19:18	20:37	1:19	LINE CLEAR AVAILED
103	7-Jan-2020	TUMKUR	110	TR-1	TURUVEKERE_110	16:05	16:16	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
104	7-Jan-2020	TUMKUR	110	TR-1	MAYASANDRA_110	12:38	14:05	1:26	LINE CLEAR AVAILED
105	7-Jan-2020	TUMKUR	110	TR-2	MAYASANDRA_110	14:07	14:42	0:35	LINE CLEAR AVAILED
106	7-Jan-2020	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	17:47	18:10	0:22	MAIN SUPPLY FAILURE
107	7-Jan-2020	TUMKUR	66	TR-2	HALUVAGALU_66	22:01	22:05	0:04	TRANSFORMER FAULT
108	7-Jan-2020	TUMKUR	66	TR-1	HDPURA_66	10:59	11:13	0:13	LINE CLEAR AVAILED
109	7-Jan-2020	TUMKUR	66	TR-1	HDPURA_66	12:48	12:51	0:03	LINE CLEAR AVAILED
110	7-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:11	14:22	2:11	LINE CLEAR AVAILED
111	7-Jan-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:42	10:58	0:16	LINE FAULT
112	7-Jan-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:11	14:22	2:11	LINE CLEAR AVAILED
113	7-Jan-2020	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	10:11	17:33	7:22	LINE CLEAR AVAILED
114	7-Jan-2020	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	18:32	18:45	0:13	LINE FAULT
115	7-Jan-2020	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	16:18	16:31	0:13	LINE CLEAR AVAILED
116	7-Jan-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	16:52	17:44	0:52	HAND TRIPPED
117	7-Jan-2020	TUMKUR	66	TR-1	MEDIGESHI_66	15:30	15:55	0:25	LINE CLEAR AVAILED
118	7-Jan-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	13:29	13:41	0:11	LINE FAULT
119	7-Jan-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	8:52	9:07	0:15	TRANSFORMER FAULT
120	7-Jan-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:24	8:51	0:27	LINE FAULT
121	7-Jan-2020	TUMKUR	66	TR-2	SHYLAPURA_66	0:18	0:32	0:14	HAND TRIPPED
122	7-Jan-2020	TUMKUR	66	TR-2	TELAGI_66	18:46	18:54	0:08	TRANSFORMER FAULT
123	7-Jan-2020	TUMKUR	66	TR-2	THIMMASANDRA_66	12:51	13:13	0:22	LINE CLEAR AVAILED
124	7-Jan-2020	TUMKUR	66	TR-1	TUMKUR_66	15:50	18:37	2:47	LINE CLEAR AVAILED
125	8-Jan-2020	BAGALKOT	110	110/11KV,HV 1	ANKOLA_110	10:07	12:35	2:28	LINE CLEAR AVAILED
126	8-Jan-2020	BAGALKOT	220	BELGAUM-KANABARGI 2	BELGAUM_220	6:56	13:09	6:13	LINE FAULT
127	8-Jan-2020	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	7:23	7:38	0:15	LOAD CURTAILMENT
128	8-Jan-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	6:50	7:00	0:10	TRANSFORMER FAULT
129	8-Jan-2020	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	7:23	7:33	0:10	LOAD CURTAILMENT
130	8-Jan-2020	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	9:25	9:42	0:17	TRANSFORMER FAULT
131	8-Jan-2020	BAGALKOT	110	RANEENNUR220-BYADAGI	BYADAGI_110	6:50	23:59	17:09	LINE CLEAR AVAILED
132	8-Jan-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110	10:06	16:20	6:14	LINE CLEAR AVAILED
133	8-Jan-2020	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	2:04	2:08	0:04	TRANSFORMER FAULT
134	8-Jan-2020	BAGALKOT	110	220/110KV, LV3	HUBLI_220	0:00	11:49	11:49	LINE CLEAR AVAILED
135	8-Jan-2020	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	18:20	23:59	5:39	LINE FAULT
136	8-Jan-2020	BAGALKOT	220	220/110KV,HV2&LV2	SODATTI_220	10:03	14:11	4:08	LINE CLEAR AVAILED
137	8-Jan-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	11:00	14:37	3:37	LINE CLEAR AVAILED
138	8-Jan-2020	BAGALKOT	110	110/33KV, HV2	SAVALGI_110, HIREPADASALGI_33, KALBALGI_33	7:24	7:28	0:04	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
139	8-Jan-2020	BAGALKOT	110	110/11KV, HV1	RATTIHALLI_110	10:05	17:15	7:10	LINE CLEAR AVAILED
140	8-Jan-2020	BAGALKOT	110	110/11KV, HV2	RATTIHALLI_110	10:05	17:45	7:40	LINE CLEAR AVAILED
141	8-Jan-2020	BAGALKOT	110	110/11KV, HV1	NANADI_110	10:44	15:20	4:36	LINE CLEAR AVAILED
142	8-Jan-2020	BAGALKOT	110	110/11KV, HV2	NANADI_110	15:25	18:16	2:51	LINE CLEAR AVAILED
143	8-Jan-2020	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	22:02	22:06	0:04	LINE CLEAR AVAILED
144	8-Jan-2020	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(B)_110	14:20	15:44	1:24	LINE CLEAR AVAILED
145	8-Jan-2020	BAGALKOT	110	110/33KV, HV1	KUMTA_110,HONNAVAR_33,ANKOLA_33	12:30	13:35	1:05	LINE CLEAR AVAILED
146	8-Jan-2020	BAGALKOT	110	110/11KV, HV2	KUMTA_110	11:05	13:35	2:30	LINE CLEAR AVAILED
147	8-Jan-2020	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	11:07	17:32	6:25	NFBC ISSUED
148	8-Jan-2020	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-1	11:50	14:04	2:14	LINE CLEAR AVAILED
149	8-Jan-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	2:21	2:28	0:07	TRANSFORMER FAULT
150	8-Jan-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	19:05	19:44	0:39	LOAD CHANGE OVER
151	8-Jan-2020	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	10:50	11:03	0:13	LINE FAULT
152	8-Jan-2020	BENGALURU	220	HOODY 220 - BEGUR 220	BEGUR 220	13:41	13:48	0:07	LINE FAULT
153	8-Jan-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	16:30	16:40	0:10	MAIN SUPPLY FAILURE
154	8-Jan-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	11:21	11:50	0:29	LINE FAULT
155	8-Jan-2020	BENGALURU	66	ANEKAL - YARANDANAHALLI 1 & 2	ANEKAL	17:34	17:38	0:04	LINE CLEAR AVAILED
156	8-Jan-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	13:41	13:48	0:07	MAIN SUPPLY FAILURE
157	8-Jan-2020	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	13:41	13:48	0:07	MAIN SUPPLY FAILURE
158	8-Jan-2020	BENGALURU	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	13:41	13:48	0:07	MAIN SUPPLY FAILURE
159	8-Jan-2020	BENGALURU	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	13:41	13:48	0:07	MAIN SUPPLY FAILURE
160	8-Jan-2020	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220kv	CHANDAPURA	16:55	16:59	0:04	LOAD CHANGE OVER
161	8-Jan-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	8:08	8:15	0:07	LINE FAULT
162	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	9:25	9:31	0:06	LINE FAULT
163	8-Jan-2020	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	10:51	11:13	0:22	MAIN SUPPLY FAILURE
164	8-Jan-2020	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	10:51	11:13	0:22	MAIN SUPPLY FAILURE
165	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	10:51	11:13	0:22	MAIN SUPPLY FAILURE
166	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:51	11:13	0:22	MAIN SUPPLY FAILURE
167	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA	10:51	11:13	0:22	MAIN SUPPLY FAILURE
168	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:51	11:13	0:22	MAIN SUPPLY FAILURE
169	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	10:51	11:13	0:22	MAIN SUPPLY FAILURE
170	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	10:51	11:13	0:22	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
171	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	10:51	11:13	0:22	MAIN SUPPLY FAILURE
172	8-Jan-2020	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	10:51	11:13	0:22	MAIN SUPPLY FAILURE
173	8-Jan-2020	BENGALURU	220	HOSKOTE 220 - HOODY 220	HOSKOTE 220	13:41	14:58	1:17	MAIN SUPPLY FAILURE
174	8-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	13:41	14:58	1:17	MAIN SUPPLY FAILURE
175	8-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:41	14:58	1:17	MAIN SUPPLY FAILURE
176	8-Jan-2020	BENGALURU	66	HOSKOTE 66 - MALUR 220	HOSKOTE 66	13:41	14:58	1:17	MAIN SUPPLY FAILURE
177	8-Jan-2020	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	13:41	14:58	1:17	MAIN SUPPLY FAILURE
178	8-Jan-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	13:41	14:58	1:17	MAIN SUPPLY FAILURE
179	8-Jan-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:41	14:58	1:17	MAIN SUPPLY FAILURE
180	8-Jan-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	10:55	11:14	0:19	MAIN SUPPLY FAILURE
181	8-Jan-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	10:55	11:14	0:19	MAIN SUPPLY FAILURE
182	8-Jan-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:55	11:14	0:19	MAIN SUPPLY FAILURE
183	8-Jan-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:55	11:14	0:19	MAIN SUPPLY FAILURE
184	8-Jan-2020	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	10:55	11:14	0:19	MAIN SUPPLY FAILURE
185	8-Jan-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	10:55	11:14	0:19	MAIN SUPPLY FAILURE
186	8-Jan-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	10:55	11:14	0:19	MAIN SUPPLY FAILURE
187	8-Jan-2020	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	10:55	11:14	0:19	MAIN SUPPLY FAILURE
188	8-Jan-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:55	11:14	0:19	MAIN SUPPLY FAILURE
189	8-Jan-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:55	11:14	0:19	MAIN SUPPLY FAILURE
190	8-Jan-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:55	11:14	0:19	MAIN SUPPLY FAILURE
191	8-Jan-2020	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	10:55	11:14	0:19	MAIN SUPPLY FAILURE
192	8-Jan-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	10:55	11:14	0:19	MAIN SUPPLY FAILURE
193	8-Jan-2020	BENGALURU	66	HV1	MAGADI	12:26	13:31	1:05	LINE CLEAR AVAILED
194	8-Jan-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:01	13:28	0:27	LINE FAULT
195	8-Jan-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:28	13:55	0:27	LINE FAULT
196	8-Jan-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:55	11:14	0:19	MAIN SUPPLY FAILURE
197	8-Jan-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	10:55	11:14	0:19	MAIN SUPPLY FAILURE
198	8-Jan-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	10:55	11:14	0:19	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
199	8-Jan-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:55	11:14	0:19	MAIN SUPPLY FAILURE
200	8-Jan-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:55	11:14	0:19	MAIN SUPPLY FAILURE
201	8-Jan-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	10:55	11:14	0:19	MAIN SUPPLY FAILURE
202	8-Jan-2020	BENGALURU	66	HV1	SURYANAGAR	12:42	12:46	0:04	LINE CLEAR AVAILED
203	8-Jan-2020	BENGALURU	66	HV2	YELAHANKA	12:36	13:13	0:37	LINE CLEAR AVAILED
204	8-Jan-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:30	18:34	0:04	LINE FAULT
205	8-Jan-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:45	16:50	0:05	LOAD CHANGE OVER
206	8-Jan-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:50	11:15	0:25	MAIN SUPPLY FAILURE
207	8-Jan-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:50	11:15	0:25	MAIN SUPPLY FAILURE
208	8-Jan-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:02	13:42	0:40	MAIN SUPPLY FAILURE
209	8-Jan-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:02	13:30	0:28	MAIN SUPPLY FAILURE
210	8-Jan-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:55	17:05	0:10	MAIN SUPPLY FAILURE
211	8-Jan-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	10:06	23:59	13:53	NFBC ISSUED
212	8-Jan-2020	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	10:55	18:50	7:55	LINE CLEAR AVAILED
213	8-Jan-2020	GULBARGA	110	HV4	LINGASUGUR_220	11:00	13:40	2:40	LINE CLEAR AVAILED
214	8-Jan-2020	HASSAN	400	TALAGUPPA_400	TALAGU-NELAMANGALA#2	21:24	23:59	2:35	LINE FAULT
215	8-Jan-2020	HASSAN	220	KEMAR_220	KEMAR-Kavoor2	10:09	13:29	3:20	LINE CLEAR AVAILED
216	8-Jan-2020	HASSAN	220	MRSMSG_220	SMRSSHM-HARAVATHY2	9:59	16:53	6:54	LINE CLEAR AVAILED
217	8-Jan-2020	HASSAN	66	MRSMSG_220	MRSSHM-HOLUR	9:10	9:18	0:08	LINE FAULT
218	8-Jan-2020	HASSAN	220	MSEZ_220	MSEZ-KEMAR2	10:10	13:30	3:20	NFBC ISSUED
219	8-Jan-2020	HASSAN	220	sharavathy_gen	SHRAVTY-SHIMOGA2	9:09	16:54	7:45	LINE CLEAR AVAILED
220	8-Jan-2020	HASSAN	220	sharavathy_gen	SHRAVTY-SIRISI 2	10:24	14:38	4:14	LINE CLEAR AVAILED
221	8-Jan-2020	HASSAN	220	SHIRALKOPPA_220	HV2	14:50	16:32	1:42	LINE CLEAR AVAILED
222	8-Jan-2020	HASSAN	110	SHIRALKOPPA_220	LV2	14:50	16:35	1:45	LINE CLEAR AVAILED
223	8-Jan-2020	HASSAN	110	SHIRALKOPPA_220	SHRLKP-BARANG	14:49	16:35	1:46	LINE CLEAR AVAILED
224	8-Jan-2020	HASSAN	110	SHIRALKOPPA_220	HRLKP-KITTADAHALLI	15:09	16:24	1:15	LINE CLEAR AVAILED
225	8-Jan-2020	HASSAN	110	SHIRALKOPPA_220	HRLKP-SHIKARIPURA	16:23	16:35	0:12	HAND TRIPPED
226	8-Jan-2020	HASSAN	110	HALADY_110	HV1	7:22	7:48	0:26	LINE FAULT
227	8-Jan-2020	HASSAN	110	BARANGI_110	HV1	13:25	16:40	3:15	LINE CLEAR AVAILED
228	8-Jan-2020	HASSAN	110	BARANGI_110	HV2	14:50	16:40	1:50	LINE CLEAR AVAILED
229	8-Jan-2020	HASSAN	110	BRAHMAVARA_110	HV1	7:22	7:36	0:14	LINE FAULT
230	8-Jan-2020	HASSAN	66	BELUR_66	HV1	10:49	17:50	7:01	LINE CLEAR AVAILED
231	8-Jan-2020	HASSAN	66	SAKALESHUPURA_66	SAKALE-HANBAL	9:02	17:09	8:07	LINE CLEAR AVAILED
232	8-Jan-2020	HASSAN	66	SALAGAME_66	HV2	12:36	13:43	1:07	LINE CLEAR AVAILED
233	8-Jan-2020	HASSAN	66	UDAYAPURA_66	HV2	7:59	8:05	0:06	LINE FAULT
234	8-Jan-2020	HASSAN	66	UDDURKOPLU_66	UDDURKO-SUZLON1	16:38	17:41	1:03	LINE FAULT
235	8-Jan-2020	HASSAN	66	CHANNARAYAPATNA_66	CHANNAR-CRPATNA1	13:20	13:55	0:35	LINE CLEAR AVAILED
236	8-Jan-2020	HASSAN	66	CHANNARAYAPATNA_66	CHANNAR-CRPATNA2	13:55	14:23	0:28	LINE CLEAR AVAILED
237	8-Jan-2020	HASSAN	66	CHANNARAYAPATNA_66	CHANNAR-SHETTIHALLY	13:06	13:50	0:44	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
238	8-Jan-2020	HASSAN	66	CHANNARAYAPATNA_66	HV2	15:06	15:55	0:49	LINE CLEAR AVAILED
239	8-Jan-2020	MYSORE	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66	13:53	14:14	0:21	LINE FAULT
240	8-Jan-2020	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	13:55	14:13	0:17	LINE FAULT
241	8-Jan-2020	MYSORE	66	HV2	SFCSHIVA_66	15:20	23:59	8:38	LINE CLEAR AVAILED
242	8-Jan-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	10:13	19:38	9:25	LINE CLEAR AVAILED
243	8-Jan-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	13:17	14:05	0:48	LINE CLEAR AVAILED
244	8-Jan-2020	TUMKUR	66	TR-1	BENKIKERE_66	7:02	7:18	0:16	LINE CLEAR AVAILED
245	8-Jan-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	12:05	12:10	0:04	TRANSFORMER FAULT
246	8-Jan-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:45	10:51	0:06	HAND TRIPPED
247	8-Jan-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:01	11:04	0:02	HAND TRIPPED
248	8-Jan-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:03	16:19	0:16	HAND TRIPPED
249	8-Jan-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	16:03	16:19	0:16	HAND TRIPPED
250	8-Jan-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:17	9:39	0:22	HAND TRIPPED
251	8-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:03	16:20	0:16	HAND TRIPPED
252	8-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:02	16:19	0:16	HAND TRIPPED
253	8-Jan-2020	TUMKUR	66	TR-1	HARIHAR_66	13:28	14:02	0:33	LINE CLEAR AVAILED
254	8-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	7:27	7:43	0:16	HAND TRIPPED
255	8-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	7:27	7:43	0:16	HAND TRIPPED
256	8-Jan-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	20:35	21:08	0:33	LINE FAULT
257	8-Jan-2020	TUMKUR	66	TR-2	LINGADAHALLY_66	14:23	14:28	0:04	TRANSFORMER FAULT
258	8-Jan-2020	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	13:18	13:24	0:05	LINE FAULT
259	8-Jan-2020	TUMKUR	66	TR-1	NAGASAMUDRA_66	18:38	18:51	0:12	TRANSFORMER FAULT
260	8-Jan-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	17:06	17:24	0:17	LINE FAULT
261	8-Jan-2020	TUMKUR	66	TR-2	THIMMASANDRA_66	11:29	13:15	1:45	LINE CLEAR AVAILED
262	9-Jan-2020	BAGALKOT	110	110/11KV ,HV 2	AREMALLAPUR_110	15:08	21:48	6:40	LINE CLEAR AVAILED
263	9-Jan-2020	BAGALKOT	110	110/11KV ,HV 1	ATHRGA_110	7:17	7:34	0:17	LOAD CURTAILMENT
264	9-Jan-2020	BAGALKOT	110	110/11KV,HV 2	BANAHATTI_110	16:44	16:48	0:04	HAND TRIPPED
265	9-Jan-2020	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	14:15	15:07	0:52	LINE CLEAR AVAILED
266	9-Jan-2020	BAGALKOT	110	BIDNAL-HUBLI 2	BIDNAL_220	11:01	14:09	3:08	LINE CLEAR AVAILED
267	9-Jan-2020	BAGALKOT	220	220/110KV,HV&LV 2	GADAG_220	10:34	17:59	7:25	LINE CLEAR AVAILED
268	9-Jan-2020	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	7:17	7:22	0:05	LOAD CURTAILMENT
269	9-Jan-2020	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	0:00	16:10	16:10	LINE CLEAR AVAILED
270	9-Jan-2020	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	3:32	3:44	0:12	LINE FAULT
271	9-Jan-2020	BAGALKOT	110	110/11KV, HV1	TARIHAL_110	15:25	15:30	0:05	TRANSFORMER FAULT
272	9-Jan-2020	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	9:55	18:35	8:40	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
273	9-Jan-2020	BAGALKOT	110	BPCL1-SHIRAHATTI	SHIRAHATTI_110	10:11	18:49	8:38	LINE CLEAR AVAILED
274	9-Jan-2020	BAGALKOT	110	BPCL2-SHIRAHATTI	SHIRAHATTI_110	10:11	18:55	8:44	LINE CLEAR AVAILED
275	9-Jan-2020	BAGALKOT	110	110/33KV, HV2	SAVALGI_110, HIREPADASALGI_33, KALBALGI_33	7:17	7:25	0:08	LOAD CURTAILMENT
276	9-Jan-2020	BAGALKOT	110	110/11KV, HV4	SADALAGA_110	11:10	14:14	3:04	LINE CLEAR AVAILED
277	9-Jan-2020	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	14:44	18:26	3:42	LINE CLEAR AVAILED
278	9-Jan-2020	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	13:19	14:05	0:46	LINE CLEAR AVAILED
279	9-Jan-2020	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(B)_110	17:19	18:52	1:33	TRANSFORMER FAULT
280	9-Jan-2020	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(B)_110	21:34	22:02	0:28	LINE CLEAR AVAILED
281	9-Jan-2020	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	LAXMESHWAR_110	10:22	18:00	7:38	LINE CLEAR AVAILED
282	9-Jan-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	18:11	18:20	0:09	TRANSFORMER FAULT
283	9-Jan-2020	BAGALKOT	110	110/33KV, HV1	HANGAL_110, PALA_33	7:17	7:30	0:13	LOAD CURTAILMENT
284	9-Jan-2020	BAGALKOT	110	110/11KV, HV3	HANGAL_110	14:57	16:09	1:12	LINE CLEAR AVAILED
285	9-Jan-2020	BENGALURU	66	HOSKOTE 66-MALUR 2	HOSKOTE 66	11:35	11:40	0:05	LOAD CHANGE OVER
286	9-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	10:12	10:53	0:41	LINE FAULT
287	9-Jan-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:26	15:32	1:06	LOAD CHANGE OVER
288	9-Jan-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:28	14:32	0:04	LOAD CHANGE OVER
289	9-Jan-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	14:20	14:36	0:16	LOAD CHANGE OVER
290	9-Jan-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	15:28	15:39	0:11	LOAD CHANGE OVER
291	9-Jan-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	15:28	15:39	0:11	LOAD CHANGE OVER
292	9-Jan-2020	BENGALURU	66	HV1	MUDIYANUR	11:57	13:10	1:13	TRANSFORMER FAULT
293	9-Jan-2020	BENGALURU	66	HV2	Y HUNSENAHALLI	11:23	11:30	0:07	LINE CLEAR AVAILED
294	9-Jan-2020	BENGALURU	66	Y HUNASENAHALLI - TALAWARA	Y HUNASENAHALLI	15:10	15:25	0:15	LINE CLEAR AVAILED
295	9-Jan-2020	BENGALURU	66	HAL 220-HOODY 1	ISRO (EHT)	18:37	19:44	1:07	LINE CLEAR AVAILED
296	9-Jan-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	18:37	19:44	1:07	LINE CLEAR AVAILED
297	9-Jan-2020	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	9:59	10:20	0:21	LINE FAULT
298	9-Jan-2020	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	10:20	10:35	0:15	LINE FAULT
299	9-Jan-2020	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	18:37	19:07	0:30	MAIN SUPPLY FAILURE
300	9-Jan-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	19:40	19:45	0:05	LOAD CHANGE OVER
301	9-Jan-2020	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	10:18	10:46	0:28	LINE FAULT
302	9-Jan-2020	BENGALURU	220	HV1	YARANDANAHALLI 220	10:18	10:31	0:13	TRANSFORMER FAULT
303	9-Jan-2020	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	10:30	23:59	13:29	LINE CLEAR AVAILED
304	9-Jan-2020	GULBARGA	220	HV1	SEDAM_220	19:06	20:10	1:04	TRANSFORMER FAULT
305	9-Jan-2020	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSTAGI_220	10:43	13:50	3:07	LINE CLEAR AVAILED
306	9-Jan-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	3:50	3:58	0:08	LINE FAULT
307	9-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	5:02	5:09	0:07	LINE FAULT
308	9-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_GLB_110,SAIDAPUR_GLB_110 ,WADAGERA_110,NALWAR_110	6:00	6:12	0:12	LINE FAULT
309	9-Jan-2020	GULBARGA	110	LINGASUGUR-KAREPOWER_IPP	KAREPOWER_IPP	8:05	15:15	7:10	LINE CLEAR AVAILED
310	9-Jan-2020	GULBARGA	110	HV4,HV5	LINGASUGUR_220	8:44	8:50	0:06	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	9-Jan-2020	GULBARGA	110	HV4,HV5	LINGASUGUR_220	10:35	10:40	0:05	TRANSFORMER FAULT
312	9-Jan-2020	HASSAN	220	KADUR-SHIMOGA	KADUR_220	9:50	12:55	3:05	LINE CLEAR AVAILED
313	9-Jan-2020	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:26	13:11	2:45	LINE CLEAR AVAILED
314	9-Jan-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:37	13:51	4:14	LINE CLEAR AVAILED
315	9-Jan-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:28	13:12	0:44	LINE CLEAR AVAILED
316	9-Jan-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:32	12:26	0:54	LINE CLEAR AVAILED
317	9-Jan-2020	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	9:51	12:53	3:02	LINE CLEAR AVAILED
318	9-Jan-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:38	13:51	4:13	NFBC ISSUED
319	9-Jan-2020	HASSAN	110	HV1	BIRUR_110	9:16	16:35	7:19	LINE CLEAR AVAILED
320	9-Jan-2020	HASSAN	110	HV2	BIRUR_110	9:16	16:35	7:19	LINE CLEAR AVAILED
321	9-Jan-2020	HASSAN	110	HV1	BRAHMAVA	7:17	7:30	0:13	LOAD CURTAILMENT
322	9-Jan-2020	HASSAN	110	HV2	GERUMARA_110	8:35	8:55	0:20	LOAD CURTAILMENT
323	9-Jan-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:28	13:12	0:44	MAIN SUPPLY FAILURE
324	9-Jan-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	11:31	12:26	0:55	MAIN SUPPLY FAILURE
325	9-Jan-2020	HASSAN	110	HV2	JAVAGAL_110	7:03	7:48	0:45	TRANSFORMER FAULT
326	9-Jan-2020	HASSAN	110	HV2	KAVOOR_220	0:00	16:38	16:38	TRANSFORMER FAULT
327	9-Jan-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:46	17:00	7:14	LINE CLEAR AVAILED
328	9-Jan-2020	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	10:29	11:00	0:31	LINE CLEAR AVAILED
329	9-Jan-2020	HASSAN	110	HV4	SHIRALKOPPA_110	12:09	12:39	0:30	LINE CLEAR AVAILED
330	9-Jan-2020	HASSAN	66	HV2	BASAVAGHATTA_66	6:58	7:10	0:12	LOAD CURTAILMENT
331	9-Jan-2020	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	6:47	7:06	0:19	LINE FAULT
332	9-Jan-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	6:58	7:11	0:13	LOAD CURTAILMENT
333	9-Jan-2020	HASSAN	66	HV2	CHIKMAGALUR_66	11:00	17:30	6:30	LINE CLEAR AVAILED
334	9-Jan-2020	HASSAN	66	HV1	HALLIMYSORE_66	7:14	7:21	0:07	LOAD CURTAILMENT
335	9-Jan-2020	HASSAN	66	HV1	HANGARANAHALLY_66	7:14	7:24	0:10	LOAD CURTAILMENT
336	9-Jan-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:27	13:22	0:55	MAIN SUPPLY FAILURE
337	9-Jan-2020	HASSAN	66	HV1	KUDLIGERE_66	12:28	13:17	0:49	MAIN SUPPLY FAILURE
338	9-Jan-2020	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	12:28	13:17	0:49	MAIN SUPPLY FAILURE
339	9-Jan-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	7:14	7:30	0:16	LOAD CURTAILMENT
340	9-Jan-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	9:01	18:30	9:29	LINE CLEAR AVAILED
341	9-Jan-2020	HASSAN	66	HV2	SALAGAME_66	7:14	7:24	0:10	LOAD CURTAILMENT
342	9-Jan-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	12:26	13:17	0:51	LINE CLEAR AVAILED
343	9-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	8:46	8:50	0:04	TRANSFORMER FAULT
344	9-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	9:27	9:30	0:03	TRANSFORMER FAULT
345	9-Jan-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:31	6:38	0:06	LINE FAULT
346	9-Jan-2020	MYSORE	66	HV2	BOMMALAPURA_66	7:09	7:39	0:29	TRANSFORMER FAULT
347	9-Jan-2020	MYSORE	66	HV2	BOMMALAPURA_66	7:43	7:46	0:02	HAND TRIPPED
348	9-Jan-2020	MYSORE	66	HV2	BOOKANAKERE_66	6:58	7:08	0:09	LOAD CURTAILMENT
349	9-Jan-2020	MYSORE	66	HV2	CHINAKURALI_66	6:58	7:07	0:09	LOAD CURTAILMENT
350	9-Jan-2020	MYSORE	66	HV1	HALAGUR_66	9:59	16:06	6:07	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
351	9-Jan-2020	MYSORE	66	HV1	HALAGUR_66	16:15	16:24	0:08	HAND TRIPPED
352	9-Jan-2020	MYSORE	66	HV2	JAIPUR_66	7:14	7:29	0:15	LOAD CURTAILMENT
353	9-Jan-2020	MYSORE	66	HV1	K_HONNALGERE_66	13:20	13:36	0:16	HAND TRIPPED
354	9-Jan-2020	MYSORE	66	HV2	K_HONNALGERE_66	13:20	13:36	0:16	HAND TRIPPED
355	9-Jan-2020	MYSORE	66	HV1	KIRUGAVALU_66	10:53	20:50	9:57	LINE CLEAR AVAILED
356	9-Jan-2020	MYSORE	66	HV2	KMDODDI_66	7:14	7:33	0:18	LOAD CURTAILMENT
357	9-Jan-2020	MYSORE	66	HV2	KOLLEGALA_66	7:14	7:41	0:27	LOAD CURTAILMENT
358	9-Jan-2020	MYSORE	66	HV1	MADDUR_66	7:14	7:22	0:07	LOAD CURTAILMENT
359	9-Jan-2020	MYSORE	66	HV1	MEGALAPURA_66	6:58	7:10	0:11	LOAD CURTAILMENT
360	9-Jan-2020	MYSORE	66	HV2	MYSORESOUTH_66	23:48	23:59	0:10	TRANSFORMER FAULT
361	9-Jan-2020	MYSORE	66	HV1	PANDAVAPURA_66	7:14	7:34	0:20	LOAD CURTAILMENT
362	9-Jan-2020	MYSORE	66	HV1	SATHEGALA_66	7:15	7:23	0:07	LOAD CURTAILMENT
363	9-Jan-2020	MYSORE	66	HV1	SANTHESARAGUR_66	11:44	15:52	4:07	LINE CLEAR AVAILED
364	9-Jan-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:15	7:25	0:10	LOAD CURTAILMENT
365	9-Jan-2020	MYSORE	66	SUTTUR-DEVNUR(N'GUD)	SUTTUR_66	10:07	18:20	8:13	LINE CLEAR AVAILED
366	9-Jan-2020	MYSORE	66	HV1	YELANDUR_66	6:58	7:08	0:10	LOAD CURTAILMENT
367	9-Jan-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:31	13:50	0:19	LINE FAULT
368	9-Jan-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:32	14:02	0:30	LINE FAULT
369	9-Jan-2020	TUMKUR	220	TR-1	HONNALLI_220	13:23	14:17	0:53	LINE CLEAR AVAILED
370	9-Jan-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:14	10:44	0:30	HAND TRIPPED
371	9-Jan-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:14	10:57	0:42	HAND TRIPPED
372	9-Jan-2020	TUMKUR	110	TR-1	KBCROSS_220	10:14	10:44	0:30	HAND TRIPPED
373	9-Jan-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	16:24	16:30	0:06	LINE FAULT
374	9-Jan-2020	TUMKUR	66	TR-1	BANUVALLI_66	8:25	8:35	0:10	HAND TRIPPED
375	9-Jan-2020	TUMKUR	66	TR-1	BANUVALLI_66	8:38	12:50	4:12	LINE CLEAR AVAILED
376	9-Jan-2020	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHLI)	CHANNAGIRI_66	13:22	14:55	1:32	MAIN SUPPLY FAILURE
377	9-Jan-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	18:15	18:18	0:02	TRANSFORMER FAULT
378	9-Jan-2020	TUMKUR	66	TR-2	CHIKKABANAGERE_66	16:59	17:40	0:41	LINE CLEAR AVAILED
379	9-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	8:03	8:20	0:17	LINE FAULT
380	9-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:32	18:39	0:06	LINE FAULT
381	9-Jan-2020	TUMKUR	66	TR-2	GULIGENAHALLI_66	11:48	12:00	0:11	HAND TRIPPED
382	9-Jan-2020	TUMKUR	66	TR-1	HANAGAL_66	8:15	11:22	3:06	LINE CLEAR AVAILED
383	9-Jan-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	13:09	13:16	0:06	TRANSFORMER FAULT
384	9-Jan-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:52	17:41	6:48	LINE CLEAR AVAILED
385	9-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:19	13:29	0:09	LINE CLEAR AVAILED
386	9-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:51	15:56	0:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
387	9-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:58	14:52	1:54	LINE CLEAR AVAILED
388	9-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:38	16:50	0:12	LINE CLEAR AVAILED
389	9-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:36	18:47	0:10	LINE CLEAR AVAILED
390	9-Jan-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:58	14:52	1:54	LINE CLEAR AVAILED
391	9-Jan-2020	TUMKUR	66	HOSAKERE- MIDIGESHI	MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66	11:55	14:39	2:43	LINE CLEAR AVAILED
392	9-Jan-2020	TUMKUR	66	TR-1	IDHALLY_66	13:32	14:35	1:03	LINE CLEAR AVAILED
393	9-Jan-2020	TUMKUR	66	TR-2	IDHALLY_66	15:03	15:29	0:25	LINE CLEAR AVAILED
394	10-Jan-2020	BAGALKOT	220	AMBEWADI -NARENDRA 1&2	AMBEWADI_220	11:25	12:59	1:34	LINE CLEAR AVAILED
395	10-Jan-2020	BAGALKOT	110	110/11KV,HV2	ANKALI_110	9:14	11:17	2:03	LINE CLEAR AVAILED
396	10-Jan-2020	BAGALKOT	110	110/33KV,HV3	ANKALI_110, SHIRAGUPPI_33,KOTTAWAD_33	13:55	16:45	2:50	LINE CLEAR AVAILED
397	10-Jan-2020	BAGALKOT	110	110/33KV,HV3	ANKALI_110,NANADIKURALI_33	11:17	13:18	2:01	LINE CLEAR AVAILED
398	10-Jan-2020	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	11:38	13:22	1:44	LINE CLEAR AVAILED
399	10-Jan-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	20:52	23:59	3:07	LINE CLEAR AVAILED
400	10-Jan-2020	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	9:49	17:12	7:23	NFBC ISSUED
401	10-Jan-2020	BAGALKOT	110	SIRSI-KUMTA1&2	KUMTA_110	13:17	13:55	0:38	LINE CLEAR AVAILED
402	10-Jan-2020	BAGALKOT	220	MAHALINGAPUR-SOUNDATTI	MAHALINGAPUR_220	11:51	15:05	3:14	LINE CLEAR AVAILED
403	10-Jan-2020	BAGALKOT	220	220/110KV,HV 3	MAHALINGAPUR_220	16:15	16:45	0:30	LINE CLEAR AVAILED
404	10-Jan-2020	BAGALKOT	110	MK HUBLI-NARENDRA1	MK HUBLI_220	10:45	18:40	7:55	LINE CLEAR AVAILED
405	10-Jan-2020	BAGALKOT	110	110/11KV,HV 1	MORATAGI_110	11:02	11:17	0:15	LINE CLEAR AVAILED
406	10-Jan-2020	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	11:02	11:27	0:25	TRANSFORMER FAULT
407	10-Jan-2020	BAGALKOT	110	BAGEWADI_220-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	17:26	17:46	0:20	LINE CLEAR AVAILED
408	10-Jan-2020	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	12:19	12:50	0:31	LINE CLEAR AVAILED
409	10-Jan-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	13:08	13:12	0:04	LINE FAULT
410	10-Jan-2020	BAGALKOT	110	VPPL-SADALAGA	SADALAGA_110	23:43	23:59	0:16	LINE CLEAR AVAILED
411	10-Jan-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:09	14:05	3:56	LINE CLEAR AVAILED
412	10-Jan-2020	BAGALKOT	110	110/11KV, HV2	SIRSI_110	10:09	13:58	3:49	LINE CLEAR AVAILED
413	10-Jan-2020	BAGALKOT	110	SIRSI220 1&2-SIRSI	SIRSI_110	13:18	13:54	0:36	LINE CLEAR AVAILED
414	10-Jan-2020	BAGALKOT	110	JOG1(SIDDAPUR)-SIRSI	SIRSI_110	12:57	13:54	0:57	LINE CLEAR AVAILED
415	10-Jan-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	10:53	17:03	6:10	LINE CLEAR AVAILED
416	10-Jan-2020	BENGALURU	66	SRS PEENYA 220 - BYDARAHALLI	BYDARAHALLI, TAVAREKERE, KODIHALLI	10:58	12:17	1:19	LINE FAULT
417	10-Jan-2020	GULBARGA	220	RAICHUR-JURALA1_IPP	RAICHUR_220	11:46	13:11	1:25	LINE CLEAR AVAILED
418	10-Jan-2020	GULBARGA	220	HV1&2	RAICHUR_220	12:08	12:40	0:32	LINE CLEAR AVAILED
419	10-Jan-2020	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	0:00	13:59	13:59	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
420	10-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_GLB_110	3:37	3:45	0:08	LINE FAULT
421	10-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_GLB_110	6:20	6:28	0:08	LINE FAULT
422	10-Jan-2020	GULBARGA	110	TEKKELKOTE-SHAHISOLAR_IPP	TEKKALAKOTE_110	19:25	23:59	4:34	LINE CLEAR AVAILED
423	10-Jan-2020	GULBARGA	110	HV1	RAICHUR_220	0:52	0:59	0:07	TRANSFORMER FAULT
424	10-Jan-2020	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	10:09	13:53	3:44	NFBC ISSUED
425	10-Jan-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	11:45	11:58	0:13	HAND TRIPPED
426	10-Jan-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:08	13:53	3:45	LINE CLEAR AVAILED
427	10-Jan-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	10:53	17:05	6:12	LINE CLEAR AVAILED
428	10-Jan-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	9:35	12:22	2:47	LINE CLEAR AVAILED
429	10-Jan-2020	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	9:35	12:35	3:00	LINE CLEAR AVAILED
430	10-Jan-2020	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	12:35	23:59	11:24	LINE CLEAR AVAILED
431	10-Jan-2020	HASSAN	110	HV1	GURUVAYANAKERE_110	12:04	13:11	1:07	LINE CLEAR AVAILED
432	10-Jan-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:03	17:20	0:17	HAND TRIPPED
433	10-Jan-2020	HASSAN	110	HV2	HIRIYADKA_110	10:51	11:57	1:06	LINE CLEAR AVAILED
434	10-Jan-2020	HASSAN	110	HV1	KEMAR_220	10:49	11:05	0:16	LINE CLEAR AVAILED
435	10-Jan-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	8:37	18:18	9:41	LINE CLEAR AVAILED
436	10-Jan-2020	HASSAN	110	HV2	NERALAKERE_110	23:57	23:59	0:02	TRANSFORMER FAULT
437	10-Jan-2020	HASSAN	110	PTTUR-SLTR	PUTTUR_220	12:54	14:07	1:13	NFBC ISSUED
438	10-Jan-2020	HASSAN	110	SALATHUR-NTMDNOR	SALATHUR_110	12:48	14:12	1:24	NFBC ISSUED
439	10-Jan-2020	HASSAN	110	HV1	BRAHMAV	11:03	12:24	1:21	LINE CLEAR AVAILED
440	10-Jan-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:47	10:52	0:05	LINE FAULT
441	10-Jan-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	8:59	9:02	0:03	LINE FAULT
442	10-Jan-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:55	13:54	2:59	MAIN SUPPLY FAILURE
443	10-Jan-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:36	13:53	3:17	MAIN SUPPLY FAILURE
444	10-Jan-2020	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	18:16	23:59	5:43	LINE CLEAR AVAILED
445	10-Jan-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:36	13:52	3:16	LINE CLEAR AVAILED
446	10-Jan-2020	HASSAN	66	HV2	HOLALUR_66	9:11	9:16	0:05	TRANSFORMER FAULT
447	10-Jan-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	7:52	8:10	0:18	LINE FAULT
448	10-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	8:45	8:49	0:04	TRANSFORMER FAULT
449	10-Jan-2020	MYSORE	66	HV2	FTS_66	10:10	11:29	1:19	LINE CLEAR AVAILED
450	10-Jan-2020	MYSORE	66	HD KOTE-KADAKOLA	HDKOTE_66	12:39	14:03	1:24	LINE CLEAR AVAILED
451	10-Jan-2020	MYSORE	66	KADAKOLA-SARGURU 2	CHANDRAVADI_66 DOORA_66 HULLAHALLI_66 HURA_66	11:05	12:34	1:29	LINE CLEAR AVAILED
452	10-Jan-2020	MYSORE	66	KADAKOLA-SARGURU 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	12:35	13:58	1:22	LINE CLEAR AVAILED
453	10-Jan-2020	MYSORE	66	HV1	SFCSHIVA_66	9:15	23:59	14:43	LINE CLEAR AVAILED
454	10-Jan-2020	MYSORE	66	HV1	VIRAJPET_66	18:54	19:25	0:31	TRANSFORMER FAULT
455	10-Jan-2020	MYSORE	66	HV1	VIRAJPET_66	20:16	20:32	0:16	TRANSFORMER FAULT
456	10-Jan-2020	MYSORE	66	HV2	VIRAJPET_66	19:16	19:22	0:05	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
457	10-Jan-2020	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	10:42	11:38	0:56	LINE CLEAR AVAILED
458	10-Jan-2020	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	12:01	14:45	2:43	LINE CLEAR AVAILED
459	10-Jan-2020	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	6:31	6:52	0:21	TRANSFORMER FAULT
460	10-Jan-2020	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	12:02	15:55	3:53	LINE CLEAR AVAILED
461	10-Jan-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	11:49	12:01	0:12	HAND TRIPPED
462	10-Jan-2020	TUMKUR	110	TR-2	TURUVEKERE_110	11:08	11:20	0:12	TRANSFORMER FAULT
463	10-Jan-2020	TUMKUR	110	TR-2	HULIYAR_110	12:18	13:30	1:11	LINE CLEAR AVAILED
464	10-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	6:56	7:09	0:13	LINE FAULT
465	10-Jan-2020	TUMKUR	66	TR-1	BANUVALLI_66	13:28	14:39	1:10	LINE CLEAR AVAILED
466	10-Jan-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	10:26	10:35	0:08	TRANSFORMER FAULT
467	10-Jan-2020	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	6:58	7:12	0:13	MAIN SUPPLY FAILURE
468	10-Jan-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	10:42	11:40	0:57	LINE CLEAR AVAILED
469	10-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	0:03	1:10	1:07	LINE FAULT
470	10-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:18	8:24	2:06	LINE CLEAR AVAILED
471	10-Jan-2020	TUMKUR	66	TR-2	HARIYABBE_66	16:07	16:14	0:07	TRANSFORMER FAULT
472	10-Jan-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:40	8:10	1:29	LINE CLEAR AVAILED
473	10-Jan-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	6:38	8:01	1:23	LINE CLEAR AVAILED
474	10-Jan-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:39	8:11	1:32	LINE CLEAR AVAILED
475	10-Jan-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	6:39	8:11	1:32	LINE CLEAR AVAILED
476	10-Jan-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	6:38	6:54	0:15	HAND TRIPPED
477	10-Jan-2020	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON1_IPP_66	6:57	8:59	2:02	LINE CLEAR AVAILED
478	10-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:02	12:21	0:19	HAND TRIPPED
479	10-Jan-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:10	13:24	0:13	LINE FAULT
480	10-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	6:52	8:08	1:16	LINE CLEAR AVAILED
481	10-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	12:29	13:01	0:32	LINE CLEAR AVAILED
482	10-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	6:31	6:52	0:21	LINE FAULT
483	10-Jan-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	6:51	7:30	0:39	LINE CLEAR AVAILED
484	10-Jan-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	6:51	8:09	1:17	LINE CLEAR AVAILED
485	10-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	6:52	8:12	1:20	LINE CLEAR AVAILED
486	10-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	6:52	8:12	1:20	LINE CLEAR AVAILED
487	10-Jan-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	10:13	17:14	7:00	LINE CLEAR AVAILED
488	10-Jan-2020	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	15:58	16:06	0:08	LINE FAULT
489	10-Jan-2020	TUMKUR	66	TR-2	LINGDHALLI_66	15:21	15:56	0:34	LINE CLEAR AVAILED
490	10-Jan-2020	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	10:23	12:54	2:31	LINE CLEAR AVAILED
491	10-Jan-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	17:09	17:12	0:03	TRANSFORMER FAULT
492	10-Jan-2020	TUMKUR	66	TR-1	PAVAGADA_66	9:41	9:54	0:13	TRANSFORMER FAULT
493	10-Jan-2020	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	8:45	10:08	1:22	LINE CLEAR AVAILED
494	10-Jan-2020	TUMKUR	66	TR-1	TUMKUR_66	11:58	12:24	0:26	LINE CLEAR AVAILED
495	10-Jan-2020	TUMKUR	66	TR-2	TUMKUR_66	12:26	13:01	0:34	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
496	11-Jan-2020	BAGALKOT	110	MAHALINGAPUR -BANAHAATTI_110	BANAHAATTI_110	10:29	11:49	1:20	LINE CLEAR AVAILED
497	11-Jan-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	7:44	7:44	LINE CLEAR AVAILED
498	11-Jan-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	20:57	23:59	3:02	LINE CLEAR AVAILED
499	11-Jan-2020	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	19:26	19:31	0:05	LINE FAULT
500	11-Jan-2020	BAGALKOT	110	110/11KV,HV1	CHIKKODI_110	10:56	12:47	1:51	LINE CLEAR AVAILED
501	11-Jan-2020	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110,SALAHALLI_110	4:26	4:46	0:20	LINE FAULT
502	11-Jan-2020	BAGALKOT	220	220/110KV,HV 2 & LV 2	MAHALINGAPUR_220	10:54	11:41	0:47	LINE CLEAR AVAILED
503	11-Jan-2020	BAGALKOT	110	110/11KV,HV 2	MALGHAN(S)_110	12:41	13:06	0:25	TRANSFORMER FAULT
504	11-Jan-2020	BAGALKOT	110	MK HUBLI-NARENDRA2	MK HUBLI_220	9:59	17:05	7:06	LINE CLEAR AVAILED
505	11-Jan-2020	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, JATRAT_33, BENADI_33	14:26	16:30	2:04	LINE CLEAR AVAILED
506	11-Jan-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	10:53	11:57	1:04	LINE CLEAR AVAILED
507	11-Jan-2020	BAGALKOT	110	SOUDATTI220-NARAGUND (RAMDURGA1)	RAMDURGA_110	18:35	18:55	0:20	LINE FAULT
508	11-Jan-2020	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	18:35	19:12	0:37	LINE FAULT
509	11-Jan-2020	BAGALKOT	110	VPPL-SADALAGA	SADALAGA_110	0:00	1:24	1:24	LINE CLEAR AVAILED
510	11-Jan-2020	BAGALKOT	110	VPPL-SADALAGA	SADALAGA_110	1:30	2:11	0:41	LINE CLEAR AVAILED
511	11-Jan-2020	BAGALKOT	110	110/33KV, HV2	UTTUR_110, VANTAGODI_33, YADWAD_33	14:49	15:00	0:11	TRANSFORMER FAULT
512	11-Jan-2020	BENGALURU	220	HV2	MITTEMARI 220	22:40	23:59	1:19	TRANSFORMER FAULT
513	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	10:05	10:08	0:03	LOAD CHANGE OVER
514	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	13:45	13:46	0:01	LOAD CHANGE OVER
515	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	10:01	10:04	0:02	LOAD CHANGE OVER
516	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	13:38	13:43	0:05	LOAD CHANGE OVER
517	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:57	13:35	3:38	LOAD CHANGE OVER
518	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	9:57	9:59	0:01	LOAD CHANGE OVER
519	11-Jan-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	13:35	13:37	0:01	LOAD CHANGE OVER
520	11-Jan-2020	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	10:08	10:10	0:02	LINE CLEAR AVAILED
521	11-Jan-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	16:38	16:49	0:11	LINE FAULT
522	11-Jan-2020	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	16:38	16:51	0:13	LINE FAULT
523	11-Jan-2020	BENGALURU	66	POTTERY ROAD - HBR LAYOUT	POTTERY ROAD, ITC (EHT)	18:56	19:12	0:16	LOAD CHANGE OVER
524	11-Jan-2020	BENGALURU	66	POTTERY ROAD - HOODY 220	POTTERY ROAD, ITC (EHT)	8:30	16:49	8:19	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
525	11-Jan-2020	BENGALURU	66	KANAKPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	5:46	6:01	0:15	LINE FAULT
526	11-Jan-2020	BENGALURU	66	RAJANKUNTE - DB PURA 2	RAJANKUNTE	11:30	13:50	2:20	LINE CLEAR AVAILED
527	11-Jan-2020	GULBARGA	110	TEKKELKOTE-SHAHISOLAR_IPP	TEKKALAKOTE_110	0:00	0:55	0:55	LINE CLEAR AVAILED
528	11-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_GLB_110	3:55	4:04	0:09	LINE FAULT
529	11-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_GLB_110	5:38	5:45	0:07	LINE FAULT
530	11-Jan-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:25	23:32	0:07	LINE FAULT
531	11-Jan-2020	GULBARGA	110	HV1	TEKKALAKOTE_110	11:00	11:05	0:05	TRANSFORMER FAULT
532	11-Jan-2020	GULBARGA	110	HV1	TEKKALAKOTE_110	11:35	11:40	0:05	TRANSFORMER FAULT
533	11-Jan-2020	GULBARGA	110	HV2	RAICHUR_220	0:00	11:28	11:28	LINE CLEAR AVAILED
534	11-Jan-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:01	1:28	0:27	LINE FAULT
535	11-Jan-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:02	5:09	0:07	LINE FAULT
536	11-Jan-2020	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	7:45	7:50	0:05	LINE FAULT
537	11-Jan-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	9:48	23:59	14:11	NFBC ISSUED
538	11-Jan-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	12:52	13:34	0:42	LINE CLEAR AVAILED
539	11-Jan-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	9:48	23:59	14:11	LINE CLEAR AVAILED
540	11-Jan-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	9:43	23:59	14:16	LINE CLEAR AVAILED
541	11-Jan-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	8:14	18:20	10:06	LINE CLEAR AVAILED
542	11-Jan-2020	HASSAN	110	HV2	NERALAKERE_110	0:00	0:05	0:05	TRANSFORMER FAULT
543	11-Jan-2020	HASSAN	66	HV1	BELUR_66	14:05	14:25	0:20	LINE CLEAR AVAILED
544	11-Jan-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	17:20	17:46	0:26	HAND TRIPPED
545	11-Jan-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	8:58	17:30	8:32	LINE CLEAR AVAILED
546	11-Jan-2020	MYSORE	66	DEVNUR(MYS)-RAJIVNAGARA	RAJEEVNAGARA_66	8:12	8:28	0:16	LINE FAULT
547	11-Jan-2020	MYSORE	66	HV2	FTS_66	10:06	11:38	1:32	LINE CLEAR AVAILED
548	11-Jan-2020	MYSORE	66	HV2	HAMPAPURA_66	14:14	14:26	0:12	TRANSFORMER FAULT
549	11-Jan-2020	MYSORE	66	HV2	PANDAVAPURA_66	10:06	15:10	5:03	LINE CLEAR AVAILED
550	11-Jan-2020	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	FTS_66 JYOTHINAGARA_66 BANNIMANTAP_66	8:07	8:16	0:09	LINE FAULT
551	11-Jan-2020	MYSORE	66	HV1	SFCSHIVA_66	10:15	10:30	0:15	HAND TRIPPED
552	11-Jan-2020	MYSORE	66	HV4	SFCSHIVA_66	11:24	23:59	12:34	LINE CLEAR AVAILED
553	11-Jan-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	12:20	12:37	0:17	LINE FAULT
554	11-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	22:11	22:45	0:33	LINE FAULT
555	11-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	22:11	22:39	0:27	LINE FAULT
556	11-Jan-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	22:11	22:43	0:31	LINE FAULT
557	11-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	22:11	22:43	0:31	LINE FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
558	11-Jan-2020	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	22:11	22:38	0:26	TRANSFORMER FAULT
559	11-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	22:11	22:43	0:31	LINE FAULT
560	11-Jan-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	15:40	15:45	0:04	TRANSFORMER FAULT
561	11-Jan-2020	TUMKUR	66	TR-1	HANAGAL_66	8:34	9:58	1:24	LINE CLEAR AVAILED
562	12-Jan-2020	BAGALKOT	110	110/33KV,HV1 &HV2	BELGAUM_110	9:12	16:38	7:26	LINE CLEAR AVAILED
563	12-Jan-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	7:48	7:48	LINE CLEAR AVAILED
564	12-Jan-2020	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	18:22	19:13	0:51	LINE CLEAR AVAILED
565	12-Jan-2020	BAGALKOT	110	110/11KV,HV1	KUD DHARWAD_110	18:49	23:59	5:10	TRANSFORMER FAULT
566	12-Jan-2020	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	11:48	12:00	0:12	TRANSFORMER FAULT
567	12-Jan-2020	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	10:01	13:47	3:46	LINE CLEAR AVAILED
568	12-Jan-2020	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	17:23	17:45	0:22	LINE CLEAR AVAILED
569	12-Jan-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:14	13:28	1:14	LINE CLEAR AVAILED
570	12-Jan-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	11:12	14:48	3:36	LINE CLEAR AVAILED
571	12-Jan-2020	BENGALURU	66	JANGAMAKOTE - VIJAYAPURA	JANGAMAKOTE	11:12	11:28	0:16	LOAD CHANGE OVER
572	12-Jan-2020	BENGALURU	66	JANGAMAKOTE - CHINTAMANI 220	JANGAMAKOTE	14:46	15:00	0:14	LOAD CHANGE OVER
573	12-Jan-2020	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	11:08	17:10	6:02	LINE CLEAR AVAILED
574	12-Jan-2020	BENGALURU	66	DODDABELANGALA - DB PURA 220	DODDABELAVANGALA	14:25	14:45	0:20	MAIN SUPPLY FAILURE
575	12-Jan-2020	BENGALURU	66	DODDABELANGALA - DB PURA 220	DODDABELAVANGALA	11:12	11:28	0:16	MAIN SUPPLY FAILURE
576	12-Jan-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:01	15:07	0:06	LINE CLEAR AVAILED
577	12-Jan-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:47	11:52	0:05	LOAD CHANGE OVER
578	12-Jan-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	TUBUGERE	11:47	11:52	0:05	LOAD CHANGE OVER
579	12-Jan-2020	BENGALURU	220	A STATION 220 - EDC 220	A STATION 220	13:15	13:17	0:02	MAIN SUPPLY FAILURE
580	12-Jan-2020	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	13:15	13:17	0:02	MAIN SUPPLY FAILURE
581	12-Jan-2020	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	13:15	13:17	0:02	MAIN SUPPLY FAILURE
582	12-Jan-2020	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	13:50	14:02	0:12	LOAD CHANGE OVER
583	12-Jan-2020	BENGALURU	66	BANASHANKARI - VRUSHABAVATHI 220	BANASHANKARI	15:33	15:43	0:10	LOAD CHANGE OVER
584	12-Jan-2020	BENGALURU	66	HV2	BANASHANKARI	11:28	11:48	0:20	LINE CLEAR AVAILED
585	12-Jan-2020	BENGALURU	220	HV1	BIDADI 220	15:37	17:34	1:57	LINE CLEAR AVAILED
586	12-Jan-2020	BENGALURU	220	HV2	BIDADI 220	14:55	16:30	1:35	LINE CLEAR AVAILED
587	12-Jan-2020	BENGALURU	66	HV1	BIDADI 220	11:08	12:54	1:46	LINE CLEAR AVAILED
588	12-Jan-2020	BENGALURU	66	HV2	BIDADI 220	12:43	16:01	3:18	LINE CLEAR AVAILED
589	12-Jan-2020	BENGALURU	66	HV1	BRINDAVANA	10:15	10:25	0:10	LINE CLEAR AVAILED
590	12-Jan-2020	BENGALURU	66	HV2	BRINDAVANA	11:00	11:15	0:15	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
591	12-Jan-2020	BENGALURU	66	HV2	BRINDAVANA	11:35	12:02	0:27	TRANSFORMER FAULT
592	12-Jan-2020	BENGALURU	66	HV1	BYDARAHALLI	8:28	8:33	0:05	LINE CLEAR AVAILED
593	12-Jan-2020	BENGALURU	66	KUMBLUGODU - KENGARI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:05	10:10	0:05	LOAD CHANGE OVER
594	12-Jan-2020	BENGALURU	66	KUMBLUGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	18:45	18:50	0:05	LOAD CHANGE OVER
595	12-Jan-2020	BENGALURU	220	NELMANGALA 400 - PEENYA 4	NRS 220	13:14	13:38	0:24	LINE FAULT
596	12-Jan-2020	BENGALURU	220	HV2	SUBRAMANYAPURA 220	10:10	10:22	0:12	TRANSFORMER FAULT
597	12-Jan-2020	BENGALURU	66	RAJANKUNTE - DB PURA 2	RAJANKUNTE	11:20	11:25	0:05	LINE CLEAR AVAILED
598	12-Jan-2020	BENGALURU	66	RAJANKUNTE - DB PURA 2	RAJANKUNTE	14:25	14:30	0:05	LINE CLEAR AVAILED
599	12-Jan-2020	GULBARGA	110	HV1	CHINCHOLI_110	9:45	9:58	0:13	TRANSFORMER FAULT
600	12-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:18	19:40	0:22	LINE FAULT
601	12-Jan-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	5:16	5:30	0:14	LINE FAULT
602	12-Jan-2020	GULBARGA	66	HV1	ITTAGI_220	4:03	4:20	0:17	TRANSFORMER FAULT
603	12-Jan-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA-400	0:00	17:12	17:12	LINE FAULT
604	12-Jan-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA-400	17:16	23:59	6:43	LINE FAULT
605	12-Jan-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	17:08	17:27	0:19	LINE FAULT
606	12-Jan-2020	HASSAN	220	MRSSHM-ARSIKERE	MRSMSG_220	17:08	17:25	0:17	LINE FAULT
607	12-Jan-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	17:08	17:42	0:34	LINE FAULT
608	12-Jan-2020	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	17:08	17:37	0:29	LINE FAULT
609	12-Jan-2020	HASSAN	220	HV1	MRSMSG_220	17:08	17:27	0:19	TRANSFORMER FAULT
610	12-Jan-2020	HASSAN	220	HV2	MRSMSG_220	17:08	17:27	0:19	TRANSFORMER FAULT
611	12-Jan-2020	HASSAN	220	HV3	MRSMSG_220	17:08	17:27	0:19	TRANSFORMER FAULT
612	12-Jan-2020	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	17:08	17:25	0:17	LINE FAULT
613	12-Jan-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	17:08	17:26	0:18	LINE FAULT
614	12-Jan-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	17:08	17:24	0:16	LINE FAULT
615	12-Jan-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	17:08	17:23	0:15	LINE FAULT
616	12-Jan-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	17:08	17:25	0:17	LINE FAULT
617	12-Jan-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	14:07	19:56	5:49	LINE FAULT
618	12-Jan-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	17:08	17:25	0:17	LINE FAULT
619	12-Jan-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	17:08	17:30	0:22	LINE FAULT
620	12-Jan-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	17:08	17:29	0:21	LINE FAULT
621	12-Jan-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	10:10	18:03	7:53	LINE CLEAR AVAILED
622	12-Jan-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	14:07	19:55	5:48	LINE FAULT
623	12-Jan-2020	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	17:07	17:41	0:34	LINE FAULT
624	12-Jan-2020	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	17:07	17:40	0:33	LINE FAULT
625	12-Jan-2020	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	17:30	17:45	0:15	LINE FAULT
626	12-Jan-2020	HASSAN	110	HV2	ESSUR_110	19:27	23:59	4:32	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
627	12-Jan-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:46	17:38	7:52	LINE CLEAR AVAILED
628	12-Jan-2020	HASSAN	110	HV1	TOGARSI_110	10:48	12:39	1:51	LINE CLEAR AVAILED
629	12-Jan-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	22:12	22:17	0:05	HAND TRIPPED
630	12-Jan-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	12:55	13:09	0:14	LINE CLEAR AVAILED
631	12-Jan-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	15:05	15:26	0:21	LINE CLEAR AVAILED
632	12-Jan-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	9:00	15:33	6:33	LINE CLEAR AVAILED
633	12-Jan-2020	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	6:45	7:01	0:16	LINE FAULT
634	12-Jan-2020	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	12:00	14:00	2:00	LINE CLEAR AVAILED
635	12-Jan-2020	HASSAN	66	CANNAR-CTPATNA1	CHANNARAYAPATNA_66	12:00	14:00	2:00	LINE CLEAR AVAILED
636	12-Jan-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	6:45	14:13	7:28	LINE FAULT
637	12-Jan-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	12:00	14:05	2:05	LINE CLEAR AVAILED
638	12-Jan-2020	MYSORE	66	KUSHALNAGARA 220-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	6:32	6:49	0:17	LINE FAULT
639	12-Jan-2020	MYSORE	66	MEGALAPURA-SFC	THUMBLA_66 CHIDRAVALLI_66 TNARASIPURA_66 VYASRAJPURA_66 GARGESHWARI_66	12:11	12:22	0:10	LINE FAULT
640	12-Jan-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 KESLAGERE_66 VADERALLI_66	4:07	4:17	0:10	LINE FAULT
641	12-Jan-2020	MYSORE	66	HUNSUR-ELWALA	GAVADAGERE_66	7:18	7:34	0:15	LINE FAULT
642	12-Jan-2020	TUMKUR	66	TR-1	HD PURA_66	7:23	7:28	0:04	TRANSFORMER FAULT
643	12-Jan-2020	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	9:38	9:41	0:03	LINE FAULT
644	12-Jan-2020	TUMKUR	66	TR-1	MEDIGESHI_66	9:37	9:48	0:11	TRANSFORMER FAULT
645	12-Jan-2020	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	9:29	9:31	0:01	LINE FAULT
646	12-Jan-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRS MG_220	12:20	12:37	0:17	LINE FAULT
647	13-Jan-2020	BAGALKOT	220	LINGASUR2-BAGEWADI	BAGEWADI_220	10:40	14:35	3:55	LINE CLEAR AVAILED
648	13-Jan-2020	BAGALKOT	220	NADIHAL1&2-BAGWADI	BAGEWADI_220	15:30	17:15	1:45	LINE FAULT
649	13-Jan-2020	BAGALKOT	220	220/110KV,HV1&2,LV1&2	BAGEWADI_220,MUDEDEBIHAL_110,MAM ADAPUR_110,UKLI_110,CHIMMALGI_110	15:30	17:51	2:21	TRANSFORMER FAULT
650	13-Jan-2020	BAGALKOT	220	220/110KV,HV3,LV3	BAGEWADI_220,NIDAGUNDI_110,SINDAG I_110	15:30	17:55	2:25	TRANSFORMER FAULT
651	13-Jan-2020	BAGALKOT	220	FORTUNE FIVE 1&2-BAGEWADI	BAGEWADI_220	15:30	18:07	2:37	LINE FAULT
652	13-Jan-2020	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	15:30	18:06	2:36	LINE FAULT
653	13-Jan-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	15:30	18:05	2:35	LINE FAULT
654	13-Jan-2020	BAGALKOT	220	ADPH1&2-BAGEWADI	BAGEWADI_220	15:30	18:32	3:02	LINE FAULT
655	13-Jan-2020	BAGALKOT	220	LINGASUR1&2-BAGEWADI	BAGEWADI_220	15:30	18:10	2:40	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
656	13-Jan-2020	BAGALKOT	110	110/33KV,HV2	BAGEWADI_220,MUTTAGI_33,MANAGULI_33,BGL_33,TALIKOTI_33	15:30	18:00	2:30	TRANSFORMER FAULT
657	13-Jan-2020	BAGALKOT	110	110/11KV,HV1	BAGEWADI_220	15:30	18:00	2:30	TRANSFORMER FAULT
658	13-Jan-2020	BAGALKOT	220	GADAG2-BAGALKOT	BAGALKOT_220	15:37	23:59	8:22	LINE FAULT
659	13-Jan-2020	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	0:00	15:52	15:52	LINE CLEAR AVAILED
660	13-Jan-2020	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	0:00	15:53	15:53	LINE CLEAR AVAILED
661	13-Jan-2020	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	BAGALKOT_220	15:53	23:59	8:06	LINE CLEAR AVAILED
662	13-Jan-2020	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	BAGALKOT_220	15:54	23:59	8:05	LINE CLEAR AVAILED
663	13-Jan-2020	BAGALKOT	110	BIDNAL-HUBLI2	BIDNAL_220	11:03	13:30	2:27	LINE CLEAR AVAILED
664	13-Jan-2020	BAGALKOT	220	SIRSI-HUBLI 1&2	SIRSI_220	11:59	14:40	2:41	LINE CLEAR AVAILED
665	13-Jan-2020	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	14:41	17:35	2:54	LINE FAULT
666	13-Jan-2020	BAGALKOT	110	MAHALINGAPUR-UTTUR	UTTUR_110	22:06	23:45	1:39	LINE FAULT
667	13-Jan-2020	BAGALKOT	110	MAHALINGAPUR-UTTUR	UTTUR_110	23:46	23:54	0:08	HAND TRIPPED
668	13-Jan-2020	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	10:31	17:01	6:30	LINE CLEAR AVAILED
669	13-Jan-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	9:16	11:20	2:04	TRANSFORMER FAULT
670	13-Jan-2020	BAGALKOT	110	110/11KV,HV1	KUD DHARWAD_110	0:00	22:00	22:00	LINE CLEAR AVAILED
671	13-Jan-2020	BAGALKOT	110	SIRSI220-KIRUVATTI	KIRUVATTI_220	10:27	23:59	13:32	LINE CLEAR AVAILED
672	13-Jan-2020	BAGALKOT	220	220/110KV,HV1	MAHALINGAPUR_220	22:02	22:25	0:23	TRANSFORMER FAULT
673	13-Jan-2020	BAGALKOT	110	MAHALINGAPUR-ITNAL	ITNAL_110	22:02	22:35	0:33	LINE FAULT
674	13-Jan-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	22:05	22:34	0:29	LINE FAULT
675	13-Jan-2020	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	22:02	23:59	1:57	LINE FAULT
676	13-Jan-2020	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	12:30	14:44	2:14	LINE CLEAR AVAILED
677	13-Jan-2020	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	23:18	23:59	0:41	NFBC ISSUED
678	13-Jan-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	9:55	10:07	0:12	LINE FAULT
679	13-Jan-2020	BENGALURU	220	LV2	BIDADI 220	9:55	10:07	0:12	TRANSFORMER FAULT
680	13-Jan-2020	BENGALURU	66	HV1	JAYADEVA	12:20	14:50	2:30	LINE CLEAR AVAILED
681	13-Jan-2020	BENGALURU	66	AUSTIN TOWN - KORMANGALA 220	AUSTIN TOWN	17:30	17:48	0:18	LOAD CHANGE OVER
682	13-Jan-2020	BENGALURU	220	HV1	CHINTAMANI 220	10:04	10:24	0:20	TRANSFORMER FAULT
683	13-Jan-2020	BENGALURU	220	HV2	CHINTAMANI 220	10:04	10:24	0:20	TRANSFORMER FAULT
684	13-Jan-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:04	10:24	0:20	MAIN SUPPLY FAILURE
685	13-Jan-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	10:04	10:24	0:20	MAIN SUPPLY FAILURE
686	13-Jan-2020	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	10:04	10:24	0:20	MAIN SUPPLY FAILURE
687	13-Jan-2020	BENGALURU	66	CHINTAMANI 220 - TALAGWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:04	10:24	0:20	MAIN SUPPLY FAILURE
688	13-Jan-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	KODIHALLI, SRINIVASAPURA, YELDUR	10:04	10:24	0:20	MAIN SUPPLY FAILURE
689	13-Jan-2020	BENGALURU	66	KEMBODI - KOLAR 220	KOMBODI, NANGLI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU	7:20	7:50	0:30	LOAD CURTAILMENT
690	13-Jan-2020	BENGALURU	66	HV2	CHANDRALAYOUT	17:09	17:16	0:07	TRANSFORMER FAULT
691	13-Jan-2020	GULBARGA	220	LINGASUGUR-BAGEWADI1&2	LINGASUGUR_220	10:40	14:35	3:55	LINE CLEAR AVAILED
692	13-Jan-2020	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	11:42	17:05	5:23	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
693	13-Jan-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	13:50	14:02	0:12	LINE FAULT
694	13-Jan-2020	GULBARGA	220	LINGASUGUR-SINDHANOOR	LINGASUGUR_220	13:50	14:20	0:30	LINE FAULT
695	13-Jan-2020	GULBARGA	220	KAPANOOR-SHAHAPUR1	SHAHAPUR_220	14:35	15:29	0:54	LINE FAULT
696	13-Jan-2020	GULBARGA	220	LINGASUGUR-BAGEWADI1	LINGASUGUR_220	15:35	15:50	0:15	LINE FAULT
697	13-Jan-2020	GULBARGA	220	LINGASUGUR-BAGEWADI2	LINGASUGUR_220	15:35	15:57	0:22	LINE FAULT
698	13-Jan-2020	GULBARGA	220	HV1	KUSTAGI_220	16:25	17:03	0:38	LINE CLEAR AVAILED
699	13-Jan-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	0:39	0:45	0:06	LINE FAULT
700	13-Jan-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:20	20:27	0:07	LINE FAULT
701	13-Jan-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:13	21:18	0:05	LINE FAULT
702	13-Jan-2020	GULBARGA	110	SINDHANOOR-SUZLON1_IPP	SINDHANOOR_220	11:55	14:50	2:55	LINE FAULT
703	13-Jan-2020	GULBARGA	66	ITTAGI-KUDLIGI1&2	KUDLIGI_66,HANASI_66,KOGALI_66,CJHALI_66,CHORNOOR_66,BANAVEKAL,GUDEKOTE_66,HOSAHALLI_66	18:00	18:09	0:09	LINE FAULT
704	13-Jan-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPUR_66,MAGLA_66,SOVENHALLI_66	19:58	20:05	0:07	LINE FAULT
705	13-Jan-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	12:36	12:36	LINE FAULT
706	13-Jan-2020	HASSAN	110	MSEZ-GSS31	MSEZ_220	9:55	15:07	5:12	LINE CLEAR AVAILED
707	13-Jan-2020	HASSAN	110	HV2	ARASIKERE_110	14:53	16:39	1:46	LINE CLEAR AVAILED
708	13-Jan-2020	HASSAN	110	HV2	ESSUR_110	0:00	11:09	11:09	TRANSFORMER FAULT
709	13-Jan-2020	HASSAN	110	HV1	BRAHMAVARA_110	7:14	7:29	0:15	LOAD CURTAILMENT
710	13-Jan-2020	HASSAN	66	HASSN22-HN PURA	HASSAN_220	14:07	14:26	0:19	LINE FAULT
711	13-Jan-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:54	12:40	2:46	LINE CLEAR AVAILED
712	13-Jan-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:48	16:02	0:14	LINE FAULT
713	13-Jan-2020	HASSAN	66	HNPR2-HSN2	HOLENARASIPURA_220	15:20	15:25	0:05	LINE FAULT
714	13-Jan-2020	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	7:54	7:56	0:02	LINE FAULT
715	13-Jan-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	12:06	12:20	0:14	HAND TRIPPED
716	13-Jan-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	18:04	18:32	0:28	HAND TRIPPED
717	13-Jan-2020	HASSAN	66	HV1	SINGAPURA_66	12:06	12:20	0:14	HAND TRIPPED
718	13-Jan-2020	HASSAN	66	HV1	SINGAPURA_66	18:04	18:32	0:28	HAND TRIPPED
719	13-Jan-2020	HASSAN	66	HV2	SINGAPURA_66	12:06	12:20	0:14	HAND TRIPPED
720	13-Jan-2020	HASSAN	66	HV2	SINGAPURA_66	18:04	18:32	0:28	HAND TRIPPED
721	13-Jan-2020	HASSAN	66	HV2	BASAVAGHATTA_66	7:13	7:26	0:13	LOAD CURTAILMENT
722	13-Jan-2020	MYSORE	66	HV2	ADDIHALLI_66	7:12	7:21	0:09	LOAD CURTAILMENT
723	13-Jan-2020	MYSORE	66	HV1	DODDINADUVADI_66	7:12	7:21	0:08	LOAD CURTAILMENT
724	13-Jan-2020	MYSORE	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI_66	13:08	14:08	1:00	LINE CLEAR AVAILED
725	13-Jan-2020	MYSORE	66	HV2	ELAVALA_66	11:31	12:31	0:59	LINE CLEAR AVAILED
726	13-Jan-2020	MYSORE	66	HV1	KOLLEGALA_66	14:33	15:32	0:58	LINE CLEAR AVAILED
727	13-Jan-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	3:20	3:39	0:19	LINE FAULT
728	13-Jan-2020	MYSORE	66	HV1	MADIKERI_66	11:23	12:19	0:55	LINE CLEAR AVAILED
729	13-Jan-2020	MYSORE	66	HV3	SFCSHIVA_66	10:21	23:59	13:37	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
730	13-Jan-2020	MYSORE	66	HV1	SHIVALLY_66	12:10	15:32	3:22	LINE CLEAR AVAILED
731	13-Jan-2020	MYSORE	66	HV1	SHIVALLY_66	16:02	16:25	0:22	LINE CLEAR AVAILED
732	13-Jan-2020	MYSORE	66	HV1	SHIVALLY_66	17:20	17:50	0:30	LINE CLEAR AVAILED
733	13-Jan-2020	MYSORE	66	HV1	SHIVALLY_66	18:20	18:30	0:10	LINE CLEAR AVAILED
734	13-Jan-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	7:33	8:06	0:33	LOAD CURTAILMENT
735	13-Jan-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	11:28	16:11	4:43	LINE CLEAR AVAILED
736	13-Jan-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	12:20	12:37	0:17	LINE FAULT
737	13-Jan-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	0:37	0:52	0:14	TRANSFORMER FAULT
738	13-Jan-2020	TUMKUR	110	TR-1	KBCROSS_220	3:58	4:37	0:39	TRANSFORMER FAULT
739	13-Jan-2020	TUMKUR	66	TR-2	BELLAVI_66	13:02	13:16	0:13	LINE CLEAR AVAILED
740	13-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:05	10:19	0:14	LINE FAULT
741	13-Jan-2020	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_IPP_66	7:42	7:57	0:14	LINE FAULT
742	13-Jan-2020	TUMKUR	66	TR-2	MALEBENNUR_66	12:17	12:24	0:06	TRANSFORMER FAULT
743	13-Jan-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	7:27	8:20	0:52	HAND TRIPPED
744	13-Jan-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	15:58	16:09	0:10	LINE FAULT
745	13-Jan-2020	TUMKUR	66	TR-2	HIREHALLY_66	12:12	12:14	0:01	TRANSFORMER FAULT
746	13-Jan-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	15:47	15:55	0:07	LINE CLEAR AVAILED
747	13-Jan-2020	TUMKUR	66	TR-1	CHITRADURGA_66	16:50	17:01	0:10	HAND TRIPPED
748	13-Jan-2020	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	13:45	14:25	0:40	HAND TRIPPED
749	13-Jan-2020	TUMKUR	66	TR-2	HDPURA_66	2:45	2:51	0:06	LINE CLEAR AVAILED
750	13-Jan-2020	TUMKUR	66	TR-2	HDPURA_66	17:39	17:41	0:01	LINE CLEAR AVAILED