

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 26.11.2019 TO 02.12.2019

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	26-Nov-19	BAGALKOT	220	AMBEWADI-NAGJARI2	AMBEWADI_220	14:13	23:59	9:46	LINE FAULT
2	26-Nov-19	BAGALKOT	220	GUTUUR1-HAVERI	HAVERI_220	15:32	17:30	1:58	LINE CLEAR AVAIED
3	26-Nov-19	BAGALKOT	220	GUTUUR2-HAVERI	HAVERI_220	10:40	12:28	1:48	LINE CLEAR AVAIED
4	26-Nov-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_220	11:00	15:07	4:07	LINE CLEAR AVAIED
5	26-Nov-19	BAGALKOT	110	MK HUBLI220-BAILHONGAL	BAILHONGAL_110	15:40	15:45	0:05	LINE FAULT
6	26-Nov-19	BAGALKOT	110	BELGAUM220-HUKKERI	HUKKERI_110	11:47	12:01	0:14	LINE FAULT
7	26-Nov-19	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	11:47	11:57	0:10	LINE FAULT
8	26-Nov-19	BAGALKOT	110	BELGAUM-KANABARGI	KANABARGI_110	15:00	15:07	0:07	LINE FAULT
9	26-Nov-19	BAGALKOT	110	ENERCON1-SOUDATTI	SOUDATTI_110	10:19	14:39	4:20	LINE CLEAR AVAIED
10	26-Nov-19	BAGALKOT	110	ENERCON2-SOUDATTI	SOUDATTI_110	14:51	18:57	4:06	LINE CLEAR AVAIED
11	26-Nov-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	11:45	12:00	0:15	LINE FAULT
12	26-Nov-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	9:21	12:40	3:19	HAND TRIPPED
13	26-Nov-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	14:01	14:24	0:23	HAND TRIPPED
14	26-Nov-19	BAGALKOT	110	110/11KV,HV2	TIKOT_110	12:24	14:00	1:36	TRANSFORMER FAULT
15	26-Nov-19	BENGALURU	66	NANGALI - KEMPANAHALLI	NANGALI	11:55	12:05	0:10	LINE FAULT
16	26-Nov-19	BENGALURU	66	HV1	NANGALI	16:55	17:20	0:25	LINE CLEAR AVAIED
17	26-Nov-19	BENGALURU	66	HV2	TK HALLI 220	15:58	16:14	0:16	LINE CLEAR AVAIED
18	26-Nov-19	BENGALURU	66	HV2	KADBISANAHALLI	14:41	15:30	0:49	LINE CLEAR AVAIED
19	26-Nov-19	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	11:15	23:59	12:44	NFBC ISSUED
20	26-Nov-19	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	14:29	17:58	3:29	NFBC ISSUED
21	26-Nov-19	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	14:35	17:58	3:23	NFBC ISSUED
22	26-Nov-19	GULBARGA	220	HV1	HUMNABAD_220	12:00	12:10	0:10	TRANSFORMER FAULT
23	26-Nov-19	GULBARGA	110	HV5	LINGASUGUR_220	12:08	14:35	2:27	LINE CLEAR AVAIED
24	26-Nov-19	GULBARGA	110	HV5	LINGASUGUR_220	14:35	14:56	0:21	TRANSFORMER FAULT
25	26-Nov-19	GULBARGA	110	HV1	LINGASUGUR_220	15:18	15:23	0:05	TRANSFORMER FAULT
26	26-Nov-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110,SRERAM	14:04	14:40	0:36	LINE CLEAR AVAIED
27	26-Nov-19	GULBARGA	110	BUSA,BUSB	HUMNABAD_220	16:10	17:27	1:17	LINE CLEAR AVAIED
28	26-Nov-19	GULBARGA	110	HV1	MADIYAL_110	19:12	19:22	0:10	LINE CLEAR AVAIED
29	26-Nov-19	GULBARGA	110	HV3	MADIYAL_110	15:15	18:30	3:15	TRANSFORMER FAULT
30	26-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:56	7:05	4:09	HAND TRIPPED
31	26-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:57	23:59	2:02	HAND TRIPPED
32	26-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:52	6:52	HAND TRIPPED
33	26-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:12	23:59	0:47	HAND TRIPPED
34	26-Nov-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	8:48	12:55	4:07	LINE CLEAR AVAIED
35	26-Nov-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:19	14:08	1:49	LINE CLEAR AVAIED
36	26-Nov-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	14:29	17:46	3:17	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
37	26-Nov-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	0:00	14:27	14:27	LINE FAULT
38	26-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	12:20	14:08	1:48	LINE CLEAR AVAILED
39	26-Nov-19	HASSAN	220	KADUR-DABUSET	KADUR_220	14:27	17:40	3:13	NFBC ISSUED
40	26-Nov-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	8:33	18:00	9:27	LINE FAULT
41	26-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	14:28	14:28	LINE FAULT
42	26-Nov-19	HASSAN	220	HV1	MSEZ_220	9:57	14:42	4:45	LINE CLEAR AVAILED
43	26-Nov-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:20	14:24	5:04	LINE CLEAR AVAILED
44	26-Nov-19	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	8:48	12:56	4:08	LINE CLEAR AVAILED
45	26-Nov-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	11:17	13:59	2:42	LINE CLEAR AVAILED
46	26-Nov-19	HASSAN	110	LV1	MSEZ_220	9:56	14:43	4:47	LINE CLEAR AVAILED
47	26-Nov-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	11:37	13:58	2:21	NFBC ISSUED
48	26-Nov-19	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	11:37	13:59	2:22	NFBC ISSUED
49	26-Nov-19	HASSAN	110	HV2	HALADY_110	10:39	12:11	1:32	LINE CLEAR AVAILED
50	26-Nov-19	HASSAN	110	HV2	KONAJE_110	10:16	14:30	4:14	LINE CLEAR AVAILED
51	26-Nov-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	9:39	17:01	7:22	LINE CLEAR AVAILED
52	26-Nov-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	17:01	17:18	0:17	LINE CLEAR AVAILED
53	26-Nov-19	HASSAN	110	SAGARA-TAL	SAGARA_110	10:07	14:27	4:20	LINE CLEAR AVAILED
54	26-Nov-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	13:45	16:20	2:35	LINE CLEAR AVAILED
55	26-Nov-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:17	16:30	0:13	LINE FAULT
56	26-Nov-19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	11:05	16:35	5:30	LINE CLEAR AVAILED
57	26-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	6:39	6:53	0:14	LINE CLEAR AVAILED
58	26-Nov-19	HASSAN	66	HV2	CHIKMAGALUR_66	6:39	6:53	0:14	LINE CLEAR AVAILED
59	26-Nov-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	13:40	16:20	2:40	NFBC ISSUED
60	26-Nov-19	HASSAN	66	HV1	HALEBEEDU_66	0:00	4:55	4:55	MAIN SUPPLY FAILURE
61	26-Nov-19	HASSAN	66	HV2	SINGAPURA_66	11:15	15:37	4:22	LINE CLEAR AVAILED
62	26-Nov-19	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	5:49	5:54	0:05	LINE FAULT
63	26-Nov-19	MYSORE	66	HV1	JAKKANAHALLY_66	4:58	12:50	7:51	TRANSFORMER FAULT
64	26-Nov-19	MYSORE	66	KR PETE 220-BOOKANAKERE	BANANGADI_66,BOOKANAKERE_66, CHINAK	0:21	0:29	0:07	LINE FAULT
65	26-Nov-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_	19:58	20:06	0:07	LINE FAULT
66	26-Nov-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_	21:43	21:51	0:08	LINE FAULT
67	26-Nov-19	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	17:07	17:30	0:22	TRANSFORMER FAULT
68	26-Nov-19	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	14:36	17:46	3:09	LINE CLEAR AVAILED
69	26-Nov-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	14:29	17:47	3:18	LINE CLEAR AVAILED
70	26-Nov-19	TUMKUR	110	TR-1	KGTEMPLE_110	4:06	4:18	0:12	LINE CLEAR AVAILED
71	26-Nov-19	TUMKUR	110	TR-1	SHETYKERE_110	11:44	15:33	3:48	LINE CLEAR AVAILED
72	26-Nov-19	TUMKUR	110	TR-2	SHETYKERE_110	12:24	14:00	1:35	LINE CLEAR AVAILED
73	26-Nov-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	11:23	14:00	2:36	LINE CLEAR AVAILED
74	26-Nov-19	TUMKUR	66	TR-2	CHANNAGIRI_66	14:29	14:34	0:05	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
75	26-Nov-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:07	17:26	0:18	HAND TRIPPED
76	26-Nov-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	17:07	17:26	0:18	HAND TRIPPED
77	26-Nov-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUV	17:07	17:26	0:19	HAND TRIPPED
78	26-Nov-19	TUMKUR	66	TR-2	HARIHAR_66	13:59	14:18	0:19	LINE CLEAR AVAILED
79	26-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	3:40	3:52	0:11	LINE FAULT
80	26-Nov-19	TUMKUR	66	TR-2	KUKKAWADA_66	12:11	14:00	1:48	LINE CLEAR AVAILED
81	26-Nov-19	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	10:10	11:19	1:08	LINE CLEAR AVAILED
82	26-Nov-19	TUMKUR	66	NAGALAMADIKE-SUNDER RAJU SOLAR_IPP_66	SUNDER RAJU SOLAR_IPP_66	11:43	11:46	0:02	LINE CLEAR AVAILED
83	26-Nov-19	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66	2:14	2:31	0:17	LINE FAULT
84	26-Nov-19	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66	2:14	2:31	0:17	LINE FAULT
85	26-Nov-19	TUMKUR	66	TR-2	THOVINAKERE_66	11:34	11:48	0:14	LINE CLEAR AVAILED
86	26-Nov-19	TUMKUR	66	TR-2	THOVINAKERE_66	14:00	14:07	0:06	LINE CLEAR AVAILED
87	26-Nov-19	TUMKUR	66	THOVINAKERE-ANTHRASANAHALI	THOVINAKERE_66	11:34	11:47	0:13	LINE CLEAR AVAILED
88	26-Nov-19	TUMKUR	66	THOVINAKERE-ANTHRASANAHALI	THOVINAKERE_66	14:00	14:03	0:03	LINE CLEAR AVAILED
89	27-Nov-19	BAGALKOT	110	110/11KV, HV1	BABLESHWAR_110	10:30	16:00	5:30	LINE CLEAR AVAILED
90	27-Nov-19	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	0:00	12:39	12:39	LINE CLEAR AVAILED
91	27-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	10:29	12:50	2:21	LINE CLEAR AVAILED
92	27-Nov-19	BAGALKOT	110	BIJAPUR220-BIJAPUR CITY	BIJAPUR CITY_110	22:43	23:59	1:16	LINE FAULT
93	27-Nov-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	12:34	19:49	7:15	LINE CLEAR AVAILED
94	27-Nov-19	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	21:33	23:59	2:26	LINE CLEAR AVAILED
95	27-Nov-19	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	13:05	13:17	0:12	LINE CLEAR AVAILED
96	27-Nov-19	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	17:45	18:11	0:26	LINE CLEAR AVAILED
97	27-Nov-19	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	10:26	17:36	7:10	LINE CLEAR AVAILED
98	27-Nov-19	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	15:04	15:09	0:05	TRANSFORMER FAULT
99	27-Nov-19	BAGALKOT	110	110/33KV, HV2	MUNDARGI_110, SINTALUR_33	10:18	10:57	0:39	LINE CLEAR AVAILED
100	27-Nov-19	BAGALKOT	110	110/33KV, HV2	MURDESHWAR_110, BHATKALA_33, KASARCI	12:35	13:10	0:35	LINE CLEAR AVAILED
101	27-Nov-19	BAGALKOT	110	ENERCON2-SOUDATTI	SOUDATTI_110	10:54	16:24	5:30	LINE CLEAR AVAILED
102	27-Nov-19	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMAWAD_33, IE_33	8:31	8:41	0:10	LINE CLEAR AVAILED
103	27-Nov-19	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	14:58	15:15	0:17	LINE CLEAR AVAILED
104	27-Nov-19	BENGALURU	66	HV2	AMAR JYOTHI	12:15	15:05	2:50	LINE CLEAR AVAILED
105	27-Nov-19	BENGALURU	66	HV1	EPIP	6:25	8:46	2:21	TRANSFORMER FAULT
106	27-Nov-19	BENGALURU	66	HV2	KHODAYS	12:06	12:09	0:03	LINE CLEAR AVAILED
107	27-Nov-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:55	12:09	0:14	LOAD CHANGE OVER
108	27-Nov-19	BENGALURU	66	GOLF LINKS - HAL 220	GOLF LINKS	12:10	12:15	0:05	LOAD CHANGE OVER
109	27-Nov-19	BENGALURU	66	GOLF LINKS - HSR LAYOUT	GOLF LINKS	16:25	16:30	0:05	LOAD CHANGE OVER
110	27-Nov-19	BENGALURU	66	LEELA VENTURE - HAL 220	LEELA VENTURE	12:05	14:52	2:47	LINE CLEAR AVAILED
111	27-Nov-19	BENGALURU	66	HV1	DEVANAHALLI	12:18	12:23	0:05	TRANSFORMER FAULT
112	27-Nov-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, Y	5:57	6:15	0:18	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
113	27-Nov-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	17:35	17:40	0:05	LOAD CHANGE OVER
114	27-Nov-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	11:25	11:30	0:05	LOAD CHANGE OVER
115	27-Nov-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:55	12:05	0:10	LOAD CHANGE OVER
116	27-Nov-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:40	17:45	0:05	LOAD CHANGE OVER
117	27-Nov-19	BENGALURU	220	HV1	MALUR 220	15:00	16:06	1:06	LINE CLEAR AVAILED
118	27-Nov-19	BENGALURU	220	HV2	MALUR 220	16:08	17:02	0:54	LINE CLEAR AVAILED
119	27-Nov-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, BUDHIKOTE, TEKAL, KAMASAMUDRA, K	15:00	16:08	1:08	LINE CLEAR AVAILED
120	27-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:00	16:08	1:08	LINE CLEAR AVAILED
121	27-Nov-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	16:08	17:05	0:57	LINE CLEAR AVAILED
122	27-Nov-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:08	17:05	0:57	LINE CLEAR AVAILED
123	27-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:08	17:05	0:57	LINE CLEAR AVAILED
124	27-Nov-19	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	0:00	20:10	20:10	LINE CLEAR AVAILED
125	27-Nov-19	GULBARGA	220	RTPS-SEDAM1	RTPS_220	10:31	15:53	5:22	NFBC ISSUED
126	27-Nov-19	GULBARGA	220	HV2	SEDAM_220	19:48	19:58	0:10	TRANSFORMER FAULT
127	27-Nov-19	GULBARGA	220	HV2	SEDAM_220	21:15	21:25	0:10	TRANSFORMER FAULT
128	27-Nov-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	13:15	13:42	0:27	LINE FAULT
129	27-Nov-19	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	13:15	13:57	0:42	LINE FAULT
130	27-Nov-19	GULBARGA	110	GURUMITAKAL-KONKAL	GURUMITKAL_110	19:45	20:05	0:20	MAIN SUPPLY FAILURE
131	27-Nov-19	GULBARGA	110	GURUMITAKAL-KONKAL	GURUMITKAL_110	21:15	21:30	0:15	MAIN SUPPLY FAILURE
132	27-Nov-19	GULBARGA	110	KOLHAR-HALBURGA, JANAWADA	KOLHAR_110	19:05	19:10	0:05	LINE FAULT
133	27-Nov-19	GULBARGA	110	HV4	LINGASUGUR_220	14:48	15:28	0:40	LINE CLEAR AVAILED
134	27-Nov-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:10	12:22	0:12	HAND TRIPPED
135	27-Nov-19	GULBARGA	66	MUNIRABAD-HANASI	HANASI_66	9:40	10:15	0:35	MAIN SUPPLY FAILURE
136	27-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:19	7:19	HAND TRIPPED
137	27-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:52	6:52	HAND TRIPPED
138	27-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:25	23:59	0:34	HAND TRIPPED
139	27-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:38	14:26	13:48	LINE FAULT
140	27-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	11:15	11:23	0:08	LINE FAULT
141	27-Nov-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	0:38	13:49	13:11	LINE FAULT
142	27-Nov-19	HASSAN	110	HV2	ANANDAPURA_110	10:35	18:10	7:35	LINE CLEAR AVAILED
143	27-Nov-19	HASSAN	110	HV1	BAIKAMPADI_110	11:20	12:40	1:20	LINE CLEAR AVAILED
144	27-Nov-19	HASSAN	110	HV5	BAIKAMPADI_110	10:10	11:15	1:05	LINE CLEAR AVAILED
145	27-Nov-19	HASSAN	110	HV3	GURUVAYANAKERE_110	10:50	13:55	3:05	LINE CLEAR AVAILED
146	27-Nov-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:15	12:29	1:14	LINE FAULT
147	27-Nov-19	HASSAN	110	HV4	MANIPAL_110	10:38	12:20	1:42	LINE CLEAR AVAILED
148	27-Nov-19	HASSAN	110	HV1	MRSMG_220	10:11	10:20	0:09	HAND TRIPPED
149	27-Nov-19	HASSAN	110	HV2	MRSMG_220	10:11	10:20	0:09	HAND TRIPPED
150	27-Nov-19	HASSAN	110	HV2	MRSMG_220	15:38	17:27	1:49	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	27-Nov-19	HASSAN	110	HV3	MRSMSG_220	10:11	10:20	0:09	HAND TRIPPED
152	27-Nov-19	HASSAN	110	HV4	MRSMSG_220	10:11	10:20	0:09	HAND TRIPPED
153	27-Nov-19	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	10:55	23:59	13:04	LINE CLEAR AVAILED
154	27-Nov-19	HASSAN	110	HV1	NAVUNDA_110	10:00	17:00	7:00	LINE CLEAR AVAILED
155	27-Nov-19	HASSAN	110	HV2	NAVUNDA_110	9:55	17:08	7:13	LINE CLEAR AVAILED
156	27-Nov-19	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	10:00	16:48	6:48	LINE CLEAR AVAILED
157	27-Nov-19	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	10:19	10:23	0:04	HAND TRIPPED
158	27-Nov-19	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	10:19	10:23	0:04	HAND TRIPPED
159	27-Nov-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:19	10:22	0:03	HAND TRIPPED
160	27-Nov-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:19	10:22	0:03	HAND TRIPPED
161	27-Nov-19	HASSAN	66	LV1	MRSMSG_220	10:11	10:22	0:11	HAND TRIPPED
162	27-Nov-19	HASSAN	66	LV2	MRSMSG_220	10:11	10:20	0:09	HAND TRIPPED
163	27-Nov-19	HASSAN	66	LV2	MRSMSG_220	15:38	17:28	1:50	LINE CLEAR AVAILED
164	27-Nov-19	HASSAN	66	LV3	MRSMSG_220	10:19	10:20	0:01	HAND TRIPPED
165	27-Nov-19	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	13:13	18:27	5:14	NFBC ISSUED
166	27-Nov-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	5:19	5:39	0:20	MAIN SUPPLY FAILURE
167	27-Nov-19	MYSORE	66	HV1	K_HONNALGERE_66	13:23	14:40	1:17	MAIN SUPPLY FAILURE
168	27-Nov-19	MYSORE	66	HV2	K_HONNALGERE_66	13:23	14:40	1:17	MAIN SUPPLY FAILURE
169	27-Nov-19	MYSORE	66	HV1	KIADBMANDYA_66	13:22	14:41	1:19	MAIN SUPPLY FAILURE
170	27-Nov-19	MYSORE	66	HV2	KIADBMANDYA_66	13:22	14:41	1:19	MAIN SUPPLY FAILURE
171	27-Nov-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	13:21	14:39	1:18	MAIN SUPPLY FAILURE
172	27-Nov-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	13:21	14:39	1:18	MAIN SUPPLY FAILURE
173	27-Nov-19	MYSORE	66	HV1	KMDODDI_66	13:21	14:38	1:17	MAIN SUPPLY FAILURE
174	27-Nov-19	MYSORE	66	HV2	KMDODDI_66	13:21	14:38	1:17	MAIN SUPPLY FAILURE
175	27-Nov-19	MYSORE	66	KUSHALNAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66, KANAGAL_66	6:26	6:37	0:11	LINE FAULT
176	27-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	11:35	14:53	3:18	LINE CLEAR AVAILED
177	27-Nov-19	TUMKUR	400	TR-2(HV SIDE)	GUTUR_400	12:06	14:52	2:45	LINE CLEAR AVAILED
178	27-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	11:53	16:27	4:34	LINE CLEAR AVAILED
179	27-Nov-19	TUMKUR	66	BADDIHALLI- HIREHALLY	BADDIHALLI_66	16:03	17:08	1:05	LINE CLEAR AVAILED
180	27-Nov-19	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	16:03	17:08	1:05	LINE CLEAR AVAILED
181	27-Nov-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	2:59	18:54	15:55	LINE CLEAR AVAILED
182	27-Nov-19	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	14:24	15:05	0:41	LINE CLEAR AVAILED
183	27-Nov-19	TUMKUR	66	MELKOTE-ANTHRASANAHALLI	MELKOTE_66	11:49	16:30	4:40	LINE CLEAR AVAILED
184	27-Nov-19	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	11:49	16:30	4:40	LINE CLEAR AVAILED
185	27-Nov-19	TUMKUR	66	TR-1& TR-2	MELKOTE_66	11:49	16:30	4:41	LINE CLEAR AVAILED
186	27-Nov-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	18:16	18:24	0:07	LINE FAULT
187	27-Nov-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	18:16	18:22	0:06	LINE FAULT
188	27-Nov-19	TUMKUR	66	NAGALAMADIKE- ATRIA_IPP_66	ATRIA_IPP_66	9:37	9:43	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
189	27-Nov-19	TUMKUR	66	TR-2	TUMKUR_66	11:24	12:18	0:54	LINE CLEAR AVAILED
190	28-Nov-19	BAGALKOT	110	110/11KV, HV2	ANANDNAGAR_110	16:06	16:45	0:39	LINE CLEAR AVAILED
191	28-Nov-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	13:47	16:33	2:46	LINE CLEAR AVAILED
192	28-Nov-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	16:40	16:46	0:06	HAND TRIPPED
193	28-Nov-19	BAGALKOT	220	220/110KV, HV1&LV1	RANEBENNUR_220	15:41	16:05	0:24	TRANSFORMER FAULT
194	28-Nov-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	11:27	16:21	4:54	LINE CLEAR AVAILED
195	28-Nov-19	BAGALKOT	110	GHATAPRABHA220-SHIRGOAN	SHIRGOAN_110	18:58	19:20	0:22	LINE FAULT
196	28-Nov-19	BAGALKOT	110	110/11KV, HV2	ITANAL_110	15:33	16:04	0:31	LINE CLEAR AVAILED
197	28-Nov-19	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	10:14	11:42	1:28	LINE CLEAR AVAILED
198	28-Nov-19	BAGALKOT	110	SATTI SUGARS-PG HUNSHYAL	PG HUNSHYAL_110	18:57	19:00	0:03	LINE FAULT
199	28-Nov-19	BAGALKOT	110	110/11KV, HV2	RON_110	11:48	12:11	0:23	TRANSFORMER FAULT
200	28-Nov-19	BAGALKOT	110	ENERCON1&2-SOUDATTI	SOUDATTI_110	12:17	12:21	0:04	LINE FAULT
201	28-Nov-19	BAGALKOT	110	110/11KV, HV1&HV2	MUNDUGANUR_110	11:50	12:55	1:05	LINE CLEAR AVAILED
202	28-Nov-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	11:03	11:08	0:05	LOAD CHANGE OVER
203	28-Nov-19	BENGALURU	66	HV3	ADUGODI	12:23	12:29	0:06	LOAD CHANGE OVER
204	28-Nov-19	BENGALURU	66	HV3	ADUGODI	15:33	15:43	0:10	LOAD CHANGE OVER
205	28-Nov-19	BENGALURU	66	SOUTH CITY-SOMNAHALLI 220	SOUTH CITY	11:05	11:10	0:05	LOAD CHANGE OVER
206	28-Nov-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	17:52	17:57	0:04	LOAD CHANGE OVER
207	28-Nov-19	BENGALURU	66	HV2	CB PURA URBAN	12:33	14:05	1:31	LINE CLEAR AVAILED
208	28-Nov-19	BENGALURU	66	HV1	AMARJYOTHI	22:33	22:49	0:15	TRANSFORMER FAULT
209	28-Nov-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	10:52	11:58	1:06	LINE CLEAR AVAILED
210	28-Nov-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	0:27	1:17	0:49	LINE FAULT
211	28-Nov-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	1:17	4:32	3:14	LINE FAULT
212	28-Nov-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA	12:16	15:25	3:08	LINE CLEAR AVAILED
213	28-Nov-19	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	17:18	17:36	0:18	LINE CLEAR AVAILED
214	28-Nov-19	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	17:17	17:36	0:19	LINE CLEAR AVAILED
215	28-Nov-19	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	17:17	17:37	0:20	LINE CLEAR AVAILED
216	28-Nov-19	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	17:19	17:35	0:16	LINE CLEAR AVAILED
217	28-Nov-19	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	0:08	15:05	14:57	LINE FAULT
218	28-Nov-19	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	6:11	6:32	0:21	LINE FAULT
219	28-Nov-19	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	6:50	9:33	2:43	LINE FAULT
220	28-Nov-19	GULBARGA	110	LINGASUGUR-MUDAGAL	MUDAGAL_110	12:55	15:30	2:35	LINE CLEAR AVAILED
221	28-Nov-19	GULBARGA	110	HV5	LINGASUGUR_220	13:39	15:09	1:30	LINE CLEAR AVAILED
222	28-Nov-19	GULBARGA	110	HV5	LINGASUGUR_220	15:12	15:16	0:04	LINE CLEAR AVAILED
223	28-Nov-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUNIRABAD_220	0:45	0:55	0:10	LINE FAULT
224	28-Nov-19	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	3:40	4:05	0:25	LINE FAULT
225	28-Nov-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUNIRABAD_220	21:45	21:55	0:10	LINE FAULT
226	28-Nov-19	GULBARGA	110	SINDHANOOR-NIRLOOPI	SINDHANOOR_220	22:12	22:32	0:20	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
227	28-Nov-19	GULBARGA	110	HV1	KOLHAR_110	11:12	16:50	5:38	LINE CLEAR AVAILED
228	28-Nov-19	GULBARGA	110	HV1	KOLHAR_110	17:15	17:30	0:15	TRANSFORMER FAULT
229	28-Nov-19	GULBARGA	110	KOLHAR-HALBURGA, JANAWADA,SHAHI SOLAR	KOLHAR_110	16:55	17:10	0:15	LINE CLEAR AVAILED
230	28-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:23	7:23	HAND TRIPPED
231	28-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:11	23:59	1:48	HAND TRIPPED
232	28-Nov-19	HASSAN	220	HV1	HASSAN_220	9:34	17:35	8:01	LINE CLEAR AVAILED
233	28-Nov-19	HASSAN	220	HV1	KEMAR_220	13:02	13:46	0:44	LINE CLEAR AVAILED
234	28-Nov-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:29	12:58	2:29	NFBC ISSUED
235	28-Nov-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	15:39	18:42	3:03	LINE FAULT
236	28-Nov-19	HASSAN	220	HV2	MSEZ_220	9:44	14:39	4:55	LINE CLEAR AVAILED
237	28-Nov-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:29	12:58	2:29	LINE CLEAR AVAILED
238	28-Nov-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:39	18:53	3:14	LINE FAULT
239	28-Nov-19	HASSAN	110	LV1	KEMAR_220	13:00	13:46	0:46	LINE CLEAR AVAILED
240	28-Nov-19	HASSAN	110	HV1	MRSMG_220	9:06	10:47	1:41	LINE CLEAR AVAILED
241	28-Nov-19	HASSAN	110	HV2	MRSMG_220	11:04	12:41	1:37	LINE CLEAR AVAILED
242	28-Nov-19	HASSAN	110	LV2	MSEZ_220	9:44	14:39	4:55	LINE CLEAR AVAILED
243	28-Nov-19	HASSAN	110	HV2	HOSANGADI_110	17:19	17:36	0:17	TRANSFORMER FAULT
244	28-Nov-19	HASSAN	110	HV2	KONAJE_110	9:41	14:16	4:35	LINE CLEAR AVAILED
245	28-Nov-19	HASSAN	110	HV1	MOODABIDRE_110	23:10	23:18	0:08	TRANSFORMER FAULT
246	28-Nov-19	HASSAN	110	HV2	NAVUNDA_110	9:44	17:57	8:13	LINE CLEAR AVAILED
247	28-Nov-19	HASSAN	66	LV1	MRSMG_220	9:06	10:48	1:42	LINE CLEAR AVAILED
248	28-Nov-19	HASSAN	66	LV2	MRSMG_220	11:03	12:42	1:39	LINE CLEAR AVAILED
249	28-Nov-19	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	9:30	10:20	0:50	LINE CLEAR AVAILED
250	28-Nov-19	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	17:56	18:08	0:12	LINE CLEAR AVAILED
251	28-Nov-19	HASSAN	66	HASSN220-CHIKAMAGLUR2	HASSAN_220	9:30	10:20	0:50	LINE CLEAR AVAILED
252	28-Nov-19	HASSAN	66	HASSN220-CHIKAMAGLUR2	HASSAN_220	17:56	18:08	0:12	LINE CLEAR AVAILED
253	28-Nov-19	HASSAN	66	HASSN220-HN PURA	HASSAN_220	9:37	18:10	8:33	LINE CLEAR AVAILED
254	28-Nov-19	HASSAN	66	LV1	HASSAN_220	9:34	18:05	8:31	LINE CLEAR AVAILED
255	28-Nov-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	9:30	18:36	9:06	LINE CLEAR AVAILED
256	28-Nov-19	HASSAN	66	HASSN220-CRP2	HASSAN_220	9:27	18:25	8:58	LINE CLEAR AVAILED
257	28-Nov-19	HASSAN	66	HASSN220-SKPURA	HASSAN_220	9:30	18:07	8:37	LINE CLEAR AVAILED
258	28-Nov-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	9:30	18:16	8:46	MAIN SUPPLY FAILURE
259	28-Nov-19	HASSAN	66	HV1	BASAVAGHATTA_66	10:22	12:57	2:35	LINE CLEAR AVAILED
260	28-Nov-19	HASSAN	66	HV2	CHIKMAGALUR_66	17:02	18:20	1:18	LINE CLEAR AVAILED
261	28-Nov-19	HASSAN	66	HAGARE-HASSAN	HAGARE_66	11:20	13:35	2:15	MAIN SUPPLY FAILURE
262	28-Nov-19	HASSAN	66	HV1	HAGARE_66	13:57	16:03	2:06	LINE CLEAR AVAILED
263	28-Nov-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	12:32	15:24	2:52	LINE CLEAR AVAILED
264	28-Nov-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	14:39	14:43	0:04	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
265	28-Nov-19	HASSAN	66	HV1	HNPURA_66	8:30	18:45	10:15	LINE CLEAR AVAILED
266	28-Nov-19	HASSAN	66	HNPURA-MYSRE1	HNPURA_66	8:30	17:10	8:40	LINE CLEAR AVAILED
267	28-Nov-19	HASSAN	66	HNPURA-GUDDENAHALLI	HNPURA_66	8:30	17:10	8:40	LINE CLEAR AVAILED
268	28-Nov-19	HASSAN	66	KIADB HA-HASAN I/C	KIADB_66	9:43	18:33	8:50	MAIN SUPPLY FAILURE
269	28-Nov-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:14	17:34	0:20	LINE FAULT
270	28-Nov-19	HASSAN	66	HV1	MAGGE_66	9:35	11:36	2:01	LINE CLEAR AVAILED
271	28-Nov-19	HASSAN	66	HV1	MAGGE_66	13:06	13:24	0:18	MAIN SUPPLY FAILURE
272	28-Nov-19	HASSAN	66	HV1	MAGGE_66	17:57	18:12	0:15	MAIN SUPPLY FAILURE
273	28-Nov-19	HASSAN	66	HV2	MAGGE_66	9:34	10:37	1:03	LINE CLEAR AVAILED
274	28-Nov-19	HASSAN	66	HV2	MAGGE_66	13:06	13:25	0:19	MAIN SUPPLY FAILURE
275	28-Nov-19	HASSAN	66	HV2	MAGGE_66	17:57	18:13	0:16	MAIN SUPPLY FAILURE
276	28-Nov-19	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	12:25	12:38	0:13	LINE CLEAR AVAILED
277	28-Nov-19	MYSORE	66	JAKKANAHALLY-NAGAMANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GU	3:40	11:50	8:10	LINE FAULT
278	28-Nov-19	MYSORE	220	HV1	KADAKOLA_220	10:32	14:26	3:53	LINE CLEAR AVAILED
279	28-Nov-19	MYSORE	220	HV2	KADAKOLA_220	14:28	17:40	3:11	LINE CLEAR AVAILED
280	28-Nov-19	MYSORE	66	MADHUVANAHALLY-PG PALYA	PG PALYA	15:22	15:48	0:25	LINE CLEAR AVAILED
281	28-Nov-19	MYSORE	66	HV2	SFC SIVA-	10:07	10:31	0:24	HAND TRIPPED
282	28-Nov-19	MYSORE	66	HV3	SFC SIVA-	10:57	11:21	0:24	HAND TRIPPED
283	28-Nov-19	MYSORE	66	HV4	SFC SIVA-	11:37	11:50	0:13	HAND TRIPPED
284	28-Nov-19	MYSORE	66	HV1	SUNTIKOPPA	14:06	15:23	1:17	LINE CLEAR AVAILED
285	28-Nov-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BG	19:46	19:56	0:10	LINE FAULT
286	28-Nov-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	20:46	20:50	0:03	LINE CLEAR AVAILED
287	28-Nov-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	11:18	12:38	1:20	LINE CLEAR AVAILED
288	28-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	8:52	9:02	0:10	LINE FAULT
289	28-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLU	7:08	7:23	0:15	LINE FAULT
290	28-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLU	8:33	9:26	0:52	LINE CLEAR AVAILED
291	28-Nov-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	12:41	12:56	0:14	HAND TRIPPED
292	28-Nov-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, B	5:23	5:34	0:11	LINE FAULT
293	28-Nov-19	TUMKUR	66	TR-2	MALEBENNUR_66	10:42	11:40	0:57	LINE CLEAR AVAILED
294	28-Nov-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	7:08	9:46	2:38	TRANSFORMER FAULT
295	28-Nov-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	7:08	9:45	2:37	TRANSFORMER FAULT
296	28-Nov-19	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	7:08	9:45	2:37	LINE FAULT
297	28-Nov-19	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	9:02	9:03	0:01	MAIN SUPPLY FAILURE
298	28-Nov-19	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	8:52	9:27	0:35	LINE FAULT
299	29-Nov-19	BAGALKOT	110	110/11KV,HV2	UGARKHUD_110	13:12	13:21	0:09	LINE CLEAR AVAILED
300	29-Nov-19	BAGALKOT	110	110/33KV.HV3	TILUVALI_110,KALKERI_33,SHESHAGIRI_33,	12:45	13:04	0:19	TRANSFORMER FAULT
301	29-Nov-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	10:10	20:25	10:15	LINE CLEAR AVAILED
302	29-Nov-19	BAGALKOT	220	220/110KV,HV1	SOUDATTI_220	10:45	17:08	6:23	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
303	29-Nov-19	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110	14:05	14:44	0:39	LINE CLEAR AVAILED
304	29-Nov-19	BAGALKOT	110	GM NAVAR-SALAHALLI	SALAHALLI_110	14:05	14:44	0:39	LINE CLEAR AVAILED
305	29-Nov-19	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	15:18	15:47	0:29	LINE CLEAR AVAILED
306	29-Nov-19	BAGALKOT	110	HIREKERUR-RATTIHALLI	RATTIHALLI_110	15:19	23:59	8:40	HAND TRIPPED
307	29-Nov-19	BAGALKOT	110	110/11KV,HV1	NANADI_110	0:40	1:03	0:23	TRANSFORMER FAULT
308	29-Nov-19	BAGALKOT	110	BLGM SOLAR-MAMADAPUR	MAMADAPUR(B)_110	17:23	18:14	0:51	LINE CLEAR AVAILED
309	29-Nov-19	BENGALURU	66	HV3	BANASHANKARI	11:26	11:30	0:03	LINE CLEAR AVAILED
310	29-Nov-19	BENGALURU	66	HAL 200 - HOODY 2	BAGMANE TEC PARK, GTRE (EHT)	8:40	10:16	1:36	LINE FAULT
311	29-Nov-19	BENGALURU	66	HSR 220 - ADUGODI 1	JAKKASANDRA	4:22	4:50	0:27	LINE FAULT
312	29-Nov-19	BENGALURU	66	HV1	ISRO LAYOUT	15:43	16:20	0:36	TRANSFORMER FAULT
313	29-Nov-19	BENGALURU	66	HV1	RAJANKUNTE	12:13	12:20	0:06	LINE CLEAR AVAILED
314	29-Nov-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	16:40	17:25	0:44	LINE FAULT
315	29-Nov-19	BENGALURU	66	HV1	YARANDANAHALLI 220	19:05	20:40	1:34	MAIN SUPPLY FAILURE
316	29-Nov-19	BENGALURU	66	HV3	YARANDANAHALLI 220	19:05	20:40	1:34	MAIN SUPPLY FAILURE
317	29-Nov-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	19:05	20:40	1:34	LINE FAULT
318	29-Nov-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA	12:17	16:04	3:47	LINE CLEAR AVAILED
319	29-Nov-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWAR	16:01	16:52	0:50	LINE CLEAR AVAILED
320	29-Nov-19	BENGALURU	66	HV1	DODDABELAVANGALA	11:00	18:05	7:05	LINE CLEAR AVAILED
321	29-Nov-19	BENGALURU	66	HV2	DODDABELAVANGALA	11:00	17:00	6:00	LINE CLEAR AVAILED
322	29-Nov-19	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	17:17	17:23	0:06	LOAD CURTAILMENT
323	29-Nov-19	BENGALURU	66	HV2	HALAGURU	10:00	11:40	1:40	LINE CLEAR AVAILED
324	29-Nov-19	BENGALURU	66	HV1	HALAGURU	11:38	12:25	0:47	LINE CLEAR AVAILED
325	29-Nov-19	BENGALURU	66	HV2	JIGANI 66	15:20	16:15	0:55	LINE CLEAR AVAILED
326	29-Nov-19	BENGALURU	66	HV3	JIGANI 66	16:15	16:55	0:40	LINE CLEAR AVAILED
327	29-Nov-19	BENGALURU	66	HV2	JIGANI 66	19:05	20:40	1:34	MAIN SUPPLY FAILURE
328	29-Nov-19	BENGALURU	66	HV3	JIGANI 66	19:05	20:40	1:34	MAIN SUPPLY FAILURE
329	29-Nov-19	BENGALURU	66	HV2	YEDUMADU	13:14	13:30	0:15	LINE CLEAR AVAILED
330	29-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	1:36	2:15	0:39	LINE FAULT
331	29-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	11:54	15:05	3:11	LINE CLEAR AVAILED
332	29-Nov-19	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	11:54	15:05	3:11	LINE CLEAR AVAILED
333	29-Nov-19	BENGALURU	66	JIGANI 220 - SOMANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	19:05	20:40	1:34	LINE FAULT
334	29-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMP	11:54	15:05	3:11	MAIN SUPPLY FAILURE
335	29-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR, BAG	11:54	15:05	3:11	MAIN SUPPLY FAILURE
336	29-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT	11:54	15:05	3:11	MAIN SUPPLY FAILURE
337	29-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDI	11:54	15:05	3:11	MAIN SUPPLY FAILURE
338	29-Nov-19	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	12:10	13:05	0:55	LINE FAULT
339	29-Nov-19	GULBARGA	220	HV2	HALBURGA_220	15:15	16:34	1:19	LINE CLEAR AVAILED
340	29-Nov-19	GULBARGA	110	LINGASUGUR-MUDAGAL	MUDAGAL_110	12:29	13:05	0:36	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
341	29-Nov-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATER	4:36	4:48	0:12	LINE FAULT
342	29-Nov-19	GULBARGA	110	SHAKTINAGAR-RAICHURBIO_IPP	SHAKTINAGAR_110	12:19	12:46	0:27	LINE FAULT
343	29-Nov-19	GULBARGA	110	HALBARGA--HALLIKED	HALIKHED_110	12:24	12:44	0:20	LINE CLEAR AVAILED
344	29-Nov-19	GULBARGA	110	HANUMSAGAR-KUSTAGI	HANUMSAGAR_110	19:55	20:00	0:05	HAND TRIPPED
345	29-Nov-19	GULBARGA	110	HANUMSAGAR-VARIKAL	HANUMSAGAR_110	19:10	20:05	0:55	HAND TRIPPED
346	29-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	5:32	5:32	HAND TRIPPED
347	29-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	10:58	23:59	13:01	HAND TRIPPED
348	29-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	15:35	18:27	2:52	LINE FAULT
349	29-Nov-19	HASSAN	220	HV1	MSEZ_220	10:15	14:22	4:07	LINE CLEAR AVAILED
350	29-Nov-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	15:35	18:27	2:52	LINE FAULT
351	29-Nov-19	HASSAN	110	LV1	MSEZ_220	10:13	14:23	4:10	LINE CLEAR AVAILED
352	29-Nov-19	HASSAN	110	BARANG-ANVATTI	BARANGI_110	10:05	16:25	6:20	LINE CLEAR AVAILED
353	29-Nov-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	10:04	14:52	4:48	LINE CLEAR AVAILED
354	29-Nov-19	HASSAN	110	HV2	KONAJE_110	9:32	16:55	7:23	LINE CLEAR AVAILED
355	29-Nov-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:01	9:03	0:02	HAND TRIPPED
356	29-Nov-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	14:56	14:58	0:02	HAND TRIPPED
357	29-Nov-19	HASSAN	110	HV2	NAVUNDA_110	9:37	11:15	1:38	LINE CLEAR AVAILED
358	29-Nov-19	HASSAN	110	HV2	PUTTUR_110	10:29	13:36	3:07	LINE CLEAR AVAILED
359	29-Nov-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:22	15:45	5:23	LINE CLEAR AVAILED
360	29-Nov-19	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	14:35	18:37	4:02	LINE CLEAR AVAILED
361	29-Nov-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	9:31	12:58	3:27	LINE CLEAR AVAILED
362	29-Nov-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	10:11	11:32	1:21	LINE CLEAR AVAILED
363	29-Nov-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	17:01	18:13	1:12	LOAD CURTAILMENT
364	29-Nov-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	18:28	18:29	0:01	LOAD CURTAILMENT
365	29-Nov-19	HASSAN	66	HV1	DODDAKADANUR_66	10:11	11:41	1:30	LINE CLEAR AVAILED
366	29-Nov-19	HASSAN	66	HV1	DODDAKADANUR_66	17:01	18:13	1:12	LOAD CURTAILMENT
367	29-Nov-19	HASSAN	66	HV1	DODDAKADANUR_66	18:25	18:26	0:01	LOAD CURTAILMENT
368	29-Nov-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	10:12	11:34	1:22	LOAD CURTAILMENT
369	29-Nov-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	17:02	18:14	1:12	LOAD CURTAILMENT
370	29-Nov-19	HASSAN	66	HV1	HIRISAVE_66	13:10	15:54	2:44	LINE CLEAR AVAILED
371	29-Nov-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	13:30	13:47	0:17	LINE FAULT
372	29-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:08	11:40	1:32	LINE CLEAR AVAILED
373	29-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	17:00	18:05	1:05	LINE CLEAR AVAILED
374	29-Nov-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	10:08	11:40	1:32	LINE CLEAR AVAILED
375	29-Nov-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	17:00	18:05	1:05	LINE CLEAR AVAILED
376	29-Nov-19	HASSAN	66	HV2	HNPURA_66	8:13	9:06	0:53	LINE CLEAR AVAILED
377	29-Nov-19	HASSAN	66	MALALI-CRPATNA	MALALI_66	18:25	18:45	0:20	HAND TRIPPED
378	29-Nov-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	3:47	4:00	0:13	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
379	29-Nov-19	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	17:58	18:05	0:07	LINE FAULT
380	29-Nov-19	MYSORE	66	KABBAHALLI-GUNDLUPETE	KABHALLY_66	21:01	21:17	0:15	LINE FAULT
381	29-Nov-19	MYSORE	66	HV1	HALAGUR_66	11:39	12:26	0:46	LINE CLEAR AVAIED
382	29-Nov-19	MYSORE	66	HV2	HALAGUR_66	10:00	11:40	1:40	LINE CLEAR AVAIED
383	29-Nov-19	MYSORE	66	KOLLEGALA-PARINAMIPURA	BGPURA_66, CHANDALLI_66, PARINAMIPUR	11:13	11:19	0:05	LINE FAULT
384	29-Nov-19	MYSORE	66	HV2	PANDAVAPURA_66	19:02	19:35	0:32	TRANSFORMER FAULT
385	29-Nov-19	MYSORE	66	HV1	SATHEGALA_66	13:48	14:38	0:49	LINE CLEAR AVAIED
386	29-Nov-19	MYSORE	66	HV1	SATHEGALA_66	15:43	15:56	0:13	HAND TRIPPED
387	29-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	9:57	10:29	0:32	LINE CLEAR AVAIED
388	29-Nov-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	12:02	12:13	0:11	LINE FAULT
389	29-Nov-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	16:12	17:11	0:58	LINE CLEAR AVAIED
390	29-Nov-19	TUMKUR	220	TR-3(HV SIDE)	DAVANGERE_SRS_220	10:48	14:44	3:56	TRANSFORMER FAULT
391	29-Nov-19	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	4:31	11:21	6:50	LINE FAULT
392	29-Nov-19	TUMKUR	220	TR-2	KBCROSS_220	12:24	15:42	3:18	TRANSFORMER FAULT
393	29-Nov-19	TUMKUR	110	TR-2	HULIYAR_110	16:10	16:24	0:13	LINE CLEAR AVAIED
394	29-Nov-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_1	10:45	12:21	1:35	LINE CLEAR AVAIED
395	29-Nov-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	12:23	15:42	3:19	TRANSFORMER FAULT
396	29-Nov-19	TUMKUR	110	TR-1	SHETYKERE_110	11:31	12:22	0:50	LINE CLEAR AVAIED
397	29-Nov-19	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	16:12	17:11	0:58	LINE CLEAR AVAIED
398	29-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	11:41	15:59	4:18	LINE CLEAR AVAIED
399	29-Nov-19	TUMKUR	66	TR-2	CHANNAGIRI_66	10:09	10:11	0:01	TRANSFORMER FAULT
400	29-Nov-19	TUMKUR	66	TR-2	CHANNAGIRI_66	16:10	16:19	0:09	TRANSFORMER FAULT
401	29-Nov-19	TUMKUR	66	TR-1	HIRIYUR_66	11:23	11:45	0:22	LINE CLEAR AVAIED
402	29-Nov-19	TUMKUR	66	TR-2	HULIYURDURGA_66	16:38	17:12	0:34	LINE CLEAR AVAIED
403	29-Nov-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	21:24	22:03	0:39	LINE FAULT
404	29-Nov-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	23:10	23:50	0:40	LINE FAULT
405	29-Nov-19	TUMKUR	66	TR-1	MATHOD_66	15:39	16:49	1:09	LINE CLEAR AVAIED
406	29-Nov-19	TUMKUR	66	TR-1& TR-2	NAGALMADIKE_66	16:41	16:49	0:08	LINE CLEAR AVAIED
407	29-Nov-19	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	16:44	16:48	0:03	LINE CLEAR AVAIED
408	29-Nov-19	TUMKUR	66	NAGALAMADIKE-SUNDER RAJU SOLAR_IPP_66	SUNDER RAJU SOLAR_IPP_66	16:40	16:50	0:10	LINE CLEAR AVAIED
409	29-Nov-19	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR_IPP_66	MUNIRAJ SOLAR_IPP_66	16:40	16:50	0:10	LINE CLEAR AVAIED
410	29-Nov-19	TUMKUR	66	NAGALAMADIKE- RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	16:40	16:50	0:10	LINE CLEAR AVAIED
411	29-Nov-19	TUMKUR	66	TR-2&TR-1	TUMKUR_66	11:42	11:45	0:03	HAND TRIPPED
412	29-Nov-19	TUMKUR	66	TR-2&TR-1	TUMKUR_66	17:40	17:44	0:03	HAND TRIPPED
413	29-Nov-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	21:25	21:42	0:16	HAND TRIPPED
414	29-Nov-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	23:13	23:51	0:38	HAND TRIPPED
415	29-Nov-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:32	10:46	0:13	HAND TRIPPED
416	29-Nov-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:37	15:49	0:11	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
417	29-Nov-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	21:26	21:42	0:16	HAND TRIPPED
418	29-Nov-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	23:13	23:51	0:38	HAND TRIPPED
419	29-Nov-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:32	10:46	0:14	HAND TRIPPED
420	29-Nov-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:46	10:47	0:01	HAND TRIPPED
421	29-Nov-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:32	10:44	0:11	HAND TRIPPED
422	29-Nov-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	21:25	21:42	0:16	HAND TRIPPED
423	29-Nov-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	23:12	23:51	0:38	HAND TRIPPED
424	29-Nov-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:32	10:48	0:15	HAND TRIPPED
425	29-Nov-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUV	21:25	21:36	0:10	HAND TRIPPED
426	29-Nov-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUV	23:12	23:51	0:38	HAND TRIPPED
427	30-Nov-19	BAGALKOT	110	110/11KV,HV1	ANANDANAGAR_110	15:58	16:18	0:20	MAIN SUPPLY FAILURE
428	30-Nov-19	BAGALKOT	110	110/11KV,HV2	ANANDANAGAR_110	15:58	16:18	0:20	MAIN SUPPLY FAILURE
429	30-Nov-19	BAGALKOT	110	HUBLI220-ANANDANAGAR	ANANDANAGAR_110	15:58	16:18	0:20	MAIN SUPPLY FAILURE
430	30-Nov-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	8:13	9:20	1:07	HAND TRIPPED
431	30-Nov-19	BAGALKOT	220	BELGAUM220-NARENDRA1	BELGAUM_220	5:02	6:36	1:34	LINE FAULT
432	30-Nov-19	BAGALKOT	110	GHATAPRABHA220-SHIRAGAON	SHIRAGAON_110	12:46	12:55	0:09	LINE FAULT
433	30-Nov-19	BAGALKOT	110	GHATAPRABHA220-SHIRAGAON	SHIRAGAON_110	13:10	14:02	0:52	LINE CLEAR AVAILED
434	30-Nov-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	11:19	21:15	9:56	LINE CLEAR AVAILED
435	30-Nov-19	BAGALKOT	110	110/11KV,HV1	YELPHARHATTI_110	13:52	13:59	0:07	LINE CLEAR AVAILED
436	30-Nov-19	BAGALKOT	110	110/11KV,HV2	YELPHARHATTI_110	13:47	13:50	0:03	LINE CLEAR AVAILED
437	30-Nov-19	BAGALKOT	220	220/110KV,HV2,LV2	ATHANI_220	15:08	16:30	1:22	LINE CLEAR AVAILED
438	30-Nov-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	8:08	9:07	0:59	LINE CLEAR AVAILED
439	30-Nov-19	BAGALKOT	110	RANEENNUR220-GUTTAL	GUTTAL_110	20:08	20:34	0:26	LINE FAULT
440	30-Nov-19	BAGALKOT	110	110/11KV,HV1	MUNDARGI_110	14:20	16:07	1:47	LINE CLEAR AVAILED
441	30-Nov-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	20:52	23:59	3:07	LINE CLEAR AVAILED
442	30-Nov-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	20:51	23:59	3:08	LINE CLEAR AVAILED
443	30-Nov-19	BENGALURU	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	0:00	0:06	0:06	LOAD CHANGE OVER
444	30-Nov-19	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	18:58	19:06	0:08	LOAD CHANGE OVER
445	30-Nov-19	BENGALURU	66	KANASWADI - YELAHANKA 220	KANASWADI	17:05	17:20	0:15	LINE FAULT
446	30-Nov-19	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	22:00	22:10	0:10	LOAD CHANGE OVER
447	30-Nov-19	BENGALURU	66	HV2	EPIP 220	9:40	17:15	7:35	LINE CLEAR AVAILED
448	30-Nov-19	BENGALURU	66	HV2	NRS 220	15:48	23:59	8:11	TRANSFORMER FAULT
449	30-Nov-19	BENGALURU	66	HV2	BAGHMANE TECH PARK	11:55	11:57	0:02	LINE CLEAR AVAILED
450	30-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	11:42	11:48	0:06	LINE CLEAR AVAILED
451	30-Nov-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	17:02	17:10	0:08	LINE CLEAR AVAILED
452	30-Nov-19	BENGALURU	66	HV3	EPIP 220	12:45	15:15	2:30	LINE CLEAR AVAILED
453	30-Nov-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	6:13	8:00	1:47	LINE FAULT
454	30-Nov-19	BENGALURU	66	KORMANGALA 220 - HAL 2	K & C VALLEY, NAL (EHT)	22:54	23:26	0:31	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
455	30-Nov-19	BENGALURU	66	KORMANGALA 220 - HAL 2	K & C VALLEY, NAL (EHT)	23:26	23:59	0:33	LINE FAULT
456	30-Nov-19	GULBARGA	220	220KV BUS	LINGASUGUR_220	1:10	1:25	0:15	TRANSFORMER FAULT
457	30-Nov-19	GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP	1:10	2:18	1:08	LINE FAULT
458	30-Nov-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	4:55	5:00	0:05	LINE FAULT
459	30-Nov-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	6:00	6:05	0:05	LINE FAULT
460	30-Nov-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	9:25	9:30	0:05	LINE FAULT
461	30-Nov-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	11:35	11:45	0:10	LINE FAULT
462	30-Nov-19	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	11:20	23:59	12:39	LINE CLEAR AVAILED
463	30-Nov-19	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	11:20	23:59	12:39	LINE CLEAR AVAILED
464	30-Nov-19	GULBARGA	110	SINDHANOOR-RAICHUR2	RAICHUR_220	18:05	18:17	0:12	LINE FAULT
465	30-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:57	12:03	2:06	HAND TRIPPED
466	30-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	0:48	0:48	HAND TRIPPED
467	30-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:18	23:59	6:41	HAND TRIPPED
468	30-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	1:50	15:43	13:53	LINE FAULT
469	30-Nov-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:48	13:33	3:45	LINE CLEAR AVAILED
470	30-Nov-19	HASSAN	220	HV2	MSEZ_220	9:41	14:40	4:59	LINE CLEAR AVAILED
471	30-Nov-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	1:50	15:43	13:53	LINE FAULT
472	30-Nov-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:48	13:33	3:45	NFBC ISSUED
473	30-Nov-19	HASSAN	110	HV2	ANANDAPURA_110	10:00	17:10	7:10	LINE CLEAR AVAILED
474	30-Nov-19	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	10:30	17:09	6:39	LINE CLEAR AVAILED
475	30-Nov-19	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	10:16	17:07	6:51	LINE CLEAR AVAILED
476	30-Nov-19	HASSAN	110	HV5	BAIKAMPADI_110	11:15	12:10	0:55	LINE CLEAR AVAILED
477	30-Nov-19	HASSAN	110	HV1	BAIKAMPADI_110	12:12	13:10	0:58	LINE CLEAR AVAILED
478	30-Nov-19	HASSAN	110	GAJNUR-SHIVAMOGGA	GAJNUR_110	9:35	13:15	3:40	LINE CLEAR AVAILED
479	30-Nov-19	HASSAN	110	GJNUR-IPP IC LINE	GAJNUR_110	13:40	14:30	0:50	HAND TRIPPED
480	30-Nov-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:42	12:54	2:12	LINE CLEAR AVAILED
481	30-Nov-19	HASSAN	110	HV2	KUNDAPURA_110	10:59	11:40	0:41	LINE CLEAR AVAILED
482	30-Nov-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	14:45	23:59	9:14	LINE CLEAR AVAILED
483	30-Nov-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	9:37	13:15	3:38	LINE CLEAR AVAILED
484	30-Nov-19	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:16	13:20	3:04	LINE CLEAR AVAILED
485	30-Nov-19	HASSAN	110	MRSSHM-SS2	MRSMSG_220	16:51	17:00	0:09	HAND TRIPPED
486	30-Nov-19	HASSAN	110	LV2	MSEZ_220	9:39	14:41	5:02	LINE CLEAR AVAILED
487	30-Nov-19	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:43	12:53	2:10	MAIN SUPPLY FAILURE
488	30-Nov-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:59	12:28	2:29	NFBC ISSUED
489	30-Nov-19	HASSAN	66	HV1	HIRISAVE_66	12:11	17:03	4:52	LINE CLEAR AVAILED
490	30-Nov-19	HASSAN	66	CHANNAR-SHETTHALLY	CHANNARAYAPATNA_66	11:05	15:05	4:00	LINE CLEAR AVAILED
491	30-Nov-19	HASSAN	66	CHANNAR-SHETTHALLY	CHANNARAYAPATNA_66	15:08	17:08	2:00	LINE CLEAR AVAILED
492	30-Nov-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	16:55	17:18	0:22	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
493	30-Nov-19	MYSORE	66	HV1	BANANGADI_66	9:05	11:10	2:05	LINE CLEAR AVAILED
494	30-Nov-19	MYSORE	66	HV2	PANDAVAPURA_66	11:06	13:08	2:01	LINE CLEAR AVAILED
495	30-Nov-19	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	13:29	13:56	0:27	HAND TRIPPED
496	30-Nov-19	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:29	15:19	1:50	HAND TRIPPED
497	30-Nov-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	13:28	13:57	0:29	HAND TRIPPED
498	30-Nov-19	TUMKUR	220	HIRIYUR 220kv- PGCIL	HIRIYUR_220	13:30	13:53	0:23	HAND TRIPPED
499	30-Nov-19	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	16:00	16:11	0:10	LINE FAULT
500	30-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA	15:16	17:10	1:54	LINE CLEAR AVAILED
501	30-Nov-19	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	14:47	14:53	0:05	LINE FAULT
502	30-Nov-19	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	6:00	6:11	0:11	MAIN SUPPLY FAILURE
503	30-Nov-19	TUMKUR	66	TR-2	CHANNAGIRI_66	17:01	17:11	0:09	TRANSFORMER FAULT
504	30-Nov-19	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	17:09	17:20	0:11	MAIN SUPPLY FAILURE
505	30-Nov-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	9:33	9:41	0:07	HAND TRIPPED
506	30-Nov-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:09	10:17	0:07	HAND TRIPPED
507	30-Nov-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	5:26	5:34	0:07	LINE FAULT
508	30-Nov-19	TUMKUR	66	TR-1	HDPURA_66	14:10	14:16	0:05	TRANSFORMER FAULT
509	30-Nov-19	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	7:29	21:55	14:26	HAND TRIPPED
510	30-Nov-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:26	13:59	0:32	HAND TRIPPED
511	30-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:27	13:59	0:31	HAND TRIPPED
512	30-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	13:27	14:06	0:38	HAND TRIPPED
513	30-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP1_IPP_66	13:27	14:05	0:38	HAND TRIPPED
514	30-Nov-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:47	10:56	0:09	HAND TRIPPED
515	30-Nov-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:27	13:59	0:32	HAND TRIPPED
516	30-Nov-19	TUMKUR	66	TR-2	HOSADURGA_66	7:43	7:52	0:08	TRANSFORMER FAULT
517	30-Nov-19	TUMKUR	66	TR-1	KATTIGE_66	4:26	4:32	0:06	TRANSFORMER FAULT
518	30-Nov-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:43	11:56	0:12	LINE FAULT
519	30-Nov-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	13:59	14:00	0:01	MAIN SUPPLY FAILURE
520	30-Nov-19	TUMKUR	66	TR-1	PANDARAHALLI_66	9:39	9:50	0:11	TRANSFORMER FAULT
521	30-Nov-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:58	16:21	0:23	HAND TRIPPED
522	30-Nov-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	21:02	21:49	0:47	LINE FAULT
523	30-Nov-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, B	5:31	5:52	0:20	LINE FAULT
524	30-Nov-19	TUMKUR	66	TR-1	LINGADAHALLY_66	10:56	18:17	7:20	LINE CLEAR AVAILED
525	30-Nov-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	0:02	0:10	0:07	LINE FAULT
526	30-Nov-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	1:32	1:48	0:16	LINE FAULT
527	30-Nov-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAP	2:28	2:47	0:19	LINE FAULT
528	30-Nov-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	5:27	5:39	0:12	MAIN SUPPLY FAILURE
529	30-Nov-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	5:27	5:38	0:11	MAIN SUPPLY FAILURE
530	1-Dec-19	BAGALKOT	110	110/11KV,HV1	BABLESHWARA_110	12:24	13:15	0:51	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
531	1-Dec-19	BAGALKOT	110	110/11KV,HV2	BABLESHWARA_110	12:24	13:15	0:51	TRANSFORMER FAULT
532	1-Dec-19	BAGALKOT	110	MAMADAPUR-BABLESHWARA	BABLESHWARA_110	12:24	13:15	0:51	LINE FAULT
533	1-Dec-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	19:00	23:59	4:59	HAND TRIPPED
534	1-Dec-19	BAGALKOT	110	BAGALKOT220-HUNGUND	HUNGUND_110	12:26	12:36	0:10	MAIN SUPPLY FAILURE
535	1-Dec-19	BAGALKOT	110	BAGALKOT220-HUNGUND	HUNGUND_110	12:45	13:10	0:25	MAIN SUPPLY FAILURE
536	1-Dec-19	BAGALKOT	110	110/11KV,HV1	YELPHARHATTI_110	12:29	13:00	0:31	LINE CLEAR AVAILED
537	1-Dec-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	12:52	14:27	1:35	LINE CLEAR AVAILED
538	1-Dec-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	17:43	17:49	0:06	TRANSFORMER FAULT
539	1-Dec-19	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	13:46	14:08	0:22	LINE CLEAR AVAILED
540	1-Dec-19	BENGALURU	66	HV3	YERANDANAHALLI 220	9:25	10:06	0:41	LINE CLEAR AVAILED
541	1-Dec-19	BENGALURU	66	HV1	YERANDANAHALLI 220	9:30	10:00	0:30	LOAD CHANGE OVER
542	1-Dec-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	10:03	19:50	9:47	LINE CLEAR AVAILED
543	1-Dec-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	10:35	19:16	8:41	LINE CLEAR AVAILED
544	1-Dec-19	BENGALURU	66	HV1	YERANDANAHALLI 220	19:40	19:50	0:10	LOAD CHANGE OVER
545	1-Dec-19	BENGALURU	66	HV3	YERANDANAHALLI 220	19:40	19:50	0:10	LOAD CHANGE OVER
546	1-Dec-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	10:18	10:30	0:12	LOAD CHANGE OVER
547	1-Dec-19	BENGALURU	66	HV2	SOMAYAJJANAHALLI	9:10	9:30	0:20	TRANSFORMER FAULT
548	1-Dec-19	BENGALURU	66	HV1	JIGANI 66	12:01	12:30	0:29	LOAD CHANGE OVER
549	1-Dec-19	BENGALURU	66	HV2	JIGANI 66	19:26	19:40	0:14	MAIN SUPPLY FAILURE
550	1-Dec-19	BENGALURU	66	HV3	JIGANI 66	19:26	19:40	0:14	MAIN SUPPLY FAILURE
551	1-Dec-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:05	11:12	0:07	LOAD CHANGE OVER
552	1-Dec-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:05	17:15	0:10	LOAD CHANGE OVER
553	1-Dec-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	15:04	15:37	0:33	LINE FAULT
554	1-Dec-19	BENGALURU	66	HV2	ATTUR YELAHANKA	20:16	20:20	0:03	LOAD CHANGE OVER
555	1-Dec-19	BENGALURU	66	HV2	ATTUR YELAHANKA	20:15	20:20	0:05	LOAD CHANGE OVER
556	1-Dec-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	22:50	22:53	0:03	LOAD CHANGE OVER
557	1-Dec-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	14:15	15:30	1:15	LINE FAULT
558	1-Dec-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	16:46	16:51	0:05	LOAD CHANGE OVER
559	1-Dec-19	BENGALURU	66	KUMBALAGODU - Kengeri SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT)	16:05	16:30	0:25	LOAD CHANGE OVER
560	1-Dec-19	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT)	11:30	11:53	0:23	LOAD CHANGE OVER
561	1-Dec-19	BENGALURU	66	BG ROAD - JIGANI 66	BG ROAD	15:05	15:10	0:05	LOAD CHANGE OVER
562	1-Dec-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	12:05	12:45	0:40	LINE CLEAR AVAILED
563	1-Dec-19	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	10:00	10:21	0:21	LINE CLEAR AVAILED
564	1-Dec-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:53	9:59	0:06	LINE FAULT
565	1-Dec-19	BENGALURU	66	KORMANGALA 220 - HAL 2	K & C VALLEY, NAL (EHT)	0:00	3:26	3:26	LINE FAULT
566	1-Dec-19	BENGALURU	66	KORMANGALA 220 - HAL 2	K & C VALLEY, NAL (EHT)	3:26	4:55	1:29	LINE FAULT
567	1-Dec-19	BENGALURU	66	KORMANGALA 220 - HAL 2	K & C VALLEY, NAL (EHT)	4:55	5:35	0:40	LINE FAULT
568	1-Dec-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:44	10:50	0:05	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
569	1-Dec-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	16:31	16:36	0:05	LOAD CHANGE OVER
570	1-Dec-19	BENGALURU	66	HV2	NANGALI	5:11	5:35	0:23	TRANSFORMER FAULT
571	1-Dec-19	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	0:00	13:20	13:20	LINE CLEAR AVAILED
572	1-Dec-19	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	0:00	13:20	13:20	LINE CLEAR AVAILED
573	1-Dec-19	GULBARGA	110	CHINCHOLI-SOLARWIND_IP[P	CHINCHOLI_110	7:15	9:45	2:30	LINE CLEAR AVAILED
574	1-Dec-19	GULBARGA	110	CHINCHOLI-CHETTINADSLR_IPP	CHINCHOLI_110	7:20	10:00	2:40	LINE CLEAR AVAILED
575	1-Dec-19	GULBARGA	110	HV1	HALBARGA_220	15:30	15:40	0:10	TRANSFORMER FAULT
576	1-Dec-19	GULBARGA	110	HV2	KAVITHAL_110	14:20	14:45	0:25	LINE CLEAR AVAILED
577	1-Dec-19	GULBARGA	110	ITTAGI-KOGALI	KOGALI_110	11:50	16:10	4:20	LINE CLEAR AVAILED
578	1-Dec-19	GULBARGA	110	KOGALI-KUDLIGI	KUDLIGI_110	11:50	16:10	4:20	LINE CLEAR AVAILED
579	1-Dec-19	GULBARGA	110	SINDHNOOR-NIRLOOPI_IPP	SINDHANOOR_220	10:05	15:30	5:25	LINE CLEAR AVAILED
580	1-Dec-19	GULBARGA	110	SINDHNOOR-NIRLOOPI_IPP	SINDHANOOR_220	23:45	23:55	0:10	LINE FAULT
581	1-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:08	23:59	7:51	HAND TRIPPED
582	1-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:58	6:58	HAND TRIPPED
583	1-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	13:16	23:59	10:43	HAND TRIPPED
584	1-Dec-19	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	10:11	10:39	0:28	LINE FAULT
585	1-Dec-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:10	10:40	0:30	LINE FAULT
586	1-Dec-19	HASSAN	110	HV1	BAIKAMPADI_110	9:59	11:38	1:39	LINE CLEAR AVAILED
587	1-Dec-19	HASSAN	110	HV2	BAIKAMPADI_110	9:59	11:39	1:40	LINE CLEAR AVAILED
588	1-Dec-19	HASSAN	110	HV5	BAIKAMPADI_110	9:59	11:39	1:40	LINE CLEAR AVAILED
589	1-Dec-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:15	10:25	0:10	LINE FAULT
590	1-Dec-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	12:16	13:24	1:08	LINE CLEAR AVAILED
591	1-Dec-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:27	12:30	0:03	LINE FAULT
592	1-Dec-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:45	12:50	0:05	LINE FAULT
593	1-Dec-19	HASSAN	66	HV2	CHIKMA	17:04	17:30	0:26	LINE CLEAR AVAILED
594	1-Dec-19	HASSAN	66	HV1	DUDDA_66	8:49	23:59	15:10	TRANSFORMER FAULT
595	1-Dec-19	HASSAN	66	HV2	UDAYAPURA_66	23:25	23:28	0:03	TRANSFORMER FAULT
596	1-Dec-19	MYSORE	66	HV1	HEBBAL_66	11:13	15:28	4:15	LINE CLEAR AVAILED
597	1-Dec-19	MYSORE	66	HV1	HDKOTE_66	12:55	13:35	0:40	HAND TRIPPED
598	1-Dec-19	MYSORE	66	HV2	HDKOTE_66	12:55	13:40	0:45	HAND TRIPPED
599	1-Dec-19	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66, DMG_HALLI_66, GVGUDI_66	10:33	10:42	0:09	LINE FAULT
600	1-Dec-19	MYSORE	66	SANTHESARGUR-B MATTGERE	B MATKERE_66	14:21	14:36	0:14	LINE FAULT
601	1-Dec-19	MYSORE	66	SANTHESARGUR-B MATTGERE	B MATKERE_66	14:36	17:26	2:50	LINE FAULT
602	1-Dec-19	MYSORE	66	HV1	SANTHESARAGUR_66	18:28	18:45	0:17	TRANSFORMER FAULT
603	1-Dec-19	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	21:39	21:49	0:10	LINE FAULT
604	1-Dec-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	18:29	18:46	0:17	LINE FAULT
605	1-Dec-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	6:55	7:04	0:08	LINE FAULT
606	1-Dec-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:08	16:03	5:54	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
607	1-Dec-19	TUMKUR	66	TR-1	KATTIGE_66	22:36	22:45	0:09	TRANSFORMER FAULT
608	1-Dec-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	6:55	7:13	0:18	MAIN SUPPLY FAILURE
609	1-Dec-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	7:01	7:12	0:11	MAIN SUPPLY FAILURE
610	1-Dec-19	TUMKUR	66	TR-1	MADHUGIRI_66	15:36	16:02	0:26	LINE CLEAR AVAILED
611	1-Dec-19	TUMKUR	66	TR-2	MANGALWADA_66	14:10	14:16	0:06	TRANSFORMER FAULT
612	2-Dec-19	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	10:00	23:59	13:59	LINE FAULT
613	2-Dec-19	BAGALKOT	110	GHATAPRABHA-MANTUR	MANTUR_110	20:48	21:15	0:27	LINE FAULT
614	2-Dec-19	BAGALKOT	110	MK HUBLI-HIREBAGEWADI	HIREBAGEWADI_110	0:00	7:10	7:10	LINE CLEAR AVAILED
615	2-Dec-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	7:12	7:12	LINE CLEAR AVAILED
616	2-Dec-19	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	14:34	21:54	7:20	NFBC ISSUED
617	2-Dec-19	BAGALKOT	110	110/33KV,HV3	MAMDAPUR(B)_110,LINGADALLI_33,DEVAR	12:50	12:57	0:07	TRANSFORMER FAULT
618	2-Dec-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	12:56	13:02	0:06	LOAD CHANGE OVER
619	2-Dec-19	BENGALURU	66	HV1	BRINDAVANA	18:07	18:35	0:28	LINE CLEAR AVAILED
620	2-Dec-19	BENGALURU	66	HV2	HOSKOTE 66	11:01	11:39	0:38	LINE CLEAR AVAILED
621	2-Dec-19	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA,NATIONAL COLLEGE,PADMAN	15:25	15:28	0:03	LINE FAULT
622	2-Dec-19	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA,NATIONAL COLLEGE,PADMAN	15:39	15:49	0:10	LINE FAULT
623	2-Dec-19	BENGALURU	66	MALUR - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI,	15:10	18:51	3:41	LINE FAULT
624	2-Dec-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:20	18:51	1:31	LINE CLEAR AVAILED
625	2-Dec-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	11:07	11:30	0:23	LINE FAULT
626	2-Dec-19	BENGALURU	66	HV2	YELAHANKA 220	10:57	10:59	0:02	LINE CLEAR AVAILED
627	2-Dec-19	BENGALURU	66	HV1	MUDIYANUR	8:15	8:37	0:22	TRANSFORMER FAULT
628	2-Dec-19	GULBARGA	220	RTPS-SHAHPUR2	SHAHPUR_220	5:24	9:14	3:50	LINE FAULT
629	2-Dec-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	13:16	20:53	7:37	LINE CLEAR AVAILED
630	2-Dec-19	GULBARGA	220	HUMNB 220 -HALBURGA 1	HALBARGA_220	20:23	23:59	3:36	HAND TRIPPED
631	2-Dec-19	GULBARGA	220	HUMNB 220 -HALBURGA 1	HALBARGA_220	0:00	6:38	6:38	LINE CLEAR AVAILED
632	2-Dec-19	GULBARGA	110	SINDHNOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATER	2:25	2:32	0:07	LINE FAULT
633	2-Dec-19	GULBARGA	110	SINDHNOOR220-RAICHUR2	MANVI_110,MADALAPURA_110,KURDICROS	6:00	6:20	0:20	LINE FAULT
634	2-Dec-19	GULBARGA	110	SINDHNOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	6:25	13:20	6:55	LINE CLEAR AVAILED
635	2-Dec-19	GULBARGA	110	HV1	KAVITAL_110	13:45	13:50	0:05	TRANSFORMER FAULT
636	2-Dec-19	GULBARGA	220	RTPS-SHAHPUR2	SHAHPUR_220	5:24	9:14	3:50	LINE FAULT
637	2-Dec-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	13:16	20:53	7:37	LINE CLEAR AVAILED
638	2-Dec-19	GULBARGA	220	HUMNB 220 -HALBURGA 1	HALBARGA_220	20:23	23:59	3:36	HAND TRIPPED
639	2-Dec-19	GULBARGA	110	SINDHNOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATER	2:25	2:32	0:07	LINE FAULT
640	2-Dec-19	GULBARGA	110	SINDHNOOR220-RAICHUR2	MANVI_110,MADALAPURA_110,KURDICROS	6:00	6:20	0:20	LINE FAULT
641	2-Dec-19	GULBARGA	110	SINDHNOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	6:25	13:20	6:55	LINE CLEAR AVAILED
642	2-Dec-19	GULBARGA	110	HV1	KAVITAL_110	13:45	13:50	0:05	TRANSFORMER FAULT
643	2-Dec-19	GULBARGA	110	HV1	KAVITAL_110	13:55	14:00	0:05	TRANSFORMER FAULT
644	2-Dec-19	GULBARGA	110	HV1	KAVITAL_110	14:20	14:30	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
645	2-Dec-19	GULBARGA	110	HV1	KUDITINI_110	10:59	13:58	2:59	TRANSFORMER FAULT
646	2-Dec-19	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110,TORANGALLU_110,METRI_110	11:00	12:05	1:05	LINE FAULT
647	2-Dec-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	6:24	6:40	0:16	LINE FAULT
648	2-Dec-19	GULBARGA	110	RAJESHWAR-WARADA SOLAR	WARADA SOLAR_110	18:53	23:59	5:06	LINE CLEAR AVAILED
649	2-Dec-19	GULBARGA	66	ITTAGI-HADAGALLI1	HIREHADAGALI_66	7:01	7:08	0:07	LINE FAULT
650	2-Dec-19	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	16:05	23:59	7:54	LINE FAULT
651	2-Dec-19	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHPUR_110	23:55	23:59	0:04	LINE FAULT
652	2-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	8:18	8:18	HAND TRIPPED
653	2-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:08	23:59	0:51	HAND TRIPPED
654	2-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:55	6:55	HAND TRIPPED
655	2-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:29	23:59	1:30	HAND TRIPPED
656	2-Dec-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	2:56	7:46	4:50	LINE FAULT
657	2-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY	MRSMSG_220	10:52	13:38	2:46	LINE FAULT
658	2-Dec-19	HASSAN	220	HV2	MSEZ_220	9:47	14:02	4:15	LINE CLEAR AVAILED
659	2-Dec-19	HASSAN	110	LV2	MSEZ_220	9:45	14:04	4:19	LINE CLEAR AVAILED
660	2-Dec-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	5:21	23:59	18:38	LINE FAULT
661	2-Dec-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:20	15:20	4:00	LINE CLEAR AVAILED
662	2-Dec-19	HASSAN	110	HV1	ANAVATTI_110	11:21	15:21	4:00	LINE CLEAR AVAILED
663	2-Dec-19	HASSAN	110	HV2	ANAVATTI_110	11:21	15:21	4:00	LINE CLEAR AVAILED
664	2-Dec-19	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	8:25	10:07	1:42	LINE CLEAR AVAILED
665	2-Dec-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	9:12	17:12	8:00	LINE CLEAR AVAILED
666	2-Dec-19	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	15:16	15:30	0:14	LINE FAULT
667	2-Dec-19	HASSAN	66	HV1	DUDDA_66	0:00	13:31	13:31	TRANSFORMER FAULT
668	2-Dec-19	HASSAN	66	HV2	HIRISAVE_66	13:25	15:53	2:28	LINE CLEAR AVAILED
669	2-Dec-19	HASSAN	66	HV1	HOLALUR_66	8:45	9:05	0:20	LOAD CURTAILMENT
670	2-Dec-19	MYSORE	66	CHIKKMANDYA-HAMPAPURA	BESAGARAHALLI_66, HAMPAPURA_66, KOPPE	2:29	3:12	0:43	LINE FAULT
671	2-Dec-19	MYSORE	66	HV1	SANTHEBACHALLI_66	13:45	15:10	1:25	LINE CLEAR AVAILED
672	2-Dec-19	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	15:34	17:03	1:28	LINE CLEAR AVAILED
673	2-Dec-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:12	16:56	1:43	HAND TRIPPED
674	2-Dec-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	2:56	7:45	4:49	LINE FAULT
675	2-Dec-19	TUMKUR	110	TR-1	BANDIHALLI_110	13:08	14:01	0:52	LINE CLEAR AVAILED
676	2-Dec-19	TUMKUR	110	TR-2	BANDIHALLI_110	14:01	14:22	0:20	LINE CLEAR AVAILED
677	2-Dec-19	TUMKUR	110	TR-1	GUBBI_110	18:21	18:51	0:29	TRANSFORMER FAULT
678	2-Dec-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	3:11	3:20	0:08	LINE FAULT
679	2-Dec-19	TUMKUR	66	TR-1(HV SIDE)	ANCHEPALYA_220	15:34	17:06	1:31	LINE CLEAR AVAILED
680	2-Dec-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:37	14:51	3:13	LINE CLEAR AVAILED
681	2-Dec-19	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	17:16	17:23	0:07	LINE FAULT
682	2-Dec-19	TUMKUR	66	TR-1	CHANNAGIRI_66	14:06	14:27	0:21	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
683	2-Dec-19	TUMKUR	66	TR-1	CHANNAGIRI_66	16:45	16:58	0:12	TRANSFORMER FAULT
684	2-Dec-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:05	14:27	0:21	LINE FAULT
685	2-Dec-19	TUMKUR	66	GULIGENAHALLI- SIRA 2	SIRA_66	5:30	5:35	0:05	LINE FAULT
686	2-Dec-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EH	11:12	11:32	0:20	LINE FAULT
687	2-Dec-19	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	11:43	14:34	2:50	LINE CLEAR AVAILED