

400/220/110/66 kV TRANSMISSION OUTAGES FROM 19.01.21 TO 25.01.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	19-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	19-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
3	19-Jan-21	BAGALKOT	110	110/33KV,HV2	HUBLI_220	9:56	18:09	8:13	LINE CLEAR AVOIDED
4	19-Jan-21	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_33, KARADI_33,MYTRA SOLAR_33	21:32	21:39	0:07	TRANSFORMER FAULT
5	19-Jan-21	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	21:10	21:22	0:12	LINE FAULT
6	19-Jan-21	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	03:52	04:11	0:19	LINE FAULT
7	19-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
8	19-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
9	19-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
10	19-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
11	19-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED
12	19-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
13	19-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
14	19-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
15	19-Jan-21	BAGALKOT	110	MANTUR(C)-TBS IPP	MANTUR(C)_110, TBS IPP_110	18:40	20:40	2:00	LINE CLEAR AVOIDED
16	19-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
17	19-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
18	19-Jan-21	BAGALKOT	220	220/110KV,HV1,LV1	GADAG_220	10:19	11:35	1:16	LINE CLEAR AVOIDED
19	19-Jan-21	BAGALKOT	220	220/110KV,HV2,LV2	GADAG_220	11:38	17:47	6:09	LINE CLEAR AVOIDED
20	19-Jan-21	BAGALKOT	220	ATHANI-KUDACHI	STATION NOT AFFECTED ATHANI_220	8:53 (19.01.2021)			LINE OPEN:LINE CLEAR AVAILED
21	19-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
22	19-Jan-21	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	10:54	16:31	5:37	LINE CLEAR AVOIDED
23	19-Jan-21	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
24	19-Jan-21	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
25	19-Jan-21	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	16:10	16:16	00:05	LINE FAULT
26	19-Jan-21	BENGALURU	66	HV1	MITTEMARI 220	18:30	18:46	00:16	TRANSFORMER FAULT
27	19-Jan-21	BENGALURU	66	HV2	KADUBISANAHALLI	16:50	17:21	00:31	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
28	19-Jan-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	22:20	22:25	00:05	LOAD CHANGE OVER
29	19-Jan-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	11:10	11:40	00:30	LOAD CHANGE OVER
30	19-Jan-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	15:39	15:42	00:03	LOAD CHANGE OVER
31	19-Jan-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	22:07	22:12	00:05	LOAD CHANGE OVER
32	19-Jan-21	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPURA_66,MAGALA_66,TBPCL IPP	15:37	15:39	00:02	LINE FAULT
33	19-Jan-21	GULBARGA	66	ITTAGI-SUZLON1	ITTAGI_220	10:45	10:48	00:03	LINE FAULT
34	19-Jan-21	GULBARGA	66	ITTAGI-SUZLON1	ITTAGI_220	15:37	15:39	00:02	LINE FAULT
35	19-Jan-21	GULBARGA	110	HV2	HATTI	17:14	17:41	00:27	LINE CLEAR AVAILED
36	19-Jan-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	06:12	06:22	00:10	LINE FAULT
37	19-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	01:57	02:07	00:10	LINE FAULT
38	19-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	02:30	02:39	00:09	LINE FAULT
39	19-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	03:25	03:32	00:07	LINE FAULT
40	19-Jan-21	GULBARGA	110	MALLAT-LINGSUGUR	MALLAT_220	02:29	02:55	00:26	LINE FAULT
41	19-Jan-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRNAGAR_110,MALLAPURA_110	15:20	18:20	03:00	LINE FAULT
42	19-Jan-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRNAGAR_110,MALLAPURA_110	18:20	22:00	03:40	LINE CLEAR AVAILED
43	19-Jan-21	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	NIRLOOTI_IPP	19:10	19:40	00:30	LINE FAULT
44	19-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	22:07	22:09	00:02	MAIN SUPPLY FAILURE
45	19-Jan-21	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	07:26	07:40	00:14	LINE FAULT
46	19-Jan-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	21:32	22:01	00:29	LINE FAULT
47	19-Jan-21	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	07:34	08:16	00:42	LINE CLEAR AVAILED
48	19-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
49	19-Jan-21	HASSAN	66	HV1	MATTANAVILE_66	15:05	17:10	02:05	LINE CLEAR AVAILED
50	19-Jan-21	HASSAN	66	HV2	BELUR_66	12:23	12:47	00:24	LINE CLEAR AVAILED
51	19-Jan-21	HASSAN	66	HV2	MAGGE_66	07:43	09:09	01:26	LINE CLEAR AVAILED
52	19-Jan-21	HASSAN	66	HV2	SALGAME_66	15:08	16:19	01:11	LINE CLEAR AVAILED
53	19-Jan-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
54	19-Jan-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
55	19-Jan-21	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLY_66	07:34	08:16	00:42	MAIN SUPPLY FAILURE
56	19-Jan-21	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:38	14:00	03:22	LINE CLEAR AVAILED
57	19-Jan-21	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
58	19-Jan-21	HASSAN	110	HV2	BAIKAMPADY_110	12:15	13:01	00:46	LINE CLEAR AVAILED
59	19-Jan-21	HASSAN	110	HV2	KARAYA_110	11:53	13:28	01:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
60	19-Jan-21	HASSAN	110	HV2	KONAJE_110	09:50	17:29	07:39	LINE CLEAR AVAILED
61	19-Jan-21	HASSAN	110	HV2	SAGARA_110	15:22	16:12	00:50	LINE CLEAR AVAILED
62	19-Jan-21	HASSAN	110	KADUR-TNGL	KADUR_220	09:59	10:27	00:28	HAND TRIPPED
63	19-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
64	19-Jan-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:16	15:18	05:02	LINE CLEAR AVAILED
65	19-Jan-21	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	12:49	13:45	00:56	LINE CLEAR AVAILED
66	19-Jan-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	22:42 (18.01.2021)	11:46 (19.01.2021)	13:04hrs	LINE CHARGED
67	19-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:16	15:18	05:02	LINE CLEAR AVAILED
68	19-Jan-21	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:49	13:45	00:56	NFBC ISSUED
69	19-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)	10:17 (19.01.2021)	325:28hrs	LINE CHARGED
70	19-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:45 (19.01.2021)			LINE OPEN:LINE CLEAR AVAILED
71	19-Jan-21	MYSORE	66	BHERYA-KR NAGARA	BHERYA_66	10:05	17:30	7:25	LINE CLEAR AVAILED
72	19-Jan-21	MYSORE	66	HV1	KIKKERI_66	11:15	16:31	5:16	LINE CLEAR AVAILED
73	19-Jan-21	MYSORE	66	HV1	PONNAMPET_66	16:17	16:36	0:19	TRANSFORMER FAULT
74	19-Jan-21	MYSORE	66	HV2	MALAVALLI_66	10:44	17:57	7:13	LINE CLEAR AVAILED
75	19-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED
76	19-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
77	19-Jan-21	MYSORE	66	KR NAGARA-BILIKERE	NO STATION EFFECTED	10:30	13:45	3:15	LINE CLEAR AVAILED
78	19-Jan-21	MYSORE	66	KR NAGARA-MYSORE 1	KRNAGARA_66	10:30	13:45	3:15	LINE CLEAR AVAILED
79	19-Jan-21	MYSORE	66	KR NAGARA-MYSORE 2	KRNAGARA_66	10:30	14:20	3:50	LINE CLEAR AVAILED
80	19-Jan-21	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	10:36	10:43	0:07	LINE FAULT
81	19-Jan-21	MYSORE	66	MIRLE-MYSORE 1	MIRLE_66	10:40	15:30	4:50	LINE CLEAR AVAILED
82	19-Jan-21	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	15:41	15:52	0:11	LINE FAULT
83	19-Jan-21	MYSORE	220	HV1	MADHUVANAHALLI_220	10:10	13:36	3:26	LINE CLEAR AVAILED
84	19-Jan-21	MYSORE	220	HV2	KUSHALNAGARA_220	13:03	17:21	4:18	LINE CLEAR AVAILED
85	19-Jan-21	MYSORE	220	HV2	MADHUVANAHALLI_220	13:42	17:35	3:53	LINE CLEAR AVAILED
86	19-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:16	12:01	1:44	LINE CLEAR AVAILED
87	19-Jan-21	TUMKUR	66	BRAHMASANDRA-SIRA(KALLAMBELLA)	BRAHMASANDRA_66	22:49	23:09	0:19	LINE FAULT
88	19-Jan-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:26	14:33	0:07	HAND TRIPPED
89	19-Jan-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:13	14:26	0:13	LINE FAULT
90	19-Jan-21	TUMKUR	66	TR-1	BRAHMASANDRA_66	10:24	11:18	0:53	LINE CLEAR AVAILED
91	19-Jan-21	TUMKUR	66	TR-1	HULIYURDURGA_66	10:34	18:39	8:04	LINE CLEAR AVAILED
92	19-Jan-21	TUMKUR	66	TR-1	IDHALLY_66	13:00	13:34	0:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
93	19-Jan-21	TUMKUR	66	TR-2	CHANNAGIRI_66	13:06	13:09	0:03	TRANSFORMER FAULT
94	19-Jan-21	TUMKUR	66	TR-2	HALURAMESHWARA_66	10:03	10:35	0:31	TRANSFORMER FAULT
95	19-Jan-21	TUMKUR	66	TR-2	IDHALLY_66	12:28	12:56	0:27	LINE CLEAR AVAILED
96	19-Jan-21	TUMKUR	66	TR-2	KUKKAWADA_66	11:24	11:47	0:23	TRANSFORMER FAULT
97	19-Jan-21	TUMKUR	66	TR-2	THALLAKK_220	15:36	17:50	2:13	LINE CLEAR AVAILED
98	19-Jan-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:58	15:35	0:37	LINE CLEAR AVAILED
99	19-Jan-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	15:00	15:35	0:35	LINE CLEAR AVAILED
100	19-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE OPEN:LINE CLEAR AVAILED
101	19-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
102	20-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
103	20-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
104	20-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
105	20-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
106	20-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED
107	20-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
108	20-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
109	20-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
110	20-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
111	20-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
112	20-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
113	20-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
114	20-Jan-21	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
115	20-Jan-21	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
116	20-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
117	20-Jan-21	BAGALKOT	220	ATHANI-KUDACHI	STATION NOT AFFECTED ATHANI_220	8:53 (19.01.2021)	18:05 (20.01.2021)	33:12hrs	LINE CHARGED
118	20-Jan-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	17:50	17:58	0:08	LOAD CURTAILMENT
119	20-Jan-21	BAGALKOT	110	ALABAL-SAIPRIYA SUGERS	ALABAL_110, SAIPRIYA SUGERS_110	19:11	19:25	0:14	LINE FAULT
120	20-Jan-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ATHARGA_110	17:51	18:00	0:09	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
121	20-Jan-21	BAGALKOT	110	BELGAUM220- VADAGOAN	STATION NOT AFFECTED VADAGOAN_110	17:17	20:31	3:14	LINE CLEAR AVOIDED
122	20-Jan-21	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	15:56	20:27	4:31	LINE FAULT
123	20-Jan-21	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220, SOUDATTI_110, BENAKATTI_110, UDIKERI_110, YARGATTI_110, MUNVALLY_110, RAMDURGA_110, MMCL_110	15:56	16:23	0:27	TRANSFORMER FAULT
124	20-Jan-21	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220, SOUDATTI_110, BENAKATTI_110, UDIKERI_110, YARGATTI_110, MUNVALLY_110, RAMDURGA_110, MMCL_110	15:56	16:24	0:28	TRANSFORMER FAULT
125	20-Jan-21	BAGALKOT	110	SOUDATTI-ENERCON2	SOUDATTI_110	15:58	16:50	0:52	LINE CLEAR AVOIDED
126	20-Jan-21	BAGALKOT	110	SOUDATTI-ENERCON1	SOUDATTI_110	16:11	16:50	0:39	LINE CLEAR AVOIDED
127	20-Jan-21	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,HIREPADASALAGI LIS_33,TUNGAL LIS_33,KALABILAGI_33	17:51	18:20	0:29	LOAD CURTAILMENT
128	20-Jan-21	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	10:05	16:58	6:53	LINE CLEAR AVOIDED
129	20-Jan-21	BAGALKOT	110	NARENDRA-BELUR2	STATION NOT AFFECTED BELUR_110	10:56	12:28	1:32	LINE CLEAR AVOIDED
130	20-Jan-21	BAGALKOT	110	TBS-MANTUR(C)	MANTUR(C)_110	18:10	22:50	4:40	LINE CLEAR AVOIDED
131	20-Jan-21	BAGALKOT	110	110/11KV,HV1	KULIGERE CROSS_110	12:08	12:29	0:21	LINE CLEAR AVOIDED
132	20-Jan-21	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	17:50	17:55	0:05	LOAD CURTAILMENT
133	20-Jan-21	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMI NAGAD_33,MYTRA SOLAR_33	21:08	21:16	0:08	TRANSFORMER FAULT
134	20-Jan-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,M YTRA SOLAR_33	17:50	18:07	0:17	LOAD CURTAILMENT
135	20-Jan-21	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	17:51	17:58	0:07	LOAD CURTAILMENT
136	20-Jan-21	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	17:50	18:05	0:15	LOAD CURTAILMENT
137	20-Jan-21	BAGALKOT	220	220/110KV,HV2,LV2	NO STATION AFFECTED GADAG_220	10:22	18:14	7:52	LINE CLEAR AVOIDED
138	20-Jan-21	BAGALKOT	220	SOUDATTI-BIDNAL	NO STATION AFFECTED BIDNAL_220	15:57	20:27	4:30	LINE FAULT
139	20-Jan-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	NO STATION AFFECTED AMBEWADI_220	13:46 (19.01.2021)	17:22 (20.01.2021)	27:36hrs	LINE CHARGED
140	20-Jan-21	BENGALURU	66	HV3	A STATION 66	15:36	15:44	00:08	TRANSFORMER FAULT
141	20-Jan-21	BENGALURU	66	BYADRAHALLI - T G HALLI	KODIGENAHALLI, TAVAREKERE	12:23	13:39	01:16	LINE FAULT
142	20-Jan-21	BENGALURU	66	HAL 220 - HOODY 2	NO STATION AFFECTED	12:33	14:36	02:03	LINE FAULT
143	20-Jan-21	BENGALURU	66	HAL 220 - HOODY 1	BAGHMANE TECH PARK	14:36	15:35	00:59	LINE CLEAR AVOIDED
144	20-Jan-21	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	12:56	13:16	00:20	LINE FAULT
145	20-Jan-21	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	12:33	12:55	00:22	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
146	20-Jan-21	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	15:00	15:10	00:10	LOAD CHANGE OVER
147	20-Jan-21	BENGALURU	66	HV2	KADUBISANAHALLI	15:10	15:57	00:47	LINE CLEAR AVAILED
148	20-Jan-21	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	12:30	12:36	00:06	LOAD CHANGE OVER
149	20-Jan-21	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	14:04	14:10	00:06	LOAD CHANGE OVER
150	20-Jan-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	17:24	17:38	00:14	LINE FAULT
151	20-Jan-21	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	BRIGADE METROPOLIS	13:22	13:26	00:04	LOAD CHANGE OVER
152	20-Jan-21	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	14:12	14:20	00:08	LOAD CHANGE OVER
153	20-Jan-21	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	08:59	09:05	00:06	LINE FAULT
154	20-Jan-21	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	09:22	09:27	00:05	LOAD CHANGE OVER
155	20-Jan-21	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	14:46	14:56	00:10	LOAD CHANGE OVER
156	20-Jan-21	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	16:14	16:39	00:25	MAIN SUPPLY FAILURE
157	20-Jan-21	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	16:39	16:41	00:01	MAIN SUPPLY FAILURE
158	20-Jan-21	BENGALURU	66	DOMMASANDRA - CHANDAPURA	DOMMASANDRA	12:19	12:30	00:10	LOAD CHANGE OVER
159	20-Jan-21	BENGALURU	66	SRINIVASPURA - CHINTAMANI	SRINIVASPURA	16:15	16:40	00:25	MAIN SUPPLY FAILURE
160	20-Jan-21	BENGALURU	66	SRINIVASPURA - CHINTAMANI	SRINIVASPURA	18:45	19:08	00:23	MAIN SUPPLY FAILURE
161	20-Jan-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	08:59	09:10	00:11	MAIN SUPPLY FAILURE
162	20-Jan-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	09:52	09:55	00:03	LOAD CHANGE OVER
163	20-Jan-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	09:14	09:58	00:44	LOAD CHANGE OVER
164	20-Jan-21	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	06:52	07:08	00:15	LINE FAULT
165	20-Jan-21	BENGALURU	66	HV1	KGF	12:23	13:15	00:51	LINE CLEAR AVAILED
166	20-Jan-21	BENGALURU	66	HV1	SADLI	14:05	14:09	00:04	TRANSFORMER FAULT
167	20-Jan-21	BENGALURU	66	HV1	WEL CAST STEEL	13:05	14:38	01:33	LINE CLEAR AVAILED
168	20-Jan-21	BENGALURU	66	HV2	WEL CAST STEEL	13:05	14:38	01:33	LINE CLEAR AVAILED
169	20-Jan-21	GULBARGA	220	LINGAPUR-JVSL-1	LINGAPUR_220	09:04	14:24	05:20	NFBC ISSUED
170	20-Jan-21	GULBARGA	220	MALLT-RTPS	MALLT_220	08:55	16:40	07:45	LINE CLEAR AVAILED
171	20-Jan-21	GULBARGA	220	RTPS-LINGSUGUR3	LINGSUGUR_220	04:38	05:16	00:38	LINE FAULT
172	20-Jan-21	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	06:12	06:38	00:26	LINE FAULT
173	20-Jan-21	GULBARGA	220	HV1	SHAHAPUR_220	15:15	16:32	01:17	LINE CLEAR AVAILED
174	20-Jan-21	GULBARGA	220	RTPS-LGSUR3	LINGSUGUR_220	08:53	17:30	08:37	NFBC ISSUED
175	20-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	02:40	02:50	00:10	LINE FAULT
176	20-Jan-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	03:02	03:10	00:08	LINE FAULT
177	20-Jan-21	GULBARGA	110	HV2	GINIGERA_110	11:25	12:55	01:30	LINE CLEAR AVAILED
178	20-Jan-21	GULBARGA	110	HALIKHED-HALBARGA	HALIKHED_110	13:45	14:00	00:15	LINE FAULT
179	20-Jan-21	GULBARGA	110	HV2	CHINCHOLI_110	17:50	18:00	00:10	LOAD CURTAILMENT
180	20-Jan-21	GULBARGA	110	HV2	HATTI_110	17:50	17:55	00:05	LOAD CURTAILMENT
181	20-Jan-21	GULBARGA	110	HV3	HANUMASAGAR_110	17:50	18:00	00:10	LOAD CURTAILMENT
182	20-Jan-21	GULBARGA	110	HV2	JEWARGI_110	17:50	18:24	00:34	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
183	20-Jan-21	GULBARGA	110	HV3	KAMPLI_GLB_110	17:50	18:16	00:26	LOAD CURTAILMENT
184	20-Jan-21	GULBARGA	110	HV1	RAJESHWAR_110	17:49	18:01	00:12	LOAD CURTAILMENT
185	20-Jan-21	GULBARGA	110	HV2	RAJESHWAR_110	17:49	17:55	00:06	LOAD CURTAILMENT
186	20-Jan-21	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110	6:30(20.01.2021)			LINE OPEN:LINE FAULT
187	20-Jan-21	GULBARGA	110	SINDHANOOR-RAICHUR2	VALKAMDINNI_110	07:05	07:12	00:07	LINE FAULT
188	20-Jan-21	GULBARGA	110	SINDHANOOR-RAICHUR2	VALKAMDINNI_110	07:28	08:35	01:07	LINE FAULT
189	20-Jan-21	GULBARGA	110	HV1	SIRWAR_110	17:50	17:55	00:05	TRANSFORMER FAULT
190	20-Jan-21	GULBARGA	110	HV1	TEKKALKOTE_110	17:49	18:15	00:26	LOAD CURTAILMENT
191	20-Jan-21	GULBARGA	110	HV1,HV2	VENKATAGIRI_110	15:00	15:20	00:20	LINE CLEAR AVAILED
192	20-Jan-21	GULBARGA	110	HV1	VENKATAGIRI_110	17:50	17:55	00:05	TRANSFORMER FAULT
193	20-Jan-21	GULBARGA	110	HV1	YELBURGA_110	11:06	18:06	07:00	LINE CLEAR AVAILED
194	20-Jan-21	GULBARGA	110	HV1	YELBURGA_110	19:42	20:00	00:18	TRANSFORMER FAULT
195	20-Jan-21	GULBARGA	110	MALLT-KAVITHAL	KAVITHAL_110	23:07	23:17	00:10	LINE FAULT
196	20-Jan-21	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:51	19:14	00:23	LINE CLEAR AVAILED
197	20-Jan-21	GULBARGA	110	SHAHPUR-KEMBHAVI 2	KBJNL_110	21:12	21:22	00:10	LINE FAULT
198	20-Jan-21	GULBARGA	110	SHAHPUR-KEMBHAVI 2	KBJNL_110	21:35	21:50	00:15	LINE FAULT
199	20-Jan-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
200	20-Jan-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
201	20-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
202	20-Jan-21	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
203	20-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
204	20-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:45 (19.01.2021)	7:09 (20.01.2021)	9:24hrs	LINE CHARGED
205	20-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:42 (20.01.2021)			LINE OPEN:LINE CLEAR AVAILED
206	20-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	22:08(20.1.2021)			LINE OPEN:LINE FAULT
207	20-Jan-21	HASSAN	220	HV2	KAVOOR_220	10:28	15:08	04:40	LINE CLEAR AVAILED
208	20-Jan-21	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:27	15:32	05:05	LINE CLEAR AVAILED
209	20-Jan-21	HASSAN	110	LV2	KAVOOR_220	10:28	15:07	04:39	LINE CLEAR AVAILED
210	20-Jan-21	HASSAN	110	KAVOOR-BEJAY	KAVOOR_220	10:17	15:37	05:20	LINE CLEAR AVAILED
211	20-Jan-21	HASSAN	110	KAVOOR-AMR	KAVOOR_220	16:31	19:21	02:50	LINE FAULT
212	20-Jan-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:20	12:39	02:19	LINE CLEAR AVAILED
213	20-Jan-21	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:26	11:14	00:48	LINE CLEAR AVAILED
214	20-Jan-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:20	12:39	02:19	NFBC ISSUED
215	20-Jan-21	HASSAN	220	GOPALAP-BASTIPURA	GOPALAPURA_220	10:33	18:09	07:36	LINE CLEAR AVAILED
216	20-Jan-21	HASSAN	110	HV1	ARASIKERE_110	10:00	10:29	00:29	LINE CLEAR AVAILED
217	20-Jan-21	HASSAN	110	HV1	BANTWAL_110	16:29	17:06	00:37	MAIN SUPPLY FAILURE
218	20-Jan-21	HASSAN	110	HV3	BANTWAL_110	16:29	17:06	00:37	MAIN SUPPLY FAILURE
219	20-Jan-21	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	09:38	15:43	06:05	LINE CLEAR AVAILED
220	20-Jan-21	HASSAN	110	HV2	KONAJE_110	14:33	16:11	01:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
221	20-Jan-21	HASSAN	110	HV3	KONAJE_110	10:17	14:15	03:58	LINE CLEAR AVAILED
222	20-Jan-21	HASSAN	110	KULASH-KAVOOR 1	KULASHEKARA_110	15:39	16:54	01:15	LINE CLEAR AVAILED
223	20-Jan-21	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:25	16:50	06:25	NFBC ISSUED
224	20-Jan-21	HASSAN	110	HV1	MOODABIDRE_110	09:40	10:08	00:28	TRANSFORMER FAULT
225	20-Jan-21	HASSAN	66	HV1	BANDISHETTIHALI_66	06:30	06:35	00:05	MAIN SUPPLY FAILURE
226	20-Jan-21	HASSAN	66	HV1	BELUR_66	10:16	18:02	07:46	LINE CLEAR AVAILED
227	20-Jan-21	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:35	17:41	07:06	LINE CLEAR AVAILED
228	20-Jan-21	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	09:45	09:55	00:10	MAIN SUPPLY FAILURE
229	20-Jan-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	10:20	10:25	00:05	LINE FAULT
230	20-Jan-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	13:25	13:30	00:05	LINE FAULT
231	20-Jan-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	13:38	13:42	00:04	LINE FAULT
232	20-Jan-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	06:30	06:35	00:05	LINE FAULT
233	20-Jan-21	HASSAN	66	HV1	HNPUA_66	10:20	10:27	00:07	MAIN SUPPLY FAILURE
234	20-Jan-21	HASSAN	66	HV2	HNPUA_66	10:20	10:27	00:07	MAIN SUPPLY FAILURE
235	20-Jan-21	HASSAN	66	HV2	MAGGE_66	08:33	09:08	00:35	LINE CLEAR AVAILED
236	20-Jan-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	17:48	18:06	00:18	TRANSFORMER FAULT
237	20-Jan-21	HASSAN	66	HV2	SALAGAME_66	17:48	17:54	00:06	TRANSFORMER FAULT
238	20-Jan-21	HASSAN	66	HV1	S.BELAGOLA_66	17:49	18:05	00:16	TRANSFORMER FAULT
239	20-Jan-21	HASSAN	66	HV1	SINGAPURA_66	13:22	14:22	01:00	LINE CLEAR AVAILED
240	20-Jan-21	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLY_66	14:45	15:35	00:50	MAIN SUPPLY FAILURE
241	20-Jan-21	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLY_66	13:25	13:40	00:15	MAIN SUPPLY FAILURE
242	20-Jan-21	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLY_66	10:20	10:25	00:05	MAIN SUPPLY FAILURE
243	20-Jan-21	HASSAN	66	HV2	BASAVAGHATTA_66	17:49	18:04	00:15	TRANSFORMER FAULT
244	20-Jan-21	MYSORE	220	MADHUVANAHALLI-WARDHA SOLAR	NO STATION EFFECTED	23:54 (20/01/2021)			LINE OPEN:LINE FAULT
245	20-Jan-21	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	14:15	14:19	0:04	LINE FAULT
246	20-Jan-21	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:42	16:48	0:05	LINE FAULT
247	20-Jan-21	MYSORE	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	10:48	11:57	1:08	LINE CLEAR AVAILED
248	20-Jan-21	MYSORE	66	HV1	DUNDANAHALLI_66	10:00 (20/01/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
249	20-Jan-21	MYSORE	66	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66	17:43	18:01	0:17	LINE FAULT
250	20-Jan-21	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	17:53	17:58	0:05	LINE FAULT
251	20-Jan-21	MYSORE	66	HV4	KUSHALNAGARA_220	15:22	16:21	0:58	LINE CLEAR AVAILED
252	20-Jan-21	MYSORE	66	CH KATTE-RAVANDUR	CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG HALLI_66 KRNAGARA_66	17:50	18:00	0:10	LINE FAULT
253	20-Jan-21	MYSORE	66	KR NAGARA -MYSORE-2	NO STATION EFFECTED	18:05 (20/01/2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
254	20-Jan-21	MYSORE	66	HV2	ADDIHALLI_66	17:49	17:58	0:08	LOAD CURTAILMENT
255	20-Jan-21	MYSORE	66	HV1	BGNAGARA_66	17:49	17:54	0:04	LOAD CURTAILMENT
256	20-Jan-21	MYSORE	66	HV1	BGPURA_66	17:48	18:05	0:16	LOAD CURTAILMENT
257	20-Jan-21	MYSORE	66	HV1	BILIKERE_66	17:49	18:01	0:11	LOAD CURTAILMENT
258	20-Jan-21	MYSORE	66	HV1	DODDINADUVADI_66	17:49	17:57	0:07	LOAD CURTAILMENT
259	20-Jan-21	MYSORE	66	HV1	COWDALLI_66	9:54	10:15	0:21	LINE CLEAR AVAILED
260	20-Jan-21	MYSORE	66	HV2	BASARALU_66	13:55	14:56	1:00	LINE CLEAR AVAILED
261	20-Jan-21	MYSORE	66	HV2	HANAGODU_66	15:30	18:08	2:37	LINE CLEAR AVAILED
262	20-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
263	20-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED
264	20-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
265	20-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
266	20-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	17:55(20.01.2021)			LINE OPEN:LINE FAULT
267	20-Jan-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	17:53	18:20	0:27	LINE CLEAR AVAILED
268	20-Jan-21	TUMKUR	220	TR-1	HIRIYUR_220	16:57	18:47	1:49	LINE CLEAR AVAILED
269	20-Jan-21	TUMKUR	220	NEELAGUNDA220KV- GUTTUR 220kv	NEELAGUNDA_220	16:59	18:33	1:34	LINE CLEAR AVAILED
270	20-Jan-21	TUMKUR	110	TR-2	SAMPIGE_110	14:11	17:30	3:19	LINE CLEAR AVAILED
271	20-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	7:34	8:34	0:59	LINE CLEAR AVAILED
272	20-Jan-21	TUMKUR	66	TR-2	AVAREGERE_66	12:04	13:12	1:07	LINE CLEAR AVAILED
273	20-Jan-21	TUMKUR	66	TR-1	BELADARA_66	11:18	11:47	0:29	LINE CLEAR AVAILED
274	20-Jan-21	TUMKUR	66	TR-1	BELADARA_66	13:01	13:09	0:08	LINE CLEAR AVAILED
275	20-Jan-21	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	9:38	9:55	0:17	LINE FAULT
276	20-Jan-21	TUMKUR	66	TR-2	CHITRADURGA_66	15:19	15:22	0:03	TRANSFORMER FAULT
277	20-Jan-21	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	10:21	14:16	3:54	LINE CLEAR AVAILED
278	20-Jan-21	TUMKUR	66	TR-1	DEVARAHALLI_66	10:20	14:16	3:55	LINE CLEAR AVAILED
279	20-Jan-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	11:41	12:05	0:24	LINE CLEAR AVAILED
280	20-Jan-21	TUMKUR	66	HARIYABBE- PD KOTE	HARIYABBE_66	20:01	20:05	0:04	HAND TRIPPED
281	20-Jan-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	18:10	18:56	0:46	MAIN SUPPLY FAILURE
282	20-Jan-21	TUMKUR	66	TR-2	HARIYABBE_66	15:50	16:07	0:17	LINE CLEAR AVAILED
283	20-Jan-21	TUMKUR	66	TR-1(LV1)	HIRIYUR_220	16:57	18:49	1:51	LINE CLEAR AVAILED
284	20-Jan-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:19	11:10	0:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
285	20-Jan-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	10:19	11:10	0:51	LINE CLEAR AVAILED
286	20-Jan-21	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	19:02	19:10	0:07	HAND TRIPPED
287	20-Jan-21	TUMKUR	66	TR-1	TUMKUR_66	7:26	7:34	0:08	HAND TRIPPED
288	20-Jan-21	TUMKUR	66	TR-2	TUMKUR_66	7:26	7:33	0:07	HAND TRIPPED
289	20-Jan-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	9:53	18:55	9:02	LINE CLEAR AVAILED
290	21-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
291	21-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
292	21-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
293	21-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
294	21-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED
295	21-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
296	21-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
297	21-Jan-21	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
298	21-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
299	21-Jan-21	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
300	21-Jan-21	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
301	21-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
302	21-Jan-21	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)	15:44 (21.01.2021)	90:41hrs	LINE CHARGED
303	21-Jan-21	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
304	21-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
305	21-Jan-21	BAGALKOT	110	ALABAL-SAI PRIYA SUGARS	ALABAL_110 (STATION NOT AFFECTED)	05:20	05:45	0:25	LINE FAULT
306	21-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220 (STATION NOT AFFECTED)	06:54	19:20	12:26	NFBC ISSUED
307	21-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 2	ATHANI_220 (STATION NOT AFFECTED)	06:54	19:21	12:27	NFBC ISSUED
308	21-Jan-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220 (STATION NOT AFFECTED)	9:45 (21.01.2021)			LINE OPEN:LINE CLEAR AVAILED
309	21-Jan-21	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	10:08	11:50	1:42	NFBC ISSUED
310	21-Jan-21	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	05:55	06:24	0:29	LINE FAULT
311	21-Jan-21	BAGALKOT	110	UDIKERI- NOKAR SOLAR	STATION NOT AFFECTED UDIKERI_110	22:11	22:24	0:13	LINE FAULT
312	21-Jan-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	2:30	2:35	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
313	21-Jan-21	BAGALKOT	110	TADASINAKOPPA-TARIHAL(KUD)	STATION NOT AFFECTED TADASINAKOPPA_110	9:28	18:41	9:13	LINE CLEAR AVOIDED
314	21-Jan-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	15:08	19:31	4:23	LINE FAULT
315	21-Jan-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	13:01	19:31	6:30	LINE FAULT
316	21-Jan-21	BAGALKOT	110	HUBLI-TARIHAL1	STATION NOT AFFECTED HUBLI_220	16:42	16:43	0:01	HAND TRIPPED
317	21-Jan-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	15:44 (21.01.2021)			LOAD CURTAILMENT
318	21-Jan-21	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	13:34	18:18	4:44	LINE FAULT
319	21-Jan-21	BAGALKOT	110	NARENDRA-KUD DHARWAD1	KUD DHARWAD_110	10:17	16:37	6:20	LINE CLEAR AVOIDED
320	21-Jan-21	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	14:06	14:43	0:37	TRANSFORMER FAULT
321	21-Jan-21	BAGALKOT	220	KUDUCHI-GHATAPRABHA(CKD1)	KUDUCHI_220	9:12 (21.01.2021)			LINE OPEN:LINE FAULT
322	21-Jan-21	BAGALKOT	220	220/110KV,HV2,LV2	NO STATION AFFECTED KUDUCHI_220	13:10	13:54	0:44	LINE CLEAR AVOIDED
323	21-Jan-21	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	15:40	16:37	0:57	LINE CLEAR AVOIDED
324	21-Jan-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	15:51	18:12	2:21	LINE CLEAR AVOIDED
325	21-Jan-21	BAGALKOT	110	KUD DHARWAD- LAKAMANAHALLI	KUD DHARWAD_110	10:11	17:20	7:09	LINE CLEAR AVOIDED
326	21-Jan-21	BAGALKOT	110	110/11KV,HV2	HIREKERUR_110	10:00	12:09	2:09	LINE CLEAR AVOIDED
327	21-Jan-21	BAGALKOT	110	110/11KV,HV2	HIREKERUR_110	12:35	19:06	6:31	LINE CLEAR AVOIDED
328	21-Jan-21	BAGALKOT	110	110/33KV,HV1	HIREKERUR_110,KODA_33,CHIKK ERUR_33	10:30	18:56	8:26	LINE CLEAR AVOIDED
329	21-Jan-21	BAGALKOT	110	110/11KV,HV3	HIREKERUR_110	11:00	18:58	7:58	LINE CLEAR AVOIDED
330	21-Jan-21	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	7:56	08:08	0:12	TRANSFORMER FAULT
331	21-Jan-21	BAGALKOT	110	HAVERI-BYADAGI	STATION NOT AFFECTED HAVERI_220	15:15	17:17	2:02	LINE CLEAR AVOIDED
332	21-Jan-21	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	9:34	9:41	0:07	TRANSFORMER FAULT
333	21-Jan-21	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)			LINE OPEN:LINE FAULT
334	21-Jan-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)			LINE OPEN:LINE FAULT
335	21-Jan-21	BAGALKOT	220	220/110KV,HV2,LV2	NO STATION AFFECTED GADAG_220	11:01	18:45	7:44	LINE CLEAR AVOIDED
336	21-Jan-21	BAGALKOT	220	BIJAPUR-VAISHALI WIND2	STATION NOT AFFECTED BIJAPUR_220	11:23	17:35	6:12	LINE CLEAR AVOIDED
337	21-Jan-21	BENGALURU	66	HV2	APPAREL PARK	11:53	12:00	00:07	LINE CLEAR AVOIDED
338	21-Jan-21	BENGALURU	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	13:50	14:00	00:10	LINE CLEAR AVOIDED
339	21-Jan-21	BENGALURU	66	APPAREL PARK - NRS 220	APPAREL PARK	14:35	14:55	00:20	LOAD CHANGE OVER
340	21-Jan-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	17:10	17:35	00:25	LOAD CHANGE OVER
341	21-Jan-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	19:14	19:18	00:04	LOAD CHANGE OVER
342	21-Jan-21	BENGALURU	66	HV2	GOKULA	10:17	10:20	00:03	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
343	21-Jan-21	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	10:20	10:50	00:30	MAIN SUPPLY FAILURE
344	21-Jan-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODUR	10:20	10:27	00:07	LINE FAULT
345	21-Jan-21	BENGALURU	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	17:11	17:23	00:12	LINE FAULT
346	21-Jan-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	17:15	17:42	00:27	MAIN SUPPLY FAILURE
347	21-Jan-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	19:20	19:25	00:05	LOAD CHANGE OVER
348	21-Jan-21	BENGALURU	66	SOBHA FOREST - SUBRAMANYAPURA 220	SOBHA FOREST	17:11	17:40	00:29	MAIN SUPPLY FAILURE
349	21-Jan-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66	02:26	02:55	00:29	LINE FAULT
350	21-Jan-21	BENGALURU	66	SRS PEENYA 220 - HEBBAL 220	NO STATION AFFECTED	15:33	18:24	02:51	LINE FAULT
351	21-Jan-21	BENGALURU	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	17:11	17:24	00:13	LINE CLEAR AVAILED
352	21-Jan-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:11	17:35	00:24	LINE CLEAR AVAILED
353	21-Jan-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	17:11	17:35	00:24	LINE CLEAR AVAILED
354	21-Jan-21	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	17:11	17:35	00:24	LINE CLEAR AVAILED
355	21-Jan-21	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	17:11	17:35	00:24	LINE CLEAR AVAILED
356	21-Jan-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	17:11	17:35	00:24	LINE CLEAR AVAILED
357	21-Jan-21	BENGALURU	66	HV2	T K HALLI 220	13:08	13:14	00:06	TRANSFORMER FAULT
358	21-Jan-21	BENGALURU	66	HV2	VICTORIA HOSPITAL	12:02	12:04	00:02	LINE CLEAR AVAILED
359	21-Jan-21	BENGALURU	66	HV2	VICTORIA HOSPITAL	13:12	13:14	00:02	LOAD CHANGE OVER
360	21-Jan-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	07:49	08:15	00:25	LINE FAULT
361	21-Jan-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	14:41	14:45	00:03	LINE CLEAR AVAILED
362	21-Jan-21	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	14:41	14:45	00:03	LINE CLEAR AVAILED
363	21-Jan-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:33	12:39	00:06	LINE FAULT
364	21-Jan-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:32	18:37	00:05	LINE FAULT
365	21-Jan-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:24	14:38	00:14	LINE FAULT
366	21-Jan-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:25	18:21	02:55	LINE CLEAR AVAILED
367	21-Jan-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	15:35	15:49	00:14	LINE CLEAR AVAILED
368	21-Jan-21	BENGALURU	66	HV2	BAIRAKURU	11:25	11:50	00:24	TRANSFORMER FAULT
369	21-Jan-21	BENGALURU	66	HV1	CHAKAVELU	15:15	15:27	00:12	LINE CLEAR AVAILED
370	21-Jan-21	BENGALURU	66	HV2	DODDABELAVANGALA	23:07	23:15	00:07	TRANSFORMER FAULT
371	21-Jan-21	BENGALURU	66	HV1	DEVANAHALLI	17:45	17:50	00:05	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
372	21-Jan-21	BENGALURU	66	HV1	KACHMARANAHALLI	12:11	14:14	02:02	LINE CLEAR AVAILED
373	21-Jan-21	BENGALURU	66	HV2	KACHMARANAHALLI	14:35	14:50	00:15	LINE CLEAR AVAILED
374	21-Jan-21	BENGALURU	66	HV2	YELAHANKA 220	15:16	15:17	00:01	LINE CLEAR AVAILED
375	21-Jan-21	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	14:40	14:45	00:05	LOAD CHANGE OVER
376	21-Jan-21	GULBARGA	110	HALBARGA_BHALKI	BHALKI_110	01:16	01:21	00:05	LINE FAULT
377	21-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110,VALKAMDINNI_110	05:07	05:20	00:13	LINE FAULT
378	21-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110,VALKAMDINNI_110	05:36	05:48	00:12	LINE FAULT
379	21-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110,VALKAMDINNI_110	05:57	06:10	00:13	LINE FAULT
380	21-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110,VALKAMDINNI_110	06:50	07:15	00:25	LINE FAULT
381	21-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110,VALKAMDINNI_110	08:34	08:45	00:11	LINE FAULT
382	21-Jan-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	05:30	05:40	00:10	LINE FAULT
383	21-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT-2	MADLAPUR_110,MANVI_110	18:19	18:39	00:20	LINE FAULT
384	21-Jan-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:15	23:25	00:10	LINE FAULT
385	21-Jan-21	GULBARGA	110	SINDHANOOR-MUNIRABAD 2	MUKKUNDA_110,KAMPLI_110,YERADONA_110,SRNAGAR_110,MALLSPURA_110	03:49	03:59	00:10	LINE CLEAR AVAILED
386	21-Jan-21	GULBARGA	110	SHAHPUR-KEMBHAVI 2	KBJNL_110	00:14	00:22	00:08	LINE CLEAR AVAILED
387	21-Jan-21	GULBARGA	110	SHAHPUR-KEMBHAVI 1	KEMBHAVI_110,HUNASIGI_110,UGARSUGAR_IPP,ASKI_110	06:04	06:12	00:08	LINE CLEAR AVAILED
388	21-Jan-21	GULBARGA	110	HV3	VALKAMDINNI_110	12:55	13:28	00:33	LINE CLEAR AVAILED
389	21-Jan-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	05:15	07:30	02:15	MAIN SUPPLY FAILURE
390	21-Jan-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	08:15	08:40	00:25	MAIN SUPPLY FAILURE
391	21-Jan-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	12:10	12:20	00:10	MAIN SUPPLY FAILURE
392	21-Jan-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	12:30	12:50	00:20	MAIN SUPPLY FAILURE
393	21-Jan-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	15:00	15:40	00:40	MAIN SUPPLY FAILURE
394	21-Jan-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	04:55	05:00	00:05	MAIN SUPPLY FAILURE
395	21-Jan-21	GULBARGA	110	VALKAMDINNI-RAICHUR2	VALKAMDINNI_110	05:25	05:40	00:15	MAIN SUPPLY FAILURE
396	21-Jan-21	GULBARGA	110	VALKAMDINNI-RAICHUR2	VALKAMDINNI_110	05:55	06:15	00:20	MAIN SUPPLY FAILURE
397	21-Jan-21	GULBARGA	110	YERADONA-BENUR	BENNUR_110	03:45	04:05	00:20	MAIN SUPPLY FAILURE
398	21-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	22:08(20.1.2021)	1:45 (21.01.2021)	3:36 hrs	LINE CLEAR AVAILED
399	21-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:42 (20.01.2021)	7:25(21.01.2021)	10:42 hrs	LINE CHARGED
400	21-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
401	21-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
402	21-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
403	21-Jan-21	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
404	21-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
405	21-Jan-21	HASSAN	400	UPCL-HASSAN	upcl_gen	21:13 (21.01.2021)			LINE OPEN:LINE CLEAR AVAILED
406	21-Jan-21	HASSAN	220	KADUR-DABUSET	KADUR_220	17:37	23:24	05:47	LINE FAULT
407	21-Jan-21	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:25	11:25	01:00	LINE CLEAR AVAILED
408	21-Jan-21	HASSAN	110	HV1	ARASIKERE_110	18:09	18:24	00:15	LINE CLEAR AVAILED
409	21-Jan-21	HASSAN	110	HV2	ESSUR_110	11:30	13:44	02:14	LINE CLEAR AVAILED
410	21-Jan-21	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:50	17:40	06:50	LINE CLEAR AVAILED
411	21-Jan-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:05	15:50	05:45	LINE CLEAR AVAILED
412	21-Jan-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:17	15:55	05:38	MAIN SUPPLY FAILURE
413	21-Jan-21	HASSAN	66	HV1	ALDUR_66	10:17	16:00	05:43	MAIN SUPPLY FAILURE
414	21-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	02:00	05:30	03:30	LINE FAULT
415	21-Jan-21	HASSAN	66	HV1	DODDAKA	14:34	14:35	00:01	HAND TRIPPED
416	21-Jan-21	HASSAN	66	HV1	GANGUR_66	12:43	13:27	00:44	LINE CLEAR AVAILED
417	21-Jan-21	HASSAN	66	HV1	MALALI_66	12:48	13:52	01:04	LINE CLEAR AVAILED
418	21-Jan-21	HASSAN	66	MALALI-ARAKALGUD	MALLIPATNA_66	03:40	05:26	01:46	MAIN SUPPLY FAILURE
419	21-Jan-21	HASSAN	66	MALALI-SANIVARSANTE	MALLIPATNA_66	01:42	05:36	03:54	MAIN SUPPLY FAILURE
420	21-Jan-21	HASSAN	66	HV1	SHRAVANABELAGOLA_66	12:49	14:14	01:25	LINE CLEAR AVAILED
421	21-Jan-21	HASSAN	66	HV2	SHRAVANABELAGOLA_66	11:28	12:47	01:19	LINE CLEAR AVAILED
422	21-Jan-21	MYSORE	220	MADHUVANAHALLI-WARDHA SOLAR	NO STATION EFFECTED	2:40	3:18	0:38	LINE FAULT
423	21-Jan-21	MYSORE	220	HV2	CRNAGAR_220	11:19	11:20	1:00	TRANSFORMER CHARGED
424	21-Jan-21	MYSORE	220	HV2	CRNAGAR_220	13:17	15:08	1:51	LINE CLEAR AVAILED
425	21-Jan-21	MYSORE	220	HEBBANI-TK HALLI 2	NO STATION EFFECTED	9:13	12:12	2:59	LINE CLEAR AVAILED
426	21-Jan-21	MYSORE	66	HV2	BASARALU_66	9:40	10:51	1:10	LINE CLEAR AVAILED
427	21-Jan-21	MYSORE	66	HV1	COWDALLI_66	15:30	17:07	1:37	LINE CLEAR AVAILED
428	21-Jan-21	MYSORE	66	GUNDLUPETE-BEGUR 2	NO STATION EFFECTED	10:48	11:50	1:01	LINE CLEAR AVAILED
429	21-Jan-21	MYSORE	66	HV2	HANAGODU_66	12:10	15:57	3:47	LINE CLEAR AVAILED
430	21-Jan-21	MYSORE	66	HOOTAGALLY-DODDAKADNUR	KAGGERE HAMPAPURA_66	10:30	10:33	0:03	LINE FAULT
431	21-Jan-21	MYSORE	66	HOOTAGALLY-DODDAKADNUR	KAGGERE HAMPAPURA_66	10:45	16:20	5:35	LINE CLEAR AVAILED
432	21-Jan-21	MYSORE	66	HOOTAGALLY-ELWALA	ELAVALA_66	18:22	18:40	0:17	LINE FAULT
433	21-Jan-21	MYSORE	66	HUNSUR-ELWALA	GAVADAGERE_66	18:22	18:40	0:17	LINE FAULT
434	21-Jan-21	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	6:37	6:43	0:06	LINE FAULT
435	21-Jan-21	MYSORE	66	KR NAGARA-BILIKERE	NO STATION EFFECTED	10:38	16:34	5:55	NFBC ISSUED
436	21-Jan-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATION EFFECTED	12:45	12:50	0:04	HAND TRIPPED
437	21-Jan-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATION EFFECTED	12:50	12:53	0:02	HAND TRIPPED
438	21-Jan-21	MYSORE	66	RK NAGARA-MANDAKALLI	NO STATION EFFECTED	13:50	14:53	1:03	LINE CLEAR AVAILED
439	21-Jan-21	MYSORE	66	HV1	RKNAGARA_66	12:32	13:10	0:37	LINE CLEAR AVAILED
440	21-Jan-21	MYSORE	66	HV2	RKNAGARA_66	13:15	13:55	0:39	LINE CLEAR AVAILED
441	21-Jan-21	MYSORE	66	SHIVALLI-TUBINKERE	SHIVALLY_66	10:02	16:20	6:17	LINE CLEAR AVAILED
442	21-Jan-21	MYSORE	66	HV1	SINDHUVALLI_66	12:47	13:45	0:57	LINE CLEAR AVAILED
443	21-Jan-21	MYSORE	66	HV2	SINDHUVALLI_66	11:40	12:45	1:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
444	21-Jan-21	MYSORE	66	SUNTIKOPPA-KUSHALNAGARA	NO STATION EFFECTED	16:26	17:44	1:17	LINE CLEAR AVAILED
445	21-Jan-21	MYSORE	66	SUNTIKOPPA-MADIKERI	NO STATION EFFECTED	15:58	16:26	0:27	LINE CLEAR AVAILED
446	21-Jan-21	MYSORE	66	HV5	SFCSHIVA_66	14:04	17:38	3:33	LINE CLEAR AVAILED
447	21-Jan-21	MYSORE	220	MADHUVANAHALLI-WARDHA SOLAR	NO STATION EFFECTED	23:54 (20/01/2021)	0:19 (21/01/2021)	0:25 HRS	LINE CHARGED
448	21-Jan-21	MYSORE	66	HV1	DUNDANAHALLI_66	10:00 (20/01/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
449	21-Jan-21	MYSORE	66	KR NAGARA -MYSORE-2	NO STATION EFFECTED	18:05 (20/01/2021)	14:50 (21/01/2021)	20:45 HRS	LINE CHARGED
450	21-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
451	21-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED
452	21-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
453	21-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
454	21-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	17:55:18 (20.01.2021)	12:14:34 (21.01.2021)	18:19hrs	LINE CHARGED
455	21-Jan-21	TUMKUR	220	NEELAGUNDA220kv- GUTTUR 220kv	NEELAGUNDA_220	12:58	17:54	4:56	NFBC ISSUED
456	21-Jan-21	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	19:24	23:19	3:54	LINE FAULT
457	21-Jan-21	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR_110	6:41	7:16	0:35	LINE FAULT
458	21-Jan-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	17:45	18:08	0:23	LOAD CURTAILMENT
459	21-Jan-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	17:44	18:08	0:24	LOAD CURTAILMENT
460	21-Jan-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:44	18:08	0:23	LOAD CURTAILMENT
461	21-Jan-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	14:07	14:38	0:31	LOAD CURTAILMENT
462	21-Jan-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	17:44	18:07	0:23	LOAD CURTAILMENT
463	21-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	11:33	12:13	0:39	LINE FAULT
464	21-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	12:31	13:46	1:14	LINE FAULT
465	21-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	14:08	14:34	0:25	LINE CLEAR AVAILED
466	21-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	17:42	18:08	0:26	LOAD CURTAILMENT
467	21-Jan-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	18:06	18:24	0:18	LINE CLEAR AVAILED
468	21-Jan-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	7:05	7:42	0:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
469	21-Jan-21	TUMKUR	66	HEGGERE- MALLASANDRA2	MALLASANDRA_66	18:36	19:13	0:37	HAND TRIPPED
470	21-Jan-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:23	7:33	0:09	HAND TRIPPED
471	21-Jan-21	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	17:07	17:16	0:09	LINE FAULT
472	21-Jan-21	TUMKUR	66	TR-1	RAMPURA_66	12:11	13:29	1:18	LINE CLEAR AVAILED
473	21-Jan-21	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	4:09	4:15	0:05	LINE FAULT
474	21-Jan-21	TUMKUR	66	TR-1	SOKKE_66	22:01	22:05	0:04	MAIN SUPPLY FAILURE
475	21-Jan-21	TUMKUR	66	SOKKE-JAGLUR	JAGALUR_66	21:58	22:14	0:16	MAIN SUPPLY FAILURE
476	22-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
477	22-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
478	22-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
479	22-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
480	22-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED
481	22-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
482	22-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
483	22-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
484	22-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
485	22-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
486	22-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
487	22-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
488	22-Jan-21	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
489	22-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
490	22-Jan-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	STATION NOT AFFECTED CHIKKODI_220	9:45 (21.01.2021)			LINE OPEN:LINE CLEAR AVAILED
491	22-Jan-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	15:44 (21.01.2021)			LOAD CURTAILMENT
492	22-Jan-21	BAGALKOT	220	KUDUCHI-GHATAPRABHA(CKD1)	STATION NOT AFFECTED KUDUCHI_220	9:12 (21.01.2021)			LINE OPEN:LINE FAULT
493	22-Jan-21	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)			LINE OPEN:LINE FAULT
494	22-Jan-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)			LINE OPEN:LINE FAULT
495	22-Jan-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	07:21	07:31	0:10	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
496	22-Jan-21	BAGALKOT	220	ATHANI 220-RAVIURJA 1	STATION NOT AFFECTED ATHANI_220	07:15	20:15	13:00	NFBC ISSUED
497	22-Jan-21	BAGALKOT	220	ATHANI 220-RAVIURJA 2	STATION NOT AFFECTED ATHANI_220	07:15	20:16	13:01	NFBC ISSUED
498	22-Jan-21	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	7:21	7:38	0:17	LOAD CURTAILMENT
499	22-Jan-21	BAGALKOT	110	110/11KV,HV4	GAJENDRGAD_110	7:20	7:54	0:34	LOAD CURTAILMENT
500	22-Jan-21	BAGALKOT	110	GHATAPRABHA220-SHIRAGOAN	SHIRAGOAN_110	10:07	18:38	8:31	LINE CLEAR AVAILED
501	22-Jan-21	BAGALKOT	110	110/11KV,HV1 & LV1	GULEDGUDDA_110	15:55	16:00	0:05	TRANSFORMER FAULT
502	22-Jan-21	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33	07:21	07:32	0:11	LOAD CURTAILMENT
503	22-Jan-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,M AITRA_SOLAR	07:22	07:30	0:08	LOAD CURTAILMENT
504	22-Jan-21	BAGALKOT	110	HIDIKAL-ITANAL(RAIBAG)	ITANAL_110	07:30	15:21	7:51	LOAD CURTAILMENT
505	22-Jan-21	BAGALKOT	110	HIDIKAL-ITANAL(RAIBAG)	HIDIKAL_110	17:08 (22.01.2021)			LINE OPEN:LINE CLEAR AVAILED
506	22-Jan-21	BAGALKOT	110	JAMAKHANDI- NAVALAGI(MLPURA)	STATION NOT AFFECTED JAMAKHANDI_110	11:27	12:14	0:47	HAND TRIPPED
507	22-Jan-21	BAGALKOT	110	110/11KV,HV1	KUDALSANGAM_110	7:20	07:28	0:08	LOAD CURTAILMENT
508	22-Jan-21	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	00:35	4:04	3:29	TRANSFORMER FAULT
509	22-Jan-21	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110, ALNAVAR_33,NIGADI_33,ARVAT AGI_33	12:20	14:50	2:30	LINE CLEAR AVAILED
510	22-Jan-21	BAGALKOT	110	110/11KV,HV2	MAMDAPUR(G)_110	19:10 (21.01.2021)	15:19 (22.01.2021)	20:09HRS	TRANSFORMER CHARGED
511	22-Jan-21	BAGALKOT	110	110/11KV,HV2	MANTU_110	16:20	16:58	0:38	LINE CLEAR AVAILED
512	22-Jan-21	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	7:18	8:20	1:02	TRANSFORMER FAULT
513	22-Jan-21	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	7:20	07:50	0:30	LOAD CURTAILMENT
514	22-Jan-21	BAGALKOT	110	110/33KV, HV2	RATTIHALI_110	12:53	13:00	0:07	TRANSFORMER FAULT
515	22-Jan-21	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	17:35	17:50	0:15	TRANSFORMER FAULT
516	22-Jan-21	BAGALKOT	220	SIRSI-HUBLI 1	STATION NOT AFFECTED SIRSI_220	13:24	15:50	2:26	NFBC ISSUED
517	22-Jan-21	BAGALKOT	110	110/33KV,HV4	ZALAKI_110 & DHULKHED,HALASANGI,NEVARA GI_33	07:51	08:01	0:10	TRANSFORMER FAULT
518	22-Jan-21	BAGALKOT	110	110/11KV,HV1 & HV2	SHIRAGOAN_110	10:05	18:38	8:33	LINE CLEAR AVAILED
519	22-Jan-21	BAGALKOT	110	110/33KV,HV2	SAVALGI_110 & HIREPADASALGI,KALABILGI &TUNGAL LIS_33	7:21	7:37	0:16	LOAD CURTAILMENT
520	22-Jan-21	BAGALKOT	220	HUBLI-SIRSI 1	HUBLI_220	13:24	15:50	2:26	LINE CLEAR AVAILED
521	22-Jan-21	BENGALURU	66	B G ROAD - SOMANAHALLI 220	B G ROAD	10:40	17:28	06:48	LINE CLEAR AVAILED
522	22-Jan-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	09:07	09:18	00:11	LOAD CHANGE OVER
523	22-Jan-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	15:57	16:05	00:08	LOAD CHANGE OVER
524	22-Jan-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	16:58	17:03	00:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
525	22-Jan-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:35	13:40	00:05	LOAD CHANGE OVER
526	22-Jan-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	20:45	20:50	00:05	LINE FAULT
527	22-Jan-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:56	12:03	00:07	LINE FAULT
528	22-Jan-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:56	12:03	00:07	LINE FAULT
529	22-Jan-21	BENGALURU	66	HV1	YARANDANAHALLI 220	09:10	09:17	00:07	LOAD CHANGE OVER
530	22-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	09:12	09:23	00:11	LOAD CHANGE OVER
531	22-Jan-21	BENGALURU	66	HV3	YARANDANAHALLI 220	10:50	10:59	00:09	LOAD CHANGE OVER
532	22-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:29	15:27	00:58	LINE FAULT
533	22-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:27	18:55	03:28	LINE CLEAR AVAILED
534	22-Jan-21	BENGALURU	220	HV2	YARANDANAHALLI 220	14:29	14:45	00:16	TRANSFORMER FAULT
535	22-Jan-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	16:15	16:25	00:10	LINE FAULT
536	22-Jan-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:51	13:10	00:18	LINE FAULT
537	22-Jan-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:17	11:23	00:06	LINE FAULT
538	22-Jan-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	04:22	05:15	00:52	LINE CLEAR AVAILED
539	22-Jan-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	05:21	06:00	00:39	LINE CLEAR AVAILED
540	22-Jan-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	07:15	07:53	00:38	LOAD CURTAILMENT
541	22-Jan-21	BENGALURU	66	HV1	TUBUGERE	15:42	16:10	00:27	LINE CLEAR AVAILED
542	22-Jan-21	BENGALURU	66	HV1	MELUR	15:58	16:58	01:00	LINE CLEAR AVAILED
543	22-Jan-21	BENGALURU	66	DG2	DB PURA 220	11:00	11:04	00:04	LOAD CHANGE OVER
544	22-Jan-21	BENGALURU	66	HV1	DEVANAHALLI	06:30	06:40	00:10	LINE CLEAR AVAILED
545	22-Jan-21	BENGALURU	66	HV1	DEVANAHALLI	06:50	06:55	00:05	LINE CLEAR AVAILED
546	22-Jan-21	BENGALURU	66	HV1	DODDABELAVANGALA	11:24	11:35	00:10	LINE CLEAR AVAILED
547	22-Jan-21	BENGALURU	66	HV1	DODDABELAVANGALA	15:50	15:53	00:03	LINE CLEAR AVAILED
548	22-Jan-21	BENGALURU	66	HV2	DODDABELAVANGALA	11:24	11:35	00:10	LINE CLEAR AVAILED
549	22-Jan-21	BENGALURU	66	HV2	DODDABELAVANGALA	15:50	15:53	00:03	LINE CLEAR AVAILED
550	22-Jan-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	10:43	17:45	07:02	LINE CLEAR AVAILED
551	22-Jan-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	10:45	18:05	07:20	LINE CLEAR AVAILED
552	22-Jan-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	10:45	18:38	07:53	LINE CLEAR AVAILED
553	22-Jan-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	10:15	18:29	08:14	LINE CLEAR AVAILED
554	22-Jan-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	10:22	18:02	07:40	LINE CLEAR AVAILED
555	22-Jan-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	10:10	17:50	07:40	LINE CLEAR AVAILED
556	22-Jan-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	10:15	18:29	08:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
557	22-Jan-21	BENGALURU	66	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	10:57	17:29	06:32	LINE CLEAR AVAILED
558	22-Jan-21	BENGALURU	66	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	10:57	17:29	06:32	LINE CLEAR AVAILED
559	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	THIMAMPALLI, SOMANATHPURA	10:45	18:40	07:55	LINE CLEAR AVAILED
560	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	10:45	18:36	07:51	LINE CLEAR AVAILED
561	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	10:45	18:35	07:50	LINE CLEAR AVAILED
562	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE, SOMENAHALLI	10:45	18:30	07:45	LINE CLEAR AVAILED
563	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	10:45	18:40	07:55	LINE CLEAR AVAILED
564	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA, NITRALLI	10:45	17:53	07:08	LINE CLEAR AVAILED
565	22-Jan-21	BENGALURU	66	GOWRIBIDANUR 220 - PGCIL	GOWRIBIDANUR 220	10:45	17:25	06:40	LINE CLEAR AVAILED
566	22-Jan-21	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110	6:30(20.01.2021)			LINE OPEN:LINE FAULT
567	22-Jan-21	GULBARGA	110	VALKAMDINNI-RAICHUR2	VALKAMDINNI_110	6:50(21.01.2021)			MAIN SUPPLY FAILURE
568	22-Jan-21	GULBARGA	220	LINGAPUR-HKTMINING	HKTMINING_110	12:09	14:28	02:19	LINE FAULT
569	22-Jan-21	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	05:41	05:54	00:13	LINE FAULT
570	22-Jan-21	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	15:43	20:45	05:02	LINE CHARGED
571	22-Jan-21	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	15:44	20:48	05:04	LINE CLEAR AVAILED
572	22-Jan-21	GULBARGA	110	HV2	JEWARGI_110	07:20	07:30	00:10	LOAD CURTAILMENT
573	22-Jan-21	GULBARGA	110	HV2	JEWARGI_110	08:35	08:50	00:15	LINE CLEAR AVAILED
574	22-Jan-21	GULBARGA	110	HV1	KADAGANCHI_110	13:50	14:05	00:15	TRANSFORMER FAULT
575	22-Jan-21	GULBARGA	110	HV1 & HV2	RAJESHWAR_110	07:20	07:30	00:10	LOAD CURTAILMENT
576	22-Jan-21	GULBARGA	110	MUNIRABAD-STARMETALLIC_IPP	STARMETALLIC_110	12:05	12:10	00:05	LINE FAULT
577	22-Jan-21	GULBARGA	110	HV1	TEKKALKOTE_110	08:00	08:30	00:30	LOAD CURTAILMENT
578	22-Jan-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	05:53	08:23	02:30	LINE FAULT
579	22-Jan-21	GULBARGA	110	HV2	BISIHALLI_110	15:30	18:00	02:30	TRANSFORMER FAULT
580	22-Jan-21	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	15:35	20:30	04:55	NFBC ISSUED
581	22-Jan-21	GULBARGA	110	HV1	NALWAR_110	16:40	17:30	00:50	LINE CLEAR AVAILED
582	22-Jan-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IP	03:47	03:52	00:05	LINE FAULT
583	22-Jan-21	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	00:35	02:55	02:20	LINE CLEAR AVAILED
584	22-Jan-21	GULBARGA	110	HV3	TEKKALKOTE_110	13:40	17:03	03:23	LINE CLEAR AVAILED
585	22-Jan-21	GULBARGA	110	TEKKALKOTE-SHAHISOLAR_IPP	TEKKALKOTE_110	22:05	22:15	00:10	LINE CLEAR AVAILED
586	22-Jan-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	20:55	21:05	00:10	LINE FAULT
587	22-Jan-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	23:17	23:26	00:09	LINE FAULT
588	22-Jan-21	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)	16:32 (22.01.2021)	168:51 hrs	TRANSFORMER CHARGED
589	22-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:13 (21.01.2021)	9:38 (22.01.2021)	12:24 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
590	22-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
591	22-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
592	22-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
593	22-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
594	22-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:23 (22.01.2021)			LINE OPEN:LINE CLEAR AVAILED
595	22-Jan-21	HASSAN	220	KADUR-DABUSET	KADUR_220	17:40 (22.01.2021)			LINE OPEN:LINE FAULT
596	22-Jan-21	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	10:02	11:31	01:29	LINE CLEAR AVAILED
597	22-Jan-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:59	16:37	05:38	LINE CLEAR AVAILED
598	22-Jan-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:59	16:37	05:38	LINE CLEAR AVAILED
599	22-Jan-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	09:41	09:45	00:04	LINE FAULT
600	22-Jan-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	09:50	14:04	04:14	LINE CLEAR AVAILED
601	22-Jan-21	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	10:02	11:31	01:29	LINE CLEAR AVAILED
602	22-Jan-21	HASSAN	110	HV3	PUTTUR_110	06:22	06:58	00:36	TRANSFORMER FAULT
603	22-Jan-21	HASSAN	110	HV1	HALADY_110	07:19	07:26	00:07	LOAD CURTAILMENT
604	22-Jan-21	HASSAN	110	HV1	GANDSI_110	13:19	13:33	00:14	TRANSFORMER FAULT
605	22-Jan-21	HASSAN	110	HV2	GANDSI_110	07:19	07:46	00:27	LOAD CURTAILMENT
606	22-Jan-21	HASSAN	110	HV2	GERUMARA_110	07:18	08:21	01:03	LOAD CURTAILMENT
607	22-Jan-21	HASSAN	66	HV1	BALEHONNUR_66	07:19	07:56	00:37	LOAD CURTAILMENT
608	22-Jan-21	HASSAN	66	HV1	HANGARANAHALLY_66	07:18	07:32	00:14	LOAD CURTAILMENT
609	22-Jan-21	HASSAN	66	HV2	HNPURA_66	15:33	17:27	01:54	LINE CLEAR AVAILED
610	22-Jan-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	07:21	07:40	00:19	LOAD CURTAILMENT
611	22-Jan-21	HASSAN	66	HV2	SALAGAME_66	07:21	07:28	00:07	LOAD CURTAILMENT
612	22-Jan-21	HASSAN	66	HV1	SHRAVANABELAGOLA_66	07:22	07:35	00:13	LOAD CURTAILMENT
613	22-Jan-21	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	15:52	15:59	00:07	HAND TRIPPED
614	22-Jan-21	HASSAN	66	HV2	BASAVAGHATTA_66	07:20	07:32	00:12	LOAD CURTAILMENT
615	22-Jan-21	MYSORE	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	10:27	11:30	1:02	LINE CLEAR AVAILED
616	22-Jan-21	MYSORE	66	HV2	ADDIHALLI_66	7:20	7:26	0:06	LOAD CURTAILMENT
617	22-Jan-21	MYSORE	66	HV2	AKKIHEBBAL_66	7:18	7:29	0:10	LOAD CURTAILMENT
618	22-Jan-21	MYSORE	66	HV1	BESAGARAHALLI_66	7:18	7:20	0:01	LOAD CURTAILMENT
619	22-Jan-21	MYSORE	66	HV1	BGNAGARA_66	7:20	7:24	0:04	LOAD CURTAILMENT
620	22-Jan-21	MYSORE	66	HV1	BGPURA_66	7:20	7:50	0:29	LOAD CURTAILMENT
621	22-Jan-21	MYSORE	66	HV1	BILIKERE_66	7:20	8:47	1:27	LOAD CURTAILMENT
622	22-Jan-21	MYSORE	66	HV2	BOOKANAKERE_66	7:18	7:24	0:06	LOAD CURTAILMENT
623	22-Jan-21	MYSORE	66	HV2	CHINAKURALI_66	7:20	8:12	0:52	LOAD CURTAILMENT
624	22-Jan-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	13:09	13:14	0:05	LINE FAULT
625	22-Jan-21	MYSORE	66	HV1	DODDINADUVADI_66	7:20	7:34	0:14	LOAD CURTAILMENT
626	22-Jan-21	MYSORE	66	HV2	DODDARAYAPET_66	7:20	7:30	0:09	LOAD CURTAILMENT
627	22-Jan-21	MYSORE	66	HV2	ELAVALA_66	7:18	7:25	0:06	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
628	22-Jan-21	MYSORE	66	HANAGODU-HUNSURU	HANAGODU_66	12:38	15:06	2:27	LINE CLEAR AVAILED
629	22-Jan-21	MYSORE	66	HANAGODU-PERİYAPATNA	HANAGODU_66	12:50	15:00	2:10	LINE CLEAR AVAILED
630	22-Jan-21	MYSORE	66	HV1	HANAGODU_66	7:20	7:31	0:11	LOAD CURTAILMENT
631	22-Jan-21	MYSORE	66	HV2	HANNUR_66	7:20	7:25	0:05	LOAD CURTAILMENT
632	22-Jan-21	MYSORE	66	HV2	HDKOTE_66	7:18	7:33	0:14	LOAD CURTAILMENT
633	22-Jan-21	MYSORE	66	HV2	JAIPUR_66	7:18	7:29	0:10	LOAD CURTAILMENT
634	22-Jan-21	MYSORE	66	HV1	KIADBMANDYA_66	11:58	12:05	0:06	MAIN SUPPLY FAILURE
635	22-Jan-21	MYSORE	66	HV2	KIRUGAVALU_66	7:20	7:51	0:31	LOAD CURTAILMENT
636	22-Jan-21	MYSORE	66	KIRUGAVALU-MALIYUR	KIRUGAVALU_66	8:50	14:33	5:43	LINE CLEAR AVAILED
637	22-Jan-21	MYSORE	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66	8:50	14:33	5:43	LINE CLEAR AVAILED
638	22-Jan-21	MYSORE	66	HV2	KMDODDI_66	7:19	7:53	0:33	LOAD CURTAILMENT
639	22-Jan-21	MYSORE	66	HV2	KOLLEGALA_66	7:18	7:24	0:06	LOAD CURTAILMENT
640	22-Jan-21	MYSORE	66	HV1	KRPET_66	7:20	7:27	0:06	LOAD CURTAILMENT
641	22-Jan-21	MYSORE	66	HV2	MALAVALLI_66	7:20	7:26	0:05	LOAD CURTAILMENT
642	22-Jan-21	MYSORE	66	HV1	NAGAMANGALA_66	7:20	7:23	0:03	LOAD CURTAILMENT
643	22-Jan-21	MYSORE	66	HV1	PANDAVAPURA_66	7:20	7:27	0:06	LOAD CURTAILMENT
644	22-Jan-21	MYSORE	66	HV1	RAMAPURA_MYS_66	7:20	7:24	0:03	LOAD CURTAILMENT
645	22-Jan-21	MYSORE	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)			LINE OPEN:LINE CLEAR AVAILED
646	22-Jan-21	MYSORE	66	HV1	SATHEGALA_66	7:21	7:59	0:38	LOAD CURTAILMENT
647	22-Jan-21	MYSORE	66	HV2	SATHEGALA_66	7:18	7:23	0:05	LOAD CURTAILMENT
648	22-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:21	7:50	0:28	LOAD CURTAILMENT
649	22-Jan-21	MYSORE	66	SR PATNA-METAGALLY	SRIRANGAPATNA_66	10:01	18:20	8:18	LINE CLEAR AVAILED
650	22-Jan-21	MYSORE	66	SR PATNA-G UKKADA	SRIRANGAPATNA_66	10:01	18:20	8:18	LINE CLEAR AVAILED
651	22-Jan-21	MYSORE	66	HV2	THALAKADU_66	7:21	7:40	0:18	LOAD CURTAILMENT
652	22-Jan-21	MYSORE	66	HV1	YELANDUR_66	7:18	7:25	0:06	LOAD CURTAILMENT
653	22-Jan-21	MYSORE	66	HV2	YELANDUR_66	7:25	7:35	0:10	LOAD CURTAILMENT
654	22-Jan-21	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	9:25	9:30	0:05	LINE FAULT
655	22-Jan-21	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:45	16:55	0:10	LINE FAULT
656	22-Jan-21	MYSORE	66	HV1	DUNDANAHALLI_66	10:00 (20/01/2021)	17:51(22.01.2021)	55:51HRS	TRANSFORMER CHARGED
657	22-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
658	22-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED
659	22-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE OPEN:LINE CLEAR AVAILED
660	22-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
661	22-Jan-21	TUMKUR	110	TR-3	AMMASANDRA_110	12:05:23 AM(22.01.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
662	22-Jan-21	TUMKUR	220	NEELAGUNDA220kV- GUTTUR 220kV	NEELAGUNDA_220	11:08	14:05	2:57	NFBC ISSUED
663	22-Jan-21	TUMKUR	220	NEELAGUNDA220kV- ITTAGI 220kV	NEELAGUNDA_220	12:29	12:43	0:13	HAND TRIPPED
664	22-Jan-21	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	8:07	8:20	0:12	LOAD CURTAILMENT
665	22-Jan-21	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	7:30	8:13	0:42	LOAD CURTAILMENT
666	22-Jan-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	6:58	7:08	0:09	LOAD CURTAILMENT
667	22-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	7:19	8:05	0:46	LOAD CURTAILMENT
668	22-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	8:03	8:30	0:27	LOAD CURTAILMENT
669	22-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	7:18	8:01	0:43	LOAD CURTAILMENT
670	22-Jan-21	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	7:18	8:06	0:47	LINE CLEAR AVAILED
671	22-Jan-21	TUMKUR	66	TR-1	DEVARAHALLI_66	7:18	8:06	0:47	LINE CLEAR AVAILED
672	22-Jan-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	12:08	12:45	0:36	LINE FAULT
673	22-Jan-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	9:26	11:07	1:40	LINE CLEAR AVAILED
674	22-Jan-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	1:54	2:15	0:20	LINE FAULT
675	22-Jan-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	7:02	7:06	0:03	HAND TRIPPED
676	22-Jan-21	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	12:42	14:10	1:28	LINE CLEAR AVAILED
677	22-Jan-21	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR IPP_66	BPCLSOLAR_IPP_66	7:13	7:20	0:07	LINE FAULT
678	22-Jan-21	TUMKUR	66	TR-1	KUKKAWADA_66	11:05	16:26	5:21	LINE CLEAR AVAILED
679	22-Jan-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	7:40	8:11	0:31	HAND TRIPPED
680	22-Jan-21	TUMKUR	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66	0:15	0:37	0:22	LINE CLEAR AVAILED
681	22-Jan-21	TUMKUR	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66	17:13	22:49	5:36	LINE CLEAR AVAILED
682	22-Jan-21	TUMKUR	66	TR-1	TUMKUR_66	8:14	9:56	1:42	LINE CLEAR AVAILED
683	22-Jan-21	TUMKUR	66	TR-1	TUMKUR_66	20:21	21:32	1:11	LINE CLEAR AVAILED
684	22-Jan-21	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANGERE	UCHCHANGIDURGA_66	15:25	15:52	0:27	MAIN SUPPLY FAILURE
685	22-Jan-21	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANGERE	UCHCHANGIDURGA_66	18:10	18:31	0:21	MAIN SUPPLY FAILURE
686	23-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
687	23-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
688	23-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
689	23-Jan-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
690	23-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED
691	23-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
692	23-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
693	23-Jan-21	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
694	23-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
695	23-Jan-21	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
696	23-Jan-21	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
697	23-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
698	23-Jan-21	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)	14:21 (23.01.2021)	137:18HRS	LINE CHARGED
699	23-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
700	23-Jan-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220 (STATION NOT AFFECTED)	9:45 (21.01.2021)			LINE OPEN:LINE CLEAR AVAILED
701	23-Jan-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	15:44 (21.01.2021)	14:36 (23.01.2021)	46:52HRS	LINE CHARGED
702	23-Jan-21	BAGALKOT	220	KUDUCHI-GHATAPRABHA(CKD1)	STATION NOT AFFECTED KUDUCHI_220	9:12 (21.01.2021)			LINE OPEN:LINE FAULT
703	23-Jan-21	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)			LINE OPEN:LINE FAULT
704	23-Jan-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)			LINE OPEN:LINE FAULT
705	23-Jan-21	BAGALKOT	110	HIDIKAL-ITANAL(RAIBAG)	HIDIKAL_110	17:08 (22.01.2021)			LINE OPEN:LINE CLEAR AVAILED
706	23-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220 (STATION NOT AFFECTED)	07:11	20:35	13:24	LINE CLEAR AVAILED
707	23-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 2	ATHANI_220 (STATION NOT AFFECTED)	07:11	20:36	13:25	LINE CLEAR AVAILED
708	23-Jan-21	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220 (STATION NOT AFFECTED)	14:13	14:20	0:07	LINE FAULT
709	23-Jan-21	BAGALKOT	220	CHIKKODI-MUDASHINGI(KOLHAPUR2)	STATION NOT AFFECTED CHIKKODI_220	10:20 (22.01.2021)	10:29 (23.01.2021)	24:09HRS	LINE CHARGED
710	23-Jan-21	BAGALKOT	220	220/110KV,HV2 & LV2	GADAG_220	10:21	17:42	7:21	LINE CLEAR AVAILED
711	23-Jan-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	13:11	13:16	0:05	TRANSFORMER FAULT
712	23-Jan-21	BAGALKOT	110	KUMATA-SIRSI1	KUMATA_110 (STATION NOT AFFECTED)	14:37	17:52	3:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
713	23-Jan-21	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	02:14	17:01	14:47	TRANSFORMER FAULT
714	23-Jan-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	14:20	17:17	2:57	LINE CLEAR AVAILED
715	23-Jan-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:23	17:26	0:03	HAND TRIPPED
716	23-Jan-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	14:20	17:30	3:10	LINE CLEAR AVAILED
717	23-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:26 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
718	23-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:30 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
719	23-Jan-21	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	15:25 (22.01.2021)	17:51 (23.01.2021)	26:26HRS	TRANSFORMER CHARGED
720	23-Jan-21	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	11:58	12:05	0:07	TRANSFORMER FAULT
721	23-Jan-21	BENGALURU	66	HV3	A STATION	09:18	09:20	00:02	LINE CLEAR AVAILED
722	23-Jan-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	09:29	09:34	00:05	LOAD CHANGE OVER
723	23-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	09:30	09:35	00:05	LOAD CHANGE OVER
724	23-Jan-21	BENGALURU	66	HV3	YARANDANAHALLI 220	09:18	09:20	00:02	LOAD CHANGE OVER
725	23-Jan-21	BENGALURU	66	HV2	SADLI	09:56	10:15	00:18	TRANSFORMER FAULT
726	23-Jan-21	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110	6:30(20.01.2021)			LINE OPEN:LINE FAULT
727	23-Jan-21	GULBARGA	110	VALKAMDINNI-RAICHUR2	VALKAMDINNI_110	6:50(21.01.2021)			MAIN SUPPLY FAILURE
728	23-Jan-21	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	05:42	06:00	00:18	LINE FAULT
729	23-Jan-21	GULBARGA	110	HV2	BELLARYSOUTH_110	19:00	22:36	03:36	LINE CLEAR AVAILED
730	23-Jan-21	GULBARGA	110	GABUR_DEODURGA	DEODURGA_110	08:50	08:55	00:05	LINE FAULT
731	23-Jan-21	GULBARGA	110	HV1	HANUMANAL_110	13:30	14:30	01:00	TRANSFORMER FAULT
732	23-Jan-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	05:45	05:54	00:09	LINE FAULT
733	23-Jan-21	GULBARGA	110	HV1	KURKUNTA_110	21:05	21:35	00:30	TRANSFORMER FAULT
734	23-Jan-21	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	8:40(23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
735	23-Jan-21	GULBARGA	110	SINDHNOOR-MUNIRABAD1	SINDHNOOR_220	09:10	09:20	00:10	LINE FAULT
736	23-Jan-21	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RADONA_110,SRNAGAR_110,M ALLAPURA_110	13:15	13:30	00:15	LINE FAULT
737	23-Jan-21	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KU RUDICROSS_110	23:38	23:48	00:10	LINE FAULT
738	23-Jan-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	20:06	20:16	00:10	LINE FAULT
739	23-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:23 (22.01.2021)	9:16 (23.01.2021)	9:52 hrs	LINE CHARGED
740	23-Jan-21	HASSAN	220	KADUR-DABUSET	KADUR_220	17:40 (22.01.2021)	18:02 (23.01.2021)	24:21 hrs	LINE CHARGED
741	23-Jan-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
742	23-Jan-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
743	23-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
744	23-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
745	23-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:59 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
746	23-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:30 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
747	23-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:41 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
748	23-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	11:30 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
749	23-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:41 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
750	23-Jan-21	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	08:57	14:21	05:24	LINE CLEAR AVAILED
751	23-Jan-21	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	08:57	14:36	05:39	LINE CLEAR AVAILED
752	23-Jan-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:36	11:38	00:02	HAND TRIPPED
753	23-Jan-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:09	20:37	02:28	LINE CLEAR AVAILED
754	23-Jan-21	HASSAN	110	JOG-JLT4	mghejog_gen	12:55	16:26	03:31	LINE CLEAR AVAILED
755	23-Jan-21	HASSAN	66	HV1	JUTTANAHALLI_66	09:07	09:11	00:04	TRANSFORMER FAULT
756	23-Jan-21	MYSORE	66	TUBINKERE-MANDYA2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	6:23	6:30	0:06	LINE FAULT
757	23-Jan-21	MYSORE	66	TUBINKERE-MANDYA4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	6:23	6:30	0:06	LINE FAULT
758	23-Jan-21	MYSORE	66	HV5	SFCSHIVA_66	10:10	12:05	1:54	LINE CLEAR AVAILED
759	23-Jan-21	MYSORE	66	HV1	JAKKANAHALLY_66	12:15	13:25	1:09	TRANSFORMER FAULT
760	23-Jan-21	MYSORE	66	CHANDAKAVADI-DODRAYPET	CHANDAKAVADI_66	17:06	17:18	0:11	LINE CLEAR AVAILED
761	23-Jan-21	MYSORE	66	HV2	MALAVALLI_66	10:15	17:46	7:31	LINE CLEAR AVAILED
762	23-Jan-21	MYSORE	66	DEVANOOR(NANJ)-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	23:55 (23/01/2021)			LINE OPEN:LINE FAULT
763	23-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
764	23-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED
765	23-Jan-21	MYSORE	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)			LINE OPEN:LINE CLEAR AVAILED
766	23-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
767	23-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
768	23-Jan-21	TUMKUR	110	TR-3	AMMASANDRA_110	12:05:23 AM(22.01.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
769	23-Jan-21	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66 HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:32	11:43	0:11	LINE FAULT
770	23-Jan-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:38	10:46	0:07	LINE FAULT
771	23-Jan-21	TUMKUR	66	TR-3	HARIYABBE_66	10:30	10:38	0:08	TRANSFORMER FAULT
772	23-Jan-21	TUMKUR	66	LINGADHALLI-CHANNAGIRI	LINGDHALLI_66	10:41	17:30	6:48	LINE CLEAR AVAILED
773	23-Jan-21	TUMKUR	66	TR-1	LINGDHALLI_66	10:05	18:08	8:03	LINE CLEAR AVAILED
774	23-Jan-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	10:41	17:30	6:48	LINE CLEAR AVAILED
775	23-Jan-21	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	8:09	8:23	0:13	LINE FAULT
776	23-Jan-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	17:50	17:52	0:02	MAIN SUPPLY FAILURE
777	23-Jan-21	TUMKUR	66	TR-1	TUMKUR_66	11:00	17:55	6:55	LINE CLEAR AVAILED
778	23-Jan-21	TUMKUR	66	TR-2	TUMKUR_66	11:00	17:55	6:55	LINE CLEAR AVAILED
779	24-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
780	24-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
781	24-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
782	24-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
783	24-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED
784	24-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
785	24-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
786	24-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
787	24-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
788	24-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
789	24-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
790	24-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
791	24-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
792	24-Jan-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220 (STATION NOT AFFECTED)	9:45 (21.01.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
793	24-Jan-21	BAGALKOT	220	KUDUCHI-GHATAPRABHA(CKD1)	STATION NOT AFFECTED KUDUCHI_220	9:12 (21.01.2021)			LINE OPEN:LINE FAULT
794	24-Jan-21	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)			LINE OPEN:LINE FAULT
795	24-Jan-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)			LINE OPEN:LINE FAULT
796	24-Jan-21	BAGALKOT	110	HIDIKAL-ITANAL(RAIBAG)	HIDIKAL_110	17:08 (22.01.2021)			LINE OPEN:LINE CLEAR AVAILED
797	24-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:26 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
798	24-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:30 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
799	24-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220 (STATION NOT AFFECTED)	07:35	19:23	11:48	LINE CLEAR AVAILED
800	24-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 2	ATHANI_220 (STATION NOT AFFECTED)	07:35	19:23	11:48	LINE CLEAR AVAILED
801	24-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220 (STATION NOT AFFECTED)	19:38 (24.01.2020)			LINE OPEN:LINE FAULT
802	24-Jan-21	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	09:27	11:48	2:21	LINE CLEAR AVAILED
803	24-Jan-21	BAGALKOT	110	110/11KV,HV1	GOKAK_110	13:01	13:25	0:24	LINE CLEAR AVAILED
804	24-Jan-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	17:01	17:06	0:05	TRANSFORMER FAULT
805	24-Jan-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	17:07	17:24	0:17	TRANSFORMER FAULT
806	24-Jan-21	BAGALKOT	110	110/11KV,HV2	KUD DHRWAD_110	19:05	19:53	0:48	TRANSFORMER FAULT
807	24-Jan-21	BAGALKOT	110	KUMATA-SIRSI1	KUMATA_110 (STATION NOT AFFECTED)	11:32	18:05	6:33	LINE CLEAR AVAILED
808	24-Jan-21	BAGALKOT	110	VAJRAMATTI220- MUDHOL	MUDHOL_110	10:24	10:34	0:10	LINE CLEAR AVAILED
809	24-Jan-21	BAGALKOT	110	UTTUR- MUDHOL	MUDHOL_110	10:11	13:16	3:05	NFBC ISSUED
810	24-Jan-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	2:51	2:59	0:08	TRANSFORMER FAULT
811	24-Jan-21	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMAWAD_33, IE_33	9:29	9:50	0:21	TRANSFORMER FAULT
812	24-Jan-21	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	11:38	12:09	0:31	TRANSFORMER FAULT
813	24-Jan-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	07:36	07:59	00:23	LOAD CHANGE OVER
814	24-Jan-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	09:48	11:08	01:20	LINE CLEAR AVAILED
815	24-Jan-21	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGANATHPURA	ELECTRONIC CITY P2 S1	08:15	08:21	00:06	LINE FAULT
816	24-Jan-21	BENGALURU	66	HV1	HANUMANTHNAGARA	11:02	11:12	00:10	TRANSFORMER FAULT
817	24-Jan-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	11:33	11:43	00:10	MAIN SUPPLY FAILURE
818	24-Jan-21	BENGALURU	66	HENNUR CROSS - MANYATHA TECH PARK 220	HENNUR CROSS	12:42	12:50	00:08	LOAD CHANGE OVER
819	24-Jan-21	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	09:50	10:02	00:12	LOAD CHANGE OVER
820	24-Jan-21	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	18:04	18:09	00:05	LOAD CHANGE OVER
821	24-Jan-21	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK	12:38	12:48	00:10	LINE CLEAR AVAILED
822	24-Jan-21	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA	09:35	09:46	00:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
823	24-Jan-21	BENGALURU	66	REMCO - NRS	NO STATION AFFECTED	16:15	17:46	01:31	LINE FAULT
824	24-Jan-21	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	09:54	09:59	00:05	LOAD CHANGE OVER
825	24-Jan-21	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:54	18:00	00:06	LOAD CHANGE OVER
826	24-Jan-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	09:46	10:00	00:14	LOAD CHANGE OVER
827	24-Jan-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	18:02	18:09	00:07	LOAD CHANGE OVER
828	24-Jan-21	BENGALURU	66	HV1	VIJAYANAGARA	16:17	16:24	00:07	MAIN SUPPLY FAILURE
829	24-Jan-21	BENGALURU	66	HV1	VIJAYANAGARA	17:46	17:51	00:05	LOAD CHANGE OVER
830	24-Jan-21	BENGALURU	66	HV1	ATTIBELE	15:56	16:05	00:09	LINE CLEAR AVOIDED
831	24-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	06:36	10:55	04:19	LINE FAULT
832	24-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	06:36	07:19	00:43	LINE FAULT
833	24-Jan-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ATTIBELE, ANEKAL	06:36	07:20	00:44	LINE FAULT
834	24-Jan-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	13:48	13:58	00:09	LINE FAULT
835	24-Jan-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	10:20	11:00	00:40	LINE FAULT
836	24-Jan-21	BENGALURU	66	HV1	MUDIYANUR	16:43	16:49	00:06	TRANSFORMER FAULT
837	24-Jan-21	BENGALURU	66	HV1	MUDIYANUR	19:25	19:32	00:07	TRANSFORMER FAULT
838	24-Jan-21	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110	6:30(20.01.2021)			LINE OPEN:LINE FAULT
839	24-Jan-21	GULBARGA	110	VALKAMDINNI-RAICHUR2	VALKAMDINNI_110	6:50(21.01.2021)			MAIN SUPPLY FAILURE
840	24-Jan-21	GULBARGA	400	RTPS-MEHBOOBNAGAR	MEHBOOBNAGAR_400	19:15(24.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
841	24-Jan-21	GULBARGA	220	LINGAPUR-MRB TR1	MUNIRABAD_220	13:43	15:47	02:04	LINE FAULT
842	24-Jan-21	GULBARGA	220	LINGAPUR-GUDDAHALLI2	GUDDAHALLI_400	13:43	16:00	02:17	LINE FAULT
843	24-Jan-21	GULBARGA	220	LINGAPUR-JVSL2	JINDAL_220	13:43	16:51	03:08	LINE FAULT
844	24-Jan-21	GULBARGA	220	LINGAPUR-JVSL1	JINDAL_220	13:43	17:02	03:19	LINE FAULT
845	24-Jan-21	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	20:13	20:54	00:41	LINE FAULT
846	24-Jan-21	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	8:40(23.01.2021)	21:06(24.01.2021)	36:26HRS	LINE CHARGED
847	24-Jan-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFACTORY,CHOWDAPUR_110	06:24	06:29	00:05	LINE FAULT
848	24-Jan-21	GULBARGA	110	RAICHUR-SINDHNOOR2	MANVI_110,MADLAPUR_110,KURUDICROSS_110	21:27	21:35	00:08	LINE FAULT
849	24-Jan-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IP	19:15	19:25	00:10	LINE FAULT
850	24-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:08	21:18	00:10	LINE FAULT
851	24-Jan-21	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURUDICROSS_110	03:55	04:15	00:20	LINE FAULT
852	24-Jan-21	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURUDICROSS_110	04:55	05:05	00:10	LINE FAULT
853	24-Jan-21	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	00:01	00:06	00:05	LINE FAULT
854	24-Jan-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	03:05	03:10	00:05	LINE FAULT
855	24-Jan-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	19:59	20:17	00:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
856	24-Jan-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:32	20:40	00:08	LINE FAULT
857	24-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:30 (23.01.2021)	22:03 (24.01.2021)	34:32 hrs	LINE CHARGED
858	24-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:41 (23:01.2021)	21:35 (24.01.2021)	33:53 hrs	LINE CHARGED
859	24-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	11:30 (23.01.2021)	22:03 (24.01.2021)	34:32 hrs	LINE CHARGED
860	24-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:41 (23:01.2021)	21:35 (24.01.2021)	33:53 hrs	LINE CHARGED
861	24-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
862	24-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
863	24-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
864	24-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
865	24-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:59 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
866	24-Jan-21	HASSAN	220	KADUR-DABUSET	KADUR_220	09:13	17:57	08:44	LINE CLEAR AVAILED
867	24-Jan-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	17:36	21:03	03:27	LINE CLEAR AVAILED
868	24-Jan-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:04	13:12	02:08	LINE CLEAR AVAILED
869	24-Jan-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	11:04	13:12	02:08	LINE CLEAR AVAILED
870	24-Jan-21	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	10:04	14:33	04:29	LINE CLEAR AVAILED
871	24-Jan-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:35	13:24	02:49	LINE CLEAR AVAILED
872	24-Jan-21	HASSAN	66	LV1	HASSAN_220	10:49	13:06	02:17	LINE CLEAR AVAILED
873	24-Jan-21	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:29	13:25	02:56	LINE CLEAR AVAILED
874	24-Jan-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:29	13:23	02:54	LINE CLEAR AVAILED
875	24-Jan-21	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	10:44	13:21	02:37	LINE CLEAR AVAILED
876	24-Jan-21	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	10:44	13:21	02:37	LINE CLEAR AVAILED
877	24-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	10:00	14:48	04:48	MAIN SUPPLY FAILURE
878	24-Jan-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:20	13:34	00:14	MAIN SUPPLY FAILURE
879	24-Jan-21	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	10:09	14:26	04:17	LINE CLEAR AVAILED
880	24-Jan-21	HASSAN	66	GORUR-HASSAN	GORUR_66	10:09	14:26	04:17	LINE CLEAR AVAILED
881	24-Jan-21	HASSAN	66	HV1	GORUR_66	10:09	14:41	04:32	LINE CLEAR AVAILED
882	24-Jan-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	13:15	13:29	00:14	LINE FAULT
883	24-Jan-21	HASSAN	66	HV2	HOLEHONNUR_66	14:24	14:56	00:32	LINE CLEAR AVAILED
884	24-Jan-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:16	13:34	00:18	MAIN SUPPLY FAILURE
885	24-Jan-21	HASSAN	66	MALALI-HASSAN	MALALI_66	13:29	13:31	10:31	MAIN SUPPLY FAILURE
886	24-Jan-21	HASSAN	66	HV1	MALALI_66	13:16	13:33	00:17	MAIN SUPPLY FAILURE
887	24-Jan-21	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	10:29	14:47	04:18	MAIN SUPPLY FAILURE
888	24-Jan-21	HASSAN	66	HV1	MALLIPATNA_66	12:22	15:06	02:44	MAIN SUPPLY FAILURE
889	24-Jan-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:24	14:49	04:25	MAIN SUPPLY FAILURE
890	24-Jan-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:34	10:45	00:11	HAND TRIPPED
891	24-Jan-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	13:11	13:32	00:21	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
892	24-Jan-21	HASSAN	66	HV1	YESLUR_66	10:10	14:14	04:04	MAIN SUPPLY FAILURE
893	24-Jan-21	HASSAN	66	YESLUR-SNVRST	YESLUR_66	10:06	14:14	04:08	MAIN SUPPLY FAILURE
894	24-Jan-21	MYSORE	66	TUBINKERE-MANDYA 2	NO STATION EFFECTED	15:06	16:43	1:37	LINE CLEAR AVAILED
895	24-Jan-21	MYSORE	66	TUBINKERE-MANDYA 4	NO STATION EFFECTED	16:44	18:16	1:32	LINE CLEAR AVAILED
896	24-Jan-21	MYSORE	66	TUBINKERE-NAGAMGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:49	16:57	0:08	LINE FAULT
897	24-Jan-21	MYSORE	66	SHANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	10:22	14:27	4:05	LINE CLEAR AVAILED
898	24-Jan-21	MYSORE	66	SHANIVARSANTHE-YESSLUR	SANIVARASANTHE_66	10:22	15:01	4:39	LINE CLEAR AVAILED
899	24-Jan-21	MYSORE	66	KR PETE 220KV-BOOKANKERE	BANANGADI_66 BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66	10:34	10:45	0:10	LINE FAULT
900	24-Jan-21	MYSORE	66	DUNDANALLY-HULIYURDURGA	DUNDANAHALLI_66	10:00	12:39	2:39	LINE CLEAR AVAILED
901	24-Jan-21	MYSORE	66	NANJANGUDU-SINDUVALLY	NO STATION EFFECTED	8:43	12:12	3:28	NFBC ISSUED
902	24-Jan-21	MYSORE	66	HV2	AKKIEBBAL_66	18:06	18:18	0:12	TRANSFORMER FAULT
903	24-Jan-21	MYSORE	66	VAJMANGALA-JYOTHINAGARA	FTS_66 JYOTHINAGARA_66	6:36	6:47	0:11	LINE FAULT
904	24-Jan-21	MYSORE	66	VAJMANGALA-DEVNOOR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	6:50	7:16	0:26	LINE FAULT
905	24-Jan-21	MYSORE	66	MADHUVANALLY-KUNTHUR	NO STATION EFFECTED	13:32	13:38	0:06	LINE FAULT
906	24-Jan-21	MYSORE	66	DEVANOOR(NANJ)-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	23:55 (23/01/2021)	00:03(24.01.2021)	00:08 HRS	LINE CHARGED
907	24-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
908	24-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED
909	24-Jan-21	MYSORE	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)			LINE OPEN:LINE CLEAR AVAILED
910	24-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
911	24-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
912	24-Jan-21	TUMKUR	110	TR-3	AMMASANDRA_110	00:05:23(22.01.2021)	14:53:17(24.01.2021)	38:48HRS	TRANSFORMER CHARGED
913	24-Jan-21	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR IPP_66	ADAN SOLAR_IPP_66	18:02	19:07	1:04	LINE FAULT
914	24-Jan-21	TUMKUR	110	HONNAVALLI 110- ARASIKERE	HONNAVALLI_110	18:10	18:50	0:40	HAND TRIPPED
915	24-Jan-21	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110, HUNSEGHATTA_110	18:22	18:47	0:25	HAND TRIPPED
916	24-Jan-21	TUMKUR	66	TR-1	BELADARA_66	13:38	13:43	0:04	LINE CLEAR AVAILED
917	24-Jan-21	TUMKUR	66	TR-1	CHIKKABANAGERE-66	12:21	12:45	0:24	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
918	24-Jan-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:31	7:35	0:04	LINE FAULT
919	24-Jan-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	7:31	7:35	0:04	LINE FAULT
920	24-Jan-21	TUMKUR	66	TR-1	KUKKAWADA_66	16:27	18:09	1:42	LINE CLEAR AVAILED
921	24-Jan-21	TUMKUR	66	TR-2	MATHOD_66	23:26	23:30	0:04	TRANSFORMER FAULT
922	24-Jan-21	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	10:25	10:34	0:08	LINE FAULT
923	24-Jan-21	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	15:12	15:20	0:08	LINE FAULT
924	24-Jan-21	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	18:12	18:29	0:17	LINE FAULT
925	24-Jan-21	TUMKUR	66	TR-1	SASALUHALLA_66	3:02	3:08	0:05	TRANSFORMER FAULT
926	24-Jan-21	TUMKUR	66	TR-1	SASALUHALLA_66	15:47	15:51	0:03	TRANSFORMER FAULT
927	24-Jan-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	7:01	7:05	0:04	TRANSFORMER FAULT
928	24-Jan-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	8:45	8:48	0:02	TRANSFORMER FAULT
929	24-Jan-21	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	10:07	10:26	0:18	LINE FAULT
930	25-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
931	25-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
932	25-Jan-21	BAGALKOT	110	110/11KV,HV1	BILAGI_110	20:03	21:41	1:38	LINE CLEAR AVAILED
933	25-Jan-21	BAGALKOT	110	110/11KV,HV2	THORVI_110	10:50	11:08	0:18	TRANSFORMER FAULT
934	25-Jan-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	23:08	23:32	0:24	TRANSFORMER FAULT
935	25-Jan-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110 (STATION NOT AFFECTED)	13:32	14:43	1:11	LINE CLEAR AVAILED
936	25-Jan-21	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_110 (STATION NOT AFFECTED)	23:49 (25.01.2021)			LINE OPEN:LINE FAULT
937	25-Jan-21	BAGALKOT	110	ENERCON1- SOUDATTI	SOUDATTI_110	7:02	9:45	2:43	LINE FAULT
938	25-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
939	25-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
940	25-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
941	25-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
942	25-Jan-21	BAGALKOT	110	HIDIKAL-ITANAL(RAIBAG)	HIDIKAL_110	17:08 (22.01.2021)	12:02 (25.01.2021)	66:54 hrs	LINE CHARGED
943	25-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
944	25-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
945	25-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
946	25-Jan-21	BAGALKOT	110	KUDACHI220- AINAPUR	AINAPUR_110	13:35	14:37	1:02	LINE CLEAR AVOIDED
947	25-Jan-21	BAGALKOT	110	KUMATA- SIRSI1&2	KUMTA_110	10:52	15:49	4:57	LINE CLEAR AVOIDED
948	25-Jan-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
949	25-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
950	25-Jan-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
951	25-Jan-21	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	10:38	12:55	2:17	LINE CLEAR AVOIDED
952	25-Jan-21	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	01:23	12:55	11:32	LINE FAULT
953	25-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220 (STATION NOT AFFECTED)	19:38 (24.01.2020)	11:57 (25.01.2021)	15:19	LINE FAULT
954	25-Jan-21	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220 (STATION NOT AFFECTED)	12:13	12:53	0:40	HAND TRIPPED
955	25-Jan-21	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220 (STATION NOT AFFECTED)	9:45 (21.01.2021)			LINE OPEN:LINE CLEAR AVAILED
956	25-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
957	25-Jan-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)			LINE OPEN:LINE FAULT
958	25-Jan-21	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)			LINE OPEN:LINE FAULT
959	25-Jan-21	BAGALKOT	220	KUDUCHI-GHATAPRABHA(CKD1)	STATION NOT AFFECTED KUDUCHI_220	9:12 (21.01.2021)			LINE OPEN:LINE FAULT
960	25-Jan-21	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	02:15	15:13	12:58	LINE FAULT
961	25-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:30 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
962	25-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:26 (23.01.2021)			LINE OPEN:LINE CLEAR AVAILED
963	25-Jan-21	BENGALURU	66	DG1	DB PURA 220	06:39	06:53	00:14	LINE FAULT
964	25-Jan-21	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK, KACHMARANAHALLI	00:42	01:12	00:30	LINE CLEAR AVOIDED
965	25-Jan-21	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK, KACHMARANAHALLI	07:40	07:46	00:06	LOAD CHANGE OVER
966	25-Jan-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	00:42	01:12	00:30	LINE CLEAR AVOIDED
967	25-Jan-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	18:45	18:55	00:10	LINE CLEAR AVOIDED
968	25-Jan-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	07:40	07:50	00:10	LOAD CHANGE OVER
969	25-Jan-21	BENGALURU	66	HAL 220 - ADUGODI 2	NO STATION AFFECTED	06:53	07:21	00:28	LINE FAULT
970	25-Jan-21	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	20:42	20:49	00:07	LINE CLEAR AVOIDED
971	25-Jan-21	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	00:42	04:15	03:33	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
972	25-Jan-21	BENGALURU	66	HV1	ATTIBELE	10:25	10:30	00:05	LINE CLEAR AVAILED
973	25-Jan-21	BENGALURU	66	HV1	BANGARPET	16:25	17:07	00:42	LINE CLEAR AVAILED
974	25-Jan-21	BENGALURU	66	HV1	HAROBEL	15:15	15:48	00:32	LINE CLEAR AVAILED
975	25-Jan-21	BENGALURU	66	HV1	MITTEMARI 220	16:05	17:15	01:10	LINE CLEAR AVAILED
976	25-Jan-21	BENGALURU	66	HV1	MUDIYANUR	11:35	11:40	00:04	TRANSFORMER FAULT
977	25-Jan-21	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	16:44	16:50	00:06	TRANSFORMER FAULT
978	25-Jan-21	BENGALURU	66	HV2	GOKULA	12:02	12:04	00:02	LINE CLEAR AVAILED
979	25-Jan-21	BENGALURU	66	HV2	HOODY 220	00:42	02:44	02:02	LINE CLEAR AVAILED
980	25-Jan-21	BENGALURU	66	HV2	MANCHENAHALLI	07:51	07:57	00:05	TRANSFORMER FAULT
981	25-Jan-21	BENGALURU	66	HV3	DIVYASHREE TECH PARK	23:54(25/01/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
982	25-Jan-21	BENGALURU	66	IISC - HEBBAL 220	IISC	20:42	21:14	00:32	MAIN SUPPLY FAILURE
983	25-Jan-21	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK, NGEF, NGEF(EHT)	00:42	01:18	00:36	LINE CLEAR AVAILED
984	25-Jan-21	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	00:42	01:18	00:36	LINE CLEAR AVAILED
985	25-Jan-21	BENGALURU	66	ITI 220 - ITI 66	ITI 66	00:42	01:18	00:36	LINE CLEAR AVAILED
986	25-Jan-21	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	00:42	01:18	00:36	LINE CLEAR AVAILED
987	25-Jan-21	BENGALURU	66	KODIGEHALLI - TAVAREKERE	TAVAREKERE	11:43	14:39	02:56	LINE CLEAR AVAILED
988	25-Jan-21	BENGALURU	66	KODIGEHALLI - TAVAREKERE	TAVAREKERE	18:18	18:20	00:02	LINE CLEAR AVAILED
989	25-Jan-21	BENGALURU	220	EPIP 220 - ITPL(EHT) 220	EPIP 220	00:42	01:12	00:30	MAIN SUPPLY FAILURE
990	25-Jan-21	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	20:42	20:48	00:06	LINE FAULT
991	25-Jan-21	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	00:42	14:17	13:35	LINE CLEAR AVAILED
992	25-Jan-21	BENGALURU	220	HOODY 220 - ITI 220	NO STATION AFFECTED	00:42	04:58	04:16	LINE CLEAR AVAILED
993	25-Jan-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	00:42	14:17	13:35	LINE CLEAR AVAILED
994	25-Jan-21	BENGALURU	220	HOODY 400 - ITPL 2	NO STATION AFFECTED	00:42	05:33	04:51	LINE FAULT
995	25-Jan-21	BENGALURU	220	HV2	EPIP 220	18:45	18:52	00:07	TRANSFORMER FAULT
996	25-Jan-21	BENGALURU	220	HV2	HOODY 220	00:42	02:41	01:59	LINE CLEAR AVAILED
997	25-Jan-21	BENGALURU	220	ITI 220 - HOODY 220	ITI 220	00:42	01:17	00:35	MAIN SUPPLY FAILURE
998	25-Jan-21	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	NO STATION AFFECTED	20:46	23:15	02:29	LINE FAULT
999	25-Jan-21	BENGALURU	400	HOODY 400 - NELAMANGALA 2	NO STATION AFFECTED	00:42	08:26	07:44	LINE FAULT
1000	25-Jan-21	BENGALURU	400	HV2	HOODY 400	00:42	03:13	02:31	TRANSFORMER FAULT
1001	25-Jan-21	GULBARGA	66	ITTAGI-HANASI	HANASI_66	11:15	11:20	00:05	LINE FAULT
1002	25-Jan-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	03:25	03:36	00:11	MAIN SUPPLY FAILURE
1003	25-Jan-21	GULBARGA	110	HATTI-SOMNAMARDI_ IPP	HATTI_110	03:27	03:46	00:19	LINE FAULT
1004	25-Jan-21	GULBARGA	110	HV1	KURKUNTA_110	20:10	21:50	01:40	TRANSFORMER FAULT
1005	25-Jan-21	GULBARGA	110	HV2	BISIHALLI_110	07:00	18:50	11:50	LINE CLEAR AVAILED
1006	25-Jan-21	GULBARGA	110	HV2	SANKLAPUR_110	07:05	07:15	00:10	TRANSFORMER FAULT
1007	25-Jan-21	GULBARGA	110	HV3	VALKAMDINNI_110	12:59	13:09	00:10	LINE CLEAR AVAILED
1008	25-Jan-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	02:41	02:51	00:10	LINE FAULT
1009	25-Jan-21	GULBARGA	110	MASKI-LINGASUGUR	MASKI_110	03:28	03:38	00:10	MAIN SUPPLY FAILURE
1010	25-Jan-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	05:18	05:25	00:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1011	25-Jan-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	05:27	05:42	00:15	LINE FAULT
1012	25-Jan-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:00	19:12	00:12	LINE FAULT
1013	25-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	14:07	14:45	00:38	LINE CLEAR AVAILED
1014	25-Jan-21	GULBARGA	110	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	03:28	04:10	00:42	LINE FAULT
1015	25-Jan-21	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	12:02	13:41	01:39	LINE CLEAR AVAILED
1016	25-Jan-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	03:27	07:20	03:53	LINE FAULT
1017	25-Jan-21	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	03:27	04:24	00:57	LINE FAULT
1018	25-Jan-21	GULBARGA	400	RTPS-MEHBOOBNAGAR	MEHBOOBNAGAR_400	19:15(24.01.2021)	11:27(25.01.2021)	16:12 hrs	LINE CHARGED
1019	25-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	01:55	02:11	00:16	LINE FAULT
1020	25-Jan-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	04:13	04:36	00:23	LINE FAULT
1021	25-Jan-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:09	18:31	08:22	MAIN SUPPLY FAILURE
1022	25-Jan-21	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1023	25-Jan-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	08:51	09:01	00:10	TRANSFORMER FAULT
1024	25-Jan-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:09	18:42	08:33	MAIN SUPPLY FAILURE
1025	25-Jan-21	HASSAN	66	HV1	JUTTANAHALLI_66	13:04	13:19	00:15	TRANSFORMER FAULT
1026	25-Jan-21	HASSAN	66	HV2	HOLEHONNUR_66	10:29	12:09	01:40	LINE CLEAR AVAILED
1027	25-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1028	25-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1029	25-Jan-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:07	11:49	01:42	LINE CLEAR AVAILED
1030	25-Jan-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	04:12	04:38	00:26	LINE FAULT
1031	25-Jan-21	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	10:10	11:50	01:40	MAIN SUPPLY FAILURE
1032	25-Jan-21	HASSAN	110	HV2	HALADY-110	08:49	09:00	00:11	TRANSFORMER FAULT
1033	25-Jan-21	HASSAN	110	HV2	ARASIKERE_110	10:50	14:10	03:20	LINE CLEAR AVAILED
1034	25-Jan-21	HASSAN	110	HV2	ARASIKERE_110	14:25	15:50	01:25	LINE CLEAR AVAILED
1035	25-Jan-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:51	13:01	02:10	NFBC ISSUED
1036	25-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1037	25-Jan-21	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	00:20	12:28	12:08	LINE FAULT
1038	25-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	0:30(25.01.2021)			LINE OPEN:LINE FAULT
1039	25-Jan-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:59 (23.01.2021)	7:06 (25.01.2021)	31:06 hrs	LINE CHARGED
1040	25-Jan-21	MYSORE	66	HV1	FTS_66	10:10	17:00	6:50	LINE CLEAR AVAILED
1041	25-Jan-21	MYSORE	66	HV1	JAKKANAHALLY_66	11:55	12:35	0:39	LINE CLEAR AVAILED
1042	25-Jan-21	MYSORE	66	HV1	JAKKANAHALLY_66	14:24	14:27	0:02	HAND TRIPPED
1043	25-Jan-21	MYSORE	66	HV1	NAGAMANGALA_66	18:30	18:43	0:13	LINE CLEAR AVAILED
1044	25-Jan-21	MYSORE	66	HV1	SANTHEMARAHALLI_66	13:20	14:30	1:10	LINE CLEAR AVAILED
1045	25-Jan-21	MYSORE	66	HV2	HDKOTE_66	17:32	18:09	0:37	LINE CLEAR AVAILED
1046	25-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:03	16:12	4:08	LINE CLEAR AVAILED
1047	25-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	16:18	16:41	0:23	LINE CLEAR AVAILED
1048	25-Jan-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1049	25-Jan-21	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	6:41	6:48	0:06	LINE FAULT
1050	25-Jan-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1051	25-Jan-21	MYSORE	66	MADHUVANAHALLY-HEBBANI	NO STATION EFFECTED	17:38	17:45	0:06	LINE FAULT
1052	25-Jan-21	MYSORE	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1053	25-Jan-21	MYSORE	66	TN PURA-THAYURU	TNARASIPURA_66	16:10	16:15	0:05	HAND TRIPPED
1054	25-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	11:31	12:59	1:27	LINE CLEAR AVAILED
1055	25-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	12:59	14:54	1:55	LINE FAULT
1056	25-Jan-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALI_66	17:11	18:35	1:23	LINE CLEAR AVAILED
1057	25-Jan-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:03	17:39	0:35	LINE FAULT
1058	25-Jan-21	TUMKUR	66	RANGANATHAPURA- WLSPTSOLAR2	WELSPUN SOLAR2 _IPP_66	15:17	17:16	1:58	LINE FAULT
1059	25-Jan-21	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	15:15	15:49	0:34	LINE CLEAR AVAILED
1060	25-Jan-21	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	18:08	18:14	0:05	LINE FAULT
1061	25-Jan-21	TUMKUR	66	SHYLAPURA-PR PURA	SHYLAPURA_66	15:11	15:49	0:38	LINE CLEAR AVAILED
1062	25-Jan-21	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	18:25	18:29	0:03	LINE FAULT
1063	25-Jan-21	TUMKUR	66	TR-1	HEGGERE_66	13:32	14:20	0:48	LINE CLEAR AVAILED
1064	25-Jan-21	TUMKUR	66	TR-1	MAVINAKATTE_66	10:25	10:26	0:01	TRANSFORMER FAULT
1065	25-Jan-21	TUMKUR	66	TR-1	MAVINAKATTE_66	10:49	10:52	0:02	TRANSFORMER FAULT
1066	25-Jan-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	15:41	16:05	0:24	LINE CLEAR AVAILED
1067	25-Jan-21	TUMKUR	66	TR-1	TUMKUR_66	11:37	12:04	0:27	TRANSFORMER FAULT
1068	25-Jan-21	TUMKUR	66	TR-1	TUMKUR_66	14:39	14:58	0:19	TRANSFORMER FAULT
1069	25-Jan-21	TUMKUR	66	TR-2	BALENAHALI_66	07:20	07:32	0:11	TRANSFORMER FAULT
1070	25-Jan-21	TUMKUR	66	TR-2	MATHOD_66	09:01	09:06	0:04	TRANSFORMER FAULT
1071	25-Jan-21	TUMKUR	66	TR-2	MATHOD_66	10:56	11:02	0:05	TRANSFORMER FAULT
1072	25-Jan-21	TUMKUR	66	TR-2	SHYLAPURA_66	15:12	15:50	0:37	LINE CLEAR AVAILED
1073	25-Jan-21	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR_110	06:37	07:05	0:27	LINE FAULT
1074	25-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE OPEN:LINE CLEAR AVAILED
1075	25-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED