

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM :01.06.21 TO 07.06.2021**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	1-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
2	1-Jun-2021	BAGALKOT	110	110/11KV,HV1	ARGA_110	10:00	10:58	0:58	TRANSFORMER FAULT
3	1-Jun-2021	BAGALKOT	110	110/11KV,HV1	KALAGATAGI_110	19:26	19:27	0:01	TRANSFORMER FAULT
4	1-Jun-2021	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED	12:18	12:48	0:30	LINE CLEAR AVAILED
5	1-Jun-2021	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	11:37	12:28	0:51	LINE CLEAR AVAILED
6	1-Jun-2021	BAGALKOT	110	110/33KV,HV1	THOUSHI_33	12:42	14:07	1:25	LINE CLEAR AVAILED
7	1-Jun-2021	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED	18:22	19:32	1:10	TRANSFORMER FAULT
8	1-Jun-2021	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	10:00	10:50	0:50	LINE FAULT
9	1-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	1-Jun-2021	BAGALKOT	110	BELLATTI-AB SOLAR	AB SOLAR_110	15:28	17:17	1:49	LINE CLEAR AVAILED
11	1-Jun-2021	BAGALKOT	110	BELLATTI-ENERCON2	ENERCON_110	15:28	17:17	1:49	LINE CLEAR AVAILED
12	1-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
13	1-Jun-2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED	10:56	14:01	3:05	LINE CLEAR AVAILED
14	1-Jun-2021	BAGALKOT	110	KARWAR-ARGA	STATION NOT AFFECTED	10:36	13:27	2:51	LINE FAULT
15	1-Jun-2021	BAGALKOT	110	KARWAR-SOLARIS(BINAGA)	KARWAR_110	10:58	13:28	2:30	LINE CLEAR AVAILED
16	1-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	STATION NOT AFFECTED	19:41(25.05.2020)			LINE OPEN,LINE FAULT
17	1-Jun-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	19:00	19:27	0:27	LINE CLEAR AVAILED
18	1-Jun-2021	BAGALKOT	110	KANBELEINOR220- HONNATTI (ADEMALLADUR)	NO STATION AFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
19	1-Jun-2021	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	STATION NOT AFFECTED	15:25	15:45	0:20	HAND TRIPPED
20	1-Jun-2021	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	STATION NOT AFFECTED	14:52(31.05.2021)	0:20(01.06.2021)	9:28 HRS	LINE CHARGED
21	1-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED	18:07(18.05.2021)			LINE OPEN,LINE FAULT
22	1-Jun-2021	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 2	STATION NOT AFFECTED	11:03	16:22	5:19	LINE CLEAR AVAILED
23	1-Jun-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED	10:39	13:54	3:15	LINE CLEAR AVAILED
24	1-Jun-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED	1:55	13:55	12:00	NFBC ISSUED
25	1-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	CHIKKODI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
26	1-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED	17:22(30.03.2021)			LINE OPEN,LINE FAULT
27	1-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
28	1-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
29	1-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
30	1-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
31	1-Jun-2021	BENGALURU	66	DODDALAHALLI - SOLAR IPP	VAJRAMATTI_220	18:53	19:07	0:14	LINE FAULT
32	1-Jun-2021	BENGALURU	66	HV1	NO STATION AFFECTED	15:56	15:59	0:03	TRANSFORMER FAULT
33	1-Jun-2021	BENGALURU	66	HV2	MITTEMARI 220	10:20	10:30	0:10	LINE CLEAR AVAILED
34	1-Jun-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	GUNDAMGERE	18:58	19:09	0:11	LINE FAULT
35	1-Jun-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	HODKONDA, KODIHALLI, HUNGENAHALLI, HAROBELE	4:59	5:33	0:34	MAIN SUPPLY FAILURE
36	1-Jun-2021	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	ANJANAPURA	4:59	5:34	0:35	MAIN SUPPLY FAILURE
37	1-Jun-2021	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	BTM 4TH PHASE	4:59	5:37	0:38	MAIN SUPPLY FAILURE
38	1-Jun-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	ELITE PROMENEDE	13:55	14:26	0:31	LINE CLEAR AVAILED
39	1-Jun-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	BANGARPET	13:29	14:19	0:50	LINE CLEAR AVAILED
40	1-Jun-2021	BENGALURU	66	SOUTH CITY - KHODAYS 220	NARASAPURA	12:36	12:39	0:03	LINE CLEAR AVAILED
41	1-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	SOUTH CITY	4:59	5:12	0:13	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
42	1-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	4:59	5:17	0:18	MAIN SUPPLY FAILURE
43	1-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	4:59	0:00	19:01	MAIN SUPPLY FAILURE
44	1-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	4:59	5:31	0:32	MAIN SUPPLY FAILURE
45	1-Jun-2021	BENGALURU	220	HV1	SUBRAMANYAPURA 220	4:59	5:12	0:13	MAIN SUPPLY FAILURE
46	1-Jun-2021	BENGALURU	220	HV1	KHODAYS 220	4:59	5:33	0:34	MAIN SUPPLY FAILURE
47	1-Jun-2021	BENGALURU	220	HV2	SUBRAMANYAPURA 220	4:59	5:14	0:15	MAIN SUPPLY FAILURE
48	1-Jun-2021	BENGALURU	220	HV2	KHODAYS 220	4:59	5:33	0:34	MAIN SUPPLY FAILURE
49	1-Jun-2021	BENGALURU	220	HV3	SUBRAMANYAPURA 220	4:59	5:14	0:15	MAIN SUPPLY FAILURE
50	1-Jun-2021	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	4:59	5:22	0:23	LINE FAULT
51	1-Jun-2021	BENGALURU	220	SUBRAMANYAPURA 220 - SOMANAHALLI 220	SUBRAMANYAPURA 220	4:59	5:12	0:13	MAIN SUPPLY FAILURE
52	1-Jun-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	7:30	7:50	0:18	LINE CLEAR AVAILED
53	1-Jun-2021	GULBARGA	66	MUNIRABAD-HANASI	HANASI_66	12:40	15:15	2:35	LINE CLEAR AVAILED
54	1-Jun-2021	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD	GULBARGA UNIVERSITY_110	15:20	15:25	0:05	MAIN SUPPLY FAILURE
55	1-Jun-2021	GULBARGA	110	HV1	DEODURGA_110	8:00	8:30	1:18	TRANSFORMER FAULT
56	1-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:17	3:30	0:13	LINE FAULT
57	1-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:01	19:05	0:04	LINE FAULT
58	1-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWA TH_110,VALKAMDINNI_110(IDLE)	10:13(31.05.2021)	19:40(01.06.2021)	33:27HRS	LINE CHARGED
59	1-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	10:13(31.05.2021)	19:38(01.06.2021)	33:25HRS	LINE CHARGED
60	1-Jun-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	19:41	19:47	0:18	LINE FAULT
61	1-Jun-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	0:51	0:58	0:18	LINE FAULT
62	1-Jun-2021	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110	20:45(01.06.2021)			LINE OPEN,LINE CLEAR AVAILED
63	1-Jun-2021	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	4:36	4:58	0:22	LINE FAULT
64	1-Jun-2021	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	5:29	5:48	0:19	LINE FAULT
65	1-Jun-2021	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	20:35	22:39	2:04	LINE CLEAR AVAILED
66	1-Jun-2021	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	19:52	20:54	1:02	LINE CLEAR AVAILED
67	1-Jun-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN,LINE FAULT
68	1-Jun-2021	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	10:29	10:31	0:02	LINE FAULT
69	1-Jun-2021	HASSAN	66	HV1	ALDUR_66	3:03	3:12	0:09	TRANSFORMER FAULT
70	1-Jun-2021	HASSAN	66	HV1	SIGEBAGE_66	8:10	8:54	0:44	LINE CLEAR AVAILED
71	1-Jun-2021	HASSAN	66	HV2	HOLALUR_66	9:27	15:56	6:29	LINE CLEAR AVAILED
72	1-Jun-2021	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	2:51	14:03	11:12	LINE FAULT
73	1-Jun-2021	HASSAN	110	ANANDA-LPH(LST-4)	ANANDPURA_110	2:52	3:46	0:54	LINE FAULT
74	1-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
75	1-Jun-2021	HASSAN	110	JOG-JLT4	mghejog_gen	9:09	12:35	3:26	LINE CLEAR AVAILED
76	1-Jun-2021	HASSAN	110	LPH-MGHE 2	lph_gen	9:09	12:39	3:30	LINE CLEAR AVAILED
77	1-Jun-2021	HASSAN	110	LV2	KAVOOR_220	9:07	13:53	4:46	LINE CLEAR AVAILED
78	1-Jun-2021	HASSAN	110	SAGARA-ALKLA	SAGARA_110	2:51	14:03	11:12	LINE FAULT
79	1-Jun-2021	HASSAN	110	SAGARA-ANANDPURA	SAGARA_110	2:52	3:53	1:01	LINE FAULT
80	1-Jun-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	4:46	4:57	0:11	HAND TRIPPED
81	1-Jun-2021	HASSAN	110	SHIRAL-SANDA	SHIRALKOPPA_110	17:23(31.5.2021)			LINE OPEN,LINE CLEAR AVAILED
82	1-Jun-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:45	13:07	0:22	LINE FAULT
83	1-Jun-2021	HASSAN	110	SORABA-MAVALLI	SORABA_110	4:48	4:58	0:10	HAND TRIPPED
84	1-Jun-2021	HASSAN	220	HV2	KAVOOR_220	9:07	13:53	4:46	LINE CLEAR AVAILED
85	1-Jun-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	11:15	11:52	0:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
86	1-Jun-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	11:16	11:52	0:36	NFBC ISSUED
87	1-Jun-2021	MYSURU	66	HV2	BILIKERE_66	8:14	8:27	0:12	TRANSFORMER FAULT
88	1-Jun-2021	MYSURU	66	HV2	KIKKERI_66	14:03	14:47	0:44	LINE CLEAR AVAILED
89	1-Jun-2021	MYSURU	66	KR NAGARA-CHUNCHANAKATTE	KRNAGARA_66 BILIKERE_66 GVGUDI_66 BHERYA_66 DMG HALLI_66	13:25	13:35	0:09	LINE FAULT
90	1-Jun-2021	MYSURU	66	KR NAGARA-KUSHALNAGARA	KRNAGARA_66 BILIKERE_66 GVGUDI_66 BHERYA_66 DMG HALLI_66	13:25	13:40	0:15	LINE FAULT
91	1-Jun-2021	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	NO STATIONS EFFECTED	18:19	18:28	0:09	LINE FAULT
92	1-Jun-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
93	1-Jun-2021	MYSURU	66	SHANIVARSANTHE-MALIPATNA	SANIVARASANTHE_66 YESSLUR_66 HETHUR_66	19:15	19:30	0:15	LINE FAULT
94	1-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
95	1-Jun-2021	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	13:48	13:53	0:05	HAND TRIPPED
96	1-Jun-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	14:23	14:35	0:12	MAIN SUPPLY FAILURE
97	1-Jun-2021	TUMKUR	66	PAVAGADA_220-NAGALMADIKE	PAVAGADA_220	1:58	2:12	0:14	LINE FAULT
98	1-Jun-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SAVALANGA_66	13:39	14:22	0:43	HAND TRIPPED
99	1-Jun-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	10:09	14:56	4:47	LINE CLEAR AVAILED
100	1-Jun-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	6:51	8:08	1:17	LINE CLEAR AVAILED
101	1-Jun-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	9:18	12:11	2:53	LINE CLEAR AVAILED
102	1-Jun-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	7:52	8:31	0:39	LINE CLEAR AVAILED
103	1-Jun-2021	TUMKUR	66	TR-2	MAVINAKATTE_66	10:09	14:57	4:47	LINE CLEAR AVAILED
104	1-Jun-2021	TUMKUR	66	YEDIYUR-ANCHEPALYA220KV	YEDIYUR_66	14:35	16:13	1:38	LINE CLEAR AVAILED
105	1-Jun-2021	TUMKUR	110	TR-1	BIDARE_110	12:26	15:44	3:18	LINE CLEAR AVAILED
106	1-Jun-2021	TUMKUR	110	TR-1	KALLUR_110	12:42	13:10	0:27	LINE CLEAR AVAILED
107	1-Jun-2021	TUMKUR	220	CHITRADURGA_220	CHITRADURGA 220- GUTTUR 220	14:31	15:53	1:22	LINE CLEAR AVAILED
108	1-Jun-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	14:30	16:46	2:15	LINE CLEAR AVAILED
109	1-Jun-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE SRS_220	19:10 (31.5.21)	16:11(1.5.21)	20:40 HRS	LINE CHARGED
110	2-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	STATION NOT AFFECTED	19:41(25.05.2020)			LINE OPEN,LINE FAULT
111	2-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
112	2-Jun-2021	BAGALKOT	110	MAHALINGAPUR-VAJRAMATTI 1	STATION NOT AFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
113	2-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
114	2-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
115	2-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
116	2-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN,LINE FAULT
117	2-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
118	2-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
119	2-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
120	2-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
121	2-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED	18:07(18.05.2021)			LINE OPEN,LINE FAULT
122	2-Jun-2021	BAGALKOT	110	AMBEWADI220-SUPA2	STATION NOT AFFECTED	10:05	11:28	1:23	LINE FAULT
123	2-Jun-2021	BAGALKOT	110	AMBEWADI220-SUPA1	STATION NOT AFFECTED	10:05	11:28	1:23	LINE CLEAR AVAILED
124	2-Jun-2021	BAGALKOT	110	ALBAL-SAIPRIYA (SPRS)	STATION NOT AFFECTED	15:53	16:00	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
125	2-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED	10:17	10:18	0:01	HAND TRIPPED
126	2-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED	18:53	18:57	0:04	HAND TRIPPED
127	2-Jun-2021	BAGALKOT	110	BAGEWADI220-MAMDAPUR1	MAMDAPUR_110	21:00	21:18	0:18	LINE FAULT
128	2-Jun-2021	BAGALKOT	110	BAGEWADI220-MAMDAPUR2	MAMDAPUR_110	21:00	21:18	0:18	LINE FAULT
129	2-Jun-2021	BAGALKOT	110	110/33KV, HV2	MINNAGAD_33, KARADI_33,	5:47	6:00	0:13	TRANSFORMER FAULT
130	2-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED	7:12	10:12	3:00	LINE CLEAR AVOID
131	2-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED	11:07	11:50	0:43	LINE CLEAR AVOID
132	2-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED	14:49	14:59	0:10	HAND TRIPPED
133	2-Jun-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED	10:52(02.06.2021)			LOAD CURTAILMENT
134	2-Jun-2021	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	12:07	12:22	0:15	LINE FAULT
135	2-Jun-2021	BAGALKOT	110	110/11KV, HV1	RON_110	15:15(02.06.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
136	2-Jun-2021	BAGALKOT	110	110/11KV, HV2	TUMMINAKATTI_110	16:45	17:59	1:14	LINE CLEAR AVOID
137	2-Jun-2021	BAGALKOT	110	110/33KV, HV3	MANGSOLI_33, SHEDABAL_33 STATION NOT AFFECTED	13:31	14:03	0:32	LINE CLEAR AVOID
138	2-Jun-2021	BAGALKOT	110	110/33KV, HV3	MANGSOLI_33, SHEDABAL_33 STATION NOT AFFECTED	15:43	15:58	0:15	LINE CLEAR AVOID
139	2-Jun-2021	BAGALKOT	110	110/33KV, HV2	HUBLI_110	10:43	12:23	1:40	LINE CLEAR AVOID
140	2-Jun-2021	BAGALKOT	110	VAJRAMATTI-KATARAKI	KATARAKI_110	3:21	3:28	0:07	LINE FAULT
141	2-Jun-2021	BAGALKOT	110	110/33KV, HV4	KALASANGI_33, NEVARAGI_33, DHOLKHER_33	15:30	15:33	0:03	TRANSFORMER FAULT
142	2-Jun-2021	BAGALKOT	110	110/33KV, HV4	KALASANGI_33, NEVARAGI_33, DHOLKHER_33	15:42	16:01	0:19	TRANSFORMER FAULT
143	2-Jun-2021	BENGALURU	66	HV1	BAGHMANE WTC	11:50	14:20	2:30	LINE CLEAR AVOID
144	2-Jun-2021	BENGALURU	66	HV1	BANGARPETE	11:00	11:10	0:10	LINE CLEAR AVOID
145	2-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	0:04	0:20	0:16	TRANSFORMER FAULT
146	2-Jun-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, THONSENAHALLI, CHEEMANGALA	20:31	20:37	0:06	LINE FAULT
147	2-Jun-2021	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	13:05	13:50	0:45	MAIN SUPPLY FAILURE
148	2-Jun-2021	BENGALURU	66	DOMMASANDRA - KACHAMARANAHALLI	DOMMASANDRA	14:50	14:55	0:05	LOAD CHANGE OVER
149	2-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	10:20	10:25	0:05	LINE CLEAR AVOID
150	2-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	22:16	22:29	0:13	TRANSFORMER FAULT
151	2-Jun-2021	BENGALURU	66	HV1	HOSKOTE 66	12:05	12:35	0:30	LINE CLEAR AVOID
152	2-Jun-2021	BENGALURU	66	HV1	KYLNUR	23:10	23:16	0:06	TRANSFORMER FAULT
153	2-Jun-2021	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:05	13:23	0:18	LINE FAULT
154	2-Jun-2021	BENGALURU	66	HV1	MANCHENAHALLI	12:30	13:30	1:00	LINE CLEAR AVOID
155	2-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	5:32	5:42	0:10	LINE FAULT
156	2-Jun-2021	BENGALURU	66	HV2	SADALI	23:09	23:21	0:12	TRANSFORMER FAULT
157	2-Jun-2021	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	13:05	13:25	0:20	MAIN SUPPLY FAILURE
158	2-Jun-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:05	13:28	0:23	LINE CLEAR AVOID
159	2-Jun-2021	BENGALURU	66	HV2	S M MANGALA	13:21	13:42	0:21	LINE CLEAR AVOID
160	2-Jun-2021	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	1:15	1:21	0:06	LINE FAULT
161	2-Jun-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	11:11	11:30	0:19	LINE FAULT
162	2-Jun-2021	BENGALURU	66	KANASWADI- DB PURA 220	KANASWADI	18:00	18:05	0:05	LOAD CHANGE OVER
163	2-Jun-2021	BENGALURU	66	HV1	KHODAYS 220	11:15	11:20	0:05	LOAD CHANGE OVER
164	2-Jun-2021	BENGALURU	66	HV2	KHODAYS 220	11:15	11:20	0:05	LOAD CHANGE OVER
165	2-Jun-2021	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	13:38	13:56	0:18	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
166	2-Jun-2021	BENGALURU	220	NRS 220 - VRISHBHAVATHI 220	NO STATION AFFECTED	15:53	19:24	3:31	LINE FAULT
167	2-Jun-2021	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	13:03	13:07	0:04	LOAD CHANGE OVER
168	2-Jun-2021	BENGALURU	220	HV1	VIKAS TECH PARK 220	13:05	13:25	0:20	MAIN SUPPLY FAILURE
169	2-Jun-2021	BENGALURU	220	HV2	VIKAS TECH PARK 220	13:05	13:26	0:21	MAIN SUPPLY FAILURE
170	2-Jun-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:05	13:26	0:21	MAIN SUPPLY FAILURE
171	2-Jun-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:05	13:26	0:21	MAIN SUPPLY FAILURE
172	2-Jun-2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:05	13:26	0:21	MAIN SUPPLY FAILURE
173	2-Jun-2021	BENGALURU	66	HV1	NELGADRENAHALLI	10:45	10:51	0:06	TRANSFORMER FAULT
174	2-Jun-2021	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	13:30	13:40	0:10	LOAD CHANGE OVER
175	2-Jun-2021	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	4:36	4:58	0:22	LINE FAULT
176	2-Jun-2021	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	5:29	5:48	0:19	LINE FAULT
177	2-Jun-2021	GULBARGA	220	HV1	ALIPUR_220	15:19	16:43	1:24	TRANSFORMER FAULT
178	2-Jun-2021	GULBARGA	220	KUSHTAGI-SUZLONWIND1_IPP	KUSHTAGI_220	14:30	19:30	5:00	LINE FAULT
179	2-Jun-2021	GULBARGA	220	SEDAM-RTPS1	RTPS_220	9:19	17:56	8:37	NFBC ISSUED
180	2-Jun-2021	GULBARGA	220	HV1	SEDAM_220	15:23	15:48	0:25	TRANSFORMER FAULT
181	2-Jun-2021	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	5:28	5:48	0:20	LINE FAULT
182	2-Jun-2021	GULBARGA	220	HUMNABAD-SEDAM1	HALBARGA_220	15:20	15:49	0:29	LINE FAULT
183	2-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:22(02.06.2021)			LINE OPEN,LINE FAULT
184	2-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	23:45(02.06.2021)			MAIN SUPPLY FAILURE
185	2-Jun-2021	GULBARGA	110	BELLARYSOUTH	BELLARYSOUTJ_110,HALKUNDI_110	15:19	15:54	0:35	LINE FAULT
186	2-Jun-2021	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110	20:45(01.06.2021)	4:31(02.06.2021)	7:46HRS	LINE CHARGED
187	2-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	0:13	7:20	7:07	LINE FAULT
188	2-Jun-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	3:05	7:44	4:39	LINE FAULT
189	2-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KORDICROSS_110,MIADLAPUR_110, MORUNDI_110	11:34	12:12	0:38	LINE CLEAR AVAILED
190	2-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	14:30	14:42	0:12	LINE FAULT
191	2-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	18:30	19:08	0:38	LINE FAULT
192	2-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KORDICROSS_110,MIADLAPUR_110, MORUNDI_110	23:07	23:14	0:07	LINE FAULT
193	2-Jun-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MORUNDI_110,KAMIPLI_110,YERADONA_110,SRNACAP_110,MALLADUR	22:08	22:18	0:10	LINE FAULT
194	2-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	11:35	12:15	0:40	LINE CLEAR AVAILED
195	2-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAIMIDININI,MIADLAPUR_110,MIANVI_110	15:10	15:22	0:12	LINE CLEAR AVAILED
196	2-Jun-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	19:33	19:49	0:16	LINE FAULT
197	2-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAIMIDININI,MIADLAPUR_110,MIANVI_110	20:12	20:25	0:13	LINE FAULT
198	2-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAIMIDININI,MIADLAPUR_110,MIANVI_110	22:56	23:05	0:09	LINE FAULT
199	2-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	0:14	4:10	3:56	LINE FAULT
200	2-Jun-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:07	2:18	0:11	LINE FAULT
201	2-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:35	18:45	0:10	LINE FAULT
202	2-Jun-2021	GULBARGA	110	NALWAR-WARDA SOLAR	NALWAR_110	18:45	19:04	0:19	LINE CLEAR AVAILED
203	2-Jun-2021	GULBARGA	110	HV1	NIRNA_110	19:30	19:34	0:04	TRANSFORMER FAULT
204	2-Jun-2021	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	15:22	16:15	0:53	LINE FAULT
205	2-Jun-2021	GULBARGA	110	HV1	CHINCHOLI_110	17:59	19:11	1:12	TRANSFORMER FAULT
206	2-Jun-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:28	5:36	0:08	LINE FAULT
207	2-Jun-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	13:02	14:20	1:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
208	2-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	5:07	5:14	0:07	LINE FAULT
209	2-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:25	20:34	0:09	LINE FAULT
210	2-Jun-2021	GULBARGA	110	HUMNABAD-BIDAR1,2	HALLIKHED_110	10:37	13:53	3:16	LINE CLEAR AVAILED
211	2-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR_110	SANTHAPUR_110,DONGARGAON_110	0:13	0:25	0:12	LINE FAULT
212	2-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR_110	SANTHAPUR_110,DONGARGAON_110	2:48	2:54	0:06	LINE FAULT
213	2-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR_110	SANTHAPUR_110,DONGARGAON_110	18:33	18:43	0:10	LINE FAULT
214	2-Jun-2021	GULBARGA	66	GUDEKOTE-HANGAL(IDLE LINE)	HANGAL_66	20:55(2.06.2021)			LINE OPEN,LINE CLEAR AVAILED
215	2-Jun-2021	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	20:50	21:05	0:15	LINE FAULT
216	2-Jun-2021	GULBARGA	66	HV1	GUDEKOTE_66	20:50	21:09	0:19	TRANSFORMER FAULT
217	2-Jun-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	11:50	15:45	3:55	LINE CLEAR AVAILED
218	2-Jun-2021	GULBARGA	66	HV1	KUDLIGI_66	11:35	11:45	0:10	LINE CLEAR AVAILED
219	2-Jun-2021	GULBARGA	66	HV3	KUDLIGI_66	10:15	11:00	0:45	LINE CLEAR AVAILED
220	2-Jun-2021	GULBARGA	66	KUDLIGI-SOKKE	HANASI_66	12:02	15:45	3:43	LINE CLEAR AVAILED
221	2-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
222	2-Jun-2021	HASSAN	110	SHIRAL-SANDA	SHIRALKOPPA_110	17:23(31.5.2021)			LINE OPEN,LINE CLEAR AVAILED
223	2-Jun-2021	HASSAN	110	HV2	KADUR_220	18:48(2.6.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
224	2-Jun-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	9:50(2.6.2021)			TRANSFORMER FAULT
225	2-Jun-2021	HASSAN	220	GER SOPA-TALGUPA2	gerusoppa_gen	10:01	12:26	2:25	LINE CLEAR AVAILED
226	2-Jun-2021	HASSAN	220	HGUNJE-KEMAR2	HEGGUNJE_220	12:12	12:46	0:34	LINE FAULT
227	2-Jun-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:45	12:50	1:05	LINE CLEAR AVAILED
228	2-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:07	13:19	4:12	LINE CLEAR AVAILED
229	2-Jun-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:26	13:20	3:54	LINE CLEAR AVAILED
230	2-Jun-2021	HASSAN	220	KEMAR-HEGGUNJE2	KEMAR_220	12:12	13:30	1:18	LINE FAULT
231	2-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:08	13:27	4:19	NFBC ISSUED
232	2-Jun-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:26	13:28	4:02	NFBC ISSUED
233	2-Jun-2021	HASSAN	110	HV2	KADUR_220	7:00	10:00	3:00	TRANSFORMER FAULT
234	2-Jun-2021	HASSAN	110	HV1	KONAJE_110	10:50	11:57	1:07	LINE CLEAR AVAILED
235	2-Jun-2021	HASSAN	110	HV2	KONAJE_110	12:01	13:54	1:53	LINE CLEAR AVAILED
236	2-Jun-2021	HASSAN	110	HV1	SORABA_110	9:55	10:20	0:25	LINE CLEAR AVAILED
237	2-Jun-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:45	13:33	2:48	LINE CLEAR AVAILED
238	2-Jun-2021	HASSAN	66	HV1	HALEBEEDU_66	17:00	17:55	0:55	TRANSFORMER FAULT
239	2-Jun-2021	HASSAN	66	HV2	HALEBEEDU_66	17:05	17:35	0:30	HAND TRIPPED
240	2-Jun-2021	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	17:33	17:40	0:07	LINE FAULT
241	2-Jun-2021	HASSAN	66	HV1	HNPURA_66	17:37	17:42	0:05	MAIN SUPPLY FAILURE
242	2-Jun-2021	HASSAN	66	HV2	HNPURA_66	17:37	17:42	0:05	MAIN SUPPLY FAILURE
243	2-Jun-2021	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	17:33	17:41	0:08	MAIN SUPPLY FAILURE
244	2-Jun-2021	HASSAN	66	HV2	KANDLI_66	8:30	8:40	0:10	HAND TRIPPED
245	2-Jun-2021	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	13:53	15:06	1:13	LINE CLEAR AVAILED
246	2-Jun-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:51	11:20	0:29	LINE CLEAR AVAILED
247	2-Jun-2021	MYSURU	66	BASARALU-HAMPAPURA	NO STATIONS EFFECTED	10:21	12:05	1:44	LINE CLEAR AVAILED
248	2-Jun-2021	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	12:35	14:10	1:35	LINE CLEAR AVAILED
249	2-Jun-2021	MYSURU	66	CR NAGARA-DR PETE 2	NO STATIONS EFFECTED	11:05	12:33	1:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
250	2-Jun-2021	MYSURU	66	HV2	KADAKOLA_220	7:11	7:20	0:08	TRANSFORMER FAULT
251	2-Jun-2021	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	9:20	14:38	5:18	LINE CLEAR AVAILED
252	2-Jun-2021	MYSURU	66	KADAKOLA-SARAGURU 1	HAMPAPURA(K)_66 JAIPUR_66	5:52	5:59	0:07	LINE FAULT
253	2-Jun-2021	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	BOGADHTIMANDYA_66 G MALUGERE_66 CHUDDENAHALLI_66	9:19	9:27	0:08	LINE FAULT
254	2-Jun-2021	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	9:52	13:27	3:34	LINE CLEAR AVAILED
255	2-Jun-2021	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	9:17	16:42	7:24	LINE CLEAR AVAILED
256	2-Jun-2021	MYSURU	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE_66 BHERYA_66 BETTADAPURA_66	7:23	7:36	0:13	LINE FAULT
257	2-Jun-2021	MYSURU	66	KUSHALANAGARA 220-BETTADAPURA	CHUNCHUNKATTE_66 KITTUR_66	7:23	7:36	0:12	LINE FAULT
258	2-Jun-2021	MYSURU	66	KUSHALANAGARA 220-HARANGI	NO STATIONS EFFECTED	9:34	16:04	6:29	LINE CLEAR AVAILED
259	2-Jun-2021	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS EFFECTED	22:59	23:04	0:04	LINE FAULT
260	2-Jun-2021	MYSURU	66	MADHUVANAHALLY-PG PALYA	PGPALYA_66	20:12	20:18	0:05	LINE FAULT
261	2-Jun-2021	MYSURU	66	NAGAMANGALA-KR PETE 220	BOGADHTIMANDYA_66 G MALUGERE_66 CHUDDENAHALLI_66	9:58	10:08	0:10	HAND TRIPPED
262	2-Jun-2021	MYSURU	66	NANJANGUDU-THANDYA	NO STATIONS EFFECTED	9:09	14:39	5:30	NFBC ISSUED
263	2-Jun-2021	MYSURU	66	PERIYAPATNA-HUNSUR	KAMPALAPURA_66	15:21	15:31	0:10	LINE FAULT
264	2-Jun-2021	MYSURU	66	SHANIVARASANTHE-YESSLUR	NO STATIONS EFFECTED	11:02	11:24	0:21	LINE FAULT
265	2-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
266	2-Jun-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
267	2-Jun-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	23:19:11(02.06.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
268	2-Jun-2021	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	13:05	14:22	1:17	LINE CLEAR AVAILED
269	2-Jun-2021	TUMKUR	110	TR-1	MAYASANDRA_110	3:51	6:50	2:59	TRANSFORMER FAULT
270	2-Jun-2021	TUMKUR	66	TR-2	AVAREGERE_66	12:10	12:57	0:46	LINE CLEAR AVAILED
271	2-Jun-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	18:23	18:40	0:17	LINE FAULT
272	2-Jun-2021	TUMKUR	66	HIRIYURkV 220kv- SUZLON 2	SUZLON2_IPP_66	19:03	20:02	0:59	LINE FAULT
273	2-Jun-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	21:52	22:06	0:14	LINE FAULT
274	2-Jun-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	6:14	6:25	0:10	LINE FAULT
275	2-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN DA_66	15:04	16:10	1:06	LINE CLEAR AVAILED
276	2-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	18:15	18:21	0:06	LINE FAULT
277	2-Jun-2021	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	5:37	12:14	6:37	LINE FAULT
278	2-Jun-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:11	13:46	5:35	LINE CLEAR AVAILED
279	2-Jun-2021	TUMKUR	66	TR-1	JIDDIGERE_66	14:41	19:28	4:47	MAIN SUPPLY FAILURE
280	2-Jun-2021	TUMKUR	66	YEDIYUR- ANCHEPALYA220KV	YEDIYUR_66	14:00	17:07	3:06	LINE CLEAR AVAILED
281	2-Jun-2021	TUMKUR	66	TR-2	SANIKERE_66	22:08	22:13	0:05	TRANSFORMER FAULT
282	2-Jun-2021	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	22:16	23:02	0:46	LINE FAULT
283	2-Jun-2021	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	22:16	23:03	0:47	LINE FAULT
284	2-Jun-2021	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	18:33	18:49	0:15	LINE FAULT
285	2-Jun-2021	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	22:16	23:07	0:51	LINE FAULT
286	2-Jun-2021	TUMKUR	66	THALLAK 220kv- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:33	18:49	0:15	LINE FAULT
287	2-Jun-2021	TUMKUR	66	THALLAK 220kv- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	22:16	23:07	0:51	LINE FAULT
288	2-Jun-2021	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	17:09	18:06	0:57	LINE FAULT
289	2-Jun-2021	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	17:09	17:44	0:35	LINE FAULT
290	2-Jun-2021	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	23:31	23:40	0:08	LINE FAULT
291	3-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
292	3-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
293	3-Jun-2021	BAGALKOT	110	KANEBENUR220- HONNATTI (ADEMALLAPUR)	NO STATION AFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
294	3-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
295	3-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
296	3-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
297	3-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED	17:22(30.03.2021)			LINE OPEN,LINE FAULT
298	3-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
299	3-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
300	3-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
301	3-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
302	3-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED	18:07(18.05.2021)			LINE OPEN,LINE FAULT
303	3-Jun-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED	10:52(02.06.2021)			LOAD CURTAILMENT
304	3-Jun-2021	BAGALKOT	110	110/11KV, HV1	RON_110	15:15(02.06.2021)	2:45(03.06.2021)	21:30HRS	TRANSFORMER CHARGED
305	3-Jun-2021	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED	9:52	9:54	0:02	TRANSFORMER FAULT
306	3-Jun-2021	BAGALKOT	220	AMBEWWADI-XELDOM(PONDA1)	STATION NOT AFFECTED	11:28	12:13	0:45	LINE FAULT
307	3-Jun-2021	BAGALKOT	220	BAGALKOT-GADAG1	STATION NOT AFFECTED	17:35	18:57	1:22	LINE FAULT
308	3-Jun-2021	BAGALKOT	220	BAGALKOT-GADAG2	STATION NOT AFFECTED	17:23	18:53	1:30	LINE FAULT
309	3-Jun-2021	BAGALKOT	110	ANKOLA-KUMTA	STATION NOT AFFECTED	10:22	16:36	6:14	LINE FAULT
310	3-Jun-2021	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	15:24	20:17	4:53	LINE CLEAR AVAILED
311	3-Jun-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	12:10	13:21	1:11	LINE CLEAR AVAILED
312	3-Jun-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	6:40	7:25	0:45	LINE CLEAR AVAILED
313	3-Jun-2021	BAGALKOT	220	BELGAUM-(KANABARGI)NARENDRA1	STATION NOT AFFECTED	16:26	20:55	4:29	LINE FAULT
314	3-Jun-2021	BAGALKOT	220	GHATAPRABHA-MUGALKOT1(CHIKKODI2)	STATION NOT AFFECTED	19:09	20:40	1:31	LINE FAULT
315	3-Jun-2021	BAGALKOT	220	GHATAPRABHA-MUGALKOT2(CHIKKODI2)	STATION NOT AFFECTED	19:09	20:38	1:29	LINE FAULT
316	3-Jun-2021	BAGALKOT	110	MAHALINGAPUR-GSML1	MAHALINGAPUR_220	17:53	18:19	0:26	LINE FAULT
317	3-Jun-2021	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110,NAVALAGI_110,JA	17:53	18:19	0:26	LINE FAULT
318	3-Jun-2021	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110,NAVALAGI_110,JA	19:24	20:49	1:25	LINE FAULT
319	3-Jun-2021	BAGALKOT	220	NARENDRA-BELGAUM1 (KNBRG1)	STATION NOT AFFECTED	16:26	16:50	0:24	LINE FAULT
320	3-Jun-2021	BAGALKOT	220	NARENDRA-BELGAUM1 (KNBRG1)	STATION NOT AFFECTED	16:57	20:54	3:57	LINE FAULT
321	3-Jun-2021	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED	17:17	21:40	4:23	LINE FAULT
322	3-Jun-2021	BAGALKOT	110	BASAVANAKATTI-GUTTAL SWITCHING	STATION NOT AFFECTED	20:27(03.06.2021)			LINE OPEN,LINE FAULT
323	3-Jun-2021	BAGALKOT	110	BASAVANAKATTI-HAVERI220	BASAVANAKATTI_110	20:36	20:42	0:06	HAND TRIPPED
324	3-Jun-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED	17:05(19.05.2021)	0:58(03.06.2021)	353:53HRS	LINE CHARGED
325	3-Jun-2021	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED	17:05(19.05.2021)	0:58(03.06.2021)	353:53HRS	LINE CHARGED
326	3-Jun-2021	BAGALKOT	110	HIREHAL-MYFAR SOLAR	MYFAR SOLAR_110	16:30	18:58	2:28	LINE CLEAR AVAILED
327	3-Jun-2021	BAGALKOT	110	JAMAKHANDI-PRABHULINGESHWAR	STATION NOT AFFECTED	18:26	21:05	2:39	LINE CLEAR AVAILED
328	3-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED	18:05	18:44	0:39	HAND TRIPPED
329	3-Jun-2021	BAGALKOT	110	KIRUVATTI-AMBEWADI220(SIRSI)	STATION NOT AFFECTED	18:50(02.06.2021)	0:29(03.06.2021)	15:39HRS	HAND TRIPPED
330	3-Jun-2021	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	10:22	10:34	0:12	LINE FAULT
331	3-Jun-2021	BAGALKOT	110	KULIGOD-GAMESH	GAMESH IPP_110	21:48	21:51	0:03	HAND TRIPPED
332	3-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED	14:35	14:47	0:12	TRANSFORMER FAULT
333	3-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED	15:28	15:34	0:06	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
334	3-Jun-2021	BAGALKOT	110	MUNDARGI-VIJAYA SUGARS	VIJAYA SUGARS_110	5:57	6:29	0:32	LINE FAULT
335	3-Jun-2021	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED	16:04	17:08	1:04	TRANSFORMER FAULT
336	3-Jun-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED	16:04	17:08	1:04	TRANSFORMER FAULT
337	3-Jun-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED	16:04	16:55	0:51	TRANSFORMER FAULT
338	3-Jun-2021	BAGALKOT	110	SOUDATTI220-RAMDURG2	STATION NOT AFFECTED	16:04	21:20	5:16	LINE FAULT
339	3-Jun-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED	17:18	19:54	2:36	TRANSFORMER FAULT
340	3-Jun-2021	BAGALKOT	110	110/33KV, HV2	TKORWADI_33, ONTAGODI_33	19:46	19:56	0:10	TRANSFORMER FAULT
341	3-Jun-2021	BAGALKOT	110	VAJJRAMATTI22-LOKAPUR	STATION NOT AFFECTED	17:18(03.06.2021)			LINE OPEN,LINE FAULT
342	3-Jun-2021	BAGALKOT	110	VAJJRAMATTI22-KATARKI	KATARKI_110	21:28	21:36	0:08	LINE FAULT
343	3-Jun-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED	13:39(03.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
344	3-Jun-2021	BAGALKOT	110	110/33KV, HV4	HUBLI_33, HALASANGI_33, NEMARGI_33	11:36	13:10	1:34	LINE CLEAR AVOIDED
345	3-Jun-2021	BENGALURU	220	LV1	BIDADI 220	16:36	16:55	0:19	TRANSFORMER FAULT
346	3-Jun-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	16:36	16:57	0:21	MAIN SUPPLY FAILURE
347	3-Jun-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	16:36	16:57	0:21	MAIN SUPPLY FAILURE
348	3-Jun-2021	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	16:36	16:57	0:21	MAIN SUPPLY FAILURE
349	3-Jun-2021	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	1:06	1:39	0:33	LINE FAULT
350	3-Jun-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	1:06	2:16	1:10	LINE FAULT
351	3-Jun-2021	BENGALURU	66	NELMANGALA 66 - ALUR	NELAMANGALA 66	2:33	2:41	0:08	LOAD CHANGE OVER
352	3-Jun-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	6:55	7:08	0:13	LINE FAULT
353	3-Jun-2021	BENGALURU	66	HV1	DEVANAHALLI	15:54	15:59	0:05	TRANSFORMER FAULT
354	3-Jun-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	7:50	10:30	2:40	LINE FAULT
355	3-Jun-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	20:35	21:20	0:45	LINE FAULT
356	3-Jun-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	21:00	21:19	0:19	LINE FAULT
357	3-Jun-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	21:00	21:19	0:19	LINE FAULT
358	3-Jun-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	21:22	22:28	1:06	LINE FAULT
359	3-Jun-2021	BENGALURU	66	HV2	MELEHALLI	14:00	14:50	0:50	LINE CLEAR AVOIDED
360	3-Jun-2021	BENGALURU	66	HV2	HANUMANTHNAGAR	14:05	15:15	1:10	LINE CLEAR AVOIDED
361	3-Jun-2021	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	10:54	11:00	0:06	LOAD CHANGE OVER
362	3-Jun-2021	BENGALURU	66	JAKKASANDRA - HRS LAYOUT 220	JAKKASANDRA	11:32	11:39	0:07	LOAD CHANGE OVER
363	3-Jun-2021	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	14:03	14:07	0:04	LOAD CHANGE OVER
364	3-Jun-2021	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	7:01	7:31	0:30	TRANSFORMER FAULT
365	3-Jun-2021	BENGALURU	66	HV3	ADUGODI	11:54	12:37	0:43	LINE CLEAR AVOIDED
366	3-Jun-2021	BENGALURU	66	HV1	PATHPALYA	12:46	13:06	0:20	LINE CLEAR AVOIDED
367	3-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	18:48	19:05	0:17	TRANSFORMER FAULT
368	3-Jun-2021	GULBARGA	110	HV1	SANKALPUR_110	22:10	22:30	0:20	TRANSFORMER FAULT
369	3-Jun-2021	GULBARGA	110	HV2	SANKALPUR_110	18:26	20:10	1:44	TRANSFORMER FAULT
370	3-Jun-2021	GULBARGA	110	HALBARGA-KAMATHANA	KAMATHANA_110	6:23	6:32	0:09	LINE FAULT
371	3-Jun-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	5:35	5:42	0:07	LINE FAULT
372	3-Jun-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	5:45	5:51	0:06	LINE FAULT
373	3-Jun-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	6:02	6:17	0:15	LINE FAULT
374	3-Jun-2021	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	5:40	6:05	0:25	LINE FAULT
375	3-Jun-2021	GULBARGA	110	KUSHTAGI-ILKAL2	ILKAL_110	5:40	9:54	4:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
376	3-Jun-2021	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	6:20	6:50	0:30	LINE FAULT
377	3-Jun-2021	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	9:25	9:35	0:10	LINE FAULT
378	3-Jun-2021	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110	20:53	21:18	0:25	LINE FAULT
379	3-Jun-2021	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110	23:35	23:55	0:20	LINE FAULT
380	3-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:18	20:30	0:12	LINE FAULT
381	3-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH_110,VALKAMDINNI_110	23:02	23:15	0:13	LINE FAULT
382	3-Jun-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	23:15	23:25	0:10	LINE FAULT
383	3-Jun-2021	GULBARGA	110	HV1 & HV2	SEDAM_220	19:01	20:13	1:12	TRANSFORMER FAULT
384	3-Jun-2021	GULBARGA	110	SINDHNOOR-NIRLOOTI_IPP	SINDHNOOR_220	22:50	23:00	0:10	LINE FAULT
385	3-Jun-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110	23:08	23:18	0:10	LINE FAULT
386	3-Jun-2021	GULBARGA	110	SINDHNOOR-TEKKALKOTE	TEKKALKOTE_110	23:03	23:18	0:15	MAIN SUPPLY FAILURE
387	3-Jun-2021	GULBARGA	110	YELBURGA-PARAMPOOJYA_IPP	YELBURGA_110	1:30	2:48	1:18	LINE FAULT
388	3-Jun-2021	GULBARGA	110	HV4	YELBURGA_110	12:54	13:08	0:14	TRANSFORMER FAULT
389	3-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:04	0:09	0:05	LINE FAULT
390	3-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:35	0:54	0:19	LINE FAULT
391	3-Jun-2021	GULBARGA	110	HV1	SHAHAPUR_220	0:24	0:43	0:19	TRANSFORMER FAULT
392	3-Jun-2021	GULBARGA	110	HV1	SHAHAPUR_220	0:58	5:08	4:10	TRANSFORMER FAULT
393	3-Jun-2021	GULBARGA	110	HV2	SHAHAPUR_220	23:41(02.06.2021)	11:40(03.06.2021)	11:59HRS	LINE CHARGED
394	3-Jun-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	23:40	23:45	0:05	LINE FAULT
395	3-Jun-2021	GULBARGA	66	KOTTUR-UJJAINI	UJJAINI_66	12:05	12:10	0:05	LINE FAULT
396	3-Jun-2021	GULBARGA	66	KOTTUR-BENNIHALLI	KOTTUR_66	20:45	20:55	0:10	LINE FAULT
397	3-Jun-2021	GULBARGA	66	HV1	KOTTUR_66	20:25	21:25	1:00	TRANSFORMER FAULT
398	3-Jun-2021	GULBARGA	66	GUDEKOTE-HANGAL(IDLE LINE)	HANGAL_66	20:55(2.06.2021)	10:10(03.06.2021)	13:15 HRS	LINE CHARGED
399	3-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
400	3-Jun-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:06(03.06.2021)			LINE OPEN,LINE CLEAR AVAILED
401	3-Jun-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:04(3.06.2021)			LINE OPEN,LINE CLEAR AVAILED
402	3-Jun-2021	HASSAN	110	SHIRAL-SANDA	SHIRALKOPPA_110	17:23(31.5.2021)	13:40(3.6.2021)	68:17hrs	LINE CHARGED
403	3-Jun-2021	HASSAN	110	HV2	KADUR_220	18:48(2.6.2021)	14:15 (3.6.2021)	19:27hrs	TRANSFORMER CHARGED
404	3-Jun-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	9:50(2.6.2021)	11:30 (3.6.2021)	25:40hrs	LINE CHARGED
405	3-Jun-2021	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	4:30	7:42	3:12	LINE FAULT
406	3-Jun-2021	HASSAN	220	HV2	KAVOOR_220	9:08	14:05	4:57	LINE CLEAR AVAILED
407	3-Jun-2021	HASSAN	110	LV2	KAVOOR_220	9:07	14:06	4:59	LINE CLEAR AVAILED
408	3-Jun-2021	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:37	13:02	2:25	LINE CLEAR AVAILED
409	3-Jun-2021	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	4:30	7:42	3:12	LINE FAULT
410	3-Jun-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:56	14:27	1:31	LINE FAULT
411	3-Jun-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:37	17:27	4:50	LINE FAULT
412	3-Jun-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:30	14:30	5:00	LINE CLEAR AVAILED
413	3-Jun-2021	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	14:04	14:23	0:19	LINE CLEAR AVAILED
414	3-Jun-2021	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	14:24	15:14	0:50	LINE CLEAR AVAILED
415	3-Jun-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	15:19	15:39	0:20	LINE CLEAR AVAILED
416	3-Jun-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:38	13:02	2:24	NFBC ISSUED
417	3-Jun-2021	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	12:56	14:27	1:31	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
418	3-Jun-2021	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	12:37	17:27	4:50	LINE FAULT
419	3-Jun-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	19:48	20:23	0:35	LINE FAULT
420	3-Jun-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:30	14:30	5:00	LINE CLEAR AVAILED
421	3-Jun-2021	HASSAN	110	HV2	HOSANGADI_110	19:48	23:49	4:01	TRANSFORMER FAULT
422	3-Jun-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:06	13:18	3:12	NFBC ISSUED
423	3-Jun-2021	HASSAN	110	IDLE	SAGARA_110	16:20	18:20	2:00	LINE CLEAR AVAILED
424	3-Jun-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	16:01	16:35	0:34	LINE FAULT
425	3-Jun-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	14:20	17:52	3:32	LINE FAULT
426	3-Jun-2021	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	16:02	16:34	0:32	LINE FAULT
427	3-Jun-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:52	13:18	0:26	HAND TRIPPED
428	3-Jun-2021	HASSAN	66	HV1	HALEBEDU_66	12:36	13:33	0:57	TRANSFORMER FAULT
429	3-Jun-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	14:06	14:14	0:08	LINE FAULT
430	3-Jun-2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	14:47	14:48	0:01	HAND TRIPPED
431	3-Jun-2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	15:06	15:07	0:01	HAND TRIPPED
432	3-Jun-2021	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGOLIPURA ARAKALAWADI_66	17:46	18:00	0:14	LINE FAULT
433	3-Jun-2021	MYSURU	66	HV1	DUNDANAHALLI_66	10:45	12:45	1:59	LINE CLEAR AVAILED
434	3-Jun-2021	MYSURU	220	HV2	KADAKOLA_220	17:28	17:54	0:26	TRANSFORMER FAULT
435	3-Jun-2021	MYSURU	66	HV1	K_HONNALGERE_66	10:00	10:13	0:13	TRANSFORMER FAULT
436	3-Jun-2021	MYSURU	66	HV1	K_HONNALGERE_66	10:26	10:35	0:08	TRANSFORMER FAULT
437	3-Jun-2021	MYSURU	66	HV1	K_HONNALGERE_66	11:31	12:05	0:33	LINE CLEAR AVAILED
438	3-Jun-2021	MYSURU	66	HV1	K_HONNALGERE_66	12:34	12:45	0:10	TRANSFORMER FAULT
439	3-Jun-2021	MYSURU	66	KIADB MANDYA -TUMBEKERE	TUMBEKERE_66	18:42	18:53	0:10	LINE FAULT
440	3-Jun-2021	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA 1	CB HALLI_66 ALUR SIDDAPURA_66 KANAGAL_66 BUDBARATNA_66	14:50	15:03	0:12	LINE FAULT
441	3-Jun-2021	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	12:23	12:29	0:06	LINE FAULT
442	3-Jun-2021	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	5:01	5:07	0:06	LINE FAULT
443	3-Jun-2021	MYSURU	66	PONNAMPETE-HV3	SRIMANGALA_33	3:31	3:55	0:23	LINE FAULT
444	3-Jun-2021	MYSURU	66	HV1	TERAKANAMBE_66	11:38	13:10	1:32	LINE CLEAR AVAILED
445	3-Jun-2021	MYSURU	66	HV2	TUBINAKERE_220	10:24	11:50	1:26	LINE CLEAR AVAILED
446	3-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)	10:14 (03/06/2021)	1009:44HRS	LINE CHARGED
447	3-Jun-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)	7:48 (03/06/2021)	818:39HRS	LINE CHARGED
448	3-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE		20:23 (03/06/2021)			LINE OPEN,LINE FAULT
449	3-Jun-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	9:23:16 PM(03.06.2021)			LINE OPEN,LINE FAULT
450	3-Jun-2021	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	3:04:46 PM(15.06.2021)			LINE OPEN,LINE CLEAR AVAILED
451	3-Jun-2021	TUMKUR	220	PAVAGADA 220kv- MADHUGIRI 1	PAVAGADA_220	11:55:33 PM(03.06.2021)			LINE OPEN,LINE FAULT
452	3-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220kv- KOLTEGERE	KOLTEGERE,CHIKKATOTILKERE_66, BELADARA_66	6:05:42 PM(03.06.2021)			LINE OPEN,LINE FAULT
453	3-Jun-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	6:03	6:17	0:14	TRANSFORMER FAULT
454	3-Jun-2021	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	9:30	11:39	2:09	TRANSFORMER FAULT
455	3-Jun-2021	TUMKUR	66	TR-1	BENKIKERE_66	6:00	6:05	0:05	TRANSFORMER FAULT
456	3-Jun-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	4:30	4:40	0:09	TRANSFORMER FAULT
457	3-Jun-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TIRUVANUR_66, ENRCONKFT_66,	5:47	5:53	0:05	LINE FAULT
458	3-Jun-2021	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	HIRIYUR_66	22:50	23:51	1:00	LINE FAULT
459	3-Jun-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	8:08	8:15	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
460	3-Jun-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	8:42	8:46	0:03	TRANSFORMER FAULT
461	3-Jun-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	8:56	8:59	0:03	TRANSFORMER FAULT
462	3-Jun-2021	TUMKUR	66	TR-1	DODDASARANGI_66	9:34	15:29	0:03	TRANSFORMER FAULT
463	3-Jun-2021	TUMKUR	66	TR-1	DODDASARANGI_66	18:30	19:06	5:54	TRANSFORMER FAULT
464	3-Jun-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66,NANDIGUDI_66	21:09	21:55	0:36	LINE FAULT
465	3-Jun-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	11:18	11:22	0:46	LINE FAULT
466	3-Jun-2021	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGARAHALLI_66,NALLUR_66	1:44	1:55	0:04	LINE FAULT
467	3-Jun-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:29	12:35	0:10	LINE FAULT
468	3-Jun-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66,NYAMATHI_66, SAVALANCA_66	22:02	22:09	0:06	LINE FAULT
469	3-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:51	12:02	0:07	HAND TRIPPED
470	3-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:49	11:56	0:11	LINE FAULT
471	3-Jun-2021	TUMKUR	66	TR-1	JIDDIGERE_66	13:16	16:28	0:06	MAIN SUPPLY FAILURE
472	3-Jun-2021	TUMKUR	66	TR-2	KORA_66	22:13	23:23	3:12	TRANSFORMER FAULT
473	3-Jun-2021	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	5:47	5:57	1:09	LINE FAULT
474	3-Jun-2021	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	5:47	5:59	0:09	LINE FAULT
475	3-Jun-2021	TUMKUR	66	TR-2	SANIKERE_66	23:09	23:31	0:11	TRANSFORMER FAULT
476	3-Jun-2021	TUMKUR	66	TR-1	PAVAGADA_220	2:23	2:46	0:22	HAND TRIPPED
477	3-Jun-2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	9:03	9:10	0:22	LINE FAULT
478	3-Jun-2021	TUMKUR	66	PAVAGADA_220-PAVGD1	PAVAGADA_220	23:05	23:14	0:06	LINE FAULT
479	3-Jun-2021	TUMKUR	66	THALLAK 220KV -BGKERE 1	BGKERE_66	7:22	7:58	0:09	LINE FAULT
480	4-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED	19:41(25.05.2020)			LINE OPEN,LINE FAULT
481	4-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
482	4-Jun-2021	BAGALKOT	110	KANEBEVINUR220- HONNALLI (ADEMALIADUR)	NO STATION EFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
483	4-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
484	4-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
485	4-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
486	4-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED	17:22(30.03.2021)			LINE OPEN,LINE FAULT
487	4-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
488	4-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
489	4-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
490	4-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
491	4-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED	18:07(18.05.2021)	7:32(04.06.2021)	407:25HRS	LINE CHARGED
492	4-Jun-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED	10:52(02.06.2021)	9:31(04.06.2021)	56:39HRS	LINE CHARGED
493	4-Jun-2021	BAGALKOT	110	BASAVANAKATTI-GUTTAL SWITCHING	STATION NOT AFFECTED	20:27(03.06.2021)	7:33(04.06.02021)	11:06HRS	LINE CHARGED
494	4-Jun-2021	BAGALKOT	110	VAJRAMATTI22-LOKAPUR	STATION NOT AFFECTED	17:18(03.06.2021)	4:18(04.06.2021)	21:00HRS	LINE CHARGED
495	4-Jun-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED	13:39(03.06.2021)	3:16(04.06.2021)	23:37HRS	LINE CHARGED
496	4-Jun-2021	BAGALKOT	110	AMBEWADI-(NK2)	STATION NOT AFFECTED	11:06	15:08	4:02	LINE CLEAR AVAILED
497	4-Jun-2021	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:55	16:04	5:09	LINE CLEAR AVAILED
498	4-Jun-2021	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	16:53	18:43	1:50	LINE CLEAR AVAILED
499	4-Jun-2021	BAGALKOT	110	110/33KV,HV3	KOLIGUDDA_33,MYTRA SOLAR_33	13:02	13:08	0:06	LINE CLEAR AVAILED
500	4-Jun-2021	BAGALKOT	110	HIREHAL- RON	STATION NOT AFFECTED	13:04	16:24	3:20	LINE CLEAR AVAILED
501	4-Jun-2021	BAGALKOT	110	JAMAKHANDI- (BRABHULINGESHWAR)SIDDAPUR	JAMAKHANDI_110	10:42	10:53	0:11	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
502	4-Jun-2021	BAGALKOT	110	JAMAKAHANDI	STATION NOT AFFECTED	13:12(04.06.2021)			LINE OPEN,LINE CLEAR AVAILED
503	4-Jun-2021	BAGALKOT	220	GHATAPRABHA-(CHIKKODI1)MUGALKOD1	STATION NOT AFFECTED	4:45	8:43	3:58	LINE FAULT
504	4-Jun-2021	BAGALKOT	220	GHATAPRABHA-(CHIKKODI2)MUGALKOD2	STATION NOT AFFECTED	2:07	2:49	0:42	LINE FAULT
505	4-Jun-2021	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	11:55	11:56	0:01	HAND TRIPPED
506	4-Jun-2021	BAGALKOT	110	110/11KV,HV2	MUKARTHIHAL_110	13:19	13:37	0:18	TRANSFORMER FAULT
507	4-Jun-2021	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	10:34	11:10	0:36	TRANSFORMER FAULT
508	4-Jun-2021	BAGALKOT	110	RON-GAMESH	RON_110	16:29	16:31	0:02	HAND TRIPPED
509	4-Jun-2021	BAGALKOT	110	PG HUNSHYAL-NAGANUR (MUDALGI)	NAGANUR_110	11:22	11:50	0:28	LINE CLEAR AVAILED
510	4-Jun-2021	BAGALKOT	110	SALAHALLI-GMNAVAR	GMNAVAR_110	16:24	19:04	2:40	LINE FAULT
511	4-Jun-2021	BAGALKOT	110	SAVANUR-ASIAN FEBTECH SOLAR	ASIAN FEBTECH_110	18:15	18:20	0:05	LINE FAULT
512	4-Jun-2021	BAGALKOT	110	SIRSI-SIRSI220-1(HUBLI1)	STATION NOT AFFECTED	10:28	16:49	6:21	LINE CLEAR AVAILED
513	4-Jun-2021	BAGALKOT	110	SIRSI-SIRSI220-2(KVALAWADA)	STATION NOT AFFECTED	10:28	16:49	6:21	LINE CLEAR AVAILED
514	4-Jun-2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED	13:39(03.06.2021)	3:15(04.06.2021)	23:36HRS	LINE CHARGED
515	4-Jun-2021	BAGALKOT	110	SIRSI220-UMACHAGI(NK1)	STATION NOT AFFECTED	10:12	16:10	5:58	LINE CLEAR AVAILED
516	4-Jun-2021	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED	10:30	16:42	6:12	LINE CLEAR AVAILED
517	4-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED	11:57	15:04	3:07	LINE CLEAR AVAILED
518	4-Jun-2021	BAGALKOT	110	SOUDATTI-ENERCON1	ENERCON_110	4:45	11:39	6:54	LINE FAULT
519	4-Jun-2021	BAGALKOT	110	SOUDATTI-ENERCON2	ENERCON_110	10:06	11:39	1:33	LINE CLEAR AVAILED
520	4-Jun-2021	BAGALKOT	110	SUVARNASOUDHA-MACHE	STATION NOT AFFECTED	7:24	19:20	11:56	LINE CLEAR AVAILED
521	4-Jun-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED	14:43	14:46	0:03	LINE CLEAR AVAILED
522	4-Jun-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED	15:11	15:17	0:06	LINE CLEAR AVAILED
523	4-Jun-2021	BAGALKOT	110	UMMACHAGI-SIRSI220	STATION NOT AFFECTED	10:45	16:11	5:26	LINE CLEAR AVAILED
524	4-Jun-2021	BAGALKOT	110	VAJJRAMATTI220-MANTUR1	STATION NOT AFFECTED	6:19	6:33	0:14	LINE FAULT
525	4-Jun-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED	18:18	20:44	2:26	TRANSFORMER FAULT
526	4-Jun-2021	BAGALKOT	110	110/33KV,HV4	NEVARGI_33,DUCKED_33,	9:55	10:07	0:12	TRANSFORMER FAULT
527	4-Jun-2021	BAGALKOT	110	110/11KV,HV4	STATION NOT AFFECTED	16:34	18:00	1:26	LINE CLEAR AVAILED
528	4-Jun-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	17:59	18:32	0:33	MAIN SUPPLY FAILURE
529	4-Jun-2021	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	17:59	18:08	0:09	MAIN SUPPLY FAILURE
530	4-Jun-2021	BENGALURU	66	A STATION 220 - KANTEERAVA	KANTEERAVA	17:59	18:08	0:09	MAIN SUPPLY FAILURE
531	4-Jun-2021	BENGALURU	66	HV2	BOODIGERE	14:20	14:50	0:30	LINE CLEAR AVAILED
532	4-Jun-2021	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	11:22	11:32	0:10	LOAD CHANGE OVER
533	4-Jun-2021	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	15:18	15:28	0:10	LOAD CHANGE OVER
534	4-Jun-2021	BENGALURU	220	EDC 220 - HAL 220	EDC 220	17:59	18:22	0:23	MAIN SUPPLY FAILURE
535	4-Jun-2021	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	17:59	18:33	0:34	LINE CLEAR AVAILED
536	4-Jun-2021	BENGALURU	66	EDC 220 - B STATION	B STATION	17:59	18:32	0:33	LINE CLEAR AVAILED
537	4-Jun-2021	BENGALURU	66	EDC 220 - BMTC	BMTC	17:59	18:35	0:36	LINE CLEAR AVAILED
538	4-Jun-2021	BENGALURU	220	HAL 220 - HOODY 400	HAL 220	17:59	19:09	1:10	MAIN SUPPLY FAILURE
539	4-Jun-2021	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	17:59	19:09	1:10	LINE CLEAR AVAILED
540	4-Jun-2021	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	17:59	19:09	1:10	LINE CLEAR AVAILED
541	4-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT)	17:59	19:09	1:10	LINE CLEAR AVAILED
542	4-Jun-2021	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	17:59	19:09	1:10	LINE CLEAR AVAILED
543	4-Jun-2021	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARIYOTHI	17:59	19:09	1:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
544	4-Jun-2021	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	17:59	19:09	1:10	LINE CLEAR AVAILED
545	4-Jun-2021	BENGALURU	400	ICT 3	HOODY 400	17:58	19:02	1:04	TRANSFORMER FAULT
546	4-Jun-2021	BENGALURU	220	HOODY 220 - ITI 220	ITI 220	18:10	19:18	1:08	LINE CLEAR AVAILED
547	4-Jun-2021	BENGALURU	220	HV2	HOODY 220	18:55	19:15	0:20	LINE CLEAR AVAILED
548	4-Jun-2021	BENGALURU	220	HV4	HOODY 220	18:55	19:30	0:35	LINE CLEAR AVAILED
549	4-Jun-2021	BENGALURU	66	HOODY 220 - PRESTIGE SHANTINIKETHAN	PRESTIGE SHANTINIKETHAN	18:10	19:19	1:09	LINE CLEAR AVAILED
550	4-Jun-2021	BENGALURU	220	HV3	HOODY 220	18:05	21:12	3:07	LINE CLEAR AVAILED
551	4-Jun-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	17:59	18:17	0:18	MAIN SUPPLY FAILURE
552	4-Jun-2021	BENGALURU	66	HV2	HSR LAYOUT 220	17:59	18:17	0:18	MAIN SUPPLY FAILURE
553	4-Jun-2021	BENGALURU	220	HSR LAYOUT 220 - KORAMANGALA 220	KORAMANGALA 220	17:59	18:38	0:39	MAIN SUPPLY FAILURE
554	4-Jun-2021	BENGALURU	66	HV1	ISCON	14:30	14:32	0:02	LINE CLEAR AVAILED
555	4-Jun-2021	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	17:59	19:17	1:18	LINE CLEAR AVAILED
556	4-Jun-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	17:59	19:17	1:18	LINE CLEAR AVAILED
557	4-Jun-2021	BENGALURU	66	ITI 220 - ITI 66	ITI 66	17:59	19:17	1:18	LINE CLEAR AVAILED
558	4-Jun-2021	BENGALURU	66	ITI 220 - BANASWADI	BANASWADI	17:59	19:17	1:18	LINE CLEAR AVAILED
559	4-Jun-2021	BENGALURU	66	ITI 220 - BAGHMANE WTC	BAGHMANE WTC	17:59	19:17	1:18	LINE CLEAR AVAILED
560	4-Jun-2021	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	17:59	19:17	1:18	LINE CLEAR AVAILED
561	4-Jun-2021	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	17:59	18:46	0:47	MAIN SUPPLY FAILURE
562	4-Jun-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	19:30	19:41	0:11	LOAD CHANGE OVER
563	4-Jun-2021	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	17:59	18:40	0:41	LINE CLEAR AVAILED
564	4-Jun-2021	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	17:59	18:40	0:41	LINE CLEAR AVAILED
565	4-Jun-2021	BENGALURU	66	KORMANGALA 220 - KORAMANGALA 66	KORAMANGALA 66	17:59	18:40	0:41	LINE CLEAR AVAILED
566	4-Jun-2021	BENGALURU	220	NIMHANS 220 - EDC 220	NIMHANS 220	17:59	18:47	0:48	MAIN SUPPLY FAILURE
567	4-Jun-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	17:59	18:47	0:48	LINE CLEAR AVAILED
568	4-Jun-2021	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	17:59	18:47	0:48	LINE CLEAR AVAILED
569	4-Jun-2021	BENGALURU	66	HV2	NRS 220	22:46	23:49	1:03	LINE CLEAR AVAILED
570	4-Jun-2021	BENGALURU	66	HV1	NRS 220	22:46	23:49	1:03	LINE CLEAR AVAILED
571	4-Jun-2021	BENGALURU	66	PADMANABHANAGARA - NIMHANS 220	PADMANABHANAGARA	17:59	18:10	0:11	MAIN SUPPLY FAILURE
572	4-Jun-2021	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	16:51	18:17	1:26	LINE FAULT
573	4-Jun-2021	BENGALURU	66	HV1	ATTUR YELAHANKA	8:19	8:50	0:31	LINE CLEAR AVAILED
574	4-Jun-2021	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	18:10	18:35	0:25	MAIN SUPPLY FAILURE
575	4-Jun-2021	BENGALURU	66	HV2	NGEF	21:20	21:30	0:10	TRANSFORMER FAULT
576	4-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELL, YENICADALE	18:55	19:00	0:05	LINE FAULT
577	4-Jun-2021	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	18:55	19:10	0:15	LINE FAULT
578	4-Jun-2021	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	18:55	19:10	0:15	LINE FAULT
579	4-Jun-2021	BENGALURU	66	HV1	MITTEMARI 220	6:40	6:45	0:05	TRANSFORMER FAULT
580	4-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	22:04	23:24	1:20	LINE CLEAR AVAILED
581	4-Jun-2021	BENGALURU	66	HV1	TEKAL	20:24	20:33	0:09	TRANSFORMER FAULT
582	4-Jun-2021	BENGALURU	66	CHELUR - MITTEMARI 220	CHELUR	18:55	19:02	0:07	LINE FAULT
583	4-Jun-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:41	17:03	0:22	LINE FAULT
584	4-Jun-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	18:09	18:25	0:16	LINE FAULT
585	4-Jun-2021	BENGALURU	66	HV1	HOSKOTE 66	2:28	3:10	0:42	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
586	4-Jun-2021	BENGALURU	66	HV1	KAMASAMUDRA	18:27	18:54	0:27	LINE CLEAR AVAILED
587	4-Jun-2021	BENGALURU	66	HV2	THIMMAMPALLI	20:04	20:18	0:14	TRANSFORMER FAULT
588	4-Jun-2021	BENGALURU	66	HV1	DALASNUSNUR	12:45	12:55	0:10	TRANSFORMER FAULT
589	4-Jun-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGOPPE, CHANNAPATNA,	17:54	18:10	0:16	LINE FAULT
590	4-Jun-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGOPPE, CHANNAPATNA,	18:10	22:27	4:17	LINE FAULT
591	4-Jun-2021	BENGALURU	66	HV1	DODDABELAVANGALA	13:40	14:00	0:20	LINE CLEAR AVAILED
592	4-Jun-2021	BENGALURU	66	CB PURA I/A - DB PURA 1 & 2	CHIKKABALLAPURA I/A,	12:35	12:45	0:10	LINE CLEAR AVAILED
593	4-Jun-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A,	17:15	17:31	0:16	LINE FAULT
594	4-Jun-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	17:15	17:31	0:16	LINE FAULT
595	4-Jun-2021	BENGALURU	66	HV2	MAASTHI	20:54	21:05	0:11	TRANSFORMER FAULT
596	4-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	1:10	1:45	0:35	TRANSFORMER FAULT
597	4-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	14:05	14:18	0:13	TRANSFORMER FAULT
598	4-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI,	15:20	15:40	0:20	LINE FAULT
599	4-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - RVNL 1	RVNL (EHT)	3:00	3:40	0:40	LINE FAULT
600	4-Jun-2021	BENGALURU	66	GOWRIBIDANUR 220 - RVNL 2	RVNL (EHT)	3:05	3:40	0:35	LINE FAULT
601	4-Jun-2021	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66, JIGANI LINK ROAD	13:07	13:22	0:15	LINE CLEAR AVAILED
602	4-Jun-2021	BENGALURU	66	VIDHURASHWATTA - GUNDLU KOTTUR	GUNDLU KOTTUR	19:15	19:20	0:05	LINE FAULT
603	4-Jun-2021	BENGALURU	66	VIDHURASHWATTA - GUNDLU KOTTUR	GUNDLU KOTTUR	19:20	19:30	0:10	LINE FAULT
604	4-Jun-2021	BENGALURU	66	VIDHURASHWATTA - GOWRIBIDANUR 220	VIDHURASHWATTA	19:15	19:35	0:20	LINE FAULT
605	4-Jun-2021	BENGALURU	66	VIDHURASHWATTA - GUNDLU KOTTUR	GUNDLU KOTTUR	19:30 (04 MAY 2021)			LINE OPEN,LINE FAULT
606	4-Jun-2021	BENGALURU	400	ICT 2	HOODY 400	17:58:00(04/06/2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
607	4-Jun-2021	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	23:32(02.06.2021)	17:33(04.06.2021)	42:01HRS	LINE CHARGED
608	4-Jun-2021	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	23:57(03.06.2021)	6:24(04.06.2021)	6:27HRS	LINE CHARGED
609	4-Jun-2021	GULBARGA	220	LINGAPUR-KUSHTAGI	LINGAPUR_220	21:05(03.06.2021)	8:48:00(04.06.2021)	21:43HRS	LINE CHARGED
610	4-Jun-2021	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	23:30(03.06.2021)	10:05(04.06.2021)	10:35HRS	LINE CHARGED
611	4-Jun-2021	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	20:05(04.06.2021)			LINE OPEN,LINE CLEAR AVAILED
612	4-Jun-2021	GULBARGA	220	LINGAPUR-BMM	ITTAGI_220	00:47(03.06.2021)	12:19(04.06.2021)	35:32HRS	LINE CHARGED
613	4-Jun-2021	GULBARGA	220	SEDAM-OREINTCEMENTS_IPP	SEDAM_220	16:30	19:53	3:23	LINE CLEAR AVAILED
614	4-Jun-2021	GULBARGA	220	SEDAM-CLEANMAX_IPP	SEDAM_220	16:33	19:59	3:26	LINE CLEAR AVAILED
615	4-Jun-2021	GULBARGA	110	HV2	NALWAR_110	22:24(03.06.2021)	00:50(04.06.2021)	2:26HRS	TRANSFORMER CHARGED
616	4-Jun-2021	GULBARGA	110	SANKLAPUR-TORANGALLU	TORANGALLU_110	19:25(03.06.2021)	5:30(04.06.2021)	20:05HRS	LINE CHARGED
617	4-Jun-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	23:52(03.06.2021)	00:05(04.06.2021)	00:13HRS	LINE CHARGED
618	4-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	23:55(04.06.2021)		18:30	LINE FAULT
619	4-Jun-2021	GULBARGA	110	HV1	BEVOOR_110	10:25	11:26	6:30	LINE CLEAR AVAILED
620	4-Jun-2021	GULBARGA	110	KAPNOOR-KADGANCHI	KADGANCHI_110	11:20	11:27	7:30	LINE FAULT
621	4-Jun-2021	GULBARGA	110	HV2	YELBURGA_110	8:55	9:53	8:30	TRANSFORMER FAULT
622	4-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MOKRATAGI_110,DEV	2:40	2:46	9:30	LINE FAULT
623	4-Jun-2021	GULBARGA	110	SHAHABAD-RAICHUR2	ANGAON_110,BENLUKA_IPP,AFZALPUR	5:05	6:10	10:30	LINE FAULT
624	4-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:50	11:58	11:30	LINE FAULT
625	4-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	20:15	20:25	12:30	LINE FAULT
626	4-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAVIDININI,MADLAPUR_110,MIA	0:28	0:36	13:30	LINE FAULT
627	4-Jun-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	0:45	0:55	14:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
628	4-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110	2:05	2:26	15:30	LINE FAULT
629	4-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	14:26	14:36	16:30	LINE FAULT
630	4-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	1:52	2:02	17:30	LINE FAULT
631	4-Jun-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	5:53	6:10	0:17	LINE FAULT
632	4-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	2:40	2:45	0:05	TRANSFORMER FAULT
633	4-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	3:10	3:15	0:05	TRANSFORMER FAULT
634	4-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	11:40	12:00	0:20	LINE CLEAR AVAILED
635	4-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	12:34	13:30	0:56	LINE CLEAR AVAILED
636	4-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	14:33	14:38	0:05	TRANSFORMER FAULT
637	4-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	15:00	16:20	1:20	LINE CLEAR AVAILED
638	4-Jun-2021	GULBARGA	110	HV2	SHORAPUR_110	9:19	10:39	1:20	LINE CLEAR AVAILED
639	4-Jun-2021	GULBARGA	110	HV1	BEVOOR_110	10:25	11:25	1:00	LINE CLEAR AVAILED
640	4-Jun-2021	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110	20:45	20:55	0:10	LINE FAULT
641	4-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	17:15	17:20	0:05	LINE FAULT
642	4-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:35	19:45	0:10	LINE FAULT
643	4-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	21:10	21:15	0:05	LINE FAULT
644	4-Jun-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	2:40	2:50	0:10	LINE FAULT
645	4-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	3:30	3:42	0:12	LINE FAULT
646	4-Jun-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	3:50	3:59	0:09	LINE FAULT
647	4-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:12	13:39	2:27	LINE CLEAR AVAILED
648	4-Jun-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	12:09	13:11	1:02	LINE CLEAR AVAILED
649	4-Jun-2021	GULBARGA	110	SHAHAPUR-SEDAM	SHAHAPUR_220	15:38	18:42	3:04	LINE FAULT
650	4-Jun-2021	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	2:32	2:40	0:08	LINE FAULT
651	4-Jun-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:35	18:09	0:34	LINE CLEAR AVAILED
652	4-Jun-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	19:01(3.06.2021)	8:52(04.06.2021)	13:51HRS	LINE CHARGED
653	4-Jun-2021	GULBARGA	110	HV1	ALIPUR_220	17:17	17:59	0:42	LINE CLEAR AVAILED
654	4-Jun-2021	GULBARGA	110	ALIPUR-MUNIRABAD	FORANGALLO_110,KODITINI_110,KO SHIGDA_110,SHATDONGARGAON_110	23:43	23:52	0:09	LINE FAULT
655	4-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110	20:50	20:55	0:05	LINE FAULT
656	4-Jun-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110	21:12	21:25	0:13	LINE FAULT
657	4-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
658	4-Jun-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:06(03.06.2021)			MAIN SUPPLY FAILURE
659	4-Jun-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:04(3.06.2021)			LINE OPEN,LINE FAULT
660	4-Jun-2021	HASSAN	110	LV1	KADUR_220	12:27 (4.06.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
661	4-Jun-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	13:01	14:32	1:31	NFBC ISSUED
662	4-Jun-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	14:32	19:35	5:03	LINE FAULT
663	4-Jun-2021	HASSAN	220	UPCL-KEMAR2	upcl_gen	13:01	15:14	2:13	LINE CLEAR AVAILED
664	4-Jun-2021	HASSAN	220	HGUNJE-VRH	HEGGUNJE_220	9:23	12:12	2:49	NFBC ISSUED
665	4-Jun-2021	HASSAN	220	KEMAR-UPCL1	KEMAR_220	13:01	14:32	1:31	LINE CLEAR AVAILED
666	4-Jun-2021	HASSAN	220	KEMAR-UPCL1	KEMAR_220	14:32	19:35	5:03	LINE FAULT
667	4-Jun-2021	HASSAN	220	KEMAR-UPCL2	KEMAR_220	13:01	15:14	2:13	LINE CLEAR AVAILED
668	4-Jun-2021	HASSAN	110	KEMAR-BELMAN	KEMAR_220	3:27	4:01	0:34	LINE FAULT
669	4-Jun-2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	12:30	14:10	1:40	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
670	4-Jun-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	2:45	3:53	1:08	LINE FAULT
671	4-Jun-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	12:43	14:13	1:30	LINE CLEAR AVAILED
672	4-Jun-2021	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	6:14	7:35	1:21	LINE FAULT
673	4-Jun-2021	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	6:14	7:28	1:14	LINE FAULT
674	4-Jun-2021	HASSAN	220	VARAHI-HEGGUNJE	varahi_gen	9:23	12:12	2:49	LINE CLEAR AVAILED
675	4-Jun-2021	HASSAN	110	HV2	HOSANGADI_110	11:52	13:42	1:50	LINE CLEAR AVAILED
676	4-Jun-2021	HASSAN	110	HV1	KADUR_220	11:57	12:56	0:59	LINE CLEAR AVAILED
677	4-Jun-2021	HASSAN	110	KA00R-MCFLine	KAVOOR_220	5:55	6:18	0:23	LINE FAULT
678	4-Jun-2021	HASSAN	110	KAVOOR-AMR	KAVOOR_220	2:10	2:40	0:30	LINE FAULT
679	4-Jun-2021	HASSAN	110	HV4	MANIPAL_110	2:26	2:37	0:11	TRANSFORMER FAULT
680	4-Jun-2021	HASSAN	110	HV1	NANDIKUR_110	12:43	14:44	2:01	MAIN SUPPLY FAILURE
681	4-Jun-2021	HASSAN	110	HV2	NANDIKUR_110	12:43	14:44	2:01	MAIN SUPPLY FAILURE
682	4-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	2:45	3:54	1:09	MAIN SUPPLY FAILURE
683	4-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	4:30	5:30	1:00	LINE FAULT
684	4-Jun-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	12:43	14:44	2:01	MAIN SUPPLY FAILURE
685	4-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	2:45	4:03	1:18	LINE FAULT
686	4-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	4:30	5:32	1:02	LINE FAULT
687	4-Jun-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	12:43	14:44	2:01	NFBC ISSUED
688	4-Jun-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	12:43	14:44	2:01	MAIN SUPPLY FAILURE
689	4-Jun-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	12:43	14:44	2:01	MAIN SUPPLY FAILURE
690	4-Jun-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	12:43	14:44	2:01	MAIN SUPPLY FAILURE
691	4-Jun-2021	HASSAN	110	HV1	NAVUNDA_110	18:31	18:55	0:24	TRANSFORMER FAULT
692	4-Jun-2021	HASSAN	110	HV2	NERALAKERE_110	13:05	14:00	0:55	LINE CLEAR AVAILED
693	4-Jun-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	10:45	11:16	0:31	MAIN SUPPLY FAILURE
694	4-Jun-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	10:45	11:05	0:20	MAIN SUPPLY FAILURE
695	4-Jun-2021	HASSAN	66	TAVAREC-HONNAHALI	TAVARECHATNAHALI_66	6:50	7:11	0:21	LINE FAULT
696	4-Jun-2021	HASSAN	110	HV1	SALATHUR_110	1:51	2:20	0:29	HAND TRIPPED
697	4-Jun-2021	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	10:44	11:01	0:17	HAND TRIPPED
698	4-Jun-2021	MYSURU	66	CR NAGARA-YELANDUR	YELANDUR_66	19:01	19:08	0:07	LINE FAULT
699	4-Jun-2021	MYSURU	66	HV2	HAMPAPURA_66	17:08	18:07	0:58	TRANSFORMER FAULT
700	4-Jun-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	6:04	6:09	0:05	LINE FAULT
701	4-Jun-2021	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	14:35	14:37	0:01	HAND TRIPPED
702	4-Jun-2021	MYSURU	66	HV1	KADAKOLA_220	14:32	14:33	0:01	HAND TRIPPED
703	4-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	16:07	19:19	3:11	LINE FAULT
704	4-Jun-2021	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	14:19	14:41	0:22	HAND TRIPPED
705	4-Jun-2021	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	14:19	14:41	0:22	HAND TRIPPED
706	4-Jun-2021	MYSURU	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HAMPAPURA(K)_66	14:24	14:27	0:02	HAND TRIPPED
707	4-Jun-2021	MYSURU	66	KADAKOLA-SARAGURU 2	DOORA_66 HOKA_66	14:24	14:27	0:02	HAND TRIPPED
708	4-Jun-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANNALI_66, PARINAMIPURA_66 , THALAKADU_66	5:39	5:45	0:06	LINE FAULT
709	4-Jun-2021	MYSURU	66	HV1	MADDUR_66	9:44	11:32	1:47	LINE CLEAR AVAILED
710	4-Jun-2021	MYSURU	66	HV2	MADDUR_66	11:33	13:14	1:40	LINE CLEAR AVAILED
711	4-Jun-2021	MYSURU	66	HV2	MALAVALLI_66	11:26	11:31	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
712	4-Jun-2021	MYSURU	66	HV2	MALAVALLI_66	12:07	12:13	0:05	TRANSFORMER FAULT
713	4-Jun-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	7:28	17:44	10:16	NFBC ISSUED
714	4-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	11:33	16:50	5:17	NFBC ISSUED
715	4-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 2	NO STATIONS EFFECTED	11:33	16:50	5:17	NFBC ISSUED
716	4-Jun-2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	11:15	12:19	1:04	LINE CLEAR AVAILED
717	4-Jun-2021	MYSURU	66	HV2	THANDYA_66	12:43	13:00	0:16	LINE CLEAR AVAILED
718	4-Jun-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADICHUNCHANAGIRI_66	23:11	23:18	0:07	LINE FAULT
719	4-Jun-2021	MYSURU	66	VAJAMANGALA-KADAKOLA 1	NO STATIONS EFFECTED	7:19	11:10	3:50	LINE CLEAR AVAILED
720	4-Jun-2021	MYSURU	66	VAJAMANGALA-KADAKOLA 2	AYRALLI_66 MARADIHUNDI_66	7:20	17:15	9:54	LINE CLEAR AVAILED
721	4-Jun-2021	MYSURU	66	VAJAMANGALA-KADAKOLA 1	NO STATIONS EFFECTED	15:13	17:15	2:01	LINE CLEAR AVAILED
722	4-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:23 (03/06/2021)	16:03(4.6.21)	19:41HRS	LINE CHARGED
723	4-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	19:31 (04/06/2021)			LINE OPEN,LINE CLEAR AVAILED
724	4-Jun-2021	MYSURU	66	HV5	SFCSHIVA_66	8:09 (04/06/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
725	4-Jun-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	21:23(03.06.2021)	16:28(4.6.21)	18:05HRS	LINE CHARGED
726	4-Jun-2021	TUMKUR	220	KB CROSS 220kV- SHIMOAGA1	KBCROSS_220	13:04(3.06.2021)			LINE OPEN,LINE CLEAR AVAILED
727	4-Jun-2021	TUMKUR	220	PAVAGADA 220KV- MADHUGIRI 1	PAVAGADA_220	11:55:33 PM(03.06.2021)	1:51 (4.6.21)	12:56HRS	LINE CHARGED
728	4-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORTEGERE	KORTEGERE,CHIKKATOTLUKERE_66, BELADABA_66	6:05:42 PM(03.06.2021)			LINE OPEN,LINE FAULT
729	4-Jun-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:37	16:20	3:43	LINE CLEAR AVAILED
730	4-Jun-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:36	16:26	3:49	LINE CLEAR AVAILED
731	4-Jun-2021	TUMKUR	110	TR-1	BIDARE_110	14:06	15:25	1:18	LINE CLEAR AVAILED
732	4-Jun-2021	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	14:08	15:25	1:16	LINE CLEAR AVAILED
733	4-Jun-2021	TUMKUR	110	TR-2	KBCROSS_220	6:04	11:42	5:38	TRANSFORMER FAULT
734	4-Jun-2021	TUMKUR	110	TR-1	HONNAVALLI_110	12:15	12:56	0:40	HAND TRIPPED
735	4-Jun-2021	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	19:21	19:31	0:09	LINE FAULT
736	4-Jun-2021	TUMKUR	66	TR-1	DODDASARANGI_66	11:17	13:10	1:52	LINE CLEAR AVAILED
737	4-Jun-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:11	10:16	0:05	HAND TRIPPED
738	4-Jun-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TAVANAGI_66, DASAVARATNA_66	10:03	10:10	0:06	HAND TRIPPED
739	4-Jun-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:19	10:23	0:04	HAND TRIPPED
740	4-Jun-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	13:35	13:58	0:23	MAIN SUPPLY FAILURE
741	4-Jun-2021	TUMKUR	66	TR-1	HIRIYUR_66	2:20	2:27	0:07	TRANSFORMER FAULT
742	4-Jun-2021	TUMKUR	66	TR-2	HIRIYUR_66	8:39	8:51	0:11	TRANSFORMER FAULT
743	4-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:14	19:18	0:04	LINE FAULT
744	4-Jun-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:27	10:31	0:04	LINE FAULT
745	4-Jun-2021	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, TUBINAKERE_66	18:42	19:16	0:33	LINE FAULT
746	4-Jun-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	0:30	0:52	0:22	LINE FAULT
747	4-Jun-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	0:30	0:51	0:20	LINE FAULT
748	4-Jun-2021	TUMKUR	66	MIDIGESHI-PAVAGADA	MEDIGESHI_66	1:35	4:50	3:14	MAIN SUPPLY FAILURE
749	4-Jun-2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	21:43	21:56	0:13	TRANSFORMER FAULT
750	4-Jun-2021	TUMKUR	66	TR-1	TAVAREKERE_66	10:07	12:32	2:25	TRANSFORMER FAULT
751	4-Jun-2021	TUMKUR	66	TR-1	TAVAREKERE_66	12:35	12:55	0:20	TRANSFORMER FAULT
752	4-Jun-2021	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	19:28	21:41	2:12	LINE CLEAR AVAILED
753	4-Jun-2021	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	13:49	13:58	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
754	4-Jun-2021	TUMKUR	66	TR-1	TYAVANAGI_66	7:45	11:21	3:35	LINE CLEAR AVAILED
755	4-Jun-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	13:14	14:01	0:46	LINE CLEAR AVAILED
756	4-Jun-2021	TUMKUR	66	TR-2	DAVANGERE_66	22:02	22:36	0:34	LINE CLEAR AVAILED
757	4-Jun-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	7:29	8:22	0:53	LINE CLEAR AVAILED
758	4-Jun-2021	TUMKUR	66	TR-2	GUTTUR_66	5:43	6:07	0:23	TRANSFORMER FAULT
759	4-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:56	12:00	0:04	LINE FAULT
760	4-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:12	12:33	0:20	LINE FAULT
761	4-Jun-2021	TUMKUR	66	TR-1	LINGADAHALLY_66	0:06	0:25	0:19	MAIN SUPPLY FAILURE
762	5-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED	19:41(25.05.2020)			LINE OPEN,LINE FAULT
763	5-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
764	5-Jun-2021	BAGALKOT	110	KANEBENKUR220- HONNALLI (ADEMALHAPUR)	NO STATION AFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
765	5-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
766	5-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
767	5-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
768	5-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED	17:22(30.03.2021)			LINE OPEN,LINE FAULT
769	5-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
770	5-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
771	5-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
772	5-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
773	5-Jun-2021	BAGALKOT	110	JAMAKHANDI- (BRABHULINGESHWAR)SIDDAPUR	STATION NOT AFFECTED	13:12(04.06.2021)			LINE OPEN,LINE CLEAR AVAILED
774	5-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	10:57	18:03	7:06	LINE FAULT
775	5-Jun-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	10:35	14:36	4:01	LINE CLEAR AVAILED
776	5-Jun-2021	BAGALKOT	110	110/33 KV,HV2	CHIKKODI_110 & KEBUR8KARACHU_22	12:40	13:12	0:32	TRANSFORMER FAULT
777	5-Jun-2021	BAGALKOT	220	CHIKKODI- MUGALKOD1	CHIKKODI_220	3:08	7:37	4:29	LINE FAULT
778	5-Jun-2021	BAGALKOT	220	CHIKKODI- MUGALKOD2	CHIKKODI_220	3:08	7:38	4:30	LINE FAULT
779	5-Jun-2021	BAGALKOT	220	GHATAPRABHA- CHIKKODI1 (MUGALKOD1)	GHATAPRABHA_220	3:07	4:13	1:06	LINE FAULT
780	5-Jun-2021	BAGALKOT	220	GHATAPRABHA- CHIKKODI2 (MUGALKOD2)	GHATAPRABHA_220	3:07	3:59	0:52	LINE FAULT
781	5-Jun-2021	BAGALKOT	110	GHATAPRABHA220- MUDALGI(MANTUR)	MANTUR_110	19:11	19:25	0:14	LINE FAULT
782	5-Jun-2021	BAGALKOT	110	HAVERI220- BYADAGI	BYADAGI_110	14:25	20:28	6:03	LINE FAULT
783	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	HIREKERUR_110	14:52	15:08	0:16	LINE CLEAR AVAILED
784	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	HIREKERUR_110	15:36	15:44	0:08	LINE CLEAR AVAILED
785	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	6:07	6:18	0:11	TRANSFORMER FAULT
786	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	21:27	21:36	0:09	TRANSFORMER FAULT
787	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	KUDACHI_110	18:48	18:55	0:07	TRANSFORMER FAULT
788	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	7:41	7:45	0:04	TRANSFORMER FAULT
789	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	8:53	9:00	0:07	TRANSFORMER FAULT
790	5-Jun-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	10:03	14:20	4:17	LINE CLEAR AVAILED
791	5-Jun-2021	BAGALKOT	110	110/11KV,HV4( HV3)	STATION NOT AFFECTED	18:18	18:42	0:24	HAND TRIPPED
792	5-Jun-2021	BAGALKOT	110	MANTUR- TBS SOLAR	TODALBAGI_110	19:11	20:22	1:11	LINE FAULT
793	5-Jun-2021	BAGALKOT	110	TAKKALAKI- WARADA SOLAR	MANTUR(G)_110	15:43	15:55	0:12	HAND TRIPPED
794	5-Jun-2021	BAGALKOT	110	TAKKALAKI- KN SOLAR	TAKKALAKI_110	15:43	15:55	0:12	HAND TRIPPED
795	5-Jun-2021	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	11:48	11:58	0:10	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
796	5-Jun-2021	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	15:37	15:47	0:10	LOAD CHANGE OVER
797	5-Jun-2021	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	10:50	11:10	0:20	LOAD CHANGE OVER
798	5-Jun-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	17:53	18:03	0:10	LOAD CHANGE OVER
799	5-Jun-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGANATHPUR 220	ELECTRONIC CITY P2 S1	15:34	15:58	0:24	LOAD CHANGE OVER
800	5-Jun-2021	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	17:35	17:46	0:11	LOAD CHANGE OVER
801	5-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADOBISANAHALLI, GESSNO PARK	10:34	10:38	0:04	LOAD CHANGE OVER
802	5-Jun-2021	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:38	10:42	0:04	LOAD CHANGE OVER
803	5-Jun-2021	BENGALURU	66	HV1	KHB	0:26	0:40	0:14	TRANSFORMER FAULT
804	5-Jun-2021	BENGALURU	66	HV1	KHB	3:15	3:19	0:04	TRANSFORMER FAULT
805	5-Jun-2021	BENGALURU	66	HV1	KHB	12:15	12:17	0:02	LINE CLEAR AVAILED
806	5-Jun-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	11:37	11:40	0:03	LOAD CHANGE OVER
807	5-Jun-2021	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	13:36	13:38	0:02	LOAD CHANGE OVER
808	5-Jun-2021	BENGALURU	66	HV1	ST.JOHNS WOOD	14:53	15:08	0:15	LINE CLEAR AVAILED
809	5-Jun-2021	BENGALURU	66	HV2	ST.JOHNS WOOD	11:01	11:08	0:07	LINE CLEAR AVAILED
810	5-Jun-2021	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	18:46	18:57	0:11	LINE FAULT
811	5-Jun-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	16:25	17:38	1:12	LINE CLEAR AVAILED
812	5-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	9:04	9:20	0:15	LINE FAULT
813	5-Jun-2021	BENGALURU	66	HV1	TEKAL	9:35	9:47	0:12	TRANSFORMER FAULT
814	5-Jun-2021	BENGALURU	66	HV1	TEKAL	17:56	18:06	0:09	TRANSFORMER FAULT
815	5-Jun-2021	BENGALURU	66	HV1	SIDDALAGATTA	10:29	10:40	0:10	LINE CLEAR AVAILED
816	5-Jun-2021	BENGALURU	66	HV2	MALLASANDRA	10:55	11:20	0:25	LINE CLEAR AVAILED
817	5-Jun-2021	BENGALURU	66	HV2	IRGAMPALLI	21:54	21:58	0:03	TRANSFORMER FAULT
818	5-Jun-2021	BENGALURU	400	ICT 2	HOODY 400	17:58:00(04/06/2021)	15:47(05/06/2021)	21:49HRS	TRANSFORMER CHARGED
819	5-Jun-2021	BENGALURU	66	VIDHURASHWATTA - GUNDLU KOTTUR	GUNDLU KOTTUR	19:30 (04 JUNE 2021)	10:27(5.06.21)	14:56HRS	LINE CHARGED
820	5-Jun-2021	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	20:05(04.06.2021)	09:02(05.06.2021)	12:57HRS	LINE CHARGED
821	5-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	10:52	11:40	0:48	LINE CLEAR AVAILED
822	5-Jun-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	0:40	1:01	0:21	LINE FAULT
823	5-Jun-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	3:56	9:46	5:50	LINE FAULT
824	5-Jun-2021	GULBARGA	220	HV2	SHAHABAD_220	3:47	8:04	4:17	TRANSFORMER FAULT
825	5-Jun-2021	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	9:08	16:48	7:40	NFBC ISSUED
826	5-Jun-2021	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	1:52	8:58	7:06	LINE CLEAR AVAILED
827	5-Jun-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGASUGUR_220	11:33	12:34	1:01	LINE CLEAR AVAILED
828	5-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:15	17:43	5:28	LINE FAULT
829	5-Jun-2021	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	9:08	16:48	7:40	NFBC ISSUED
830	5-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN,LINE CLEAR AVAILED
831	5-Jun-2021	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	18:30(5.06.2021)			LINE OPEN,LINE FAULT
832	5-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	0:15	16:50	16:35	LINE FAULT
833	5-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	23:55(04.06.2021)	00:05(05.06.2021)	18:30HRS	LINE CHARGED
834	5-Jun-2021	GULBARGA	110	HV2	KAVITAL_110	0:30	8:50	8:20	TRANSFORMER FAULT
835	5-Jun-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:54	2:04	9:20	LINE FAULT
836	5-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAVADININI,WADLAPUR_110,WIA NVL_110	2:00	2:14	10:20	LINE FAULT
837	5-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110	2:28	2:45	11:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
838	5-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAMDINNI,MADLAPUR_110,MIA NVI_110	3:04	3:24	12:20	LINE FAULT
839	5-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:42	4:05	13:20	LINE FAULT
840	5-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:16	5:23	14:20	LINE FAULT
841	5-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:26	5:36	15:20	LINE FAULT
842	5-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAMDINNI,MADLAPUR_110,MIA NVI_110	5:25	5:35	16:20	LINE FAULT
843	5-Jun-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:54	2:04	17:20	LINE FAULT
844	5-Jun-2021	GULBARGA	110	CHIDRI-HALBARGA2	CHIDRI_110	10:50	12:15	1:25	LINE CLEAR AVAILED
845	5-Jun-2021	GULBARGA	110	HV2	KAVITAL_110	0:27	9:00	8:33	TRANSFORMER FAULT
846	5-Jun-2021	GULBARGA	110	HV2	SANKLAPUR_110	11:05	12:30	1:25	LINE CLEAR AVAILED
847	5-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	11:40	11:45	0:05	TRANSFORMER FAULT
848	5-Jun-2021	GULBARGA	110	HV1	SANKLAPUR_110	13:15	14:39	1:24	LINE CLEAR AVAILED
849	5-Jun-2021	GULBARGA	110	SANKLAPUR-TORANGALLU	TORANGALLU_110	12:23	14:08	1:45	LINE CLEAR AVAILED
850	5-Jun-2021	GULBARGA	110	HV2	SINDHANOOR_110	17:05	17:30	0:25	TRANSFORMER FAULT
851	5-Jun-2021	GULBARGA	110	SINDHANOOR110-SINDHANOOR2	SINDHANOOR_110	0:20	0:30	0:10	LINE FAULT
852	5-Jun-2021	GULBARGA	110	HV1	SINDHANOOR_110	1:50	2:05	0:15	TRANSFORMER FAULT
853	5-Jun-2021	GULBARGA	110	HV1	SINDHANOOR_110	17:55	18:10	0:15	TRANSFORMER FAULT
854	5-Jun-2021	GULBARGA	110	HV1	SINDHANOOR_110	18:55	19:20	0:25	TRANSFORMER FAULT
855	5-Jun-2021	GULBARGA	110	HV1	SINDHANOOR_110	20:35	20:45	0:10	TRANSFORMER FAULT
856	5-Jun-2021	GULBARGA	110	SINDHANOOR110-VALKAMDINNI	VALKAMDINNI_110	2:20	2:50	0:30	LINE FAULT
857	5-Jun-2021	GULBARGA	110	SINDHANOOR110-VALKAMDINNI	VALKAMDINNI_110	3:20	3:30	0:10	LINE FAULT
858	5-Jun-2021	GULBARGA	110	SINDHANOOR110-VALKAMDINNI	VALKAMDINNI_110	20:35	20:45	0:10	LINE FAULT
859	5-Jun-2021	GULBARGA	110	SINDHANOOR110-MUDDAPURA	MUDDAPURA_110	2:20	2:30	0:10	LINE FAULT
860	5-Jun-2021	GULBARGA	110	HV3	YELBURGA_110	14:42	15:43	1:01	TRANSFORMER FAULT
861	5-Jun-2021	GULBARGA	110	HV3	YELBURGA_110	18:30	18:38	0:08	TRANSFORMER FAULT
862	5-Jun-2021	GULBARGA	110	HV3	YELBURGA_110	18:43	18:58	0:15	TRANSFORMER FAULT
863	5-Jun-2021	GULBARGA	110	HV3	YELBURGA_110	18:58	19:46	0:48	TRANSFORMER FAULT
864	5-Jun-2021	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWARTEMPLE_ 110	2:52	2:58	0:06	LINE FAULT
865	5-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADDEWAL_110,MOKATAGI_110,DEV SANGAR_110,REKOD_110,BTAGAWA TU_110,VALKAMDINNI_110,RAICHUR_110, MANNI_110	7:02	7:15	0:13	LINE FAULT
866	5-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	RAICHUR_110	0:12	0:48	0:36	LINE FAULT
867	5-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	RAICHUR_110	0:56	1:13	0:17	LINE FAULT
868	5-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:56	2:42	1:46	LINE FAULT
869	5-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KORDICROSS_110,MADLAPUR_110, SANKLAPUR_110,ALKOD_110,BTAGAWA TU_110,VALKAMDINNI_110,GOOGLE_110	1:50	2:10	0:20	LINE FAULT
870	5-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	RAICHUR_110	3:23	3:40	0:17	LINE FAULT
871	5-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:02	6:14	0:12	LINE FAULT
872	5-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:31	7:10	0:39	LINE FAULT
873	5-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	9:05	10:20	1:15	LINE FAULT
874	5-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:30	13:45	1:15	LINE FAULT
875	5-Jun-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	0:45	6:21	5:36	LINE FAULT
876	5-Jun-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:13	2:27	0:14	LINE FAULT
877	5-Jun-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:54	22:00	2:06	LINE FAULT
878	5-Jun-2021	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110	6:13	6:20	0:07	LINE FAULT
879	5-Jun-2021	GULBARGA	110	HALBARGA-CHIDRI	CHIDRI_110	11:02	12:10	1:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
880	5-Jun-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	15:00	16:20	1:20	LINE CLEAR AVAILED
881	5-Jun-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:06(3.6.2021)	22:29(5.6.2021)	55:23hrs	LINE CHARGED
882	5-Jun-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:04(3.06.2021)	22:33(5.6.2021)	55:29hrs	LINE CHARGED
883	5-Jun-2021	HASSAN	110	LV1	KADUR_220	12:27 (4.06.2021)	13:01(5.6.2021)	24:34hrs	TRANSFORMER CHARGED
884	5-Jun-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	4:57	7:13	2:16	LINE CLEAR AVAILED
885	5-Jun-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:26	12:43	2:17	NFBC ISSUED
886	5-Jun-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	15:02	16:29	1:27	LINE CLEAR AVAILED
887	5-Jun-2021	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	10:58	13:26	2:28	LINE CLEAR AVAILED
888	5-Jun-2021	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	10:58	13:26	2:28	LINE CLEAR AVAILED
889	5-Jun-2021	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	15:10	16:30	1:20	LINE CLEAR AVAILED
890	5-Jun-2021	HASSAN	110	HV1	MOODABIDRE_110	13:06	13:46	0:40	LINE CLEAR AVAILED
891	5-Jun-2021	HASSAN	66	CRPATNA-CHMUNDSUG	C R PATNA_220	13:45	14:45	1:00	LINE CLEAR AVAILED
892	5-Jun-2021	HASSAN	66	HV1	GORUR_66	12:36	13:06	0:30	LINE CLEAR AVAILED
893	5-Jun-2021	HASSAN	66	HV2	HOLEHONNUR_66	10:54	12:28	1:34	LINE CLEAR AVAILED
894	5-Jun-2021	HASSAN	66	HV2	HOLEHONNUR_66	15:52	17:04	1:12	LINE CLEAR AVAILED
895	5-Jun-2021	HASSAN	66	HV1	MAGGE_66	1:55	7:10	5:15	TRANSFORMER FAULT
896	5-Jun-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATAN_66	21:12	21:22	0:10	LINE FAULT
897	5-Jun-2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	12:40	12:45	0:05	HAND TRIPPED
898	5-Jun-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:35	12:44	0:09	LINE FAULT
899	5-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	13:35	18:44	5:09	LINE FAULT
900	5-Jun-2021	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	8:58	12:24	3:25	LINE CLEAR AVAILED
901	5-Jun-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	19:04	19:10	0:06	LINE FAULT
902	5-Jun-2021	MYSURU	66	HV1	KIADBMANDYA_66	11:24	11:52	0:28	LINE CLEAR AVAILED
903	5-Jun-2021	MYSURU	66	HV1	DUNDANAHALLI_66	12:10	13:31	1:21	LINE CLEAR AVAILED
904	5-Jun-2021	MYSURU	66	HV2	DUNDANAHALLI_66	10:35	12:10	1:35	LINE CLEAR AVAILED
905	5-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	19:31 (04/06/2021)	3:34 (05/06/2021)	18:02HRS	LINE CHARGED
906	5-Jun-2021	MYSURU	66	HV5	SFCSHIVA_66	8:09 (04/06/2021)	3:06 (05/06/2021)	18:56HRS	TRANSFORMER CHARGED
907	5-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:02 (05/06/2021)			LINE OPEN,LINE FAULT
908	5-Jun-2021	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	13:04(3.06.2021)	34:06 PM(05.06.2021)	48:34HRS	LINE CHARGED
909	5-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220kV- KORTEGERE	KORTEGERE,CHIKKATOTLOKERE_66, BELADARA_66	6:05:42 PM(03.06.2021)			LINE OPEN,LINE FAULT
910	5-Jun-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:46	13:01	0:14	HAND TRIPPED
911	5-Jun-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	14:33	16:35	2:01	LINE FAULT
912	5-Jun-2021	TUMKUR	220	HONNAVALI 110-TIPTUR	HONNAVALI_110	15:36	15:47	0:10	MAIN SUPPLY FAILURE
913	5-Jun-2021	TUMKUR	220	TR-3(HV SIDE)	THALLAKK_220	18:50	18:38	0:10	TRANSFORMER FAULT
914	5-Jun-2021	TUMKUR	110	TR-1	BANDIHALLI_110	15:36	15:47	0:10	LINE CLEAR AVAILED
915	5-Jun-2021	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	13:49	15:46	1:57	LINE CLEAR AVAILED
916	5-Jun-2021	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110,HALKURKE_110,HONSE	12:54	13:54	0:59	HAND TRIPPED
917	5-Jun-2021	TUMKUR	110	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66,HD-01A_66, CHITRADURGA_66	6:52	7:12	0:19	LINE FAULT
918	5-Jun-2021	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	CHITRADURGA_66,CHITRADURGA_66	6:52	7:05	0:12	LINE FAULT
919	5-Jun-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1 IPP	MEGMICON_1 IPP_66	6:52	8:06	1:13	LINE FAULT
920	5-Jun-2021	TUMKUR	66	TR-2	DAVANAGERE_66	14:33	14:52	0:19	LINE CLEAR AVAILED
921	5-Jun-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJI_66,MELK	16:32	17:55	1:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
922	5-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:34	5:45	0:11	LINE FAULT
923	5-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:27	14:34	0:07	LINE FAULT
924	5-Jun-2021	TUMKUR	66	TR-3	HOLALKERE_66	16:44	16:54	0:09	TRANSFORMER FAULT
925	5-Jun-2021	TUMKUR	66	TR-1	HONNALI_66	6:47	10:07	3:19	LINE CLEAR AVAILED
926	5-Jun-2021	TUMKUR	66	TR-2	HONNALI_66	7:14	10:22	3:07	LINE CLEAR AVAILED
927	5-Jun-2021	TUMKUR	66	HONNALLI 220kv- KUNDOOR66	KUNDUR_66,MALEBENINUR_66	10:14	10:24	0:09	LINE FAULT
928	5-Jun-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	11:40	11:50	0:09	LINE FAULT
929	5-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN	9:08	13:30	4:22	LINE CLEAR AVAILED
930	5-Jun-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN	14:25	14:32	0:06	LINE FAULT
931	5-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:02	12:07	0:05	LINE FAULT
932	5-Jun-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	18:07	18:11	0:03	LINE FAULT
933	5-Jun-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	RAMPURA_66	18:15	18:26	0:11	MAIN SUPPLY FAILURE
934	5-Jun-2021	TUMKUR	66	TR-1	RAMPURA_66	8:20	8:52	0:31	HAND TRIPPED
935	5-Jun-2021	TUMKUR	66	RAMPURA66-HANAGAL66	RAMPURA_66	17:42	18:28	0:45	LINE FAULT
936	5-Jun-2021	TUMKUR	66	TR-3(LV SIDE)	THALLAKK_220	18:38	18:52	0:45	TRANSFORMER FAULT
937	5-Jun-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:45	18:53	0:45	HAND TRIPPED
938	5-Jun-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	18:39	18:53	0:45	LINE FAULT
939	5-Jun-2021	TUMKUR	66	TR-1	PAVAGADA_220	16:39	16:41	0:45	TRANSFORMER FAULT
940	5-Jun-2021	TUMKUR	66	TR-1	PAVAGADA_220	21:06	21:07	0:45	TRANSFORMER FAULT
941	5-Jun-2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	23:24	23:30	0:45	LINE FAULT
942	6-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED	19:41(25.05.2020)			LINE OPEN,LINE FAULT
943	6-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
944	6-Jun-2021	BAGALKOT	110	KANEBEVINUR220- HONNALLI	NO STATION EFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
945	6-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
946	6-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
947	6-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
948	6-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED	17:22(30.03.2021)			LINE OPEN,LINE FAULT
949	6-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
950	6-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
951	6-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
952	6-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
953	6-Jun-2021	BAGALKOT	110	JAMKHANDI- DRABHULINGESHWARISIDDAPUR	STATION NOT AFFECTED	13:12(04.06.2021)			LINE OPEN,LINE CLEAR AVAILED
954	6-Jun-2021	BAGALKOT	110	110/33KV,HV2	AMKOLA_110 & 110	8:46	8:56	0:10	TRANSFORMER FAULT
955	6-Jun-2021	BAGALKOT	110	BAGALKOT-KERUR	MASTIKATTARSEARIPUR_22	3:19	3:40	0:21	LINE FAULT
956	6-Jun-2021	BAGALKOT	220	220/110KV,HV1 & LV 1	KERUR_110	15:41	15:55	0:14	TRANSFORMER FAULT
957	6-Jun-2021	BAGALKOT	220	220/110KV,HV2 & LV 2	BIJAPUR_220	15:41	15:55	0:14	TRANSFORMER FAULT
958	6-Jun-2021	BAGALKOT	220	BIJAPUR-VAISHALI 1	BIJAPUR_220	15:41	16:21	0:40	LINE FAULT
959	6-Jun-2021	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	21:53	22:01	0:08	LINE FAULT
960	6-Jun-2021	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	10:56 (06.06.2021)			LINE OPEN,LINE CLEAR AVAILED
961	6-Jun-2021	BAGALKOT	110	110/11KV, HV1A	JAMKHANDI_110	11:55	12:50	0:55	LINE CLEAR AVAILED
962	6-Jun-2021	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	11:55	12:50	0:55	LINE CLEAR AVAILED
963	6-Jun-2021	BAGALKOT	110	110/11KV, HV3	JAMKHANDI_110	11:55	12:50	0:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
964	6-Jun-2021	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	5:31	11:47	6:16	TRANSFORMER FAULT
965	6-Jun-2021	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	22:06	22:10	0:04	HAND TRIPPED
966	6-Jun-2021	BAGALKOT	110	RON-GAJENDRAGAD1&GAJENDRAGAD2	RON_110	16:20(04.06.2021)	3:43(06.06.2021)	35:23HRS	LINE CHARGED
967	6-Jun-2021	BAGALKOT	110	RON-GMSH	RON_110	3:43	3:46	0:03	HAND TRIPPED
968	6-Jun-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	5:14	5:25	0:11	TRANSFORMER FAULT
969	6-Jun-2021	BENGALURU	66	HV1	APPAREL PARK	9:50	10:40	0:50	LINE CLEAR AVAILED
970	6-Jun-2021	BENGALURU	66	HV2	APPAREL PARK	10:38	12:16	1:38	LINE CLEAR AVAILED
971	6-Jun-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELETHALLI, JALAMANICALA	10:56	11:04	0:08	LINE CLEAR AVAILED
972	6-Jun-2021	BENGALURU	66	HV1	C STATION	19:46	20:08	0:22	TRANSFORMER FAULT
973	6-Jun-2021	BENGALURU	66	HV3	EPIP 220	23:02	23:16	0:14	TRANSFORMER FAULT
974	6-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISKR (EHT), KADUBISANAHALLI, GEGNO PARK	10:20	10:29	0:09	LOAD CHANGE OVER
975	6-Jun-2021	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:20	10:29	0:09	LOAD CHANGE OVER
976	6-Jun-2021	BENGALURU	66	HV1	KHB	12:00	12:22	0:22	TRANSFORMER FAULT
977	6-Jun-2021	BENGALURU	66	KODIGEHALI - T G HALLI	TAVAREKERE	6:26	6:34	0:08	LINE FAULT
978	6-Jun-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	10:50	12:29	1:39	LINE CLEAR AVAILED
979	6-Jun-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	15:27	16:40	1:13	LINE CLEAR AVAILED
980	6-Jun-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNANAHALLI	16:12	16:26	0:14	LINE FAULT
981	6-Jun-2021	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	12:02	12:10	0:08	LOAD CHANGE OVER
982	6-Jun-2021	BENGALURU	66	SURYANAGAR - YERANDANAHALLI	SURYANAGAR	12:31	12:40	0:09	LOAD CHANGE OVER
983	6-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	10:05	10:10	0:05	LINE FAULT
984	6-Jun-2021	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	14:40	14:56	0:16	LOAD CHANGE OVER
985	6-Jun-2021	BENGALURU	66	JIGANI 66 - SOMANAHALLI 220	JIGANI 66	17:51	17:58	0:07	LOAD CHANGE OVER
986	6-Jun-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	14:21	14:42	0:21	LOAD CHANGE OVER
987	6-Jun-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	22:09	22:16	0:06	LINE FAULT
988	6-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	22:17	22:23	0:06	LINE FAULT
989	6-Jun-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	8:10	8:17	0:07	LINE FAULT
990	6-Jun-2021	BENGALURU	66	HV1	SOMENAHALLI	6:01	6:15	0:14	TRANSFORMER FAULT
991	6-Jun-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	5:27	6:09	0:42	LINE FAULT
992	6-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	0:05	6:25	6:20	LINE CLEAR AVAILED
993	6-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN,LINE CLEAR AVAILED
994	6-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAVIDINNI,VIADLAPUR_110,VI NW_110	1:31	1:41	0:10	LINE FAULT
995	6-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110	2:05	10:38	8:33	LINE FAULT
996	6-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110	1:47	1:57	0:10	LINE FAULT
997	6-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAVIDINNI,VIADLAPUR_110,VI NW_110	2:51	3:01	0:10	LINE FAULT
998	6-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:02	4:12	0:10	LINE FAULT
999	6-Jun-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAVIDINNI,VIADLAPUR_110,VI NW_110	19:37	19:47	0:10	LINE FAULT
1000	6-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	1:38	1:54	0:16	LINE FAULT
1001	6-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	3:35	4:20	0:45	LINE FAULT
1002	6-Jun-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	PGLR_WIND_IPP	11:36	15:40	4:04	LINE FAULT
1003	6-Jun-2021	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	20:25	20:35	0:10	LINE FAULT
1004	6-Jun-2021	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	18:30(5.06.2021)	7:10(06.06.2021)	12:40 HRS	LINE CHARGED
1005	6-Jun-2021	GULBARGA	110	HV2	GULBARGA UNIVERSITY_110	2:25	5:45	3:20	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1006	6-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:35	19:49	0:14	LINE FAULT
1007	6-Jun-2021	GULBARGA	110	HV3	KEREHALLI_110	8:20	8:26	0:06	TRANSFORMER FAULT
1008	6-Jun-2021	GULBARGA	110	HV3	KEREHALLI_110	12:27	12:33	0:06	TRANSFORMER FAULT
1009	6-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
1010	6-Jun-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	12:20	12:40	0:20	MAIN SUPPLY FAILURE
1011	6-Jun-2021	GULBARGA	110	SINDHANOOR110-VALKAMDINNI	VALKAMDINNI_110	2:20	2:30	0:10	LINE FAULT
1012	6-Jun-2021	GULBARGA	110	SINDHANOOR110-MUDDAPURA	MUDDAPURA_110	1:10	1:15	0:05	LINE FAULT
1013	6-Jun-2021	GULBARGA	110	SINDHANOOR110-MUDDAPURA	MUDDAPURA_110	1:15	2:20	1:05	LINE FAULT
1014	6-Jun-2021	GULBARGA	110	SINDHANOOR110-SINDHANOOR2	SINDHANOOR_110	10:13	10:23	0:10	LINE FAULT
1015	6-Jun-2021	GULBARGA	110	SINDHANOOR110-SINDHANOOR1	SINDHANOOR_110	10:13	10:23	0:10	LINE FAULT
1016	6-Jun-2021	GULBARGA	110	HV3	YELBURGA_110	9:10	10:10	1:00	TRANSFORMER FAULT
1017	6-Jun-2021	GULBARGA	110	LINGASUGUR-BAGEWADI3CUBCHUNTA_110,KHULI_IPB_WV		11:30	13:10	1:40	LINE FAULT
1018	6-Jun-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MOKATAGI_110,DEV ANGAON_110,BENLUKA_IPB,AFZALPUR	5:40	5:48	0:08	LINE FAULT
1019	6-Jun-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	9:42	10:15	0:33	LINE FAULT
1020	6-Jun-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	16:51	16:59	0:08	LINE FAULT
1021	6-Jun-2021	GULBARGA	110	HALBARGA-SANTHPUR	SANTHAPUR_110	19:35	19:40	0:05	LINE FAULT
1022	6-Jun-2021	GULBARGA	66	KOTTUR-KUDLIGI	UJJANI_66	18:51	19:09	0:18	LINE FAULT
1023	6-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1024	6-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:52(06.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1025	6-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:03	7:13	6:10	LINE CLEAR AVAILED
1026	6-Jun-2021	HASSAN	110	HV2	HALADY_110	2:03	14:45	12:42	TRANSFORMER FAULT
1027	6-Jun-2021	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	12:38	13:26	0:48	HAND TRIPPED
1028	6-Jun-2021	HASSAN	66	CHIKKAK-HASN	CHIKKAKONDAGOLA_66	12:06	13:07	1:01	LINE FAULT
1029	6-Jun-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66	8:08	8:15	0:06	LINE FAULT
1030	6-Jun-2021	MYSURU	66	MADDUR-SOMANAHALLI	SOMANAHALLI_66	14:42	14:52	0:10	LINE FAULT
1031	6-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:02 (05/06/2021)	8:18 (06/06/2021)	21:15HRS	LINE CHARGED
1032	6-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORTEGERE	KORTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	6:05:42 PM(03.06.2021)	3:09 PM(06.06.2021)	55:56HRS	LINE CHARGED
1033	6-Jun-2021	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTUNARASAPURA_2	ANTHRASANAHALLI_220	11:50	14:23	2:32	LINE CLEAR AVAILED
1034	6-Jun-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	9:52	11:34	1:41	LINE CLEAR AVAILED
1035	6-Jun-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	9:56	11:41	1:44	LINE CLEAR AVAILED
1036	6-Jun-2021	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	2:46	3:09	0:23	TRANSFORMER FAULT
1037	6-Jun-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAKMANASANDRA_66,THOVINAKERE	7:41	8:13	0:31	LINE FAULT
1038	6-Jun-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	10:42	10:49	0:07	TRANSFORMER FAULT
1039	6-Jun-2021	TUMKUR	66	TR-3	HARIYABBE_66	14:03	14:07	0:03	TRANSFORMER FAULT
1040	6-Jun-2021	TUMKUR	66	TR-1	HARIYABBE_66	8:17	10:45	2:28	LINE CLEAR AVAILED
1041	6-Jun-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	19:38	19:48	0:09	TRANSFORMER FAULT
1042	6-Jun-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	5:29	5:46	0:17	LINE FAULT
1043	6-Jun-2021	TUMKUR	66	HONNALLI 220kv- KUNDOOR66	KUNDOOR_66,MALEBENINUR_66	12:47	12:57	0:10	LINE FAULT
1044	6-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	DEVABARELUKERE_66	9:52	10:07	0:14	LINE FAULT
1045	6-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:42	11:04	0:22	LINE FAULT
1046	6-Jun-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:43	11:46	0:02	LINE FAULT
1047	6-Jun-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	9:22	10:00	0:38	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1048	6-Jun-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	23:44	23:50	0:06	LINE FAULT
1049	6-Jun-2021	TUMKUR	66	TR-1	RAMAPURA_66	9:31	9:49	0:17	TRANSFORMER FAULT
1050	6-Jun-2021	TUMKUR	66	TR-1	RAMAPURA_66	16:33	16:45	0:12	TRANSFORMER FAULT
1051	6-Jun-2021	TUMKUR	66	PAVAGADA_220-NAGALMADIKE	PAVAGADA_220	15:45	15:52	0:12	LINE FAULT
1052	6-Jun-2021	TUMKUR	66	YEDIYUR- ANCHEPALYA220KV	YEDIYUR_66	1:10	1:28	0:12	MAIN SUPPLY FAILURE
1053	6-Jun-2021	TUMKUR	66	YEDIYUR- ANCHEPALYA220KV	YEDIYUR_66	5:18	6:46	0:12	MAIN SUPPLY FAILURE
1054	6-Jun-2021	TUMKUR	66	TR-1	THIPPUR_66	5:13	6:50	0:12	TRANSFORMER FAULT
1055	7-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED	19:41(25.05.2020)			LINE OPEN,LINE FAULT
1056	7-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED	12:45(04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
1057	7-Jun-2021	BAGALKOT	110	KANEENUR220- HONNATTI (ADEMALLAPUR)	NO STATION EFFECTED	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
1058	7-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1059	7-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1060	7-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
1061	7-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED	17:22(30.03.2021)			LINE OPEN,LINE FAULT
1062	7-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
1063	7-Jun-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
1064	7-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
1065	7-Jun-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED	15:17(15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
1066	7-Jun-2021	BAGALKOT	110	JAMAKHANDI-(PRABHOLINGESHWAR) SIDDAPUR	STATION NOT AFFECTED	13:12(04.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1067	7-Jun-2021	BAGALKOT	110	HIREHAL- RON	HIREHAL_110	10:56 (06.06.2021)	08:08 (07.06.2021)	21:12HRS	LINE CHARGED
1068	7-Jun-2021	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:15	11:36	1:21	LINE CLEAR AVAILED
1069	7-Jun-2021	BAGALKOT	220	AMBEWADI- PONDA1(XELDOM)	AMBEWADI_220	10:10	16:00	5:50	LINE FAULT
1070	7-Jun-2021	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	13:05	17:49	4:44	LINE FAULT
1071	7-Jun-2021	BAGALKOT	220	BAGEWADI- LINGASUR2	BAGEWADI_220	12:16	14:21	2:05	LINE CLEAR AVAILED
1072	7-Jun-2021	BAGALKOT	110	VAJRAMATTI220- KD JAMBAGI	KD JAMBAGI_110	1:30	1:40	0:10	LINE FAULT
1073	7-Jun-2021	BAGALKOT	110	110/33KV, HV3&HV4	MACHE_110, AKP_33, RM1_33	17:21	17:26	0:05	TRANSFORMER FAULT
1074	7-Jun-2021	BAGALKOT	110	220/110KV, LV3	MAHALINGAPUR_220	5:22	6:05	0:43	TRANSFORMER FAULT
1075	7-Jun-2021	BAGALKOT	110	MAHALINGAPUR- RABKAVI	RABKAVI_110	5:22	6:32	1:10	LINE CLEAR AVAILED
1076	7-Jun-2021	BAGALKOT	110	220/110KV, LV2	MAHALINGAPUR_220	19:14	19:27	0:13	TRANSFORMER FAULT
1077	7-Jun-2021	BAGALKOT	110	MAHALINGAPUR- GSML1	MAHALINGAPUR_220	19:14	19:35	0:21	LINE FAULT
1078	7-Jun-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	8:14 (07.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1079	7-Jun-2021	BAGALKOT	110	RON- GAMESHA	RON_110	8:14	8:18	0:04	HAND TRIPPED
1080	7-Jun-2021	BAGALKOT	110	SOUDATTI- RAMDURGA1 (UDIKERI)	UDIKERI_110	11:53	13:06	1:13	LINE CLEAR AVAILED
1081	7-Jun-2021	BAGALKOT	110	110/11KV,HV1	TILUVALLI_110	16:03	17:36	1:33	LINE CLEAR AVAILED
1082	7-Jun-2021	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	6:20	6:30	0:10	HAND TRIPPED
1083	7-Jun-2021	BAGALKOT	110	110/11KV,HV1	ZALKI_110	13:29	16:10	2:41	LINE CLEAR AVAILED
1084	7-Jun-2021	BAGALKOT	220	GHATAPRABHA-CHIKKODI2(MUGALKOD2)	GHATAPRABHA_220	10:58	12:27	1:29	LINE CLEAR AVAILED
1085	7-Jun-2021	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI, BOSCH (EHT)	13:40	13:50	0:10	LOAD CHANGE OVER
1086	7-Jun-2021	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	16:48	17:02	0:14	LINE FAULT
1087	7-Jun-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	4:35	5:08	0:33	LINE FAULT
1088	7-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	8:03	8:42	0:39	LINE FAULT
1089	7-Jun-2021	BENGALURU	66	HOODY 220 - BMRL (EHT)	BMRL (EHT)	11:13	14:58	3:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1090	7-Jun-2021	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	12:05	12:10	0:05	LINE FAULT
1091	7-Jun-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	11:29	12:07	0:38	LINE CLEAR AVAILED
1092	7-Jun-2021	BENGALURU	66	HV1	MITTEMARI 220	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1093	7-Jun-2021	BENGALURU	66	HV1	MULBAGAL	14:13	14:31	0:18	LINE CLEAR AVAILED
1094	7-Jun-2021	BENGALURU	66	HV1	DABUSPET 220	11:13	12:28	1:15	LINE CLEAR AVAILED
1095	7-Jun-2021	BENGALURU	66	HV2	KHB	11:50	11:53	0:03	LINE CLEAR AVAILED
1096	7-Jun-2021	BENGALURU	66	HV2	NIMHANS 220	10:11	10:13	0:02	LINE CLEAR AVAILED
1097	7-Jun-2021	BENGALURU	66	HV2	MAASTHI	17:50	19:30	1:40	LINE CLEAR AVAILED
1098	7-Jun-2021	BENGALURU	66	HV2	MAASTHI	19:50	20:00	0:10	LINE CLEAR AVAILED
1099	7-Jun-2021	BENGALURU	66	HV2	MAASTHI	9:35	11:35	2:00	TRANSFORMER FAULT
1100	7-Jun-2021	BENGALURU	66	HV2	MAASTHI	2:45	3:25	0:40	TRANSFORMER FAULT
1101	7-Jun-2021	BENGALURU	66	HV2	SIDDALAGATTA	11:15	11:20	0:05	LINE CLEAR AVAILED
1102	7-Jun-2021	BENGALURU	66	JAYADEVA - ADUGODI	JAYADEVA	12:16	12:18	0:02	LOAD CHANGE OVER
1103	7-Jun-2021	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	10:54	11:02	0:08	LOAD CHANGE OVER
1104	7-Jun-2021	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALCERE, DASHAVARA	13:01	13:07	0:06	LINE FAULT
1105	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1106	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1107	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1108	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1109	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1110	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELOR, CHAKAVELLU, VENICADALE	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1111	7-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	4:35	5:08	0:33	MAIN SUPPLY FAILURE
1112	7-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	11:55	12:00	0:05	LINE FAULT
1113	7-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	12:00	12:10	0:10	LINE FAULT
1114	7-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	12:15	12:25	0:10	LINE FAULT
1115	7-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	13:00	13:15	0:15	LINE FAULT
1116	7-Jun-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	14:45	14:50	0:05	LINE FAULT
1117	7-Jun-2021	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	9:40	17:31	7:51	NFBC ISSUED
1118	7-Jun-2021	GULBARGA	220	ITTAGI-BMMISPAT_IPP	ITTAGI_220	12:50	20:20	7:30	NFBC ISSUED
1119	7-Jun-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:45(05.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1120	7-Jun-2021	GULBARGA	110	SINDHANOOR110-SINDHANOOR1	SINDHANOOR_110	11:21	12:40	1:19	LINE CLEAR AVAILED
1121	7-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHPUR_110	19:00	19:10	0:10	LINE FAULT
1122	7-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHPUR_110	21:30	21:35	0:05	LINE FAULT
1123	7-Jun-2021	GULBARGA	110	KAPNOOR-KADAGANCHI	KADAGANCHI_110	11:42	11:50	0:08	LINE FAULT
1124	7-Jun-2021	GULBARGA	110	KAPNOOR-KADAGANCHI	KADAGANCHI_110	14:10	14:35	0:25	LINE CLEAR AVAILED
1125	7-Jun-2021	GULBARGA	110	HV2	SHAHAPUR_220	17:51	18:09	0:18	TRANSFORMER FAULT
1126	7-Jun-2021	GULBARGA	110	SINDHNOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	11:30	12:43	1:13	LINE CLEAR AVAILED
1127	7-Jun-2021	GULBARGA	110	SINDHANOOR110-VALKAMDINNI	VALKAMDINNI_110	4:35	4:45	0:10	LINE FAULT
1128	7-Jun-2021	GULBARGA	66	KUDLIGI-BALADAKU	KUDLIGI_66	2:47	2:55	0:08	LINE FAULT
1129	7-Jun-2021	GULBARGA	66	KUDLIGI-ITTAGGI1	KUDLIGI_66,KOGALI_66	2:47	6:40	3:53	LINE FAULT
1130	7-Jun-2021	GULBARGA	66	ITAAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66,UPHALLI_66	13:20	13:25	0:05	LINE CLEAR AVAILED
1131	7-Jun-2021	GULBARGA	66	ITAAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66,UPHALLI_66	19:57	20:00	0:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1132	7-Jun-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1133	7-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:52(06.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1134	7-Jun-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:56	6:44	5:48	LINE CLEAR AVAILED
1135	7-Jun-2021	HASSAN	220	HV2	KAVOOR_220	9:05	14:18	5:13	LINE CLEAR AVAILED
1136	7-Jun-2021	HASSAN	110	LV2	KAVOOR_220	9:05	14:18	5:13	LINE CLEAR AVAILED
1137	7-Jun-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:06	13:39	4:33	NFBC ISSUED
1138	7-Jun-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:25	12:32	2:07	LINE CLEAR AVAILED
1139	7-Jun-2021	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	9:07	14:17	5:10	LINE CLEAR AVAILED
1140	7-Jun-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	15:01	16:13	1:12	LINE FAULT
1141	7-Jun-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:07	13:38	4:31	LINE CLEAR AVAILED
1142	7-Jun-2021	HASSAN	110	HV1	DMKURKE_110	15:07	15:34	0:27	LINE CLEAR AVAILED
1143	7-Jun-2021	HASSAN	110	HV1	KALLUSADARAHALLY_110	14:22	14:42	0:20	LINE CLEAR AVAILED
1144	7-Jun-2021	HASSAN	110	HV1	KONAJE_110	9:44	9:45	0:01	HAND TRIPPED
1145	7-Jun-2021	HASSAN	110	HV2	KONAJE_110	9:44	9:45	0:01	HAND TRIPPED
1146	7-Jun-2021	HASSAN	110	HV3	KONAJE_110	9:44	9:45	0:01	HAND TRIPPED
1147	7-Jun-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:00	16:36	5:36	NFBC ISSUED
1148	7-Jun-2021	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	15:10	16:30	1:20	LINE CLEAR AVAILED
1149	7-Jun-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:30	12:34	2:04	NFBC ISSUED
1150	7-Jun-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:33	11:56	0:23	LINE CLEAR AVAILED
1151	7-Jun-2021	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	11:33	11:55	0:22	LINE CLEAR AVAILED
1152	7-Jun-2021	HASSAN	66	BHADRA-SHMG 2	bhadra_gen	11:33	11:55	0:22	LINE CLEAR AVAILED
1153	7-Jun-2021	HASSAN	66	HASSN220-BELUR	HASSAN_220	10:19	14:45	4:26	LINE CLEAR AVAILED
1154	7-Jun-2021	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	12:25	14:43	2:18	LINE CLEAR AVAILED
1155	7-Jun-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	13:52	14:01	0:09	LINE FAULT
1156	7-Jun-2021	HASSAN	66	SAKALE-IPCL1	SAKALESHUPURA_66	13:32	16:56	3:24	LINE CLEAR AVAILED
1157	7-Jun-2021	HASSAN	66	HV2	SALAGAME_66	11:32	11:53	0:21	LINE CLEAR AVAILED
1158	7-Jun-2021	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	12:26	14:42	2:16	NFBC ISSUED
1159	7-Jun-2021	HASSAN	66	HV1	YESLUR_66	13:53	14:13	0:20	LINE CLEAR AVAILED
1160	7-Jun-2021	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	10:05	13:54	3:48	LINE CLEAR AVAILED
1161	7-Jun-2021	MYSURU	220	KADAKOLA-BEGUR 1	NO STATIONS EFFECTED	12:00	13:42	1:42	LINE CLEAR AVAILED
1162	7-Jun-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	0:49(7.6.21)			LINE OPEN,LINE FAULT
1163	7-Jun-2021	MYSURU	66	HV3	KUSHALANAGARA_66	19:44	20:32	0:47	LINE CLEAR AVAILED
1164	7-Jun-2021	MYSURU	66	HV2	PERIYAPATNA_66	23:38	23:49	0:10	TRANSFORMER FAULT
1165	7-Jun-2021	MYSURU	66	HV2	TERAKANAMBE_66	9:41	11:00	1:18	LINE CLEAR AVAILED
1166	7-Jun-2021	TUMKUR	110	TR-1	HONNAVALLI_110	10:10	18:56	8:45	LINE CLEAR AVAILED
1167	7-Jun-2021	TUMKUR	110	TR-1	TURUVEKERE_110	10:55	14:47	3:51	LINE CLEAR AVAILED
1168	7-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHANNAGIRI_66	9:32	9:43	0:11	LINE FAULT
1169	7-Jun-2021	TUMKUR	66	TR-2	AVAREGERE_66	11:46	12:40	0:53	LINE CLEAR AVAILED
1170	7-Jun-2021	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	11:55	13:27	1:32	LINE CLEAR AVAILED
1171	7-Jun-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	7:26	7:34	0:07	TRANSFORMER FAULT
1172	7-Jun-2021	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANKERE_66	11:49	13:28	1:38	LINE CLEAR AVAILED
1173	7-Jun-2021	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	5:44	5:53	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1174	7-Jun-2021	TUMKUR	66	TR-2	GUTTUR_66	12:51	14:38	1:47	LINE CLEAR AVAILED
1175	7-Jun-2021	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	13:36	13:53	0:16	LINE CLEAR AVAILED
1176	7-Jun-2021	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	14:03	15:42	1:38	LINE CLEAR AVAILED
1177	7-Jun-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_66	19:00	19:07	0:07	LINE FAULT
1178	7-Jun-2021	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	14:36	15:03	0:27	LINE CLEAR AVAILED
1179	7-Jun-2021	TUMKUR	66	TR-1	PAVAGADA_66	12:15	13:45	1:30	LINE CLEAR AVAILED
1180	7-Jun-2021	TUMKUR	66	TR-1	TUMKUR_66	8:30	8:52	0:22	TRANSFORMER FAULT
1181	7-Jun-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:26	5:28	0:02	LINE FAULT