

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 01.12.2020 TO 07.12.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	1-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
2	1-Dec-2020	BAGALKOT	110	110/11KV ,HV2	ZALKI_110	07:32	07:34	0:02	TRANSFORMER FAULT
3	1-Dec-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)	17:44 (01.12.2020)	409:39 hrs	TRANSFORMER CHARGED
4	1-Dec-2020	BAGALKOT	110	110/11KV, HV1	THORVI_110	11:08	12:30	1:22	LINE CLEAR AVAILED
5	1-Dec-2020	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	06:11	08:01	1:50	LINE CLEAR AVAILED
6	1-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
7	1-Dec-2020	BAGALKOT	110	110/11KV,HV 2	KALAGHATGI_110	07:42	07:47	0:05	TRANSFORMER FAULT
8	1-Dec-2020	BAGALKOT	110	110/11KV,HV2	ITANAL_110	8:05	08:10	0:05	TRANSFORMER FAULT
9	1-Dec-2020	BAGALKOT	110	110/33KV HV4	LAKAMANAHALLI_110 & ALNAVAR 33	10:01	10:05	0:04	TRANSFORMER FAULT
10	1-Dec-2020	BAGALKOT	110	110/33KV,HV2 ,LV2	UTTUR_110,YADWAD_110,VANTIGODI_110	12:41	12:50	0:09	TRANSFORMER FAULT
11	1-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
12	1-Dec-2020	BAGALKOT	110	220/110KV,LV3	HUBLI_220	17:39 (26.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
13	1-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
14	1-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
15	1-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
16	1-Dec-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	10:00	14:07	4:07	LOAD CHANGE OVER
17	1-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
18	1-Dec-2020	BAGALKOT	110	KAVALWAD -HUBLI TO KALAGHATGI	KALAGHTGI_110	09:51	15:15	5:24	LOAD CHANGE OVER
19	1-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
20	1-Dec-2020	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	13:08	17:15	4:07	LOAD CHANGE OVER
21	1-Dec-2020	BAGALKOT	110	MAHALINGAPUR-DHAVLESHWAR	(STATION NOT AFFECTED) DHAVALLESHWAR_110	13:10 (30.11.2020)	8:39(01.12.2020)	19:29 hrs	LINE CHARGED
22	1-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
23	1-Dec-2020	BAGALKOT	110	SRS HUBLI-KADANAKOPPA	KADANAKOPPA_110	10:15	13:58	3:43	LINE CLEAR AVAILED
24	1-Dec-2020	BAGALKOT	110	SRS HUBLI-KALAGHATGI	KALAGHATGI_110	10:14	13:58	3:44	LINE CLEAR AVAILED
25	1-Dec-2020	BAGALKOT	110	SRS HUBLI-TARIHAL 2	TARIHAL_110	18:19 (01.12.2020)			LINE OPEN,LINE FAULT
26	1-Dec-2020	BAGALKOT	110	SRS HUBLI2-TARIHAL	STATION NOT AFFECTED TARIHAL_110	18:41 (1.12.2020)			LINE OPEN,LINE CLEAR AVAILED
27	1-Dec-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	STATION NOT AFFECTED	18:41	18:45	0:04	LINE CLEAR AVAILED
28	1-Dec-2020	BAGALKOT	110	TARIHAL-TADASINKOPPA NAVANAGAR(H)	TARIHAL_110	15:00 (30.11.2020)	13:18 (01.12.2020)	22:18 HRS	LINE CHARGED
29	1-Dec-2020	BAGALKOT	110	TODALBAGI-MAMDAPUR(B)	STATION NOT AFFECTED	17:47	18:28	0:41	HAND TRIPPED
30	1-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR_110	13:10 (30.11.2020)			LINE OPEN,LINE FAULT
31	1-Dec-2020	BAGALKOT	110	VAJRAMATTI-KATARKI	KATARKI_110	06:23	06:36	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
32	1-Dec-2020	BAGALKOT	110	VAJRAMATTI-LOKAPUR	STATION NOT AFFECTED	07:11	10:09	2:58	LINE FAULT
33	1-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
34	1-Dec-2020	BAGALKOT	220	220/110KV, HV 1 & LV1	SOUDATTI_220	10:26	14:19	3:53	LINE CLEAR AVOID
35	1-Dec-2020	BAGALKOT	220	220/110KV, HV 2 & LV2	SOUDATTI_220	15:27	17:39	2:12	LINE CLEAR AVOID
36	1-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN, LINE CLEAR AVOID
37	1-Dec-2020	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	15:50	18:27	2:37	LINE CLEAR AVOID
38	1-Dec-2020	BAGALKOT	220	NARENDRA-KANABARAGI	NARENDRA_220	17:49	18:28	0:39	HAND TRIPPED
39	1-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
40	1-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
41	1-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN, LINE CLEAR AVOID
42	1-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
43	1-Dec-2020	BENGALURU	66	HV1	DALASANUR	14:35	15:00	00:25	LINE CLEAR AVOID
44	1-Dec-2020	BENGALURU	66	HV2	HULIMANGALA	17:20	18:15	00:55	LINE CLEAR AVOID
45	1-Dec-2020	BENGALURU	66	HV2	DALASANUR	14:00	14:35	00:35	LINE CLEAR AVOID
46	1-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN, LINE CLEAR AVOID
47	1-Dec-2020	GULBARGA	66	HV1	KUDLIGI_66	08:45	08:50	00:05	TRANSFORMER FAULT
48	1-Dec-2020	GULBARGA	66	HV1	KUDLIGI_66	11:00	12:40	01:40	LINE CLEAR AVOID
49	1-Dec-2020	GULBARGA	66	HV2	KUDLIGI_66	12:50	13:30	00:40	LINE CLEAR AVOID
50	1-Dec-2020	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	11:25	13:40	02:15	LINE CLEAR AVOID
51	1-Dec-2020	GULBARGA	110	HV2	MANVI_110	10:57	11:07	00:10	TRANSFORMER FAULT
52	1-Dec-2020	GULBARGA	110	HV2	MANVI_110	12:19	12:29	00:10	TRANSFORMER FAULT
53	1-Dec-2020	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	20:44(26.11.2020)	15:45(01.12.2020)	115:01HRS	LINE CHARGED
54	1-Dec-2020	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	15:46	18:25	02:39	LINE FAULT
55	1-Dec-2020	GULBARGA	110	LV1	KUSHTAGI_220	15:46	16:15	00:29	TRANSFORMER FAULT
56	1-Dec-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	20:27	20:49	00:22	LINE FAULT
57	1-Dec-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:19(01.12.2020)			LINE OPEN, LINE FAULT
58	1-Dec-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	13:50	19:19	05:29	NFBC ISSUED
59	1-Dec-2020	GULBARGA	220	HV2	SEDAM_220	9:24(01.12.2020)			TRANSFORMER OPEN, LINE CLEAR AVOID
60	1-Dec-2020	GULBARGA	220	HV2	ITTAGI_220	14:45	16:30	01:45	LINE CLEAR AVOID
61	1-Dec-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:40 (25.11.2020)			LINE OPEN, LINE CLEAR AVOID
62	1-Dec-2020	HASSAN	66	HV1	MAGGE_66	12:29	13:34	01:05	MAIN SUPPLY FAILURE
63	1-Dec-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:57	11:24	00:27	LINE CLEAR AVOID
64	1-Dec-2020	HASSAN	66	HV2	MAGGE_66	12:30	13:34	01:04	MAIN SUPPLY FAILURE
65	1-Dec-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:13	13:30	01:17	LINE CLEAR AVOID
66	1-Dec-2020	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOID
67	1-Dec-2020	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOID
68	1-Dec-2020	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOID
69	1-Dec-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	12:25	13:34	01:09	NFBC ISSUED
70	1-Dec-2020	HASSAN	110	HV1	ARASIKERE_110	11:18	12:43	01:25	LINE CLEAR AVOID
71	1-Dec-2020	HASSAN	110	HV1	BAIKAMPADI_110	10:05	16:31	06:26	LINE CLEAR AVOID
72	1-Dec-2020	HASSAN	110	HV1	BARANGI_110	11:48	13:15	01:27	LINE CLEAR AVOID
73	1-Dec-2020	HASSAN	110	HV2	ARASIKERE_110	11:57	13:16	01:19	LINE CLEAR AVOID
74	1-Dec-2020	HASSAN	110	JOG110-MGHE	JOG_110	08:42	18:37	09:55	NFBC ISSUED
75	1-Dec-2020	HASSAN	110	JOG-JLT3	mghejog_gen	08:44	18:37	09:53	LINE CLEAR AVOID

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	1-Dec-2020	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN,LINE CLEAR AVAILED
77	1-Dec-2020	HASSAN	110	JOG-JLT4	mghejog_gen	8:50(01.12.2020)			LINE OPEN,LINE CLEAR AVAILED
78	1-Dec-2020	HASSAN	110	JOG-JST1	mghejog_gen	08:41	18:39	09:58	LINE CLEAR AVAILED
79	1-Dec-2020	HASSAN	110	JOG-JST2	mghejog_gen	08:52	18:41	09:49	LINE CLEAR AVAILED
80	1-Dec-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:30	14:17	02:47	NFBC ISSUED
81	1-Dec-2020	HASSAN	110	LV1	ARASIKERE_220	12:31	14:12	01:41	LINE CLEAR AVAILED
82	1-Dec-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	08:39	18:39	10:00	NFBC ISSUED
83	1-Dec-2020	HASSAN	110	SAGARA-JST2	SAGARA_110	09:01	18:41	09:40	NFBC ISSUED
84	1-Dec-2020	HASSAN	220	HV1	ARASIKERE_220	12:31	14:11	01:40	LINE CLEAR AVAILED
85	1-Dec-2020	HASSAN	220	HV1	SHIRALKOPPA_220	15:24	17:06	01:42	LINE CLEAR AVAILED
86	1-Dec-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:03	12:20	02:17	LINE CLEAR AVAILED
87	1-Dec-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	10:03(01.12.2020)			LINE OPEN,LINE CLEAR AVAILED
88	1-Dec-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:03	12:49	02:46	NFBC ISSUED
89	1-Dec-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	09:01	16:38	07:37	NFBC ISSUED
90	1-Dec-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	09:35	12:49	03:14	LINE CLEAR AVAILED
91	1-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:47 (30.11.2020)	7:05 (1.12.2020)	7:17 hrs	LINE CHARGED
92	1-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:51 (1.2.2020)			LINE OPEN,LINE CLEAR AVAILED
93	1-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:17 (30.11.2020)	11:51(1.12.2020)	16:33 hrs	LINE CHARGED
94	1-Dec-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:25 (1.12.2020)			LINE OPEN,LINE CLEAR AVAILED
95	1-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT
96	1-Dec-2020	MYSURU	66	TUBINKERE-MC-4	NO STATIONS EFFECTED	5:45	5:50	0:05	LINE FAULT
97	1-Dec-2020	MYSURU	66	TUBINKERE-MC-4	NO STATIONS EFFECTED	6:20	6:25	0:05	LINE FAULT
98	1-Dec-2020	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	6:32	6:39	0:07	LINE FAULT
99	1-Dec-2020	MYSURU	220	KR PETE-TUBINKERE	NO STATIONS EFFECTED	13:58	14:10	0:12	LINE FAULT
100	1-Dec-2020	TUMKUR	66	CHITRADURGA 66KV- MEGMICON 2	MEGMICON 1_IPP_66	9:21:57 AM(01.12.2020)			LINE OPEN,LINE CLEAR AVAILED
101	1-Dec-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:46	10:52	0:05	MAIN SUPPLY FAILURE
102	1-Dec-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:55	11:03	0:08	MAIN SUPPLY FAILURE
103	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	9:53	10:06	0:12	HAND TRIPPED
104	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:37	10:56	0:19	HAND TRIPPED
105	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:07	11:18	0:10	HAND TRIPPED
106	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	9:53	10:07	0:13	HAND TRIPPED
107	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	9:53	10:06	0:13	HAND TRIPPED
108	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:37	10:56	0:18	HAND TRIPPED
109	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	9:53	10:06	0:13	HAND TRIPPED
110	1-Dec-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:37	10:56	0:18	HAND TRIPPED
111	1-Dec-2020	TUMKUR	66	HIRIYURKV 220kv- SUZLON 2	SUZLON1_IPP_66	9:52	10:58	1:06	HAND TRIPPED
112	1-Dec-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	18:21	18:30	0:09	HAND TRIPPED
113	1-Dec-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	10:47	11:07	0:19	MAIN SUPPLY FAILURE
114	1-Dec-2020	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	10:39	13:35	2:56	MAIN SUPPLY FAILURE
115	1-Dec-2020	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR IPP 66	SEL DIAMOND SOLAR_IPP_66	18:24	22:19	3:54	LINE CLEAR AVAILED
116	1-Dec-2020	TUMKUR	66	THALLAK 220kv- SEI VENUS DIAMOND IPP 66	SEI VENUS DIAMOND_IPP_66	18:24	22:19	3:54	LINE CLEAR AVAILED
117	1-Dec-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	20:36:51(01.12.2020)			LINE OPEN,LINE FAULT
118	1-Dec-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	1:28	6:10	4:42	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
119	1-Dec-2020	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	6:31	17:02	10:31	LINE FAULT
120	1-Dec-2020	TUMKUR	66	TR-1	HDPURA_66	10:37	10:56	0:18	TRANSFORMER FAULT
121	1-Dec-2020	TUMKUR	66	TR-1	KATTIGE_66	22:15	22:20	0:05	TRANSFORMER FAULT
122	1-Dec-2020	TUMKUR	66	TR-2	HOLALKERE_66	16:28	16:32	0:04	TRANSFORMER FAULT
123	1-Dec-2020	TUMKUR	66	TR-2	KOLALA_66	13:36	14:14	0:38	LINE CLEAR AVAILED
124	1-Dec-2020	TUMKUR	220	TR-3	HIRIYUR_220	9:35	18:09	8:34	LINE CLEAR AVAILED
125	2-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
126	2-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
127	2-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
128	2-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
129	2-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
130	2-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
131	2-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
132	2-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
133	2-Dec-2020	BAGALKOT	110	220/110KV,LV3	HUBLI_220	17:39 (26.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
134	2-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
135	2-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
136	2-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
137	2-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
138	2-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE CLEAR AVAILED
139	2-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR_110	13:10 (30.11.2020)			LINE OPEN,LINE FAULT
140	2-Dec-2020	BAGALKOT	110	SRS HUBLI-TARIAL 2	TARIAL_110/HUBLI_220	18:19 (01.12.2020)	11:06 (02.12.2020)	40:37hrs	LINE CHARGED
141	2-Dec-2020	BAGALKOT	110	SRSHUBLI2-TARIAL	STATION NOT AFFECTED TARIAL_110	18:41 (1.12.2020)	11:06 (02.12.2020)	40:15hrs	LINE CHARGED
142	2-Dec-2020	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	00:29	00:55	0:26	LINE FAULT
143	2-Dec-2020	BAGALKOT	110	SRSHUBLI-TARIAL 1	STATION NOT AFFECTED	09:10	11:06	1:56	LINE CLEAR AVAILED
144	2-Dec-2020	BAGALKOT	110	110/33KV, HV1	HUBLI_220	10:08	14:31	4:23	LINE CLEAR AVAILED
145	2-Dec-2020	BAGALKOT	110	110/11KV,HV2	SIRSI_110	18:42	20:02	1:20	TRANSFORMER FAULT
146	2-Dec-2020	BAGALKOT	110	RANNABELAGALI-UTTUR (MUDHOL)	STATION NOT AFFECTED RANNABELAGALI_110	10:44	11:28	0:44	LINE FAULT
147	2-Dec-2020	BAGALKOT	220	GADAG-BAGALKOT 2	GADAG_220	17:52	17:54	0:02	HAND TRIPPED
148	2-Dec-2020	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	11:47	14:53	3:06	LINE CLEAR AVAILED
149	2-Dec-2020	BAGALKOT	110	KARAWAR- ARGA	ARGA_110	14:19	14:21	0:02	HAND TRIPPED
150	2-Dec-2020	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	VAJRAMATTI_220	16:53	18:35	1:42	LINE CLEAR AVAILED
151	2-Dec-2020	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	00:29	00:55	0:26	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
152	2-Dec-2020	BAGALKOT	110	SRSUBLI-TARIHAL 1	STATION NOT AFFECTED	09:10	11:06	1:56	LINE CLEAR AVAILED
153	2-Dec-2020	BAGALKOT	110	110/33KV, HV1	HUBLI_220	10:08	14:31	4:23	LINE CLEAR AVAILED
154	2-Dec-2020	BAGALKOT	110	110/11KV,HV2	SIRSI_110	18:42	20:02	1:20	TRANSFORMER FAULT
155	2-Dec-2020	BAGALKOT	110	RANNABELAGALI-UTTUR (MUDHOL)	STATION NOT AFFECTED RANNABELAGALI_110	10:44	11:28	0:44	LINE FAULT
156	2-Dec-2020	BENGALURU	66	HV2	KOLAR 220	16:30	16:43	00:13	LINE CLEAR AVAILED
157	2-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
158	2-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
159	2-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
160	2-Dec-2020	GULBARGA	220	HV2	SEDAM_220	14:55	15:38	00:43	LINE CLEAR AVAILED
161	2-Dec-2020	GULBARGA	220	LINGAPUR-JVSL1	JINDAL_220	09:41	17:05	07:24	LINE CLEAR AVAILED
162	2-Dec-2020	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	20:39(02.12.220)			LINE OPEN,LINE FAULT
163	2-Dec-2020	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	10:24	18:00	07:36	LINE CLEAR AVAILED
164	2-Dec-2020	GULBARGA	110	HV1,HV2,HV3	HANUMASAGAR_110,HANUM ANAL_110,HIREGONNAGAR_1 10	08:15	08:27	00:12	LINE CLEAR AVAILED
165	2-Dec-2020	GULBARGA	110	HV2	MANVI_110	10:54	11:06	00:12	TRANSFORMER FAULT
166	2-Dec-2020	GULBARGA	110	HV2	MANVI_110	13:11	13:21	00:10	TRANSFORMER FAULT
167	2-Dec-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:19(01.12.2020)	7:35(02.12.2020)	10:16HRS	LINE CHARGED
168	2-Dec-2020	GULBARGA	110	HV4	YELBURGA_110	16:34	16:46	00:12	TRANSFORMER FAULT
169	2-Dec-2020	GULBARGA	110	HALBARGA-ACMESLR_IPP	HALBARGA_220	11:43	11:48	00:05	LINE FAULT
170	2-Dec-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	10:40	17:14	06:34	LINE CLEAR AVAILED
171	2-Dec-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRIYAPU R_66,MAGALA_66,SOVENAHA LLI_66,TUNGABHADRA_IPP	21:07	21:19	00:12	LINE FAULT
172	2-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
173	2-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
174	2-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
175	2-Dec-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:40 (25.11.2020)			LINE OPEN,LINE CLEAR AVAILED
176	2-Dec-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:25 (1.12.2020)			LINE OPEN,LINE CLEAR AVAILED
177	2-Dec-2020	HASSAN	110	JOG-JLT4	mghejog_gen	8:50(1.12.2020)			LINE OPEN,LINE CLEAR AVAILED
178	2-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:51 (1.2.2020)	8:42(02.12.2020)	8:51hrs	LINE CHARGED
179	2-Dec-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	10:03(01.12.2020)	14:23(2.12.2020)	28:60hrs	LINE CHARGED
180	2-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:51(2.12.2020)			LINE OPEN,LINE CLEAR AVAILED
181	2-Dec-2020	HASSAN	220	CRPATNA2-HUYGNH	CRPATNA_220	14:07	14:33	00:26	LINE FAULT
182	2-Dec-2020	HASSAN	66	CRPATNA2-HNPURA	CRPATNA_220	14:33	14:39	00:06	LINE FAULT
183	2-Dec-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:41	13:20	03:39	LINE CLEAR AVAILED
184	2-Dec-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:26	15:24	01:58	LINE CLEAR AVAILED
185	2-Dec-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:45	12:59	02:14	LINE CLEAR AVAILED
186	2-Dec-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	12:07	14:25	02:18	LINE CLEAR AVAILED
187	2-Dec-2020	HASSAN	220	HV3	MRSMSG_220	16:07	17:49	01:42	TRANSFORMER FAULT
188	2-Dec-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	10:49	12:04	01:15	LINE FAULT
189	2-Dec-2020	HASSAN	110	HV2	MRSMSG_220	16:42	16:51	00:09	HAND TRIPPED
190	2-Dec-2020	HASSAN	110	HV3	MRSMSG_220	16:42	16:52	00:10	HAND TRIPPED
191	2-Dec-2020	HASSAN	110	HV4	MRSMSG_220	16:42	16:52	00:10	HAND TRIPPED
192	2-Dec-2020	HASSAN	110	LV3	MRSMSG_220	16:07	17:50	01:43	HAND TRIPPED
193	2-Dec-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:32	16:57	00:25	HAND TRIPPED
194	2-Dec-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	18:03	18:06	00:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
195	2-Dec-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	16:32	16:55	00:23	HAND TRIPPED
196	2-Dec-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	18:03	18:05	00:02	HAND TRIPPED
197	2-Dec-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:07	18:24	02:17	LINE CLEAR AVAILED
198	2-Dec-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	16:32	16:55	00:23	HAND TRIPPED
199	2-Dec-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	18:03	18:05	00:02	HAND TRIPPED
200	2-Dec-2020	HASSAN	66	LV1	MRSMSG_220	16:07	18:04	01:57	HAND TRIPPED
201	2-Dec-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	09:48	14:53	05:05	LINE CLEAR AVAILED
202	2-Dec-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	09:40	13:21	03:41	NFBC ISSUED
203	2-Dec-2020	HASSAN	220	VARAHIKEMAR2	varahi_gen	13:25	15:26	02:01	NFBC ISSUED
204	2-Dec-2020	HASSAN	110	HV1	BAIKAMPADY_110	09:41	16:34	06:53	LINE CLEAR AVAILED
205	2-Dec-2020	HASSAN	110	HV2	BARANGI_110	08:42	08:57	00:15	LINE CLEAR AVAILED
206	2-Dec-2020	HASSAN	110	HV1	GANDASI_110	08:25	08:30	00:05	TRANSFORMER FAULT
207	2-Dec-2020	HASSAN	110	HV1	GURUPURA_110	17:09	17:15	00:06	TRANSFORMER FAULT
208	2-Dec-2020	HASSAN	110	JOG-JLT3	mghejog_gen	08:42	18:41	09:59	LINE CLEAR AVAILED
209	2-Dec-2020	HASSAN	110	JOG-JST2	mghejog_gen	08:47	18:43	09:56	LINE CLEAR AVAILED
210	2-Dec-2020	HASSAN	110	JOG110-MGHE	JOG_110	08:42	18:41	09:59	NFBC ISSUED
211	2-Dec-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	08:47	18:43	09:56	NFBC ISSUED
212	2-Dec-2020	HASSAN	110	SAGARA-JST2	SAGARA_110	08:47	18:44	09:57	NFBC ISSUED
213	2-Dec-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:08	16:58	00:50	HAND TRIPPED
214	2-Dec-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	18:04	18:07	00:03	HAND TRIPPED
215	2-Dec-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:08	16:58	00:50	HAND TRIPPED
216	2-Dec-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	18:04	18:07	00:03	HAND TRIPPED
217	2-Dec-2020	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLY_66	18:00	18:06	00:06	HAND TRIPPED
218	2-Dec-2020	HASSAN	66	HV2	BYACHANAHALLY_66	15:15	16:50	01:35	LINE CLEAR AVAILED
219	2-Dec-2020	HASSAN	66	HV1	BYACHANAHALLY_66	16:45	18:10	01:25	LINE CLEAR AVAILED
220	2-Dec-2020	HASSAN	66	HV1	GANGUR_66	07:57	08:03	00:06	TRANSFORMER FAULT
221	2-Dec-2020	HASSAN	66	HV1	GORUR_66	15:42	16:50	01:08	LINE CLEAR AVAILED
222	2-Dec-2020	HASSAN	66	HASSN220-SKPURA	HASSAN_220	13:45	14:05	00:20	HAND TRIPPED
223	2-Dec-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	13:44	14:06	00:22	HAND TRIPPED
224	2-Dec-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	18:22	18:27	00:05	HAND TRIPPED
225	2-Dec-2020	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	17:03	18:23	01:20	NFBC ISSUED
226	2-Dec-2020	HASSAN	66	HV1	SOMANAHALLI_66	16:02	17:00	00:58	LINE CLEAR AVAILED
227	2-Dec-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	16:10	16:59	00:49	MAIN SUPPLY FAILURE
228	2-Dec-2020	MYSURU	220	KR PETE 220KV-YACHENAHALLI	NO STATIONS EFFECTED	14:06	14:31	0:25	LINE FAULT
229	2-Dec-2020	MYSURU	66	HOOTAGALLI-BARC-2	NO STATIONS EFFECTED	8:44	12:45	4:01	LINE CLEAR AVAILED
230	2-Dec-2020	MYSURU	66	HULLALLI-KADAKOLA	HULLAHALLI_66	10:05	16:42	6:37	LINE CLEAR AVAILED
231	2-Dec-2020	MYSURU	66	HV2	DEVANOORMYS_66	10:05	16:19	6:13	LINE CLEAR AVAILED
232	2-Dec-2020	MYSURU	66	HV2	MADIKERI_66	11:37	16:34	4:57	LINE CLEAR AVAILED
233	2-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT
323	2-Dec-2020	TUMKUR	66	CHITRADURGA 66KV- MEGMICON 2	MEGMICON 2_IPP_66	9:21:57 AM(01.12.2020)			LINE CLEAR AVAILED
324	2-Dec-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	20:36(01.12.2020)	1:40(02.12.2020)	5:04hrs	LINE CHARGED
325	2-Dec-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:24	20:19	12:55	LINE FAULT
326	2-Dec-2020	TUMKUR	220	NITTUR 220kv- HASSAN(ARASIKERE)	NITTUR_220	9:18	14:01	4:42	LOAD CURTAILMENT
327	2-Dec-2020	TUMKUR	66	TR-1	BENKIKERE_66	9:04	9:07	0:03	TRANSFORMER FAULT
328	2-Dec-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	13:09	13:44	0:35	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
329	2-Dec-2020	TUMKUR	66	TR-1	HOLALKERE_66	17:48	18:08	0:20	LINE CLEAR AVAILED
330	2-Dec-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	12:28	13:52	1:24	TRANSFORMER FAULT
331	2-Dec-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	14:09	15:36	1:26	TRANSFORMER FAULT
332	2-Dec-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	9:19	13:47	4:27	MAIN SUPPLY FAILURE
333	2-Dec-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	9:19	13:47	4:27	MAIN SUPPLY FAILURE
334	2-Dec-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:10	15:21	0:11	LINE FAULT
335	2-Dec-2020	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:06	13:34	4:28	LINE FAULT
336	2-Dec-2020	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	13:41	13:47	0:05	LINE FAULT
337	2-Dec-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66,BASAVAPATNA_66	11:39	13:34	1:54	LINE CLEAR AVAILED
338	2-Dec-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:20	17:33	0:13	LINE FAULT
339	2-Dec-2020	TUMKUR	66	TR-1	MAVINAKATTE_66	0:00	0:04	0:04	TRANSFORMER FAULT
340	2-Dec-2020	TUMKUR	66	TR-1	PAVAGADA_220	13:58	14:24	0:25	LINE CLEAR AVAILED
234	3-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
235	3-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
236	3-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
237	3-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
238	3-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
239	3-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
240	3-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
241	3-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
242	3-Dec-2020	BAGALKOT	110	220/110KV,LV3	HUBLI_220	17:39 (26.11.2020)	14:35 (03.12.2020)	164:36hrs	TRANSFORMER CHARGED
243	3-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
244	3-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
245	3-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
246	3-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
247	3-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
248	3-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR_110	13:10 (30.11.2020)			LINE OPEN,LINE FAULT
249	3-Dec-2020	BAGALKOT	110	110/33KV,HV2	SAVANUR_110	08:33	09:20	0:47	LINE CLEAR AVAILED
250	3-Dec-2020	BAGALKOT	110	110/11KV ,HV1	STATION NOT AFFECTED MUNDUGANUR_110	13:08	14:55	1:47	LINE CLEAR AVAILED
251	3-Dec-2020	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	13:32	14:01	0:29	LINE FAULT
252	3-Dec-2020	BAGALKOT	110	110/11KV,HV2	ITANAL_110	8:27	8:43	0:16	TRANSFORMER FAULT
253	3-Dec-2020	BAGALKOT	110	11/11KV,HV1&2	KAGAWAD_110	20:07	22:35	2:28	TRANSFORMER FAULT
254	3-Dec-2020	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	20:07	22:35	2:28	LINE FAULT
255	3-Dec-2020	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	10:57			LINE OPEN,LINE CLEAR AVAILED
256	3-Dec-2020	BAGALKOT	110	110/33KV,HV2	KUDACHI_110	1:28	1:39	0:11	TRANSFORMER FAULT
257	3-Dec-2020	BENGALURU	66	HV2	GOLF LINK	19:45	20:05	00:20	TRANSFORMER FAULT
258	3-Dec-2020	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	23:12(03/12/2020)			LINE OPEN,LINE FAULT
259	3-Dec-2020	BENGALURU	220	HV3	HSR LAYOUT 220	23:12(03/12/2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
260	3-Dec-2020	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	23:12(03/12/2020)			LINE OPEN,LINE FAULT
261	3-Dec-2020	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	23:12(03/12/2020)			LINE OPEN,LINE CLEAR AVAILED
262	3-Dec-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	23:12(03/12/2020)			LINE OPEN,LINE CLEAR AVAILED
263	3-Dec-2020	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	23:12(03/12/2020)			LINE OPEN,LINE CLEAR AVAILED
264	3-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
265	3-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
266	3-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
267	3-Dec-2020	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	20:39(02.12.220)	17:28(03.12.2020)	20:49HRS	LINE CHARGED
268	3-Dec-2020	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	08:35	23:03	14:28	LINE CHARGED
269	3-Dec-2020	GULBARGA	220	KUSHATGI-LINGSUGUR	LINGSUGUR_220	13:06	13:36	00:30	LINE FAULT
270	3-Dec-2020	GULBARGA	220	KUSHATGI-LINGSUGUR	LINGSUGUR_220	02:12	02:47	00:35	LINE FAULT
271	3-Dec-2020	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	13:12	13:22	00:10	LINE CLEAR AVAILED
272	3-Dec-2020	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	02:13	11:30	09:17	LINE FAULT
273	3-Dec-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:15	14:40	03:25	LINE CLEAR AVAILED
274	3-Dec-2020	GULBARGA	110	HALBARGA-SANTHPUR	SANTHPUR_110	06:17	06:21	00:04	LINE FAULT
275	3-Dec-2020	GULBARGA	110	HATTI-SOMANMARADHI	SOMANMARADHI_110	05:48	05:57	00:09	LINE FAULT
276	3-Dec-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	17:10	17:15	00:05	LINE FAULT
277	3-Dec-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	08:48	16:21	07:33	LINE CLEAR AVAILED
278	3-Dec-2020	GULBARGA	110	HV1	MANVI_110	16:10	16:20	00:10	TRANSFORMER FAULT
279	3-Dec-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:30	14:13	02:43	LINE CLEAR AVAILED
280	3-Dec-2020	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	20:54	21:01	00:07	LINE FAULT
281	3-Dec-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	18:12	18:26	00:14	LINE FAULT
282	3-Dec-2020	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
283	3-Dec-2020	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
284	3-Dec-2020	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
285	3-Dec-2020	HASSAN	66	BHADRA-SHMG 2	bhadra_gen	10:40 (25.11.2020)			LINE OPEN,LINE CLEAR AVAILED
286	3-Dec-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:25(1.12.2020)	6:38(3.12.2020)	35:13hrs	LINE CHARGED
287	3-Dec-2020	HASSAN	110	JOG-JLT4	mghejog_gen	8:50(1.12..2020)	17:33(03.12.2020)	55:43hrs	LINE CHARGED
288	3-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:51(2.12.2020)			LINE OPEN,LINE CLEAR AVAILED
289	3-Dec-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	09:21	11:46	02:25	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
290	3-Dec-2020	HASSAN	220	UPCL-KEMAR2	upcl_gen	12:06	13:44	01:38	NFBC ISSUED
291	3-Dec-2020	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	09:21	09:41	00:20	LINE FAULT
292	3-Dec-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	09:21	11:46	02:25	LINE CLEAR AVAILED
293	3-Dec-2020	HASSAN	220	KEMAR-UPCL2	KEMAR_220	12:06	13:44	01:38	LINE CLEAR AVAILED
294	3-Dec-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:22	09:49	00:27	LINE FAULT
295	3-Dec-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:05	12:46	01:41	LINE CLEAR AVAILED
296	3-Dec-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	13:52	15:48	01:56	LINE CLEAR AVAILED
297	3-Dec-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:02	14:56	03:54	LINE CLEAR AVAILED
298	3-Dec-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	11:57	12:08	00:11	LINE CLEAR AVAILED
299	3-Dec-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	11:19	11:39	00:20	LINE CLEAR AVAILED
300	3-Dec-2020	HASSAN	220	VARAHIKEMAR1	varahi_gen	09:22	09:50	00:28	LINE FAULT
301	3-Dec-2020	HASSAN	220	VARAHIKEMAR1	varahi_gen	11:04	12:47	01:43	NFBC ISSUED
302	3-Dec-2020	HASSAN	220	VARAHIKEMAR3	varahi_gen	13:52	15:48	01:56	NFBC ISSUED
303	3-Dec-2020	HASSAN	220	VARAHISHIMOGA1	varahi_gen	11:57	12:20	00:23	LINE CLEAR AVAILED
304	3-Dec-2020	HASSAN	220	VARAHISHIMOGA2	varahi_gen	11:19	11:39	00:20	LINE CLEAR AVAILED
305	3-Dec-2020	HASSAN	110	HV2	BARANGI_110	12:55	14:29	01:34	LINE CLEAR AVAILED
306	3-Dec-2020	HASSAN	110	GAJNUR-MUTHIKOPPA	GAJANUR_110	12:12	12:44	00:32	LINE FAULT
307	3-Dec-2020	HASSAN	110	JOG-JLT3	mghejog_gen	09:06	17:16	08:10	LINE CLEAR AVAILED
308	3-Dec-2020	HASSAN	110	JOG-JST1	mghejog_gen	09:08	17:14	08:06	LINE CLEAR AVAILED
309	3-Dec-2020	HASSAN	110	JOG-JST2	mghejog_gen	09:08	17:13	08:05	LINE CLEAR AVAILED
310	3-Dec-2020	HASSAN	110	HV2	JOG_110	10:51	11:20	00:29	LINE CLEAR AVAILED
311	3-Dec-2020	HASSAN	110	JOG110-MGHE	JOG_110	09:05	17:17	08:12	NFBC ISSUED
312	3-Dec-2020	HASSAN	110	HV1	MADHUVANA_110	09:44	11:08	01:24	LINE CLEAR AVAILED
313	3-Dec-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	09:07	17:13	08:06	NFBC ISSUED
314	3-Dec-2020	HASSAN	110	SAGARA-JST2	SAGARA_110	09:07	17:12	08:05	NFBC ISSUED
315	3-Dec-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	09:15	11:16	02:01	LINE CLEAR AVAILED
316	3-Dec-2020	MYSURU	66	KR PETE 220 KV-KR PETE 1	AKKIEBBAL_66 KRPET_66 KICKERI_66	20:37	20:52	0:14	LINE FAULT
317	3-Dec-2020	MYSURU	66	KR PETE-HUYGONALLY 2	NO STATIONS EFFECTED	20:37	20:54	0:17	LINE FAULT
318	3-Dec-2020	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS EFFECTED	14:48	14:53	0:05	LINE FAULT
319	3-Dec-2020	MYSURU	66	HOOTAGALLI-DODDA KADNUR	HAMAPAPURA(KAGGERE)_66	12:05	12:10	0:05	LINE FAULT
320	3-Dec-2020	MYSURU	66	AKKIEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	20:37	21:15	0:37	LINE FAULT
321	3-Dec-2020	MYSURU	66	DUNDANALLY-HULIYURDURGA	DUNDANAHALLI_66	10:59	11:55	0:55	LINE FAULT
322	3-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT
341	3-Dec-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 2_IPP_66	9:22(01.12.2020)			LINE CLEAR AVAILED
342	3-Dec-2020	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP 66	AZURE POWER SOLAR_IPP_66	18:13	19:22	1:08	LINE CLEAR AVAILED
343	3-Dec-2020	TUMKUR	110	NIITUR 220kv- KADABA	KADABA_110	6:51	8:00	1:09	LOAD CURTAILMENT
344	3-Dec-2020	TUMKUR	110	NIITUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	6:51	7:58	1:06	LOAD CURTAILMENT
345	3-Dec-2020	TUMKUR	66	TR-2	BEVINAHALLI_66	17:41	18:43	1:01	LINE CLEAR AVAILED
346	3-Dec-2020	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	15:24	15:25	0:00	LINE CLEAR AVAILED
347	3-Dec-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:51	7:55	0:03	HAND TRIPPED
348	3-Dec-2020	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	7:09	7:19	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
349	3-Dec-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:37	12:53	0:16	LINE FAULT
350	3-Dec-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:56	8:10	0:14	LINE FAULT
351	3-Dec-2020	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	5:54	6:20	0:26	LINE FAULT
352	3-Dec-2020	TUMKUR	66	THALLAK 220kV -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	5:54	6:24	0:30	LINE FAULT
353	3-Dec-2020	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	6:07	6:10	0:03	HAND TRIPPED
354	3-Dec-2020	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	5:54	6:11	0:16	TRANSFORMER FAULT
355	3-Dec-2020	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEI DIAMOND SOLAR_IPP_66	6:07	6:12	0:04	HAND TRIPPED
356	3-Dec-2020	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	6:07	6:12	0:04	HAND TRIPPED
357	3-Dec-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:33	8:39	0:06	HAND TRIPPED
358	4-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
359	4-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
360	4-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
361	4-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
362	4-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
363	4-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
364	4-Dec-2020	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
365	4-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
366	4-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
367	4-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
368	4-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
369	4-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
370	4-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE CLEAR AVAILED
371	4-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR_110	13:10 (30.11.2020)			LINE OPEN,LINE FAULT
372	4-Dec-2020	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	10:57(03.12.2020)			LINE OPEN,LINE CLEAR AVAILED
373	4-Dec-2020	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	16:23	16:32	0:09	LINE FAULT
374	4-Dec-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	17:33	19:02	1:29	LINE CLEAR AVAILED
375	4-Dec-2020	BAGALKOT	110	BANAHATTI-NAVALGI(JAMKHANDI)	NAVALAGI_110	13:20	13:38	0:18	LINE FAULT
376	4-Dec-2020	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	5:59	13:32	7:33	LINE FAULT
377	4-Dec-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	11:24	15:07	3:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
378	4-Dec-2020	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	12:52	14:35	1:43	LINE CLEAR AVAILED
379	4-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110,TIKOTA_110, TAKKALAKI_110	07:10	07:12	0:02	LINE FAULT
380	4-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110,TIKOTA_110, TAKKALAKI_110	07:10	07:12	0:02	LINE CLEAR AVAILED
381	4-Dec-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	11:40	15:11	3:31	NFBC ISSUED
382	4-Dec-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	13:11	16:29	3:18	LINE CLEAR AVAILED
383	4-Dec-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	17:00	17:12	0:12	LINE CLEAR AVAILED
384	4-Dec-2020	BAGALKOT	110	110/11KV, HV3	TIKOTA_110	9:57	16:56	6:59	LINE CLEAR AVAILED
385	4-Dec-2020	BAGALKOT	110	GAMESHA - RON	RON_110	05:15	05:45	0:30	HAND TRIPPED
386	4-Dec-2020	BAGALKOT	110	110/11KV, HV3	RATTIHALLI_110	14:31	15:29	0:58	LINE CLEAR AVAILED
387	4-Dec-2020	BAGALKOT	110	NARENDRA- KUD DHARWAD1	STATION NOT AFFECTED KUD DHARWAD_110	12:26	16:44	4:18	LINE CLEAR AVAILED
388	4-Dec-2020	BAGALKOT	110	NAREGAL- BETAGERI	NAREGAL_110, RON_110	6:15	13:40	7:25	LINE CLEAR AVAILED
389	4-Dec-2020	BAGALKOT	110	NAREGAL- RON	RON_110	13:39	14:09	0:30	HAND TRIPPED
390	4-Dec-2020	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	19:50	20:05	0:15	TRANSFORMER FAULT
391	4-Dec-2020	BAGALKOT	220	220/110KV, HV1& LV1	STATION NOT AFFECTED KUDACHI_220	10:55	15:45	4:50	LINE CLEAR AVAILED
392	4-Dec-2020	BAGALKOT	220	220/110KV, HV1& LV1	STATION NOT AFFECTED KUDACHI_220	16:23 (04.12.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
393	4-Dec-2020	BAGALKOT	110	RON1&2- GAJENDRAGAD	GAJENDRAGAD_110	6:14	6:29	0:15	HAND TRIPPED
394	4-Dec-2020	BAGALKOT	110	KUSHTAGI- GAJENDRAGAD	GAJENDRAGAD_110	6:12	6:27	0:15	HAND TRIPPED
395	4-Dec-2020	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	23:12(03/12/2020)	00:42(04/12/2020)	1:30hrs	LINE CHARGED
396	4-Dec-2020	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	23:12(03/12/2020)	00:46:00(04/12/2020)	1:34hrs	LINE CHARGED
397	4-Dec-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	23:12(03/12/2020)	00:46:00(04/12/2020)	1:34hrs	LINE CHARGED
398	4-Dec-2020	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	23:12(03/12/2020)	00:46:00(04/12/2020)	1:34hrs	LINE CHARGED
399	4-Dec-2020	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	23:12(03/12/2020)	00:42(04/12/2020)	1:30hrs	LINE CHARGED
400	4-Dec-2020	BENGALURU	66	HV2	HEBBALA 220	14:35	14:38	00:03	LINE CLEAR AVAILED
401	4-Dec-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU,GODUR	08:24	09:25	01:01	LINE CLEAR AVAILED
402	4-Dec-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU,GODUR	17:00	17:44	00:44	LINE CLEAR AVAILED
403	4-Dec-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	11:49	12:07	00:18	LINE FAULT
404	4-Dec-2020	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	20:59	21:29	00:30	LINE FAULT
405	4-Dec-2020	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	15:20	16:20	01:00	LINE CLEAR AVAILED
406	4-Dec-2020	BENGALURU	66	HV1	MAGADI 66	15:20	16:40	01:20	LINE CLEAR AVAILED
407	4-Dec-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:09	17:33	00:23	LINE FAULT
408	4-Dec-2020	BENGALURU	66	HV1	MELUR	21:48	22:45	00:56	TRANSFORMER FAULT
409	4-Dec-2020	BENGALURU	66	KEMPANAHALLI - BIDADI 220	KEMPANAHALLI, RAMANAGARA	12:00	12:08	00:08	LOAD CHANGE OVER
410	4-Dec-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	08:40	08:50	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
411	4-Dec-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	08:57	09:15	00:18	LINE FAULT
412	4-Dec-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	09:40	11:20	01:40	LINE CLEAR AVAILED
413	4-Dec-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	11:25	11:32	00:07	LINE FAULT
414	4-Dec-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	19:05	20:50	01:45	LINE CLEAR AVAILED
415	4-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
416	4-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
417	4-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
418	4-Dec-2020	BENGALURU	220	HV3	HSR LAYOUT 220	23:12(03/12/2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
419	4-Dec-2020	GULBARGA	220	SEDAM-CLNMAX_IPP	SEDAM_220	14:45	15:15	00:30	LINE CLEAR AVAILED
420	4-Dec-2020	GULBARGA	220	HUMNABAD-HALBURGA	HUMNABAD_220	15:05	16:18	01:13	LINE CLEAR AVAILED
421	4-Dec-2020	GULBARGA	220	HUMNABAD-HALBURGA	HALBURGA_220	16:30	18:08	01:38	LINE CLEAR AVAILED
422	4-Dec-2020	GULBARGA	220	MALLAT-BYGWAT1	BYGWAT_110,VALKAMDINI_110	20:51	21:28	00:37	LINE FAULT
423	4-Dec-2020	GULBARGA	220	MALLAT-BYGWAT1	BYGWAT_110,VALKAMDINI_110	22:16	22:26	00:10	LINE FAULT
424	4-Dec-2020	GULBARGA	220	MALLAT-BYGWAT2	MADLAPUR_110,MANVI_110	23:42	23:59	00:17	LINE FAULT
425	4-Dec-2020	GULBARGA	110	HV1,HV2	MYLAR_110	12:10	13:15	01:05	LINE CLEAR AVAILED
426	4-Dec-2020	GULBARGA	110	P D HALLI-CLNSLR_IPP	CLNSLR_IPP	18:05	02:16	08:11	LINE CLEAR AVAILED
427	4-Dec-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66,SOVENAH ALLI_66,GIRIYAPUR_66,MAN GALA_66,TUNGABHADRA_IPP	11:20	12:40	01:20	LINE CLEAR AVAILED
428	4-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:51(2.12.2020)	5:59(04.12.2020)	31:07 hrs	LINE CHARGED
429	4-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
430	4-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
431	4-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
432	4-Dec-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:40 (25.11.2020)			LINE OPEN,LINE CLEAR AVAILED
433	4-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:24(4.12.2020)			LINE OPEN,LINE CLEAR AVAILED
434	4-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	02:02	06:14	04:12	HAND TRIPPED
435	4-Dec-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	09:58	12:48	02:50	NFBC ISSUED
436	4-Dec-2020	HASSAN	220	UPCL-KEMAR2	upcl_gen	12:53	14:36	01:43	NFBC ISSUED
437	4-Dec-2020	HASSAN	220	HV2	KEMAR_220	08:39	09:01	00:22	LINE CLEAR AVAILED
438	4-Dec-2020	HASSAN	110	LV2	KEMAR_220	08:39	09:02	00:23	LINE CLEAR AVAILED
439	4-Dec-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	09:58	12:48	02:50	LINE CLEAR AVAILED
440	4-Dec-2020	HASSAN	220	KEMAR-UPCL2	KEMAR_220	12:53	14:36	01:43	LINE CLEAR AVAILED
441	4-Dec-2020	HASSAN	110	KEMAR-NANDHIKUR	KEMAR_220	10:35	13:19	02:44	LINE CLEAR AVAILED
442	4-Dec-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:03	16:35	03:32	LINE FAULT
443	4-Dec-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:02	18:28	02:26	HAND TRIPPED
444	4-Dec-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	14:10	18:27	04:17	LINE FAULT
445	4-Dec-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	06:34	07:21	00:47	LINE FAULT
446	4-Dec-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	13:03	16:35	03:32	LINE FAULT
447	4-Dec-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:29	13:50	03:21	LINE CLEAR AVAILED
448	4-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	08:18	08:22	00:04	LINE FAULT
449	4-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	09:10	09:22	00:12	LINE FAULT
450	4-Dec-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	08:17	09:45	01:28	LINE CLEAR AVAILED
451	4-Dec-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	09:11	09:24	00:13	LINE FAULT
452	4-Dec-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	09:11	09:24	00:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
453	4-Dec-2020	HASSAN	110	HV3	PUTTUR_110	10:10	14:04	03:54	LINE CLEAR AVAILED
454	4-Dec-2020	HASSAN	110	HV4	PUTTUR_110	14:04	14:29	00:25	TRANSFORMER FAULT
455	4-Dec-2020	HASSAN	66	HV2	BAGUR_66	16:07	16:17	00:10	LINE CLEAR AVAILED
456	4-Dec-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:01	18:31	02:30	LINE CLEAR AVAILED
457	4-Dec-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:01	18:30	02:29	LINE CLEAR AVAILED
458	4-Dec-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:39	14:52	03:13	LINE CLEAR AVAILED
459	4-Dec-2020	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	09:50	15:36	05:46	LINE CLEAR AVAILED
460	4-Dec-2020	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	16:01	16:54	00:53	TRANSFORMER FAULT
461	4-Dec-2020	HASSAN	66	KANDLI-SAKLLESHPUR	KANDLI_66	11:09	16:23	05:14	LINE CLEAR AVAILED
462	4-Dec-2020	HASSAN	66	HV1	MAGGE_66	10:03	16:26	06:23	LINE CLEAR AVAILED
463	4-Dec-2020	HASSAN	66	HV2	MAGGE_66	10:03	16:27	06:24	LINE CLEAR AVAILED
464	4-Dec-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHUPURA_66	21:28	21:42	00:14	LINE FAULT
465	4-Dec-2020	HASSAN	66	SAKALE-HASSAN	SAKLESHUPURA_66	11:09	16:25	05:16	NFBC ISSUED
466	4-Dec-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	07:25	07:54	00:29	HAND TRIPPED
467	4-Dec-2020	HASSAN	66	HV1	YESLUR_66	14:56	15:03	00:07	LINE CLEAR AVAILED
468	4-Dec-2020	HASSAN	66	HV1	YESLUR_66	15:12	16:24	01:12	LINE CLEAR AVAILED
469	4-Dec-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:50	11:55	0:05	LINE FAULT
470	4-Dec-2020	MYSURU	66	KR PETE 220-KR PETE 1	AKKIHBBAL_66 KRPET_66 KIKKERI_66	3:59	4:11	0:12	LINE FAULT
471	4-Dec-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	10:38	17:32	6:53	NFBC ISSUED
472	4-Dec-2020	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	10:38	17:32	6:53	LINE CLEAR AVAILED
473	4-Dec-2020	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	10:34	12:21	1:47	NFBC ISSUED
474	4-Dec-2020	MYSURU	66	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	13:07	15:10	2:03	HAND TRIPPED
475	4-Dec-2020	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	11:49	12:00	0:10	LINE FAULT
476	4-Dec-2020	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	12:58	13:13	0:14	HAND TRIPPED
477	4-Dec-2020	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	9:10(4.12.20)			LINE OPEN,LINE CLEAR AVAILED
478	4-Dec-2020	MYSURU	66	HV1	FTS_66	9:10	16:45	7:35	LINE CLEAR AVAILED
479	4-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT
480	4-Dec-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 2_IPP_66	9:21(01.12.2020)			LINE CLEAR AVAILED
481	4-Dec-2020	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_11 0, SAMPIGE_110, DODDAGUNI_110	8:02(04.12.2020)			LINE CLEAR AVAILED
482	4-Dec-2020	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	20:50	21:09	0:18	TRANSFORMER FAULT
483	4-Dec-2020	TUMKUR	66	AVAREGERE 66KV-DAVANGERE SRS	AVAREGERE_66	11:44	16:59	5:14	LINE CLEAR AVAILED
484	4-Dec-2020	TUMKUR	66	TR-2	AVAREGERE_66	10:17	16:59	6:41	LINE CLEAR AVAILED
485	4-Dec-2020	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	13:42	13:57	0:14	MAIN SUPPLY FAILURE
486	4-Dec-2020	TUMKUR	66	TR-1	BELADARA_66	10:22	10:36	0:13	LINE CLEAR AVAILED
487	4-Dec-2020	TUMKUR	66	TR-1	BELADARA_66	11:47	12:10	0:23	LINE CLEAR AVAILED
488	4-Dec-2020	TUMKUR	66	TR-2	BELADARA_66	10:22	10:36	0:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
489	4-Dec-2020	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	6:11	6:23	0:12	LINE FAULT
490	4-Dec-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:49	14:28	3:38	LINE CLEAR AVAILED
491	4-Dec-2020	TUMKUR	66	TR-2	HARIYABBE_66	13:37	13:55	0:17	LINE CLEAR AVAILED
492	4-Dec-2020	TUMKUR	66	TR-1	HIRIYUR_66	6:11	6:26	0:15	TRANSFORMER FAULT
493	4-Dec-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	23:04	23:07	0:02	LINE FAULT
494	4-Dec-2020	TUMKUR	66	TR-1	LINGADAHALLI_TM2_66	12:13	12:28	0:14	TRANSFORMER FAULT
495	4-Dec-2020	TUMKUR	66	TR-1	MADHUGIRI_66	12:09	14:44	2:35	LINE CLEAR AVAILED
496	4-Dec-2020	TUMKUR	66	TR-2	MADHUGIRI_66	14:49	15:07	0:17	LINE CLEAR AVAILED
497	4-Dec-2020	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	2:06	2:10	0:04	TRANSFORMER FAULT
498	5-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
499	5-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
500	5-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
501	5-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
502	5-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
503	5-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
504	5-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
505	5-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
506	5-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
507	5-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
508	5-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
509	5-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
510	5-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
511	5-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR_110	13:10 (30.11.2020)			LINE OPEN,LINE FAULT
512	5-Dec-2020	BAGALKOT	220	KADRA 1-KARAWAR	KARWAR_220	10:57 (03.12.2020)	16:15 (05.12.2020)	52:18hrs	LINE CHARGED
513	5-Dec-2020	BAGALKOT	220	220/110KV, HV1& LV1	STATION NOT AFFECTED KUDACHI_220	16:23 (04.12.2020)	14:04 (05.12.2020)	20:41hrs	TRANSFORMER CHARGED
514	5-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	03:07	08:47	5:40	HAND TRIPPED
515	5-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	21:59 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
516	5-Dec-2020	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED NAENDRA_220	08:32	18:07	9:35	LINE CLEAR AVAILED
517	5-Dec-2020	BAGALKOT	110	NARENDRA-KUD DHARWAD	STATION NOT AFFECTED KUD DHARWAD_110	8:10 (05.12.2020)			LINE OPEN,LINE CLEAR AVAILED
518	5-Dec-2020	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	09:39	09:49	00:10	LOAD CHANGE OVER
519	5-Dec-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	18:20	18:28	00:08	LOAD CHANGE OVER
520	5-Dec-2020	BENGALURU	66	KHB - YELAHANKA 220	KHB	10:30	10:42	00:12	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
521	5-Dec-2020	BENGALURU	66	KHB - SRS PEENYA 220	KHB	17:10	17:20	00:10	LOAD CHANGE OVER
522	5-Dec-2020	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANAKUNTE	10:45	10:50	00:05	LOAD CHANGE OVER
523	5-Dec-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	09:17	09:24	00:07	LOAD CHANGE OVER
524	5-Dec-2020	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	07:25	07:50	00:25	LOAD CURTAILMENT
525	5-Dec-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	07:25	07:50	00:25	LOAD CURTAILMENT
526	5-Dec-2020	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	07:50	08:20	00:30	LOAD CURTAILMENT
527	5-Dec-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	07:50	08:20	00:30	LOAD CURTAILMENT
528	5-Dec-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	08:20	08:50	00:30	LOAD CURTAILMENT
529	5-Dec-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	08:20	08:50	00:30	LOAD CURTAILMENT
530	5-Dec-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:53	18:57	00:04	LINE FAULT
531	5-Dec-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:53	18:57	00:04	LINE FAULT
532	5-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVOIDED
533	5-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVOIDED
534	5-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
535	5-Dec-2020	BENGALURU	220	HV3	HSR LAYOUT 220	23:12(03/12/2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
536	5-Dec-2020	GULBARGA	220	MALLAT-BYGWAT2	MALLAT-BYGWAT3	19:44	19:54	00:10	LINE FAULT
537	5-Dec-2020	GULBARGA	110	STAR-METALLIC_IPP-MUNIRABAD	MUNIRABAD_220	09:06	09:19	00:13	LINE FAULT
538	5-Dec-2020	GULBARGA	110	HV1	KUDITINI_110	21:20	21:26	00:06	TRANSFORMER FAULT
539	5-Dec-2020	GULBARGA	110	HV2	CHINCHOLI_110	07:15	07:27	00:12	LOAD CURTAILMENT
540	5-Dec-2020	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	14:05	14:30	00:25	LINE CLEAR AVOIDED
541	5-Dec-2020	GULBARGA	110	CHINCHOLI-MANEKHALI	CHINCHOLI_110	14:05	14:30	00:25	LINE CLEAR AVOIDED
542	5-Dec-2020	GULBARGA	110	BYAGAWAT-MALLAT	BYAGAWAT_110,VALKAMDIN NI_110	18:40	21:30	02:50	LINE CLEAR AVOIDED
543	5-Dec-2020	GULBARGA	110	HV1	BYAGAWAT_110	18:40	21:30	02:50	LINE CLEAR AVOIDED
544	5-Dec-2020	GULBARGA	110	BYAGAWAT-ACMESLR	BYAGAWAT_110	21:50	22:00	00:10	LINE FAULT
545	5-Dec-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:40 (25.11.2020)	16:20 (5.12.2020)	245:39 hrs	LINE CHARGED
546	5-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:24(4.12.2020)	7:54 (5.12.2020)	8:29 hrs	LINE CHARGED
547	5-Dec-2020	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
548	5-Dec-2020	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
549	5-Dec-2020	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
550	5-Dec-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
551	5-Dec-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
552	5-Dec-2020	HASSAN	66	MRSSHM-BD-1	MRSMG_220	16:26 (5.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
553	5-Dec-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:31	12:31	01:00	LINE CLEAR AVOIDED
554	5-Dec-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	14:33	15:50	01:17	LINE CLEAR AVOIDED
555	5-Dec-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	12:35	14:07	01:32	LINE CLEAR AVOIDED
556	5-Dec-2020	HASSAN	66	MRSSHM-BD-2	MRSMG_220	15:00	16:19	01:19	LINE CLEAR AVOIDED
557	5-Dec-2020	HASSAN	66	MRSSHM-BD-2	MRSMG_220	20:05	23:20	03:15	LINE FAULT
558	5-Dec-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	09:32	14:03	04:31	LINE CLEAR AVOIDED
559	5-Dec-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:31	12:31	01:00	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
560	5-Dec-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:33	15:50	01:17	NFBC ISSUED
561	5-Dec-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:35	14:07	01:32	NFBC ISSUED
562	5-Dec-2020	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	10:58	13:56	02:58	LINE CLEAR AVAILED
563	5-Dec-2020	HASSAN	110	HV1	ARASIKERE_110	14:30	14:45	00:15	LINE CLEAR AVAILED
564	5-Dec-2020	HASSAN	110	HV2	ARASIKERE_110	14:30	14:45	00:15	LINE CLEAR AVAILED
565	5-Dec-2020	HASSAN	110	HV3	HIRIYADKA_110	10:48	14:43	03:55	LINE CLEAR AVAILED
566	5-Dec-2020	HASSAN	110	HV1	JAVAGAL_110	10:57	16:33	05:36	LINE CLEAR AVAILED
567	5-Dec-2020	HASSAN	110	HV2	KULASHEKARA_110	09:20	15:59	06:39	LINE CLEAR AVAILED
568	5-Dec-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	09:41	09:48	00:07	HAND TRIPPED
569	5-Dec-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	16:17	16:28	00:11	LINE FAULT
570	5-Dec-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	16:28	20:37	04:09	LINE FAULT
571	5-Dec-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	21:08	21:26	00:18	HAND TRIPPED
572	5-Dec-2020	HASSAN	66	HV1	BALEHONNUR_66	07:12	07:57	00:45	TRANSFORMER FAULT
573	5-Dec-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	20:05	23:20	03:15	LINE FAULT
574	5-Dec-2020	HASSAN	66	GANGUR-HASSAN	GANGUR_66	10:25	14:26	04:01	MAIN SUPPLY FAILURE
575	5-Dec-2020	HASSAN	66	HV1	GANGUR_66	10:25	14:26	04:01	MAIN SUPPLY FAILURE
576	5-Dec-2020	HASSAN	66	HV1	HALEBEEDU_66	10:37	15:03	04:26	LINE CLEAR AVAILED
577	5-Dec-2020	HASSAN	66	HV2	HALEBEEDU_66	10:37	15:05	04:28	LINE CLEAR AVAILED
578	5-Dec-2020	HASSAN	66	MATNAV-CRPATNA	MATNAVILE_66	18:25	22:06	03:41	MAIN SUPPLY FAILURE
579	5-Dec-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHUPURA_66	04:55	05:18	00:23	LINE FAULT
580	5-Dec-2020	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:54	14:05	02:11	LINE CLEAR AVAILED
581	5-Dec-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	07:12	07:21	00:09	LOAD CURTAILMENT
582	5-Dec-2020	MYSURU	66	HV3	KUSHALANAGARA_66	7:12	7:17	0:05	LOAD CURTAILMENT
583	5-Dec-2020	MYSURU	66	DR PETE -KUNTHUR	SANTHEMARAHALLI_66 MUGUR_66 JANNUR_66 THAYURU_66 TNARASIPURA_66	10:46	10:51	0:04	LINE FAULT
584	5-Dec-2020	MYSURU	66	HOOTAGALLI-BARC 1	NO STATIONS EFFECTED	9:45	10:39	0:54	LINE CLEAR AVAILED
585	5-Dec-2020	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	10:15	17:19	7:04	LINE CLEAR AVAILED
586	5-Dec-2020	MYSURU	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:11	12:24	1:13	LINE CLEAR AVAILED
587	5-Dec-2020	MYSURU	66	JYOTHINAGARA-DK MAIDANA	JYOTHINAGARA_66	10:01	17:20	7:19	LINE CLEAR AVAILED
588	5-Dec-2020	MYSURU	66	JYOTHINAGARA-FTS	JYOTHINAGARA_66	10:01	17:30	7:29	LINE CLEAR AVAILED
589	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	9:40	10:51	1:11	LINE CLEAR AVAILED
590	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	9:40	10:51	1:11	LINE CLEAR AVAILED
591	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:25	11:38	1:13	LINE CLEAR AVAILED
592	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:17	12:28	1:11	LINE CLEAR AVAILED
593	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	12:34	13:52	1:18	LINE CLEAR AVAILED
594	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	12:34	13:53	1:19	LINE CLEAR AVAILED
595	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	13:08	14:12	1:04	LINE CLEAR AVAILED
596	5-Dec-2020	MYSURU	66	MADHUVANAHALLI-DODDINADUVADI	NO STATIONS EFFECTED	13:08	14:11	1:03	LINE CLEAR AVAILED
597	5-Dec-2020	MYSURU	66	HV1	MADHUVANAHALLI_220	9:15	11:12	1:57	LINE CLEAR AVAILED
598	5-Dec-2020	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	10:19	16:44	6:24	NFBC ISSUED
599	5-Dec-2020	MYSURU	66	BEGUR 220KV-BEGUR -1	NO STATIONS EFFECTED	11:42	12:19	0:37	LINE CLEAR AVAILED
600	5-Dec-2020	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	09:10 (04.12.2020)	17:40 (05/12/2020)	32:30 HRS	LINE CHARGED
601	5-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
602	5-Dec-2020	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_11 0, SAMPIGE_110, DODDAGUNI_110	8:02(04.12.2020)			LINE CLEAR AVAILED
603	5-Dec-2020	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2	MEGMICON 2_IPP_66	9:21:57(01.12.2020)	11:15:34 (05.12.2020)	96:54hrs	LINE CHARGED
604	5-Dec-2020	TUMKUR	220	TR-3	HIRIYUR_220	16:11	18:40	2:29	LINE CLEAR AVAILED
605	5-Dec-2020	TUMKUR	110	TR1	SAMPIGE_110	9:32	10:24	0:52	LINE CLEAR AVAILED
606	5-Dec-2020	TUMKUR	110	TR-2	SAMPIGE_110	9:32	10:25	0:52	LINE CLEAR AVAILED
607	5-Dec-2020	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	16:05	18:20	2:14	LINE CLEAR AVAILED
608	5-Dec-2020	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA 1	CHITRADURGA_66	12:56	15:01	2:04	LINE CLEAR AVAILED
609	5-Dec-2020	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA2	CHITRADURGA_66	12:55	14:54	1:58	LINE CLEAR AVAILED
610	5-Dec-2020	TUMKUR	66	CHITRADURGA 66kv- CHITRADURGA 2	CHITRADURGA_66	13:06	15:01	1:55	LINE CLEAR AVAILED
611	5-Dec-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	2:46	3:01	0:14	LINE FAULT
612	5-Dec-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	22:01	22:06	0:05	LINE FAULT
613	5-Dec-2020	TUMKUR	66	TR-1	HULIYURDURGA_66	1:20	1:32	0:11	TRANSFORMER FAULT
614	5-Dec-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	15:47	16:10	0:22	LINE CLEAR AVAILED
615	5-Dec-2020	TUMKUR	66	TR-1	KATTIGE_66	11:03	11:10	0:07	TRANSFORMER FAULT
616	5-Dec-2020	TUMKUR	66	TR-1	KATTIGE_66	13:02	13:08	0:06	TRANSFORMER FAULT
617	5-Dec-2020	TUMKUR	66	TR-1	KATTIGE_66	13:43	13:51	0:07	TRANSFORMER FAULT
618	5-Dec-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	13:28	13:42	0:13	TRANSFORMER FAULT
619	5-Dec-2020	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	15:58	18:33	2:34	LINE CLEAR AVAILED
620	5-Dec-2020	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	15:58	18:33	2:34	LINE CLEAR AVAILED
621	6-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
622	6-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
623	6-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
624	6-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
625	6-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
626	6-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
627	6-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
628	6-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
629	6-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
630	6-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED
631	6-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
632	6-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
633	6-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
634	6-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR_110	13:10 (30.11.2020)			LINE OPEN,LINE FAULT
635	6-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	21:59 (5.12.2020)	7:17 (6.12.2020)	9:16hrs	LINE OPEN,LINE CLEAR AVAILED
636	6-Dec-2020	BAGALKOT	110	NARENDRA-KUD DHARWAD	STATION NOT AFFECTED KUD DHARWAD_110	8:10 (05.12.2020)	15:12 (06.11.2020)	30:02hrs	LINE CHARGED
637	6-Dec-2020	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	22:56 (6.12.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
638	6-Dec-2020	BAGALKOT	110	HIDIKAL DAM-GHATAPRABHA	GHATAPRABHA_110	16:41	17:29	0:48	LINE FAULT
639	6-Dec-2020	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	ANKALAGI_110	17:29	17:53	0:24	HAND TRIPPED
640	6-Dec-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINAGAD&KARADI_33	20:50	20:54	0:04	TRANSFORMER FAULT
641	6-Dec-2020	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	07:41	17:43	10:02	LINE FAULT
642	6-Dec-2020	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	06:20	13:27	7:07	LINE FAULT
643	6-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	20:23 (6.12.2020)			LINE OPEN,LINE CLEAR AVAILED
644	6-Dec-2020	BAGALKOT	220	BELGAUM-NARENDRA 1	BELGAUM_220	20:24 (6.12.2020)			LINE OPEN,LINE CLEAR AVAILED
645	6-Dec-2020	BAGALKOT	110	110/11KV,HV3	HUBLI_220	00:09	01:24	1:15	LINE CLEAR AVAILED
646	6-Dec-2020	BAGALKOT	110	110/11KV,HV1	SLOUDATTI_220	09:25	15:34	6:09	LINE CLEAR AVAILED
647	6-Dec-2020	BAGALKOT	110	RANEBENNUR-GUTTAL	GUTTAL_110	20:52	20:59	0:07	LINE FAULT
648	6-Dec-2020	BAGALKOT	220	220/110KV,HV2,LV2	NAENDRA_220	09:48	14:27	4:39	LINE CLEAR AVAILED
649	6-Dec-2020	BAGALKOT	220	KUDUCHI-GHATAPRABHA	STATION NOT AFFECTED KUDUCHI_220	7:10	19:03	11:53	LINE CLEAR AVAILED
650	6-Dec-2020	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	7:12	19:01	11:49	LINE CLEAR AVAILED
651	6-Dec-2020	BAGALKOT	110	110/11KV,HV2	ITNAL_110	10:56	11:00	0:04	TRANSFORMER FAULT
652	6-Dec-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_ 33,KARADI_33,MYTRA SOLAR_33	20:50	20:54	0:04	TRANSFORMER FAULT
653	6-Dec-2020	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	12:15	12:20	00:05	LOAD CHANGE OVER
654	6-Dec-2020	BENGALURU	66	HV2	MALLASANDRA	14:30	15:44	01:14	LINE CLEAR AVAILED
655	6-Dec-2020	BENGALURU	220	HV1	MALUR 220	15:37	16:06	00:29	TRANSFORMER FAULT
656	6-Dec-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	15:37	16:28	00:51	LINE FAULT
657	6-Dec-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	16:28	16:42	00:14	LINE FAULT
658	6-Dec-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:37	16:10	00:33	LINE CLEAR AVAILED
659	6-Dec-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:37	16:11	00:34	LINE CLEAR AVAILED
660	6-Dec-2020	BENGALURU	66	HV2	YELAHANKA 220	13:29	13:35	00:06	LINE CLEAR AVAILED
661	6-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
662	6-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
663	6-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
664	6-Dec-2020	BENGALURU	220	HV3	HSR LAYOUT 220	23:12(03/12/2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
665	6-Dec-2020	GULBARGA	220	HV1	SHAHPUR_220	20:37	21:00	00:23	TRANSFORMER FAULT
666	6-Dec-2020	GULBARGA	220	MALLAT-BYGWAT1	BYGWAT_110,VALKAMDINI_1 10	03:46	03:56	00:10	LINE FAULT
667	6-Dec-2020	GULBARGA	220	MALLAT-BYGWAT2	MADLAPUR_110,MANVI_110	20:37	20:47	00:10	LINE FAULT
668	6-Dec-2020	GULBARGA	110	BYAGAWAT-MALLAT	BYAGAWAT_110,VALKAMDIN NI_110	03:45	03:55	00:10	MAIN SUPPLY FAILURE
669	6-Dec-2020	GULBARGA	110	HV2	CHICKSUGUR_110	13:53	13:56	00:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
670	6-Dec-2020	GULBARGA	110	HV2	CHICKSUGUR_110	13:07	13:20	00:13	TRANSFORMER FAULT
671	6-Dec-2020	GULBARGA	110	CHICKSUGUR-I/CAPMC	CHICKSUGUR_110,SHAKTINA GAR_110	00:50	01:10	00:20	MAIN SUPPLY FAILURE
672	6-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
673	6-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
674	6-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
675	6-Dec-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
676	6-Dec-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
677	6-Dec-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
678	6-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:38 (6.12.2020)			LINE OPEN,LINE CLEAR AVAILED
679	6-Dec-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:46	15:38	04:52	LINE CLEAR AVAILED
680	6-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:06	08:09	08:03	HAND TRIPPED
681	6-Dec-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:44	15:36	04:52	LINE CLEAR AVAILED
682	6-Dec-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:46	15:38	04:52	LINE CLEAR AVAILED
683	6-Dec-2020	HASSAN	110	HV2	KEMAR_220	11:35	14:01	02:26	TRANSFORMER FAULT
684	6-Dec-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:44	15:36	04:52	LINE CLEAR AVAILED
685	6-Dec-2020	HASSAN	110	HV1	ALKOLA_110	20:05	21:28	01:23	LINE CLEAR AVAILED
686	6-Dec-2020	HASSAN	110	HV2	ALKOLA_110	20:05	21:54	01:49	LINE CLEAR AVAILED
687	6-Dec-2020	HASSAN	110	HV2	NAVUNDA_110	11:10	11:15	00:05	TRANSFORMER FAULT
688	6-Dec-2020	HASSAN	110	HV2	NAVUNDA_110	11:15	11:35	00:20	LINE CLEAR AVAILED
689	6-Dec-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:41	14:07	01:26	LINE FAULT
690	6-Dec-2020	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	23:46	23:52	00:06	LINE FAULT
691	6-Dec-2020	MYSURU	66	BESAGRALLI-KOPPA	BESAGARAHALLI_66	9:50	12:00	2:10	NFBC ISSUED
692	6-Dec-2020	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	8:05	8:50	0:45	LINE FAULT
693	6-Dec-2020	MYSURU	66	SHANIVARSANTHE-YESSLUR	NO STATIONS EFFECTED	23:47	23:59	0:11	LINE FAULT
694	6-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT
695	6-Dec-2020	TUMKUR	110	NITTUR 220KV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	8:02(04.12.2020)			LINE CLEAR AVAILED
696	6-Dec-2020	TUMKUR	66	CHITRADURGA 66KV-MEGMICON 2	MEGMICON 2_IPP_66	9:21(01.12.2020)	11:15(05.12.2020)	86:12hrs	LINE CHARGED
697	6-Dec-2020	TUMKUR	110	TR-1	KGTEMPLE_110	14:31	14:48	0:16	HAND TRIPPED
698	6-Dec-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	2:16	2:24	0:08	TRANSFORMER FAULT
699	6-Dec-2020	TUMKUR	66	HULIYURDURGA-DUNDANAHALLI	DUNDANAHALLI_66	8:07	8:32	0:25	LINE FAULT
700	6-Dec-2020	TUMKUR	66	TR-1	MATHOD_66	6:39	6:46	0:06	TRANSFORMER FAULT
701	6-Dec-2020	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:42	13:08	2:26	LINE FAULT
702	7-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
703	7-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
704	7-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
705	7-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
706	7-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
707	7-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
708	7-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
709	7-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
710	7-Dec-2020	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
711	7-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL 220	12:39 (28.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
712	7-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
713	7-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
714	7-Dec-2020	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND 110	11:41 (28.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
715	7-Dec-2020	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED UTTUR 110	13:10 (30.11.2020)	3:05 (07.12.2020)	157:55hrs	LINE CHARGED
716	7-Dec-2020	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AREMALLAPUR 110	22:56 (6.12.2020)	20:06 (07.12.2020)	21:10hrs	TRANSFORMER CHARGED
717	7-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	20:23 (6.12.2020)	6:16 (07.12.2020)	9:53hrs	LINE CHARGED
718	7-Dec-2020	BAGALKOT	220	BELGAUM-NARENDRA 1	STATION NOT AFFECTED BELGAUM 220	20:24 (6.12.2020)	7:46 (07.12.2020)	11:22hrs	LINE CHARGED
719	7-Dec-2020	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	14:58	18:41	3:43	LINE CLEAR AVOIDED
720	7-Dec-2020	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	14:53	17:52	2:59	LINE CLEAR AVOIDED
721	7-Dec-2020	BAGALKOT	110	110/11KV, HV3(HV2)	GOPANAKOPPA_110	10:21	14:35	4:14	LINE CLEAR AVOIDED
722	7-Dec-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	08:31	12:12	3:41	TRANSFORMER FAULT
723	7-Dec-2020	BAGALKOT	110	110/11KV, HV3	YARAGATTI_110	12:30	13:03	0:33	LINE CLEAR AVOIDED
724	7-Dec-2020	BAGALKOT	110	110/11KV, HV2	YARAGATTI_110	14:52	15:42	0:50	LINE CLEAR AVOIDED
725	7-Dec-2020	BAGALKOT	220	220/110KV, HV1& LV1	VAJRAMATTI_220, BILAGI_110, KATARKI_110, VAJRAMATTI_110, MELLIGERI_110, LOKAPUR_110, MANTUR_110, MUDHOL_110	2:33	3:28	0:55	TRANSFORMER FAULT
726	7-Dec-2020	BAGALKOT	220	220/110KV, HV2& LV2	VAJRAMATTI_220, BILAGI_110, KATARKI_110, VAJRAMATTI_110, MELLIGERI_110, LOKAPUR_110, MANTUR_110, MUDHOL_110	02:33	03:38	1:05	TRANSFORMER FAULT
727	7-Dec-2020	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110	03:29	03:40	0:11	HAND TRIPPED
728	7-Dec-2020	BAGALKOT	110	VAJRAMATTI220- MANTUR1&2	MANTUR_110	03:29	03:41	0:12	HAND TRIPPED
729	7-Dec-2020	BAGALKOT	220	KUDUCHI-GHATAPRABHA	KUDUCHI_220	6:39 (07.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
730	7-Dec-2020	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
731	7-Dec-2020	BAGALKOT	110	110/11KV, HV3	NIPPANI_110,MAGNUM TUFF 33,BENNADI 33	12:03	13:41	1:38	LINE CLEAR AVOIDED
732	7-Dec-2020	BAGALKOT	110	110/11KV, HV1	NIPPANI_110	13:39	14:39	1:00	LINE CLEAR AVOIDED
733	7-Dec-2020	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	15:28	16:53	1:25	LINE CLEAR AVOIDED
734	7-Dec-2020	BAGALKOT	110	110/11KV, HV2	ITNAL_110	9:30	9:34	0:04	TRANSFORMER FAULT
735	7-Dec-2020	BAGALKOT	110	110/11KV, HV2	ITNAL_110	14:00	14:06	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
736	7-Dec-2020	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	11:30	11:40	0:10	LOAD CHANGE OVER
737	7-Dec-2020	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	12:02	12:12	0:10	LOAD CHANGE OVER
738	7-Dec-2020	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	22:28	22:33	0:05	LOAD CHANGE OVER
739	7-Dec-2020	BENGALURU	66	KADUGODI - ARMY WELFARE	ARMY WELFARE, KONDASPURA	16:07	16:51	0:44	LINE FAULT
740	7-Dec-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODUR	18:42	18:43	0:01	LINE CLEAR AVAILED
741	7-Dec-2020	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	13:25	13:29	0:04	LOAD CHANGE OVER
742	7-Dec-2020	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	15:40	15:45	0:05	LOAD CHANGE OVER
743	7-Dec-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	BRIGADE MEADOWS,SHOBHA FOREST	15:44	15:52	0:08	LINE CLEAR AVAILED
744	7-Dec-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	11:53	12:00	0:07	LOAD CHANGE OVER
745	7-Dec-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:15	12:45	0:30	LINE FAULT
746	7-Dec-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	13:00	15:33	2:33	LINE CLEAR AVAILED
747	7-Dec-2020	BENGALURU	66	HV1	AGALAKOTE	12:10	14:20	2:10	LINE CLEAR AVAILED
748	7-Dec-2020	BENGALURU	66	HV2	AGALAKOTE	14:10	17:15	3:05	LINE CLEAR AVAILED
749	7-Dec-2020	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	15:30	16:10	0:40	LINE CLEAR AVAILED
750	7-Dec-2020	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	16:30	17:15	0:45	LINE CLEAR AVAILED
751	7-Dec-2020	BENGALURU	66	HV1	CHATRA	12:27	13:14	0:47	LINE CLEAR AVAILED
752	7-Dec-2020	BENGALURU	66	HV2	CHATRA	12:28	13:14	0:46	LINE CLEAR AVAILED
753	7-Dec-2020	BENGALURU	66	HV1	KEMBODI	14:08	14:33	0:24	LINE CLEAR AVAILED
754	7-Dec-2020	BENGALURU	66	HV2	SULIBELE	15:30	15:35	0:05	LINE CLEAR AVAILED
755	7-Dec-2020	BENGALURU	66	HV1	TEMAGONDALU	13:38	13:40	0:01	LINE CLEAR AVAILED
756	7-Dec-2020	BENGALURU	66	YEDUMADU - KANAKAPURA 220	YEDUMADU, HANUMANTH NAGAR	11:32	11:50	0:18	LOAD CHANGE OVER
757	7-Dec-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:03	10:21	0:18	LOAD CHANGE OVER
758	7-Dec-2020	BENGALURU	220	HV3	HSR LAYOUT 220	23:12(03/12/2020)	17:04(07/12/2020)	89:48HRS	TRANSFORMER CHARGED
759	7-Dec-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	23:08 (07-12-2020)			LINE OPEN,LINE FAULT
760	7-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
761	7-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
762	7-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
763	7-Dec-2020	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	21:36(7/12/2020)			LINE OPEN,LINE FAULT
764	7-Dec-2020	GULBARGA	220	SEDAM-ORIENT	SEDAM_220	12:26	20:24	07:58	LINE OPEN,LINE CLEAR AVAILED
765	7-Dec-2020	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	17:45	17:55	00:10	LINE CLEAR AVAILED
766	7-Dec-2020	GULBARGA	110	HALBARGA-SANTHPUR	SANTHPUR_110	05:05	05:17	00:12	LINE FAULT
767	7-Dec-2020	GULBARGA	110	SEDAM-MUNIRABAD1	MUNIRABAD1_110	13:55	14:00	00:05	LINE FAULT
768	7-Dec-2020	GULBARGA	110	HV1	KUDITINI_110	12:13	13:55	01:42	LINE CLEAR AVAILED
769	7-Dec-2020	GULBARGA	110	MUNIRABAD1-SANKLAPUR	SANKLAPUR_110	16:20	16:25	00:05	MAIN SUPPLY FAILURE
770	7-Dec-2020	GULBARGA	66	HV1	HANSI_66	11:40	12:45	01:05	LINE CLEAR AVAILED
771	7-Dec-2020	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	15:00	16:40	01:40	LINE CLEAR AVAILED
772	7-Dec-2020	GULBARGA	66	GUDEKOTE-HANGAL(IDLE LINE)	GUDEKOTE_66	14:05	18:00	03:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
773	7-Dec-2020	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	17:05	17:25	00:20	LINE CLEAR AVAILED
774	7-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:38 (6.12.2020)	6:39(07.12.2020)	7:00 hrs	LINE CHARGED
775	7-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
776	7-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
777	7-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
778	7-Dec-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
779	7-Dec-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
780	7-Dec-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN,LINE CLEAR AVAILED
781	7-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:17(7.12.2020)			LINE OPEN,LINE CLEAR AVAILED
782	7-Dec-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	02:05	06:32	04:27	HAND TRIPPED
783	7-Dec-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:42	11:29	00:47	HAND TRIPPED
784	7-Dec-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:31	12:14	00:43	HAND TRIPPED
785	7-Dec-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:31	12:14	00:43	LINE CLEAR AVAILED
786	7-Dec-2020	HASSAN	220	HV1	GOPALAPURA_220	10:11	16:50	06:39	LINE CLEAR AVAILED
787	7-Dec-2020	HASSAN	110	HV1	HIRIYADKA_110	10:38	12:43	02:05	LINE CLEAR AVAILED
788	7-Dec-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:11	14:11	01:00	LINE CLEAR AVAILED
789	7-Dec-2020	HASSAN	66	HV2	HOLALUR_66	11:25	16:29	05:04	LINE CLEAR AVAILED
790	7-Dec-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	04:02	04:28	00:26	LINE FAULT
791	7-Dec-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	05:01	11:16	06:15	LINE FAULT
792	7-Dec-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	08:37	09:41	01:04	LINE CLEAR AVAILED
793	7-Dec-2020	HASSAN	66	HV1	MAGGE_66	04:05	04:30	00:25	MAIN SUPPLY FAILURE
794	7-Dec-2020	HASSAN	66	HV1	MAGGE_66	05:01	11:19	06:18	MAIN SUPPLY FAILURE
795	7-Dec-2020	HASSAN	66	HV2	MAGGE_66	04:05	04:30	00:25	MAIN SUPPLY FAILURE
796	7-Dec-2020	HASSAN	66	HV2	MAGGE_66	05:01	11:19	06:18	MAIN SUPPLY FAILURE
797	7-Dec-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	04:02	04:29	00:27	LINE FAULT
798	7-Dec-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	05:00	11:21	06:21	LINE FAULT
799	7-Dec-2020	HASSAN	66	HV2	MALLAPURA_66	13:25	13:45	00:20	LINE CLEAR AVAILED
800	7-Dec-2020	MYSURU	66	HV1	AKKIHBBAL_66	12:11	14:09	1:58	LINE CLEAR AVAILED
801	7-Dec-2020	MYSURU	66	HV2	CHANDAKAVADI_66	12:43 (07.12.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
802	7-Dec-2020	MYSURU	66	HV1	COWDALLI_66	12:55	13:04	0:08	HAND TRIPPED
803	7-Dec-2020	MYSURU	66	HV2	COWDALLI_66	13:40	13:45	0:05	HAND TRIPPED
804	7-Dec-2020	MYSURU	66	HV1	DATTAGALLY_66	14:40	15:00	0:20	HAND TRIPPED
805	7-Dec-2020	MYSURU	66	DATAGALLI-RK NAGARA	RKNAGARA_66	12:27	17:05	4:37	NFBC ISSUED
806	7-Dec-2020	MYSURU	66	HAMPAPURA-CHIKKAMANDYA	NO STATIONS EFFECTED	16:09	17:40	1:31	LINE CLEAR AVAILED
807	7-Dec-2020	MYSURU	66	JAIPURA-KADAKOLA	JAIPUR_66	10:05	17:42	7:37	LINE CLEAR AVAILED
808	7-Dec-2020	MYSURU	66	HV2	KIKKERI_66	16:31	17:14	0:42	LINE CLEAR AVAILED
809	7-Dec-2020	MYSURU	66	MADDUR-KIADB MANDYA	NO STATIONS EFFECTED	9:19	14:49	5:30	NFBC ISSUED
810	7-Dec-2020	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 TUMBEKERE 66	12:15	12:36	0:21	LINE FAULT
811	7-Dec-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	10:34	10:41	0:06	LINE FAULT
812	7-Dec-2020	MYSURU	66	RK NAGARA-MANDAKALLI	RKNAGARA_66	10:05	16:55	6:49	LINE CLEAR AVAILED
813	7-Dec-2020	MYSURU	66	HV1	SANIVARASANTHE_66	19:14	19:18	0:04	TRANSFORMER FAULT
814	7-Dec-2020	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN,LINE FAULT
815	7-Dec-2020	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_11 0, SAMPIGE_110, DODDAGUNI_110	8:02(04.12.2020)	15:01(07.12.2020)	79:03hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
816	7-Dec-2020	TUMKUR	66	TR-2	HALURAMESHWARA_66	5:13(07.12.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
817	7-Dec-2020	TUMKUR	220	TR-3	HIRIYUR_220	21:36	23:47	2:10	TRANSFORMER FAULT
818	7-Dec-2020	TUMKUR	110	TR-2	SAMPIGE_110	17:11	17:26	0:14	TRANSFORMER FAULT
819	7-Dec-2020	TUMKUR	110	TR-2	SAMPIGE_110	19:02	19:17	0:15	TRANSFORMER FAULT
820	7-Dec-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	9:35	12:28	2:53	LINE CLEAR AVAILED
821	7-Dec-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	18:46	19:58	1:12	LINE CLEAR AVAILED
822	7-Dec-2020	TUMKUR	66	BALENAHALLI- FEFCWIND IPP_66	FEFCWIND_IPP_66	20:25	21:32	1:06	LINE CLEAR AVAILED
823	7-Dec-2020	TUMKUR	66	BRAHMASANDRA- SIRA	SIRA_66,ANKASANDRA_66	6:33	7:03	0:30	LINE FAULT
824	7-Dec-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:26	10:34	0:08	LINE FAULT
825	7-Dec-2020	TUMKUR	66	TR-2	HALURAMESHWARA_66	16:49	17:12	0:23	TRANSFORMER FAULT
826	7-Dec-2020	TUMKUR	66	TR-2	HARIYABBE_66	16:24	16:36	0:12	LINE CLEAR AVAILED
827	7-Dec-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	19:43	20:10	0:27	TRANSFORMER FAULT
828	7-Dec-2020	TUMKUR	66	TR-2	MATHOD_66	7:44	7:53	0:08	TRANSFORMER FAULT
829	7-Dec-2020	TUMKUR	66	TR-1	RAMPURA_66	12:14	12:24	0:10	TRANSFORMER FAULT
830	7-Dec-2020	TUMKUR	66	THIMMASANDRA-HEBBUR	THIMMASANDRA_66	8:40	14:53	6:13	MAIN SUPPLY FAILURE
831	7-Dec-2020	TUMKUR	66	TR-1	CHITRADURGA_220	9:01	9:38	0:37	LINE CLEAR AVAILED
832	7-Dec-2020	TUMKUR	66	TR-1	CHITRADURGA_220	13:00	14:36	1:36	LINE CLEAR AVAILED
833	7-Dec-2020	TUMKUR	66	TR-2	CHITRADURGA_220	9:01	9:39	0:37	LINE CLEAR AVAILED
834	7-Dec-2020	TUMKUR	66	TR-2	CHITRADURGA_220	12:55	14:35	1:39	LINE CLEAR AVAILED