

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 25.12.2018 to 31.12.2018

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|---|---|---------|-----------|----------|---------------------|
| 1 | 24-Dec-18 | BAGALKOT | 220 | NAGJHARI 1-AMBEWADI | AMBEWADI_220 | 9:31 | 17:06 | 7:35 | LINE CLEAR AVAILED |
| 2 | 24-Dec-18 | BAGALKOT | 220 | PONDA 2 -AMBEWADI | AMBEWADI_220 | 0:00 | 15:56 | 15:56 | LINE CLEAR AVAILED |
| 3 | 24-Dec-18 | BAGALKOT | 220 | PONDA 2 -AMBEWADI | AMBEWADI_220 | 22:07 | 23:59 | 1:52 | LINE FAULT |
| 4 | 24-Dec-18 | BAGALKOT | 220 | CHIKKODI 220-BELGAUM 1 | CHIKKODI_220 | 0:00 | 9:27 | 9:27 | LINE CLEAR AVAILED |
| 5 | 24-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-1 | BIDNAL_220 | 11:15 | 16:47 | 5:32 | HAND TRIPPED |
| 6 | 24-Dec-18 | BAGALKOT | 110 | MAHALINGAPUR-DHAVALSHWAR | DHAVALSHWAR_110 | 0:00 | 8:44 | 8:44 | LINE CLEAR AVAILED |
| 7 | 24-Dec-18 | BAGALKOT | 110 | 110/33KV,HV3 | TILUVALLI_110,SHESAGIRI_33,KALKERI_33 | 22:00 | 22:29 | 0:29 | HAND TRIPPED |
| 8 | 24-Dec-18 | BAGALKOT | 110 | TADASINAKOPPA-TARIHAL | TARIHAL_110 | 9:40 | 9:50 | 0:10 | HAND TRIPPED |
| 9 | 24-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | NIDAGUNDI_110 | 12:53 | 13:36 | 0:43 | HAND TRIPPED |
| 10 | 24-Dec-18 | BAGALKOT | 110 | 110/11KV,HV2 | NIDAGUNDI_110 | 12:53 | 13:58 | 1:05 | HAND TRIPPED |
| 11 | 24-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | KIRUVATTI_110 | 10:12 | 17:55 | 7:43 | LINE CLEAR AVAILED |
| 12 | 24-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENAHALI, CHEEMANGALA | 13:45 | 16:59 | 3:13 | LINE FAULT |
| 13 | 24-Dec-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 1 | MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT) | 7:55 | 8:06 | 0:11 | LINE FAULT |
| 14 | 24-Dec-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 1 | MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT) | 9:00 | 9:33 | 0:33 | LINE FAULT |
| 15 | 24-Dec-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 1 | MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT) | 9:44 | 10:25 | 0:40 | LINE FAULT |
| 16 | 24-Dec-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 6 | SOLDEVANAHALI | 6:33 | 6:50 | 0:17 | LINE FAULT |
| 17 | 24-Dec-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 6 | SOLDEVANAHALI | 12:39 | 13:01 | 0:22 | LINE CLEAR AVAILED |
| 18 | 24-Dec-18 | BANGALORE | 66 | HV2 | SARJAPURA 220 | 3:46 | 3:56 | 0:09 | TRANSFORMER FAULT |
| 19 | 24-Dec-18 | BANGALORE | 66 | HOSKOTE 66 - MALUR | MALUR I/A, JADIGENAHALLI | 18:45 | 19:00 | 0:14 | LOAD CHANGE OVER |
| 20 | 24-Dec-18 | BANGALORE | 66 | ADUGODI-HAL 2 | K & C VALLEY,KORAMANGALA | 14:10 | 15:11 | 1:01 | LINE CLEAR AVAILED |
| 21 | 24-Dec-18 | BANGALORE | 66 | ADUGODI-NIMHANS 66 | NIMHANS 66,BOSCH(EHT) | 15:03 | 15:07 | 0:04 | LINE CLEAR AVAILED |
| 22 | 24-Dec-18 | BANGALORE | 66 | A STATION 220 - A STATION 66 | A STATION 66 | 0:21 | 0:24 | 0:03 | LOAD CHANGE OVER |
| 23 | 24-Dec-18 | BANGALORE | 66 | ELECTRONIC CITY - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY, INFOSYS (EHT) | 6:38 | 6:48 | 0:10 | LOAD CHANGE OVER |
| 24 | 24-Dec-18 | BANGALORE | 66 | HV2 | GOKULA | 9:35 | 9:36 | 0:01 | LOAD CHANGE OVER |
| 25 | 24-Dec-18 | BANGALORE | 66 | HV3 | HEBBAL 220 | 9:28 | 9:48 | 0:20 | TRANSFORMER FAULT |
| 26 | 24-Dec-18 | BANGALORE | 66 | HV3 | HEBBAL 220 | 14:32 | 14:46 | 0:14 | LINE CLEAR AVAILED |
| 27 | 24-Dec-18 | BANGALORE | 66 | HV3 | HEBBAL 220 | 14:48 | 16:53 | 2:05 | TRANSFORMER FAULT |
| 28 | 24-Dec-18 | BANGALORE | 220 | HV2 | HOODY 220 | 16:36 | 16:59 | 0:23 | TRANSFORMER FAULT |
| 29 | 24-Dec-18 | BANGALORE | 66 | ITI-HOODY 220 | ITI | 16:36 | 21:05 | 4:29 | MAIN SUPPLY FAILURE |
| 30 | 24-Dec-18 | BANGALORE | 66 | HV2 | JAYANAGARA | 12:52 | 13:14 | 0:22 | LINE CLEAR AVAILED |
| 31 | 24-Dec-18 | BANGALORE | 66 | HV1 | KENGERI SATELLITE TOWN | 18:47 | 20:30 | 1:43 | TRANSFORMER FAULT |
| 32 | 24-Dec-18 | BANGALORE | 66 | HV1 | MATHIKERE | 14:15 | 14:20 | 0:05 | LOAD CHANGE OVER |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|-------------------------------|--------------------------------|---------|-----------|----------|--------------------|
| 33 | 24-Dec-18 | BANGALORE | 66 | HV2 | MATHIKERE | 15:35 | 15:38 | 0:03 | LOAD CHANGEOVER |
| 34 | 24-Dec-18 | BANGALORE | 66 | SUBRAMANYAPURA 220 - REMCO 2 | GLOBAL VILLAGE (EHT), RR NAGAR | 8:10 | 8:25 | 0:15 | LINE FAULT |
| 35 | 24-Dec-18 | BANGALORE | 66 | RR NAGAR - VRISHABHAVATHI 220 | RR NAGAR | 14:43 | 14:48 | 0:05 | LOAD CHANGEOVER |
| 36 | 24-Dec-18 | GULBARGA | 220 | HV2 | ALIPUR_220 | 14:14 | 14:28 | 0:14 | TRANSFORMER FAULT |
| 37 | 24-Dec-18 | GULBARGA | 110 | HV2,HV3 | KAMPLI_110 | 14:33 | 14:36 | 0:03 | TRANSFORMER FAULT |
| 38 | 24-Dec-18 | GULBARGA | 110 | KAPNOOR-HUMNABAD2 | ALAND_110.KADAGANCHI_110 | 14:48 | 14:53 | 0:05 | LINE CLEAR AVAILED |
| 39 | 24-Dec-18 | GULBARGA | 110 | SINDHANOOR-PGLR_IPP | SIDHANOOR_220 | 5:42 | 6:04 | 0:22 | LINE FAULT |
| 40 | 24-Dec-18 | GULBARGA | 110 | SINDHANOOR-FUTURE-1 | TURVIHAL_110 | 13:32 | 13:38 | 0:06 | LINE FAULT |
| 41 | 24-Dec-18 | GULBARGA | 110 | HV3 | KUSTAGI_220 | 13:02 | 14:26 | 1:24 | TRANSFORMER FAULT |
| 42 | 24-Dec-18 | GULBARGA | 110 | HV3 | KUSTAGI_220 | 14:36 | 14:48 | 0:12 | TRANSFORMER FAULT |
| 43 | 24-Dec-18 | GULBARGA | 110 | HV3 | KUSTAGI_220 | 16:01 | 16:41 | 0:40 | TRANSFORMER FAULT |
| 44 | 24-Dec-18 | GULBARGA | 110 | MASKI-RENEWSLR | MASKI_110 | 0:00 | 13:40 | 13:40 | LINE FAULT |
| 45 | 24-Dec-18 | GULBARGA | 110 | MASKI-RENEWSLR | MASKI_110 | 18:27 | 19:22 | 0:55 | LINE CLEAR AVAILED |
| 46 | 24-Dec-18 | GULBARGA | 66 | HV1,HV2 | UPANAYAKANAHALLI_66 | 10:58 | 11:38 | 0:40 | LINE CLEAR AVAILED |
| 47 | 24-Dec-18 | HASSAN | 220 | GERSOPPA-STRP1 | GERSOPPA_GEN | 11:11 | 14:12 | 3:01 | LINE CLEAR AVAILED |
| 48 | 24-Dec-18 | HASSAN | 220 | GERSOPPA-STRP2 | GERSOPPA_GEN | 11:11 | 14:12 | 3:01 | LINE CLEAR AVAILED |
| 49 | 24-Dec-18 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 10:39 | 14:12 | 3:33 | LINE CLEAR AVAILED |
| 50 | 24-Dec-18 | HASSAN | 220 | SSHRAVTY-HIRALKOPPA | SHRAVTY_GEN | 11:30 | 14:03 | 2:33 | HAND TRIPPED |
| 51 | 24-Dec-18 | HASSAN | 220 | SHRLKP-SGS | SHRLKP_220 | 11:31 | 12:04 | 0:33 | HAND TRIPPED |
| 52 | 24-Dec-18 | HASSAN | 220 | SHRLKP-SGS | SHRLKP_220 | 12:09 | 12:21 | 0:12 | HAND TRIPPED |
| 53 | 24-Dec-18 | HASSAN | 220 | SHRLKP-SGS | SHRLKP_220 | 12:37 | 13:07 | 0:30 | HAND TRIPPED |
| 54 | 24-Dec-18 | HASSAN | 220 | SHRLKP-SGS | SHRLKP_220 | 13:13 | 14:03 | 0:50 | HAND TRIPPED |
| 55 | 24-Dec-18 | HASSAN | 220 | TALAGUPPA-STRP2 | TALAGUPPA_400 | 10:32 | 14:34 | 4:02 | LINE CLEAR AVAILED |
| 56 | 24-Dec-18 | HASSAN | 110 | ARSKERE2-ARSKR | ARSIKERE_220 | 10:34 | 11:15 | 0:41 | LINE CLEAR AVAILED |
| 57 | 24-Dec-18 | HASSAN | 110 | MOODAB-SOHAM1 | MOODAB_110 | 7:06 | 7:45 | 0:39 | HAND TRIPPED |
| 58 | 24-Dec-18 | HASSAN | 110 | MOODAB-SOHAM2 | MOODAB_110 | 7:06 | 7:45 | 0:39 | HAND TRIPPED |
| 59 | 24-Dec-18 | HASSAN | 110 | MOODAB-KEMAR | MOODAB_110 | 7:06 | 7:35 | 0:29 | LOAD CURTAILMENT |
| 60 | 24-Dec-18 | HASSAN | 110 | SHRLKP-BARANG | SHRLKP_220 | 11:18 | 12:54 | 1:36 | HAND TRIPPED |
| 61 | 24-Dec-18 | HASSAN | 110 | HV1 | SHRLKP_220 | 12:04 | 12:22 | 0:18 | LOAD CURTAILMENT |
| 62 | 24-Dec-18 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHRLKP_220 | 11:11 | 11:53 | 0:42 | HAND TRIPPED |
| 63 | 24-Dec-18 | HASSAN | 110 | KITTADAHALLI | SHRLKP_220 | 12:31 | 13:12 | 0:41 | HAND TRIPPED |
| 64 | 24-Dec-18 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHRLKP_220 | 11:55 | 13:04 | 1:09 | HAND TRIPPED |
| 65 | 24-Dec-18 | HASSAN | 110 | SHRLKP-SORAB | SHRLKP_220 | 11:56 | 13:27 | 1:31 | HAND TRIPPED |
| 66 | 24-Dec-18 | HASSAN | 66 | BALLUPE-KANDLI | BALLUPETE_66 | 6:20 | 7:15 | 0:55 | LOAD CURTAILMENT |
| 67 | 24-Dec-18 | HASSAN | 66 | HV2 | BELUR_66 | 11:25 | 12:50 | 1:25 | LINE CLEAR AVAILED |
| 68 | 24-Dec-18 | HASSAN | 66 | BELUR-MUDIGERE | BELUR_66 | 11:25 | 11:40 | 0:15 | LINE CLEAR AVAILED |
| 69 | 24-Dec-18 | HASSAN | 66 | HV1 | BELUR_66 | 11:25 | 11:40 | 0:15 | LINE CLEAR AVAILED |
| 70 | 24-Dec-18 | HASSAN | 66 | HNPR2-HASS1 | HNPURA_220 | 13:47 | 13:52 | 0:05 | LINE FAULT |
| 71 | 24-Dec-18 | HASSAN | 66 | HNPR2-MYSOR1 | HNPURA_220 | 8:22 | 8:30 | 0:08 | LINE FAULT |
| 72 | 24-Dec-18 | HASSAN | 66 | KANDLI0-SAKLESHPUR | KANDLI_66 | 11:35 | 13:08 | 1:33 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|----------|---------|--|--|---------|-----------|----------|---------------------|
| 73 | 24-Dec-18 | HASSAN | 66 | SAKALESH-HASSAN | SAKALESH PURA_66 | 11:59 | 13:09 | 1:10 | LOAD CURTAILMENT |
| 74 | 24-Dec-18 | MYSORE | 66 | DEVANUR NANJ-SUTTUR | SUTTUR_66 | 3:20 | 3:24 | 0:04 | LINE FAULT |
| 75 | 24-Dec-18 | MYSORE | 66 | HV1 | GUDDENAHALLI_66 | 15:06 | 16:08 | 1:02 | LINE CLEAR AVAILED |
| 76 | 24-Dec-18 | MYSORE | 66 | HV1 | K_HONNALGERE_66 | 14:53 | 15:13 | 0:20 | LINE CLEAR AVAILED |
| 77 | 24-Dec-18 | MYSORE | 66 | HV3 | KIKKERI_66 | 14:15 | 15:12 | 0:56 | LINE CLEAR AVAILED |
| 78 | 24-Dec-18 | TUMKUR | 110 | TR-2 | SAMPIGE_110 | 14:05 | 14:11 | 0:06 | TRANSFORMER FAULT |
| 79 | 24-Dec-18 | TUMKUR | 66 | TR-2 | ANTHRASANAHALLI_220 | 12:10 | 14:07 | 1:56 | LINE CLEAR AVAILED |
| 80 | 24-Dec-18 | TUMKUR | 66 | BELADADARA-CTKERE | BELADARA_66 | 13:44 | 13:55 | 0:11 | HAND TRIPPED |
| 81 | 24-Dec-18 | TUMKUR | 66 | DAVANGERE SRS- GUTTUR66 | GUTTUR_66 | 10:29 | 10:38 | 0:08 | LINE FAULT |
| 82 | 24-Dec-18 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:54 | 17:45 | 8:51 | LINE CLEAR AVAILED |
| 83 | 24-Dec-18 | TUMKUR | 66 | TR-1 | HALURAMESHWARA_66 | 11:47 | 13:23 | 1:36 | LINE CLEAR AVAILED |
| 84 | 24-Dec-18 | TUMKUR | 66 | TR-2 | HARAPPANAHALLI_66 | 16:03 | 18:12 | 2:08 | LINE CLEAR AVAILED |
| 85 | 24-Dec-18 | TUMKUR | 66 | TR-1 | HIREGUNTANUR_66 | 12:51 | 13:57 | 1:06 | LINE CLEAR AVAILED |
| 86 | 24-Dec-18 | TUMKUR | 66 | TR-2 | HIREGUNTANUR_66 | 13:24 | 13:33 | 0:09 | LINE CLEAR AVAILED |
| 87 | 24-Dec-18 | TUMKUR | 66 | KATTIGE- RENEW WIND IPP | RENEWIND_IPP_66 | 18:35 | 19:48 | 1:13 | LINE CLEAR AVAILED |
| 88 | 24-Dec-18 | TUMKUR | 66 | MADHUGIRI 220kV- SIRA | SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66 | 23:01 | 23:24 | 0:23 | LINE FAULT |
| 89 | 24-Dec-18 | TUMKUR | 66 | TR-1 | MANGALWADA_66 | 13:59 | 14:20 | 0:21 | LINE CLEAR AVAILED |
| 90 | 24-Dec-18 | TUMKUR | 66 | TR-2 | MANGALWADA_66 | 13:55 | 14:20 | 0:25 | LINE CLEAR AVAILED |
| 91 | 24-Dec-18 | TUMKUR | 66 | TR-2 | SANIKERE_66 | 19:33 | 19:54 | 0:21 | TRANSFORMER FAULT |
| 92 | 24-Dec-18 | TUMKUR | 66 | SIRA- BUKKAPATNA | BUKKAPATNA_66 | 23:22 | 23:36 | 0:13 | HAND TRIPPED |
| 93 | 24-Dec-18 | TUMKUR | 66 | SIRA- KALLAMBELLA | KALLAMBELLA_66 | 2:52 | 3:01 | 0:08 | LINE FAULT |
| 94 | 24-Dec-18 | TUMKUR | 66 | SIRA- MADHUGIRI 2 | BUKKAPATNA_66, KALLAMBELLA_66 | 2:52 | 3:01 | 0:08 | LINE FAULT |
| 95 | 24-Dec-18 | TUMKUR | 66 | SAVALANGA 66kV-HNLI220_NYMT | SAVALANGA_66 | 13:15 | 14:23 | 1:08 | MAIN SUPPLY FAILURE |
| 96 | 25-Dec-18 | BAGALKOT | 110 | 110/33KV,HV-3 | ANKALI_110 | 18:29 | 18:41 | 0:12 | TRANSFORMER FAULT |
| 97 | 25-Dec-18 | BAGALKOT | 220 | NAGJHARI 1-AMBEWADI | AMBEWADI_220 | 12:40 | 13:05 | 0:25 | LINE FAULT |
| 98 | 25-Dec-18 | BAGALKOT | 220 | NAGJHARI 1-AMBEWADI | AMBEWADI_220 | 15:02 | 15:24 | 0:22 | LINE FAULT |
| 99 | 25-Dec-18 | BAGALKOT | 220 | 220/110 KV,HV-2 | ATHANI_220 | 13:45 | 14:20 | 0:35 | TRANSFORMER FAULT |
| 100 | 25-Dec-18 | BAGALKOT | 220 | ATHANI-MAHALINGAPUR | ATHANI_220 | 13:45 | 15:01 | 1:16 | LINE FAULT |
| 101 | 25-Dec-18 | BAGALKOT | 110 | 220/110KV,LV-1 | ATHANI_220 | 13:57 | 14:22 | 0:25 | TRANSFORMER FAULT |
| 102 | 25-Dec-18 | BAGALKOT | 110 | ATHANI220-ATHANI 2 | ATHANI_110 | 14:04 | 14:45 | 0:41 | MAIN SUPPLY FAILURE |
| 103 | 25-Dec-18 | BAGALKOT | 110 | ATHANI220-TAUSHI | TAUSHI_110 | 14:04 | 14:34 | 0:30 | MAIN SUPPLY FAILURE |
| 104 | 25-Dec-18 | BAGALKOT | 110 | ATHANI220-AIGALI | AIGALI_110 | 14:04 | 14:31 | 0:27 | MAIN SUPPLY FAILURE |
| 105 | 25-Dec-18 | BAGALKOT | 110 | ATHANI220-SATTI | SATTI_110 | 14:05 | 14:40 | 0:35 | MAIN SUPPLY FAILURE |
| 106 | 25-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | BHUTANAL_110 | 7:33 | 7:37 | 0:04 | TRANSFORMER FAULT |
| 107 | 25-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | BHUTANAL_110 | 7:39 | 7:47 | 0:08 | TRANSFORMER FAULT |
| 108 | 25-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | BHUTANAL_110 | 8:53 | 8:58 | 0:05 | TRANSFORMER FAULT |
| 109 | 25-Dec-18 | BAGALKOT | 66 | HOSPET66-BANUVALLY | BANUVALLY_66 | 15:00 | 15:33 | 0:33 | LINE FAULT |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|--|---|---------|-----------|----------|---------------------|
| 110 | 25-Dec-18 | BAGALKOT | 110 | HUBLI220-TARIHAL | TARIHAL_110 | 6:33 | 12:20 | 5:47 | LINE FAULT |
| 111 | 25-Dec-18 | BAGALKOT | 110 | TADASINAKOPPA-TARIHAL | TARIHAL_110 | 12:35 | 12:40 | 0:05 | HAND TRIPPED |
| 112 | 25-Dec-18 | BAGALKOT | 110 | ENERCON1&2-SOUDATTI | SOUDATTI_110 | 12:32 | 19:17 | 6:45 | LINE CLEAR AVAILED |
| 113 | 25-Dec-18 | BAGALKOT | 110 | MATRIX WIND-MUKARTHAL | MUKARTHAL_110 | 14:39 | 19:12 | 4:33 | LINE CLEAR AVAILED |
| 114 | 25-Dec-18 | BAGALKOT | 110 | 110/11KV,HV2 | KUD DHARAWAD_110 | 18:19 | 18:27 | 0:08 | TRANSFORMER FAULT |
| 115 | 25-Dec-18 | BAGALKOT | 110 | 110/11KV,HV2 | KUD DHARAWAD_110 | 18:27 | 23:59 | 5:32 | TRANSFORMER FAULT |
| 116 | 25-Dec-18 | BAGALKOT | 110 | 110/11KV,HV4 | GAJENDRAGAD_110 | 22:14 | 23:10 | 0:56 | TRANSFORMER FAULT |
| 117 | 25-Dec-18 | BAGALKOT | 110 | HUBLI220-BIDNAL1 | BIDNAL_220 | 17:22 | 23:59 | 6:37 | LINE CLEAR AVAILED |
| 118 | 25-Dec-18 | BANGALORE | 66 | HV1 | HULLENAHALLI | 13:16 | 14:09 | 0:52 | TRANSFORMER FAULT |
| 119 | 25-Dec-18 | BANGALORE | 66 | HANUMANTHNAGARA - KANAKAPURA 220 | CHATRA, MARALWADI,HANUMANTHNAGARA,YED UMADU | 8:25 | 9:20 | 0:55 | MAIN SUPPLY FAILURE |
| 120 | 25-Dec-18 | BANGALORE | 66 | ITI-HEBBAL 220 | ITI | 19:20 | 20:02 | 0:42 | LOAD CHANGEOVER |
| 121 | 25-Dec-18 | BANGALORE | 66 | KANAKAPURA 220 - SOMANAHALLI 1 | CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU | 8:20 | 8:30 | 0:10 | LINE FAULT |
| 122 | 25-Dec-18 | BANGALORE | 66 | KANAKAPURA 220 - SOMANAHALLI 1 | CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU | 8:30 | 9:20 | 0:50 | LINE FAULT |
| 123 | 25-Dec-18 | BANGALORE | 66 | HV1 | SHAM RAJU TECH PARK | 20:25 | 21:10 | 0:45 | LOAD CHANGEOVER |
| 124 | 25-Dec-18 | BANGALORE | 220 | HV2 | YARANDANAHALLI 220 | 6:35 | 6:55 | 0:20 | TRANSFORMER FAULT |
| 125 | 25-Dec-18 | BANGALORE | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | ELECTRONIC CITY, INFOSYS (EHT) | 6:35 | 6:57 | 0:22 | LINE FAULT |
| 126 | 25-Dec-18 | GULBARGA | 220 | HV1 | ALIPUR_220 | 8:50 | 14:01 | 5:11 | LINE CLEAR AVAILED |
| 127 | 25-Dec-18 | GULBARGA | 220 | HV2 | ALIPUR_220 | 14:03 | 19:17 | 5:14 | LINE CLEAR AVAILED |
| 128 | 25-Dec-18 | GULBARGA | 110 | HV2 | BETAGERA_110 | 8:47 | 8:51 | 0:04 | TRANSFORMER FAULT |
| 129 | 25-Dec-18 | GULBARGA | 110 | HV2 | BETAGERA_110 | 11:35 | 11:38 | 0:03 | TRANSFORMER FAULT |
| 130 | 25-Dec-18 | GULBARGA | 110 | HV3 | DEODURGA_110 | 11:07 | 12:17 | 1:10 | LINE CLEAR AVAILED |
| 131 | 25-Dec-18 | GULBARGA | 110 | HV1,HV2 | LINGASUGUR_220 | 10:13 | 10:24 | 0:11 | LINE CLEAR AVAILED |
| 132 | 25-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 0:00 | 23:17 | 23:17 | LINE CLEAR AVAILED |
| 133 | 25-Dec-18 | HASSAN | 220 | KAVOOR-KEMR2 | KAVOOR_220 | 20:43 | 23:10 | 2:27 | LINE FAULT |
| 134 | 25-Dec-18 | HASSAN | 220 | SHARAVATHY4 | MRSSMG_220 | 11:44 | 13:46 | 2:02 | LINE CLEAR AVAILED |
| 135 | 25-Dec-18 | HASSAN | 220 | MSEZ-KAVOOR1 | MSEZ_220 | 20:43 | 23:14 | 2:31 | LINE FAULT |
| 136 | 25-Dec-18 | HASSAN | 220 | SHIMOGA4 | SHRAVTY_GEN | 11:44 | 13:46 | 2:02 | NBFC ISSUED |
| 137 | 25-Dec-18 | HASSAN | 220 | VARAHI-KEMAR1 | VARAHI_GEN | 12:09 | 13:53 | 1:44 | NBFC ISSUED |
| 138 | 25-Dec-18 | MYSORE | 66 | HV2 | AKKIHEBBAL_66 | 7:21 | 7:35 | 0:14 | TRANSFORMER FAULT |
| 139 | 25-Dec-18 | MYSORE | 66 | HV1 | HOOTAGALLY_220 | 10:41 | 10:54 | 0:12 | LINE CLEAR AVAILED |
| 140 | 25-Dec-18 | MYSORE | 66 | HV2 | SALIGRAMA_66 | 10:30 | 15:00 | 4:30 | LINE CLEAR AVAILED |
| 141 | 25-Dec-18 | MYSORE | 66 | HV1 | SALIGRAMA_66 | 10:30 | 15:00 | 4:30 | LINE CLEAR AVAILED |
| 142 | 25-Dec-18 | MYSORE | 66 | HV1 | SALIGRAMA_66 | 8:15 | 9:10 | 0:55 | LINE CLEAR AVAILED |
| 143 | 25-Dec-18 | TUMKUR | 110 | TR-2 | MAYASANDRA_110 | 19:24 | 19:37 | 0:13 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|---------------------------------------|---|---------|-----------|----------|---------------------|
| 144 | 25-Dec-18 | TUMKUR | 66 | TR-1 | HONNAVALI_110 | 12:36 | 12:39 | 0:02 | TRANSFORMER FAULT |
| 145 | 25-Dec-18 | TUMKUR | 66 | HONNAVALI 110-ADANSOLAR_IPP_110 | ADANSOLAR_IPP_110 | 12:36 | 12:38 | 0:02 | LINE FAULT |
| 146 | 25-Dec-18 | TUMKUR | 66 | HONNAVALI 110-DMKURKE | DMKURKE_110 | 12:36 | 12:38 | 0:02 | LINE FAULT |
| 147 | 25-Dec-18 | TUMKUR | 66 | TR-2 | BUKKAPATNA_66 | 10:54 | 12:39 | 1:45 | LINE CLEAR AVAILED |
| 148 | 25-Dec-18 | TUMKUR | 66 | DYAVARANAHALI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:15 | 17:21 | 9:05 | LINE CLEAR AVAILED |
| 149 | 25-Dec-18 | TUMKUR | 66 | NEELAGUNDA- TELAGI | TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66 | 6:58 | 7:06 | 0:08 | LINE FAULT |
| 150 | 25-Dec-18 | TUMKUR | 66 | SHYLAPURA- MADHUGIRI | SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66 | 6:11 | 6:16 | 0:04 | HAND TRIPPED |
| 151 | 26-Dec-18 | BAGALKOT | 220 | PONDA 2-AMBEWADI | AMBEWADI_220 | 0:00 | 15:24 | 15:24 | LINE CLEAR AVAILED |
| 152 | 26-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | AMBEWADI_220 | 9:46 | 12:04 | 2:18 | LINE CLEAR AVAILED |
| 153 | 26-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | BHUTANAL_110 | 9:21 | 9:22 | 0:01 | TRANSFORMER FAULT |
| 154 | 26-Dec-18 | BAGALKOT | 220 | BAGEWADI-ATRIA 1 | BAGEWADI_220 | 17:24 | 18:52 | 1:28 | LINE CLEAR AVAILED |
| 155 | 26-Dec-18 | BAGALKOT | 110 | KARAWAR 220-ARAGA | ARAGA_110 | 10:15 | 12:55 | 2:40 | LINE CLEAR AVAILED |
| 156 | 26-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | KUD DHARWAD_110 | 0:00 | 14:42 | 14:42 | LINE CLEAR AVAILED |
| 157 | 26-Dec-18 | BAGALKOT | 220 | SOUDATTI-MAHALINGAPUR | SOUDATTI_220 | 7:05 | 18:27 | 11:22 | LINE CLEAR AVAILED |
| 158 | 26-Dec-18 | BAGALKOT | 220 | HIREBENDIGERI1-BIDNAL | BIDNAL_220 | 21:14 | 23:59 | 2:45 | HAND TRIPPED |
| 159 | 26-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | SIDDAPUR_110 | 13:32 | 14:14 | 0:42 | LINE CLEAR AVAILED |
| 160 | 26-Dec-18 | BAGALKOT | 110 | HUBLI220-BIDNAL2 | HUBLI_220 | 11:17 | 16:59 | 5:42 | LINE CLEAR AVAILED |
| 161 | 26-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | SHIRGOAN_110 | 8:22 | 9:13 | 0:51 | LINE CLEAR AVAILED |
| 162 | 26-Dec-18 | BAGALKOT | 110 | 110/33KV, HV2 | MATTIHAL_110, NTPC_33, KOLAR W/S_33 | 15:17 | 15:26 | 0:09 | HAND TRIPPED |
| 163 | 26-Dec-18 | BAGALKOT | 110 | 110/11KV,HV2 | BIDNAL_220 | 10:25 | 16:39 | 6:14 | LINE CLEAR AVAILED |
| 164 | 26-Dec-18 | BANGALORE | 66 | SARJAPURA 220 - DOMMASANDRA | DOMMASANDRA | 14:14 | 15:01 | 0:47 | MAIN SUPPLY FAILURE |
| 165 | 26-Dec-18 | BANGALORE | 220 | MALUR 220 - SARJAPURA 220 | SARJAPURA 220, VIKAS TECH PARK 220 | 14:14 | 15:01 | 0:47 | LINE FAULT |
| 166 | 26-Dec-18 | BANGALORE | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 13:55 | 14:14 | 0:19 | LINE FAULT |
| 167 | 26-Dec-18 | BANGALORE | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 14:14 | 15:40 | 1:26 | LINE FAULT |
| 168 | 26-Dec-18 | BANGALORE | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 15:40 | 16:38 | 0:58 | LINE CLEAR AVAILED |
| 169 | 26-Dec-18 | BANGALORE | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 16:38 | 18:20 | 1:42 | LINE FAULT |
| 170 | 26-Dec-18 | BANGALORE | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 18:20 | 19:48 | 1:28 | LINE CLEAR AVAILED |
| 171 | 26-Dec-18 | BANGALORE | 66 | HV1 | KANAKAPURA | 7:47 | 7:56 | 0:08 | TRANSFORMER FAULT |
| 172 | 26-Dec-18 | BANGALORE | 66 | HONNIGANAHALLI - HALAGUR | HONNIGANAHALLI | 10:32 | 18:02 | 7:30 | LINE CLEAR AVAILED |
| 173 | 26-Dec-18 | BANGALORE | 66 | DEVANAHALLI - DB PURA 1 | DEVANAHALLI | 15:58 | 16:04 | 0:06 | LINE CLEAR AVAILED |
| 174 | 26-Dec-18 | BANGALORE | 66 | DEVANAHALLI - DB PURA 2 | DEVANAHALLI | 15:58 | 16:04 | 0:06 | LINE CLEAR AVAILED |
| 175 | 26-Dec-18 | BANGALORE | 66 | HALAGUR - TK HALLI 220 | HALAGUR | 10:10 | 16:15 | 6:05 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|------------------------------|-------------------------------------|---------|-----------|----------|---------------------|
| 176 | 26-Dec-18 | BANGALORE | 66 | AUSTIN TOWN - KORMANGALA | KORMANGALA | 12:14 | 12:20 | 0:06 | LINE FAULT |
| 177 | 26-Dec-18 | BANGALORE | 66 | EDC 220 - BMTC | BMTC | 12:13 | 12:30 | 0:17 | MAIN SUPPLY FAILURE |
| 178 | 26-Dec-18 | BANGALORE | 66 | HV1 | EDC 220 | 12:13 | 12:38 | 0:25 | MAIN SUPPLY FAILURE |
| 179 | 26-Dec-18 | BANGALORE | 66 | HV2 | EDC 220 | 12:13 | 12:38 | 0:25 | MAIN SUPPLY FAILURE |
| 180 | 26-Dec-18 | BANGALORE | 220 | NIMHANS 220 - EDC 220 | EDC 220, A STATION 220 | 12:13 | 12:33 | 0:20 | LINE FAULT |
| 181 | 26-Dec-18 | BANGALORE | 66 | A STATION 220 - A STATION 66 | A STATION 66 | 12:13 | 12:24 | 0:11 | MAIN SUPPLY FAILURE |
| 182 | 26-Dec-18 | BANGALORE | 220 | HV1 | EDC 220 | 12:13 | 12:23 | 0:10 | MAIN SUPPLY FAILURE |
| 183 | 26-Dec-18 | BANGALORE | 220 | HV2 | EDC 220 | 12:13 | 12:24 | 0:11 | MAIN SUPPLY FAILURE |
| 184 | 26-Dec-18 | BANGALORE | 66 | HV2 | GOKULA | 12:19 | 12:23 | 0:04 | LINE CLEAR AVAILED |
| 185 | 26-Dec-18 | BANGALORE | 66 | HV1 | GOKULA | 14:16 | 14:20 | 0:03 | LINE CLEAR AVAILED |
| 186 | 26-Dec-18 | BANGALORE | 66 | HV1 | GOKULA | 20:37 | 21:25 | 0:47 | LINE CLEAR AVAILED |
| 187 | 26-Dec-18 | BANGALORE | 66 | HV3 | HEBBAL 220 | 13:16 | 14:07 | 0:50 | LINE CLEAR AVAILED |
| 188 | 26-Dec-18 | BANGALORE | 66 | HV1 | KENGERI SATELLITE TOWN | 11:06 | 11:55 | 0:48 | LINE CLEAR AVAILED |
| 189 | 26-Dec-18 | BANGALORE | 66 | SRS PEENYA 220 - TG HALLI | BYDRAHALLI, TAVAREKERE, KODIGEHALLI | 8:38 | 10:13 | 1:35 | LINE FAULT |
| 190 | 26-Dec-18 | BANGALORE | 66 | HV2 | TELECOM LAYOUT | 11:27 | 11:31 | 0:03 | LINE CLEAR AVAILED |
| 191 | 26-Dec-18 | BANGALORE | 66 | TK HALLI 220 - BWSSB (EHT) | BWSSB (EHT) | 6:29 | 7:18 | 0:48 | LINE CLEAR AVAILED |
| 192 | 26-Dec-18 | BANGALORE | 66 | HV1 | MATHIKERE | 16:45 | 16:50 | 0:05 | LINE CLEAR AVAILED |
| 193 | 26-Dec-18 | BANGALORE | 66 | HV2 | MATHIKERE | 15:09 | 15:30 | 0:20 | LINE CLEAR AVAILED |
| 194 | 26-Dec-18 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 13:17 | 17:29 | 4:12 | LINE FAULT |
| 195 | 26-Dec-18 | GULBARGA | 110 | HV1,HV2 | LINGASUGUR_220 | 10:01 | 10:08 | 0:07 | TRANSFORMER FAULT |
| 196 | 26-Dec-18 | GULBARGA | 110 | LV2 | MALLAT_220 | 4:26 | 5:36 | 1:10 | TRANSFORMER FAULT |
| 197 | 26-Dec-18 | GULBARGA | 110 | HV4 | YELBURGA_110 | 13:39 | 14:34 | 0:55 | LINE CLEAR AVAILED |
| 198 | 26-Dec-18 | GULBARGA | 110 | SHAHPUR-YADGIR | YADGIR_110 | 0:00 | 11:37 | 11:37 | LINE FAULT |
| 199 | 26-Dec-18 | GULBARGA | 66 | HV2 | UPANAYAKANAHALLI_66 | 11:59 | 12:06 | 0:07 | TRANSFORMER FAULT |
| 200 | 26-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 0:00 | 10:33 | 10:33 | LINE CLEAR AVAILED |
| 201 | 26-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 23:39 | 23:59 | 0:20 | LINE CLEAR AVAILED |
| 202 | 26-Dec-18 | HASSAN | 220 | MRSSHM-SHARAVATHY4 | MRSMSG_220 | 3:41 | 4:13 | 0:32 | LINE FAULT |
| 203 | 26-Dec-18 | HASSAN | 220 | MRSSHM-SHARAVATHY4 | MRSMSG_220 | 4:13 | 12:37 | 8:24 | LINE FAULT |
| 204 | 26-Dec-18 | HASSAN | 220 | HV1 | MSEZ_220 | 11:24 | 11:26 | 0:02 | HAND TRIPPED |
| 205 | 26-Dec-18 | HASSAN | 220 | HV2 | MSEZ_220 | 11:32 | 11:36 | 0:04 | HAND TRIPPED |
| 206 | 26-Dec-18 | HASSAN | 220 | SHRAVATHY-SHIMOGA4 | SHRAVTY_GEN | 3:40 | 12:37 | 8:57 | LINE FAULT |
| 207 | 26-Dec-18 | HASSAN | 220 | MSEZ-KAVOOR1 | MSEZ_220 | 14:56 | 14:59 | 0:03 | HAND TRIPPED |
| 208 | 26-Dec-18 | HASSAN | 220 | MSEZ-KAVOOR2 | MSEZ_220 | 14:59 | 15:02 | 0:03 | HAND TRIPPED |
| 209 | 26-Dec-18 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 15:28 | 17:09 | 1:41 | LINE CLEAR AVAILED |
| 210 | 26-Dec-18 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 14:57 | 15:00 | 0:03 | HAND TRIPPED |
| 211 | 26-Dec-18 | HASSAN | 110 | HV1 | MSEZ_220 | 14:29 | 14:38 | 0:09 | HAND TRIPPED |
| 212 | 26-Dec-18 | HASSAN | 110 | MSEZ-LV1 | MSEZ_220 | 11:23 | 11:27 | 0:04 | HAND TRIPPED |
| 213 | 26-Dec-18 | HASSAN | 110 | MSEZ-LV2 | MSEZ_220 | 11:32 | 11:37 | 0:05 | HAND TRIPPED |
| 214 | 26-Dec-18 | HASSAN | 110 | MSEZ-GSS3-L2 | MSEZ_220 | 13:34 | 13:37 | 0:03 | HAND TRIPPED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|---------|---------|--|--|---------|-----------|----------|--------------------|
| 215 | 26-Dec-18 | HASSAN | 110 | MSEZ-GSS3-L1 | MSEZ_220 | 13:40 | 13:42 | 0:02 | HAND TRIPPED |
| 216 | 26-Dec-18 | HASSAN | 110 | HV3 | GURUVAYANKERE_110 | 10:29 | 13:58 | 3:29 | LINE CLEAR AVAILED |
| 217 | 26-Dec-18 | HASSAN | 110 | GURUVA-KEMAR2 | GURUVAYANKERE_110 | 11:03 | 17:28 | 6:25 | NBFC ISSUED |
| 218 | 26-Dec-18 | HASSAN | 110 | KEMAR-Guruvykere2 | KEMAR_220 | 11:03 | 17:28 | 6:25 | LINE CLEAR AVAILED |
| 219 | 26-Dec-18 | HASSAN | 110 | MANIPAL-BRAMVR | MANIPAL_110 | 8:29 | 17:29 | 9:00 | LINE CLEAR AVAILED |
| 220 | 26-Dec-18 | HASSAN | 110 | MOODAB-GURUPURA | MOODABIDRE_110 | 12:10 | 12:12 | 0:02 | HAND TRIPPED |
| 221 | 26-Dec-18 | HASSAN | 110 | MOODAB-KEMAR | MOODABIDRE_110 | 12:15 | 13:50 | 1:35 | LINE CLEAR AVAILED |
| 222 | 26-Dec-18 | HASSAN | 110 | HV3 | PUTUR_110 | 13:14 | 13:18 | 0:04 | TRANSFORMER FAULT |
| 223 | 26-Dec-18 | HASSAN | 110 | HV1 | SAGARA_110 | 13:44 | 14:08 | 0:24 | TRANSFORMER FAULT |
| 224 | 26-Dec-18 | HASSAN | 66 | HASSAN22-HN PURA | HASSN_220 | 10:05 | 14:18 | 4:13 | LINE CLEAR AVAILED |
| 225 | 26-Dec-18 | HASSAN | 66 | HV2 | KIADB HASSAN_66 | 16:11 | 16:20 | 0:09 | TRANSFORMER FAULT |
| 226 | 26-Dec-18 | HASSAN | 66 | KATTEPURA_MINIH | RAMNATHPURA_66 | 20:31 | 20:47 | 0:16 | LINE FAULT |
| 227 | 26-Dec-18 | MYSORE | 66 | HV2 | HONNALLY_MYS_66 | 15:09 | 15:43 | 0:33 | HAND TRIPPED |
| 228 | 26-Dec-18 | MYSORE | 66 | HV1 | RAMAPURA_MYS_66 | 11:21 | 18:11 | 6:49 | LINE CLEAR AVAILED |
| 229 | 26-Dec-18 | MYSORE | 66 | HV2 | RAMAPURA_MYS_66 | 11:21 | 18:11 | 6:49 | LINE CLEAR AVAILED |
| 230 | 26-Dec-18 | MYSORE | 66 | HV2 | KIRUGAVALU_66 | 13:15 | 16:19 | 3:04 | LINE CLEAR AVAILED |
| 231 | 26-Dec-18 | MYSORE | 66 | HV3 | KRPET_66 | 14:34 | 15:13 | 0:38 | LINE CLEAR AVAILED |
| 232 | 26-Dec-18 | MYSORE | 66 | GUNDLUPETE-BEGUR | BEGUR_66 SINDHUVALI_66 | 14:32 | 14:38 | 0:06 | HAND TRIPPED |
| 233 | 26-Dec-18 | MYSORE | 66 | TALAKADU-KOLLEGALA | THALAKADU_66 | 21:50 | 22:16 | 0:26 | HAND TRIPPED |
| 234 | 26-Dec-18 | MYSORE | 66 | TALAKADU-BG PURA | THALAKADU_66 | 21:50 | 22:16 | 0:26 | HAND TRIPPED |
| 235 | 26-Dec-18 | MYSORE | 66 | KADAKOLA-SARGUR 2 | DOORA_66, HURA_66 HULLAHALLI_66 | 2:19 | 2:24 | 0:05 | LINE FAULT |
| 236 | 26-Dec-18 | MYSORE | 66 | KUSHALANAGARA 220-MYSORE 1 | MIRLE_66, BILIKERE_66, GVGUDI_66, KRNAGARA_66 | 16:43 | 16:55 | 0:12 | LINE FAULT |
| 237 | 26-Dec-18 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | SHIVALLY_66, ADDIHALLI_66, HARADANAHALLI(JAK)_66, BGNAGARA_66, ADICHUNCHANAGIRI_66, VADERALLI_66 | 17:43 | 17:50 | 0:07 | LINE FAULT |
| 238 | 26-Dec-18 | TUMKUR | 110 | TR-1 | GUBBI_110 | 11:28 | 11:31 | 0:03 | TRANSFORMER FAULT |
| 239 | 26-Dec-18 | TUMKUR | 110 | TR-1(HV SIDE) | KALLUR_110 | 13:22 | 15:28 | 2:05 | LINE CLEAR AVAILED |
| 240 | 26-Dec-18 | TUMKUR | 110 | TR-1 | KALLUR_110 | 15:47 | 15:53 | 0:06 | LINE CLEAR AVAILED |
| 241 | 26-Dec-18 | TUMKUR | 110 | TR-1 | KALLUR_110 | 15:59 | 17:05 | 1:06 | LINE CLEAR AVAILED |
| 242 | 26-Dec-18 | TUMKUR | 110 | TR-1 | KALLUR_110 | 17:35 | 18:18 | 0:42 | LINE CLEAR AVAILED |
| 243 | 26-Dec-18 | TUMKUR | 110 | KALLUR- NITTUR | KALLUR_110 | 10:36 | 11:18 | 0:42 | LINE CLEAR AVAILED |
| 244 | 26-Dec-18 | TUMKUR | 110 | KALLUR- NITTUR | KALLUR_110 | 15:14 | 15:26 | 0:11 | LINE CLEAR AVAILED |
| 245 | 26-Dec-18 | TUMKUR | 110 | KALLUR- NITTUR | KALLUR_110 | 15:49 | 16:15 | 0:26 | LINE CLEAR AVAILED |
| 246 | 26-Dec-18 | TUMKUR | 110 | KALLUR- NITTUR | KALLUR_110 | 17:36 | 18:18 | 0:42 | LINE CLEAR AVAILED |
| 247 | 26-Dec-18 | TUMKUR | 66 | TR-1 | BAGUR_TMK_66 | 10:45 | 10:52 | 0:06 | TRANSFORMER FAULT |
| 248 | 26-Dec-18 | TUMKUR | 66 | TR-2 | CHELURU_66 | 8:51 | 9:18 | 0:26 | LINE CLEAR AVAILED |
| 249 | 26-Dec-18 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:47 | 17:43 | 8:55 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|--------------------------------|--|---------|-----------|----------|---------------------|
| 250 | 26-Dec-18 | TUMKUR | 66 | TR-1 | HARIHAR_66 | 9:53 | 10:09 | 0:16 | TRANSFORMER FAULT |
| 251 | 26-Dec-18 | TUMKUR | 66 | KUKKAWADA- LINGADAHALLI | TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 15:04 | 15:14 | 0:10 | LINE FAULT |
| 252 | 26-Dec-18 | TUMKUR | 66 | TR-1 | MANGALWADA_66 | 11:45 | 12:00 | 0:15 | TRANSFORMER FAULT |
| 253 | 26-Dec-18 | TUMKUR | 66 | TR-2 | MANGALWADA_66 | 11:45 | 12:00 | 0:15 | TRANSFORMER FAULT |
| 254 | 26-Dec-18 | TUMKUR | 66 | MANGALWADA-SHYLAPURA | MANGALWADA_66 | 11:45 | 11:59 | 0:14 | LINE FAULT |
| 255 | 26-Dec-18 | TUMKUR | 66 | MATHOD- PANCHANAHALLI | PANCHANAHALLI_66, GARAGA_66 | 10:29 | 12:07 | 1:38 | LINE CLEAR AVAILED |
| 256 | 26-Dec-18 | TUMKUR | 66 | TR-1 | NYAMATHI_66 | 15:14 | 16:18 | 1:03 | LINE CLEAR AVAILED |
| 257 | 26-Dec-18 | TUMKUR | 66 | TR-1 | SAVALANGA_66 | 21:03 | 21:15 | 0:11 | TRANSFORMER FAULT |
| 258 | 26-Dec-18 | TUMKUR | 66 | SHYLAURA- Y N HOSKOTE | YNHOSKOTE_66 | 16:53 | 16:54 | 0:01 | HAND TRIPPED |
| 259 | 26-Dec-18 | TUMKUR | 66 | SIRA- BUKKAPATNA | BUKKAPATNA_66 | 9:49 | 13:14 | 3:25 | LINE CLEAR AVAILED |
| 260 | 26-Dec-18 | TUMKUR | 66 | SIRA- KALLAMBELLA | KALLAMBELLA_66 | 8:58 | 9:50 | 0:51 | HAND TRIPPED |
| 261 | 26-Dec-18 | TUMKUR | 66 | SIRA- MADHUGIRI 2 | BUKKAPATNA_66, KALLAMBELLA_66 | 8:58 | 9:48 | 0:50 | LINE FAULT |
| 262 | 27-Dec-18 | BAGALKOT | 220 | AMBEWADI-NARENDRA 2 | AMBEWADI_220 | 10:43 | 17:12 | 6:29 | LINE CLEAR AVAILED |
| 263 | 27-Dec-18 | BAGALKOT | 110 | ANNIGERI-GADAG | ANNIGERI_110 | 13:23 | 13:30 | 0:07 | LINE CLEAR AVAILED |
| 264 | 27-Dec-18 | BAGALKOT | 110 | ANNIGERI-GADAG | ANNIGERI_110 | 17:25 | 17:31 | 0:06 | LINE CLEAR AVAILED |
| 265 | 27-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-2 | BANAHATTI_110 | 11:03 | 23:59 | 12:56 | LINE CLEAR AVAILED |
| 266 | 27-Dec-18 | BAGALKOT | 110 | BETAGERI-NAREGAL | BETAGERI_110 | 21:03 | 21:29 | 0:26 | HAND TRIPPED |
| 267 | 27-Dec-18 | BAGALKOT | 220 | ATHANI 220- RAVI URJA 1&2 | ATHANI_220 | 8:35 | 20:35 | 12:00 | LINE CLEAR AVAILED |
| 268 | 27-Dec-18 | BAGALKOT | 110 | BIDNAL-ANNIGERI | ANNIGERI_110 | 13:31 | 17:23 | 3:52 | HAND TRIPPED |
| 269 | 27-Dec-18 | BAGALKOT | 110 | MAHALINGAPUR-DAVALESHWAR | DAVALESHWAR_110 | 9:16 | 14:53 | 5:37 | LINE CLEAR AVAILED |
| 270 | 27-Dec-18 | BAGALKOT | 66 | HARIHAR HOSPET-BANUVALLY | BANUVALLY_66 | 15:07 | 19:20 | 4:13 | LINE FAULT |
| 271 | 27-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | YELLAPARHATTI_110 | 13:21 | 15:37 | 2:16 | LINE CLEAR AVAILED |
| 272 | 27-Dec-18 | BAGALKOT | 110 | HUBLI220-BIDNAL2 | HUBLI_220 | 11:09 | 16:03 | 4:54 | NBFC ISSUED |
| 273 | 27-Dec-18 | BAGALKOT | 110 | HIRA SUGAR FACTORY2-SANKESHWAR | SANKESHWAR_110 | 12:28 | 13:33 | 1:05 | LINE FAULT |
| 274 | 27-Dec-18 | BAGALKOT | 110 | NARENDRA-MRUTHYUNJAYNAGAR2 | MRUTHYUNJAYNAGAR_110 | 14:35 | 14:59 | 0:24 | LINE CLEAR AVAILED |
| 275 | 27-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | LOKAPUR_110 | 16:51 | 17:13 | 0:22 | LINE CLEAR AVAILED |
| 276 | 27-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | KUD DHARWAD_110 | 19:16 | 21:38 | 2:22 | LINE CLEAR AVAILED |
| 277 | 27-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2 | GUTTAL_110 | 3:57 | 4:18 | 0:21 | TRANSFORMER FAULT |
| 278 | 27-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2 | GUTTAL_110 | 11:03 | 11:26 | 0:23 | TRANSFORMER FAULT |
| 279 | 27-Dec-18 | BAGALKOT | 110 | GADAG ROAD-GOPPANAKOPPA | GOPPANAKOPPA_110 | 10:02 | 23:59 | 13:57 | LINE CLEAR AVAILED |
| 280 | 27-Dec-18 | BAGALKOT | 110 | NARAGUNDD-GOPPANAKOPPA | GOPPANAKOPPA_110 | 10:02 | 23:59 | 13:57 | LINE CLEAR AVAILED |
| 281 | 27-Dec-18 | BAGALKOT | 110 | 110/33KV, HV3&HV4 | GOPPANAKOPPA_110,KMC_33,KUSUGAL_33 | 9:59 | 15:51 | 5:52 | LINE CLEAR AVAILED |
| 282 | 27-Dec-18 | BAGALKOT | 110 | MRUTHYUNJAYNAGAR-GOPPANAKOPPA | GOPPANAKOPPA_110 | 15:51 | 16:35 | 0:44 | LINE CLEAR AVAILED |
| 283 | 27-Dec-18 | BAGALKOT | 110 | RON1&2-GAJENDRAGAD | GAJENDRAGAD_110 | 20:48 | 21:48 | 1:00 | MAIN SUPPLY FAILURE |
| 284 | 27-Dec-18 | BANGALORE | 66 | VIJAYANAGARA - CHANDRA LAYOUT | VIJAYANAGARA | 13:56 | 14:01 | 0:05 | LOAD CHANGEVER |
| 285 | 27-Dec-18 | BANGALORE | 66 | VIJAYANAGARA-NRS 220 | VIJAYANAGARA | 17:06 | 17:11 | 0:05 | LOAD CHANGEVER |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|--|--|---------|-----------|----------|--------------------|
| 286 | 27-Dec-18 | BANGALORE | 66 | ADUGODI - NIMHANS 220 | BOSCH (EHT), ADUGODI | 17:30 | 17:48 | 0:18 | LOAD CHANGEOVER |
| 287 | 27-Dec-18 | BANGALORE | 66 | ADUGODI-HAL 2 | K & C VALLEY,KORAMANGALA | 17:30 | 17:48 | 0:18 | LOAD CHANGEOVER |
| 288 | 27-Dec-18 | BANGALORE | 66 | HOODY 220-HOSKOTE 66 | HOSKOTE 66 | 8:21 | 9:23 | 1:02 | LINE FAULT |
| 289 | 27-Dec-18 | BANGALORE | 66 | PLATINUM CITY - SRS PEENYA 220 | PLATINUM CITY | 16:10 | 16:20 | 0:10 | LOAD CHANGEOVER |
| 290 | 27-Dec-18 | BANGALORE | 66 | PLATINUM CITY - SAHAKARINAGAR | PLATINUM CITY | 17:00 | 17:10 | 0:10 | LOAD CHANGEOVER |
| 291 | 27-Dec-18 | BANGALORE | 66 | SUBRAMANYPUARA 220 - SOMANAHALLI 1 | SUBRAMANYPUARA 66, ISKON | 10:35 | 10:45 | 0:10 | LOAD CHANGEOVER |
| 292 | 27-Dec-18 | BANGALORE | 66 | SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220 | SUBRAMANYAPURA 66 | 15:28 | 15:35 | 0:07 | LOAD CHANGEOVER |
| 293 | 27-Dec-18 | BANGALORE | 220 | HV2 | T K HALLI 220 | 13:15 | 13:27 | 0:12 | TRANSFORMER FAULT |
| 294 | 27-Dec-18 | BANGALORE | 66 | TK HALLI 220 - MANDYA 2 | KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE | 13:15 | 15:10 | 1:55 | LINE FAULT |
| 295 | 27-Dec-18 | BANGALORE | 66 | TK HALLI 220 - HAROHALLI 2 | INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT) | 13:15 | 13:34 | 0:19 | LINE CLEAR AVAILED |
| 296 | 27-Dec-18 | BANGALORE | 66 | TK HALLI 220 - IGGALUR | IGGALUR, AKKURMOLE, K HONALGERE | 13:15 | 13:34 | 0:19 | LINE CLEAR AVAILED |
| 297 | 27-Dec-18 | BANGALORE | 66 | TK HALLI 220 - SHIMSHA 1 | TK HALLI 220 | 13:18 | 13:46 | 0:28 | LINE CLEAR AVAILED |
| 298 | 27-Dec-18 | BANGALORE | 66 | TK HALLI 220 - SHIMSHA 2 | TK HALLI 220 | 13:18 | 13:44 | 0:26 | LINE CLEAR AVAILED |
| 299 | 27-Dec-18 | BANGALORE | 66 | TK HALLI 220 - SOMANAHALLI 1 | HALAGUR | 13:18 | 13:34 | 0:16 | LINE CLEAR AVAILED |
| 300 | 27-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA | 7:53 | 8:05 | 0:12 | LINE FAULT |
| 301 | 27-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA | 18:19 | 18:42 | 0:22 | LINE FAULT |
| 302 | 27-Dec-18 | BANGALORE | 66 | DOMMASANDRA - KACHAMARANAHALLI | KACHAMARANAHALLI | 14:50 | 17:00 | 2:10 | LINE FAULT |
| 303 | 27-Dec-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 1 & 2 | MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI | 10:07 | 18:17 | 8:10 | LINE CLEAR AVAILED |
| 304 | 27-Dec-18 | BANGALORE | 220 | NELAMANGALA 400 - ANCHEPALYA 1 | ANCHEPALYA 220 | 9:36 | 10:07 | 0:30 | LINE FAULT |
| 305 | 27-Dec-18 | BANGALORE | 220 | NELAMANGALA 400 - MAGADI 220 | MAGADI 220 | 9:36 | 10:13 | 0:37 | LINE FAULT |
| 306 | 27-Dec-18 | GULBARGA | 220 | SINDHANOOR-LINGASUGUR | SIDHANOOR_220 | 12:06 | 12:35 | 0:29 | LINE FAULT |
| 307 | 27-Dec-18 | GULBARGA | 220 | HV1 | HALBARGA_220 | 12:08 | 12:13 | 0:05 | TRANSFORMER FAULT |
| 308 | 27-Dec-18 | GULBARGA | 220 | HV2 | KUSTAGI_220 | 9:20 | 11:05 | 1:45 | LINE CLEAR AVAILED |
| 309 | 27-Dec-18 | GULBARGA | 220 | HV1 | KUSTAGI_220 | 10:40 | 11:05 | 0:25 | HAND TRIPPED |
| 310 | 27-Dec-18 | GULBARGA | 220 | LINGAPUR-KUSTAGI | LINGAPUR_220 | 8:06 | 19:45 | 11:39 | LINE CLEAR AVAILED |
| 311 | 27-Dec-18 | GULBARGA | 220 | HV1 | KUSTAGI_220 | 14:30 | 17:50 | 3:20 | LINE CLEAR AVAILED |
| 312 | 27-Dec-18 | GULBARGA | 220 | HV2 | KUSTAGI_220 | 17:10 | 17:40 | 0:30 | TRANSFORMER FAULT |
| 313 | 27-Dec-18 | GULBARGA | 110 | KUSTAGI-YELBURGA | YELBURGA_110 | 10:49 | 14:25 | 3:36 | LINE CLEAR AVAILED |
| 314 | 27-Dec-18 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110 | 12:32 | 13:01 | 0:29 | LINE FAULT |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|----------|---------|------------------------------------|--|---------|-----------|----------|--------------------|
| 315 | 27-Dec-18 | GULBARGA | 110 | BETAGERA-KSHVCMNT_SLR | BETAGERA_110 | 2:43 | 2:56 | 0:13 | LINE FAULT |
| 316 | 27-Dec-18 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,BHALKI_SUGURS_IPP | 2:20 | 2:30 | 0:10 | LINE FAULT |
| 317 | 27-Dec-18 | GULBARGA | 110 | HV2 | HANUMANAL_110 | 12:05 | 12:15 | 0:10 | TRANSFORMER FAULT |
| 318 | 27-Dec-18 | GULBARGA | 110 | SHAHBAD-GULBARGA UNIVERSITY | GULBARGA UNIVERSITY_110 | 10:33 | 12:50 | 2:17 | NBFC ISSUED |
| 319 | 27-Dec-18 | GULBARGA | 110 | GULBARGA SOUTH-GULBARGA UNIVERSITY | GULBARGA UNIVERSITY_110 | 10:30 | 10:40 | 0:10 | LINE CLEAR AVAILED |
| 320 | 27-Dec-18 | GULBARGA | 66 | UPANAYAKANAHALLI-MUNIRABAD | UPANAYAKANAHALLI_66 | 12:07 | 14:50 | 2:43 | LINE CLEAR AVAILED |
| 321 | 27-Dec-18 | GULBARGA | 66 | LV1 | ITTAGI_220 | 11:08 | 11:13 | 0:05 | HAND TRIPPED |
| 322 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-KUDILIGI2 | GUDEKOTE_66,HOSAHALLI_66,CJHALLI_66,BANVEKAL_66,CHORNOOR_66 | 11:30 | 11:48 | 0:18 | LINE FAULT |
| 323 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-KUDILIGI1,2 | KUDILGI_66,GUDEKOTE_66,HOSAHALLI_66,CJHALLI_66,BANVEKAL_66,CHORNOOR_66,KOGALI_66,HANASI_66 | 12:25 | 12:35 | 0:10 | LINE FAULT |
| 324 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-TBHALLI | HAMPASAGAR_66,MORAGERE_66,TAMB ARHALLI_66 | 12:25 | 12:45 | 0:20 | LINE FAULT |
| 325 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-HBHALLI | UPANAYAKANAHALLI_66,HAGARIBOMMA NAHALLI_66 | 12:25 | 12:45 | 0:20 | LINE FAULT |
| 326 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-TBHALLI | HAMPASAGAR_66,MORAGERE_66,TAMB ARHALLI_66 | 12:35 | 15:10 | 2:35 | LINE CLEAR AVAILED |
| 327 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-HIRAHADAGALLI | HIRAHADAGALLI_66,GIRIYAPUR_66,MAN GALA_66,SOVENAHALLI_66,TUNGABHAD RA_66 | 16:10 | 16:20 | 0:10 | LINE CLEAR AVAILED |
| 328 | 27-Dec-18 | GULBARGA | 66 | ITTAGI-KUDILIGI1 | KUDILGI_66,KOGALI_66,HANASI_66 | 18:05 | 18:08 | 0:03 | LINE FAULT |
| 329 | 27-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 0:00 | 6:45 | 6:45 | LINE CLEAR AVAILED |
| 330 | 27-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 21:06 | 23:59 | 2:53 | LINE CLEAR AVAILED |
| 331 | 27-Dec-18 | HASSAN | 400 | TALAGUP-SHANTHIGRAMA | TALAGUPPA_400 | 10:34 | 17:35 | 7:01 | LINE CLEAR AVAILED |
| 332 | 27-Dec-18 | HASSAN | 220 | KEMAR-BACHPE | KEMAR_220 | 12:45 | 16:51 | 4:06 | LINE FAULT |
| 333 | 27-Dec-18 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 12:44 | 16:50 | 4:06 | LINE FAULT |
| 334 | 27-Dec-18 | HASSAN | 110 | PUTTUR1-HV2 | PUTUR_110 | 10:25 | 12:27 | 2:02 | LINE CLEAR AVAILED |
| 335 | 27-Dec-18 | HASSAN | 110 | ANANDA-SHIMOGA | ANANDAPURA_110 | 10:35 | 11:00 | 0:25 | LINE CLEAR AVAILED |
| 336 | 27-Dec-18 | HASSAN | 110 | ANANDA-SHIMOGA | ANANDAPURA_110 | 11:40 | 12:00 | 0:20 | LINE CLEAR AVAILED |
| 337 | 27-Dec-18 | HASSAN | 110 | ARSK2-ARSKR | ARSIKERE_220 | 0:00 | 9:40 | 9:40 | LINE CLEAR AVAILED |
| 338 | 27-Dec-18 | HASSAN | 110 | ARSK2-BANAVARA | ARSIKERE_220 | 10:02 | 13:28 | 3:26 | LINE CLEAR AVAILED |
| 339 | 27-Dec-18 | HASSAN | 110 | HV1 | KALLUSANDRA_110 | 10:08 | 14:20 | 4:12 | LINE CLEAR AVAILED |
| 340 | 27-Dec-18 | HASSAN | 110 | MRSSHM-SS2 | MRSMG_220 | 10:37 | 10:42 | 0:05 | HAND TRIPPED |
| 341 | 27-Dec-18 | HASSAN | 110 | MRSSHM-SS2 | MRSMG_220 | 11:49 | 11:53 | 0:04 | HAND TRIPPED |
| 342 | 27-Dec-18 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 7:06 | 17:50 | 10:44 | LINE CLEAR AVAILED |
| 343 | 27-Dec-18 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 10:31 | 15:12 | 4:41 | LINE CLEAR AVAILED |
| 344 | 27-Dec-18 | HASSAN | 66 | HV1 | ALDUR_66 | 10:24 | 15:12 | 4:48 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|---------|---------|-------------------------------|---|---------|-----------|----------|---------------------|
| 345 | 27-Dec-18 | HASSAN | 66 | HV2 | BAGUR_66 | 2:30 | 2:45 | 0:15 | TRANSFORMER FAULT |
| 346 | 27-Dec-18 | HASSAN | 66 | HV2 | BAGUR_66 | 5:41 | 10:32 | 4:51 | TRANSFORMER FAULT |
| 347 | 27-Dec-18 | HASSAN | 66 | HV2 | BAGUR_66 | 12:26 | 13:35 | 1:09 | TRANSFORMER FAULT |
| 348 | 27-Dec-18 | HASSAN | 66 | HV1 | KBYARAPURA_66 | 14:45 | 15:20 | 0:35 | LINE CLEAR AVAILED |
| 349 | 27-Dec-18 | HASSAN | 66 | HV1 | CHIKMAGALUR_66 | 10:30 | 17:02 | 6:32 | LINE CLEAR AVAILED |
| 350 | 27-Dec-18 | HASSAN | 66 | HV2 | CHIKMAGALUR_66 | 10:50 | 17:02 | 6:12 | LINE CLEAR AVAILED |
| 351 | 27-Dec-18 | HASSAN | 66 | CHIKMAG-L1-ALDUR | CHIKMAGALUR_66 | 11:26 | 15:01 | 3:35 | LINE CLEAR AVAILED |
| 352 | 27-Dec-18 | HASSAN | 66 | HV1 | HASSAN_66 | 13:36 | 14:20 | 0:44 | LINE CLEAR AVAILED |
| 353 | 27-Dec-18 | HASSAN | 66 | HV2 | HASSAN_66 | 13:36 | 14:20 | 0:44 | LINE CLEAR AVAILED |
| 354 | 27-Dec-18 | HASSAN | 66 | HIREMANG-CHIKAMANGALUR | HIREMANGLUR_66 | 10:58 | 16:58 | 6:00 | LINE CLEAR AVAILED |
| 355 | 27-Dec-18 | HASSAN | 66 | HNPR2-MYSOR2 | HNPURA_220 | 9:31 | 9:35 | 0:04 | HAND TRIPPED |
| 356 | 27-Dec-18 | HASSAN | 66 | HNPR2-MYSOR2 | HNPURA_220 | 18:31 | 18:35 | 0:04 | HAND TRIPPED |
| 357 | 27-Dec-18 | MYSORE | 66 | HV1 | DEVANOORMYS_66 | 12:00 | 12:29 | 0:28 | LINE CLEAR AVAILED |
| 358 | 27-Dec-18 | MYSORE | 66 | HV2 | DEVANOORMYS_66 | 12:30 | 13:02 | 0:32 | LINE CLEAR AVAILED |
| 359 | 27-Dec-18 | MYSORE | 66 | HV1 | KUSHALANAGARA_66 | 13:06 | 13:25 | 0:18 | LINE CLEAR AVAILED |
| 360 | 27-Dec-18 | MYSORE | 66 | HV1 | MADIKERI_66 | 10:48 | 15:42 | 4:54 | LINE CLEAR AVAILED |
| 361 | 27-Dec-18 | MYSORE | 66 | HV1 | KUSHALANAGARA_66 | 13:25 | 13:36 | 0:11 | TRANSFORMER FAULT |
| 362 | 27-Dec-18 | MYSORE | 66 | KM DODDI-MANDYA | KMDODDI_66, KOLKARANADODDI_66, KIADBMANDYA_6 6, MADDUR_66 K_HONNALGERE_66 | 13:14 | 15:18 | 2:04 | HAND TRIPPED |
| 363 | 27-Dec-18 | MYSORE | 66 | KADAKOLA-SARAGUR 2 | DOORA_66, HURA_66 HULLAHALLI_66 | 12:59 | 13:09 | 0:10 | LINE FAULT |
| 364 | 27-Dec-18 | MYSORE | 66 | KADAKOLA-SARAGUR 1 | JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66 SANTHESARAGUR_66 | 12:59 | 13:09 | 0:10 | LINE FAULT |
| 365 | 27-Dec-18 | MYSORE | 66 | SFC SIVA-VAJMANGALA | KIRUGAVALU_66 | 18:05 | 18:15 | 0:10 | LINE FAULT |
| 366 | 27-Dec-18 | MYSORE | 66 | SUTTUR-DEVNUR(N'GUD) | SUTTUR_66 | 19:16 | 19:26 | 0:10 | LINE FAULT |
| 367 | 27-Dec-18 | MYSORE | 66 | SUTTUR-DEVNUR(N'GUD) | SUTTUR_66 | 19:35 | 20:05 | 0:30 | LINE FAULT |
| 368 | 27-Dec-18 | TUMKUR | 110 | TR-1 | TURUVEKERE_110 | 15:27 | 15:33 | 0:06 | TRANSFORMER FAULT |
| 369 | 27-Dec-18 | TUMKUR | 110 | TURUVEKERE110-KBCROSS | TURUVEKERE_110 | 11:17 | 14:37 | 3:20 | MAIN SUPPLY FAILURE |
| 370 | 27-Dec-18 | TUMKUR | 110 | TR-1 | GUNGURMALE_110 | 12:15 | 12:47 | 0:31 | LINE CLEAR AVAILED |
| 371 | 27-Dec-18 | TUMKUR | 110 | GUNGURMALE110-KB CROSS220 | GUNGURMALE_110 | 12:17 | 12:47 | 0:29 | LINE CLEAR AVAILED |
| 372 | 27-Dec-18 | TUMKUR | 110 | TR-1 | KALLUR_110 | 12:34 | 14:21 | 1:46 | LINE CLEAR AVAILED |
| 373 | 27-Dec-18 | TUMKUR | 110 | KALLUR- NITTUR | KALLUR_110 | 12:34 | 14:21 | 1:46 | LINE CLEAR AVAILED |
| 374 | 27-Dec-18 | TUMKUR | 110 | KB CROSS 220kV- MAYASANDRA | MAYASANDRA_110, TANDAGA_110, KADEHALLI_110 | 11:28 | 14:30 | 3:02 | LINE CLEAR AVAILED |
| 375 | 27-Dec-18 | TUMKUR | 110 | NITTUR 220kV- GUBBI | GUBBI_110, BIDARE_110 | 11:25 | 18:09 | 6:43 | LINE CLEAR AVAILED |
| 376 | 27-Dec-18 | TUMKUR | 110 | NITTUR 220kV- KADABA | KADABA_110 | 16:49 | 17:58 | 1:09 | LINE CLEAR AVAILED |
| 377 | 27-Dec-18 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 9:40 | 9:44 | 0:04 | LINE FAULT |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|----------|---------|----------------------------------|---|---------|-----------|----------|---------------------|
| 378 | 27-Dec-18 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 10:04 | 10:28 | 0:23 | LINE FAULT |
| 379 | 27-Dec-18 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- TUMKUR | TUMKUR_66 | 13:16 | 17:44 | 4:28 | HAND TRIPPED |
| 380 | 27-Dec-18 | TUMKUR | 66 | TR-1 | CHIKKABANAGERE_66 | 16:00 | 16:29 | 0:29 | LINE CLEAR AVAILED |
| 381 | 27-Dec-18 | TUMKUR | 66 | TR-1 | HARIHAR_66 | 10:54 | 11:04 | 0:09 | TRANSFORMER FAULT |
| 382 | 27-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 9:40 | 9:54 | 0:14 | LINE FAULT |
| 383 | 27-Dec-18 | TUMKUR | 66 | MADANAYAKANAHALLI-CHITRADURGA220 | MADANAYAKANAHALLI_66 | 11:41 | 12:42 | 1:01 | LINE CLEAR AVAILED |
| 384 | 27-Dec-18 | TUMKUR | 66 | TR-1 | RANGANATHAPURA_66 | 16:15 | 17:32 | 1:16 | LINE CLEAR AVAILED |
| 385 | 27-Dec-18 | TUMKUR | 66 | SHYLAPURA- MADHUGIRI | SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66 | 21:59 | 22:03 | 0:03 | HAND TRIPPED |
| 386 | 27-Dec-18 | TUMKUR | 66 | SOKKE-JAGLUR | SOKKE_66 | 12:06 | 12:09 | 0:03 | HAND TRIPPED |
| 387 | 27-Dec-18 | TUMKUR | 66 | SOKKE-JAGLUR | SOKKE_66 | 12:49 | 14:00 | 1:10 | LINE CLEAR AVAILED |
| 388 | 27-Dec-18 | TUMKUR | 66 | THALLAK 220kv- CHALLAKERE-2 | CHALLAKERE_66, SANIKERE_66 | 6:26 | 6:34 | 0:07 | LINE FAULT |
| 389 | 27-Dec-18 | TUMKUR | 66 | THALLAK 220kv- CHALLAKERE-2 | CHALLAKERE_66, SANIKERE_66 | 6:42 | 6:48 | 0:05 | LINE FAULT |
| 390 | 27-Dec-18 | TUMKUR | 66 | TR-2 | TUMKUR_66 | 17:47 | 17:58 | 0:10 | HAND TRIPPED |
| 391 | 28-Dec-18 | BAGALKOT | 220 | AMBEWADI-NARENDRA 1 | AMBEWADI_220 | 10:39 | 14:24 | 3:45 | LINE CLEAR AVAILED |
| 392 | 28-Dec-18 | BAGALKOT | 110 | ATHANI 220-TAUSHI | TAUSHI_110 | 5:32 | 5:42 | 0:10 | LINE FAULT |
| 393 | 28-Dec-18 | BAGALKOT | 110 | BELLATTI- AB SOLAR | BELLATTI_110 | 17:42 | 18:30 | 0:48 | LINE CLEAR AVAILED |
| 394 | 28-Dec-18 | BAGALKOT | 110 | BIDNAL-NAVALAGUND | NAVALAGUND_110 | 11:04 | 15:21 | 4:17 | HAND TRIPPED |
| 395 | 28-Dec-18 | BAGALKOT | 110 | BIDNAL-GADAG ROAD | GADAG ROAD_110 | 11:18 | 13:28 | 2:10 | HAND TRIPPED |
| 396 | 28-Dec-18 | BAGALKOT | 110 | 110/11KV,HV-3 | JAMAKHANDI_110 | 13:04 | 13:48 | 0:44 | HAND TRIPPED |
| 397 | 28-Dec-18 | BAGALKOT | 110 | 11011KV,HV-1 | JAMBAGI_110 | 1:14 | 2:22 | 1:08 | MAIN SUPPLY FAILURE |
| 398 | 28-Dec-18 | BAGALKOT | 110 | JAMBAGI-MUDHOL(HALAKI) | HALAKI_110 | 1:14 | 2:22 | 1:08 | MAIN SUPPLY FAILURE |
| 399 | 28-Dec-18 | BAGALKOT | 220 | 220/110KV, HV1&LV1 | VAJRAMATTI_220,VAJRAMATTI_110, MELLGERI_110,MANTUR_110, BILAGI_110, KATARKI_110,JAMBAGI_110 | 1:13 | 1:33 | 0:20 | TRANSFORMER FAULT |
| 400 | 28-Dec-18 | BAGALKOT | 220 | 220/110KV, HV2 | VAJRAMATTI_220,VAJRAMATTI_110, MELLGERI_110,MANTUR_110, BILAGI_110, KATARKI_110,JAMBAGI110 | 1:13 | 1:35 | 0:22 | TRANSFORMER FAULT |
| 401 | 28-Dec-18 | BAGALKOT | 220 | VAJRAMATTI220-KAVATAGI LIS | VAJRAMATTI_220 | 1:13 | 2:11 | 0:58 | LINE FAULT |
| 402 | 28-Dec-18 | BAGALKOT | 110 | 110/33KV, HV2 | UTTUR_110,YADWAD_33, VANTAGODI_33 | 1:13 | 2:11 | 0:58 | TRANSFORMER FAULT |
| 403 | 28-Dec-18 | BAGALKOT | 110 | 110/11KV, HV3 | HUBLI_220 | 12:54 | 13:52 | 0:58 | HAND TRIPPED |
| 404 | 28-Dec-18 | BAGALKOT | 220 | 220/110KV, HV1&LV1 | SOUDATTI_220 | 7:13 | 9:19 | 2:06 | LINE CLEAR AVAILED |
| 405 | 28-Dec-18 | BAGALKOT | 220 | 220/110KV, HV2&LV2 | SOUDATTI_220 | 10:41 | 17:33 | 6:52 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|---|---|---------|-----------|----------|---------------------|
| 406 | 28-Dec-18 | BAGALKOT | 110 | SOUDATTI220-YARGATTI | YARGATTI_110 | 7:01 | 10:24 | 3:23 | LINE CLEAR AVAILED |
| 407 | 28-Dec-18 | BAGALKOT | 110 | SOUDATTI220-MUNVALLY | MUNVALLY_110 | 7:04 | 17:33 | 10:29 | LINE CLEAR AVAILED |
| 408 | 28-Dec-18 | BAGALKOT | 110 | SATTI-RABKAVI | RABKAVI_110 | 13:08 | 15:18 | 2:10 | LINE CLEAR AVAILED |
| 409 | 28-Dec-18 | BAGALKOT | 110 | 110/11KV,HV2 | NIPPANI_110 | 16:01 | 16:15 | 0:14 | LINE CLEAR AVAILED |
| 410 | 28-Dec-18 | BAGALKOT | 110 | KONNUR-NAVALGUND | NAVALGUND_110 | 15:27 | 23:59 | 8:32 | LINE CLEAR AVAILED |
| 411 | 28-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | NANADI_110 | 12:14 | 14:17 | 2:03 | LINE CLEAR AVAILED |
| 412 | 28-Dec-18 | BANGALORE | 66 | HV2 | APPAREAL PARK | 10:20 | 10:29 | 0:09 | TRANSFORMER FAULT |
| 413 | 28-Dec-18 | BANGALORE | 66 | AUSTIN TOWN - KORAMANGALA | KORAMANGALA | 16:53 | 17:14 | 0:20 | LINE FAULT |
| 414 | 28-Dec-18 | BANGALORE | 66 | NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 | ELECTRONIC CITY PH 2 SEC 2, BIOCON (EHT), TECH MAHINDRA (EHT) | 10:15 | 11:00 | 0:45 | LINE FAULT |
| 415 | 28-Dec-18 | BANGALORE | 66 | AGALAKOTE-ANCHEPALYA | AGALAKOTE | 7:45 | 8:05 | 0:20 | MAIN SUPPLY FAILURE |
| 416 | 28-Dec-18 | BANGALORE | 66 | AGALAKOTE-ANCHEPALYA | AGALAKOTE | 8:10 | 11:45 | 3:35 | MAIN SUPPLY FAILURE |
| 417 | 28-Dec-18 | BANGALORE | 66 | ATTIBELE - SARAJAPURA 220 | ATTIBELE | 15:00 | 15:05 | 0:05 | LINE FAULT |
| 418 | 28-Dec-18 | BANGALORE | 66 | ATTIBELE - SARAJAPURA 220 | ATTIBELE | 15:20 | 15:30 | 0:10 | LINE FAULT |
| 419 | 28-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - GANJIGUNTE 1 & 2 | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 5:59 | 6:09 | 0:10 | LINE FAULT |
| 420 | 28-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - GANJIGUNTE 1 | GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA | 6:22 | 6:26 | 0:04 | LINE FAULT |
| 421 | 28-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - YENNIGADALE | YENNIGADALE, CHELUR, CHAKAVELU | 12:20 | 14:10 | 1:50 | LINE FAULT |
| 422 | 28-Dec-18 | BANGALORE | 66 | GANJIGUNTE - DIBBURAHALLI | DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI | 6:20 | 6:45 | 0:25 | LINE FAULT |
| 423 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR - ACC LTD. | ACC LTD. | 10:15 | 18:17 | 8:02 | LINE CLEAR AVAILED |
| 424 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - BAGEPALLI 1 | VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA | 10:15 | 19:05 | 8:50 | LINE CLEAR AVAILED |
| 425 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - BAGEPALLI 2 | VIDURASHWATHA, GUNDLU KOTTUR, BAGEPALLI | 10:15 | 19:05 | 8:50 | LINE CLEAR AVAILED |
| 426 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - DB 1 | THONDEBHAVI, MANCHENAHALLI | 10:15 | 19:05 | 8:50 | LINE CLEAR AVAILED |
| 427 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - KODIGENAHALLI | KODIGENAHALLI, ID HALLI | 10:15 | 19:05 | 8:50 | LINE CLEAR AVAILED |
| 428 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - PERESANDRA | PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE | 10:15 | 19:05 | 8:50 | LINE CLEAR AVAILED |
| 429 | 28-Dec-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - RAMAPURA | RAMAPURA, NITRAHALLI | 10:15 | 19:05 | 8:50 | LINE CLEAR AVAILED |
| 430 | 28-Dec-18 | BANGALORE | 220 | GOWRIBIDANUR 220 - PGCIL 1 & 2 | GOWRIBIDANUR 220 | 11:45 | 17:40 | 5:55 | LINE CLEAR AVAILED |
| 431 | 28-Dec-18 | BANGALORE | 220 | HV1 | GOWRIBIDANUR 220 | 10:15 | 18:15 | 8:00 | LINE CLEAR AVAILED |
| 432 | 28-Dec-18 | BANGALORE | 220 | HV2 | GOWRIBIDANUR 220 | 10:15 | 18:15 | 8:00 | LINE CLEAR AVAILED |
| 433 | 28-Dec-18 | BANGALORE | 220 | HV3 | GOWRIBIDANUR 220 | 10:15 | 18:15 | 8:00 | LINE CLEAR AVAILED |
| 434 | 28-Dec-18 | BANGALORE | 66 | HV2 | KGF | 14:39 | 16:49 | 2:10 | LINE CLEAR AVAILED |
| 435 | 28-Dec-18 | BANGALORE | 66 | HV1 | KODIHALLI | 11:07 | 11:12 | 0:05 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|-------------------------|---|---------|-----------|----------|--------------------|
| 436 | 28-Dec-18 | BANGALORE | 66 | HV2 | MAGADI | 9:50 | 10:15 | 0:25 | TRANSFORMER FAULT |
| 437 | 28-Dec-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT) | 6:36 | 6:47 | 0:11 | LINE FAULT |
| 438 | 28-Dec-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT) | 9:58 | 10:11 | 0:13 | LINE FAULT |
| 439 | 28-Dec-18 | BANGALORE | 66 | RAMANAGARA-BIDADI 220 | RAMANAGARA | 12:02 | 12:08 | 0:06 | LINE FAULT |
| 440 | 28-Dec-18 | GULBARGA | 220 | HUMNABAD-SEDAM2 | HUMNABAD_220 | 10:55 | 11:48 | 0:53 | LINE FAULT |
| 441 | 28-Dec-18 | GULBARGA | 220 | HUMNABAD-KAPNOOR1 | KAPNOOR_220 | 10:55 | 11:20 | 0:25 | LINE FAULT |
| 442 | 28-Dec-18 | GULBARGA | 220 | HUMNABAD-KAPNOOR2 | KAPNOOR_220 | 10:55 | 11:45 | 0:50 | LINE FAULT |
| 443 | 28-Dec-18 | GULBARGA | 220 | HV1,HV2 | HALBARGA_220 | 10:27 | 10:40 | 0:13 | TRANSFORMER FAULT |
| 444 | 28-Dec-18 | GULBARGA | 220 | HUMNABAD220-SEDAM1 | HUMNABAD_220 | 10:07 | 17:23 | 7:16 | NBFC ISSUED |
| 445 | 28-Dec-18 | GULBARGA | 220 | HUMNABAD-KAPNOOR1 | KAPNOOR_220 | 17:17 | 17:30 | 0:13 | LINE CLEAR AVAILED |
| 446 | 28-Dec-18 | GULBARGA | 220 | KUSTAGI-LINGAPUR | LINGAPUR_220 | 8:07 | 19:10 | 11:03 | LINE CLEAR AVAILED |
| 447 | 28-Dec-18 | GULBARGA | 220 | HV1,LV1 | SEDAM_220 | 9:45 | 17:40 | 7:55 | LINE CLEAR AVAILED |
| 448 | 28-Dec-18 | GULBARGA | 220 | SEDAM-RTPS2 | SEDAM_220 | 10:17 | 18:25 | 8:08 | LINE CLEAR AVAILED |
| 449 | 28-Dec-18 | GULBARGA | 220 | SEDAM-SHREE CEMENTS_IPP | SEDAM_220 | 10:10 | 11:58 | 1:48 | LOAD CHANGEOVER |
| 450 | 28-Dec-18 | GULBARGA | 220 | SEDAM-RTPS1 | SEDAM_220 | 10:45 | 11:40 | 0:55 | HAND TRIPPED |
| 451 | 28-Dec-18 | GULBARGA | 220 | HV1 | ITTAGI_220 | 8:42 | 14:00 | 5:18 | LINE CLEAR AVAILED |
| 452 | 28-Dec-18 | GULBARGA | 220 | HV2 | ITTAGI_220 | 10:05 | 10:18 | 0:13 | TRANSFORMER FAULT |
| 453 | 28-Dec-18 | GULBARGA | 220 | HV2 | ITTAGI_220 | 10:38 | 10:45 | 0:07 | TRANSFORMER FAULT |
| 454 | 28-Dec-18 | GULBARGA | 220 | HV2 | ITTAGI_220 | 14:03 | 18:03 | 4:00 | LINE CLEAR AVAILED |
| 455 | 28-Dec-18 | GULBARGA | 110 | HUMNABAD-BIDAR1 | HALLIKHED_110 | 6:52 | 7:03 | 0:11 | LINE FAULT |
| 456 | 28-Dec-18 | GULBARGA | 110 | HALBARGA-ACME SLR | HALBARGA_220 | 11:50 | 12:00 | 0:10 | LINE FAULT |
| 457 | 28-Dec-18 | GULBARGA | 110 | HV1 | RAICHUR_220 | 10:05 | 10:09 | 0:04 | TRANSFORMER FAULT |
| 458 | 28-Dec-18 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 12:22 | 12:33 | 0:11 | LINE FAULT |
| 459 | 28-Dec-18 | GULBARGA | 110 | KAPNOOR-MADIYAL | MADIYAL_110,NSL SUGUR FACTORY,CHOWDAPUR_110 | 20:08 | 20:14 | 0:06 | LINE FAULT |
| 460 | 28-Dec-18 | GULBARGA | 110 | KEMBHAVI-SHAHPUR | KEMBHAVI_110 | 2:10 | 2:15 | 0:05 | LINE FAULT |
| 461 | 28-Dec-18 | GULBARGA | 110 | KEMBHAVI-SHAHPUR | KEMBHAVI_110 | 5:45 | 5:50 | 0:05 | LINE FAULT |
| 462 | 28-Dec-18 | GULBARGA | 110 | KEMBHAVI-SHAHPUR | KEMBHAVI_110 | 6:50 | 7:15 | 0:25 | LINE FAULT |
| 463 | 28-Dec-18 | GULBARGA | 110 | KEMBHAVI-SHAHPUR | KEMBHAVI_110 | 20:45 | 20:50 | 0:05 | LINE FAULT |
| 464 | 28-Dec-18 | GULBARGA | 66 | HV1 | HAMPASAGAR_66 | 3:27 | 3:35 | 0:08 | TRANSFORMER FAULT |
| 465 | 28-Dec-18 | GULBARGA | 66 | HV1 | HAMPASAGAR_66 | 7:47 | 7:51 | 0:04 | TRANSFORMER FAULT |
| 466 | 28-Dec-18 | GULBARGA | 66 | ITTAGI-KUDILIGI1,2 | KUDILIGI-66,KOGALI_66,HANASI_66,CJHALLI_66,BA NVEKAL_66,CHONOR_66,GUDEKOTE_66 ,HOSAHALLI_66 | 10:05 | 10:20 | 0:15 | LINE FAULT |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|----------|---------|--------------------------------|---|---------|-----------|----------|--------------------|
| 467 | 28-Dec-18 | GULBARGA | 66 | ITTAGI-KUDILIGI1,2 | KUDILIGI-66,KOGALI_66,HANASI_66,CJHALLI_66,BA NVEKAL_66,CHONOR_66,GUDEKOTE_66 ,HOSAHALLI_66 | 10:38 | 10:45 | 0:07 | LINE FAULT |
| 468 | 28-Dec-18 | GULBARGA | 66 | ITTAGI-HUVINAHADAGALLI | HUVINAHADAGALLI_66,HOLAGUNDI_66 | 11:00 | 11:28 | 0:28 | LOAD CHANGEOVER |
| 469 | 28-Dec-18 | GULBARGA | 66 | ITTGAI-RENEW SLR1,2 | ITTAGI_220 | 11:05 | 11:35 | 0:30 | LINE FAULT |
| 470 | 28-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 0:00 | 6:19 | 6:19 | LINE CLEAR AVAILED |
| 471 | 28-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 23:04 | 23:59 | 0:55 | LINE CLEAR AVAILED |
| 472 | 28-Dec-18 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 11:03 | 13:09 | 2:06 | LINE CLEAR AVAILED |
| 473 | 28-Dec-18 | HASSAN | 220 | MSEZ-KEMAR-BACHPE2 | MSEZ_220 | 11:02 | 13:09 | 2:07 | NBFC ISSUED |
| 474 | 28-Dec-18 | HASSAN | 110 | KAVOOR-EMAR | KAVOOR_220 | 11:57 | 12:10 | 0:13 | LINE CLEAR AVAILED |
| 475 | 28-Dec-18 | HASSAN | 110 | HV3 | MANIPAL | 9:44 | 10:05 | 0:21 | LINE CLEAR AVAILED |
| 476 | 28-Dec-18 | HASSAN | 110 | MOODAB-GURUPURA | MOODABIDRE_110 | 10:40 | 13:24 | 2:44 | LINE CLEAR AVAILED |
| 477 | 28-Dec-18 | HASSAN | 66 | HV1 | BAGUR_66 | 11:30 | 13:30 | 2:00 | LINE CLEAR AVAILED |
| 478 | 28-Dec-18 | HASSAN | 66 | BYACHAN-HNPURA | BYACHANAHALLI_66 | 12:05 | 12:10 | 0:05 | HAND TRIPPED |
| 479 | 28-Dec-18 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 12:11 | 12:58 | 0:47 | LINE CLEAR AVAILED |
| 480 | 28-Dec-18 | HASSAN | 66 | DODDAKA-KRNAGARA | DODDAKADNUR_66 | 11:39 | 11:48 | 0:09 | HAND TRIPPED |
| 481 | 28-Dec-18 | HASSAN | 66 | HV1 | HOLALUR_66 | 7:00 | 9:53 | 2:53 | LINE CLEAR AVAILED |
| 482 | 28-Dec-18 | MYSORE | 66 | HV2 | DUNDANAHALLI_66 | 15:49 | 15:56 | 0:06 | TRANSFORMER FAULT |
| 483 | 28-Dec-18 | MYSORE | 66 | HV1 | KIADBMANDYA_66 | 9:52 | 10:33 | 0:40 | TRANSFORMER FAULT |
| 484 | 28-Dec-18 | MYSORE | 66 | HV2 | KIADBMANDYA_66 | 9:52 | 10:33 | 0:40 | TRANSFORMER FAULT |
| 485 | 28-Dec-18 | MYSORE | 66 | HV3 | KRPET_66 | 18:32 | 0:00 | 5:27 | TRANSFORMER FAULT |
| 486 | 28-Dec-18 | MYSORE | 66 | HV2 | BGNAGARA_66 | 11:15 | 12:26 | 1:10 | LINE CLEAR AVAILED |
| 487 | 28-Dec-18 | MYSORE | 66 | HV3 | KIKKERI_66 | 11:01 | 11:38 | 0:36 | LINE CLEAR AVAILED |
| 488 | 28-Dec-18 | MYSORE | 66 | HV3 | KRPET_66 | 18:05 | 18:31 | 0:26 | LINE CLEAR AVAILED |
| 489 | 28-Dec-18 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 15:10 | 15:15 | 0:05 | HAND TRIPPED |
| 490 | 28-Dec-18 | MYSORE | 66 | HV1 | DODDARAYAPET_66 | 15:20 | 15:25 | 0:05 | HAND TRIPPED |
| 491 | 28-Dec-18 | MYSORE | 66 | HV2 | DODDARAYAPET_66 | 15:20 | 15:25 | 0:05 | HAND TRIPPED |
| 492 | 28-Dec-18 | MYSORE | 66 | HV1 | HANAGODU_66 | 13:40 | 16:30 | 2:50 | LINE CLEAR AVAILED |
| 493 | 28-Dec-18 | MYSORE | 66 | COWDALLI-MARTHALLI | MARTAHALLI_66,I RAMAPURA_MYS_66 | 18:27 | 18:42 | 0:14 | LINE FAULT |
| 494 | 28-Dec-18 | MYSORE | 66 | HANAGODU-PONNAMPETE | PONNAMPET_66, VIRAJPET_66 | 9:45 | 17:38 | 7:53 | NBFC ISSUED |
| 495 | 28-Dec-18 | MYSORE | 66 | PERIAPATNA-HANAGODU | PONNAMPET_66, VIRAJPET_66 | 9:43 | 17:37 | 7:53 | LINE CLEAR AVAILED |
| 496 | 28-Dec-18 | MYSORE | 66 | PANDAVAPURA-TUBINAKERE | PANDAVAPURA_66 | 10:24 | 14:19 | 3:55 | LINE CLEAR AVAILED |
| 497 | 28-Dec-18 | MYSORE | 66 | PANDAVAPURA-TUBINAKERE | PANDAVAPURA_66 | 15:17 | 17:14 | 1:56 | LINE CLEAR AVAILED |
| 498 | 28-Dec-18 | MYSORE | 66 | DB HALLI-TUBINAKERE | DODDABYADARAHALLI_66 | 12:02 | 13:03 | 1:01 | NBFC ISSUED |
| 499 | 28-Dec-18 | TUMKUR | 110 | KB CROSS 220kV- MAYASANDRA | MAYASANDRA_110, TANDAGA_110, KADEHALLI_110 | 3:34 | 3:54 | 0:20 | LINE FAULT |
| 500 | 28-Dec-18 | TUMKUR | 66 | ANCHEPALYA 220kV- KEMPANAHALLI | KEMPANAHALLI_66, AGALKOTE_66 | 7:45 | 8:02 | 0:16 | LINE FAULT |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|--|--|---------|-----------|----------|---------------------|
| 501 | 28-Dec-18 | TUMKUR | 66 | ANCHEPALYA 220KV- KEMPANAHALLI | KEMPANAHALLI_66, AGALKOTE_66 | 8:11 | 10:56 | 2:45 | LINE FAULT |
| 502 | 28-Dec-18 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 15:39 | 17:31 | 1:52 | LINE FAULT |
| 503 | 28-Dec-18 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- KOLALA (dabaspete) | KOLALA_66, URDIGERE_66 | 12:53 | 17:05 | 4:12 | LINE FAULT |
| 504 | 28-Dec-18 | TUMKUR | 66 | TR-1 | BAGUR_TMK_66 | 9:13 | 9:33 | 0:20 | TRANSFORMER FAULT |
| 505 | 28-Dec-18 | TUMKUR | 66 | TR-2 | BEVINAHALLI_66 | 12:41 | 13:37 | 0:56 | LINE CLEAR AVAILED |
| 506 | 28-Dec-18 | TUMKUR | 66 | CHELLUR-ANTHRASANAHALLI | CHELURU_66 | 15:47 | 17:40 | 1:52 | MAIN SUPPLY FAILURE |
| 507 | 28-Dec-18 | TUMKUR | 66 | TR-2 | CHIKKABANAGERE_66 | 15:19 | 15:54 | 0:35 | HAND TRIPPED |
| 508 | 28-Dec-18 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:34 | 17:46 | 9:12 | LINE CLEAR AVAILED |
| 509 | 28-Dec-18 | TUMKUR | 66 | TR-2 | HULIYURDURGA_66 | 10:49 | 12:23 | 1:33 | LINE CLEAR AVAILED |
| 510 | 28-Dec-18 | TUMKUR | 66 | I D HALLI- CLEAN MAX SOLAR | CLEANMAXSOLAR_IPP_66 | 10:07 | 16:05 | 5:58 | LINE CLEAR AVAILED |
| 511 | 28-Dec-18 | TUMKUR | 66 | TR-1 & TR-2 | IDHALLY_66 | 10:07 | 16:01 | 5:54 | LINE CLEAR AVAILED |
| 512 | 28-Dec-18 | TUMKUR | 66 | I D HALLI- KODIGENAHALLI | KODIGENAHALLI_66 | 10:07 | 17:01 | 6:54 | LINE CLEAR AVAILED |
| 513 | 28-Dec-18 | TUMKUR | 66 | KATTIGE- RENEW WIND IPP | RENEW WIND ENERGY_IPP_66 | 19:21 | 21:17 | 1:55 | LINE CLEAR AVAILED |
| 514 | 28-Dec-18 | TUMKUR | 66 | KEMPANAHALLI - AGALAKOTE | AGALKOTE_66 | 11:18 | 11:21 | 0:02 | HAND TRIPPED |
| 515 | 28-Dec-18 | TUMKUR | 66 | TR-1 | RAMPURA_66 | 8:22 | 8:33 | 0:11 | TRANSFORMER FAULT |
| 516 | 28-Dec-18 | TUMKUR | 66 | TR-1 | YNHOSKOTE_66 | 14:45 | 14:47 | 0:02 | TRANSFORMER FAULT |
| 517 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | ANAND NAGAR_110 | 16:03 | 16:28 | 0:25 | LINE CLEAR AVAILED |
| 518 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV, HV1 | HATTARGI_110 | 12:11 | 12:52 | 0:41 | LINE CLEAR AVAILED |
| 519 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2A | JAMKHANDI_110 | 11:57 | 12:05 | 0:08 | LINE CLEAR AVAILED |
| 520 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2A | JAMKHANDI_110 | 12:15 | 12:22 | 0:07 | LINE CLEAR AVAILED |
| 521 | 29-Dec-18 | BAGALKOT | 220 | 220/110KV, HV1&LV1 | KUDACHI_220 | 0:34 | 0:53 | 0:19 | TRANSFORMER FAULT |
| 522 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2 | KULIGOD_110 | 23:09 | 23:15 | 0:06 | TRANSFORMER FAULT |
| 523 | 29-Dec-18 | BAGALKOT | 110 | KNI SOLAR-ATHARGA | ATHARGA_110 | 20:50 | 22:35 | 1:45 | LINE FAULT |
| 524 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2 | MUNAVALLY_110 | 14:08 | 14:55 | 0:47 | LINE CLEAR AVAILED |
| 525 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | YELLAPARAHATTI_110 | 15:09 | 15:29 | 0:20 | HAND TRIPPED |
| 526 | 29-Dec-18 | BAGALKOT | 110 | SOUDATTI220-MUNAVALLI | MUNAVALLI_110 | 12:03 | 13:04 | 1:01 | LINE CLEAR AVAILED |
| 527 | 29-Dec-18 | BAGALKOT | 110 | JOG1&2-SIRSI | SIRSI_110 | 10:09 | 18:18 | 8:09 | LINE CLEAR AVAILED |
| 528 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | SIDDAPUR_110 | 10:19 | 18:35 | 8:16 | LINE CLEAR AVAILED |
| 529 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | RAIBAG_110 | 11:02 | 16:36 | 5:34 | LINE CLEAR AVAILED |
| 530 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV,HV3 | RAIBAG_110 | 11:02 | 16:31 | 5:29 | LINE CLEAR AVAILED |
| 531 | 29-Dec-18 | BAGALKOT | 110 | CHIKKODI220-RAIBAG | RAIBAG_110 | 11:02 | 16:37 | 5:35 | LINE CLEAR AVAILED |
| 532 | 29-Dec-18 | BAGALKOT | 110 | P G HUNSYAL-MUDALGI | MUDALGI_110 | 0:08 | 0:22 | 0:14 | LINE FAULT |
| 533 | 29-Dec-18 | BAGALKOT | 110 | SATI SUGARS-MUDALGI | MUDALGI_110 | 0:08 | 0:23 | 0:15 | HAND TRIPPED |
| 534 | 29-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | NAVANAGAR(H) | 12:20 | 14:46 | 2:26 | TRANSFORMER FAULT |
| 535 | 29-Dec-18 | BAGALKOT | 110 | 110/33KV,HV2 | MUNDARGI_110,SINGATALUR_33 | 10:56 | 12:52 | 1:56 | HAND TRIPPED |
| 536 | 29-Dec-18 | BANGALORE | 66 | HV1 | ANDERSONPET | 17:34 | 18:27 | 0:52 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|----------------------------------|--|---------|-----------|----------|---------------------|
| 537 | 29-Dec-18 | BANGALORE | 66 | HV2 | ANDERSONPET | 17:40 | 18:27 | 0:47 | LINE CLEAR AVAILED |
| 538 | 29-Dec-18 | BANGALORE | 66 | CHINTAMANI 220- GANJIGUNTE 1 & 2 | GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI | 12:05 | 13:03 | 0:57 | LINE CLEAR AVAILED |
| 539 | 29-Dec-18 | BANGALORE | 66 | HBR LAYOUT - HOSKOTE 220 | HBR LAYOUT | 11:43 | 11:53 | 0:10 | LOAD CHANGEOVER |
| 540 | 29-Dec-18 | BANGALORE | 66 | HV1 | KEMBODI | 14:08 | 14:20 | 0:12 | TRANSFORMER FAULT |
| 541 | 29-Dec-18 | BANGALORE | 66 | HV1 | NANGALI | 12:12 | 12:51 | 0:39 | LINE CLEAR AVAILED |
| 542 | 29-Dec-18 | BANGALORE | 66 | ABBIGERE - ATTUR YELAHANKA | ABBIGERE | 12:37 | 13:17 | 0:40 | MAIN SUPPLY FAILURE |
| 543 | 29-Dec-18 | BANGALORE | 66 | ADUGODI - HSR LAYOUT 1 | ADUGODI, BOSCH (EHT) | 4:18 | 4:40 | 0:22 | LINE FAULT |
| 544 | 29-Dec-18 | BANGALORE | 66 | ADUGODI - HSR LAYOUT 1 & 2 | ADUGODI, BOSCH (EHT) | 9:33 | 10:19 | 0:46 | LINE FAULT |
| 545 | 29-Dec-18 | BANGALORE | 66 | ADUGODI - NIMHANS 220 | ADUGODI, BOSCH (EHT) | 10:20 | 10:27 | 0:07 | LINE CLEAR AVAILED |
| 546 | 29-Dec-18 | BANGALORE | 66 | ADUGODI - NIMHANS 220 | ADUGODI, BOSCH (EHT) | 10:30 | 10:55 | 0:25 | LINE CLEAR AVAILED |
| 547 | 29-Dec-18 | BANGALORE | 66 | APERAL PARK - KIADB DB PURA 220 | APERAL PARK | 13:10 | 13:15 | 0:05 | LOAD CHANGEOVER |
| 548 | 29-Dec-18 | BANGALORE | 66 | APERAL PARK - DB PURA 220 | APERAL PARK | 14:10 | 14:40 | 0:30 | LOAD CHANGEOVER |
| 549 | 29-Dec-18 | BANGALORE | 66 | HV1 | GOLF LINK | 12:51 | 13:06 | 0:15 | LINE CLEAR AVAILED |
| 550 | 29-Dec-18 | BANGALORE | 220 | HV2 | HSR LAYOUT 220 | 4:18 | 4:31 | 0:13 | TRANSFORMER FAULT |
| 551 | 29-Dec-18 | BANGALORE | 66 | HSR LAYOUT 220 - ADUGODI 1 | ADUGODI, BOSCH (EHT) | 4:18 | 9:33 | 5:15 | LINE FAULT |
| 552 | 29-Dec-18 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA | 10:44 | 10:50 | 0:06 | LINE FAULT |
| 553 | 29-Dec-18 | BANGALORE | 66 | HV2 | NALLIMARADANAHALLI | 16:28 | 16:54 | 0:26 | TRANSFORMER FAULT |
| 554 | 29-Dec-18 | GULBARGA | 220 | KUSTAGI-LINGAPUR | KUSTAGI_220 | 7:12 | 18:09 | 10:57 | LINE CLEAR AVAILED |
| 555 | 29-Dec-18 | GULBARGA | 110 | HUMNABAD-BIDAR1 | HALIKHED_110 | 12:08 | 12:12 | 0:04 | LINE CLEAR AVAILED |
| 556 | 29-Dec-18 | HASSAN | 400 | UPCL-HASSAN1 | UPCL_GEN | 0:00 | 7:35 | 7:35 | LINE CLEAR AVAILED |
| 557 | 29-Dec-18 | HASSAN | 400 | UPCL-HASSAN2 | UPCL_GEN | 21:37 | 23:59 | 2:22 | LINE CLEAR AVAILED |
| 558 | 29-Dec-18 | HASSAN | 220 | HV1 | HASSAN_220 | 14:27 | 14:50 | 0:23 | MAIN SUPPLY FAILURE |
| 559 | 29-Dec-18 | HASSAN | 220 | HASSN22-SHANTHIGRAMA | HASSAN_220 | 8:34 | 16:12 | 7:38 | LINE CLEAR AVAILED |
| 560 | 29-Dec-18 | HASSAN | 66 | HASSN22-ARAKALGUD | HASSAN_220 | 14:30 | 14:53 | 0:23 | HAND TRIPPED |
| 561 | 29-Dec-18 | HASSAN | 66 | HASSN22-HN PURA | HASSAN_220 | 14:27 | 14:54 | 0:27 | HAND TRIPPED |
| 562 | 29-Dec-18 | HASSAN | 66 | HASSN22-HSN66 | HASSAN_220 | 14:31 | 14:42 | 0:11 | HAND TRIPPED |
| 563 | 29-Dec-18 | HASSAN | 66 | LV1 | HASSAN_220 | 14:27 | 14:51 | 0:24 | HAND TRIPPED |
| 564 | 29-Dec-18 | HASSAN | 66 | HASSN22-MALLALI | HASSAN_220 | 14:27 | 15:22 | 0:55 | HAND TRIPPED |
| 565 | 29-Dec-18 | HASSAN | 66 | HASSN22-R R NAGAR | HASSAN_220 | 14:27 | 14:54 | 0:27 | HAND TRIPPED |
| 566 | 29-Dec-18 | HASSAN | 66 | HASSN22-SKPURA | HASSAN_220 | 14:31 | 14:55 | 0:24 | HAND TRIPPED |
| 567 | 29-Dec-18 | HASSAN | 66 | HASSN22-UDDURKOPLU | HASSAN_220 | 14:31 | 14:41 | 0:10 | HAND TRIPPED |
| 568 | 29-Dec-18 | HASSAN | 220 | HV1 | KEMAR_220 | 9:43 | 10:28 | 0:45 | LINE CLEAR AVAILED |
| 569 | 29-Dec-18 | HASSAN | 220 | HV1 | KEMAR_220 | 10:57 | 11:29 | 0:32 | TRANSFORMER FAULT |
| 570 | 29-Dec-18 | HASSAN | 220 | KEMAR-Varahi3 | KEMAR_220 | 9:36 | 10:27 | 0:51 | LINE CLEAR AVAILED |
| 571 | 29-Dec-18 | HASSAN | 110 | LV1 | KEMAR_220 | 9:43 | 10:29 | 0:46 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|---------|---------|------------------|---|---------|-----------|----------|---------------------|
| 572 | 29-Dec-18 | HASSAN | 110 | LV1 | KEMAR_220 | 10:57 | 11:29 | 0:32 | TRANSFORMER FAULT |
| 573 | 29-Dec-18 | HASSAN | 110 | KEMAR-Manipal1 | KEMAR_220 | 9:16 | 10:29 | 1:13 | LINE CLEAR AVAILED |
| 574 | 29-Dec-18 | HASSAN | 110 | KEMAR-Manipal1 | KEMAR_220 | 11:07 | 11:30 | 0:23 | LINE CLEAR AVAILED |
| 575 | 29-Dec-18 | HASSAN | 110 | KEMAR-Manipal2 | KEMAR_220 | 9:16 | 10:29 | 1:13 | LINE CLEAR AVAILED |
| 576 | 29-Dec-18 | HASSAN | 110 | KEMAR-Manipal2 | KEMAR_220 | 11:07 | 11:31 | 0:24 | LINE CLEAR AVAILED |
| 577 | 29-Dec-18 | HASSAN | 66 | MRSSHM-HOLUR | MRSMSG_220 | 11:08 | 11:34 | 0:26 | LINE FAULT |
| 578 | 29-Dec-18 | HASSAN | 220 | VARAHI-KEMAR3 | VARAHI_GEN | 9:36 | 10:27 | 0:51 | LINE CLEAR AVAILED |
| 579 | 29-Dec-18 | HASSAN | 220 | VARAHI-KEMAR3 | VARAHI_GEN | 10:57 | 11:40 | 0:43 | LINE CLEAR AVAILED |
| 580 | 29-Dec-18 | HASSAN | 110 | HV2 | BAIKAMPADY_110 | 11:14 | 23:37 | 12:23 | TRANSFORMER FAULT |
| 581 | 29-Dec-18 | HASSAN | 110 | HV1 | KITTADAHALLI_110 | 11:09 | 12:29 | 1:20 | LINE CLEAR AVAILED |
| 582 | 29-Dec-18 | HASSAN | 110 | MANIPAL-BRAMVR | MANIPAL_110 | 8:27 | 17:51 | 9:24 | LINE CLEAR AVAILED |
| 583 | 29-Dec-18 | HASSAN | 110 | MOODAB-KEMAR | MOODABISDRE_110 | 9:35 | 13:00 | 3:25 | LINE CLEAR AVAILED |
| 584 | 29-Dec-18 | HASSAN | 110 | HV1 | SHIRALKOPPA_220 | 10:35 | 15:38 | 5:03 | LINE CLEAR AVAILED |
| 585 | 29-Dec-18 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 7:08 | 18:51 | 11:43 | LINE CLEAR AVAILED |
| 586 | 29-Dec-18 | HASSAN | 66 | ARAKA-MALLIPATNA | ARAKALGUD_66 | 8:40 | 11:55 | 3:15 | LINE CLEAR AVAILED |
| 587 | 29-Dec-18 | HASSAN | 66 | GORUR-ARAKALGUD | GORUR_66 | 8:41 | 11:15 | 2:34 | LINE CLEAR AVAILED |
| 588 | 29-Dec-18 | HASSAN | 66 | HV1 | HARIHARPURA_66 | 16:28 | 16:58 | 0:30 | LINE CLEAR AVAILED |
| 589 | 29-Dec-18 | HASSAN | 66 | HV2 | KANDLI_66 | 14:38 | 14:56 | 0:18 | MAIN SUPPLY FAILURE |
| 590 | 29-Dec-18 | HASSAN | 66 | HV1 | KUDLIGERE_66 | 13:29 | 13:59 | 0:30 | LINE CLEAR AVAILED |
| 591 | 29-Dec-18 | MYSORE | 66 | HV1 | CHINAKURALI_66 | 10:45 | 15:19 | 4:34 | LINE CLEAR AVAILED |
| 592 | 29-Dec-18 | MYSORE | 66 | HV2 | CHINAKURALI_66 | 10:45 | 15:19 | 4:34 | LINE CLEAR AVAILED |
| 593 | 29-Dec-18 | MYSORE | 66 | HV1 | CHUNCHUNKATTE_66 | 12:57 | 13:08 | 0:11 | HAND TRIPPED |
| 594 | 29-Dec-18 | MYSORE | 66 | DR PETE-KUNTHUR | SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 | 7:02 | 7:19 | 0:16 | LINE FAULT |
| 595 | 29-Dec-18 | MYSORE | 66 | HV1 | DODDABYADARAHALLI_66 | 11:21 | 16:46 | 5:24 | LINE CLEAR AVAILED |
| 596 | 29-Dec-18 | MYSORE | 66 | HV2 | HAMPAPURA_66 | 7:58 | 8:02 | 0:03 | TRANSFORMER FAULT |
| 597 | 29-Dec-18 | MYSORE | 66 | HOOTAGALLI-BEML | HEBBAL-INDUSTRIAL_66 | 10:02 | 12:49 | 2:47 | LINE CLEAR AVAILED |
| 598 | 29-Dec-18 | MYSORE | 66 | HV1 | MADIKERI_66 | 10:21 | 17:07 | 6:45 | LINE CLEAR AVAILED |
| 599 | 29-Dec-18 | MYSORE | 66 | MANDYA-HAMPAPURA | CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 | 8:31 | 8:40 | 0:08 | LINE FAULT |
| 600 | 29-Dec-18 | MYSORE | 66 | MANDYA-HAMPAPURA | CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 | 12:38 | 12:44 | 0:05 | LINE FAULT |
| 601 | 29-Dec-18 | MYSORE | 66 | MEGALAPURA-SFC | THUMBLA_66 BGPURA_66 CHIDRAVALLI_66 | 12:47 | 12:54 | 0:06 | LINE FAULT |
| 602 | 29-Dec-18 | MYSORE | 66 | HV1 | NAGAMANGALA_66 | 18:18 | 18:48 | 0:29 | LINE CLEAR AVAILED |
| 603 | 29-Dec-18 | MYSORE | 66 | HV2 | NAGAMANGALA_66 | 18:18 | 18:48 | 0:29 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|---------|---------|----------------------------|---|---------|-----------|----------|--------------------|
| 604 | 29-Dec-18 | MYSORE | 66 | HV1 | SANIVARASANTHE_66 | 8:47 | 15:14 | 6:27 | LINE CLEAR AVAILED |
| 605 | 29-Dec-18 | MYSORE | 66 | SHANIVARASANTHE-MALLIPATNA | SANIVARASANTHE_66 | 8:47 | 13:43 | 4:56 | LINE CLEAR AVAILED |
| 606 | 29-Dec-18 | MYSORE | 66 | SHANIVARASANTHE-YESSLUR | YESSLUR | 8:47 | 15:22 | 6:34 | LINE CLEAR AVAILED |
| 607 | 29-Dec-18 | MYSORE | 66 | TUBINAKERE-ARAKERE | ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 | 8:31 | 9:02 | 0:30 | HAND TRIPPED |
| 608 | 29-Dec-18 | MYSORE | 66 | TUBINAKERE-G UKKADA | ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 | 8:31 | 9:13 | 0:41 | HAND TRIPPED |
| 609 | 29-Dec-18 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 | 8:31 | 9:03 | 0:31 | HAND TRIPPED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|---------|---------|--|---|---------|-----------|----------|---------------------|
| 610 | 29-Dec-18 | MYSORE | 66 | TUBINAKERE-PANDAVAPURA | ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 | 8:31 | 9:13 | 0:42 | HAND TRIPPED |
| 611 | 29-Dec-18 | MYSORE | 66 | HV2 | TUBINAKERE_220 | 8:41 | 9:04 | 0:22 | HAND TRIPPED |
| 612 | 29-Dec-18 | MYSORE | 220 | HV2 | TUBINAKERE_220 | 8:27 | 8:59 | 0:32 | TRANSFORMER FAULT |
| 613 | 29-Dec-18 | MYSORE | 66 | HV1 | VAJAMANGALA_220 | 11:04 | 11:11 | 0:06 | HAND TRIPPED |
| 614 | 29-Dec-18 | MYSORE | 66 | VAJAMANGALA-KADAKOLA 1 | AYRALLI_66 MARADIHUNDI_66 | 10:18 | 10:23 | 0:04 | HAND TRIPPED |
| 615 | 29-Dec-18 | TUMKUR | 220 | TR-1(HV SIDE) | CHITRADURGA_220 | 18:31 | 19:07 | 0:35 | TRANSFORMER FAULT |
| 616 | 29-Dec-18 | TUMKUR | 110 | TR3 | AMMASANDRA_110 | 6:50 | 7:14 | 0:24 | TRANSFORMER FAULT |
| 617 | 29-Dec-18 | TUMKUR | 110 | TR3 | AMMASANDRA_110 | 18:07 | 18:10 | 0:02 | HAND TRIPPED |
| 618 | 29-Dec-18 | TUMKUR | 110 | KADEHALLI- KB CROSS | KADEHALLI_110 | 16:22 | 16:27 | 0:04 | LINE CLEAR AVAILED |
| 619 | 29-Dec-18 | TUMKUR | 110 | DODDAGUNI- SAMPIGE | SAMPIGE_110 | 9:32 | 17:55 | 8:23 | LINE CLEAR AVAILED |
| 620 | 29-Dec-18 | TUMKUR | 66 | TR-1(LV SIDE) | CHITRADURGA_220 | 18:31 | 19:08 | 0:36 | TRANSFORMER FAULT |
| 621 | 29-Dec-18 | TUMKUR | 110 | NITTUR 220kV- AMMASANDRA | AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110 | 9:03 | 18:00 | 8:57 | LINE CLEAR AVAILED |
| 622 | 29-Dec-18 | TUMKUR | 110 | TR-2 | NITTUR_220 | 21:10 | 21:31 | 0:20 | LINE CLEAR AVAILED |
| 623 | 29-Dec-18 | TUMKUR | 110 | SAMPIGE- DODDAGUNI | SAMPIGE_110 | 9:05 | 18:06 | 9:01 | MAIN SUPPLY FAILURE |
| 624 | 29-Dec-18 | TUMKUR | 110 | TR-1 & TR-2 | SAMPIGE_110 | 9:05 | 18:06 | 9:01 | MAIN SUPPLY FAILURE |
| 625 | 29-Dec-18 | TUMKUR | 110 | SAMPIGE- RENEWIND_IPP | RENEW_WIND_IPP_110 | 9:05 | 18:15 | 9:09 | MAIN SUPPLY FAILURE |
| 626 | 29-Dec-18 | TUMKUR | 66 | BALENAHALLI-CHALKERE | BALENAHALLI_66 | 16:32 | 17:26 | 0:54 | LINE CLEAR AVAILED |
| 627 | 29-Dec-18 | TUMKUR | 66 | TR-2 | BALENAHALLI_66 | 16:32 | 17:16 | 0:43 | LINE CLEAR AVAILED |
| 628 | 29-Dec-18 | TUMKUR | 66 | CHITRADURGA 66kV- PANDARAHALLI 2 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 19:13 | 19:16 | 0:03 | MAIN SUPPLY FAILURE |
| 629 | 29-Dec-18 | TUMKUR | 66 | TR-2 | DAVANAGERE_66 | 10:47 | 10:53 | 0:05 | TRANSFORMER FAULT |
| 630 | 29-Dec-18 | TUMKUR | 66 | DAVANGERE SRS- GUTTUR66 | GUTTUR_66 | 23:46 | 23:56 | 0:10 | LINE FAULT |
| 631 | 29-Dec-18 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:59 | 17:44 | 8:44 | LINE CLEAR AVAILED |
| 632 | 29-Dec-18 | TUMKUR | 66 | TR-1 | HALUVAGALU_66 | 12:18 | 13:00 | 0:42 | TRANSFORMER FAULT |
| 633 | 29-Dec-18 | TUMKUR | 66 | TR-1 | HANAGAL_66 | 10:14 | 11:58 | 1:43 | LINE CLEAR AVAILED |
| 634 | 29-Dec-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-1 | ENERCON1_IPP_66 | 12:30 | 13:03 | 0:33 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|------------------------------|---|---------|-----------|----------|--------------------|
| 635 | 29-Dec-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-2 | ENERCON1_IPP_66 | 12:30 | 13:03 | 0:33 | LINE CLEAR AVAILED |
| 636 | 29-Dec-18 | TUMKUR | 66 | HIRIYUR 220KV- RKP 1 | RKP1_IPP_66 | 12:29 | 13:05 | 0:35 | LINE CLEAR AVAILED |
| 637 | 29-Dec-18 | TUMKUR | 66 | HIRIYUR 220KV- RKP2 | RKP2_IPP_66 | 12:29 | 13:05 | 0:35 | LINE CLEAR AVAILED |
| 638 | 29-Dec-18 | TUMKUR | 66 | TR-1 | HOLALKERE_66 | 16:55 | 18:08 | 1:13 | LINE CLEAR AVAILED |
| 639 | 29-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 10:18 | 11:03 | 0:44 | HAND TRIPPED |
| 640 | 29-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 11:32 | 11:53 | 0:20 | HAND TRIPPED |
| 641 | 29-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 12:52 | 12:55 | 0:02 | HAND TRIPPED |
| 642 | 29-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 19:19 | 19:35 | 0:15 | HAND TRIPPED |
| 643 | 29-Dec-18 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 4:47 | 4:59 | 0:12 | LINE FAULT |
| 644 | 29-Dec-18 | TUMKUR | 66 | TR-2 | HONNUDIKE_66 | 12:13 | 12:17 | 0:04 | TRANSFORMER FAULT |
| 645 | 29-Dec-18 | TUMKUR | 66 | JAVAGONDANAHALLI- INFOSYS-1 | INFOSYS1_EHT_66 | 10:11 | 10:15 | 0:04 | LINE FAULT |
| 646 | 29-Dec-18 | TUMKUR | 66 | TR-1 | KATTIGE_66 | 6:51 | 11:19 | 4:27 | TRANSFORMER FAULT |
| 647 | 29-Dec-18 | TUMKUR | 66 | KUKKAWADA- LINGADAHALLI | TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 14:15 | 14:25 | 0:09 | LINE FAULT |
| 648 | 29-Dec-18 | TUMKUR | 66 | TR-2 | KUKKAWADA_66 | 12:29 | 13:38 | 1:09 | LINE CLEAR AVAILED |
| 649 | 29-Dec-18 | TUMKUR | 66 | NAGASAMUDRA- IPP_SOLAR | WELSPUN_IPP_SOLAR_66 | 11:41 | 13:21 | 1:39 | LINE FAULT |
| 650 | 29-Dec-18 | TUMKUR | 66 | TR-1 | NYAMATHI_66 | 15:07 | 15:53 | 0:46 | LINE CLEAR AVAILED |
| 651 | 30-Dec-18 | BAGALKOT | 110 | BAGEWADI220-MAMDAPUR1&2 | MAMDAPUR_110 | 6:31 | 6:47 | 0:16 | LINE FAULT |
| 652 | 30-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2 | GUTTAL_110 | 8:25 | 8:46 | 0:21 | TRANSFORMER FAULT |
| 653 | 30-Dec-18 | BAGALKOT | 110 | ITANAL-RAIBAG1&2 | RAIBAG_110 | 12:05 | 16:07 | 4:02 | LINE CLEAR AVAILED |
| 654 | 30-Dec-18 | BAGALKOT | 110 | 110/11KV, HV3 | JAMKHANDI_110 | 12:16 | 12:47 | 0:31 | LINE CLEAR AVAILED |
| 655 | 30-Dec-18 | BAGALKOT | 220 | CHIKKODI-BELGAUM1 | CHIKKODI_220 | 21:44 | 23:59 | 2:15 | HAND TRIPPED |
| 656 | 30-Dec-18 | BAGALKOT | 110 | KUMATA-SIRSI1 | SIRSI_110 | 0:00 | 9:39 | 9:39 | LINE CLEAR AVAILED |
| 657 | 30-Dec-18 | BAGALKOT | 110 | 110/11KV, HV2 | MUNAVALLY_110 | 8:52 | 9:10 | 0:18 | TRANSFORMER FAULT |
| 658 | 30-Dec-18 | BAGALKOT | 110 | KONNUR-NAVALGUND | NAVALGUND_110 | 0:00 | 10:20 | 10:20 | LINE CLEAR AVAILED |
| 659 | 30-Dec-18 | BAGALKOT | 110 | MANALI SUGARS-MALGHAN(S) | MALAGHAN(S)_110 | 6:50 | 6:51 | 0:01 | LINE FAULT |
| 660 | 30-Dec-18 | BAGALKOT | 110 | 110/11KV,HV1 | MALAGHAN(B)_110 | 22:05 | 22:08 | 0:03 | TRANSFORMER FAULT |
| 661 | 30-Dec-18 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 11:11 | 11:17 | 0:06 | LINE FAULT |
| 662 | 30-Dec-18 | BANGALORE | 66 | CHINTAMANI 220 - LAKSHMIPURA | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI | 18:47 | 18:53 | 0:05 | LINE FAULT |
| 663 | 30-Dec-18 | BANGALORE | 66 | A STATION 220 - A STATION 1 | A STATION 66 | 5:45 | 5:46 | 0:01 | LOAD CHANGEOVER |
| 664 | 30-Dec-18 | BANGALORE | 66 | HV1 | HOODY 220 | 18:35 | 22:45 | 4:10 | TRANSFORMER FAULT |
| 665 | 30-Dec-18 | BANGALORE | 66 | HV1 | HOODY 220 | 22:45 | 23:30 | 0:45 | TRANSFORMER FAULT |
| 666 | 30-Dec-18 | BANGALORE | 66 | HV1 | ISRO LAYOUT | 14:31 | 14:36 | 0:05 | LOAD CHANGEOVER |
| 667 | 30-Dec-18 | BANGALORE | 66 | HV2 | ISRO LAYOUT | 12:17 | 12:20 | 0:03 | LOAD CHANGEOVER |
| 668 | 30-Dec-18 | BANGALORE | 66 | HV1 | NANDINI LAYOUT | 7:36 | 7:40 | 0:04 | LOAD CHANGEOVER |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|----------------------------|--|---------|-----------|----------|--------------------|
| 669 | 30-Dec-18 | BANGALORE | 66 | TK HALLI 220 - HAROHALLI 2 | INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI | 12:38 | 13:41 | 1:03 | LINE CLEAR AVAILED |
| 670 | 30-Dec-18 | BANGALORE | 66 | VR DODDI - TK HALLI 220 | VR DODDI | 12:14 | 12:20 | 0:06 | LOAD CHANGEOVER |
| 671 | 30-Dec-18 | BANGALORE | 66 | VR DODDI - SOMANAHALLI 220 | VR DODDI | 13:30 | 13:35 | 0:05 | LOAD CHANGEOVER |
| 672 | 30-Dec-18 | GULBARGA | 220 | KUSTAGI-LINGAPUR | KUSTAGI_220 | 6:53 | 16:48 | 9:55 | NBFC ISSUED |
| 673 | 30-Dec-18 | GULBARGA | 220 | HV2 | RAICHUR_220 | 16:44 | 16:57 | 0:13 | LINE CLEAR AVAILED |
| 674 | 30-Dec-18 | GULBARGA | 220 | HV1 | RAICHUR_220 | 16:43 | 17:04 | 0:21 | LINE CLEAR AVAILED |
| 675 | 30-Dec-18 | GULBARGA | 110 | KAPNOOR-HUMNABAD2 | ALAND_110,KADAGANCHI_110 | 19:58 | 20:09 | 0:11 | LINE FAULT |
| 676 | 30-Dec-18 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 11:45 | 11:56 | 0:11 | LINE FAULT |
| 677 | 30-Dec-18 | GULBARGA | 110 | RAICHUR-SHABAD2 | GOOGAL_110 | 1:47 | 2:34 | 0:47 | LINE FAULT |
| 678 | 30-Dec-18 | GULBARGA | 110 | RAICHUR-SHABAD2 | GOOGAL_110 | 20:50 | 20:55 | 0:05 | LINE FAULT |
| 679 | 30-Dec-18 | GULBARGA | 110 | RAICHUR-SHABAD2 | GOOGAL_110 | 19:20 | 19:26 | 0:06 | LINE FAULT |
| 680 | 30-Dec-18 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWARTEMPLE_110 | 10:55 | 14:00 | 3:05 | LINE CLEAR AVAILED |
| 681 | 30-Dec-18 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 10:52 | 13:40 | 2:48 | LINE CLEAR AVAILED |
| 682 | 30-Dec-18 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 1:13 | 7:39 | 6:26 | LINE CLEAR AVAILED |
| 683 | 30-Dec-18 | HASSAN | 400 | UPCL-HASSAN2 | UPCL_GEN | 0:00 | 7:24 | 7:24 | LINE CLEAR AVAILED |
| 684 | 30-Dec-18 | HASSAN | 400 | UPCL-HASSAN2 | UPCL_GEN | 21:37 | 23:59 | 2:22 | LINE CLEAR AVAILED |
| 685 | 30-Dec-18 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 11:54 | 17:10 | 5:16 | LINE FAULT |
| 686 | 30-Dec-18 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 17:56 | 19:48 | 1:52 | LINE CLEAR AVAILED |
| 687 | 30-Dec-18 | HASSAN | 220 | SHRAVTY-SHIMOGA1 | SHARAVATHY_GEN | 11:54 | 19:48 | 7:54 | LINE FAULT |
| 688 | 30-Dec-18 | HASSAN | 110 | HV2 | GANDASI_110 | 12:48 | 13:06 | 0:18 | TRANSFORMER FAULT |
| 689 | 30-Dec-18 | HASSAN | 110 | HV1 | KONAJE_110 | 8:44 | 8:50 | 0:06 | HAND TRIPPED |
| 690 | 30-Dec-18 | HASSAN | 110 | HV1 | KONAJE_110 | 15:10 | 15:13 | 0:03 | HAND TRIPPED |
| 691 | 30-Dec-18 | HASSAN | 110 | HV2 | KONAJE_110 | 8:44 | 8:48 | 0:04 | HAND TRIPPED |
| 692 | 30-Dec-18 | HASSAN | 110 | HV2 | KONAJE_110 | 15:09 | 15:13 | 0:04 | HAND TRIPPED |
| 693 | 30-Dec-18 | HASSAN | 110 | HV3 | KONAJE_110 | 8:44 | 8:48 | 0:04 | HAND TRIPPED |
| 694 | 30-Dec-18 | HASSAN | 110 | HV3 | KONAJE_110 | 15:10 | 15:13 | 0:03 | HAND TRIPPED |
| 695 | 30-Dec-18 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 0:48 | 0:53 | 0:05 | LINE FAULT |
| 696 | 30-Dec-18 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 5:10 | 6:00 | 0:50 | LINE FAULT |
| 697 | 30-Dec-18 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 6:17 | 14:11 | 7:54 | LINE FAULT |
| 698 | 30-Dec-18 | HASSAN | 66 | BHADRA-LINGADAHALLI | BHADRA_GEN | 13:10 | 13:19 | 0:09 | LINE FAULT |
| 699 | 30-Dec-18 | MYSORE | 66 | HV2 | THALAKADU_66 | 16:26 | 16:37 | 0:11 | HAND TRIPPED |
| 700 | 30-Dec-18 | MYSORE | 66 | HV1 | THALAKADU_66 | 16:26 | 16:37 | 0:11 | HAND TRIPPED |
| 701 | 30-Dec-18 | MYSORE | 66 | TUBINAKERE-NAGAMANGALA 2 | SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 | 13:01 | 15:47 | 2:45 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|----------|---------|--|--|---------|-----------|----------|--------------------|
| 702 | 30-Dec-18 | MYSORE | 66 | COWDALLI-MARTHALLI | MARTAHALLI_66 RAMAPURA_MYS_66 | 17:34 | 17:48 | 0:13 | LINE FAULT |
| 703 | 30-Dec-18 | TUMKUR | 110 | CHIKKANAYAKANAHALLI-HULIYAR | SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110 | 6:34 | 7:27 | 0:53 | LINE FAULT |
| 704 | 30-Dec-18 | TUMKUR | 110 | CHIKKANAYAKANAHALLI- K B CROSS | CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110 | 6:34 | 7:12 | 0:38 | LINE FAULT |
| 705 | 30-Dec-18 | TUMKUR | 110 | KB CROSS 220KV- CHIKKANAYAKANAHALLI | CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110 | 6:34 | 7:11 | 0:36 | LINE FAULT |
| 706 | 30-Dec-18 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 11:54 | 11:58 | 0:03 | TRANSFORMER FAULT |
| 707 | 30-Dec-18 | TUMKUR | 66 | DAVANGERE SRS- GUTTUR66 | GUTTUR_66 | 3:25 | 3:40 | 0:14 | LINE FAULT |
| 708 | 30-Dec-18 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:11 | 17:35 | 9:23 | LINE CLEAR AVAILED |
| 709 | 30-Dec-18 | TUMKUR | 66 | TR-1 | KATTIGE_66 | 2:04 | 2:13 | 0:09 | TRANSFORMER FAULT |
| 710 | 30-Dec-18 | TUMKUR | 66 | YEDIYUR- BG NAGARA | BGNAGARA_66 | 13:11 | 15:50 | 2:39 | HAND TRIPPED |
| 711 | 30-Dec-18 | TUMKUR | 66 | TR-1 | YNHOSKOTE_66 | 6:40 | 6:46 | 0:05 | TRANSFORMER FAULT |
| 712 | 31-Dec-18 | BAGALKOT | 66 | 66/33KV,HV3 | HARIHAR HOSPET_66,MUDENUR_33 | 6:25 | 14:49 | 8:24 | TRANSFORMER FAULT |
| 713 | 31-Dec-18 | BAGALKOT | 110 | P G HUNSYAL-MUDALGI | MUDALGI_110 | 0:08 | 0:22 | 0:14 | LINE FAULT |
| 714 | 31-Dec-18 | BAGALKOT | 110 | SATI SUGARS-P G HUNSYAL | P G HUNSYAL_110 | 0:08 | 0:23 | 0:15 | HAND TRIPPED |
| 715 | 31-Dec-18 | BAGALKOT | 110 | 110/33KV,HV3 | MUNAVALLI_110,MUNAVALLI_33,MALLU R_33 | 6:46 | 8:40 | 1:54 | TRANSFORMER FAULT |
| 716 | 31-Dec-18 | BAGALKOT | 110 | 110/33KV,HV3 | MUNAVALLI_110,MUNAVALLI_33,MALLU R_33 | 17:49 | 18:25 | 0:36 | HAND TRIPPED |
| 717 | 31-Dec-18 | BAGALKOT | 110 | 110/11KV,HV2 | MUNAVALLI_110 | 17:00 | 17:50 | 0:50 | HAND TRIPPED |
| 718 | 31-Dec-18 | BAGALKOT | 110 | 110/33KV,HV4 | LAKAMANAHALLI_110,ALNAVAR_33 | 18:43 | 19:01 | 0:18 | TRANSFORMER FAULT |
| 719 | 31-Dec-18 | BAGALKOT | 110 | NARENDRA220 1&2-MRUTHYNJAY NAGAR | MRUTHYNJAY NAGAR_110 | 13:18 | 14:09 | 0:51 | HAND TRIPPED |
| 720 | 31-Dec-18 | BAGALKOT | 110 | GOPPANAKOPPA-MRUTHYNJAY NAGAR | MRUTHYNJAY NAGAR_110 | 13:15 | 13:17 | 0:02 | HAND TRIPPED |
| 721 | 31-Dec-18 | BAGALKOT | 110 | GOPPANAKOPPA-MRUTHYNJAY NAGAR | MRUTHYNJAY NAGAR_110 | 14:09 | 23:59 | 9:50 | LINE CLEAR AVAILED |
| 722 | 31-Dec-18 | BAGALKOT | 110 | SIRSI1-KUMTA | KUMTA_110 | 13:19 | 23:59 | 10:40 | LINE CLEAR AVAILED |
| 723 | 31-Dec-18 | BAGALKOT | 110 | GAMESH-KULIGOD | KULIGOD_110 | 0:25 | 0:31 | 0:06 | HAND TRIPPED |
| 724 | 31-Dec-18 | BAGALKOT | 220 | ALAMATTI 2-BAGALKOT | BAGALKOT_220 | 13:07 | 13:16 | 0:09 | LINE CLEAR AVAILED |
| 725 | 31-Dec-18 | BAGALKOT | 220 | ALAMATTI 2-BAGALKOT | BAGALKOT_220 | 18:44 | 19:41 | 0:57 | LINE CLEAR AVAILED |
| 726 | 31-Dec-18 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GOPANAKOPPA_110 | 0:00 | 13:09 | 13:09 | LINE CLEAR AVAILED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|-----------|---------|------------------------------------|-----------------|---------|-----------|----------|--------------------|
| 727 | 31-Dec-18 | BAGALKOT | 220 | CHIKKODI-BELAGAUM 1 | CHIKKODI_220 | 0:00 | 7:38 | 7:38 | LINE CLEAR AVAILED |
| 728 | 31-Dec-18 | BAGALKOT | 110 | GOPANAKOPPA-MRUTHYUNJAYNAGAR 1 & 2 | GOPANAKOPPA_110 | 13:10 | 13:16 | 0:06 | HAND TRIPPED |
| 729 | 31-Dec-18 | BAGALKOT | 110 | GOPANAKOPPA-MRUTHYUNJAYNAGAR 1 & 2 | GOPANAKOPPA_110 | 14:17 | 14:38 | 0:21 | HAND TRIPPED |
| 730 | 31-Dec-18 | BANGALORE | 66 | HV3 | ADUGODI | 9:05 | 9:09 | 0:04 | LOAD CHANGEOVER |
| 731 | 31-Dec-18 | BANGALORE | 66 | HV1 | KUMBALAGODU | 13:35 | 14:25 | 0:50 | LINE CLEAR AVAILED |
| 732 | 31-Dec-18 | BANGALORE | 66 | HV2 | KUMBALAGODU | 12:32 | 13:30 | 0:58 | LINE CLEAR AVAILED |
| 733 | 31-Dec-18 | BANGALORE | 66 | CHANDAPURA - SARJAPURA 220 | CHANDAPURA | 14:32 | 14:35 | 0:03 | LINE FAULT |
| 734 | 31-Dec-18 | BANGALORE | 66 | HV1 | DEVANAHALLI | 8:45 | 8:50 | 0:05 | TRANSFORMER FAULT |
| 735 | 31-Dec-18 | BANGALORE | 66 | HBR LAYOUT - LR BANDE | HBR LAYOUT | 9:40 | 9:48 | 0:08 | LOAD CHANGEOVER |
| 736 | 31-Dec-18 | BANGALORE | 66 | HV2 | KANAKAPURA | 4:36 | 4:40 | 0:04 | TRANSFORMER FAULT |
| 737 | 31-Dec-18 | BANGALORE | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA | 11:22 | 12:21 | 0:58 | LINE CLEAR AVAILED |
| 738 | 31-Dec-18 | BANGALORE | 66 | HV2 | SULIBELE | 15:02 | 16:00 | 0:57 | LINE CLEAR AVAILED |
| 739 | 31-Dec-18 | BANGALORE | 66 | HV2 | KEMBODI | 10:37 | 10:43 | 0:06 | TRANSFORMER FAULT |
| 740 | 31-Dec-18 | GULBARGA | 220 | HV1,HV2 | HALBURGA_220 | 11:05 | 11:12 | 0:07 | TRANSFORMER FAULT |
| 741 | 31-Dec-18 | GULBARGA | 220 | HV2 | RAICHUR_220 | 16:39 | 17:04 | 0:25 | HAND TRIPPED |
| 742 | 31-Dec-18 | GULBARGA | 220 | HV1 | RAICHUR_220 | 16:50 | 17:02 | 0:12 | LINE CLEAR AVAILED |
| 743 | 31-Dec-18 | GULBARGA | 110 | HALBURGA-ACMVSLR | HALBURGA_220 | 11:30 | 11:58 | 0:28 | LOAD CHANGEOVER |
| 744 | 31-Dec-18 | GULBARGA | 110 | HV1 | KAVITAL_110 | 13:28 | 13:37 | 0:09 | TRANSFORMER FAULT |
| 745 | 31-Dec-18 | GULBARGA | 110 | KOLHAR-SAHI_SLR | KOLHAR_110 | 11:38 | 11:41 | 0:03 | LINE FAULT |
| 746 | 31-Dec-18 | GULBARGA | 110 | HV1,HV2 | LINGUSUGUR_220 | 11:00 | 11:11 | 0:11 | TRANSFORMER FAULT |
| 747 | 31-Dec-18 | GULBARGA | 110 | HV2 | KAMALAPUR_110 | 16:18 | 16:25 | 0:07 | TRANSFORMER FAULT |
| 748 | 31-Dec-18 | GULBARGA | 110 | HV2 | HATTI_110 | 17:35 | 17:45 | 0:10 | TRANSFORMER FAULT |
| 749 | 31-Dec-18 | GULBARGA | 110 | SHAHAPUR2 | RAICHUR_220 | 0:10 | 0:18 | 0:08 | LINE FAULT |
| 750 | 31-Dec-18 | GULBARGA | 110 | DHADESUGUR-SIRUGUPPA | SIRUGUPPA_110 | 6:25 | 6:45 | 0:20 | LINE FAULT |
| 751 | 31-Dec-18 | GULBARGA | 66 | ITTAGGI-CLEANSOLAR1 | ITTAGGI_220 | 17:45 | 18:55 | 1:10 | LINE CLEAR AVAILED |
| 752 | 31-Dec-18 | HASSAN | 400 | HASSAN40-UPCL2 | HASSAN_400 | 0:00 | 8:12 | 8:12 | LINE CLEAR AVAILED |
| 753 | 31-Dec-18 | HASSAN | 400 | HASSAN40-UPCL2 | HASSAN_400 | 23:14 | 23:59 | 0:45 | LINE CLEAR AVAILED |
| 754 | 31-Dec-18 | HASSAN | 400 | UPCL-HASSAN2 | UPCL_GEN | 0:00 | 8:12 | 8:12 | LINE CLEAR AVAILED |
| 755 | 31-Dec-18 | HASSAN | 400 | UPCL-HASSAN2 | UPCL_GEN | 23:14 | 23:59 | 0:45 | LINE CLEAR AVAILED |
| 756 | 31-Dec-18 | HASSAN | 110 | ARSK2-GANDASI | ARSIKERE_220 | 9:59 | 13:09 | 3:10 | LINE CLEAR AVAILED |
| 757 | 31-Dec-18 | HASSAN | 110 | HV2 | KAVOOR_220 | 14:28 | 15:01 | 0:33 | TRANSFORMER FAULT |
| 758 | 31-Dec-18 | HASSAN | 110 | HV1 | KEMAR_220 | 10:38 | 13:08 | 2:30 | LINE CLEAR AVAILED |
| 759 | 31-Dec-18 | HASSAN | 110 | HV1 | SHIRALKOPPA_220 | 9:30 | 10:55 | 1:25 | LINE CLEAR AVAILED |
| 760 | 31-Dec-18 | MYSORE | 66 | HV2 | BOOKANAKERE_66 | 13:35 | 13:45 | 0:10 | TRANSFORMER FAULT |
| 761 | 31-Dec-18 | MYSORE | 66 | HV2 | BOOKANAKERE_66 | 14:04 | 14:17 | 0:12 | TRANSFORMER FAULT |
| 762 | 31-Dec-18 | MYSORE | 66 | HV1 | K_HONNALGERE_66 | 12:07 | 12:42 | 0:34 | LINE CLEAR AVAILED |
| 763 | 31-Dec-18 | MYSORE | 66 | HV1 | KIADBMANDYA_66 | 10:30 | 11:59 | 1:29 | HAND TRIPPED |
| 764 | 31-Dec-18 | MYSORE | 66 | HV2 | KIADBMANDYA_66 | 10:30 | 11:59 | 1:29 | HAND TRIPPED |

| Sl.No. | Date | Tr_ZONE | Voltage | Line | Station_Name | Open_At | Closed_At | Duration | REASON |
|--------|-----------|---------|---------|--|--|---------|-----------|----------|---------------------|
| 765 | 31-Dec-18 | MYSORE | 66 | HV3 | KIKKERI_66 | 12:10 | 12:56 | 0:46 | LINE CLEAR AVAILED |
| 766 | 31-Dec-18 | MYSORE | 220 | HV2 | MADHUVANAHALLI_220 | 12:24 | 12:28 | 0:04 | HAND TRIPPED |
| 767 | 31-Dec-18 | MYSORE | 66 | HV4 | SFCSHIVA_66 | 10:03 | 10:35 | 0:32 | LINE CLEAR AVAILED |
| 768 | 31-Dec-18 | MYSORE | 66 | HV3 | PONNAMPET_66 | 9:37 | 11:03 | 1:25 | LINE CLEAR AVAILED |
| 769 | 31-Dec-18 | MYSORE | 66 | TUBINAKERE-MANDYA 2 | CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 MANDYA_66 MALAVALLI_66 & HADLI_66 | 19:30 | 21:05 | 1:35 | LINE FAULT |
| 770 | 31-Dec-18 | MYSORE | 66 | TUBINAKERE-MANDYA 4 | CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 MANDYA_66 MALAVALLI_66 & HADLI_66 | 19:30 | 21:05 | 1:35 | LINE FAULT |
| 771 | 31-Dec-18 | TUMKUR | 220 | MADHUGIRI 220kV-PAVAGADA_220 2 | MADHUGIRI 220kV | 11:12 | 11:26 | 0:13 | LINE CLEAR AVAILED |
| 772 | 31-Dec-18 | TUMKUR | 66 | DYAVARANAHALLI-RANGENAHALLI (P R PURA) | PRPURA_66, LINGADAHALLI_TMK2_66 | 8:39 | 17:32 | 8:53 | LINE CLEAR AVAILED |
| 773 | 31-Dec-18 | TUMKUR | 66 | TR-1 | HALUVAGALU_66 | 20:29 | 21:14 | 0:45 | TRANSFORMER FAULT |
| 774 | 31-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 8:40 | 9:08 | 0:28 | HAND TRIPPED |
| 775 | 31-Dec-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 19:20 | 19:36 | 0:16 | HAND TRIPPED |
| 776 | 31-Dec-18 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 21:07 | 21:20 | 0:13 | LINE FAULT |
| 777 | 31-Dec-18 | TUMKUR | 66 | TR-1 | MALLASANDRA_66 | 16:03 | 22:12 | 6:08 | LINE CLEAR AVAILED |
| 778 | 31-Dec-18 | TUMKUR | 66 | SIRA- KALLAMBELLA | KALLAMBELLA_66 | 8:55 | 9:18 | 0:23 | LINE FAULT |
| 779 | 31-Dec-18 | TUMKUR | 66 | SIRA- MADHUGIRI 2 | BUKKAPATNA_66, KALLAMBELLA_66 | 8:55 | 9:18 | 0:23 | LINE FAULT |
| 780 | 31-Dec-18 | TUMKUR | 66 | TR2 | TAVAREKERE(C)_66 | 21:21 | 21:25 | 0:03 | MAIN SUPPLY FAILURE |
| 781 | 31-Dec-18 | TUMKUR | 66 | UCHANGIDURGA- PALLAGATTE | PALLAGATTE_66,SOKKE_66 | 14:27 | 15:03 | 0:35 | LINE FAULT |
| 782 | 31-Dec-18 | TUMKUR | 66 | TR-1 | YEDIYUR_66 | 13:16 | 18:12 | 4:56 | LINE CLEAR AVAILED |