400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 28.07.2020 TO 03.08.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
1	4-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN:LINE CLEAR AVAILED
2	4-Aug-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	13:25	15:23	1:58	LINE CLEAR AVAILED
3	4-Aug-20	BAGALKOT	110	110/11KV,HV1	AMBEWADI_220	21:24	21:31	0:07	TRANSFORMER FAULT
4	4-Aug-20	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	17:21	17:55	0:34	LINE CLEAR AVAILED
5	4-Aug-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	22:02	22:05	0:03	TRANSFORMER FAULT
6	4-Aug-20	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, WIND1&2_33	17:56	18:14	0:18	TRANSFORMER FAULT
7	4-Aug-20	BAGALKOT	110	110/33KV,HV2	ANKOLA_110, SEABIRD & MASTIKATTA_33	15:55	19:43	3:48	TRANSFORMER FAULT
8	4-Aug-20	BAGALKOT	110	110/33KV,HV2	ANKOLA_110, SEABIRD & MASTIKATTA_33	20:15	20:23	0:08	TRANSFORMER FAULT
9	4-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
10	4-Aug-20	BAGALKOT	110	110KV,LV1	MK HUBLI_220	8:30 (03.08.2020)	8:53 (04.08.2020)	24:23hrs	LINE CHARGED
11	4-Aug-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	17:32 (04.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
12	4-Aug-20	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	10:40 (22.07.2020)	1:55 (04.08.2020)	303:15hrs	LINE CHARGED
13	4-Aug-20	BAGALKOT	110	AMBEWADI-NK2 (KAVALAWADA)	KAVALWADA_110	8:10	8:20	0:10	HAND TRIPPED
14	4-Aug-20	BAGALKOT	110	AMBEWADI-NK2 (KAVALAWADA)	KAVALWADA_110	8:22	8:27	0:05	LINE FAULT
15	4-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
16	4-Aug-20	BAGALKOT	110	DAMBAL-MUNDARGI1	MUNDARAGI_110	6:55	14:50	7:55	LINE FAULT
17	4-Aug-20	BAGALKOT	110	DAMBAL-MUNDARGI2	MUNDARAGI_110	12:20	14:55	2:35	LINE CLEAR AVAILED
18	4-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
19	4-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
20	4-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
21	4-Aug-20	BAGALKOT	110	HUNGUND- KUDALSANGAM	KUDAL SANGAM_110	16:09	16:21	0:12	LINE FAULT
22	4-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
23	4-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
24	4-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
25	4-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
26	4-Aug-20	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	15:55	17:24	1:29	TRANSFORMER FAULT
27	4-Aug-20	BAGALKOT	220	AMBEWADI-NAGAJHARI	AMBEWADI_220	11:10	16:41	5:31	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
28	4-Aug-20	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	15:39 (04.08.2020)			LINE OPEN:LINE FAULT
29	4-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
30	4-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
31	4-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
32	4-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
33	4-Aug-20	BAGALKOT	220	BELGAUM-NARENDRA2 (KANABARAGI 2)	BELGAUM_220	22:05 (03.08.2020)	7:02 (04.08.2020)	8:57hrs	LINE CHARGED
34	4-Aug-20	BAGALKOT	220	GUTTUR1- HAVERI	HAVERI_220	12:58	17:39	4:41	LINE FAULT
35	4-Aug-20	BAGALKOT	220	GUTTUR2- HAVERI	HAVERI_220	12:58	17:38	4:40	LINE FAULT
36	4-Aug-20	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	9:53	12:46	2:53	NFBC ISSUED
37	4-Aug-20	BAGALKOT	220	HUBLI 2 -SIRSI	SIRSI_220	14:00 (03.08.2020)			LINE OPEN:LINE CLEAR AVAILED
38	4-Aug-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:55 (23.07.2020)			LINE OPEN:LINE CLEAR AVAILED
39	4-Aug-20	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	23:33 (04.08.2020)			LINE OPEN:LINE FAULT
40	4-Aug-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	17:24 (04.08.2020)			LINE OPEN:LINE FAULT
41	4-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
42	4-Aug-20	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	09:55	10:05	00:10	LINE CLEAR AVAILED
43	4-Aug-20	BENGALURU	66	HV1	NANGALI	15:10	15:21	00:11	LINE CLEAR AVAILED
44	4-Aug-20	BENGALURU	66	HV1	DOMMASANDRA	19:03	19:20	00:16	TRANSFORMER FAULT
45	4-Aug-20	BENGALURU	66	HV1	ELECTRONIC CITY	12:10	12:15	00:05	TRANSFORMER FAULT
46	4-Aug-20	BENGALURU	66	HV2	KYALANUR	08:02	09:05	01:02	LINE CLEAR AVAILED
47	4-Aug-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
48	4-Aug-20	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASNUR	18:05	18:25	00:20	LOAD CHANGEOVER
49	4-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
50	4-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
51	4-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
52	4-Aug-20	GULBARGA	110	BYAGAWAT-ACMESOLAR_IPP	BYAGWAT_110	15:05	15:58	00:53	LINE CLEAR AVAILED
53	4-Aug-20	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	16:07	16:47	00:40	LINE CLEAR AVAILED
54	4-Aug-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	08:15	08:20	00:05	LINE CLEAR AVAILED
55	4-Aug-20	GULBARGA	110	HV1	SHAHAPUR_220	15:31	15:51	00:20	TRANSFORMER FAULT
56	4-Aug-20	GULBARGA	110	HV2	HATTI_110	11:15	11:22	00:07	TRANSFORMER FAULT
57	4-Aug-20	GULBARGA	110	HV2	HATTI_110	12:38	12:44	00:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
58	4-Aug-20	GULBARGA	110	HV2	HATTI_110	13:17	13:24	00:07	TRANSFORMER FAULT
59	4-Aug-20	GULBARGA	110	HV2	HANUMANAL_110	08:30	09:25	00:55	LINE CLEAR AVAILED
60	4-Aug-20	GULBARGA	110	HV2	HANUMANAL_110	13:30	14:05	00:35	LINE CLEAR AVAILED
61	4-Aug-20	GULBARGA	110	HV4	YELBURGA_110	12:30	12:40	00:10	TRANSFORMER FAULT
62	4-Aug-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	01:25	01:39	00:14	LINE FAULT
63	4-Aug-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:32	20:42	00:10	LINE FAULT
64	4-Aug-20	GULBARGA	110	WALKAMDINNI-MALLAT	VALKAMDINNI_110	01:43	01:49	00:06	MAIN SUPPLY FAILURE
65	4-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
66	4-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
67	4-Aug-20	HASSAN	66	BALEHONNUR	ALDUR_66	16:21	17:02	00:41	NFBC ISSUED
68	4-Aug-20	HASSAN	66	BALEHONNUR	ALDUR_66	18:45(4.8.2020)			LINE OPEN:LINE FAULT
69	4-Aug-20	HASSAN	66	CHIKKAMAGLUR	ALDUR_66	16:17	17:00	00:43	MAIN SUPPLY FAILURE
70	4-Aug-20	HASSAN	66	HASSAN	SAKLESHPURA_66	17:33	18:15	00:42	LINE FAULT
71	4-Aug-20	HASSAN	66	HN PURA	HASSAN_220	22:54			LINE OPEN:LINE FAULT
72	4-Aug-20	HASSAN	66	HV1	MAGGE_66	17:42	17:55	00:13	MAIN SUPPLY FAILURE
73	4-Aug-20	HASSAN	66	HV1	SAKLESHPURA_66	17:00	17:19	00:19	TRANSFORMER FAULT
74	4-Aug-20	HASSAN	66	HV2	MAGGE_66	17:42	17:55	00:13	MAIN SUPPLY FAILURE
75	4-Aug-20	HASSAN	66	KANDLI	BALLUPETE_66	17:48	18:14	00:26	LINE FAULT
76	4-Aug-20	HASSAN	66	LV1	MRSMG_220	16:08	17:38	01:30	LINE CLEAR AVAILED
77	4-Aug-20	HASSAN	66	LV2	MRSMG_220	15:48	17:20	01:32	LINE CLEAR AVAILED
78	4-Aug-20	HASSAN	66	SAKLESHPUR	KANDLI_66	17:33	17:52	00:19	LINE FAULT
79	4-Aug-20	HASSAN	110	HV1	NANDIKUR_110	17:38	17:45	00:07	TRANSFORMER FAULT
80	4-Aug-20	HASSAN	110	HV1	BAIKAMPADI_110	17:01	17:21	00:20	MAIN SUPPLY FAILURE
81	4-Aug-20	HASSAN	110	HV1	BAIKAMPADI_110	21:09	21:26	00:17	MAIN SUPPLY FAILURE
82	4-Aug-20	HASSAN	110	HV2	SORABA_110	04:21	15:25	11:04	TRANSFORMER FAULT
83	4-Aug-20	HASSAN	110	MANJESWARG	KONAJE_110	17:10	17:29	00:19	LINE FAULT
84	4-Aug-20	HASSAN	110	MCFLine	KAVOOR_220	16:56	17:18	00:22	LINE FAULT
85	4-Aug-20	HASSAN	110	MCFLine	KAVOOR_220	21:06	21:24	00:18	LINE FAULT
86	4-Aug-20	HASSAN	220	KAVOOR2	MSEZ_220	22:36(4.8.2020)			LOAD CURTAILMENT
87	4-Aug-20	HASSAN	220	Kavoor2	KEMAR_220	22:34	22:36	00:02	LINE FAULT
88	4-Aug-20	HASSAN	220	KEMAR2	MSEZ_220	13:39	19:05	05:26	NFBC ISSUED
89	4-Aug-20	HASSAN	220	KEMAR2	MSEZ_220	22:33			LOAD CURTAILMENT
90	4-Aug-20	HASSAN	220	KEMR2	KAVOOR_220	22:36(4.8.20)			LOAD CURTAILMENT
91	4-Aug-20	HASSAN	220	SHARAVATHY4	MRSMG_220	18:41	19:07	00:26	LINE FAULT
92	4-Aug-20	HASSAN	220	Varahi2	KEMAR_220	18:30	18:32	00:02	LINE FAULT
93	4-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:13 (03.08.2020)	8:13(04.08.2020)	9:00hrs	LINE CHARGED
94	4-Aug-20	MYSURU	66	HV1	GAMANAHALLY_66	16:28	17:03	0:35	LINE CLEAR AVAILED
95	4-Aug-20	MYSURU	66	HV1	SANIVARASANTHE_66	1:07	1:14	0:07	TRANSFORMER FAULT
96	4-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
97	4-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	8:50	9:05	0:15	LINE FAULT
98	4-Aug-20	MYSURU	66	MALAVALLY-KK HALLY	MALAVALLI_66 HADLI_66	8:18	19:04	10:46	NFBC ISSUED
99	4-Aug-20	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:52	19:00	0:08	LINE FAULT
100	4-Aug-20	TUMKUR	66	BENKIKERE-NALLUR	BENKIKERE_66	23:43	23:45	0:01	MAIN SUPPLY FAILURE
101	4-Aug-20	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66,	23:21	23:31	0:10	MAIN SUPPLY FAILURE
102	4-Aug-20	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	16:59	17:04	0:05	LINE CLEAR AVAILED
103	4-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
104	4-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	17:00	17:48	0:47	LINE CLEAR AVAILED
105	4-Aug-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	21:36	21:48	0:11	LINE FAULT
106	4-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:49	17:32	9:43	LINE CLEAR AVAILED
107	4-Aug-20	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	18:06	18:54	0:47	MAIN SUPPLY FAILURE
108	4-Aug-20	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	18:41	18:43	0:01	MAIN SUPPLY FAILURE
109	4-Aug-20	TUMKUR	66	TR-1	BENKIKERE_66	23:43	23:45	0:01	MAIN SUPPLY FAILURE
110	4-Aug-20	TUMKUR	66	TR-1	DEVARAHALLI_66	23:21	23:31	0:10	MAIN SUPPLY FAILURE
111	4-Aug-20	TUMKUR	66	TR-1	MATHOD_66	22:01	22:08	0:07	TRANSFORMER FAULT
112	4-Aug-20	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	17:18	17:25	0:07	TRANSFORMER FAULT
113	4-Aug-20	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	18:05	18:52	0:47	MAIN SUPPLY FAILURE
114	4-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
115	4-Aug-20	TUMKUR	66	TR-2	BENKIKERE_66	23:43	23:45	0:01	MAIN SUPPLY FAILURE
116	4-Aug-20	TUMKUR	66	TR-2	HALUVAGALU_66	22:20	22:23	0:03	TRANSFORMER FAULT
117	4-Aug-20	TUMKUR	66	TR-2	HOLALKERE_66	21:02	21:07	0:04	TRANSFORMER FAULT
118	4-Aug-20	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	18:05	18:56	0:50	MAIN SUPPLY FAILURE
119	4-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	16:49	17:04	0:14	MAIN SUPPLY FAILURE
120	4-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
121	4-Aug-20	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI_220	18:06	20:14	2:08	LINE FAULT
122	4-Aug-20	TUMKUR	220	TR-1	PAVAGADA_220	18:05	18:53	0:47	MAIN SUPPLY FAILURE
123	4-Aug-20	TUMKUR	220	TR-2	PAVAGADA_220	18:05	18:54	0:49	MAIN SUPPLY FAILURE
124	5-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN:LINE CLEAR AVAILED
125	5-Aug-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	15:45	16:27	00:42	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
126	5-Aug-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	08:37	08:44	00:07	TRANSFORMER FAULT
127	5-Aug-20	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	15:01	15:04	00:03	TRANSFORMER FAULT
128	5-Aug-20	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	12:30	13:06	00:36	LINE CLEAR AVAILED
129	5-Aug-20	BAGALKOT	110	110/11KV, HV2	ITANAL_110	18:05	18:42	00:37	TRANSFORMER FAULT
130	5-Aug-20	BAGALKOT	110	110/11KV,HV1	AMBEWADI_220	08:15	08:18	00:03	TRANSFORMER FAULT
131	5-Aug-20	BAGALKOT	110	110/11KV,HV1	ARGA_110	15:22	17:02	01:40	LINE CLEAR AVAILED
132	5-Aug-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	02:31	02:39	00:08	TRANSFORMER FAULT
133	5-Aug-20	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, WIND1&2_33	19:44	20:35	00:51	LINE CLEAR AVAILED
134	5-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
135	5-Aug-20	BAGALKOT	110	110/33KV,HV4	ANKALI_110	12:05	12:40	00:35	TRANSFORMER FAULT
136	5-Aug-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	17:32 (04.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
137	5-Aug-20	BAGALKOT	110	AMBEWADI-NK2 (KAVALAWADA)	KAVALAWADA_110	18:38	18:43	00:05	LINE FAULT
138	5-Aug-20	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110 (STATION NOT EFFECTED)	03:56	11:45	07:49	LINE FAULT
139	5-Aug-20	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	05:50	06:04	00:14	LINE FAULT
140	5-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
141	5-Aug-20	BAGALKOT	110	ESALE1(SIRSI220)- SIRSI	SIRSI_110	02:03	12:50	10:47	LINE FAULT
142	5-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
143	5-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
144	5-Aug-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN:LINE CLEAR AVAILED
145	5-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
146	5-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
147	5-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
148	5-Aug-20	BAGALKOT	110	RANEBENNUR- HIREKERUR	HIREKERUR_110	03:03	03:08	00:05	LINE FAULT
149	5-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
150	5-Aug-20	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	02:39	03:32	00:53	LINE FAULT
151	5-Aug-20	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	09:54	16:16	06:22	LINE FAULT
152	5-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
153	5-Aug-20	BAGALKOT	220	220/110KV, HV2	MKHUBLI_220	09:35	09:55	00:20	TRANSFORMER FAULT
154	5-Aug-20	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	11:02	15:39	04:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
155	5-Aug-20	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	15:39 (04.08.2020)			LINE OPEN:LINE FAULT
156	5-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
157	5-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
158	5-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
159	5-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
160	5-Aug-20	BAGALKOT	220	HUBLI 1 -SIRSI	SIRSI_220	17:55 (05.08.2020)			LINE OPEN:LINE CLEAR AVAILED
161	5-Aug-20	BAGALKOT	220	HUBLI 2 -SIRSI	SIRSI_220	14:00 (03.08.2020)	13:24 (05.08.2020)	47:24 HRS	LINE CHARGED
162	5-Aug-20	BAGALKOT	220	HUBLI 2 -SIRSI	SIRSI_220	17:55 (05.08.2020)			LINE OPEN:LINE CLEAR AVAILED
163	5-Aug-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:55 (23.07.2020)	9:08 (05.08.2020)	310:10 HRS	NFBC ISSUED
164	5-Aug-20	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	23:33 (04.08.2020)	17:55 (05.08.2020)	18:22 HRS	LINE CHARGED
165	5-Aug-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	17:24 (04.08.2020)	17:55 (05.08.2020)	24:31 HRS	LINE CHARGED
166	5-Aug-20	BAGALKOT	220	SHIRALKOPPA (BELLIGAVI)-RANEBENNUR	RANEBENNUR_220	8:40 (05.08.2020)			LINE OPEN:LINE CLEAR AVAILED
167	5-Aug-20	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	10:50	10:55	00:05	LOAD CHANGEOVER
168	5-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
169	5-Aug-20	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:17	10:50	00:33	MAIN SUPPLY FAILURE
170	5-Aug-20	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	14:45	14:50	00:05	LOAD CHANGEOVER
171	5-Aug-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	13:02	13:16	00:14	LINE FAULT
172	5-Aug-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:03	13:16	00:13	LINE FAULT
173	5-Aug-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	07:40	07:49	00:09	TRANSFORMER FAULT
174	5-Aug-20	BENGALURU	66	HV1	SANKALGERE	18:26	18:45	00:19	TRANSFORMER FAULT
175	5-Aug-20	BENGALURU	66	HV1	HOSPALYA	14:50	14:55	00:05	TRANSFORMER FAULT
176	5-Aug-20	BENGALURU	66	HV1	HOSPALYA	22:20	22:30	00:10	TRANSFORMER FAULT
177	5-Aug-20	BENGALURU	66	HV1	MUDIYANUR	11:05	11:15	00:10	TRANSFORMER FAULT
178	5-Aug-20	BENGALURU	66	HV1	MUDIYANUR	11:50	12:10	00:20	TRANSFORMER FAULT
179	5-Aug-20	BENGALURU	66	HV1	TADIGOLU	14:10	14:40	00:30	LINE CLEAR AVAILED
180	5-Aug-20	BENGALURU	66	HV2	TADIGOLU	14:10	14:40	00:30	LINE CLEAR AVAILED
181	5-Aug-20	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	11:38	11:41	00:03	LOAD CHANGEOVER
182	5-Aug-20	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	15:09	16:51	01:42	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
183	5-Aug-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
184	5-Aug-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	18:46	20:20	01:34	LINE CLEAR AVAILED
185	5-Aug-20	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	16:15	16:17	00:02	LOAD CHANGEOVER
186	5-Aug-20	BENGALURU	66	KUMBALAGODU - SOMANAHLLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	11:26	11:50	00:24	LOAD CHANGEOVER
187	5-Aug-20	BENGALURU	66	MITTEMARI 220 - SADALI	SADALI	08:59	09:55	00:56	LINE CLEAR AVAILED
188	5-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
189	5-Aug-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	NO STATION EFFECTED	10:10	10:40	00:30	LINE FAULT
190	5-Aug-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	NO STATION EFFECTED	10:40	14:17	03:37	LINE FAULT
191	5-Aug-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	11:20	11:24	00:04	LINE FAULT
192	5-Aug-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	NO STATION AFFECTED	11:26	15:48	04:22	LINE FAULT
193	5-Aug-20	BENGALURU	220	HV1	MITTEMARI	08:59	09:51	00:52	TRANSFORMER FAULT
194	5-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
195	5-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
196	5-Aug-20	BENGALURU	400	NELAMANGALA 400 - MYSORE 2	NO STATIONS EFFECTED	03:17	06:34	03:17	LINE FAULT
197	5-Aug-20	GULBARGA	66	HV1	GUDEKOTE_66	14:46	15:36	00:50	LINE CLEAR AVAILED
198	5-Aug-20	GULBARGA	66	HV1	GUDEKOTE_66	18:35	18:55	00:20	LINE CLEAR AVAILED
199	5-Aug-20	GULBARGA	66	HV1	KUDLIGI_66	15:26	17:35	02:09	LINE CLEAR AVAILED
200	5-Aug-20	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,HOSAHALLI_66, BANVEKAL_66, GUDEKOTE_66, CHORNOOR 66	10:04	10:27	00:23	LINE FAULT
201	5-Aug-20	GULBARGA	66	ITTAGI-RENEWSOLAR1	ITTAGI_220	11:58	12:10	00:12	LINE CLEAR AVAILED
202	5-Aug-20	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	23:40	23:45	00:05	LINE FAULT
203	5-Aug-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110	12:38	13:28	00:50	LINE FAULT
204	5-Aug-20	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED
205	5-Aug-20	GULBARGA	110	SINDHANOOR220-RAICHUR2	MASKI_110,MUDDAPUR_110	05:35	05:40	00:05	LINE FAULT
206	5-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
207	5-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
208	5-Aug-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	11:51	12:04	00:13	LINE FAULT
209	5-Aug-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	18:45 (4.08.2020)	11:52 (5.08.2020)	17:6 hrs	LINE CHARGED
210	5-Aug-20	HASSAN	66	BALLUPE-SAKLE	BALLUPETE_66	05:15	05:30	00:15	LINE FAULT
211	5-Aug-20	HASSAN	66	BALLUPE-SAKLE	BALLUPETE_66	05:55	06:40	00:45	LINE FAULT
212	5-Aug-20	HASSAN	66	BALLUPE-SAKLE	BALLUPETE_66	12:05	17:40	05:35	NFBC ISSUED
213	5-Aug-20	HASSAN	66	BALUPE-KANDLI	BALLUPETE_66	04:25	04:45	00:20	LINE FAULT
214	5-Aug-20	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	18:40	19:45	01:05	LINE FAULT
215	5-Aug-20	HASSAN	66	HASSN220-HN PURA	HASSAN_220	22:54 (4.08.2020)	12:55 (5.08.2020)	14:00 hrs	LINE CHARGED
216	5-Aug-20	HASSAN	66	HV1	ATTICHOWDENAHALLI_66	02:32	02:39	00:07	TRANSFORMER FAULT
217	5-Aug-20	HASSAN	66	HV1	BELUR_66	06:05	06:30	00:25	MAIN SUPPLY FAILURE
218	5-Aug-20	HASSAN	66	HV1	BELUR_66	12:50	14:20	01:30	MAIN SUPPLY FAILURE
219	5-Aug-20	HASSAN	66	HV1	HALEBEEEDU_66	13:45	14:20	00:35	LINE CLEAR AVAILED
220	5-Aug-20	HASSAN	66	HV1	MAGGE_66	04:25	04:56	00:31	MAIN SUPPLY FAILURE
221	5-Aug-20	HASSAN	66	HV1	MAGGE_66	05:15	22:20	17:05	MAIN SUPPLY FAILURE
222	5-Aug-20	HASSAN	66	HV2	BELUR_66	06:05	06:30	00:25	MAIN SUPPLY FAILURE
223	5-Aug-20	HASSAN	66	HV2	BELUR_66	12:50	14:20	01:30	MAIN SUPPLY FAILURE
224	5-Aug-20	HASSAN	66	HV2	CHIKKAK	15:00	16:00	01:00	TRANSFORMER FAULT
225	5-Aug-20	HASSAN	66	HV2	MAGGE_66	04:25	04:56	00:31	MAIN SUPPLY FAILURE
226	5-Aug-20	HASSAN	66	HV2	MAGGE_66	05:15	22:20	17:05	MAIN SUPPLY FAILURE
227	5-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	2:25 (5.08.2020)			LINE OPEN:LINE FAULT
228	5-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	01:40	02:20	00:40	LINE FAULT
229	5-Aug-20	HASSAN	66	SAKALE-HASSAN1	SAKALESHPURA_66	5:45 (5.08.2020)			LINE OPEN:LINE FAULT
230	5-Aug-20	HASSAN	66	SAKALE-HASSAN1	SAKALESHPURA_66	04:25	05:00	00:35	LINE FAULT
231	5-Aug-20	HASSAN	66	SAKALE-HASSAN1	SAKALESHPURA_66	05:15	05:45	00:30	LINE FAULT
232	5-Aug-20	HASSAN	66	SAKALE-HASSAN2	SAKALESHPURA_66	04:25	05:00	00:35	LINE FAULT
233	5-Aug-20	HASSAN	66	SAKALE-HASSAN2	SAKALESHPURA_66	05:15	05:45	00:30	LINE FAULT
234	5-Aug-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:40	12:10	01:30	LINE CLEAR AVAILED
235	5-Aug-20	HASSAN	110	HV1	JOG_110	15:17	16:25	01:08	LINE CLEAR AVAILED
236	5-Aug-20	HASSAN	110	HV2	BARANGI_110	00:49	00:55	00:06	HAND TRIPPED
237	5-Aug-20	HASSAN	110	HV2	SORABA_110	11:45	12:30	00:45	LINE CLEAR AVAILED
238	5-Aug-20	HASSAN	110	HV2	SORABA_110	18:00	18:35	00:35	LINE CLEAR AVAILED
239	5-Aug-20	HASSAN	110	JOG-JST1	gen_mghe	08:50	09:45	00:55	LINE FAULT
240	5-Aug-20	HASSAN	110	NANDIKU-ISTRL	NANDIKUR_110	04:20	04:44	00:24	MAIN SUPPLY FAILURE
241	5-Aug-20	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	04:20	04:44	00:24	MAIN SUPPLY FAILURE
242	5-Aug-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	04:20	04:44	00:24	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
243	5-Aug-20	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	04:20	04:44	00:24	MAIN SUPPLY FAILURE
244	5-Aug-20	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:55	11:25	00:30	LOAD CHANGEOVER
245	5-Aug-20	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	22:36 (4.08.2020)	8:00 (5.08.2020)	9:23 hrs	LINE CHARGED
246	5-Aug-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	04:24	08:09	03:45	LINE FAULT
247	5-Aug-20	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	22:36 (4.08.2020)	8:00 (5.08.2020)	9:23 hrs	LINE CHARGED
248	5-Aug-20	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	22:33 (4.08.2020)	8:00 (5.08.2020)	9:26 hrs	LINE CHARGED
249	5-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	7:46 (3.08.2020)	7:24 (5.08.2020)	47:37 hrs	LINE CHARGED
250	5-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:08 (3.08.2020)			LINE OPEN:LINE CLEAR AVAILED
251	5-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
252	5-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	19:04	19:38	00:34	NFBC ISSUED
253	5-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	PONNAMPET_66 VIRAJPET_66	20:48	20:56	00:08	LINE FAULT
254	5-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	PONNAMPET_66 VIRAJPET_66	20:57	21:14	00:16	LINE FAULT
255	5-Aug-20	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	06:55	10:45	03:49	LINE FAULT
256	5-Aug-20	MYSURU	66	HANNUR-MADNHL 1	NO STATIONS EFFECTED	06:55	07:40	00:44	LINE FAULT
257	5-Aug-20	MYSURU	66	HOOTAGALLI-BELAGOLA	NO STATIONS EFFECTED	10:13 (05.08.2020)			LINE OPEN:LINE CLEAR AVAILED
258	5-Aug-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	09:21	11:21	02:00	LINE CLEAR AVAILED
259	5-Aug-20	MYSURU	66	HV1	BETTADHAPURA_66	15:14	15:21	00:07	HAND TRIPPED
260	5-Aug-20	MYSURU	66	HV1	COWDALLI_66	10:15	12:53	02:37	LINE CLEAR AVAILED
261	5-Aug-20	MYSURU	66	HV1	DODDABYADARAHALLI_66	12:37	12:52	00:14	LINE CLEAR AVAILED
262	5-Aug-20	MYSURU	66	HV1	HANNUR_66	17:43	17:56	00:13	LINE CLEAR AVAILED
263	5-Aug-20	MYSURU	66	HV1	HONNALY_MYS_66	13:13	13:17	00:03	TRANSFORMER FAULT
264	5-Aug-20	MYSURU	66	HV1	MADDUR_66	12:33	13:12	00:39	TRANSFORMER FAULT
265	5-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
266	5-Aug-20	MYSURU	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66	04:12	04:23	00:10	LINE FAULT
267	5-Aug-20	MYSURU	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66 SUNTIKOPPA_66	21:15	21:23	00:08	LINE FAULT
268	5-Aug-20	MYSURU	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66 SUNTIKOPPA_66	21:30	21:45	00:14	LINE FAULT
269	5-Aug-20	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	04:12	04:23	00:10	LINE FAULT
270	5-Aug-20	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	23:37	23:46	00:09	LINE FAULT
271	5-Aug-20	MYSURU	66	PERIAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66 HANAGODU_66	06:32	06:42	00:09	LINE FAULT
272	5-Aug-20	MYSURU	66	PERIAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66 HANAGODU_66	07:15	17:30	10:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
273	5-Aug-20	MYSURU	66	PERIAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	17:30	17:53	00:23	LINE FAULT
274	5-Aug-20	MYSURU	66	PERIAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66, HANAGODU_66	18:33	18:40	00:06	LINE FAULT
275	5-Aug-20	MYSURU	66	PERIAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	18:40 (05.08.2020)			LINE OPEN:LINE FAULT
276	5-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	9:10 (05.08.2020)			LINE OPEN:LINE FAULT
277	5-Aug-20	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	19:10	19:25	00:15	LINE FAULT
278	5-Aug-20	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	19:25 (05.08.2020)			LINE OPEN:LINE FAULT
279	5-Aug-20	TUMKUR	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	11:25	12:30	01:05	MAIN SUPPLY FAILURE
280	5-Aug-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	08:54	09:29	00:34	LINE FAULT
281	5-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
282	5-Aug-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:43	18:50	00:06	LINE FAULT
283	5-Aug-20	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	09:51	10:02	00:10	TRANSFORMER FAULT
284	5-Aug-20	TUMKUR	66	TR-1	BENKIKERE_66	11:25	12:30	01:05	MAIN SUPPLY FAILURE
285	5-Aug-20	TUMKUR	66	TR-1	CHAWANAKUPPE_66	13:06	13:55	00:48	LINE CLEAR AVAILED
286	5-Aug-20	TUMKUR	66	TR-1	THIMMASANDRA_66	10:35	10:48	00:12	LINE CLEAR AVAILED
287	5-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN : TRANSFORMER FAULT
288	5-Aug-20	TUMKUR	66	TR-2	CHITRADURGA_66	02:29	02:40	00:10	TRANSFORMER FAULT
289	5-Aug-20	TUMKUR	66	TR-2	KOLALA_66	11:59	14:05	02:05	LINE CLEAR AVAILED
290	5-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
291	5-Aug-20	TUMKUR	110	TR-2	KADEHALLI_110	11:58	13:04	01:05	LINE CLEAR AVAILED
292	5-Aug-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	03:20	07:30	04:10	LINE CLEAR AVAILED
293	6-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN:LINE CLEAR AVAILED
294	6-Aug-20	BAGALKOT	110	110/11KV, HV1	AREMALLAPUR_110	15:06	16:03	0:57	LINE CLEAR AVAILED
295	6-Aug-20	BAGALKOT	110	110/11KV, HV1	GADAG_110	15:40	16:07	0:27	LINE CLEAR AVAILED
296	6-Aug-20	BAGALKOT	110	110/11KV,HV 2	ITANAL_110	10:01	15:33	5:32	LINE CLEAR AVAILED
297	6-Aug-20	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	16:47	17:12	0:25	LINE CLEAR AVAILED
298	6-Aug-20	BAGALKOT	110	110/11KV,HV2	KUDCHI_110	13:25	14:17	0:52	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
299	6-Aug-20	BAGALKOT	110	110/11KV,HV2	RATTIHALLI_110	10:55	17:10	6:15	LINE CLEAR AVAILED
300	6-Aug-20	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110 &KARADI,AMINAGAD_33	18:14	18:21	0:07	TRANSFORMER FAULT
301	6-Aug-20	BAGALKOT	110	110/33KV,HV3	RATTIHALLI_110 &HALLU,MASUR_33	10:55	17:15	6:20	LINE CLEAR AVAILED
302	6-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
303	6-Aug-20	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	23:32 (06.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
304	6-Aug-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	17:32 (04.08.2020)	11:39:00 AM (06.08.2020)	42:07hrs	TRANSFORMER CHARGED
305	6-Aug-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	14:18 (06.08.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
306	6-Aug-20	BAGALKOT	110	33/110KV,HV 2	GAJENDRAGAD_110,RRB 1&2_33	15:26	15:38	0:12	TRANSFORMER FAULT
307	6-Aug-20	BAGALKOT	110	ATHANISUGARS- AINAPUR	AINAPUR_110	20:27	20:41	0:14	LINE FAULT
308	6-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
309	6-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
310	6-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
311	6-Aug-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT AFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN:LINE CLEAR AVAILED
312	6-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
313	6-Aug-20	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	20:27	20:32	0:05	LINE FAULT
314	6-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
315	6-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
316	6-Aug-20	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	9:25	9:57	0:32	LINE CLEAR AVAILED
317	6-Aug-20	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	11:04	14:10	3:06	LINE CLEAR AVAILED
318	6-Aug-20	BAGALKOT	110	SADALAGA-BORAGOAN	BORAGOAN_110	12:32	14:00	1:28	LINE FAULT
319	6-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
320	6-Aug-20	BAGALKOT	110	SIRSI-KUMATA 2	KUMATA_110	16:50	17:01	0:11	LOAD CHANGEOVER
321	6-Aug-20	BAGALKOT	110	SUPA1- AMBEWADI	AMBEWADI_220	8:54	12:12	3:18	LINE FAULT
322	6-Aug-20	BAGALKOT	110	SUPA2- AMBEWADI	AMBEWADI_220	9:21	12:13	2:52	LINE CLEAR AVAILED
323	6-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
324	6-Aug-20	BAGALKOT	220	220/110KV, HV2	MK HUBLI_220	4:07	10:01	5:54	TRANSFORMER FAULT
325	6-Aug-20	BAGALKOT	220	ALAMATTI 2- BAGALKOT	BAGALKOT_220	13:51	14:25	0:34	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
326	6-Aug-20	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	15:39 (04.08.2020)			LINE OPEN:LINE FAULT
327	6-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
328	6-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
329	6-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA1	BAGEWADI_220	13:54	14:10	0:16	LOAD CURTAILMENT
330	6-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
331	6-Aug-20	BAGALKOT	220	BAGEWADI-FORTUNE FIVE2	BAGEWADI_220	12:21	12:54	0:33	LOAD CURTAILMENT
332	6-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
333	6-Aug-20	BAGALKOT	220	HARTI1- BIDNAL	BIDNAL_220	14:11 (06.08.2020)			LOAD CURTAILMENT
334	6-Aug-20	BAGALKOT	220	HUBLI 1 -SIRSI	SIRSI_220	17:55 (05.08.2020)	14:48 (06.08.2020)	20:53hrs	LINE CHARGED
335	6-Aug-20	BAGALKOT	220	HUBLI 2 -SIRSI	SIRSI_220	17:55 (05.08.2020)	14:44 (06.08.2020)	20:49hrs	LINE CHARGED
336	6-Aug-20	BAGALKOT	220	HUBLI-SIRSI 1	HUBLI_220	14:48 (06.08.2020)			LOAD CURTAILMENT
337	6-Aug-20	BAGALKOT	220	HUBLI-SIRSI 2	HUBLI_220	12:58	13:42	0:44	HAND TRIPPED
338	6-Aug-20	BAGALKOT	220	HUBLI-SIRSI 2	HUBLI_220	14:43	17:37	2:54	LINE CLEAR AVAILED
339	6-Aug-20	BAGALKOT	220	HUBLI-SIRSI 2	HUBLI_220	19:23 (06.08.2020)			LOAD CURTAILMENT
340	6-Aug-20	BAGALKOT	220	KUDACHI-GHATAPRABHA(CHIKKODI1)	KUDACHI_220	20:27	21:02	0:35	LINE FAULT
341	6-Aug-20	BAGALKOT	220	SHARAVTY 1-SIRSI	SIRSI_220	17:37	19:05	1:28	LINE CLEAR AVAILED
342	6-Aug-20	BAGALKOT	220	SHARAVTY 2-SIRSI	SIRSI_220	3:49	19:06	15:17	LINE FAULT
343	6-Aug-20	BAGALKOT	220	SHIRALKOPPA (BELLIGAVI)-RANEBENNUR	RANEBENNUR_220	8:40 (05.08.2020)	19:39 (06.08.2020)	34:59hrs	LINE CHARGED
344	6-Aug-20	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATI_220	12:55	13:46	0:51	LOAD CURTAILMENT
345	6-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
346	6-Aug-20	BENGALURU	66	HV1	KGF	13:58	15:13	01:15	LINE CLEAR AVAILED
347	6-Aug-20	BENGALURU	66	HV1	HONNIGANAHALLI	11:05	11:15	00:10	LINE CLEAR AVAILED
348	6-Aug-20	BENGALURU	66	HV1	DEVANAHALLI	23:37	23:45	00:08	TRANSFORMER FAULT
349	6-Aug-20	BENGALURU	66	HV1	SHOBHA APARTMENT	20:58	21:04	00:05	LINE CLEAR AVAILED
350	6-Aug-20	BENGALURU	66	HV2	SHOBHA APARTMENT	20:58	21:04	00:05	LINE CLEAR AVAILED
351	6-Aug-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
352	6-Aug-20	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	15:10	15:12	00:02	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
353	6-Aug-20	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:35	10:40	00:05	LOAD CHANGEOVER
354	6-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
355	6-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
356	6-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
357	6-Aug-20	GULBARGA	66	KOGALI-ITTAGI	KOGALI_66	08:45	08:55	00:10	LINE FAULT
358	6-Aug-20	GULBARGA	66	RENEWSOLAR1_IPP	ITTAGI_220	11:20	11:25	00:05	LINE CLEAR AVAILED
359	6-Aug-20	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	15:58	16:34	00:36	LINE FAULT
360	6-Aug-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	05:50	06:01	00:11	LINE FAULT
361	6-Aug-20	GULBARGA	110	KUSTAGI-KANKAGIRI	KANKAGIRI_110, GANADAL_110	12:10	12:58	00:48	LINE FAULT
362	6-Aug-20	GULBARGA	110	MASKI-RENEWSOALR_IPP	MASKI_110	12:18	12:26	00:08	LINE FAULT
363	6-Aug-20	GULBARGA	110	MASKI-RENEWSOALR_IPP	MASKI_110	11:35	11:45	00:10	LINE FAULT
364	6-Aug-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	05:49	06:03	00:14	LINE FAULT
365	6-Aug-20	GULBARGA	110	SEDAM-ULTRATECHCEMENTS	ULTRATECH_CEMENTS	14:37	14:46	00:09	LINE CLEAR AVAILED
366	6-Aug-20	GULBARGA	110	SHAHPUR220-SHAHAPUR2	SHAHAPUR_110, NALWAR_110	17:36	17:39	00:03	LINE CLEAR AVAILED
367	6-Aug-20	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED
368	6-Aug-20	GULBARGA	220	HV2	KUSTAGI_220	11:15	11:30	00:15	TRANSFORMER FAULT
369	6-Aug-20	GULBARGA	220	HV2	KUSTAGI_220	12:10	12:25	00:15	TRANSFORMER FAULT
370	6-Aug-20	GULBARGA	220	ITTAGI-BMMISPAT	ITTAGI_220	12:10	12:27	00:17	LINE FAULT
371	6-Aug-20	GULBARGA	220	ITTAGI-CLEANMAX2_IPP	ITTAGI_220	10:50	11:00	00:10	LINE CLEAR AVAILED
372	6-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
373	6-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
374	6-Aug-20	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	02:03	02:37	00:34	LINE FAULT
375	6-Aug-20	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	12:06	16:13	04:07	NFBC ISSUED
376	6-Aug-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	11:55	14:29	02:34	MAIN SUPPLY FAILURE
377	6-Aug-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	11:55	14:29	02:34	MAIN SUPPLY FAILURE
378	6-Aug-20	HASSAN	66	HASSN22-HN PURA	HASSAN_220	00:55	12:55	12:00	LINE FAULT
379	6-Aug-20	HASSAN	66	HV1	BYACHANAHALLI_66	23:05	23:10	00:05	TRANSFORMER FAULT
380	6-Aug-20	HASSAN	66	HV1	KANDLI_66	11:35	12:20	00:45	LINE CLEAR AVAILED
381	6-Aug-20	HASSAN	66	HV1	SAKLESHPURA_66	10:42	10:57	00:15	TRANSFORMER FAULT
382	6-Aug-20	HASSAN	66	HV1	SOMANAHALLI_66	10:18	11:05	00:47	LINE CLEAR AVAILED
383	6-Aug-20	HASSAN	66	IDLE	TAVARECHANAHALLI_66	12:00	13:00	01:00	MAIN SUPPLY FAILURE
384	6-Aug-20	HASSAN	66	KANDLI-HASSAN	KANDLI_66	02:30	02:45	00:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
385	6-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	2:25 (5.08.2020)	1:40 (6.08.2020)	26:14 hrs	LINE CHARGED
386	6-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	01:50	02:30	00:40	LINE FAULT
387	6-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	02:35	16:14	13:39	LINE FAULT
388	6-Aug-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	12:18	13:35	01:17	MAIN SUPPLY FAILURE
389	6-Aug-20	HASSAN	66	LV2	MRSMG_220	11:57	12:26	00:29	HAND TRIPPED
390	6-Aug-20	HASSAN	66	LV2	MRSMG_220	12:28	12:35	00:07	HAND TRIPPED
391	6-Aug-20	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	20:49	21:03	00:14	LINE FAULT
392	6-Aug-20	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	22.54 (6.08.2020)			LINE OPEN:LINE CLEAR AVAILED
393	6-Aug-20	HASSAN	66	MRSSHM-BD-1	MRSMG_220	11:54	13:08	01:14	LINE CLEAR AVAILED
394	6-Aug-20	HASSAN	66	MRSSHM-BD-2	MRSMG_220	11:54	13:08	01:14	LINE CLEAR AVAILED
395	6-Aug-20	HASSAN	66	MRSSHM-DVG2	MRSMG_220	11:56	13:02	01:06	LINE CLEAR AVAILED
396	6-Aug-20	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	11:56	13:02	01:06	LINE CLEAR AVAILED
397	6-Aug-20	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	5:45 (5.08.2020)	16:14 (6.08.2020)	34:28 hrs	LINE CHARGED
398	6-Aug-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	13:30	13:35	00:05	LINE CLEAR AVAILED
399	6-Aug-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:37	18:30	01:53	NFBC ISSUED
400	6-Aug-20	HASSAN	110	HV1	BANTWAL_110	09:51	11:00	01:09	LINE CLEAR AVAILED
401	6-Aug-20	HASSAN	110	HV1	MOODABIDRE_110	18:40	18:50	00:10	TRANSFORMER FAULT
402	6-Aug-20	HASSAN	110	HV1	NANDIKUR_110	10:27	13:18	02:51	LINE CLEAR AVAILED
403	6-Aug-20	HASSAN	110	HV2	BHADRAVATHI_110	09:45	10:45	01:00	LINE CLEAR AVAILED
404	6-Aug-20	HASSAN	110	KADUR-YGTI	KADUR_220	06:53	08:44	01:51	LINE FAULT
405	6-Aug-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:36	18:30	01:54	LINE CLEAR AVAILED
406	6-Aug-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	20:41	21:26	00:45	LINE FAULT
407	6-Aug-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	20:27	20:41	00:14	LINE FAULT
408	6-Aug-20	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	14:43	15:32	00:49	LINE CLEAR AVAILED
409	6-Aug-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:07 (6.08.2020)			LINE OPEN:LINE FAULT
410	6-Aug-20	HASSAN	220	HV3	MRSMG_220	09:58	10:59	01:01	LINE CLEAR AVAILED
411	6-Aug-20	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:25	13:57	03:32	LINE CLEAR AVAILED
412	6-Aug-20	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:26	13:57	03:31	LINE CLEAR AVAILED
413	6-Aug-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	17:43	19:05	01:22	LINE CLEAR AVAILED
414	6-Aug-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	03:50	19:06	15:16	LINE FAULT
415	6-Aug-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	22:07 (6.08.2020)			LINE OPEN:LINE FAULT
416	6-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:13	19:56	03:43	LINE CLEAR AVAILED
417	6-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
418	6-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
419	6-Aug-20	MYSURU	66	PERIAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	18:40 (05.08.2020)	12:31	**17:51 HRS**	NFBC ISSUED
420	6-Aug-20	MYSURU	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	10:20	12:40	2:20	LINE CLEAR AVAILED
421	6-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	19:05	20:31	1:26	LINE FAULT
422	6-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	20:34	20:40	0:05	HAND TRIPPED
423	6-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	20:40	23:03	2:23	LINE CLEAR AVAILED
424	6-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)			LINE OPEN:LINE CLEAR AVAILED
425	6-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	9:10 (05.08.2020)	19:05	**33:55 HRS**	LINE CHARGED
426	6-Aug-20	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	19:25 (05.08.2020)	10:25	**14:59 HRS**	NFBC ISSUED
427	6-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	13:07	13:15	0:08	MAIN SUPPLY FAILURE
428	6-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)	17:37(06.08.2020)	1738hrs	LINE CHARGED
429	6-Aug-20	TUMKUR	66	KUKKAWADA-LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:59	15:14	10:14	LINE FAULT
430	6-Aug-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	4:59	5:10	0:10	LINE FAULT
431	6-Aug-20	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	11:14	13:50	2:36	LINE CLEAR AVAILED
432	6-Aug-20	TUMKUR	66	TR-1	BHAKTARAHALLI_66	16:51	18:37	1:45	LINE CLEAR AVAILED
433	6-Aug-20	TUMKUR	66	TR-1	DAVANGERE_66	12:33	13:01	0:28	LINE CLEAR AVAILED
434	6-Aug-20	TUMKUR	66	TR-1	DEVARAHALLI_66	15:35	15:56	0:21	LINE CLEAR AVAILED
435	6-Aug-20	TUMKUR	66	TR-1	KANCHIPURA_66	14:08	14:21	0:12	TRANSFORMER FAULT
436	6-Aug-20	TUMKUR	66	TR-1	KANCHIPURA_66	17:04	17:17	0:13	TRANSFORMER FAULT
437	6-Aug-20	TUMKUR	66	TR-1	KATTIGE_66	11:34	12:02	0:28	LINE CLEAR AVAILED
438	6-Aug-20	TUMKUR	66	TR-1	KATTIGE_66	13:44	15:33	1:48	LINE CLEAR AVAILED
439	6-Aug-20	TUMKUR	66	TR-1	KATTIGE_66	16:34	17:18	0:44	LINE CLEAR AVAILED
440	6-Aug-20	TUMKUR	66	TR-1	LINGDHALLI_66	21:04	21:20	0:15	TRANSFORMER FAULT
441	6-Aug-20	TUMKUR	66	TR-1	MYLANAHALLI_66	13:01	13:08	0:07	TRANSFORMER FAULT
442	6-Aug-20	TUMKUR	66	TR-1	MYLANAHALLI_66	14:49	15:01	0:11	TRANSFORMER FAULT
443	6-Aug-20	TUMKUR	66	TR-1	MYLANAHALLI_66	16:28	16:38	0:10	TRANSFORMER FAULT
444	6-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN : TRANSFORMER FAULT
445	6-Aug-20	TUMKUR	66	TR-2	BUKKAPATNA_66	15:10	15:59	0:49	HAND TRIPPED
446	6-Aug-20	TUMKUR	66	TR-2	HALUVAGALU_66	13:38	13:47	0:09	TRANSFORMER FAULT
447	6-Aug-20	TUMKUR	66	TR-2	HALUVAGALU_66	14:22	14:29	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
448	6-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
449	6-Aug-20	TUMKUR	220	NEELAGUNDA220kV- GUTTUR 220kV	NEELAGUNDA_220	12:09	12:38	0:28	LINE FAULT
450	6-Aug-20	TUMKUR	220	TR-3	HIRIYUR_220	12:50	12:58	0:08	TRANSFORMER FAULT
451	7-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN:LINE CLEAR AVAILED
452	7-Aug-20	BAGALKOT	110	11/33KV,HV2	GAJENDRAGAD_110 & RRB 1&2_33	14:34	14:41	0:07	TRANSFORMER FAULT
453	7-Aug-20	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	13:16	13:26	0:10	TRANSFORMER FAULT
454	7-Aug-20	BAGALKOT	110	110/11KV, HV4	MKHUBLI_110	15:31	16:02	0:31	LINE CLEAR AVAILED
455	7-Aug-20	BAGALKOT	110	110/11KV,HV 2	ANKOLA_110	11:01	17:35	6:34	LINE CLEAR AVAILED
456	7-Aug-20	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:44	19:03	8:19	LINE CLEAR AVAILED
457	7-Aug-20	BAGALKOT	110	110/11KV,HV-1	BEDI_110	17:29	19:44	2:15	LINE CLEAR AVAILED
458	7-Aug-20	BAGALKOT	110	110/33KV,HV1	YARAGATTI_110,BOSCH_33,CHUNCHNUR_33,SHIVAPUR_33	17:43	18:25	0:42	LINE CLEAR AVAILED
459	7-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
460	7-Aug-20	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	23:32 (06.08.2020)	9:51 (07.08.2020)	10:19hrs	TRANSFORMER CHARGED
461	7-Aug-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	14:18 (06.08.2020)	6:46 (07.08.2020)	16:28hrs	TRANSFORMER CHARGED
462	7-Aug-20	BAGALKOT	110	BAGALKOT-BAGALKOT 2	BAGALKOT_110	10:22	10:40	0:18	HAND TRIPPED
463	7-Aug-20	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	10:22	10:45	0:23	HAND TRIPPED
464	7-Aug-20	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	10:22	10:41	0:19	HAND TRIPPED
465	7-Aug-20	BAGALKOT	110	BAGALKOT-LOKAPUR1	LOKAPUR_110	10:22	10:42	0:20	HAND TRIPPED
466	7-Aug-20	BAGALKOT	110	BAGALKOT-NAVANAGAR 1	NAVANAGAR(B)_110	10:22	10:41	0:19	HAND TRIPPED
467	7-Aug-20	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	10:22	10:41	0:19	HAND TRIPPED
468	7-Aug-20	BAGALKOT	110	BAGEWADI- MUDDEBIHAL	MUDDEBIHAL_110	9:54	10:45	0:51	HAND TRIPPED
469	7-Aug-20	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	9:58	10:23	0:25	HAND TRIPPED
470	7-Aug-20	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	9:57	10:14	0:17	HAND TRIPPED
471	7-Aug-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	9:57	10:12	0:15	HAND TRIPPED
472	7-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
473	7-Aug-20	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	9:58	11:58	2:00	LINE CLEAR AVAILED
474	7-Aug-20	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	20:15	20:56	0:41	HAND TRIPPED
475	7-Aug-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	9:58	11:58	2:00	LINE CLEAR AVAILED
476	7-Aug-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	20:15	20:53	0:38	HAND TRIPPED
477	7-Aug-20	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	6:01	6:37	0:36	LINE FAULT
478	7-Aug-20	BAGALKOT	110	DAMBAL-SUZLON(3)	DAMBAL_110	17:10	19:26	2:16	LINE FAULT
479	7-Aug-20	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	10:12	10:37	0:25	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
480	7-Aug-20	BAGALKOT	110	GADAG-DAMBAL	DAMBAL_110	10:12	10:37	0:25	HAND TRIPPED
481	7-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
482	7-Aug-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL	HIDIKAL_110	22:47 (8.8.2020)			LINE OPEN:LINE FAULT
483	7-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
484	7-Aug-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN:LINE CLEAR AVAILED
485	7-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
486	7-Aug-20	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	12:03	12:38	0:35	HAND TRIPPED
487	7-Aug-20	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	18:11	20:39	2:28	LINE CLEAR AVAILED
488	7-Aug-20	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	23:40 (08.08.2020)			LINE OPEN:LINE CLEAR AVAILED
489	7-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
490	7-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
491	7-Aug-20	BAGALKOT	110	LAXMESHWAR- BELLATTI	BELLATTI_110	20:05	20:40	0:35	LINE FAULT
492	7-Aug-20	BAGALKOT	110	MUNDARGI-VIJAY SUGARS	MUNDARAGI_110, SINGATALUR_33,VIJAY SUGARS IPP	9:56	10:44	0:48	LINE FAULT
493	7-Aug-20	BAGALKOT	110	NAGJHARI-1-AMBEWADI	AMBEWADI_220	12:34	12:51	0:17	LINE FAULT
494	7-Aug-20	BAGALKOT	110	RANEBENNUR220-HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	14:16	17:53	3:37	LINE CLEAR AVAILED
495	7-Aug-20	BAGALKOT	110	RATTIHALLI-HIREKERUR	STATION NOT AFFECTED RATTIHALLI_110	17:15 (30.07.2020)	16:49 (07.08.2020)	191:34hrs	LINE CHARGED
496	7-Aug-20	BAGALKOT	110	RON-GAMESH	STATION NOT AFFECTED RON_110	10:48	10:56	0:08	HAND TRIPPED
497	7-Aug-20	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED RON_110	10:48	10:53	0:05	HAND TRIPPED
498	7-Aug-20	BAGALKOT	110	SHIRATTI-BPCL 1	SHIRATTI_110,BPCL _IPP	10:51	11:54	1:03	LINE CLEAR AVAILED
499	7-Aug-20	BAGALKOT	110	SHIRATTI-BPCL 2	SHIRATTI_110,BPCL _IPP	10:51	12:11	1:20	LINE CLEAR AVAILED
500	7-Aug-20	BAGALKOT	110	SHIRATTI-LAXMESHWAR	STATION NOT AFFECTED SHIRATTI_110	10:51	11:06	0:15	HAND TRIPPED
501	7-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
502	7-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI1	STATION NOT AFFECTED SIRSI_220	20:39	23:41	3:02	LINE CLEAR AVAILED
503	7-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	16:50 (06.08.2020)	17:06 (07.08.2020)	24:16hrs	LINE CHARGED
504	7-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	17:07 (07.08.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
505	7-Aug-20	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_IPP	22:33	22:56	0:23	LINE FAULT
506	7-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
507	7-Aug-20	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	9:54	10:26	0:32	LINE FAULT
508	7-Aug-20	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	15:39 (04.08.2020)	3:24:00 PM (7.8.2020)	71:55hrs	LINE CHARGED
509	7-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
510	7-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	9:54	10:22	0:28	LINE FAULT
511	7-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
512	7-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
513	7-Aug-20	BAGALKOT	220	BAGEWADI-FORTUNE 2	BAGEWADI_220	9:54	10:16	0:22	LINE FAULT
514	7-Aug-20	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	9:54	10:23	0:29	LINE FAULT
515	7-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
516	7-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	23:10 (7.8.2020)			LOAD CURTAILMENT
517	7-Aug-20	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:11:00 AM (7.8.2020)			LOAD CURTAILMENT
518	7-Aug-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:22 (7.8.2020)			LOAD CURTAILMENT
519	7-Aug-20	BAGALKOT	220	GADAG- HARTI 1&2	GADAG_220	10:03	10:25	0:22	HAND TRIPPED
520	7-Aug-20	BAGALKOT	220	GADAG-BAGALKOT 2	GADAG_220	9:54	11:55	2:01	LINE CLEAR AVAILED
521	7-Aug-20	BAGALKOT	220	GADAG-DHONI 1&2	GADAG_220	9:56	10:35	0:39	LINE FAULT
522	7-Aug-20	BAGALKOT	220	HARTI1- BIDNAL	BIDNAL_220	14:11 (06.08.2020)	9:11 (7.8.2020)	10:00hrs	LINE CHARGED
523	7-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
524	7-Aug-20	BAGALKOT	220	HUBLI-SIRSI 1	HUBLI_220	14:48 (06.08.2020)			LOAD CURTAILMENT
525	7-Aug-20	BAGALKOT	220	HUBLI-SIRSI 2	HUBLI_220	19:23 (06.08.2020)			LOAD CURTAILMENT
526	7-Aug-20	BENGALURU	66	ADUGODI - HAL 1	ADUGODI, BOSCH (EHT)	11:40	12:01	00:21	LOAD CHANGEOVER
527	7-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
528	7-Aug-20	BENGALURU	66	HV1	L R BANDE	13:32	13:44	00:12	TRANSFORMER FAULT
529	7-Aug-20	BENGALURU	66	HV1	KONDASPURA	11:49	14:37	02:48	LINE CLEAR AVAILED
530	7-Aug-20	BENGALURU	66	HV1	NELEMANGALA 66	14:37	14:42	00:04	TRANSFORMER FAULT
531	7-Aug-20	BENGALURU	66	HV2	KONDASPURA	13:10	14:30	01:20	LINE CLEAR AVAILED
532	7-Aug-20	BENGALURU	66	HV2	TEKAL	15:48	15:55	00:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
533	7-Aug-20	BENGALURU	66	HV2	SOMAYAJJANAHALLI	16:23	16:28	00:05	TRANSFORMER FAULT
534	7-Aug-20	BENGALURU	66	HV3	CB PURA I/A	14:08	14:17	00:09	TRANSFORMER FAULT
535	7-Aug-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
536	7-Aug-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	07:12	07:53	00:41	LOAD CURTAILMENT
537	7-Aug-20	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	13:10	13:17	00:07	LOAD CHANGEOVER
538	7-Aug-20	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	11:47	12:30	00:43	LOAD CHANGEOVER
539	7-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
540	7-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
541	7-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
542	7-Aug-20	GULBARGA	66	HV3	ITTAGI_220	11:25	13:00	01:35	LINE CLEAR AVAILED
543	7-Aug-20	GULBARGA	66	ITTAGI-HUVINAHADAGALI1	HUVINAHADAGALI_66, HOLAGUNDI_66	18:50	18:57	00:07	LINE FAULT
544	7-Aug-20	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	10:10	10:22	00:12	LINE CLEAR AVAILED
545	7-Aug-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,KAMALAPUR_110,SHATAVAHANA_IPP,AGRAWAL_IPP	06:37	06:50	00:13	LINE FAULT
546	7-Aug-20	GULBARGA	110	HUMNABAD220-BHALKI1	DUBALGUNDI_110	15:36	16:28	00:52	LINE CLEAR AVAILED
547	7-Aug-20	GULBARGA	110	KUSTAGI-KUSTAGISOLAR_IPP	KUSTAGI_220	13:55	14:10	00:15	LINE CLEAR AVAILED
548	7-Aug-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	04:11	04:22	00:11	LINE FAULT
549	7-Aug-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110, VADAVATTI_110	04:56	05:06	00:10	LINE FAULT
550	7-Aug-20	GULBARGA	110	RAICHUR-MATMARI, SHAHPUR2	MATMARI_110, GOOGLE_110	07:28	08:00	00:32	LINE CLEAR AVAILED
551	7-Aug-20	GULBARGA	110	SHAHABAD-BAGEWADI1&2	MANDEWAL_110,MORATGI_110, DEVANGOAN_110, AFZALPUR_110, KARAJGI_110, YEDRAMI_110	09:20	17:50	08:30	LINE CLEAR AVAILED
552	7-Aug-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP,ASKI_110, HUNASGI_110	07:35	07:41	00:06	LINE FAULT
553	7-Aug-20	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	19:45	21:49	02:04	LINE CLEAR AVAILED
554	7-Aug-20	GULBARGA	110	SINDHANOOR220-RAICHUR2	MASKI_110,MUDDAPUR_110	02:30	02:40	00:10	LINE FAULT
555	7-Aug-20	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	05:00	07:00	02:00	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
556	7-Aug-20	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	22:30	22:45	00:15	LINE FAULT
557	7-Aug-20	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	16:40	19:40	03:00	LINE CLEAR AVAILED
558	7-Aug-20	GULBARGA	220	LINGAPUR-ARESS STEELS_IPP	LINGAPUR_220	10:19	14:37	04:18	LINE CLEAR AVAILED
559	7-Aug-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	20:16(7/8/2020)			LINE OPEN:LINE CLEAR AVAILED
560	7-Aug-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:35	19:55	04:20	NFBC ISSUED
561	7-Aug-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	15:35	19:55	04:20	NFBC ISSUED
562	7-Aug-20	HASSAN	66	CRPATNA2-MATTANAVILE	CHANNARAYAPATNA_220	00:20	13:28	13:08	LINE FAULT
563	7-Aug-20	HASSAN	66	CRPATNA2-SBELAGOLA	CHANNARAYAPATNA_220	10:29	13:28	02:59	LINE CLEAR AVAILED
564	7-Aug-20	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	06:06	06:15	00:09	LINE FAULT
565	7-Aug-20	HASSAN	66	HV1	BYACHANAHALLI_66	13:03	14:20	01:17	LINE CLEAR AVAILED
566	7-Aug-20	HASSAN	66	HV1	SAKLESHPURA_66	10:29	10:39	00:10	TRANSFORMER FAULT
567	7-Aug-20	HASSAN	66	HV1	SINGAPURA_66	11:25	12:38	01:13	LINE CLEAR AVAILED
568	7-Aug-20	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	22.54 (6.08.2020)	13:55 (7.08.2020)	15:00 hrs	NFBC ISSUED
569	7-Aug-20	HASSAN	66	MRSSHM-BD-1	MRSMG_220	15:10	19:55	04:45	NFBC ISSUED
570	7-Aug-20	HASSAN	66	UPCL-HASSAN1	upcl_gen	21:56 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
571	7-Aug-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:37	13:15	01:38	LINE CLEAR AVAILED
572	7-Aug-20	HASSAN	110	HV2	BHADRAVATHI_110	09:33	10:35	01:02	LINE CLEAR AVAILED
573	7-Aug-20	HASSAN	110	HV2	SHIKARIPURA_110	11:53	12:27	00:34	LINE CLEAR AVAILED
574	7-Aug-20	HASSAN	110	JOG110-MGHE	JOG110	23:37	23:54	00:17	LINE FAULT
575	7-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	21:10 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
576	7-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	11:53	20:49	08:56	LINE FAULT
577	7-Aug-20	HASSAN	110	JOG-NK2	mghejog_gen	23:36 (7.08.2020)			LINE OPEN:LINE FAULT
578	7-Aug-20	HASSAN	110	JOG-NK2	mghejog_gen	18:10	20:35	02:25	LINE CLEAR AVAILED
579	7-Aug-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:58	11:25	00:27	HAND TRIPPED
580	7-Aug-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	09:12	12:33	03:21	LINE CLEAR AVAILED
581	7-Aug-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	09:12	12:33	03:21	NFBC ISSUED
582	7-Aug-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:07 (6.08.2020)	12:42 (7.08.2020)	14:34 hrs	LINE CHARGED
583	7-Aug-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	10:35	13:58	03:23	NFBC ISSUED
584	7-Aug-20	HASSAN	220	MRSSHM-VARAHI3	MRSMG_220	12:41	15:07	02:26	LINE FAULT
585	7-Aug-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	22:07 (6.08.2020)	12:42 (7.08.2020)	14:34 hrs	LINE CHARGED
586	7-Aug-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:41	15:07	02:26	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
587	7-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
588	7-Aug-20	MYSURU	66	BANNUR-VAJMANGALA	NO STATIONS EFFECTED	11:19	11:25	0:06	LINE FAULT
589	7-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	2:47 (06.08.2020)			LINE OPEN:LINE FAULT
590	7-Aug-20	MYSURU	66	HV1	HANNUR_66	16:27	16:33	0:06	HAND TRIPPED
591	7-Aug-20	MYSURU	66	HV1	SANIVARASANTHE_66	14:43	14:49	0:05	TRANSFORMER FAULT
592	7-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
593	7-Aug-20	MYSURU	66	HV2	BASARALU_66	11:34	12:12	0:38	LINE CLEAR AVAILED
594	7-Aug-20	MYSURU	66	HV2	ELAVALA_66	13:06	14:44	1:37	LINE CLEAR AVAILED
595	7-Aug-20	MYSURU	66	HV2	GVGUDI_66	11:48	14:50	3:01	LINE CLEAR AVAILED
596	7-Aug-20	MYSURU	66	HV2	HANNUR_66	16:35	16:41	0:05	HAND TRIPPED
597	7-Aug-20	MYSURU	66	HV2	HDKOTE_66	7:45	8:06	0:20	LINE CLEAR AVAILED
598	7-Aug-20	MYSURU	66	HV2	SATHEGALA_66	12:28	13:42	1:13	LINE CLEAR AVAILED
599	7-Aug-20	MYSURU	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66	12:50	13:17	0:27	MAIN SUPPLY FAILURE
600	7-Aug-20	MYSURU	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	9:03	9:12	0:08	LINE FAULT
601	7-Aug-20	MYSURU	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	9:03	9:12	0:09	LINE FAULT
602	7-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	10:43 (07.08.2020)			LINE OPEN:LINE CLEAR AVAILED
603	7-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)			LINE OPEN:LINE CLEAR AVAILED
604	7-Aug-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	15:07	16:32	1:24	LINE CLEAR AVAILED
605	7-Aug-20	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	07:14:15	07:48:55	0:34	LOAD CURTAILMENT
606	7-Aug-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	16:01:03	19:55:39	3:54	LINE FAULT
607	7-Aug-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	07:17	07:57	0:40	LOAD CURTAILMENT
608	7-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
609	7-Aug-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	19:07:07	19:15:56	0:08	LINE FAULT
610	7-Aug-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:47:47	11:54:22	0:06	LINE FAULT
611	7-Aug-20	TUMKUR	66	PALLAGATTA-NEELAGUNDA	PALLAGATTE_66	03:40:38	03:54:11	0:13	MAIN SUPPLY FAILURE
612	7-Aug-20	TUMKUR	66	PALLAGATTA-NEELAGUNDA	PALLAGATTE_66	04:06:10	06:30:52	2:24	MAIN SUPPLY FAILURE
613	7-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	08:18:13	17:49:42	9:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
614	7-Aug-20	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	16:07:51	16:15:29	0:07	HAND TRIPPED
615	7-Aug-20	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	14:27:43	15:24:08	0:56	HAND TRIPPED
616	7-Aug-20	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	16:07:57	16:17:29	0:09	HAND TRIPPED
617	7-Aug-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:54:40	16:20:15	4:25	LINE CLEAR AVAILED
618	7-Aug-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	16:27:35	17:58:05	1:30	LINE FAULT
619	7-Aug-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	16:08:14	16:20:23	0:12	HAND TRIPPED
620	7-Aug-20	TUMKUR	66	TR-1	DEVARAHALLI_66	14:05:25	14:19:55	0:14	HAND TRIPPED
621	7-Aug-20	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	16:14:57	16:32:25	0:17	HAND TRIPPED
622	7-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN : TRANSFORMER FAULT
623	7-Aug-20	TUMKUR	66	TR-2	BADDIHALLI_66	11:18:43	11:39:09	0:20	LINE CLEAR AVAILED
624	7-Aug-20	TUMKUR	66	TR-2	CHITRADURGA_66	17:24:32	17:31:07	0:06	TRANSFORMER FAULT
625	7-Aug-20	TUMKUR	66	TR-2	URDIGERE_66	16:07:50	17:12:34	1:04	LINE CLEAR AVAILED
626	7-Aug-20	TUMKUR	66	TR-2	URDIGERE_66	19:40:03	19:55:55	0:15	LINE CLEAR AVAILED
627	7-Aug-20	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	16:00:02	19:55:44	3:55	LINE CLEAR AVAILED
628	7-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	14:41:44	15:01:25	0:19	LINE CLEAR AVAILED
629	7-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	16:09:32	17:12:05	1:02	LINE CLEAR AVAILED
630	7-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	19:29:53	19:59:11	0:29	LINE CLEAR AVAILED
631	7-Aug-20	TUMKUR	110	TR-1	TURUVEKERE_110	05:38:24	06:05:00	0:26	TRANSFORMER FAULT
632	7-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
633	8-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN:LINE CLEAR AVAILED
634	8-Aug-20	BAGALKOT	110	11/33KV,HV2	GAJENDRAGAD_110 & RRB 1&2_33	11:00	11:36	0:36	LINE CLEAR AVAILED
635	8-Aug-20	BAGALKOT	110	110/11KV,HV 3	BIJAPUR_110	21:17	21:34	0:17	TRANSFORMER FAULT
636	8-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
637	8-Aug-20	BAGALKOT	110	ANKOLA-KUMATA(L2)	KUMATA_110	14:58	14:59	0:01	LOAD CHANGEOVER
638	8-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
639	8-Aug-20	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	10:58	11:30	0:32	HAND TRIPPED
640	8-Aug-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	10:57	11:30	0:33	HAND TRIPPED
641	8-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
642	8-Aug-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL	HIDIKAL_110	22:47 (7.8.2020)	10:16 (08.08.2020)	11:29hrs	LINE CHARGED
643	8-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
644	8-Aug-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)	18:10 (8.8.2020)	214:55hrs	LINE CHARGED
645	8-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
646	8-Aug-20	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	23:40 (07.08.2020)	14:56 (08.08.2020)	15:16hrs	LINE CHARGED
647	8-Aug-20	BAGALKOT	110	KARWAR -KUMATA	KUMATA_110	8:16	14:39	6:23	LINE FAULT
648	8-Aug-20	BAGALKOT	110	KARWAR220- KUMTA(ARGA)	KUMATA_110	8:15	14:38	6:23	LINE FAULT
649	8-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
650	8-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
651	8-Aug-20	BAGALKOT	110	LAXMESHWAR- BELLATTI	BELLATTI_110	10:55	11:17	0:22	LINE FAULT
652	8-Aug-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:10	12:25	0:15	HAND TRIPPED
653	8-Aug-20	BAGALKOT	110	RANEBENNUR220-TUMMINAKATTI	TUMMINAKATTI_110	23:03	23:15	0:12	LINE FAULT
654	8-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
655	8-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI 2	STATION NOT AFFECTED SIRSI_220	17:44 (05.08.2020)	8:31 (08.08.2020)	62:87hrs	LINE CHARGED
656	8-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI 2	STATION NOT AFFECTED SIRSI_220	19:15 (08.08.2020)			LINE OPEN:LINE CLEAR AVAILED
657	8-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI1	STATION NOT AFFECTED SIRSI_220	19:16	21:35	2:19	LINE CLEAR AVAILED
658	8-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	17:07 (07.08.2020)	14:56 (08.08.2020)	21:49hrs	LINE CHARGED
659	8-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	14:56	19:01	4:05	LINE FAULT
660	8-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
661	8-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
662	8-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
663	8-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
664	8-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
665	8-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	23:10 (7.8.2020)	8:08 (8.8.2020)	8:58hrs	LINE CHARGED
666	8-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	22:27 (8.8.2020)			LOAD CURTAILMENT
667	8-Aug-20	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:11:00 AM (7.8.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
668	8-Aug-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:22 (7.8.2020)			LOAD CURTAILMENT
669	8-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	13:57 (08.08.2020)			LINE OPEN:LINE CLEAR AVAILED
670	8-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
671	8-Aug-20	BAGALKOT	220	HUBLI-SIRSI 1	HUBLI_220	14:48 (06.08.2020)	21:48 (08.08.2020)	55:00hrs	LINE CHARGED
672	8-Aug-20	BAGALKOT	220	HUBLI-SIRSI 2	HUBLI_220	19:23 (06.08.2020)	21:48 (08.08.2020)	50:25hrs	LINE CHARGED
673	8-Aug-20	BAGALKOT	220	KADRA 1 -KARWAR	KARWAR_220	8:16	11:21	3:05	LINE FAULT
674	8-Aug-20	BAGALKOT	220	KADRA 2-KARWAR	KARWAR_220	8:16	8:52	0:36	LINE FAULT
675	8-Aug-20	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	11:35	11:48	00:13	LOAD CHANGEOVER
676	8-Aug-20	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	16:53	16:57	00:04	LOAD CHANGEOVER
677	8-Aug-20	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:10	11:14	00:04	LOAD CHANGEOVER
678	8-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
679	8-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:27	18:04	00:37	LINE FAULT
680	8-Aug-20	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	11:50	11:56	00:06	LOAD CHANGEOVER
681	8-Aug-20	BENGALURU	66	JAYADEVA - SARAKKI 1	JAYADEVA	16:26	16:32	00:06	LOAD CHANGEOVER
682	8-Aug-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)	11:50(08/08/2020)	1584:12HRS	LINE CHARGED
683	8-Aug-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	12:32	13:23	00:51	LINE CLEAR AVAILED
684	8-Aug-20	BENGALURU	66	KUNDANA - DB PURA 220	KUNDANA	10:35	17:54	07:19	LINE CLEAR AVAILED
685	8-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
686	8-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
687	8-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
688	8-Aug-20	GULBARGA	66	HV1	KUDLIGI_66	10:50	10:55	00:05	TRANSFORMER FAULT
689	8-Aug-20	GULBARGA	66	ITTAGI-HIREHADAGLI1	HIREHADAGLI_66	18:58	19:15	00:17	LINE FAULT
690	8-Aug-20	GULBARGA	66	ITTAGI-KUDLIGI1,2	KOGALI_66, KUDLIGI_66, HANSI_66,CJHALLI_66,HOSAHALLI_66, BANVEKAL_66, GUDEKOTE_66, CHORNOOR_66	10:35	15:54	05:19	LINE CLEAR AVAILED
691	8-Aug-20	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,HOSAHALLI_66, BANVEKAL_66, GUDEKOTE_66, CHORNOOR_66	06:10	15:54	09:44	LINE FAULT
692	8-Aug-20	GULBARGA	66	ITTAGI-TAMBRAHALLI	TABRAHALLI_66	06:10	06:40	00:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
693	8-Aug-20	GULBARGA	110	HV1, HV2	HANUMANAL_110	08:45	09:25	00:40	LINE CLEAR AVAILED
694	8-Aug-20	GULBARGA	110	HV2	DEODURGA_110	12:45	13:05	00:20	LINE CLEAR AVAILED
695	8-Aug-20	GULBARGA	110	HV2	YEDRAMI_110	17:49	18:02	00:13	LINE CLEAR AVAILED
696	8-Aug-20	GULBARGA	110	HV4	YELBURGA_110	23:34	23:45	00:11	TRANSFORMER FAULT
697	8-Aug-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	20:11	20:21	00:10	LINE FAULT
698	8-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	01:25	01:30	00:05	LINE FAULT
699	8-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	01:25	01:30	00:05	LINE FAULT
700	8-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	07:40	07:56	00:16	LINE FAULT
701	8-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:40	18:45	00:05	LINE FAULT
702	8-Aug-20	GULBARGA	110	SHAHPUR-SHAHBAD	SHAHABAD_220	14:08	14:28	00:20	LINE CLEAR AVAILED
703	8-Aug-20	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	01:16	01:26	00:10	LINE FAULT
704	8-Aug-20	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	02:40	02:50	00:10	LINE FAULT
705	8-Aug-20	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	04:20	04:35	00:15	LINE FAULT
706	8-Aug-20	GULBARGA	220	HV2	ITTAGI_220	06:10	06:20	00:10	TRANSFORMER FAULT
707	8-Aug-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	20:16(7/8/2020)	21:18(8.8.2020)	25:02HRS	LINE CHARGED
708	8-Aug-20	HASSAN	66	HV1	KUDLIGERE_66	00:50	01:00	00:10	TRANSFORMER FAULT
709	8-Aug-20	HASSAN	66	HV1	KUDLIGERE_66	05:05	05:20	00:15	HAND TRIPPED
710	8-Aug-20	HASSAN	66	HV2	HOLALUR_66	03:40	04:52	01:12	TRANSFORMER FAULT
711	8-Aug-20	HASSAN	66	HV2	HOLALUR_66	04:52	06:50	01:58	TRANSFORMER FAULT
712	8-Aug-20	HASSAN	66	HV2	HOLALUR_66	08:55	12:27	03:32	LINE CLEAR AVAILED
713	8-Aug-20	HASSAN	66	HV2	HOLALUR_66	12:27	12:50	00:23	TRANSFORMER FAULT
714	8-Aug-20	HASSAN	66	HV2	SINGAPURA_66	11:05	13:05	02:00	LINE CLEAR AVAILED
715	8-Aug-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:00	13:35	00:35	LINE FAULT
716	8-Aug-20	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	14:30	17:50	03:20	NFBC ISSUED
717	8-Aug-20	HASSAN	110	JOG-JLT3	mghejog_gen	7:10 (8.08.2020)			LINE OPEN:LINE CLEAR AVAILED
718	8-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	21:10 (7.08.2020)	17:02 (8.08.2020)	19:51 hrs	LINE CHARGED
719	8-Aug-20	HASSAN	110	JOG-NK2	mghejog_gen	23:36 (7.08.2020)			LINE OPEN:LINE FAULT
720	8-Aug-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	04:28	04:42	00:14	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
721	8-Aug-20	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	14:33	17:48	03:15	LINE CLEAR AVAILED
722	8-Aug-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	04:27	04:33	00:06	LINE FAULT
723	8-Aug-20	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	14:27	16:37	02:10	LINE FAULT
724	8-Aug-20	HASSAN	220	MRSSHM-VARAHI3	MRSMG_220	13:07	17:50	04:43	LINE FAULT
725	8-Aug-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	13:06	17:52	04:46	LINE FAULT
726	8-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:56 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
727	8-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
728	8-Aug-20	MYSURU	66	BG PURA-CHANDALLY	CHANDALLI_66	11:49	15:30	3:41	NFBC ISSUED
729	8-Aug-20	MYSURU	66	BG PURA-SFC	NO STATIONS EFFECTED.	7:50	11:36	3:46	NFBC ISSUED
730	8-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	2:47 (06.08.2020)			LINE OPEN:LINE FAULT
731	8-Aug-20	MYSURU	66	HV1	TNARASIPURA_66	9:00	16:38	7:38	LINE CLEAR AVAILED
732	8-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
733	8-Aug-20	MYSURU	66	HV2	TNARASIPURA_66	9:00	16:38	7:38	LINE CLEAR AVAILED
734	8-Aug-20	MYSURU	66	HV2	MALAVALLI_66	15:54	17:53	1:58	LINE CLEAR AVAILED
735	8-Aug-20	MYSURU	66	HV2	MALAVALLI_66	18:13	18:37	0:24	LINE CLEAR AVAILED
736	8-Aug-20	MYSURU	66	K HONALAGERE-IGGLUR	K_HONNALGERE_66	13:40	14:24	0:44	MAIN SUPPLY FAILURE
737	8-Aug-20	MYSURU	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	12:35	15:20	2:44	LINE CLEAR AVAILED
738	8-Aug-20	MYSURU	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	12:35	15:20	2:45	LINE CLEAR AVAILED
739	8-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	10:43 (07.08.2020)			LINE OPEN:LINE CLEAR AVAILED
740	8-Aug-20	MYSURU	66	PARINAMIPURA-TALAKADU	CHANDALLI_66 THALAKADU_66	18:43	18:49	0:06	LINE FAULT
741	8-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)			LINE OPEN:LINE CLEAR AVAILED
742	8-Aug-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	14:34	14:41	0:06	LINE FAULT
743	8-Aug-20	MYSURU	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	15:54	16:04	0:09	LINE FAULT
744	8-Aug-20	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	15:54	16:04	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
745	8-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
746	8-Aug-20	TUMKUR	66	TR-1	GOWRASAMUDRA_66	18:04	18:13	0:08	TRANSFORMER FAULT
747	8-Aug-20	TUMKUR	66	TR-1	HOLALKERE_66	16:36	17:57	1:20	MAIN SUPPLY FAILURE
748	8-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN : TRANSFORMER FAULT
749	8-Aug-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	14:21	14:37	0:15	LINE CLEAR AVAILED
750	8-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	17:09	17:19	0:09	LINE CLEAR AVAILED
751	8-Aug-20	TUMKUR	110	TR-1	MAYASANDRA_110	14:42	16:11	1:29	TRANSFORMER FAULT
752	8-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
753	8-Aug-20	TUMKUR	110	TR-2	SHETYKERE_110	12:41	13:22	0:40	LINE CLEAR AVAILED
754	9-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
755	9-Aug-20	BAGALKOT	110	110/11KV,HV 2	AINAPUR_110	11:57	12:25	0:28	LINE CLEAR AVAILED
756	9-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
757	9-Aug-20	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	3:04	3:23	0:19	LINE FAULT
758	9-Aug-20	BAGALKOT	110	AMBEWADI-NK2	KAVALAVAD_110	10:25	11:16	0:51	LINE FAULT
759	9-Aug-20	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	4:04	4:25	0:21	LINE FAULT
760	9-Aug-20	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	11:12	13:00	1:48	LINE CLEAR AVAILED
761	9-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
762	9-Aug-20	BAGALKOT	110	CHIKKODI-DKSS CO GEN	CHIKKODI_220	9:57	11:33	1:36	LINE CLEAR AVAILED
763	9-Aug-20	BAGALKOT	110	GADAG-HARTI2	GADAG_220	11:02 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
764	9-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
765	9-Aug-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL	HIDIKAL_110	10:26	10:48	0:22	LOAD CHANGEOVER
766	9-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
767	9-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
768	9-Aug-20	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	23:40 (08.08.2020)			LINE OPEN:LINE CLEAR AVAILED
769	9-Aug-20	BAGALKOT	110	KARWAR220- KUMTA(ARGA)	KUMATA_110	17:09	17:39	0:30	LINE FAULT
770	9-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
771	9-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
772	9-Aug-20	BAGALKOT	110	MAMADAPUR(B)- MATTIHAL	MATTIHAL_110	11:29	13:09	1:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
773	9-Aug-20	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	11:25	13:24	1:59	LINE CLEAR AVAILED
774	9-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
775	9-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI 2	STATION NOT AFFECTED SIRSI_220	19:15 (08.08.2020)	17:40 (09.08.2020)	22:25hrs	LINE CHARGED
776	9-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	17:07 (07.08.2020)			LINE OPEN:LINE FAULT
777	9-Aug-20	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_IPP	4:27	5:42	1:15	LINE FAULT
778	9-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
779	9-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
780	9-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
781	9-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
782	9-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
783	9-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	22:27 (8.8.2020)	9:03 (9.8.2020)	9:36hrs	LINE CHARGED
784	9-Aug-20	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:11:00 AM (7.8.2020)			LOAD CURTAILMENT
785	9-Aug-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:22 (7.8.2020)			LOAD CURTAILMENT
786	9-Aug-20	BAGALKOT	220	HAVERI-NARENDRA 2	HAVERI_220	23:51 (09.08.2020)			LOAD CURTAILMENT
787	9-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	13:57 (08.08.2020)			LINE OPEN:LINE CLEAR AVAILED
788	9-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
789	9-Aug-20	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	16:12	16:32	00:19	LINE CLEAR AVAILED
790	9-Aug-20	BENGALURU	66	BANASAWADI - HEBBALA 220	BANASAWADI	10:52	10:53	00:01	LOAD CHANGEOVER
791	9-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
792	9-Aug-20	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	13:09	13:15	00:05	LINE FAULT
793	9-Aug-20	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	08:23	08:25	00:01	LINE CLEAR AVAILED
794	9-Aug-20	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	13:09	13:15	00:05	LINE FAULT
795	9-Aug-20	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	21:12	21:17	00:04	LINE CLEAR AVAILED
796	9-Aug-20	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	19:15	19:29	00:14	LINE FAULT
797	9-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:37	18:50	00:12	LINE FAULT
798	9-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	22:04	22:09	00:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
799	9-Aug-20	BENGALURU	66	HV1	APPAREL PARK	14:20	14:25	00:05	LINE CLEAR AVAILED
800	9-Aug-20	BENGALURU	66	HV1	ELECTRONIC PH2 SEC 1	12:00	12:07	00:07	TRANSFORMER FAULT
801	9-Aug-20	BENGALURU	66	HV1	ATTUR YELAHANKA	15:14	15:28	00:13	TRANSFORMER FAULT
802	9-Aug-20	BENGALURU	66	HV2	APPAREL PARK	11:10	11:15	00:05	LINE CLEAR AVAILED
803	9-Aug-20	BENGALURU	66	HV2	BMTC	6:04(09/08/2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
804	9-Aug-20	BENGALURU	66	HV3	A STATION	11:42	12:09	00:27	TRANSFORMER FAULT
805	9-Aug-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	03:50	03:59	00:09	LINE FAULT
806	9-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
807	9-Aug-20	BENGALURU	66	SRINIVASPURA - DALASNUR	YELDUR	06:24	06:48	00:23	LINE FAULT
808	9-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
809	9-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
810	9-Aug-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,KAMALAPUR_110,SHATAVAHANA_IPP,AGRAWAL_IPP	09:04	09:28	00:24	LINE CLEAR AVAILED
811	9-Aug-20	GULBARGA	110	HV2	BISIHALLI_110	21:17	21:38	00:21	TRANSFORMER FAULT
812	9-Aug-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	04:51	05:08	00:17	LINE CLEAR AVAILED
813	9-Aug-20	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED
814	9-Aug-20	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWATERWORKS	00:10	00:20	00:10	LINE FAULT
815	9-Aug-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_1PP	SIDHANOOR_220	04:40	05:05	00:25	LINE FAULT
816	9-Aug-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	20:18	20:35	00:17	LINE FAULT
817	9-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
818	9-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
819	9-Aug-20	GULBARGA	220	LINGAPUR-BMMISPAT	LINGAPUR_220	20:55	23:09	02:14	LINE FAULT
820	9-Aug-20	GULBARGA	220	LINGAPUR-GUDEHALLI	GUDEHALLI_220	11:27	14:51	03:24	LINE FAULT
821	9-Aug-20	GULBARGA	220	RAICHUR- JURALA2	RAICHUR_220	19:15	20:33	01:18	LINE FAULT
822	9-Aug-20	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	07:41	07:54	00:13	LINE FAULT
823	9-Aug-20	HASSAN	66	HV1	MAGGE_66	07:25	07:55	00:30	MAIN SUPPLY FAILURE
824	9-Aug-20	HASSAN	66	HV2	MAGGE_66	07:25	07:55	00:30	MAIN SUPPLY FAILURE
825	9-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	07:25	07:55	00:30	LINE FAULT
826	9-Aug-20	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	07:25	07:55	00:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
827	9-Aug-20	HASSAN	110	HV1	BAIKAMPADI_110	09:14	18:35	09:21	MAIN SUPPLY FAILURE
828	9-Aug-20	HASSAN	110	HV2	JOG110	14:36	16:31	01:55	LINE CLEAR AVAILED
829	9-Aug-20	HASSAN	110	HV2	KARAYA_110	07:39	13:05	05:26	TRANSFORMER FAULT
830	9-Aug-20	HASSAN	110	JOG-JLT3	mghejog_gen	7:10 (8.08.2020)	7:53 (9.08.2020)	24:42 hrs	LINE CHARGED
831	9-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	16:43 (9.08.2020)			LINE OPEN:LINE FAULT
832	9-Aug-20	HASSAN	110	JOG-NK2	mghejog_gen	23:36 (7.08.2020)			LINE OPEN:LINE FAULT
833	9-Aug-20	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	09:16	12:56	03:40	LINE CLEAR AVAILED
834	9-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	17:05	17:16	00:11	LINE FAULT
835	9-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21 (9.08.2020)			LINE OPEN:LINE CLEAR AVAILED
836	9-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:56 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
837	9-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
838	9-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	2:47 (06.08.2020)			LINE OPEN:LINE FAULT
839	9-Aug-20	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	9:29	9:37	0:07	LINE FAULT
840	9-Aug-20	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	9:29	9:36	0:06	LINE FAULT
841	9-Aug-20	MYSURU	66	HV1	GUNDULPET_66	1:37	1:45	0:08	TRANSFORMER FAULT
842	9-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
843	9-Aug-20	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	1:37	1:57	0:19	LINE FAULT
844	9-Aug-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	22:11	22:36	0:25	LINE FAULT
845	9-Aug-20	MYSURU	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	9:27	16:25	6:57	NFBC ISSUED
846	9-Aug-20	MYSURU	66	KIRUGAVALU-VADKEPURA	NO STATIONS EFFECTED	12:15	12:22	0:06	MAIN SUPPLY FAILURE
847	9-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	10:43 (07.08.2020)			LINE OPEN:LINE CLEAR AVAILED
848	9-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
849	9-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)			LINE OPEN:LINE CLEAR AVAILED
850	9-Aug-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	7:07	7:09	0:01	LINE FAULT
851	9-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
852	9-Aug-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	7:03	7:17	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
853	9-Aug-20	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:34	11:42	0:07	LINE FAULT
854	9-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:15	17:49	9:34	LINE CLEAR AVAILED
855	9-Aug-20	TUMKUR	66	TR1	PAVAGADA_220	15:15	15:16	0:01	TRANSFORMER FAULT
856	9-Aug-20	TUMKUR	66	TR-1	HANAGAL_66	11:07	11:58	0:51	LINE CLEAR AVAILED
857	9-Aug-20	TUMKUR	66	TR-1	HDPURA_66	8:20	8:29	0:09	HAND TRIPPED
858	9-Aug-20	TUMKUR	66	TR-1	THIMMASANDRA_66	19:00	21:51	2:51	TRANSFORMER FAULT
859	9-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
860	9-Aug-20	TUMKUR	66	TR-2	SANIKERE_66	14:43	15:43	1:00	LINE CLEAR AVAILED
861	9-Aug-20	TUMKUR	110	TR-1	MAYASANDRA_110	15:03	17:17	2:14	TRANSFORMER FAULT
862	9-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
863	10-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
864	10-Aug-20	BAGALKOT	110	110/11KV HV 1	BIJAPUR _110	17:41	18:09	0:28	HAND TRIPPED
865	10-Aug-20	BAGALKOT	110	110/11KV.HV 4	KERUR_110	16:24	16:52	0:28	HAND TRIPPED
866	10-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
867	10-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
868	10-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
869	10-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
870	10-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
871	10-Aug-20	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	23:40 (08.08.2020)	14:43 (10.8.2020)	63:03hrs	LINE CHARGED
872	10-Aug-20	BAGALKOT	110	KARAWAR-ARGA	ARGA_110	10:20	15:41	5:21	LINE CLEAR AVAILED
873	10-Aug-20	BAGALKOT	110	KARAWAR-SOLARIS	SOLARIS_110	12:45	15:41	2:56	LINE CLEAR AVAILED
874	10-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
875	10-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
876	10-Aug-20	BAGALKOT	110	KULIGOD -GAMESH	KULIGOD_110	13:56	14:25	0:29	LINE FAULT
877	10-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
878	10-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI1	SIRSI_220	15:50	18:33	2:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
879	10-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI2	SIRSI_220	15:50: (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
880	10-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	17:07 (07.08.2020)			LINE OPEN:LINE FAULT
881	10-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	SIRSI_110	11:45:00 AM (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
882	10-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
883	10-Aug-20	BAGALKOT	110	VAJRAMATTI-HALAKI(MUDHOL)	HALAKI_110	12:32	13:01	0:29	LINE FAULT
884	10-Aug-20	BAGALKOT	110	VAJRAMATTI-JAMBAGI	JAMBAGI_110	10:07	10:12	0:05	HAND TRIPPED
885	10-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
886	10-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
887	10-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
888	10-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
889	10-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	23:05 (10.8.2020)			LINE OPEN:LINE CLEAR AVAILED
890	10-Aug-20	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:11:00 AM (7.8.2020)			LOAD CURTAILMENT
891	10-Aug-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:22 (7.8.2020)			LOAD CURTAILMENT
892	10-Aug-20	BAGALKOT	220	GADAG-HARTI1	GADAG_220	15:00 (10.8.2020)			LINE OPEN:LINE CLEAR AVAILED
893	10-Aug-20	BAGALKOT	220	GADAG-HARTI2	GADAG_220	11:02 (09.08.2020)	15:00 (10.8.2020)	27:58hrs	NFBC ISSUED
894	10-Aug-20	BAGALKOT	220	HAVERI-NARENDRA 2	HAVERI_220	23:51 (09.08.2020)	6:14 (10.8.2020)	6:23hrs	LOAD CURTAILMENT
895	10-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	13:57 (08.08.2020)	14:26 (10.8.2020)	48:29hrs	LINE CHARGED
896	10-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
897	10-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
898	10-Aug-20	BAGALKOT	220	SHARAVATY 1-SIRSI	SIRSI_220	14:26	16:56	2:30	LINE CLEAR AVAILED
899	10-Aug-20	BAGALKOT	220	SHARAVATY 2-SIRSI	SIRSI_220	14:25	16:57	2:32	LINE CLEAR AVAILED
900	10-Aug-20	BAGALKOT	220	SHARAVATY 2-SIRSI	SIRSI_220	5:24:00 PM (10.8.2020)			LOAD CURTAILMENT
901	10-Aug-20	BENGALURU	66	BANASAWADI - HEBBALA 220	BANASAWADI	11:35	11:41	00:06	LOAD CHANGEOVER
902	10-Aug-20	BENGALURU	66	BANASAWADI - ITI 220	BANASAWADI	12:45	12:49	00:04	LOAD CHANGEOVER
903	10-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
904	10-Aug-20	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	05:55	06:00	00:05	LOAD CHANGEOVER
905	10-Aug-20	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	02:38	03:13	00:35	MAIN SUPPLY FAILURE
906	10-Aug-20	BENGALURU	66	GOKULA - SRS PEENYA 2	NO STATION AFFECTED	02:38	10:14	07:36	LINE FAULT
907	10-Aug-20	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA,ADUGODI,BOSCH (EHT)	16:49	17:02	00:13	LINE FAULT
908	10-Aug-20	BENGALURU	66	HV1	BG ROAD	07:38	07:48	00:10	TRANSFORMER FAULT
909	10-Aug-20	BENGALURU	66	HV1	HOSPALYA CIRCLE	14:49	14:55	00:06	TRANSFORMER FAULT
910	10-Aug-20	BENGALURU	66	HV1	SANKALGERE	23:22	23:34	00:12	TRANSFORMER FAULT
911	10-Aug-20	BENGALURU	66	HV2	BRIGADE METROPOLIS	14:59	15:04	00:05	LINE CLEAR AVAILED
912	10-Aug-20	BENGALURU	66	HV2	BMTC	6:04(09/08/2020)	13:18(10/08/2020)	32:14HRS	TRANSFORMER CHARGED
913	10-Aug-20	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	13:10	13:13	00:03	LOAD CHANGEOVER
914	10-Aug-20	BENGALURU	66	LR BANDE - HEBBAL 220	LR BANDE	12:34	12:38	00:04	LOAD CHANGEOVER
915	10-Aug-20	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	02:38	02:58	00:20	LOAD CHANGEOVER
916	10-Aug-20	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	06:45	06:49	00:04	LOAD CHANGEOVER
917	10-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
918	10-Aug-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	02:38	03:07	00:29	LOAD CHANGEOVER
919	10-Aug-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	10:26	10:30	00:04	LOAD CHANGEOVER
920	10-Aug-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	02:38	04:55	02:17	LINE FAULT
921	10-Aug-20	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	HENNUR CROSS	07:16	07:33	00:17	LINE FAULT
922	10-Aug-20	BENGALURU	220	HV2	HSR LAYOUT	16:49	17:00	00:11	TRANSFORMER FAULT
923	10-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
924	10-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
925	10-Aug-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	21:55	22:15	00:20	LINE CLEAR AVAILED
926	10-Aug-20	GULBARGA	110	HV1	MANVI_110	04:39	04:44	00:05	TRANSFORMER FAULT
927	10-Aug-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFACTORY,CHOWDAPUR_110	07:05	07:10	00:05	LINE FAULT
928	10-Aug-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	15:10	15:23	00:13	LINE FAULT
929	10-Aug-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	22:13	22:24	00:11	LINE FAULT
930	10-Aug-20	GULBARGA	110	SEDAM-VICATSAGAR CEMENTS	VICATSAGAR_CEMENTS	23:02	23:32	00:30	LINE FAULT
931	10-Aug-20	GULBARGA	110	SEDAM-VICATSAGAR CEMENTS	VICATSAGAR_CEMENTS	21:27	21:37	00:10	LINE FAULT
932	10-Aug-20	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_110	19:32	20:06	00:34	LINE FAULT
933	10-Aug-20	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_110	22:00	23:26	01:26	LINE CLEAR AVAILED
934	10-Aug-20	GULBARGA	110	SHAHBAD-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110	18:45	18:50	00:05	LINE FAULT
935	10-Aug-20	GULBARGA	110	SHAHPUR-SHAHPUR1	NO STATION AFFECTED	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
936	10-Aug-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	23:10	23:30	00:20	LINE FAULT
937	10-Aug-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	02:23	02:33	00:10	LINE FAULT
938	10-Aug-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	02:54	03:04	00:10	LINE FAULT
939	10-Aug-20	GULBARGA	220	HV2	SHAHAPUR_220	19:32	20:06	00:34	TRANSFORMER FAULT
940	10-Aug-20	GULBARGA	220	HV2	SHAHAPUR_220	21:42	21:57	00:15	TRANSFORMER FAULT
941	10-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
942	10-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
943	10-Aug-20	GULBARGA	220	LINGAPUR-BMMISPAT	LINGAPUR_220	10:33	13:47	03:14	LINE CLEAR AVAILED
944	10-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	02:03	07:27	05:24	LINE FAULT
945	10-Aug-20	HASSAN	66	HV1	SAKLESHPURA_66	12:33	13:27	00:54	LINE CLEAR AVAILED
946	10-Aug-20	HASSAN	66	HV2	HOLEHONNUR_66	10:50	11:43	00:53	MAIN SUPPLY FAILURE
947	10-Aug-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	07:00	07:17	00:17	LINE FAULT
948	10-Aug-20	HASSAN	66	TAVAREC-IDLE	TAVARECHANAHALLI_66	10:53	11:20	00:27	LINE FAULT
949	10-Aug-20	HASSAN	110	HV1	BARANGI_110	11:02	17:30	06:28	LINE CLEAR AVAILED
950	10-Aug-20	HASSAN	110	HV3	ALKOLA_110	14:33	15:16	00:43	LINE CLEAR AVAILED
951	10-Aug-20	HASSAN	110	JOG-JLT4	mghejog_gen	0:33 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
952	10-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	16:43 (9.08.2020)	14:15 (10.08.2020)	16:31 hrs	LINE CHARGED
953	10-Aug-20	HASSAN	110	JOG-NK2	mghejog_gen	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
954	10-Aug-20	HASSAN	110	LV2	KEMAR_220	10:18	12:18	02:00	LINE CLEAR AVAILED
955	10-Aug-20	HASSAN	110	LV2	KEMAR_220	17:45	17:47	00:02	HAND TRIPPED
956	10-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:53	16:30	03:37	LINE FAULT
957	10-Aug-20	HASSAN	220	HV2	KEMAR_220	10:18	12:18	02:00	LINE CLEAR AVAILED
958	10-Aug-20	HASSAN	220	HV2	KEMAR_220	17:45	17:47	00:02	HAND TRIPPED
959	10-Aug-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	14:26	16:57	02:31	NFBC ISSUED
960	10-Aug-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	14:25 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
961	10-Aug-20	HASSAN	220	SHRAVTY-ST3	sharavathy_gen	11:20	12:07	00:47	HAND TRIPPED
962	10-Aug-20	HASSAN	220	TALAGU-STRP3	TALAGUPPA_400	11:21	12:07	00:46	LINE CLEAR AVAILED
963	10-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21 (9.08.2020)	7:26 (10.08.2020)	31:04 hrs	LINE CHARGED
964	10-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:06 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
965	10-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:56 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
966	10-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
967	10-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	2:47 (06.08.2020)			LINE OPEN:LINE FAULT
968	10-Aug-20	MYSURU	66	HV1	CHUNCHUNKATTE_66	11:35	12:10	0:34	LINE CLEAR AVAILED
969	10-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
970	10-Aug-20	MYSURU	66	HV4	NANJANGUDU_66	11:27	11:54	0:26	LINE CLEAR AVAILED
971	10-Aug-20	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	10:34	10:40	0:05	LINE FAULT
972	10-Aug-20	MYSURU	66	KADAKOLA-SARGUR-1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	15:12	15:18	0:06	LINE FAULT
973	10-Aug-20	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	11:20	11:41	0:21	LINE FAULT
974	10-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	10:43 (07.08.2020)			LINE OPEN:LINE CLEAR AVAILED
975	10-Aug-20	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	18:35	18:40	0:04	LINE FAULT
976	10-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
977	10-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)			LINE OPEN:LINE CLEAR AVAILED
978	10-Aug-20	MYSURU	66	THANDYA-KADAKOLA	THANDYA_66	14:05	14:48	0:43	HAND TRIPPED
979	10-Aug-20	MYSURU	66	THANDYA-NANJANGUDU	THANDYA_66	14:05	14:49	0:44	HAND TRIPPED
980	10-Aug-20	MYSURU	66	VAJMANGALA-KADKOLA 1	AYRALLI_66 MARADIHUNDI_66	6:17	6:25	0:08	LINE FAULT
981	10-Aug-20	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	12:22	15:22	3:00	LINE CLEAR AVAILED
982	10-Aug-20	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	12:19	15:22	3:03	LINE CLEAR AVAILED
983	10-Aug-20	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:09	15:12	3:03	LINE CLEAR AVAILED
984	10-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
985	10-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:11	19:19	0:08	MAIN SUPPLY FAILURE
986	10-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:43	14:59	0:15	LINE FAULT
987	10-Aug-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAGIRI_66	18:46	19:08	0:22	LINE FAULT
988	10-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:01	17:56	9:55	LINE CLEAR AVAILED
989	10-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN : TRANSFORMER FAULT
990	10-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	14:32	14:39	0:06	LINE CLEAR AVAILED
991	10-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	14:54	15:23	0:29	LINE CLEAR AVAILED
992	10-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
993	10-Aug-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	6:18	13:01	6:42	LINE FAULT
994	10-Aug-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	6:17	13:17	6:59	LINE FAULT