

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 19.03.2019 to 25.03.2019

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	19-Mar-19	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	9:56	12:48	2:52	LINE CLEAR AVAILED
2	19-Mar-19	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	0:00	15:50	15:50	LINE CLEAR AVAILED
3	19-Mar-19	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	15:39	15:42	0:03	LINE FAULT
4	19-Mar-19	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	15:49	18:16	2:27	LINE FAULT
5	19-Mar-19	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	18:25	18:30	0:05	HAND TRIPPED
6	19-Mar-19	BAGALKOT	110	ATHANI2-AIGALI	AIGALI_110	11:08	12:46	1:38	LINE CLEAR AVAILED
7	19-Mar-19	BAGALKOT	110	110/11KV,HV-1	BAGALKOT_110	7:25	7:32	0:07	TRANSFORMER FAULT
8	19-Mar-19	BAGALKOT	110	110/11KV,HV-2	BANAHATTI_110	17:39	18:15	0:36	LINE CLEAR AVAILED
9	19-Mar-19	BAGALKOT	220	BIDNAL -NARENDRA	BIDNAL_220	0:00	1:08	1:08	LINE FAULT
10	19-Mar-19	BAGALKOT	220	BIDNAL-HUBLI 1&3	BIDNAL_220	0:00	1:12	1:12	LINE FAULT
11	19-Mar-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	0:00	1:13	1:13	LINE FAULT
12	19-Mar-19	BAGALKOT	220	BIDNAL-HIREBENDIGER 1	BIDNAL_220	0:00	1:14	1:14	LINE FAULT
13	19-Mar-19	BAGALKOT	220	220/11KV,HV&LV-1	BIDNAL_220	0:00	2:30	2:30	TRANSFORMER FAULT
14	19-Mar-19	BAGALKOT	110	BIDNAL- PH COMPOUND	PH COMPOUND_110	0:00	2:09	2:09	MAIN SUPPLY FAILURE
15	19-Mar-19	BAGALKOT	110	BIDNAL- NAVALGUND	NAVALGUND_110	0:00	2:11	2:11	MAIN SUPPLY FAILURE
16	19-Mar-19	BAGALKOT	110	BIDNAL- ANNIGERI	ANNIGERI_110	0:00	2:26	2:26	MAIN SUPPLY FAILURE
17	19-Mar-19	BAGALKOT	110	BIDNAL- GADAG	GADAG ROAD_110	0:00	2:30	2:30	MAIN SUPPLY FAILURE
18	19-Mar-19	BAGALKOT	110	110/11KV,HV-1	DAMBAL_110	20:16	20:30	0:14	TRANSFORMER FAULT
19	19-Mar-19	BAGALKOT	110	GOPANAKOPPA -GADAG ROAD	GADAG ROAD_110	8:19	8:22	0:03	HAND TRIPPED
20	19-Mar-19	BAGALKOT	110	GOPANAKOPPA -MR NAGAR2	MR NAGAR_110	8:22	8:27	0:05	HAND TRIPPED
21	19-Mar-19	BAGALKOT	110	GOPANAKOPPA-BIDNAL-NVLKD	NARAGUND_110	11:34	15:32	3:58	LINE CLEAR AVAILED
22	19-Mar-19	BAGALKOT	110	110/11KV,HV-1	GOPANAKOPPA_110	12:57	14:13	1:16	TRANSFORMER FAULT
23	19-Mar-19	BAGALKOT	110	110/11KV,HV-1	GOPANAKOPPA_110	17:49	18:50	1:01	TRANSFORMER FAULT
24	19-Mar-19	BAGALKOT	110	HIREHAL-IDLE	BADAMI_110	12:07	18:08	6:01	LINE CLEAR AVAILED
25	19-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:38	10:57	0:19	LINE FAULT
26	19-Mar-19	BANGALORE	66	A STATION 220 - A STATION 2	A STATION 66	23:11	23:18	0:06	LINE CLEAR AVAILED
27	19-Mar-19	BANGALORE	66	SUBRAMNYAPURA 220 - SARAKKI 2	SARAKKI	15:23	15:38	0:14	LINE FAULT
28	19-Mar-19	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	4:44	4:50	0:06	LINE FAULT
29	19-Mar-19	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	17:40	18:07	0:27	MAIN SUPPLY FAILURE
30	19-Mar-19	BANGALORE	66	HV1	AKKURMOLE	17:28	18:02	0:33	TRANSFORMER FAULT
31	19-Mar-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:43	14:55	0:12	LINE FAULT
32	19-Mar-19	BANGALORE	66	HV1	CHANDAPURA	14:43	14:59	0:16	MAIN SUPPLY FAILURE
33	19-Mar-19	BANGALORE	66	HV2	CHANDAPURA	14:43	14:59	0:16	MAIN SUPPLY FAILURE
34	19-Mar-19	BANGALORE	66	HV3	CHIKKABALLAPURA I/A	6:55	12:11	5:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
35	19-Mar-19	BANGALORE	66	CHINTAMANI - GANJIGUNTE 1	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	13:43	13:54	0:11	LINE FAULT
36	19-Mar-19	BANGALORE	66	CHINTAMANI - GANJIGUNTE 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	13:43	13:54	0:11	LINE FAULT
37	19-Mar-19	BANGALORE	66	HV2	DODDABELAVANGALA	18:01	18:22	0:20	LINE CLEAR AVAILED
38	19-Mar-19	BANGALORE	220	HV3	KOLAR 220	11:30	12:20	0:50	LINE CLEAR AVAILED
39	19-Mar-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:30	12:25	0:55	MAIN SUPPLY FAILURE
40	19-Mar-19	BANGALORE	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	11:30	12:28	0:58	MAIN SUPPLY FAILURE
41	19-Mar-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:30	12:30	1:00	MAIN SUPPLY FAILURE
42	19-Mar-19	BANGALORE	66	HV2	NANGLI	16:59	17:25	0:25	LINE CLEAR AVAILED
43	19-Mar-19	BANGALORE	66	SURYANAGAR - ANEKAL	ANEKAL	16:20	16:48	0:28	LINE FAULT
44	19-Mar-19	BANGALORE	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	16:20	16:47	0:26	LINE FAULT
45	19-Mar-19	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	16:20	16:47	0:26	LINE FAULT
46	19-Mar-19	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	16:20	16:48	0:28	LINE FAULT
47	19-Mar-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	10:52	11:02	0:10	LINE FAULT
48	19-Mar-19	GULBARGA	220	HV2	HUMNABAD_220	6:15	7:24	1:09	LINE CLEAR AVAILED
49	19-Mar-19	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	7:01	7:28	0:27	HAND TRIPPED
50	19-Mar-19	GULBARGA	220	HV2	KAPNOOR_220	12:50	13:43	0:53	LINE CLEAR AVAILED
51	19-Mar-19	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	14:20	14:40	0:20	MAIN SUPPLY FAILURE
52	19-Mar-19	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	14:20	14:29	0:09	MAIN SUPPLY FAILURE
53	19-Mar-19	GULBARGA	220	HV2	SINDHANOOR_220	10:20	14:15	3:55	LINE CLEAR AVAILED
54	19-Mar-19	GULBARGA	220	HV2	LINGASUGUR_220	12:42	12:55	0:13	LINE CLEAR AVAILED
55	19-Mar-19	GULBARGA	220	LINGASUGUR-SHAHPUR	LINGASUGUR_220	11:00	11:25	0:25	LINE CLEAR AVAILED
56	19-Mar-19	GULBARGA	220	LINGASUGUR-RTPS3	LINGASUGUR_220	12:40	13:48	1:08	LINE CLEAR AVAILED
57	19-Mar-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANDAL_110	7:00	9:21	2:21	LINE CLEAR AVAILED
58	19-Mar-19	GULBARGA	110	HV2	HATTI_110	14:55	15:07	0:12	LINE CLEAR AVAILED
59	19-Mar-19	GULBARGA	110	HV3	KUSTAGI_220	13:36	14:03	0:27	LINE CLEAR AVAILED
60	19-Mar-19	GULBARGA	110	HV1	RAJESHWAR_110	12:25	13:33	1:08	LINE CLEAR AVAILED
61	19-Mar-19	GULBARGA	110	HV2	MADIYAL_110	21:19	21:46	0:27	MAIN SUPPLY FAILURE
62	19-Mar-19	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110, TORANGALLU_110	20:31	20:35	0:04	MAIN SUPPLY FAILURE
63	19-Mar-19	GULBARGA	66	HV1	TAMBRAHALLI_66	9:15	9:32	0:17	LINE CLEAR AVAILED
64	19-Mar-19	GULBARGA	66	HV2	UPANAYAKANAHALLI_66	11:00	11:07	0:07	MAIN SUPPLY FAILURE
65	19-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	13:21	13:21	LINE FAULT
66	19-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:23	17:39	4:16	LINE FAULT
67	19-Mar-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:27	18:51	7:24	LINE FAULT
68	19-Mar-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	0:00	10:04	10:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
69	19-Mar-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:34	11:38	1:04	LINE CLEAR AVAILED
70	19-Mar-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	6:30	12:32	6:02	LINE FAULT
71	19-Mar-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	16:06	17:12	1:06	LINE FAULT
72	19-Mar-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	9:53	10:05	0:12	NFBC ISSUED
73	19-Mar-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	0:00	10:04	10:04	LINE FAULT
74	19-Mar-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:34	11:27	0:53	NFBC ISSUED
75	19-Mar-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:53	14:17	2:24	LINE CLEAR AVAILED
76	19-Mar-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:53	14:18	2:25	LINE CLEAR AVAILED
77	19-Mar-19	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:26	18:52	7:26	LINE FAULT
78	19-Mar-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	6:30	12:32	6:02	LINE FAULT
79	19-Mar-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	16:06	17:12	1:06	LINE FAULT
80	19-Mar-19	HASSAN	110	HV2	AJJAMPURA_110	6:20	7:16	0:56	LINE CLEAR AVAILED
81	19-Mar-19	HASSAN	110	HV2	AJJAMPURA_110	12:03	12:25	0:22	LINE CLEAR AVAILED
82	19-Mar-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	21:19	21:33	0:14	LINE FAULT
83	19-Mar-19	HASSAN	110	HV1	BIRUR_110	8:49	9:09	0:20	TRANSFORMER FAULT
84	19-Mar-19	HASSAN	110	HV1	KITTADAHALLI_110	13:11	13:39	0:28	LINE CLEAR AVAILED
85	19-Mar-19	HASSAN	110	HV1	KITTADAHALLI_110	13:58	14:21	0:23	LINE CLEAR AVAILED
86	19-Mar-19	HASSAN	110	HV2	KITTADAHALLI_110	12:25	12:55	0:30	LINE CLEAR AVAILED
87	19-Mar-19	HASSAN	110	HV2	MRSMSG_220	8:36	14:23	5:47	LINE CLEAR AVAILED
88	19-Mar-19	HASSAN	110	HV1	SAGARA_110	19:13	19:22	0:09	TRANSFORMER FAULT
89	19-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	7:46	7:50	0:04	TRANSFORMER FAULT
90	19-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:55	13:23	1:28	LINE CLEAR AVAILED
91	19-Mar-19	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	11:55	13:20	1:25	LINE CLEAR AVAILED
92	19-Mar-19	HASSAN	66	LV2	MRSMSG_220	8:36	14:24	5:48	LINE CLEAR AVAILED
93	19-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:50	10:06	0:16	LINE FAULT
94	19-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	11:50	19:55	8:05	LINE CLEAR AVAILED
95	19-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	12:05	19:53	7:48	LINE CLEAR AVAILED
96	19-Mar-19	HASSAN	66	HV2	SHRAVANABELAGOLA_66	14:36	14:43	0:07	TRANSFORMER FAULT
97	19-Mar-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	11:55	13:20	1:25	LINE CLEAR AVAILED
98	19-Mar-19	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	12:45	12:55	0:10	LINE FAULT
99	19-Mar-19	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	13:00	13:10	0:10	LINE FAULT
100	19-Mar-19	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	16:20	16:30	0:10	LINE FAULT
101	19-Mar-19	MYSORE	66	HV2	BANNUR_66	11:25	12:00	0:35	LINE CLEAR AVAILED
102	19-Mar-19	MYSORE	66	HV1	BGNAGARA_66	8:00	14:00	6:00	LINE CLEAR AVAILED
103	19-Mar-19	MYSORE	66	HV2	BGNAGARA_66	8:00	14:00	6:00	LINE CLEAR AVAILED
104	19-Mar-19	MYSORE	66	HV2	BGNAGARA_66	15:30	15:57	0:27	LINE CLEAR AVAILED
105	19-Mar-19	MYSORE	66	HV1	BOOKANAKERE_66	17:15	17:48	0:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
106	19-Mar-19	MYSORE	66	BYLUKUPPE-KUSHALANAGARA 220	BYLUKUPPE_66	8:29	8:38	0:08	LINE FAULT
107	19-Mar-19	MYSORE	66	BYLUKUPPE-KUSHALANAGARA 220	BYLUKUPPE_66	9:51	10:10	0:18	LINE FAULT
108	19-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	18:01	18:16	0:15	LINE FAULT
109	19-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	18:01	18:16	0:14	LINE FAULT
110	19-Mar-19	MYSORE	66	HV1	MADIKERI_66	10:23	16:21	5:57	LINE CLEAR AVAILED
111	19-Mar-19	MYSORE	66	MADIKERI-HV2	MADIKERI_66	13:34	15:13	1:39	LINE CLEAR AVAILED
112	19-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	15:06	20:55	5:48	LINE CLEAR AVAILED
113	19-Mar-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	11:21	15:58	4:36	LOAD CURTAILMENT
114	19-Mar-19	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	10:51	18:45	7:53	LINE CLEAR AVAILED
115	19-Mar-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	13:44	14:08	0:24	HAND TRIPPED
116	19-Mar-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	17:40	17:52	0:12	LINE FAULT
117	19-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	11:05	17:28	6:22	LINE CLEAR AVAILED
118	19-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	15:30	16:49	1:19	LINE FAULT
119	19-Mar-19	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	16:40	18:02	1:22	LINE CLEAR AVAILED
120	19-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	7:29	7:36	0:07	TRANSFORMER FAULT
121	19-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	16:13	16:16	0:03	TRANSFORMER FAULT
122	19-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	22:39	23:10	0:31	TRANSFORMER FAULT
123	19-Mar-19	TUMKUR	66	TR-2	CHITRADURGA_220	11:14	18:16	7:01	LINE CLEAR AVAILED
124	19-Mar-19	TUMKUR	66	TR-2	DAVANAGERE_66	13:22	13:55	0:33	LINE CLEAR AVAILED
125	19-Mar-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:23	15:06	3:42	LINE CLEAR AVAILED
126	19-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:08	17:35	10:26	LINE CLEAR AVAILED
127	19-Mar-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	7:08	7:32	0:23	HAND TRIPPED
128	19-Mar-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	11:14	13:19	2:04	LINE CLEAR AVAILED
129	19-Mar-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:22	10:31	0:08	LINE FAULT
130	19-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	18:16	18:26	0:10	LINE FAULT
131	19-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:16	11:21	0:05	LINE FAULT
132	19-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:49	18:55	0:06	LINE FAULT
133	19-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:50	22:11	0:21	LINE FAULT
134	19-Mar-19	TUMKUR	66	TR-1	SHYLAPURA_66	13:13	13:16	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
135	19-Mar-19	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	18:41	18:52	0:10	LINE FAULT
136	20-Mar-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	13:14	13:57	0:43	LINE FAULT
137	20-Mar-19	BAGALKOT	110	110/33KV,HV2	KUDUCHI_110,YELPARATTI_33KV,CHINCHALI_33KV	16:26	16:41	0:15	TRANSFORMER FAULT
138	20-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	11:27	11:33	0:05	LINE FAULT
139	20-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	12:20	12:26	0:06	LINE FAULT
140	20-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	22:03	22:09	0:05	LINE FAULT
141	20-Mar-19	BANGALORE	66	HV2	SOMANAHALLI 220	2:44	4:30	1:45	TRANSFORMER FAULT
142	20-Mar-19	BANGALORE	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	6:06	6:28	0:22	LINE FAULT
143	20-Mar-19	BANGALORE	220	HV2	SOMANAHALLI 220	2:44	3:20	0:36	TRANSFORMER FAULT
144	20-Mar-19	BANGALORE	220	HV3	SOMANAHALLI 220	2:44	6:45	4:00	TRANSFORMER FAULT
145	20-Mar-19	BANGALORE	66	HV2	BMTC	16:16	16:44	0:27	TRANSFORMER FAULT
146	20-Mar-19	BANGALORE	66	HV2	ANEKAL	5:27	6:49	1:22	TRANSFORMER FAULT
147	20-Mar-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	10:08	10:14	0:05	LINE FAULT
148	20-Mar-19	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	14:33	15:38	1:05	LINE FAULT
149	20-Mar-19	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110	15:25	15:35	0:10	LINE FAULT
150	20-Mar-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS, MUKUNDA_110, KAMPLI_110	10:35	11:30	0:55	LINE FAULT
151	20-Mar-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	17:15	17:29	0:14	LINE FAULT
152	20-Mar-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	14:55	15:20	0:25	LINE FAULT
153	20-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	7:00	7:05	0:05	TRANSFORMER FAULT
154	20-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	14:55	15:20	0:25	TRANSFORMER FAULT
155	20-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	18:25	18:45	0:20	TRANSFORMER FAULT
156	20-Mar-19	MYSORE	66	HV1	ARAKERE_66	21:03	21:08	0:05	TRANSFORMER FAULT
157	20-Mar-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALI_66	13:18	13:20	0:02	LINE FAULT
158	20-Mar-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66	11:19	11:27	0:08	LINE FAULT
159	20-Mar-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66	12:08	12:18	0:10	LINE FAULT
160	20-Mar-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66	12:22	12:27	0:05	LINE FAULT
161	20-Mar-19	MYSORE	66	HV2	KMDODDI_66	12:36	12:41	0:05	TRANSFORMER FAULT
162	20-Mar-19	MYSORE	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	15:23	15:35	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
163	20-Mar-19	MYSORE	66	HV1	RAMAPURA_MYS_66	17:43	18:05	0:21	TRANSFORMER FAULT
164	20-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	6:58	7:16	0:17	TRANSFORMER FAULT
165	20-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	13:57	14:04	0:07	LINE FAULT
166	20-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:09	13:32	4:23	LINE FAULT
167	20-Mar-19	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:27	14:42	4:15	LINE FAULT
168	21-Mar-19	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	6:21	6:25	0:04	LINE FAULT
169	21-Mar-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	19:07	19:27	0:20	LINE FAULT
170	21-Mar-19	BAGALKOT	110	SODATTI220-RAMDURGA1	RAMDURGA_110	6:26	7:15	0:49	LINE FAULT
171	21-Mar-19	BAGALKOT	110	BALAGI SUGAR-MUDDEBIHAL	MUDDEBIHAL_110	6:27	6:46	0:19	LINE FAULT
172	21-Mar-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	6:33	6:52	0:19	LINE FAULT
173	21-Mar-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	18:15	18:30	0:15	LINE FAULT
174	21-Mar-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:47	9:15	0:28	LINE FAULT
175	21-Mar-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	10:32	10:37	0:05	LINE FAULT
176	21-Mar-19	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	16:54	17:59	1:05	LINE FAULT
177	21-Mar-19	GULBARGA	110	KUSTAGI-SUZLONWIND1	KUSTAGI_220	11:01	13:30	2:29	LINE FAULT
178	21-Mar-19	GULBARGA	110	KUSTAGI-ILKAL	KUSTAGI_220	12:10	12:25	0:15	LINE FAULT
179	21-Mar-19	GULBARGA	66	HV1	HAGRIBOMMANAHALLI_66	22:00	22:05	0:05	TRANSFORMER FAULT
180	21-Mar-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	2:58	3:55	0:57	LINE FAULT
181	21-Mar-19	HASSAN	110	HV1	GURUVAYANAKERE_110	7:40	7:47	0:07	TRANSFORMER FAULT
182	21-Mar-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	7:46	8:10	0:24	LINE FAULT
183	21-Mar-19	HASSAN	66	HV2	BELUR_66	14:40	14:50	0:10	TRANSFORMER FAULT
184	21-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:12	15:15	0:03	LINE FAULT
185	21-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	6:43	6:51	0:08	TRANSFORMER FAULT
186	21-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	9:25	9:33	0:08	TRANSFORMER FAULT
187	21-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	14:07	14:17	0:10	LINE FAULT
188	21-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	14:31	14:49	0:18	LINE FAULT
189	21-Mar-19	HASSAN	66	HV2	SHANTHIGRAMA_66	12:40	17:20	4:40	TRANSFORMER FAULT
190	21-Mar-19	MYSORE	66	HV1	CHUNCHUNKATTE_66	7:18	23:59	16:40	TRANSFORMER FAULT
191	21-Mar-19	MYSORE	66	HOOTAGALLY-ELWALA	ELAVALA_66 GAVADAGERE_66	13:47	13:54	0:06	LINE FAULT
192	21-Mar-19	MYSORE	66	HUNSUR-HOOTAGALLY	HUNSUR_66 HANAGODU_66 BANNIKUPPE_66 HOSURGATE_66	13:45	13:55	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
193	21-Mar-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	12:28	12:45	0:16	LINE FAULT
194	21-Mar-19	MYSORE	66	HV2	RKNAGARA_66	21:20	21:45	0:25	TRANSFORMER FAULT
195	21-Mar-19	MYSORE	66	HV2	SANTHESARAGUR_66	18:08	18:17	0:08	TRANSFORMER FAULT
196	21-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	17:11	17:26	0:14	LINE FAULT
197	21-Mar-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	7:57	8:02	0:05	LINE FAULT
198	21-Mar-19	TUMKUR	66	TR-2	LINGADAHALLY_66	21:03	21:10	0:07	TRANSFORMER FAULT
199	21-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	8:06	8:11	0:05	LINE FAULT
200	21-Mar-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_IPP_66	7:04	7:08	0:03	LINE FAULT
201	21-Mar-19	TUMKUR	66	MADHUGIRI 220KV- PULAMAGATTA	PULAMG_66	5:50	6:04	0:14	LINE FAULT
202	22-Mar-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	12:47	21:01	8:14	LINE FAULT
203	22-Mar-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	0:05	0:12	0:07	LINE FAULT
204	22-Mar-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	12:16	17:50	5:34	LINE FAULT
205	22-Mar-19	BAGALKOT	220	SIRSI220-HUBLI2	SIRSI_220	13:54	16:18	2:24	LINE FAULT
206	22-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	14:29	14:31	0:02	TRANSFORMER FAULT
207	22-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDARGI_110	6:45	14:07	7:22	TRANSFORMER FAULT
208	22-Mar-19	BANGALORE	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220, EDC 220	16:28	16:38	0:09	LINE FAULT
209	22-Mar-19	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), K & C VALLEY, NAL (EHT)	16:28	16:42	0:14	LINE FAULT
210	22-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	12:13	12:20	0:07	LINE FAULT
211	22-Mar-19	BANGALORE	66	HV1	ATTIBELE	17:25	17:32	0:06	TRANSFORMER FAULT
212	22-Mar-19	BANGALORE	66	HV1	YELAHANKA 220	7:21	8:06	0:45	TRANSFORMER FAULT
213	22-Mar-19	BANGALORE	66	HV1	YELAHANKA 220	18:01	19:20	1:18	TRANSFORMER FAULT
214	22-Mar-19	BANGALORE	66	HV1	YELAHANKA 220	19:20	23:59	4:39	TRANSFORMER FAULT
215	22-Mar-19	BANGALORE	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	13:07	13:20	0:12	LINE FAULT
216	22-Mar-19	GULBARGA	220	HV2	KUSTAGI_220	10:44	10:56	0:12	TRANSFORMER FAULT
217	22-Mar-19	GULBARGA	110	KAPNOOR-HUMNABAD1	ALAND_110,KADAGANCHI_110	6:04	6:12	0:08	LINE FAULT
218	22-Mar-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	5:33	5:40	0:07	LINE FAULT
219	22-Mar-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	6:16	6:55	0:39	LINE FAULT
220	22-Mar-19	HASSAN	110	HV2	SORABA_110	10:46	11:04	0:18	TRANSFORMER FAULT
221	22-Mar-19	HASSAN	110	HV2	SORABA_110	11:11	11:35	0:24	TRANSFORMER FAULT
222	22-Mar-19	HASSAN	66	HV2	BELUR_66	23:05	23:15	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
223	22-Mar-19	HASSAN	66	HV1	BELUR_66	17:10	17:35	0:25	TRANSFORMER FAULT
224	22-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	6:49	6:55	0:06	LINE FAULT
225	22-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	14:55	15:21	0:26	LINE FAULT
226	22-Mar-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	6:52	7:02	0:09	LINE FAULT
227	22-Mar-19	MYSORE	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KRPET_66	14:14	14:23	0:09	LINE FAULT
228	22-Mar-19	MYSORE	66	KR PETE 220-KR PETE 2	AKKI HEBBAL & KR PETE	14:14	14:23	0:09	LINE FAULT
229	22-Mar-19	MYSORE	66	HV2	MALAVALLI_66	19:16	19:53	0:37	TRANSFORMER FAULT
230	22-Mar-19	MYSORE	66	HV1	MARTAHALLI_66	16:20	17:10	0:50	TRANSFORMER FAULT
231	22-Mar-19	MYSORE	66	HV2	NAGAMANGALA_66	12:21	13:03	0:42	TRANSFORMER FAULT
232	22-Mar-19	TUMKUR	220	TR-3	HIRIYUR_220	18:08	19:54	1:46	TRANSFORMER FAULT
233	22-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	15:13	15:29	0:15	TRANSFORMER FAULT
234	22-Mar-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:42	9:51	0:09	LINE FAULT
235	22-Mar-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	7:09	7:16	0:06	TRANSFORMER FAULT
236	22-Mar-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	8:57	9:02	0:04	TRANSFORMER FAULT
237	22-Mar-19	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	17:13	17:20	0:07	LINE FAULT
238	22-Mar-19	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	5:50	6:06	0:16	LINE FAULT
239	22-Mar-19	TUMKUR	66	TR-1	MYLANAHALLI_66	16:05	16:14	0:08	TRANSFORMER FAULT
240	23-Mar-19	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	16:26	16:33	0:07	LINE FAULT
241	23-Mar-19	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	16:47	23:59	7:12	LINE CLEAR AVAILED
242	23-Mar-19	BAGALKOT	220	ATHANI_220-RAVI URJA 1	ATHANI_220, RAVIURJA_IPP	12:22	23:59	11:37	LINE CLEAR AVAILED
243	23-Mar-19	BAGALKOT	110	JAMAKHANDI -PRABHU LINGESHWAR(SHIROL)	JAMAKHANDI_110	12:22	16:20	3:58	LINE CLEAR AVAILED
244	23-Mar-19	BAGALKOT	110	CHIKKODI -DKSS COGEN	CHIKKODI_220	10:39	12:42	2:03	LINE CLEAR AVAILED
245	23-Mar-19	BAGALKOT	110	CHIKKODI -ANKALI	ANKALI_110	15:54	17:27	1:33	LINE CLEAR AVAILED
246	23-Mar-19	BAGALKOT	220	HIREBENDIGERI 1-BIIDNAL	BIDNAL_220	0:00	18:02	18:02	LINE CLEAR AVAILED
247	23-Mar-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110,YADAWAD_33,VANTAGODI_33	14:37	14:48	0:11	TRANSFORMER FAULT
248	23-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	9:01	14:56	5:55	LINE CLEAR AVAILED
249	23-Mar-19	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	12:22	12:41	0:19	LINE CLEAR AVAILED
250	23-Mar-19	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	22:03	22:10	0:07	TRANSFORMER FAULT
251	23-Mar-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	14:16	14:21	0:05	TRANSFORMER FAULT
252	23-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	16:38	16:43	0:05	LINE FAULT
253	23-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	17:04	23:59	6:55	LINE CLEAR AVAILED
254	23-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	13:57	14:04	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
255	23-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	11:44	11:50	0:06	LINE FAULT
256	23-Mar-19	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	11:25	11:30	0:05	LOAD CHANGEOVER
257	23-Mar-19	BANGALORE	66	RBI - ELITA PROMENENDE	RBI	15:47	15:50	0:03	LOAD CHANGEOVER
258	23-Mar-19	BANGALORE	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	11:38	11:41	0:02	LOAD CHANGEOVER
259	23-Mar-19	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	16:04	16:07	0:03	LOAD CHANGEOVER
260	23-Mar-19	BANGALORE	66	VR DODDI - TK HALLI 220	VR DODDI	16:02	16:07	0:05	LOAD CHANGEOVER
261	23-Mar-19	BANGALORE	66	HV1	VIJAYANAGARA	22:32	22:40	0:07	LOAD CHANGEOVER
262	23-Mar-19	BANGALORE	66	SOMANAHALLI 220 - SB PURA 1	ISKON, SUBRAMANYAPURA 66	16:02	16:15	0:13	LINE FAULT
263	23-Mar-19	BANGALORE	66	HV2	ADDAGAL	13:00	13:50	0:50	LINE CLEAR AVAILED
264	23-Mar-19	BANGALORE	66	HV2	ADDAGAL	19:10	19:20	0:10	LINE CLEAR AVAILED
265	23-Mar-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	7:29	7:40	0:11	LINE FAULT
266	23-Mar-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	8:12	8:24	0:11	LINE FAULT
267	23-Mar-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	8:24	9:35	1:10	LINE FAULT
268	23-Mar-19	BANGALORE	66	RAJANAKUNTE - DB PURA 220	RAJANAKUNTE	11:40	11:45	0:05	HAND TRIPPED
269	23-Mar-19	BANGALORE	66	HULLENAHALLI - KUDUR	KUDUR	12:21	12:59	0:38	LINE CLEAR AVAILED
270	23-Mar-19	BANGALORE	66	HV1	SIDLAGHATTA	13:01	13:16	0:14	LINE CLEAR AVAILED
271	23-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	13:29	13:42	0:13	LINE FAULT
272	23-Mar-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:05	13:42	0:37	LINE CLEAR AVAILED
273	23-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:30	5:38	0:08	LINE FAULT
274	23-Mar-19	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	14:40	15:03	0:23	LINE FAULT
275	23-Mar-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	14:40	15:23	0:43	LINE FAULT
276	23-Mar-19	GULBARGA	110	HV1	KUDITINI_110	10:05	13:20	3:15	LINE CLEAR AVAILED
277	23-Mar-19	GULBARGA	110	HV1	SHAHAPUR_220	6:56	7:45	0:49	TRANSFORMER FAULT
278	23-Mar-19	GULBARGA	110	HV1	SIRWAR_110	4:48	5:58	1:10	LINE CLEAR AVAILED
279	23-Mar-19	GULBARGA	66	LV2	ITTAGI_220	12:30	12:50	0:20	TRANSFORMER FAULT
280	23-Mar-19	GULBARGA	66	LV2	ITTAGI_220	12:50	13:05	0:15	TRANSFORMER FAULT
281	23-Mar-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALLI_66,HOLAGUNDI_66	13:10	13:20	0:10	LINE CLEAR AVAILED
282	23-Mar-19	GULBARGA	66	ITTAGI-TBHALLI	HAMPASAGARA_66,MORAGERE_66,TAMB RAHALLI_66	12:50	13:05	0:15	LINE FAULT
283	23-Mar-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	9:43	13:48	4:05	LINE CLEAR AVAILED
284	23-Mar-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:16	17:02	7:46	LINE CLEAR AVAILED
285	23-Mar-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:17	17:03	7:46	NFBC ISSUED
286	23-Mar-19	HASSAN	110	HV1	KEMAR_220	23:47	23:59	0:12	LINE CLEAR AVAILED
287	23-Mar-19	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	16:51	17:04	0:13	HAND TRIPPED
288	23-Mar-19	HASSAN	110	HV1	ARASIKERE_220	11:52	13:02	1:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
289	23-Mar-19	HASSAN	110	HV1	SAGARA_110	18:54	19:10	0:16	TRANSFORMER FAULT
290	23-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:11	16:19	0:08	LINE FAULT
291	23-Mar-19	HASSAN	66	HV1	BYACHANAHALLY_66	10:23	10:29	0:06	TRANSFORMER FAULT
292	23-Mar-19	HASSAN	66	HV1	BYACHANAHALLY_66	12:40	13:25	0:45	LOAD CURTAILMENT
293	23-Mar-19	HASSAN	66	HV1	DODDAKADANUR_66	10:30	14:30	4:00	LINE CLEAR AVAILED
294	23-Mar-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	12:40	13:25	0:45	NFBC ISSUED
295	23-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	7:26	14:32	7:06	LINE CLEAR AVAILED
296	23-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	7:31	14:32	7:01	LINE CLEAR AVAILED
297	23-Mar-19	MYSORE	66	BYLUKUPPE-KUSHALANAGARA 220	BYLUKUPPE_66	13:53	14:00	0:07	LINE FAULT
298	23-Mar-19	MYSORE	220	HV2	CRNAGAR_220	11:09	23:59	12:50	LINE CLEAR AVAILED
299	23-Mar-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALLI_66	11:18	11:30	0:12	LINE FAULT
300	23-Mar-19	MYSORE	66	HV1	HANAGODU_66	14:07	14:35	0:27	LINE CLEAR AVAILED
301	23-Mar-19	MYSORE	66	HV2	HANAGODU_66	14:08	14:35	0:27	LINE CLEAR AVAILED
302	23-Mar-19	MYSORE	66	HV2	KMDODDI_66	13:22	13:27	0:05	TRANSFORMER FAULT
303	23-Mar-19	MYSORE	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66	13:06	13:17	0:10	LINE FAULT
304	23-Mar-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	13:06	13:17	0:11	LINE FAULT
305	23-Mar-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	13:56	15:13	1:17	LINE FAULT
306	23-Mar-19	MYSORE	66	HV2	MADHUVANAHALLI_220	12:29	13:22	0:53	LINE CLEAR AVAILED
307	23-Mar-19	MYSORE	66	HV2	MALAVALLI_66	1:30	17:36	16:06	TRANSFORMER FAULT
308	23-Mar-19	MYSORE	66	HV2	MALAVALLI_66	17:39	18:32	0:53	HAND TRIPPED
309	23-Mar-19	MYSORE	66	HV2	RKNAGARA_66	11:10	11:40	0:30	TRANSFORMER FAULT
310	23-Mar-19	MYSORE	66	HV4	RKNAGARA_66	13:19	23:59	10:39	LINE CLEAR AVAILED
311	23-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	15:44	23:59	8:14	LINE CLEAR AVAILED
312	23-Mar-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	18:09	18:10	0:01	HAND TRIPPED
313	23-Mar-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:04	18:07	0:02	HAND TRIPPED
314	23-Mar-19	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	6:58	8:17	1:19	LINE CLEAR AVAILED
315	23-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:18	17:24	12:05	LINE CLEAR AVAILED
316	23-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:19	17:24	12:05	LINE CLEAR AVAILED
317	23-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	17:11	17:18	0:07	TRANSFORMER FAULT
318	23-Mar-19	TUMKUR	110	TR-1	GUBBI_110	22:07	22:11	0:04	TRANSFORMER FAULT
319	23-Mar-19	TUMKUR	110	TR-1	KADABA_110	7:28	7:46	0:18	LINE CLEAR AVAILED
320	23-Mar-19	TUMKUR	110	TR-1	KADABA_110	12:12	12:46	0:33	LINE CLEAR AVAILED
321	23-Mar-19	TUMKUR	110	TR-1	KADABA_110	13:05	14:02	0:57	LINE CLEAR AVAILED
322	23-Mar-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	6:57	8:18	1:20	LINE CLEAR AVAILED
323	23-Mar-19	TUMKUR	66	TR-1	CHANNAGIRI_66	20:20	20:26	0:06	TRANSFORMER FAULT
324	23-Mar-19	TUMKUR	66	TR-2 (HV SIDE)	CHITRADURGA_220	12:35	13:08	0:32	LINE CLEAR AVAILED
325	23-Mar-19	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:04	13:51	0:47	HAND TRIPPED
326	23-Mar-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:12	12:20	0:08	HAND TRIPPED
327	23-Mar-19	TUMKUR	66	I D HALLI- KODIGENAHALLI	KODIGENAHALLI_66	11:54	15:11	3:17	MAIN SUPPLY FAILURE
328	23-Mar-19	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	11:54	15:11	3:17	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
329	23-Mar-19	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	12:16	17:57	5:40	LINE CLEAR AVAILED
330	23-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	19:01	19:12	0:10	TRANSFORMER FAULT
331	23-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	20:03	20:13	0:09	TRANSFORMER FAULT
332	23-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	21:25	21:38	0:13	TRANSFORMER FAULT
333	23-Mar-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	21:14	23:25	2:10	LINE CLEAR AVAILED
334	23-Mar-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	21:14	22:17	1:02	LINE CLEAR AVAILED
335	23-Mar-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	21:14	22:24	1:09	LINE CLEAR AVAILED
336	23-Mar-19	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	21:14	22:35	1:20	LINE CLEAR AVAILED
337	23-Mar-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	11:50	13:52	2:01	LINE CLEAR AVAILED
338	23-Mar-19	TUMKUR	66	TR-2	PUNABHAGHATTA_66	22:19	22:21	0:01	HAND TRIPPED
339	23-Mar-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	12:23	12:36	0:13	MAIN SUPPLY FAILURE
340	23-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:58	15:36	5:38	LINE FAULT
341	23-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	12:58	14:42	1:44	LINE FAULT
342	24-Mar-19	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	0:00	13:24	13:24	LINE CLEAR AVAILED
343	24-Mar-19	BAGALKOT	110	AMBEWADI-NK-1	HALIYAL_110	13:51	23:59	10:08	LINE CLEAR AVAILED
344	24-Mar-19	BAGALKOT	220	ATHANI_220-RAVI URJA 1	ATHANI_220, RAVIURJA_IPP	0:00	14:09	14:09	LINE CLEAR AVAILED
345	24-Mar-19	BAGALKOT	220	ATHANI_220-RAVI URJA 2	ATHANI_220, RAVIURJA_IPP	10:28	14:13	3:45	LINE CLEAR AVAILED
346	24-Mar-19	BAGALKOT	220	ATHANI_220-RAVI URJA 2	ATHANI_220, RAVIURJA_IPP	16:32	16:56	0:24	LINE CLEAR AVAILED
347	24-Mar-19	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	15:33	16:01	0:28	LINE FAULT
348	24-Mar-19	BAGALKOT	110	110/33KV,HV-2	BELGAUM_110	14:54	15:51	0:57	LINE CLEAR AVAILED
349	24-Mar-19	BAGALKOT	220	BELGAUM-KANBARGI2	BELGAUM_220	21:13	23:59	2:46	LINE FAULT
350	24-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:37	23:59	1:22	LINE CLEAR AVAILED
351	24-Mar-19	BAGALKOT	110	GOPANAKOPPA-BIDNAL-NVLKD	NARAGUND_110	10:12	15:54	5:42	LINE CLEAR AVAILED
352	24-Mar-19	BAGALKOT	110	110/11KV,HV-2A	JAMAKHANDI_110	7:00	20:52	13:52	LINE CLEAR AVAILED
353	24-Mar-19	BAGALKOT	110	KADANAKOPPA-KAWALAVAD	KADANAKOPPA_110	11:39	13:44	2:05	LINE CLEAR AVAILED
354	24-Mar-19	BAGALKOT	220	HIREBENDIGERI 2-BIIDNAL	BIDNAL_220	8:30	23:59	15:29	LINE CLEAR AVAILED
355	24-Mar-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	8:23	11:55	3:32	LINE CLEAR AVAILED
356	24-Mar-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33	9:57	16:04	6:07	LINE CLEAR AVAILED
357	24-Mar-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	4:13	12:35	8:22	LINE FAULT
358	24-Mar-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	10:49	12:36	1:47	LINE CLEAR AVAILED
359	24-Mar-19	BAGALKOT	220	NARENNDRA-BELGAUM1	NARENDRA_220	21:13	21:48	0:35	LINE FAULT
360	24-Mar-19	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	19:26	19:32	0:06	TRANSFORMER FAULT
361	24-Mar-19	BAGALKOT	110	BPCL-NARGUND	NARGUND_110	9:55	16:00	6:05	LINE CLEAR AVAILED
362	24-Mar-19	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110, ALANAVAR_33	11:21	11:36	0:15	TRANSFORMER FAULT
363	24-Mar-19	BAGALKOT	110	KUDACHI-MORAB	MORAB_110	13:15	16:36	3:21	LINE CLEAR AVAILED
364	24-Mar-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	10:04	15:57	5:53	LINE CLEAR AVAILED
365	24-Mar-19	BAGALKOT	110	110/11KV, HV1	KONNUR_110	10:04	15:58	5:54	LINE CLEAR AVAILED
366	24-Mar-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	4:56	13:18	8:22	LINE FAULT
367	24-Mar-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	10:51	12:23	1:32	LINE CLEAR AVAILED
368	24-Mar-19	BAGALKOT	110	KONNUR-KERUR	KERUR_110	10:04	16:36	6:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
369	24-Mar-19	BAGALKOT	110	KONNUR-KERUR	KERUR_110	18:04	18:10	0:06	HAND TRIPPED
370	24-Mar-19	BANGALORE	66	HV1	VIJAYANAGARA	22:15	22:28	0:13	LOAD CHANGEOVER
371	24-Mar-19	BANGALORE	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220	20:08	20:39	0:30	LINE CLEAR AVAILED
372	24-Mar-19	BANGALORE	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	15:50	16:00	0:10	LOAD CHANGEOVER
373	24-Mar-19	BANGALORE	66	ABBIGERE - DG3	ABBIGERE	16:45	16:50	0:05	LOAD CHANGEOVER
374	24-Mar-19	BANGALORE	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	9:55	10:10	0:15	LOAD CHANGEOVER
375	24-Mar-19	BANGALORE	66	ABBIGERE - DG3	ABBIGERE	12:05	12:10	0:05	LOAD CHANGEOVER
376	24-Mar-19	BANGALORE	66	MANYATHA TECH PARK - DG 3	MANYATHA TECH PARK	9:55	16:42	6:47	LINE CLEAR AVAILED
377	24-Mar-19	BANGALORE	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	9:54	11:54	2:00	LINE CLEAR AVAILED
378	24-Mar-19	BANGALORE	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	15:50	16:40	0:50	LINE CLEAR AVAILED
379	24-Mar-19	BANGALORE	66	HV1	WIDIA	6:57	8:55	1:57	LINE CLEAR AVAILED
380	24-Mar-19	BANGALORE	66	NRS 220 - TELECOM LAYOUT	TELECOM LAYOUT	10:08	16:35	6:26	LINE CLEAR AVAILED
381	24-Mar-19	BANGALORE	66	PLATINUM CITY - DG 3	PLATINUM CITY	10:00	10:10	0:10	LOAD CHANGEOVER
382	24-Mar-19	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	13:25	13:30	0:05	LOAD CHANGEOVER
383	24-Mar-19	BANGALORE	66	PLATINUM CITY - DG 3	PLATINUM CITY	15:55	16:05	0:10	LOAD CHANGEOVER
384	24-Mar-19	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	16:30	16:35	0:05	LOAD CHANGEOVER
385	24-Mar-19	BANGALORE	220	HV1	NRS 220	10:25	16:37	6:11	LINE CLEAR AVAILED
386	24-Mar-19	BANGALORE	220	HV2	NRS 220	10:25	16:37	6:11	LINE CLEAR AVAILED
387	24-Mar-19	BANGALORE	66	HV3	NRS 220	10:24	16:37	6:12	LINE CLEAR AVAILED
388	24-Mar-19	BANGALORE	66	HV4	NRS 220	10:21	16:37	6:15	LINE CLEAR AVAILED
389	24-Mar-19	BANGALORE	66	HV5	NRS 220	10:24	16:37	6:12	LINE CLEAR AVAILED
390	24-Mar-19	BANGALORE	66	HV1	NRS 220	10:21	16:37	6:15	LINE CLEAR AVAILED
391	24-Mar-19	BANGALORE	66	HV2	NRS 220	10:21	16:37	6:15	LINE CLEAR AVAILED
392	24-Mar-19	BANGALORE	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	20:08	20:48	0:39	MAIN SUPPLY FAILURE
393	24-Mar-19	BANGALORE	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2	20:08	20:47	0:39	MAIN SUPPLY FAILURE
394	24-Mar-19	BANGALORE	66	HV3	NAGANATHPURA 220	20:08	20:44	0:36	MAIN SUPPLY FAILURE
395	24-Mar-19	BANGALORE	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA (EHT)	8:29	8:48	0:18	LINE CLEAR AVAILED
396	24-Mar-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	10:25	10:28	0:03	LOAD CHANGEOVER
397	24-Mar-19	BANGALORE	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	5:10	5:15	0:05	LOAD CHANGEOVER
398	24-Mar-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	15:06	15:48	0:41	LINE FAULT
399	24-Mar-19	BANGALORE	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	18:05	18:15	0:10	LOAD CHANGEOVER
400	24-Mar-19	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	9:39	9:48	0:09	LOAD CHANGEOVER
401	24-Mar-19	BANGALORE	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	0:20	0:30	0:10	LOAD CHANGEOVER
402	24-Mar-19	BANGALORE	66	BANASHANKARI - AREHALLI	BANASHANKARI	22:25	22:30	0:05	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
403	24-Mar-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:52	8:55	0:02	LINE FAULT
404	24-Mar-19	BANGALORE	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	7:49	8:05	0:16	LINE FAULT
405	24-Mar-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	6:11	6:19	0:08	LINE FAULT
406	24-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	0:07	3:02	2:55	LINE CLEAR AVAILED
407	24-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	9:48	17:52	8:04	LINE CLEAR AVAILED
408	24-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	0:07	3:02	2:55	LINE CLEAR AVAILED
409	24-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:48	17:52	8:04	LINE CLEAR AVAILED
410	24-Mar-19	BANGALORE	66	YEDMADU - HANUMANTHNAGARA	YEDMADU	18:10	18:15	0:05	LOAD CHANGEOVER
411	24-Mar-19	GULBARGA	110	KAPNOOR-HUMNABAD2	MAHAGOAN AND MARGUTTI_110	5:14	5:25	0:11	LINE FAULT
412	24-Mar-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURGUNTA_110	10:00	17:30	7:30	LINE CLEAR AVAILED
413	24-Mar-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:53	18:02	9:09	LINE CLEAR AVAILED
414	24-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	23:57	23:59	0:02	LINE FAULT
415	24-Mar-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	23:57	23:59	0:02	LINE FAULT
416	24-Mar-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:54	18:03	9:09	NFBC ISSUED
417	24-Mar-19	HASSAN	110	HV3	BANTWAL_110	18:51	19:00	0:09	TRANSFORMER FAULT
418	24-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:17	18:23	11:06	LOAD CURTAILMENT
419	24-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	6:28	18:23	11:55	LOAD CURTAILMENT
420	24-Mar-19	HASSAN	66	HV1	ALDUR_66	7:17	18:24	11:07	LOAD CURTAILMENT
421	24-Mar-19	HASSAN	66	HV2	BELUR_66	9:34	18:50	9:16	LINE CLEAR AVAILED
422	24-Mar-19	HASSAN	66	HV1	BELUR_66	23:09	23:14	0:05	TRANSFORMER FAULT
423	24-Mar-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	9:34	18:50	9:16	LINE CLEAR AVAILED
424	24-Mar-19	HASSAN	66	HV1	BYACHANAHALLY_66	9:19	19:23	10:04	TRANSFORMER FAULT
425	24-Mar-19	HASSAN	66	HV1	BYACHANAHALLY_66	10:20	10:25	0:05	TRANSFORMER FAULT
426	24-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	6:27	18:21	11:54	LINE CLEAR AVAILED
427	24-Mar-19	HASSAN	66	HV1	DODDAKADANUR_66	6:50	6:59	0:09	TRANSFORMER FAULT
428	24-Mar-19	MYSORE	66	HANAGODU-PONNAMPETE	PONNAMPET_66 VIRAJPETE	17:40	18:50	1:10	LINE CLEAR AVAILED
429	24-Mar-19	MYSORE	66	HV1	HEBBAL_66	16:44	16:55	0:11	HAND TRIPPED
430	24-Mar-19	MYSORE	66	HV1	HEBBAL_66	19:52	20:40	0:47	HAND TRIPPED
431	24-Mar-19	MYSORE	66	HV2	HEBBAL_66	14:07	20:52	6:45	TRANSFORMER FAULT
432	24-Mar-19	MYSORE	66	HV2	HEBBAL_66	20:57	21:00	0:03	HAND TRIPPED
433	24-Mar-19	MYSORE	66	KM DODDI-TK HALLI	K_HONNALGERE_66 KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66_66	12:03	12:21	0:18	LINE FAULT
434	24-Mar-19	MYSORE	66	MADHUVANAHALLI-HANNUR 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	18:23	18:55	0:32	HAND TRIPPED
435	24-Mar-19	MYSORE	66	MADHUVANAHALLI-DODDINADUVADI	DODDINADUVADI_66	18:23	18:55	0:32	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
436	24-Mar-19	MYSORE	66	HV2	MADHUVANAHALLI_220	18:22	19:04	0:41	TRANSFORMER FAULT
437	24-Mar-19	MYSORE	66	HV1	MADHUVANAHALLI_220	18:22	18:50	0:28	HAND TRIPPED
438	24-Mar-19	MYSORE	66	MANDYA-M2	HADLI_66 MALAVALLI_66	12:18	12:27	0:09	LINE FAULT
439	24-Mar-19	MYSORE	66	MANDYA-M2	HADLI_66 MALAVALLI_66	16:52	17:00	0:08	LINE FAULT
440	24-Mar-19	MYSORE	66	MANDYA-M2	HADLI_66 MALAVALLI_66	17:28	17:39	0:11	LINE FAULT
441	24-Mar-19	MYSORE	66	METAGALLY-HEBBAL	METAGALLY_66 SRIRANGAPATNA_66	17:35	17:45	0:10	HAND TRIPPED
442	24-Mar-19	MYSORE	66	METAGALLY-G UKKADA	METAGALLY_66 SRIRANGAPATNA_66	17:35	17:45	0:10	HAND TRIPPED
443	24-Mar-19	MYSORE	66	HV1	PANDAVAPURA_66	7:13	8:52	1:38	LINE CLEAR AVAILED
444	24-Mar-19	MYSORE	66	HV2	PANDAVAPURA_66	7:13	8:49	1:36	LINE CLEAR AVAILED
445	24-Mar-19	MYSORE	66	HV1	PGPALYA_66	18:29	18:54	0:24	HAND TRIPPED
446	24-Mar-19	MYSORE	66	HV3	SFCSHIVA_66	9:25	9:35	0:10	TRANSFORMER FAULT
447	24-Mar-19	MYSORE	220	HV1	TUBINAKERE_220 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66	7:06	8:06	1:00	TRANSFORMER FAULT
448	24-Mar-19	MYSORE	220	HV2	TUBINAKERE_220 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66	7:06	8:06	1:00	TRANSFORMER FAULT
449	24-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66	16:17	16:23	0:06	LINE FAULT
450	24-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66	17:42	17:47	0:05	LINE FAULT
451	24-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	23:07	23:14	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
452	24-Mar-19	TUMKUR	110	TR-1	KADABA_110	2:00	2:11	0:11	TRANSFORMER FAULT
453	24-Mar-19	TUMKUR	110	TR-1	KADABA_110	6:19	7:01	0:41	TRANSFORMER FAULT
454	24-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:38	17:35	8:56	LINE CLEAR AVAILED
455	24-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:44	13:51	0:07	LINE FAULT
456	25-Mar-19	BAGALKOT	110	SUPA 1-AMBEWADI	AMBEWADI_220	17:07	18:44	1:37	LINE FAULT
457	25-Mar-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	15:30	23:59	8:29	LINE FAULT
458	25-Mar-19	BAGALKOT	110	AMBEWADI220-KAVALWADA	KAVALWADA_110	15:02	23:59	8:57	LINE CLEAR AVAILED
459	25-Mar-19	BAGALKOT	110	110/11KV,HV2	ANDANDA NAGAR_110	19:43	19:57	0:14	TRANSFORMER FAULT
460	25-Mar-19	BAGALKOT	110	110/11KV,HV1	ANDANDA NAGAR_110	20:43	21:03	0:20	TRANSFORMER FAULT
461	25-Mar-19	BAGALKOT	110	BAGALKOT220-NEERBUDIHAL	NEERABUDIHAL_110	12:29	12:37	0:08	LINE FAULT
462	25-Mar-19	BAGALKOT	220	BELGAUM-KANABARGI 2	BELGAUM_220	0:00	8:16	8:16	LINE CLEAR AVAILED
463	25-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	8:28	8:28	LINE CLEAR AVAILED
464	25-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:06	23:59	5:53	LINE CLEAR AVAILED
465	25-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	15:56	18:20	2:24	LINE FAULT
466	25-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	19:55	20:04	0:09	HAND TRIPPED
467	25-Mar-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	14:26	14:53	0:27	LINE FAULT
468	25-Mar-19	BAGALKOT	220	CHIKKODI-TALANDAGE	CHIKKODI_220	15:26	17:03	1:37	LINE FAULT
469	25-Mar-19	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	15:45	17:20	1:35	LINE CLEAR AVAILED
470	25-Mar-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	15:53	16:54	1:01	LINE FAULT
471	25-Mar-19	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	ANKALAGI_110	16:54	23:59	7:05	LINE CLEAR AVAILED
472	25-Mar-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	16:42	16:48	0:06	HAND TRIPPED
473	25-Mar-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	20:16	20:46	0:30	HAND TRIPPED
474	25-Mar-19	BAGALKOT	220	KADRA 2-KARWAR	KARWAR_220	10:58	18:14	7:16	LINE CLEAR AVAILED
475	25-Mar-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	17:27	17:56	0:29	LINE FAULT
476	25-Mar-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	15:35	20:37	5:02	LINE FAULT
477	25-Mar-19	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	18:29	23:59	5:30	LINE FAULT
478	25-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	15:00	15:08	0:08	HAND TRIPPED
479	25-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	16:31	23:59	7:28	LINE FAULT
480	25-Mar-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	18:23	18:45	0:22	LINE FAULT
481	25-Mar-19	BAGALKOT	110	SIRSI110-JOG2	SIRSI_110	13:53	14:09	0:16	LINE FAULT
482	25-Mar-19	BAGALKOT	110	SIRSI110-JOG2	SIRSI_110	14:09	18:54	4:45	LINE FAULT
483	25-Mar-19	BAGALKOT	110	SIRSI110-KUMTA1	KUMTA_110	18:10	20:24	2:14	LINE CLEAR AVAILED
484	25-Mar-19	BAGALKOT	110	SIRSI110-KUMTA2	KUMTA_110	18:12	20:26	2:14	LINE CLEAR AVAILED
485	25-Mar-19	BAGALKOT	110	SIRSI110-JOG1	SIRSI_110	18:10	18:54	0:44	LINE CLEAR AVAILED
486	25-Mar-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	7:49	10:31	2:42	LINE CLEAR AVAILED
487	25-Mar-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	17:06	18:23	1:17	LINE CLEAR AVAILED
488	25-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	15:56	19:53	3:57	LINE FAULT
489	25-Mar-19	BAGALKOT	110	KONNUR-NAVALGUND	NAVALGUND_110	19:59	20:32	0:33	LINE CLEAR AVAILED
490	25-Mar-19	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD	16:04	16:20	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
491	25-Mar-19	BAGALKOT	110	110/11KV,HV1	MUDALGI_110	8:53	14:44	5:51	TRANSFORMER FAULT
492	25-Mar-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	18:03	19:27	1:24	LINE CLEAR AVAILED
493	25-Mar-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	20:30	20:39	0:09	HAND TRIPPED
494	25-Mar-19	BAGALKOT	220	NARENDRA220-AMBEWADI1	NARENRA_220	15:30	23:59	8:29	LINE FAULT
495	25-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	0:00	14:59	14:59	LINE CLEAR AVAILED
496	25-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	11:35	17:53	6:18	LINE CLEAR AVAILED
497	25-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	18:48	18:55	0:07	TRANSFORMER FAULT
498	25-Mar-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	20:16	20:22	0:06	TRANSFORMER FAULT
499	25-Mar-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	1:53	1:56	0:03	TRANSFORMER FAULT
500	25-Mar-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	17:40	18:23	0:43	LINE CLEAR AVAILED
501	25-Mar-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	18:53	19:02	0:09	TRANSFORMER FAULT
502	25-Mar-19	BANGALORE	66	VIJAYANAGAR - NRS 220	VIJAYANAGARA	15:46	16:51	1:05	LINE CLEAR AVAILED
503	25-Mar-19	BANGALORE	66	HV2	VIJAYANAGARA	22:33	22:38	0:05	LOAD CHANGEOVER
504	25-Mar-19	BANGALORE	66	HV3	YERANDANAHALLI 220	9:01	9:04	0:02	LOAD CHANGEOVER
505	25-Mar-19	BANGALORE	66	HV2	YERANDANAHALLI 220	9:10	9:15	0:05	LOAD CHANGEOVER
506	25-Mar-19	BANGALORE	66	NRS 220 - VIJAYANAGAR 2	VIJAYANAGARA	12:51	13:05	0:13	LINE FAULT
507	25-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	21:00	21:05	0:05	LINE FAULT
508	25-Mar-19	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	7:09	7:25	0:15	LINE FAULT
509	25-Mar-19	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	13:48	14:06	0:17	LINE CLEAR AVAILED
510	25-Mar-19	BANGALORE	66	HV2	ISRO LAYOUT	10:27	10:40	0:12	TRANSFORMER FAULT
511	25-Mar-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	11:37	11:59	0:21	LINE FAULT
512	25-Mar-19	BANGALORE	66	ELECTRONIC CITY -YARANDANAHALLI	ELECTRONIC CITY, INFOSYS (EHT)	8:11	8:17	0:06	LOAD CHANGEOVER
513	25-Mar-19	BANGALORE	66	HV2	BIDADI 220	21:05	21:52	0:47	LINE CLEAR AVAILED
514	25-Mar-19	GULBARGA	110	HV1	KOLHAR_110	15:23	15:29	0:06	LINE CLEAR AVAILED
515	25-Mar-19	GULBARGA	110	HV1	KUDITINI_110	7:37	7:50	0:13	LINE CLEAR AVAILED
516	25-Mar-19	GULBARGA	110	RAJESHWAR-WARADHA SLR	RAJESHWAR_110	18:24	20:40	2:16	LINE CLEAR AVAILED
517	25-Mar-19	GULBARGA	110	HV1	SIRWAR_110	18:16	18:43	0:27	LINE CLEAR AVAILED
518	25-Mar-19	GULBARGA	110	GULBARGA SOUTH-GULBARGA WEST	GULBARGASOUTH_110	19:45	19:55	0:10	LINE FAULT
519	25-Mar-19	GULBARGA	110	GULBARGA SOUTH-SHAHBAD	SHAHBAD_220	19:45	20:40	0:55	LINE FAULT
520	25-Mar-19	GULBARGA	110	GULBARGA SOUTH-FARTHABAD	FARTHABAD_110	20:45	20:50	0:05	LINE FAULT
521	25-Mar-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:58	18:11	8:13	LINE CLEAR AVAILED
522	25-Mar-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	18:23	23:59	5:36	LINE FAULT
523	25-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	0:00	11:37	11:37	LINE FAULT
524	25-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	18:17	23:25	5:08	LINE FAULT
525	25-Mar-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	0:00	11:38	11:38	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
526	25-Mar-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	18:29	23:59	5:30	LINE FAULT
527	25-Mar-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:58	18:11	8:13	NFBC ISSUED
528	25-Mar-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	18:23	23:59	5:36	LINE FAULT
529	25-Mar-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_!10	18:25	19:32	1:07	LINE FAULT
530	25-Mar-19	HASSAN	110	HV3	BANTWAL_110	14:26	14:34	0:08	TRANSFORMER FAULT
531	25-Mar-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	13:31	13:43	0:12	LINE FAULT
532	25-Mar-19	HASSAN	110	JOG-NK2	mghejog_gen	13:53	18:56	5:03	LINE FAULT
533	25-Mar-19	HASSAN	110	HV1	KULASHEKARA_110	10:57	11:03	0:06	TRANSFORMER FAULT
534	25-Mar-19	HASSAN	110	HV2	KULASHEKARA_110	10:57	11:03	0:06	TRANSFORMER FAULT
535	25-Mar-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:57	11:03	0:06	LINE FAULT
536	25-Mar-19	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	13:46	13:50	0:04	LINE FAULT
537	25-Mar-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	19:03	19:18	0:15	LOAD CURTAILMENT
538	25-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:33	21:55	0:22	LINE FAULT
539	25-Mar-19	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	22:08	23:27	1:19	LOAD CURTAILMENT
540	25-Mar-19	HASSAN	66	SAKALE-HASSAN 1	SAKLESH PURA_66	19:02	19:20	0:18	LINE FAULT
541	25-Mar-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:41	19:29	11:48	LINE CLEAR AVAILED
542	25-Mar-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:41	19:30	11:49	LINE CLEAR AVAILED
543	25-Mar-19	HASSAN	66	HV1	SIGEBAGE_66	18:17	23:59	5:42	TRANSFORMER FAULT
544	25-Mar-19	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	18:39	19:11	0:32	LINE CLEAR AVAILED
545	25-Mar-19	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	22:03	23:26	1:23	LINE CLEAR AVAILED
546	25-Mar-19	MYSORE	66	FTS-HOOTAGALLI 2	FTS_66	6:40	23:59	17:19	LINE FAULT
547	25-Mar-19	MYSORE	66	HV2	HARVEY_66	18:01	18:36	0:35	LINE CLEAR AVAILED
548	25-Mar-19	MYSORE	66	HOOTAGALLI-FTS 1	FTS_66	6:35	6:55	0:20	LINE FAULT
549	25-Mar-19	MYSORE	66	HV1	KADAKOLA_220	0:09	0:42	0:32	HAND TRIPPED
550	25-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 2	JAIPUR_66 HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66	12:57	16:48	3:50	LINE CLEAR AVAILED
551	25-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66 HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66	12:57	16:48	3:50	LINE CLEAR AVAILED
552	25-Mar-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:13	14:44	4:31	LINE CLEAR AVAILED
553	25-Mar-19	MYSORE	66	MANDYA-M2	HADLI_66 MALAVALLI_66	7:28	7:34	0:06	LINE FAULT
554	25-Mar-19	MYSORE	66	MANDYA-M2	HADLI_66 MALAVALLI_66	8:37	8:45	0:08	LINE FAULT
555	25-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	17:24	17:30	0:05	TRANSFORMER FAULT
556	25-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	18:13	23:59	5:45	LINE CLEAR AVAILED
557	25-Mar-19	MYSORE	66	HV1	THANDYA_66	13:44	23:59	10:14	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
558	25-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66	7:01	7:08	0:07	LINE FAULT
559	25-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:40	19:21	13:41	LINE CLEAR AVAILED
560	25-Mar-19	TUMKUR	220	TR-1 & TR-2	MADHUGIRI_220	18:42	18:54	0:12	HAND TRIPPED
561	25-Mar-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	9:26	16:55	7:28	LOAD CURTAILMENT
562	25-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:41	19:25	13:44	LINE CLEAR AVAILED
563	25-Mar-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	11:43	14:57	3:14	LINE FAULT
564	25-Mar-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:54	13:17	0:22	LINE FAULT
565	25-Mar-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	14:58	15:17	0:18	HAND TRIPPED
566	25-Mar-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	14:59	16:17	1:17	LINE CLEAR AVAILED
567	25-Mar-19	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	14:58	15:20	0:21	HAND TRIPPED
568	25-Mar-19	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	14:59	16:17	1:17	LINE CLEAR AVAILED
569	25-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:49	16:17	6:28	LINE FAULT
570	25-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	14:59	16:17	1:18	LINE CLEAR AVAILED
571	25-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:33	12:27	1:53	LINE CLEAR AVAILED
572	25-Mar-19	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	12:29	12:44	0:14	HAND TRIPPED
573	25-Mar-19	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	15:21	15:27	0:06	HAND TRIPPED
574	25-Mar-19	TUMKUR	66	TR-2	BEVINAHALLI_66	12:24	13:16	0:52	LINE CLEAR AVAILED
575	25-Mar-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	12:48	16:49	4:01	LINE CLEAR AVAILED
576	25-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:42	12:48	5:06	LINE CLEAR AVAILED
577	25-Mar-19	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	12:48	16:30	3:42	LINE CLEAR AVAILED
578	25-Mar-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	11:50	12:55	1:05	MAIN SUPPLY FAILURE
579	25-Mar-19	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66	12:55	15:21	2:25	MAIN SUPPLY FAILURE
580	25-Mar-19	TUMKUR	66	HANAGAL- B G KERE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	15:21	15:28	0:06	MAIN SUPPLY FAILURE
581	25-Mar-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	12:55	12:58	0:02	MAIN SUPPLY FAILURE
582	25-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:04	9:16	0:11	LINE FAULT
583	25-Mar-19	TUMKUR	66	TR-2	NAGALMADIKE_66	11:35	12:41	1:05	TRANSFORMER FAULT
584	25-Mar-19	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	WELSPUN_IPP_SOLAR_66	12:30	13:00	0:30	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
585	25-Mar-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	12:30	12:59	0:29	HAND TRIPPED
586	25-Mar-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	15:33	15:34	0:01	MAIN SUPPLY FAILURE