

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 29.09.2020 TO 05.10.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	29-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVOIDED
2	29-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
3	29-Sep-2020	BAGALKOT	110	110/11KV,HV3	LOKAPUR_110	10:35	10:45	00:10	TRANSFORMER FAULT
4	29-Sep-2020	BAGALKOT	110	110/11KV,HV5	RANEBENNUR_220	07:35	08:22	00:47	TRANSFORMER FAULT
5	29-Sep-2020	BAGALKOT	110	110/33, HV3	HUNAGUND_110, AMINAGAD_33, KARADI_33, MYTRA IPP	15:30	15:40	00:10	TRANSFORMER FAULT
6	29-Sep-2020	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	23:47 (28.09.2020)	22:30 (29.09.2020)	22:43 hrs	TRANSFORMER CHARGED
7	29-Sep-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED VAJJARMATTI 220	09:54	13:00	03:06	LINE CLEAR AVOIDED
8	29-Sep-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI 220	23:46 (28.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVOIDED
9	29-Sep-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED VAJJARMATTI 220	09:53	13:07	03:14	LINE CLEAR AVOIDED
10	29-Sep-2020	BAGALKOT	110	ATHANI220- THOUSHI(BALIGERI)	STATION NOT AFFECTED THOUSHI 110	00:33	00:38	00:05	LINE FAULT
11	29-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVOIDED
12	29-Sep-2020	BAGALKOT	110	GADAG220-DAMBAL	STATION NOT AFFECTED DAMBAL 110	18:34	18:39	00:05	LINE CLEAR AVOIDED
13	29-Sep-2020	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	STATION NOT AFFECTED SAMBAPUR ROAD 110	17:06	17:37	00:31	LINE FAULT
14	29-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVOIDED
15	29-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVOIDED
16	29-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVOIDED
17	29-Sep-2020	BAGALKOT	110	HAVERI220- TILUVALI(HANGAL)	TILUVALI_110	06:07	06:45	00:38	LINE FAULT
18	29-Sep-2020	BAGALKOT	110	HUNAGUND-JINDAL	JINDAL(EHT)_110	12:55	13:10	00:15	LINE CLEAR AVOIDED
19	29-Sep-2020	BAGALKOT	110	ILKAL1-HUNGUND	STATION NOT AFFECTED HUNGUND 110	18:55 (28.09.2020)	13:25 (29.09.2020)	18:30 hrs	LINE CHARGED
20	29-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWA DI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVOIDED
21	29-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
22	29-Sep-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
23	29-Sep-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
24	29-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI 110	16:50 (25.09.2020)	23:55(29.09.2020)	138:42HRS	LINE CHARGED
25	29-Sep-2020	BAGALKOT	110	VAJJARAMATTI220-MANTUR(MUDHOL)	MUDHOL_110	09:36	09:55	00:19	HAND TRIPPED
26	29-Sep-2020	BAGALKOT	110	VAJJARAMATTI220-MANTUR(MUDHOL)	MUDHOL_110	12:58	13:02	00:04	HAND TRIPPED
27	29-Sep-2020	BAGALKOT	110	VAJJARAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
28	29-Sep-2020	BAGALKOT	220	220/110KV,HV1,HV2	STATION NOT AFFECTED MK HUBLI 220	11:22	22:30	11:08	LINE CLEAR AVAILED
29	29-Sep-2020	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED GADAG 220	13:05 (24.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
30	29-Sep-2020	BAGALKOT	220	BAGALKOT-VAJJARAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
31	29-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
32	29-Sep-2020	BAGALKOT	220	BAGLAKOT-GADAG 2	STATION NOT AFFECTED BAGALKOT 220	18:03 (24.09.2020)	12:10 (29.09.2020)	18:07 hrs	LINE CHARGED
33	29-Sep-2020	BAGALKOT	220	BALLIGAVI-RANEENNUR	STATION NOT AFFECTED RANEENNUR 220	11:45	11:57	00:12	LOAD CURTAILMENT
34	29-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	00:26	06:55	06:29	LOAD CURTAILMENT
35	29-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	21:52 (29.09.2020)			LOAD CURTAILMENT
36	29-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
37	29-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG 220	16:28 (24.09.2020)	12:11 (29.09.2020)	19:43 hrs	LINE CHARGED
38	29-Sep-2020	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI 220	10:14	17:05	06:51	LINE CLEAR AVAILED
39	29-Sep-2020	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI 220	14:34 (28.09.2020)	17:05 (29.09.2020)	2:31 hrs	LINE CHARGED
40	29-Sep-2020	BAGALKOT	220	HUBLI220-NAGJHARI1	STATION NOT AFFECTE HUBLI 220	04:08	04:27	00:19	LOAD CURTAILMENT
41	29-Sep-2020	BAGALKOT	220	HUBLI220-NAGJHARI2	STATION NOT AFFECTE HUBLI 220	04:09	04:29	00:20	LOAD CURTAILMENT
42	29-Sep-2020	BAGALKOT	220	MAHALINGAPUR-VAJJARAMATTI1	STATION NOT AFFECTED MAHALINGAPUR 220	10:05	15:52	05:47	LINE CLEAR AVAILED
43	29-Sep-2020	BAGALKOT	220	MAHALINGAPUR-VAJJARAMATTI2	STATION NOT AFFECTED MAHALINGAPUR_220	15:23 (28.09.2020)	12:50 (29.09.2020)	21:27 hrs	LINE CHARGED
44	29-Sep-2020	BAGALKOT	220	MKHUBLI- NARENDRA2	STATION NOT AFFECTED MK HUBLI 220	8:02 (27.09.2020)	22:38 (29.09.2020)	15:53 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
45	29-Sep-2020	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI 220	12:20 (27.09.2020)	23:55 (29.09.2020)	11:35 hrs	LINE CHARGED
46	29-Sep-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	5:13 (25.09.2020)	23:55 (29.09.2020)	18:42 hrs	LINE CHARGED
47	29-Sep-2020	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, NELAMANGALA 66,BIEC	22:15	22:32	00:17	MAIN SUPPLY FAILURE
48	29-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
49	29-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN , LINE FAULT
50	29-Sep-2020	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:54	12:10	00:16	LOAD CHANGE OVER
51	29-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	07:24	07:29	00:05	LOAD CHANGE OVER
52	29-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	23:21	23:46	00:25	LOAD CHANGE OVER
53	29-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	23:21	23:46	00:25	LOAD CHANGE OVER
54	29-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	23:21	23:46	00:25	LOAD CHANGE OVER
55	29-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	23:21	23:46	00:25	LOAD CHANGE OVER
56	29-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	23:21	23:46	00:25	LOAD CHANGE OVER
57	29-Sep-2020	BENGALURU	66	RAJANAKUNTE - DB PURA 220	RAJANAKUNTE	12:15	12:20	00:05	LOAD CHANGE OVER
58	29-Sep-2020	BENGALURU	66	SRS PEENYA 220 - DG2	NO STATION AFFECTED	22:15:00(29/09/2020)			LINE OPEN , LINE FAULT
59	29-Sep-2020	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	12:55	13:55	01:00	LINE FAULT
60	29-Sep-2020	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	10:31	11:05	00:34	LINE FAULT
61	29-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN , LINE FAULT
62	29-Sep-2020	GULBARGA	66	HV1	KUDLIGI_66	17:05	17:40	00:35	LINE CLEAR AVAILED
63	29-Sep-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_66	05:55	07:50	01:55	MAIN SUPPLY FAILURE
64	29-Sep-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_66	07:50	08:05	00:15	MAIN SUPPLY FAILURE
65	29-Sep-2020	GULBARGA	66	KUDLIGI-BALLATAGI	KUDLIGI_66	06:00	08:00	02:00	MAIN SUPPLY FAILURE
66	29-Sep-2020	GULBARGA	66	KUDLIGI-ITTAGGI1	KUDLIGI_66	10:55	11:05	00:10	LINE FAULT
67	29-Sep-2020	GULBARGA	66	KUDLIGI-ITTAGGI2	KUDLIGI_66	09:40	10:20	00:40	LINE FAULT
68	29-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	19:07	19:14	00:07	MAIN SUPPLY FAILURE
69	29-Sep-2020	GULBARGA	110	HATTI- SOMMANAMARDI IPP	HATTI_110	19:03	19:31	00:28	LINE FAULT
70	29-Sep-2020	GULBARGA	110	HUMNABAD- MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)	15:35(29.9.20 20)	238:46HR S	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
71	29-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	15:36	18:35	02:59	LINE FAULT
72	29-Sep-2020	GULBARGA	110	HV1	SINDHANOOR_110	10:45	15:05	04:20	LINE CLEAR AVAILED
73	29-Sep-2020	GULBARGA	110	HV1	MARAGUTTI_110	11:30	19:10	07:40	LINE CLEAR AVAILED
74	29-Sep-2020	GULBARGA	110	HV1,HV2	HANUMANAL_110	17:00	17:30	00:30	LINE CLEAR AVAILED
75	29-Sep-2020	GULBARGA	110	HV2	HATTI_110	09:30	09:38	00:08	TRANSFORMER FAULT
76	29-Sep-2020	GULBARGA	110	HV3	YELBURGA_110	21:20(28.9.2020)	2:30(29.9.2020)	5:10 HRS	TRANSFORMER CHARGED
77	29-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
78	29-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	20:08	20:18	00:10	LINE FAULT
79	29-Sep-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVAILED
80	29-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	21:55(28.9.2020)	7:24(29.9.2020)	9:29 HRS	LINE CHARGED
81	29-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	19:05	19:15	00:10	TRANSFORMER FAULT
82	29-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	19:05	19:20	00:15	TRANSFORMER FAULT
83	29-Sep-2020	GULBARGA	220	HV2	HUMNABAD_220	16:50	17:56	01:06	LINE CLEAR AVAILED
84	29-Sep-2020	GULBARGA	220	LINGAPUR-ARESSSTEEL IPP	LINGAPUR_220	14:40	17:15	02:35	LINE CLEAR AVAILED
85	29-Sep-2020	GULBARGA	220	LINGAPUR-JVSL_IPP	LINGAPUR_220	12:39	14:03	01:24	LINE FAULT
86	29-Sep-2020	GULBARGA	220	LINGAPUR-MUNIRABAD1	LINGAPUR_220	09:14	15:26	06:12	LINE CLEAR AVAILED
87	29-Sep-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	23:50(28.9.2020)	9:07(29.9.2020)	9:17 HRS	LINE CHARGED
88	29-Sep-2020	GULBARGA	220	SHAHAPUR-SHAHABAD1	SHAHAPUR_220	21:05(29.9.2020)			LINE OPEN ,LINE CLEAR AVAILED
89	29-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
90	29-Sep-2020	HASSAN	66	CRPTNA2-HNPURA	CRPATNA_220	08:45	17:13	08:28	LINE CLEAR AVAILED
91	29-Sep-2020	HASSAN	66	HV1	SINGAPURA_66	08:30	17:17	08:47	LINE CLEAR AVAILED
92	29-Sep-2020	HASSAN	66	HV2	SINGAPURA_66	08:30	17:17	08:47	LINE CLEAR AVAILED
93	29-Sep-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	08:30	17:17	08:47	LINE CLEAR AVAILED
94	29-Sep-2020	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	00:05	14:23	14:18	MAIN SUPPLY FAILURE
95	29-Sep-2020	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	09:41	11:10	01:29	LINE CLEAR AVAILED
96	29-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
97	29-Sep-2020	HASSAN	110	HV1	KONAJE_110	00:05	00:38	00:33	MAIN SUPPLY FAILURE
98	29-Sep-2020	HASSAN	110	HV1	KONAJE_110	01:39	01:45	00:06	HAND TRIPPED
99	29-Sep-2020	HASSAN	110	HV1	KONAJE_110	14:22	14:26	00:04	HAND TRIPPED
100	29-Sep-2020	HASSAN	110	HV2	KONAJE_110	00:05	00:38	00:33	MAIN SUPPLY FAILURE
101	29-Sep-2020	HASSAN	110	HV2	KONAJE_110	01:39	01:45	00:06	HAND TRIPPED
102	29-Sep-2020	HASSAN	110	HV2	KONAJE_110	14:22	14:26	00:04	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
103	29-Sep-2020	HASSAN	110	HV3	BHADRAVATHI_110	11:05	15:30	04:25	LINE CLEAR AVAILED
104	29-Sep-2020	HASSAN	110	HV3	KONAJE_110	00:05	00:38	00:33	MAIN SUPPLY FAILURE
105	29-Sep-2020	HASSAN	110	HV3	KONAJE_110	01:39	01:45	00:06	HAND TRIPPED
106	29-Sep-2020	HASSAN	110	HV3	KONAJE_110	14:22	14:26	00:04	HAND TRIPPED
107	29-Sep-2020	HASSAN	110	HV3	PUTTUR_110	09:40	13:41	04:01	LINE CLEAR AVAILED
108	29-Sep-2020	HASSAN	110	HV3	SAGARA_110	00:40	02:50	02:10	TRANSFORMER FAULT
109	29-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	12:35	12:40	00:05	LINE FAULT
110	29-Sep-2020	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	00:05	00:40	00:35	MAIN SUPPLY FAILURE
111	29-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
112	29-Sep-2020	HASSAN	110	LV1	KAVOOR_220	00:05	00:37	00:32	TRANSFORMER FAULT
113	29-Sep-2020	HASSAN	110	LV2	KAVOOR_220	00:05	00:37	00:32	TRANSFORMER FAULT
114	29-Sep-2020	HASSAN	110	MRSSHM-BD1	MRSMG_220	18:38	19:12	00:34	LINE CLEAR AVAILED
115	29-Sep-2020	HASSAN	110	MRSSHM-BD2	MRSMG_220	18:38	19:12	00:34	LINE CLEAR AVAILED
116	29-Sep-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	07:50	08:15	00:25	HAND TRIPPED
117	29-Sep-2020	HASSAN	110	SORABA-SHR220	SORABA_110	07:45	08:15	00:30	HAND TRIPPED
118	29-Sep-2020	HASSAN	220	HV3	KAVOOR_220	00:05	13:00	12:55	LINE CLEAR AVAILED
119	29-Sep-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	00:07	01:36	01:29	LINE CLEAR AVAILED
120	29-Sep-2020	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	00:07	00:34	00:27	HAND TRIPPED
121	29-Sep-2020	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	00:07	00:34	00:27	HAND TRIPPED
122	29-Sep-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	00:05	00:39	00:34	LINE FAULT
123	29-Sep-2020	HASSAN	220	KEMAR-Kavoor3	KEMAR_220	00:05	01:35	01:30	LINE FAULT
124	29-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	12:31	13:16	00:45	LINE FAULT
125	29-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	8:30 (26.09.2020)	15:26 (29.09.2020)	54:55 hrs	LINE CHARGED
126	29-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	15:32	18:01	02:29	LINE FAULT
127	29-Sep-2020	HASSAN	220	MRSSHM-VARAH11	MRSMG_220	10:21	13:11	02:50	LINE CLEAR AVAILED
128	29-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	8:30 (26.09.2020)	15:26 (29.09.2020)	54:55 hrs	LINE CHARGED
129	29-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	15:32	18:01	02:29	LINE FAULT
130	29-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
131	29-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:29 (28.09.2020)	6:23 (29.09.2020)	6:53 hrs	LINE CHARGED
132	29-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:04 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
133	29-Sep-2020	MYSORE	66	CHUNCHANAKATTE-KR NAGARA	KRNAGARA_66	10:20	13:05	02:45	NFBC ISSUED
134	29-Sep-2020	MYSORE	66	HV1	KRNAGARA_66	10:00	17:35	07:35	LINE CLEAR AVAILED
135	29-Sep-2020	MYSORE	66	HV1	MIRLE_66	10:30	16:30	06:00	LINE CLEAR AVAILED
136	29-Sep-2020	MYSORE	66	HV1	KRPET_220	15:08	15:24	00:16	LINE CLEAR AVAILED
137	29-Sep-2020	MYSORE	66	HV2	KRNAGARA_66	10:00	17:30	07:30	LINE CLEAR AVAILED
138	29-Sep-2020	MYSORE	66	HV2	KIRUGAVALU_66	11:08	12:06	00:57	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
139	29-Sep-2020	MYSORE	66	HV2	KRPET_220	14:44	15:08	00:24	HAND TRIPPED
140	29-Sep-2020	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	04:44	04:51	00:06	LINE FAULT
141	29-Sep-2020	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:53	17:02	05:09	NFBC ISSUED
142	29-Sep-2020	MYSORE	66	KR NAGARA -BILIKERE	KRNAGARA_66	11:05	14:00	02:55	LINE CLEAR AVAILED
143	29-Sep-2020	MYSORE	66	KR PETE 220-BOOKANKERE	NO STATIONS EFFECTED	12:51	13:28	00:37	HAND TRIPPED
144	29-Sep-2020	MYSORE	66	KR PETE 220-KR PETE 1	NO STATIONS EFFECTED	11:35	12:17	00:42	HAND TRIPPED
145	29-Sep-2020	MYSORE	66	KR PETE 220-KR PETE 2	NO STATIONS EFFECTED	12:20	12:40	00:20	HAND TRIPPED
146	29-Sep-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	15:21	16:03	00:42	HAND TRIPPED
147	29-Sep-2020	MYSORE	66	KUSHALNAGARA-MYSORE-1	MIRLE_66 KRNAGARA_66	12:52	14:49	01:57	LINE CLEAR AVAILED
148	29-Sep-2020	MYSORE	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	14:04	14:41	00:37	LINE FAULT
149	29-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR-1	NO STATIONS EFFECTED	22:43	22:49	00:06	LINE FAULT
150	29-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR-2	NO STATIONS EFFECTED	20:41	20:46	00:05	LINE FAULT
151	29-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	14:40	14:45	00:05	LINE FAULT
152	29-Sep-2020	MYSORE	66	TUBINKERE-NAGMANGALA-1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	13:15	13:20	00:05	LINE FAULT
153	29-Sep-2020	MYSORE	220	HV1	KRPET_220	13:06	13:28	00:22	HAND TRIPPED
154	29-Sep-2020	MYSORE	220	HV2	KUSHALNAGARA_220	11:23	12:47	01:24	LINE CLEAR AVAILED
155	29-Sep-2020	MYSORE	220	HV2	BEGUR_220	11:50	17:10	05:20	LINE CLEAR AVAILED
156	29-Sep-2020	MYSORE	220	HV2	VAJAMANGALA_220	10:06	13:04	02:58	LINE CLEAR AVAILED
157	29-Sep-2020	MYSORE	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)	11:45 (29/09/2020)	241:35 HRS	LINE CHARGED
158	29-Sep-2020	MYSORE	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)	11:45 (29/09/2020)	241:35 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
159	29-Sep-2020	TUMKUR	66	HONNALLI 220kv-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	09:08	09:23	00:14	LINE FAULT
160	29-Sep-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	15:14	15:23	00:09	LINE FAULT
161	29-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	12:18	12:31	00:13	LINE FAULT
162	29-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	12:59	13:06	00:07	LINE FAULT
163	29-Sep-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:16	15:57	02:41	LINE FAULT
164	29-Sep-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:40	14:50	00:10	LINE FAULT
165	29-Sep-2020	TUMKUR	66	PAVAGADA220-MIDIGESHI	MEDIGESHI_66	10:48	10:55	00:07	LINE FAULT
166	29-Sep-2020	TUMKUR	66	TAVAREKERE (H)-PATTNAYAKANAHALLI	TAVAREKERE(H)_66	10:27	12:24	01:56	LINE CLEAR AVAILED
167	29-Sep-2020	TUMKUR	66	TR-1	CHAWANAKUPPE_66	16:01	16:51	00:50	LINE CLEAR AVAILED
168	29-Sep-2020	TUMKUR	66	TR-1	HANAGAL_66	10:01	18:14	08:12	LINE CLEAR AVAILED
169	29-Sep-2020	TUMKUR	66	TR-1	HOLALKERE_66	10:57	16:55	05:58	LINE CLEAR AVAILED
170	29-Sep-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	20:26	21:00	00:33	TRANSFORMER FAULT
171	29-Sep-2020	TUMKUR	66	TR-2	HOLALKERE_66	11:56	16:55	04:58	LINE CLEAR AVAILED
172	29-Sep-2020	TUMKUR	66	TR-2	THOVINAKERE_66	18:03	18:36	00:32	LINE CLEAR AVAILED
173	29-Sep-2020	TUMKUR	110	TR-1	SAMPIGE_110	10:02	15:57	05:55	LINE CLEAR AVAILED
174	29-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
175	30-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
176	30-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
177	30-Sep-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	23:46 (28.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
178	30-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
179	30-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
180	30-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
181	30-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
182	30-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWA DI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
183	30-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
184	30-Sep-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
185	30-Sep-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
186	30-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
187	30-Sep-2020	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED GADAG 220	13:05 (24.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
188	30-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
189	30-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
190	30-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	21:52 (29.09.2020)			LOAD CURTAILMENT
191	30-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
192	30-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
193	30-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN , LINE FAULT
194	30-Sep-2020	BENGALURU	66	SRS PEENYA 220 - DG2	NO STATION AFFECTED	22:15:00(29/09/2020)			LINE OPEN , LINE FAULT
195	30-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN , LINE FAULT
196	30-Sep-2020	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	08:10	09:00	00:50	LINE CLEAR AVAILED
197	30-Sep-2020	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABUR_110	21:20	21:30	00:10	MAIN SUPPLY FAILURE
198	30-Sep-2020	GULBARGA	110	HANUMNABAD-SASTHAPUR	SASTHAPUR_110,RAJESHWAR_110,MANTHAL 110	19:40	19:52	00:12	LINE FAULT
199	30-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	20:11	20:16	00:05	MAIN SUPPLY FAILURE
200	30-Sep-2020	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	23:57	23:59	00:02	LINE FAULT
201	30-Sep-2020	GULBARGA	110	HV1	HANUMANAL_110	07:30	07:35	00:05	TRANSFORMER FAULT
202	30-Sep-2020	GULBARGA	110	HV2	HANUMANAL_110	07:10	07:35	00:25	TRANSFORMER FAULT
203	30-Sep-2020	GULBARGA	110	HV2	DEODURGA_110	20:35	20:51	00:16	TRANSFORMER FAULT
204	30-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
205	30-Sep-2020	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	10:37	12:46	02:09	LINE CLEAR AVAILED
206	30-Sep-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
207	30-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:30(30.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
208	30-Sep-2020	GULBARGA	220	HV2	KAPNOOR_220	10:25	10:30	00:05	TRANSFORMER FAULT
209	30-Sep-2020	GULBARGA	220	KAPNOOR-SHAHAPUR1	KAPNOOR_220	20:14(30.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
210	30-Sep-2020	GULBARGA	220	SHAHAPUR-SHAHABAD1	SHAHAPUR_220	21:05(29.9.2020)	9:12(30.9.2020)	12:07 HRS	LINE CHARGED
211	30-Sep-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:13	16:43	06:30	LINE CLEAR AVAILED
212	30-Sep-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:22	16:40	06:18	LINE CLEAR AVAILED
213	30-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
214	30-Sep-2020	HASSAN	66	HV1	ALDUR_66	10:33	16:41	06:08	LINE CLEAR AVAILED
215	30-Sep-2020	HASSAN	66	HV2	CHANNARA	12:02	18:39	06:37	LINE CLEAR AVAILED
216	30-Sep-2020	HASSAN	66	HV2	MALLAPURA_66	10:59	11:57	00:58	LINE CLEAR AVAILED
217	30-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
218	30-Sep-2020	HASSAN	110	HV1	KONAJE_110	10:48	14:25	03:37	LINE CLEAR AVAILED
219	30-Sep-2020	HASSAN	110	HV2	MSEZ_220	09:50	15:56	06:06	LINE CLEAR AVAILED
220	30-Sep-2020	HASSAN	110	HV3	BHADRAVATHI_110	13:14	13:57	00:43	LINE CLEAR AVAILED
221	30-Sep-2020	HASSAN	110	HV4	PUTTUR_110	09:12	12:46	03:34	LINE CLEAR AVAILED
222	30-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	10:10	12:05	01:55	LINE FAULT
223	30-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
224	30-Sep-2020	HASSAN	110	LV1	ARASIKERE_220	17:14	17:32	00:18	TRANSFORMER FAULT
225	30-Sep-2020	HASSAN	110	LV2	PUTTUR_220	12:09	13:16	01:07	LINE CLEAR AVAILED
226	30-Sep-2020	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	10:58	13:08	02:10	LINE CLEAR AVAILED
227	30-Sep-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:53	12:49	01:56	LINE CLEAR AVAILED
228	30-Sep-2020	HASSAN	220	HV1	ARASIKERE_220	17:14	17:32	00:18	TRANSFORMER FAULT
229	30-Sep-2020	HASSAN	220	HV2	PUTTUR_220	12:09	13:16	01:07	LINE CLEAR AVAILED
230	30-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	09:35	12:51	03:16	LINE CLEAR AVAILED
231	30-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:53	15:26	03:33	LINE FAULT
232	30-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	09:35	12:51	03:16	NFBC ISSUED
233	30-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:53	15:26	03:33	LINE FAULT
234	30-Sep-2020	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	11:53	13:51	01:58	LINE FAULT
235	30-Sep-2020	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	11:53	13:51	01:58	LINE FAULT
236	30-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
237	30-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:04 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
238	30-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:28 (30.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
239	30-Sep-2020	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	6:39	6:47	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
240	30-Sep-2020	MYSORE	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	11:22			LINE OPEN ,LINE CLEAR AVAILED
241	30-Sep-2020	MYSORE	66	ELWALA -HUNSUR	GAVADAGERE_66	3:08	3:28	0:19	LINE FAULT
242	30-Sep-2020	MYSORE	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	5:44	5:53	0:08	LINE FAULT
243	30-Sep-2020	MYSORE	66	HV1	ARAKERE_66	16:42	17:24	0:41	LINE CLEAR AVAILED
244	30-Sep-2020	MYSORE	66	HV1	DUNDANAHALLI_66	17:40	17:51	0:10	LINE CLEAR AVAILED
245	30-Sep-2020	MYSORE	66	HV2	KOPPA_66	13:41	14:28	0:47	LINE CLEAR AVAILED
246	30-Sep-2020	MYSORE	66	HV2	SATHEGALA_66	12:41	13:51	1:10	LINE CLEAR AVAILED
247	30-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	6:09	6:14	0:05	LINE FAULT
248	30-Sep-2020	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	6:40	6:50	0:09	LINE FAULT
249	30-Sep-2020	MYSORE	66	TN PURA-THAYUR	TNARASIPURA_66	14:02	14:07	0:04	HAND TRIPPED
250	30-Sep-2020	MYSORE	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	1:16	1:22	0:06	LINE FAULT
251	30-Sep-2020	MYSORE	220	HV1	KUSHALNAGARA_220	12:12	14:05	1:53	LINE CLEAR AVAILED
252	30-Sep-2020	MYSORE	220	HV2	CRNAGAR_220	10:40	17:36	6:55	LINE CLEAR AVAILED
253	30-Sep-2020	MYSORE	220	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	13:11	13:18	0:07	LINE FAULT
254	30-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
255	1-Oct-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
256	1-Oct-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
257	1-Oct-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
258	1-Oct-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
259	1-Oct-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
260	1-Oct-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
261	1-Oct-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
262	1-Oct-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
263	1-Oct-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
264	1-Oct-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
265	1-Oct-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
266	1-Oct-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
267	1-Oct-2020	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED GADAG 220	13:05 (24.09.2020)	18:46 (01.10.2020)	173:41hrs	TRANSFORMER CHARGED
268	1-Oct-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI 110	16:50 (25.09.2020)	10:08 (01.10.2020)	137:18hrs	LINE CHARGED
269	1-Oct-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
270	1-Oct-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI 220	23:46 (28.09.2020)	9:07 (30.09.2020)	24:40hrs	TRANSFORMER CHARGED
271	1-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	21:52 (29.09.2020)	7:05 (30.09.2020)	7:13hrs	LINE CHARGED
272	1-Oct-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
273	1-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM 220	14:35	15:05	0:30	LINE FAULT
274	1-Oct-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	13:25 (30.09.2020)	10:40 (01.10.2020)	21:15hrs	LINE CHARGED
275	1-Oct-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	23:32 (01.10.2020)			LOAD CURTAILMENT
276	1-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1&2	STATION NOT AFFECTED SIRSI 220	9:08	22:58	13:50	LOAD CURTAILMENT
277	1-Oct-2020	BAGALKOT	110	SIRSI220-SIRSI110	STATION NOT AFFECTED SIRSI 110	10:32	11:36	1:04	LOAD CURTAILMENT
278	1-Oct-2020	BAGALKOT	110	JOG2-SIRSI	STATION NOT AFFECTED SIRSI 110	12:40 (01.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
279	1-Oct-2020	BENGALURU	66	SRS PEENYA 220 - DG2	NO STATION AFFECTED	22:15:00(29/09/2020)	12:51:00(30/09/2020)	14:36hrs	LINE CHARGED
280	1-Oct-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)	18:33(30/09/2020)	211:29HRS	LINE CHARGED
281	1-Oct-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
282	1-Oct-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)	13:51(30-09-2020)	2174:26hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
283	1-Oct-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVAILED
284	1-Oct-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
285	1-Oct-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:30(30.09.2020)	6:22(1.10.2020)	7:52 HRS	LINE CHARGED
286	1-Oct-2020	GULBARGA	220	KAPNOOR-SHAHAPUR1	KAPNOOR_220	20:14(30.09.2020)	7:14(1.10.2020)	11:00 HRS	LINE CHARGED
287	1-Oct-2020	GULBARGA	220	ALIPUR-RAGHULPADU	NEELGUNDA_220,GUTTI_220	14:07	17:29	03:22	LINE FAULT
288	1-Oct-2020	GULBARGA	220	HV2	SHAHAPUR_220	00:01	00:14	00:13	TRANSFORMER FAULT
289	1-Oct-2020	GULBARGA	220	HV2	SHAHAPUR_220	01:04	03:05	02:01	TRANSFORMER FAULT
290	1-Oct-2020	GULBARGA	110	HV2	CHITGUPPA_110	15:02	15:10	00:08	TRANSFORMER FAULT
291	1-Oct-2020	GULBARGA	220	RTPS-LINGSUGUR2	RTPS_220	01:55	02:07	00:12	LINE FAULT
292	1-Oct-2020	GULBARGA	220	RTPS-LINGSUGUR1	RTPS_220	04:07	04:22	00:15	LINE FAULT
293	1-Oct-2020	GULBARGA	110	HATTI-GAMESHAWIND IPP	HATTI_110	23:57(30.09.2020)	00:05(01.10.2020)	00:08HRS	LINE CHARGED
294	1-Oct-2020	GULBARGA	110	SINDHANOOR-MUDDAPUR	MUDDAPUR_110,MASKI_110	11:45	14:23	02:38	LINE CLEAR AVAILED
295	1-Oct-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	12:04	14:10	02:06	LINE CLEAR AVAILED
296	1-Oct-2020	GULBARGA	110	HV1	RAJESHWAR_110	16:29	16:34	00:05	TRANSFORMER FAULT
297	1-Oct-2020	GULBARGA	66	ITTAGGI-KUDLIGI1,2	KUDLIGI_66,KOGALI_66,BANA VEKAL,CHORNOOR,GUDEKOTE_66,HANASI_66,CJHALLI_66,HOSALLI_66	12:20	13:30	01:10	LINE CLEAR AVAILED
298	1-Oct-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66,GIRIYAPURA_66,MAGALA_66,SOVENAHALLI_66,TUNGABHADRA_IPP	18:45	18:53	00:08	LINE FAULT
299	1-Oct-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66,GIRIYAPURA_66,MAGALA_66,SOVENAHALLI_66,TUNGABHADRA_IPP	01:06	01:25	00:19	LINE FAULT
300	1-Oct-2020	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	12:20	13:30	01:10	LINE CLEAR AVAILED
301	1-Oct-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
302	1-Oct-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
303	1-Oct-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
304	1-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:04 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
305	1-Oct-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
306	1-Oct-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:28 (30.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
307	1-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
308	1-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:00 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
309	1-Oct-2020	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
310	1-Oct-2020	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
311	1-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	17:00 (1.10.02020)			LINE OPEN ,LINE CLEAR AVAILED
312	1-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:04 (28.09.2020)	5:43(1.10.2020)	55:38 hrs	LINE CHARGED
313	1-Oct-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:28 (30.09.2020)	12:36 (1.10.2020)	14:7 hrs	LINE CHARGED
314	1-Oct-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:57	15:42	03:45	LINE FAULT
315	1-Oct-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:48	13:29	02:41	LINE CLEAR AVAILED
316	1-Oct-2020	HASSAN	220	HV1	MRSMSG_220	09:48	10:05	00:17	TRANSFORMER FAULT
317	1-Oct-2020	HASSAN	110	LV1	MRSMSG_220	09:48	09:54	00:06	HAND TRIPPED
318	1-Oct-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	09:54	10:09	00:15	HAND TRIPPED
319	1-Oct-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	10:36	12:32	01:56	LINE CLEAR AVAILED
320	1-Oct-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	09:54	10:09	00:15	HAND TRIPPED
321	1-Oct-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	10:36	12:32	01:56	LINE CLEAR AVAILED
322	1-Oct-2020	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	09:48	10:09	00:21	HAND TRIPPED
323	1-Oct-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	09:54	10:07	00:13	HAND TRIPPED
324	1-Oct-2020	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	09:48	10:11	00:23	HAND TRIPPED
325	1-Oct-2020	HASSAN	110	MRSSHM-SS1	MRSMSG_220	09:54	10:08	00:14	HAND TRIPPED
326	1-Oct-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	09:55	10:10	00:15	HAND TRIPPED
327	1-Oct-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	09:48	09:58	00:10	LINE FAULT
328	1-Oct-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	09:48	09:58	00:10	LINE FAULT
329	1-Oct-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:57	15:43	03:46	LINE FAULT
330	1-Oct-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:49	13:29	02:40	LINE CLEAR AVAILED
331	1-Oct-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	09:26	10:03	00:37	LINE CLEAR AVAILED
332	1-Oct-2020	HASSAN	110	HV1	ANAVATTI_110	13:12	13:29	00:17	LINE CLEAR AVAILED
333	1-Oct-2020	HASSAN	110	HV2	ANAVATTI_110	13:12	13:29	00:17	LINE CLEAR AVAILED
334	1-Oct-2020	HASSAN	110	HV3	BHADRAVTHI_110	17:26	17:57	00:31	HAND TRIPPED
335	1-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	09:50	10:50	01:00	HAND TRIPPED
336	1-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	12:55	16:35	03:40	LINE CLEAR AVAILED
337	1-Oct-2020	HASSAN	110	JOG-JLT4	mghejog_gen	09:50	10:50	01:00	HAND TRIPPED
338	1-Oct-2020	HASSAN	110	JOG-JLT4	mghejog_gen	12:55	16:27	03:32	LINE CLEAR AVAILED
339	1-Oct-2020	HASSAN	110	JOG-JST1	mghejog_gen	09:40	10:50	01:10	LINE FAULT
340	1-Oct-2020	HASSAN	110	JOG-JST1	mghejog_gen	12:55	16:15	03:20	LINE CLEAR AVAILED
341	1-Oct-2020	HASSAN	110	JOG-NK1	mghejog_gen	09:50	10:12	00:22	HAND TRIPPED
342	1-Oct-2020	HASSAN	110	JOG-NK2	mghejog_gen	09:42	10:12	00:30	HAND TRIPPED
343	1-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	13:10	16:30	03:20	LINE CLEAR AVAILED
344	1-Oct-2020	HASSAN	110	HV4	PUTTUR_110	09:14	13:53	04:39	LINE CLEAR AVAILED
345	1-Oct-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	09:50	10:50	01:00	MAIN SUPPLY FAILURE
346	1-Oct-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	13:10	16:15	03:05	LINE CLEAR AVAILED
347	1-Oct-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:46	10:50	00:04	HAND TRIPPED
348	1-Oct-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	05:50	06:00	00:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
349	1-Oct-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	06:50	07:05	00:15	MAIN SUPPLY FAILURE
350	1-Oct-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:55	12:20	00:25	MAIN SUPPLY FAILURE
351	1-Oct-2020	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	06:48	08:56	02:08	TRANSFORMER FAULT
352	1-Oct-2020	HASSAN	66	HASSN220-SKPURA2	HASSAN_220	15:16	15:34	00:18	HAND TRIPPED
353	1-Oct-2020	HASSAN	66	HASSN220-SKPURA1	HASSAN_220	15:36	15:48	00:12	HAND TRIPPED
354	1-Oct-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	06:58	07:05	00:07	LINE FAULT
355	1-Oct-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	15:36	15:52	00:16	HAND TRIPPED
356	1-Oct-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:36	15:39	00:03	HAND TRIPPED
357	1-Oct-2020	HASSAN	66	HV1	KUDLIGERE_66	11:14	11:23	00:09	HAND TRIPPED
358	1-Oct-2020	HASSAN	66	HV1	KUDLIGERE_66	13:49	13:50	00:01	HAND TRIPPED
359	1-Oct-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	05:48	06:02	00:14	LINE FAULT
360	1-Oct-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:51	12:05	00:14	LINE CLEAR AVAILED
361	1-Oct-2020	HASSAN	66	HV1	MALALI_66	06:59	07:06	00:07	MAIN SUPPLY FAILURE
362	1-Oct-2020	HASSAN	66	HV1	SAKLESH PURA_66	06:32	06:46	00:14	TRANSFORMER FAULT
363	1-Oct-2020	HASSAN	66	HV1	SAKLESH PURA_66	06:48	08:19	01:31	TRANSFORMER FAULT
364	1-Oct-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	05:50	06:05	00:15	MAIN SUPPLY FAILURE
365	1-Oct-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	06:55	07:05	00:10	MAIN SUPPLY FAILURE
366	1-Oct-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	11:58	12:01	00:03	MAIN SUPPLY FAILURE
367	1-Oct-2020	HASSAN	66	HV1	SINGAPURA_66	11:36	12:37	01:01	LINE CLEAR AVAILED
368	1-Oct-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	09:50	10:05	00:15	MAIN SUPPLY FAILURE
369	1-Oct-2020	MYSORE	66	CR NAGARA - KOLLEGALA	NO STATIONS EFFECTED	12:48	12:58	0:10	LINE FAULT
370	1-Oct-2020	MYSORE	220	HV1	BEGUR_220	11:52	15:22	3:30	LINE CLEAR AVAILED
371	1-Oct-2020	MYSORE	66	BEGUR 220KV-HV1	BEGUR_220	16:10	16:45	0:35	LINE CLEAR AVAILED
372	1-Oct-2020	MYSORE	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	10:15	20:18	10:03	LINE CLEAR AVAILED
373	1-Oct-2020	MYSORE	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	11:22 (30/09/2020)			LINE OPEN ,LINE CLEAR AVAILED
374	1-Oct-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
375	1-Oct-2020	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	11:46	13:12	1:25	LINE CLEAR AVAILED
376	1-Oct-2020	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	18:42	18:49	0:06	TRANSFORMER FAULT
377	1-Oct-2020	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	15:17	16:23	1:05	LINE CLEAR AVAILED
378	1-Oct-2020	TUMKUR	110	TR-1(HV SIDE)	CHIKKANAYAKANAHALLI_110	7:18	7:35	0:16	TRANSFORMER FAULT
379	1-Oct-2020	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	15:17	16:25	1:08	LINE CLEAR AVAILED
380	1-Oct-2020	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	11:46	13:12	1:26	LINE CLEAR AVAILED
381	1-Oct-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	11:33	17:00	5:27	LINE CLEAR AVAILED
382	1-Oct-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	18:42	18:57	0:15	TRANSFORMER FAULT
383	1-Oct-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	16:12	16:24	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
384	1-Oct-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66, CHITRAHALLI_66	18:44	19:06	0:22	HAND TRIPPED
385	1-Oct-2020	TUMKUR	66	TR-1	HANAGAL_66	11:31	15:52	4:21	LINE CLEAR AVAILED
386	1-Oct-2020	TUMKUR	66	TR-2	HANAGAL_66	14:56	15:52	0:55	LINE CLEAR AVAILED
387	1-Oct-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:54	13:07	0:12	LINE FAULT
388	1-Oct-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:33	13:36	0:02	LINE FAULT
389	1-Oct-2020	TUMKUR	66	PAVAGADA- VENKATAPURA	VENKATAPURA_66	7:20	7:53	0:32	LINE FAULT
390	1-Oct-2020	TUMKUR	66	PAVAGADA66- PAVAGADA	PAVAGADA_66	7:20	7:31	0:11	LINE FAULT
391	2-Oct-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
392	2-Oct-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
393	2-Oct-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
394	2-Oct-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
395	2-Oct-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
396	2-Oct-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
397	2-Oct-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
398	2-Oct-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
399	2-Oct-2020	BAGALKOT	110	KAVALWADA(AMBEWA DI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
400	2-Oct-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
401	2-Oct-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
402	2-Oct-2020	BAGALKOT	220	CHIKKODI- GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
403	2-Oct-2020	BAGALKOT	110	KUDALASANGAM- ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
404	2-Oct-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL_110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
405	2-Oct-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	23:32 (01.10.2020)			LOAD CURTAILMENT
406	2-Oct-2020	BAGALKOT	110	JOG2-SIRSI	STATION NOT AFFECTED SIRSI 110	12:40 (01.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
407	2-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	16:08 (02.10.2020)			LOAD CURTAILMENT
408	2-Oct-2020	BAGALKOT	110	220/110KV, LV1	MK HUBLI 220	22:07 (02.10.2020)			LOAD CURTAILMENT
409	2-Oct-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	21:50 (02.10.2020)			LOAD CURTAILMENT
410	2-Oct-2020	BAGALKOT	110	ITNAL- SULTANPUR(HIDIKAL)	ITNAL_110	16:25	16:37	0:12	LINE FAULT
411	2-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1&2	STATION NOT AFFECTED SIRSI 220	6:13	16:25	10:12	LOAD CURTAILMENT
412	2-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1&2	STATION NOT AFFECTED SIRSI 220	17:26	22:18	4:52	LOAD CURTAILMENT
413	2-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
414	2-Oct-2020	BAGALKOT	110	SIRSI220-UMACHAGI & KAVALAWADA	STATION NOT AFFECTED UMACHAGI_110, KAVALAWADA 110	11:12	18:30	7:18	LOAD CURTAILMENT
415	2-Oct-2020	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI 220	23:06	23:11	0:05	LOAD CURTAILMENT
416	2-Oct-2020	BAGALKOT	220	SIRSI-HUBLI 2	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
417	2-Oct-2020	BAGALKOT	220	HUBLI-NAGAJHARI1	STATION NOT AFFECTED HUBLI 220	23:06 (02.10.2020)			LOAD CURTAILMENT
418	2-Oct-2020	BAGALKOT	220	HUBLI-NAGAJHARI2	STATION NOT AFFECTED HUBLI 220	23:07 (02.10.2020)			LOAD CURTAILMENT
419	2-Oct-2020	BENGALURU	66	NELAMANGALA 400 - SRS PEENYA 3	NO STATION AFFECTED	16:33	20:20	03:47	LINE FAULT
420	2-Oct-2020	BENGALURU	66	NELAMANGALA 400 - SRS PEENYA 4	NO STATION AFFECTED	16:33	16:56	00:23	LINE FAULT
421	2-Oct-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	16:50	16:55	00:05	LOAD CHANGE OVER
422	2-Oct-2020	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	17:00	17:04	00:04	LOAD CHANGE OVER
423	2-Oct-2020	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	20:16	20:20	00:04	LOAD CHANGE OVER
424	2-Oct-2020	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	NO STATION AFFECTED	16:42	20:41	03:59	LINE FAULT
425	2-Oct-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR,PADMANABHANA GAR	16:42	16:52	00:10	LINE FAULT
426	2-Oct-2020	BENGALURU	66	PADMANABHANAGARA - JAYANAGARA	PADMANABHANAGARA	16:42	17:17	00:35	MAIN SUPPLY FAILURE
427	2-Oct-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
428	2-Oct-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVAILED
429	2-Oct-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
430	2-Oct-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:45(2.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
431	2-Oct-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	23:33(2.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
432	2-Oct-2020	GULBARGA	220	HV2	LINGASUGUR_220	11:40	11:50	00:10	LINE CLEAR AVAILED
433	2-Oct-2020	GULBARGA	220	LINGSUGUR-RTPS2	LINGASUGUR_220	13:32	14:05	00:33	LINE FAULT
434	2-Oct-2020	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	01:20	01:56	00:36	LINE FAULT
435	2-Oct-2020	GULBARGA	220	KUSHTAGI-SUZLON1	KUSHTAGI_220	01:20	02:00	00:40	LINE FAULT
436	2-Oct-2020	GULBARGA	220	HV1	KUSHTAGI_220	22:29	23:14	00:45	TRANSFORMER FAULT
437	2-Oct-2020	GULBARGA	220	HV2	KUSHTAGI_220	22:29	22:40	00:11	TRANSFORMER FAULT
438	2-Oct-2020	GULBARGA	110	HV2	HANUMANAL_110	22:50	23:00	00:55	TRANSFORMER FAULT
439	2-Oct-2020	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	19:25	20:20	00:55	MAIN SUPPLY FAILURE
440	2-Oct-2020	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	21:10	21:15	00:05	LINE CLEAR AVAILED
441	2-Oct-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	21:45	21:48	00:03	LINE FAULT
442	2-Oct-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	22:15	22:30	00:15	LINE FAULT
443	2-Oct-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66,GIRIYAPU RA_66,MAGALA_66,SOVENAH ALLI_66,TUNGABHADRA_IPP	08:05	08:32	00:27	LINE FAULT
444	2-Oct-2020	GULBARGA	66	ITTAGGI-RENEWSOLAR2	ITTAGGI_220	19:00	21:45	02:45	LINE CLEAR AVAILED
445	2-Oct-2020	GULBARGA	66	ITTAGGI-RENEWSOLAR1	ITTAGGI_220	20:25	21:45	01:20	LINE CLEAR AVAILED
446	2-Oct-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN , LINE CLEAR AVAILED
447	2-Oct-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
448	2-Oct-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
449	2-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:04 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
450	2-Oct-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
451	2-Oct-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:28 (30.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
452	2-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
453	2-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:00 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
454	2-Oct-2020	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
455	2-Oct-2020	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
456	2-Oct-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	17:14(2.10.2020)			LINE OPEN , LINE FAULT
457	2-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	16:45 (2.10.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
458	2-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	17:00 (1.10.02020)	11:15 (2.10.2020)	18:14 hrs	LINE CHARGED
459	2-Oct-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:18	14:32	04:14	LINE CLEAR AVAILED
460	2-Oct-2020	HASSAN	110	MRSSHM-MYSORE	MRS MG_220	10:17	17:44	07:27	LINE CLEAR AVAILED
461	2-Oct-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:17	14:54	04:37	LINE CLEAR AVAILED
462	2-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	11:30	14:15	02:45	LINE CLEAR AVAILED
463	2-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	14:45	16:40	01:55	LINE CLEAR AVAILED
464	2-Oct-2020	HASSAN	110	HV1	MANIPAL_110	11:05	11:30	00:25	LINE CLEAR AVAILED
465	2-Oct-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	09:00	09:07	00:07	TRANSFORMER FAULT
466	2-Oct-2020	HASSAN	66	HV1	MALLAPURA_66	10:27	10:59	00:32	LINE CLEAR AVAILED
467	2-Oct-2020	HASSAN	66	HV1	SIGEBAGI_66	12:29	13:16	00:47	LINE CLEAR AVAILED
468	2-Oct-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	10:38	10:43	0:05	LINE FAULT
469	2-Oct-2020	MYSORE	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	9:14	9:29	0:15	LINE FAULT
470	2-Oct-2020	MYSORE	66	CR NAGARA - KOLLEGALA	NO STATIONS EFFECTED	14:22	14:27	0:05	LINE FAULT
471	2-Oct-2020	MYSORE	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	11:22 (30/09/2020)			LINE OPEN ,LINE CLEAR AVAILED
472	2-Oct-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
473	2-Oct-2020	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	2:13	2:16	0:03	LINE FAULT
474	2-Oct-2020	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	10:57	11:42	0:45	LINE FAULT
475	2-Oct-2020	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	15:34	15:52	0:18	LINE FAULT
476	2-Oct-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:24	6:35	0:11	LINE FAULT
477	2-Oct-2020	TUMKUR	66	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	10:45	10:49	0:03	HAND TRIPPED
478	2-Oct-2020	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:29	12:39	0:10	LINE FAULT
479	2-Oct-2020	TUMKUR	66	TR-1	HALUVAGALU_66	14:20	14:28	0:07	TRANSFORMER FAULT
480	2-Oct-2020	TUMKUR	66	TR-1	HANAGAL_66	11:18	14:03	2:44	LINE CLEAR AVAILED
481	2-Oct-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:53	4:55	0:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
482	2-Oct-2020	TUMKUR	66	HONNALLI 220kv-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	2:59	3:11	0:11	LINE FAULT
483	2-Oct-2020	TUMKUR	66	HONNALLI 220kv-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	14:42	14:52	0:09	LINE FAULT
484	2-Oct-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:28	10:33	0:04	LINE FAULT
485	2-Oct-2020	TUMKUR	66	TR-2	LINGDHALLI_66(CHANNAGIRI)	14:33	15:10	0:37	TRANSFORMER FAULT
486	2-Oct-2020	TUMKUR	66	TR-2	LINGDHALLI_66(CHANNAGIRI)	15:26	17:50	2:23	TRANSFORMER FAULT
487	2-Oct-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE 66	MAYAKONDA_66	6:25	6:38	0:12	MAIN SUPPLY FAILURE
488	2-Oct-2020	TUMKUR	66	TR-2	URDIGERE_66	15:18	15:29	0:11	LINE CLEAR AVAILED
489	3-Oct-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)	16:32 (3.10.2020)	3751:06hrs	LINE CHARGED
490	3-Oct-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
491	3-Oct-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
492	3-Oct-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
493	3-Oct-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
494	3-Oct-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
495	3-Oct-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
496	3-Oct-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
497	3-Oct-2020	BAGALKOT	110	KAVALWADA(AMBEWA DI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
498	3-Oct-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
499	3-Oct-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
500	3-Oct-2020	BAGALKOT	220	CHIKKODI- GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
501	3-Oct-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
502	3-Oct-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
503	3-Oct-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI 220	23:32 (01.10.2020)	8:27 (03.10.2020)	32:55hrs	TRANSFORMER CHARGED
504	3-Oct-2020	BAGALKOT	110	JOG2-SIRSI	STATION NOT AFFECTED SIRSI 110	12:40 (01.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
505	3-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	16:08 (02.10.2020)	6:58 (03.10.2020)	14:50hrs	LINE CHARGED
506	3-Oct-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED MK HUBLI 220	22:07 (02.10.2020)	6:40 (3.10.2020)	8:33hrs	TRANSFORMER CHARGED
507	3-Oct-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	21:50 (02.10.2020)	8:11 (03.10.2020)	10:23hrs	LINE CHARGED
508	3-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
509	3-Oct-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
510	3-Oct-2020	BAGALKOT	220	HUBLI-NAGAJHARI1	STATION NOT AFFECTED HUBLI 220	23:06 (02.10.2020)	6:04 (03.10.2020)	6:58hrs	LINE CHARGED
511	3-Oct-2020	BAGALKOT	220	HUBLI-NAGAJHARI2	STATION NOT AFFECTED HUBLI 220	23:07 (02.10.2020)	6:04 (03.10.2020)	6:57hrs	LINE CHARGED
512	3-Oct-2020	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	12:05	12:39	0:34	LINE CLEAR AVAILED
513	3-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	19:42 (03.10.2020)			LOAD CURTAILMENT
514	3-Oct-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	20:31 (03.10.2020)			LOAD CURTAILMENT
515	3-Oct-2020	BAGALKOT	110	BELGAUM220-VADAGOAN	STATION NOT AFFECTED VADAGOAN 110	8:56	19:15	10:19	LINE FAULT
516	3-Oct-2020	BAGALKOT	110	BAGALKOT-BAGALKOT2	BAGALKOT_110	5:31	6:15	0:44	LINE FAULT
517	3-Oct-2020	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220 (STATION NOT AFFECTED)	16:07	16:15	0:08	LINE FAULT
518	3-Oct-2020	BAGALKOT	110	110/33KV,HV3	GADAG_110 &NAGAVI,MALLASAMUDRA&H B 33	13:35	14:20	0:45	HAND TRIPPED
519	3-Oct-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & RUSTUM PUR,BELGAUM W/S_33	10:00	17:52	7:52	LINE CLEAR AVAILED
520	3-Oct-2020	BAGALKOT	220	HUBLI-SIRSI 1	STATION NOT AFFECTED HUBLI 220	10:13	17:46	7:33	LINE CLEAR AVAILED
521	3-Oct-2020	BAGALKOT	220	HUBLI-SIRSI 2	STATION NOT AFFECTED HUBLI 220	10:14	17:46	7:32	LINE CLEAR AVAILED
522	3-Oct-2020	BAGALKOT	220	HUBLI-SIRSI 1	STATION NOT AFFECTED HUBLI 220	22:30 (03.10.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
523	3-Oct-2020	BAGALKOT	220	HUBLI-SIRSI 2	STATION NOT AFFECTED HUBLI 220	22:30 (03.10.2020)			LOAD CURTAILMENT
524	3-Oct-2020	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	14:23	15:03	0:40	LINE CLEAR AVOID
525	3-Oct-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	12:50	13:15	0:25	TRANSFORMER FAULT
526	3-Oct-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGADA 33	14:16	14:22	0:06	TRANSFORMER FAULT
527	3-Oct-2020	BENGALURU	66	HV2	KADUGODI	04:05	04:38	00:33	TRANSFORMER FAULT
528	3-Oct-2020	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	17:40	17:45	00:05	LOAD CHANGE OVER
529	3-Oct-2020	BENGALURU	66	HV3	SHAMARAJU TECH PARK	12:48	12:50	00:02	LINE CLEAR AVOID
530	3-Oct-2020	BENGALURU	66	HV3	CHIKKABALLAPURA IND AREA	10:45	15:30	04:45	LINE CLEAR AVOID
531	3-Oct-2020	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	10:10	10:25	00:15	LINE CLEAR AVOID
532	3-Oct-2020	BENGALURU	66	HV1	NANDIGANAHALLI	13:30	16:03	02:33	LINE CLEAR AVOID
533	3-Oct-2020	BENGALURU	66	HV2	NANDIGANAHALLI	11:45	13:30	01:45	LINE CLEAR AVOID
534	3-Oct-2020	BENGALURU	66	HV2	NANDIGANAHALLI	16:10	16:40	00:30	LINE CLEAR AVOID
535	3-Oct-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
536	3-Oct-2020	GULBARGA	110	SINDHANOR- RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVOID
537	3-Oct-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVOID
538	3-Oct-2020	GULBARGA	220	HUMNABAD- KAPNOOR1	KAPNOOR_220	22:45(2.10.2020)	6:41(3.10.2020)	7:56hrs	LINE CHARGED
539	3-Oct-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	23:33(2.10.2020)	6:49(3.10.2020)	7:16hrs	LINE CHARGED
540	3-Oct-2020	GULBARGA	110	HV2	HANUMASAGAR_110	00:00	14:50	14:50	LINE CLEAR AVOID
541	3-Oct-2020	GULBARGA	110	HV1	HANUMASAGAR_110	16:05	16:20	00:15	LINE CLEAR AVOID
542	3-Oct-2020	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	06:20	06:25	00:05	LINE FAULT
543	3-Oct-2020	GULBARGA	110	KAPNOOR- HUMNABAD1	MADIYAL_110,MARGUTTI_110	18:22	18:31	00:09	LINE FAULT
544	3-Oct-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVOID
545	3-Oct-2020	HASSAN	400	TALAGU- NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVOID
546	3-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46 (1.10.2020)			LINE OPEN ,LINE CLEAR AVOID
547	3-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:00 (1.10.2020)			LINE OPEN ,LINE CLEAR AVOID
548	3-Oct-2020	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVOID
549	3-Oct-2020	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVOID
550	3-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:17 (3.10.2020)			LINE OPEN ,LINE CLEAR AVOID
551	3-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	13:30(3.10.2020)			LINE OPEN ,LINE CLEAR AVOID
552	3-Oct-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11 (21.10.2020)	15:45 (3.10.2020)	278:33 hrs	TRANSFORMER CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
553	3-Oct-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	17:14(2.10.2020)	17:56 (3.10.2020)	24:41 hrs	LINE CHARGED
554	3-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:00 (1.10.2020)	13:20 (3.10.2020)	44:19 hrs	LINE CHARGED
555	3-Oct-2020	HASSAN	110	JG110-MGHE	JOG_110	16:45 (2.10.2020)	13:25 (3.10.2020)	20:39 hrs	LINE CHARGED
556	3-Oct-2020	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	09:55	10:49	00:54	LINE CLEAR AVAILED
557	3-Oct-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	08:01	09:53	01:52	NFBC ISSUED
558	3-Oct-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	10:01	12:11	02:10	NFBC ISSUED
559	3-Oct-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	09:55	10:49	00:54	NFBC ISSUED
560	3-Oct-2020	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	10:05	14:10	04:05	LINE CLEAR AVAILED
561	3-Oct-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	10:00	12:13	02:13	LINE CLEAR AVAILED
562	3-Oct-2020	HASSAN	110	LV1	ARASIKERE_220	14:25	14:48	00:23	HAND TRIPPED
563	3-Oct-2020	HASSAN	110	HV2	BHADRAVATHI_110	11:05	15:45	04:40	LINE CLEAR AVAILED
564	3-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	13:25	17:13	03:48	LINE CLEAR AVAILED
565	3-Oct-2020	HASSAN	110	JOG110-AMBT1	JOG_110	16:40	18:40	02:00	LINE CLEAR AVAILED
566	3-Oct-2020	HASSAN	110	JOG110-AMBT2	JOG_110	16:40	18:40	02:00	LINE CLEAR AVAILED
567	3-Oct-2020	HASSAN	110	JOG110-LPH	JOG_110	16:40	18:50	02:10	LINE CLEAR AVAILED
568	3-Oct-2020	HASSAN	110	HV2	KULASHEKARA_110	10:23	18:01	07:38	LINE CLEAR AVAILED
569	3-Oct-2020	HASSAN	66	HV1	BASAVAGHATTA_66	12:24	14:40	02:16	LINE CLEAR AVAILED
570	3-Oct-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	19:55	19:59	00:04	LINE FAULT
571	3-Oct-2020	MYSORE	66	HV1	ADDIHALLI_66	12:00	14:05	2:05	LINE CLEAR AVAILED
572	3-Oct-2020	MYSORE	66	HV2	ADDIHALLI_66	10:20	12:50	2:30	LINE CLEAR AVAILED
573	3-Oct-2020	MYSORE	66	HUNSUR-ELWALA	GAVADAGERE_66	5:59	6:10	0:10	LINE FAULT
574	3-Oct-2020	MYSORE	66	HV2	KRPET_66	10:10	14:19	4:08	LINE CLEAR AVAILED
575	3-Oct-2020	MYSORE	66	TUBINKERE - PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	16:15	16:20	0:05	LINE FAULT
576	3-Oct-2020	MYSORE	66	VAJMANGALA- KADAKOLA 2	NO STATIONS EFFECTED	18:02	18:08	0:06	LINE FAULT
577	3-Oct-2020	MYSORE	220	MADHUVANAHALLI- HEBBANI 2	NO STATIONS EFFECTED	12:22	15:45	3:23	NFBC ISSUED
578	3-Oct-2020	MYSORE	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	11:22 (30/09/2020)			LINE OPEN ,LINE CLEAR AVAILED
579	3-Oct-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
580	3-Oct-2020	TUMKUR	66	TR-2	BUKKAPATNA_66	15:02	15:25	0:22	LINE CLEAR AVAILED
581	3-Oct-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	10:10	10:21	0:11	LINE CLEAR AVAILED
582	3-Oct-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:30	10:40	0:10	LINE FAULT
583	3-Oct-2020	TUMKUR	66	TR-2	MALEBENNUR_66	10:35	17:01	6:26	LINE CLEAR AVAILED
584	3-Oct-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	15:17	16:48	1:31	LINE CLEAR AVAILED
585	3-Oct-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	10:40	12:38	1:58	LINE CLEAR AVAILED
586	3-Oct-2020	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	7:12	8:35	1:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
587	3-Oct-2020	TUMKUR	66	THALLAK 220KV-NAYAKANHATTI	THALLAKK_220	8:34	8:40	0:06	HAND TRIPPED
588	4-Oct-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
589	4-Oct-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
590	4-Oct-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
591	4-Oct-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
592	4-Oct-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
593	4-Oct-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
594	4-Oct-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
595	4-Oct-2020	BAGALKOT	110	KAVALLWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
596	4-Oct-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
597	4-Oct-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
598	4-Oct-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
599	4-Oct-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
600	4-Oct-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
601	4-Oct-2020	BAGALKOT	110	JOG2-SIRSI	STATION NOT AFFECTED SIRSI 110	12:40 (01.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
602	4-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
603	4-Oct-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
604	4-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM 220	19:42 (03.10.2020)	7:54 (04.10.2020)	12:12hrs	LINE CHARGED
605	4-Oct-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	20:31 (03.10.2020)			LOAD CURTAILMENT
606	4-Oct-2020	BAGALKOT	220	HUBLI-SIRSI 1	STATION NOT AFFECTED HUBLI 220	22:30 (03.10.2020)	6:57 (04.10.2020)	8:27hrs	LINE CHARGED
607	4-Oct-2020	BAGALKOT	220	HUBLI-SIRSI 2	STATION NOT AFFECTED HUBLI 220	22:30 (03.10.2020)	6:48 (04.10.2020)	8:18hrs	LINE CHARGED
608	4-Oct-2020	BAGALKOT	110	110/11KV,HV1	ATHANI_220	17:10	17:44	0:34	TRANSFORMER FAULT
609	4-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM 220	18:55 (04.10.2020)			LINE OPEN , LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
610	4-Oct-2020	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GADAG ROAD_110	11:10	17:03	5:53	LINE CLEAR AVAILED
611	4-Oct-2020	BAGALKOT	110	HIREBEVANUR-RODAGI	RODAGI_110	15:06	15:30	0:24	LINE FAULT
612	4-Oct-2020	BAGALKOT	110	VAJJRAMATTI220-KATARAKI	KATARAKI_110	18:38 (04.10.2020)			LINE OPEN , LINE FAULT
613	4-Oct-2020	BAGALKOT	110	VAJJRAMATTI220-BILAGI	BILAGI_110	18:38 (04.10.2020)			LINE OPEN , LINE FAULT
614	4-Oct-2020	BAGALKOT	110	110/33KV, HV3	TODALBAGI_110, BIDARI_33, HIREPADASALAGI 33	14:45	14:56	0:11	TRANSFORMER FAULT
615	4-Oct-2020	BAGALKOT	110	110/33KV, HV3	TODALBAGI_110, BIDARI_33, HIREPADASALAGI 33	14:59	21:26	6:27	TRANSFORMER FAULT
616	4-Oct-2020	BAGALKOT	110	CHIKKODI1&2- RAIBAG	RAIBAG_110	10:30	10:50	0:20	LINE CLEAR AVAILED
617	4-Oct-2020	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	5:09	5:28	0:19	LINE FAULT
618	4-Oct-2020	BAGALKOT	110	MKHUBLI220- BEDI	BEDI_110	9:40	17:08	7:28	LINE CLEAR AVAILED
619	4-Oct-2020	BENGALURU	220	BEGUR 220 - D B PURA 220	BEGUR 220,DEVANAHALLI KIADB HARDWARE PARK 220,HOSKOTE 220	11:38	11:40	00:02	LINE FAULT
620	4-Oct-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	11:38	11:53	00:15	LINE CLEAR AVAILED
621	4-Oct-2020	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	11:38	11:41	00:03	LINE CLEAR AVAILED
622	4-Oct-2020	BENGALURU	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	11:38	11:41	00:03	LINE CLEAR AVAILED
623	4-Oct-2020	BENGALURU	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	11:38	11:41	00:03	LINE CLEAR AVAILED
624	4-Oct-2020	BENGALURU	66	HV2	BEGUR 220	11:38	11:41	00:03	LINE CLEAR AVAILED
625	4-Oct-2020	BENGALURU	220	D B PURA 220 - BEGUR 220	BEGUR 220	11:38	12:33	00:55	LINE FAULT
626	4-Oct-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:00	13:04	00:04	LINE FAULT
627	4-Oct-2020	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	11:53	12:56	01:03	LINE FAULT
628	4-Oct-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	11:53	13:02	01:09	MAIN SUPPLY FAILURE
629	4-Oct-2020	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	11:53	13:02	01:09	MAIN SUPPLY FAILURE
630	4-Oct-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:53	12:52	00:59	MAIN SUPPLY FAILURE
631	4-Oct-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:53	12:52	00:59	MAIN SUPPLY FAILURE
632	4-Oct-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:53	12:52	00:59	MAIN SUPPLY FAILURE
633	4-Oct-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:53	12:52	00:59	MAIN SUPPLY FAILURE
634	4-Oct-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	11:53	12:52	00:59	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
635	4-Oct-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:53	12:52	00:59	MAIN SUPPLY FAILURE
636	4-Oct-2020	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:53	12:52	00:59	MAIN SUPPLY FAILURE
637	4-Oct-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	15:05	15:16	00:11	LINE CLEAR AVAILED
638	4-Oct-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:53	13:03	01:10	MAIN SUPPLY FAILURE
639	4-Oct-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:53	13:08	01:15	MAIN SUPPLY FAILURE
640	4-Oct-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:53	13:03	01:10	MAIN SUPPLY FAILURE
641	4-Oct-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:05	15:16	00:11	MAIN SUPPLY FAILURE
642	4-Oct-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:05	15:16	00:11	MAIN SUPPLY FAILURE
643	4-Oct-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:05	15:16	00:11	MAIN SUPPLY FAILURE
644	4-Oct-2020	BENGALURU	66	HV2	SARJAPURA 220	15:05	15:16	00:11	MAIN SUPPLY FAILURE
645	4-Oct-2020	BENGALURU	66	HV2	SARJAPURA 220	11:53	13:03	01:10	MAIN SUPPLY FAILURE
646	4-Oct-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	11:53	13:03	01:10	MAIN SUPPLY FAILURE
647	4-Oct-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:53	13:03	01:10	MAIN SUPPLY FAILURE
648	4-Oct-2020	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	11:53	13:03	01:10	MAIN SUPPLY FAILURE
649	4-Oct-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	15:05	15:16	00:11	MAIN SUPPLY FAILURE
650	4-Oct-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:05	15:16	00:11	MAIN SUPPLY FAILURE
651	4-Oct-2020	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	15:05	15:16	00:11	MAIN SUPPLY FAILURE
652	4-Oct-2020	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	11:38	11:52	00:14	MAIN SUPPLY FAILURE
653	4-Oct-2020	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - BHP (EHT)	BHP (EHT)	11:38	11:52	00:14	MAIN SUPPLY FAILURE
654	4-Oct-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	11:38	12:08	00:30	MAIN SUPPLY FAILURE
655	4-Oct-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:38	12:08	00:30	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
656	4-Oct-2020	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:38	12:08	00:30	MAIN SUPPLY FAILURE
657	4-Oct-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	11:38	12:08	00:30	MAIN SUPPLY FAILURE
658	4-Oct-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:38	12:08	00:30	MAIN SUPPLY FAILURE
659	4-Oct-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:53	12:54	01:01	MAIN SUPPLY FAILURE
660	4-Oct-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	12:54	14:45	01:50	MAIN SUPPLY FAILURE
661	4-Oct-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	11:53	12:54	01:01	MAIN SUPPLY FAILURE
662	4-Oct-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:53	12:54	01:01	MAIN SUPPLY FAILURE
663	4-Oct-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:53	13:03	01:10	MAIN SUPPLY FAILURE
664	4-Oct-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:53	12:55	01:02	MAIN SUPPLY FAILURE
665	4-Oct-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	11:53	12:55	01:02	MAIN SUPPLY FAILURE
666	4-Oct-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	11:53	12:52	00:59	MAIN SUPPLY FAILURE
667	4-Oct-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	11:53	14:13	02:20	MAIN SUPPLY FAILURE
668	4-Oct-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
669	4-Oct-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVAILED
670	4-Oct-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
671	4-Oct-2020	GULBARGA	220	RTPS-LINGSUGUR3	RTPS_220	14:30	14:51	00:21	LINE FAULT
672	4-Oct-2020	GULBARGA	110	HV2	DEODURGA_110	11:11	11:32	00:21	TRANSFORMER FAULT
673	4-Oct-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
674	4-Oct-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
675	4-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
676	4-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:00 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
677	4-Oct-2020	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
678	4-Oct-2020	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
679	4-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:17 (3.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
680	4-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	13:30(3.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
681	4-Oct-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:30	11:55	00:25	LINE CLEAR AVAILED
682	4-Oct-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	00:34	00:47	00:13	LINE FAULT
683	4-Oct-2020	MYSORE	66	HV1	K_HONNALGERE_66	9:12	12:42	3:30	TRANSFORMER FAULT
684	4-Oct-2020	MYSORE	66	HV1	SATHEGALA_66	11:00	18:35	7:34	LINE CLEAR AVAILED
685	4-Oct-2020	MYSORE	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	10:45	10:58	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
686	4-Oct-2020	MYSORE	66	CR NAGARA-HONNAHALLI	HONNALLY_MYS_66 ATTIGULIPURA 66	7:37	7:45	0:08	LINE FAULT
687	4-Oct-2020	MYSORE	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	11:22 (30/09/2020)			LINE OPEN ,LINE CLEAR AVAILED
688	4-Oct-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
689	4-Oct-2020	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI 66	6:51	7:05	0:13	LINE FAULT
690	4-Oct-2020	TUMKUR	66	THALLAK 220KV-GOWRASAMUDRA	GOWRASAMUDRA_66	6:12	6:37	0:25	LINE FAULT
691	5-Oct-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
692	5-Oct-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
693	5-Oct-2020	BAGALKOT	110	110/11KV,HV 1	BILAGI_110	19:25	20:39	01:14	LINE CLEAR AVAILED
694	5-Oct-2020	BAGALKOT	110	110/11KV,HV1	UCHAGOAN_110	15:01	15:59	00:58	LINE CLEAR AVAILED
695	5-Oct-2020	BAGALKOT	110	110/11KV,HV1	UCHAGOAN_110	14:04	14:30	00:26	LINE CLEAR AVAILED
696	5-Oct-2020	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	13:34	13:55	00:21	LINE CLEAR AVAILED
697	5-Oct-2020	BAGALKOT	110	110/11KV,HV2	ITANAL_110	15:34	16:17	00:43	HAND TRIPPED
698	5-Oct-2020	BAGALKOT	110	110/11KV,HV2	RON_110	02:05	03:05	01:00	TRANSFORMER FAULT
699	5-Oct-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	19:54	20:31	00:37	TRANSFORMER FAULT
700	5-Oct-2020	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,& ALNAVAR 33	16:17	16:24	00:07	TRANSFORMER FAULT
701	5-Oct-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
702	5-Oct-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
703	5-Oct-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
704	5-Oct-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
705	5-Oct-2020	BAGALKOT	110	JOG2-SIRSI	STATION NOT AFFECTED SIRSI 110	12:40 (01.10.2020)	15:03 (05.10.2020)	02:23	LINE CHARGED
706	5-Oct-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
707	5-Oct-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
708	5-Oct-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
709	5-Oct-2020	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
710	5-Oct-2020	BAGALKOT	110	SUARNASOUDA-MACHE	MACHE_110	16:39	16:53	00:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
711	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110, SHIRGUPPI_110, BISNAL_110, TOLMATTI_110, GIRISAGAR_110	18:38 (04.10.2020)	19:05 (05.10.2020)	0:27 hrs	LINE CHARGED
712	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-KATARAKI	KATARAKI_110	18:38 (04.10.2020)			LINE OPEN , LINE FAULT
713	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
714	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-MALLIGERI	MALLIGERI_110	15:14	16:03	00:49	LINE CLEAR AVAILED
715	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-MANTUR1	STATION NOT AFFECTED MANTUR_110	16:26	16:44	00:18	LINE CLEAR AVAILED
716	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-MANTUR2	STATION NOT AFFECTED MANTUR_110	15:57	16:17	00:20	LINE CLEAR AVAILED
717	5-Oct-2020	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	16:15	16:31	00:16	LINE CLEAR AVAILED
718	5-Oct-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1	BAGALKOT_220	15:02	17:18	02:16	LINE CLEAR AVAILED
719	5-Oct-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	15:02	17:53	02:51	LINE CLEAR AVAILED
720	5-Oct-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
721	5-Oct-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	20:31 (03.10.2020)	9:27 (05.10.2020)	11:56 hrs	LINE CHARGED
722	5-Oct-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	18:55 (04.10.2020)	9:25 (05.10.2020)	14:30 hrs	LINE CHARGED
723	5-Oct-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
724	5-Oct-2020	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	15:46 (05.10.2020)			LINE OPEN , LINE FAULT
725	5-Oct-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)			LOAD CURTAILMENT
726	5-Oct-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)			LOAD CURTAILMENT
727	5-Oct-2020	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	9:16 (30.04.2020)	18:01 (05.10.2020)	8:29 hrs	LINE CHARGED
728	5-Oct-2020	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	9:16 (30.04.2020)	17:19 (05.10.2020)	7:47 hrs	LINE CHARGED
729	5-Oct-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
730	5-Oct-2020	BENGALURU	66	BIAL BEGUR 220 - ITC(EHT)	ITC(EHT)	11:30	11:33	00:03	LINE CLEAR AVAILED
731	5-Oct-2020	BENGALURU	66	BIAL BEGUR 220 - VIDYANAGARA	VIDYANAGARA,HENNUR CROSS	10:32	10:48	00:16	LINE CLEAR AVAILED
732	5-Oct-2020	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	11:21	11:25	00:04	LOAD CHANGE OVER
733	5-Oct-2020	BENGALURU	66	HV1	KUMBALAGODU	13:50	14:10	00:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
734	5-Oct-2020	BENGALURU	66	HV1	PALLICHERLU	12:08	16:05	03:57	LINE CLEAR AVAILED
735	5-Oct-2020	BENGALURU	66	HV1	YELAHANKA	10:49(5/10/2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
736	5-Oct-2020	BENGALURU	66	HV2	KODIHALLI	12:44	12:48	00:04	LINE CLEAR AVAILED
737	5-Oct-2020	BENGALURU	66	KODIHALLI - HUNSENAHALLI	BIJJAHALLI,HUNSENAHALLI	07:35	08:05	00:30	LINE FAULT
738	5-Oct-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	18:19	19:15	00:56	LOAD CURTAILMENT
739	5-Oct-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:07	19:09	01:02	LOAD CURTAILMENT
740	5-Oct-2020	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:09	19:16	00:07	LOAD CURTAILMENT
741	5-Oct-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	18:07	19:09	01:02	LOAD CURTAILMENT
742	5-Oct-2020	BENGALURU	66	MALLASANDRA - DALASANUR	DALASANUR	19:10	19:20	00:10	LOAD CURTAILMENT
743	5-Oct-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	18:04	18:15	00:11	LINE FAULT
744	5-Oct-2020	GULBARGA	110	HUMNABAD- MANEKHALLI	MANEKHALLI_110	06:10	12:30	06:20	LINE FAULT
745	5-Oct-2020	GULBARGA	110	HV1	HALIKHED_110	13:35	15:00	01:25	LINE CLEAR AVAILED
746	5-Oct-2020	GULBARGA	110	HV1	HATTI_110	17:59	18:04	00:05	LOAD CURTAILMENT
747	5-Oct-2020	GULBARGA	110	HV2	ALIPUR_220	12:18	14:09	01:51	LINE CLEAR AVAILED
748	5-Oct-2020	GULBARGA	110	HV2	KAMPLI_110	17:55	18:05	00:10	LOAD CURTAILMENT
749	5-Oct-2020	GULBARGA	110	KOLHAR-SHAHI_SLR_IPP	KOLHAR_110	12:30	12:35	00:05	LINE FAULT
750	5-Oct-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN ,LINE CLEAR AVAILED
751	5-Oct-2020	GULBARGA	110	RAICHUR-RTPS1	RAICHUR_220	16:02	16:10	00:08	LINE CLEAR AVAILED
752	5-Oct-2020	GULBARGA	110	RAICHUR-RTPS2	RAICHUR_220	12:47	15:52	03:05	LINE FAULT
753	5-Oct-2020	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110,ALKOD_110,BYA GWAT 110	20:08	20:18	00:10	LINE FAULT
754	5-Oct-2020	GULBARGA	110	RAICHUR-SINDHNOOR2	KURUDICROOS_110,MADLAPU R 110,MANVI 110	20:07	20:14	00:07	LINE FAULT
755	5-Oct-2020	GULBARGA	110	RAICHUR-SINDHNOOR2	KURUDICROOS_110,MADLAPU R 110,MANVI 110	23:45	23:50	00:05	LINE FAULT
756	5-Oct-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:58	18:03	00:05	LOAD CURTAILMENT
757	5-Oct-2020	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_1 10	19:30	19:46	00:16	LINE FAULT
758	5-Oct-2020	GULBARGA	110	SINDHANOOR- RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN ,LINE CLEAR AVAILED
759	5-Oct-2020	GULBARGA	220	HUMNABAD- KAPNOOR2	KAPNOOR_220	12:59	13:00	00:01	LINE FAULT
760	5-Oct-2020	HASSAN	66	ATTICHO--HNPURA	ATTICHOWDENAHALLY_66	13:15	14:15	01:00	NFBC ISSUED
761	5-Oct-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
762	5-Oct-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:58	14:15	02:11	LINE CLEAR AVAILED
763	5-Oct-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	13:00	19:09	06:00	LINE FAULT
764	5-Oct-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:15	14:15	01:00	MAIN SUPPLY FAILURE
765	5-Oct-2020	HASSAN	66	HV1	DUDDA_66	11:44	18:04	03:14	LINE CLEAR AVAILED
766	5-Oct-2020	HASSAN	66	HV1	KANDLI_66	11:45	14:58	01:01	LINE CLEAR AVAILED
767	5-Oct-2020	HASSAN	66	HV1	SIGEBAGI_66	12:49	14:15	02:12	LINE CLEAR AVAILED
768	5-Oct-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:05	19:00	06:59	LINE CLEAR AVAILED
769	5-Oct-2020	HASSAN	66	HV2	UDAYAPURA_66	17:30	15:01	00:10	TRANSFORMER FAULT
770	5-Oct-2020	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	12:57	12:46	02:04	MAIN SUPPLY FAILURE
771	5-Oct-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:14	15:01	01:01	LINE CLEAR AVAILED
772	5-Oct-2020	HASSAN	66	MRSSHM-BD-1	MRSMG_220	16:37	19:11	02:34	LINE CLEAR AVAILED
773	5-Oct-2020	HASSAN	66	MRSSHM-BD-2	MRSMG_220	12:59	19:02	06:03	LINE FAULT
774	5-Oct-2020	HASSAN	66	MRSSHM-DVG2	MRSMG_220	12:47	14:58	02:11	NFBC ISSUED
775	5-Oct-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	13:15	14:15	01:00	MAIN SUPPLY FAILURE
776	5-Oct-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	12:49	15:01	02:12	LINE CLEAR AVAILED
777	5-Oct-2020	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	12:49	15:01	02:12	LINE CLEAR AVAILED
778	5-Oct-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:09	10:18	00:09	LINE FAULT
779	5-Oct-2020	HASSAN	110	HV1	KONDENALU_110	06:15	11:45	05:30	TRANSFORMER FAULT
780	5-Oct-2020	HASSAN	110	HV1	MSEZ_220	10:09	14:47	04:38	LINE CLEAR AVAILED
781	5-Oct-2020	HASSAN	110	HV2	GANDASI_110	17:56	18:06	00:10	LOAD CURTAILMENT
782	5-Oct-2020	HASSAN	110	HV2	KONDENALU_110	06:15	11:45	05:30	TRANSFORMER FAULT
783	5-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	13:30(3.10.2020)	12:55 (5.10.2020)	47:24 hrs	LINE CHARGED
784	5-Oct-2020	HASSAN	110	JOG110-MGHE	JOG_110	14:10	15:05	00:55	HAND TRIPPED
785	5-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	17:17 (3.10.2020)	12:45 (5.10.2020)	43:27 hrs	LINE CHARGED
786	5-Oct-2020	HASSAN	110	JOG-JLT3	mghejog_gen	14:10	15:05	00:55	HAND TRIPPED
787	5-Oct-2020	HASSAN	110	JOG-JLT4	mghejog_gen	09:23	13:35	04:12	NFBC ISSUED
788	5-Oct-2020	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
789	5-Oct-2020	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED
790	5-Oct-2020	HASSAN	110	KONDENA-KADUR-ARSIKERE	KONDENALU_110	06:15	11:45	05:30	LINE FAULT
791	5-Oct-2020	HASSAN	110	LV2	PUTTUR_220	11:55	14:06	02:11	LINE CLEAR AVAILED
792	5-Oct-2020	HASSAN	220	GESOPA-TALGUPA1	gerusoppa_gen	09:09	10:26	01:17	LINE FAULT
793	5-Oct-2020	HASSAN	220	HV2	PUTTUR_220	11:55	14:06	02:11	LINE CLEAR AVAILED
794	5-Oct-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	11:41	14:07	02:26	NFBC ISSUED
795	5-Oct-2020	HASSAN	220	MRSSHM-GERSOPPA	MRSMG_220	09:10	10:25	01:15	LINE FAULT
796	5-Oct-2020	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	10:09	11:34	01:25	LINE FAULT
797	5-Oct-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:09	11:35	01:26	LINE FAULT
798	5-Oct-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)			LINE OPEN ,LINE CLEAR AVAILED
799	5-Oct-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46 (1.10.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
800	5-Oct-2020	MYSORE	66	BEGUR 220KV-SARGUR	NO STATIONS EFFECTED	08:02	08:26	00:24	LINE FAULT
801	5-Oct-2020	MYSORE	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	11:22 (30/09/2020)	16:13 (5/10/2020)	124:51 hrs	LINE CHARGED
802	5-Oct-2020	MYSORE	66	HV1	BESAGARAHALLI_66	17:56	18:10	00:13	LOAD CURTAILMENT
803	5-Oct-2020	MYSORE	66	HV1	HANAGODU_66	17:56	18:25	00:28	LOAD CURTAILMENT
804	5-Oct-2020	MYSORE	66	HV2	AKKIHEBBAL_66	17:56	18:07	00:11	LOAD CURTAILMENT
805	5-Oct-2020	MYSORE	66	HV2	BOOKANAKERE_66	17:56	18:04	00:08	LOAD CURTAILMENT
806	5-Oct-2020	MYSORE	66	HV2	CHINAKURALI_66	17:56	18:35	00:39	LOAD CURTAILMENT
807	5-Oct-2020	MYSORE	66	HV2	DKMAIDANA_66	11:08	13:36	02:28	LINE CLEAR AVAILED
808	5-Oct-2020	MYSORE	66	HV2	ELAVALA_66	17:56	18:06	00:09	LOAD CURTAILMENT
809	5-Oct-2020	MYSORE	66	HV2	HANNUR_66	17:56	18:05	00:08	LOAD CURTAILMENT
810	5-Oct-2020	MYSORE	66	HV2	KMDODDI_66	12:20	12:38	00:18	HAND TRIPPED
811	5-Oct-2020	MYSORE	66	JYOTHINAGARA-DK MAIDANA	DKMAIDANA_66	13:36	13:44	00:08	LINE FAULT
812	5-Oct-2020	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:42	17:08	00:06	LINE FAULT
813	5-Oct-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	07:13	11:49	00:11	LINE FAULT
814	5-Oct-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:11	07:25	00:11	LINE FAULT
815	5-Oct-2020	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	15:40	18:25	01:28	LINE CLEAR AVAILED
816	5-Oct-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	04:50	13:23	00:01	LINE FAULT
817	5-Oct-2020	TUMKUR	66	HONNALLI 220KV-NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	07:35	06:51	00:08	LINE FAULT
818	5-Oct-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	06:46	04:52	00:04	LINE FAULT
819	5-Oct-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	12:27	07:44	00:11	LINE FAULT
820	5-Oct-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	16:54	12:39	00:06	LINE CLEAR AVAILED
821	5-Oct-2020	TUMKUR	66	MAYAKONDA-DAVANAGERE SRS 220KV	MAYAKONDA_66	18:41	15:02	00:39	LINE FAULT
822	5-Oct-2020	TUMKUR	66	PUNABHAGHATTA-UCHCHANGIDURGA66	PUNABHAGHATTA_66, UCHCHANGIDURGA_66, PALLAGATTE_66	12:46	19:20	02:11	LINE CLEAR AVAILED
823	5-Oct-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	14:45	14:12	00:12	HAND TRIPPED
824	5-Oct-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	20:36	14:57	00:12	HAND TRIPPED
825	5-Oct-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	11:32	17:54	03:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
826	5-Oct-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	15:40	17:08	01:28	LINE CLEAR AVAILED
827	5-Oct-2020	TUMKUR	66	TR-1	MAVINAKATTE_66	12:58	17:01	02:04	LINE CLEAR AVAILED
828	5-Oct-2020	TUMKUR	66	TR-2	CHIKKABANAGERE_66	16:01	15:02	02:23	LINE CLEAR AVAILED
829	5-Oct-2020	TUMKUR	66	TR-2	SASALUHALLA_66	10:38	14:58	03:34	LINE CLEAR AVAILED
830	5-Oct-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
831	5-Oct-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:03	17:54	06:51	LINE CLEAR AVAILED