

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:21.01.2020 TO 27.01.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	21-Jan-2020	BAGALKOT	110	110/11KV,HV 1	ANANDNAGAR_110	13:02	13:28	0:26	LINE CLEAR AVAILED
2	21-Jan-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	0:00	14:08	14:08	LINE CLEAR AVAILED
3	21-Jan-2020	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	8:08	8:38	0:30	LINE FAULT
4	21-Jan-2020	BAGALKOT	220	BELGAUM -CHIKKODI 2	BELGAUM_220	0:00	7:37	7:37	LINE CLEAR AVAILED
5	21-Jan-2020	BAGALKOT	220	220/110KV,HV1 & LV1	GADAG_220	0:00	17:49	17:49	LINE CLEAR AVAILED
6	21-Jan-2020	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAY NAGAR 1&2	GOPANAKOPPA_110	11:10	17:55	6:45	LINE CLEAR AVAILED
7	21-Jan-2020	BAGALKOT	110	GOPANAKOPPA TO BIDNAL-NAVALGUNG	GOPANAKOPPA_110	11:16	18:28	7:12	LINE CLEAR AVAILED
8	21-Jan-2020	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GOPANAKOPPA_110	11:16	17:54	6:38	LINE CLEAR AVAILED
9	21-Jan-2020	BAGALKOT	110	KADNDAKOPPA-KAVALWAD_110	KAVALWAD_110	10:14	10:24	0:10	HAND TRIPPED
10	21-Jan-2020	BAGALKOT	220	220/110KV,HV1 & LV1	KARAWAR_220	10:41	15:04	4:23	LINE CLEAR AVAILED
11	21-Jan-2020	BAGALKOT	220	220/110KV,HV2& LV2	KARAWAR_220	15:05	19:19	4:14	LINE CLEAR AVAILED
12	21-Jan-2020	BAGALKOT	110	110/11KV,HV3	LOKAPUR_110	11:35	12:13	0:38	TRANSFORMER FAULT
13	21-Jan-2020	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	8:07	19:09	11:02	LINE CLEAR AVAILED
14	21-Jan-2020	BAGALKOT	220	220/110KV, HV3	HUBLI_220	10:12	12:53	2:41	LINE CLEAR AVAILED
15	21-Jan-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	12:10	12:29	0:19	LINE CLEAR AVAILED
16	21-Jan-2020	BAGALKOT	110	HUBLI-TARIHAL1	TARIHAL_110	15:26	17:22	1:56	LINE CLEAR AVAILED
17	21-Jan-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	11:02	12:33	1:31	LINE CLEAR AVAILED
18	21-Jan-2020	BAGALKOT	110	110/33KV, HV2	MATTIHAL_110	13:48	13:54	0:06	HAND TRIPPED
19	21-Jan-2020	GULBARGA	220	LINGASUGUR-MALLAT	LINGASUGUR_220	2:44	3:39	0:55	LINE FAULT
20	21-Jan-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	3:37	10:52	7:15	LINE FAULT
21	21-Jan-2020	GULBARGA	220	LINGASUGUR-B.BAGEWADI1	B.BAGEWADI_220	0:00	19:35	19:35	LINE CLEAR AVAILED
22	21-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	11:48	12:45	0:57	LINE CLEAR AVAILED
23	21-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,HUNSAGI_110,ASKI_110	22:54	23:00	0:06	LINE FAULT
24	21-Jan-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:15	17:16	3:01	LINE CLEAR AVAILED
25	21-Jan-2020	HASSAN	220	HV1	KEMAR_220	12:55	12:59	0:04	HAND TRIPPED
26	21-Jan-2020	HASSAN	220	HV2	KEMAR_220	13:02	13:20	0:18	HAND TRIPPED
27	21-Jan-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	9:56	14:19	4:23	NFBC ISSUED
28	21-Jan-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	9:57	14:19	4:22	LINE CLEAR AVAILED
29	21-Jan-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:03	12:35	1:32	LINE CLEAR AVAILED
30	21-Jan-2020	HASSAN	110	LV1	KEMAR_220	12:55	12:59	0:04	HAND TRIPPED
31	21-Jan-2020	HASSAN	110	LV2	KEMAR_220	13:02	13:20	0:18	HAND TRIPPED
32	21-Jan-2020	HASSAN	110	HV1	ANAVATTI_110	11:00	11:05	0:05	HAND TRIPPED
33	21-Jan-2020	HASSAN	110	HV1	ANAVATTI_110	11:55	12:05	0:10	HAND TRIPPED
34	21-Jan-2020	HASSAN	110	HV2	ANAVATTI_110	11:05	11:55	0:50	LINE CLEAR AVAILED
35	21-Jan-2020	HASSAN	110	HV1	ARASIKERE_110	11:33	12:49	1:16	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
36	21-Jan-2020	HASSAN	110	HV1	ARASIKERE_110	22:36	22:47	0:11	TRANSFORMER FAULT
37	21-Jan-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	12:46	12:49	0:03	HAND TRIPPED
38	21-Jan-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	12:50	17:23	4:33	LINE CLEAR AVAILED
39	21-Jan-2020	HASSAN	110	HV2	NERALAKERE_110	11:59	13:01	1:02	LINE CLEAR AVAILED
40	21-Jan-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	11:30	14:28	2:58	LINE CLEAR AVAILED
41	21-Jan-2020	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:19	14:08	1:49	LINE CLEAR AVAILED
42	21-Jan-2020	HASSAN	66	HV1	RAMPURA_66	6:03	6:11	0:08	TRANSFORMER FAULT
43	21-Jan-2020	HASSAN	66	HV1	RAMPURA_66	6:29	6:34	0:05	TRANSFORMER FAULT
44	21-Jan-2020	MYSORE	66	BETTADAPURA -KR NAGARA	BETTADHAPURA_66	12:00	12:09	0:09	LINE CLEAR AVAILED
45	21-Jan-2020	MYSORE	66	HV1	DATTAGALLY_66	9:46	9:53	0:06	TRANSFORMER FAULT
46	21-Jan-2020	MYSORE	66	HV1	DUNDANAHALLI_66	14:43	16:16	1:32	LINE CLEAR AVAILED
47	21-Jan-2020	MYSORE	66	HV2	DUNDANAHALLI_66	18:23	18:53	0:29	LINE CLEAR AVAILED
48	21-Jan-2020	MYSORE	66	HV2	KIADBMANDYA_66	18:10	18:31	0:21	TRANSFORMER FAULT
49	21-Jan-2020	MYSORE	66	HV2	KIADBMANDYA_66	18:31	23:59	5:27	TRANSFORMER FAULT
50	21-Jan-2020	MYSORE	66	HV2	YELANDUR_66	10:17	17:18	7:00	LINE CLEAR AVAILED
51	21-Jan-2020	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	11:45	11:56	0:10	TRANSFORMER FAULT
52	21-Jan-2020	TUMKUR	220	TR-1(HV SIDE)	NEELAGUNDA_220	11:26	13:11	1:45	LINE CLEAR AVAILED
53	21-Jan-2020	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	13:54	14:15	0:21	HAND TRIPPED
54	21-Jan-2020	TUMKUR	110	TR-1	TIMMANAHALLI_110	12:19	12:28	0:08	TRANSFORMER FAULT
55	21-Jan-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	8:20	8:32	0:11	LINE FAULT
56	21-Jan-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	13:28	13:40	0:12	LINE CLEAR AVAILED
57	21-Jan-2020	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	11:36	11:57	0:21	TRANSFORMER FAULT
58	21-Jan-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	8:10	8:25	0:15	LINE FAULT
59	21-Jan-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:48	13:37	1:48	LINE FAULT
60	21-Jan-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	17:09	17:56	0:47	LINE CLEAR AVAILED
61	21-Jan-2020	TUMKUR	66	TR-1	KATTIGE_66	17:31	17:35	0:03	TRANSFORMER FAULT
62	21-Jan-2020	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	13:25	13:39	0:14	HAND TRIPPED
63	21-Jan-2020	TUMKUR	66	TR-1	MEDIGESHI_66	16:52	17:15	0:22	LINE CLEAR AVAILED
64	21-Jan-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGIDU RGA_66, JAGALUR_66, PALLAGATTE_66	11:26	13:16	1:50	LINE CLEAR AVAILED
65	21-Jan-2020	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	11:26	13:12	1:46	LINE CLEAR AVAILED
66	21-Jan-2020	TUMKUR	66	TR-1	YNHOSKOTE_66	14:11	14:24	0:12	LINE CLEAR AVAILED
67	22-Jan-2020	BAGALKOT	110	110/11KV, HV 1	BABALESHWAR_110	12:30	13:13	0:43	HAND TRIPPED
68	22-Jan-2020	BAGALKOT	220	BAGEWADI-NANDIHAL 1&2	BAGEWADI_220	18:18	23:59	5:41	NFBC ISSUED
69	22-Jan-2020	BAGALKOT	220	220/110KV, HV3	HUBLI_220	10:57	18:14	7:17	LINE CLEAR AVAILED
70	22-Jan-2020	BAGALKOT	110	220/110KV, LV3	HUBLI_220	0:00	18:14	18:14	LINE CLEAR AVAILED
71	22-Jan-2020	BAGALKOT	110	220/110KV, LV 1	HUBLI_220	18:14	23:59	5:45	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
72	22-Jan-2020	BAGALKOT	220	MAHALINGAPUR-SOUNDATTI	MAHALINGPUR_220	19:22	23:59	4:37	LINE CLEAR AVAILED
73	22-Jan-2020	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	11:06	12:36	1:30	LINE CLEAR AVAILED
74	22-Jan-2020	BAGALKOT	110	110/33KV,HV 3	TARIHAL_110,33KV-INDUSTRIAL ESTATE& DHUMAWAD	10:57	18:14	7:17	LINE CLEAR AVAILED
75	22-Jan-2020	BAGALKOT	110	SAVALAGI-TODALABAGI	TODALABAGI_110	23:23	23:40	0:17	LINE FAULT
76	22-Jan-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	3:36	4:52	1:15	LINE FAULT
77	22-Jan-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	4:52	10:55	6:03	LINE FAULT
78	22-Jan-2020	BENGALURU	66	HV1	HOSKOTE 220	11:44	11:49	0:05	TRANSFORMER FAULT
79	22-Jan-2020	BENGALURU	66	KOLAR 220 - TYALUR	TYALUR, NG HULKUR, MALLANAYAKANAHALLI, MULBAGALU, AVANI, TAMAKA	9:11	9:36	0:25	LINE FAULT
80	22-Jan-2020	BENGALURU	66	KOLAR 220 - TYALUR	TYALUR, NG HULKUR, MALLANAYAKANAHALLI, MULBAGALU, AVANI, TAMAKA	16:10	16:35	0:25	LINE FAULT
81	22-Jan-2020	BENGALURU	66	KOLAR 220 - TYALUR	TYALUR, NG HULKUR, MALLANAYAKANAHALLI, MULBAGALU, AVANI, TAMAKA	16:40	16:50	0:10	LINE FAULT
82	22-Jan-2020	BENGALURU	220	HV1	KOLAR 220	13:20	14:05	0:45	TRANSFORMER FAULT
83	22-Jan-2020	BENGALURU	220	HV2	KOLAR 220	13:20	14:05	0:45	TRANSFORMER FAULT
84	22-Jan-2020	BENGALURU	66	KOLAR 220 - BANGARPETE 1	BANGARPETE	13:20	14:05	0:45	MAIN SUPPLY FAILURE
85	22-Jan-2020	BENGALURU	66	KOLAR 220 - TYALUR	TYALUR, NG HULKUR, MALLANAYAKANAHALLI, MULBAGALU, AVANI, TAMAKA	13:20	14:05	0:45	MAIN SUPPLY FAILURE
86	22-Jan-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO(EHT), DAALSNUR, SRINIVASAPURA	13:20	14:05	0:45	MAIN SUPPLY FAILURE
87	22-Jan-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGLI	13:20	14:05	0:45	MAIN SUPPLY FAILURE
88	22-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	15:21	16:10	0:49	MAIN SUPPLY FAILURE
89	22-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	15:21	16:00	0:39	MAIN SUPPLY FAILURE
90	22-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	15:21	16:11	0:50	MAIN SUPPLY FAILURE
91	22-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	15:21	16:04	0:43	MAIN SUPPLY FAILURE
92	22-Jan-2020	BENGALURU	66	VRISHBHAVATHI 220 - RR NAGAR	RR NAGAR	15:21	16:12	0:51	MAIN SUPPLY FAILURE
93	22-Jan-2020	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	9:45	9:54	0:09	MAIN SUPPLY FAILURE
94	22-Jan-2020	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	7:28	7:55	0:27	LINE FAULT
95	22-Jan-2020	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	15:21	16:03	0:42	LINE FAULT
96	22-Jan-2020	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	10:06	10:09	0:03	LOAD CHANGEOVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
97	22-Jan-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, SOMANTHPURA, THIMAMPALLI	16:05	16:10	0:05	LINE FAULT
98	22-Jan-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, SOMANTHPURA, THIMAMPALLI	16:30	16:55	0:25	LINE FAULT
99	22-Jan-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, SOMANTHPURA, THIMAMPALLI	11:10	13:10	2:00	LINE CLEAR AVAILED
100	22-Jan-2020	BENGALURU	66	HV1	TUBUGERE	0:00	0:35	0:35	TRANSFORMER FAULT
101	22-Jan-2020	BENGALURU	66	HV1	CHANDRAPPA CIRCLE	9:23	9:32	0:08	TRANSFORMER FAULT
102	22-Jan-2020	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL, KYALANUR	12:40	14:20	1:40	LINE CLEAR AVAILED
103	22-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAID APUR_110	5:24	5:30	0:06	LINE FAULT
104	22-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAID APUR_110	6:20	6:27	0:07	LINE FAULT
105	22-Jan-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1,2	HIREHADAGALI_66,GIRIYAPURA_66,SO VENAHALLI_66,TUNGABHADRA,MAGAL_66	8:42	8:49	0:07	LINE CLEAR AVAILED
106	22-Jan-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	KUDLIGI_66,KOGALI_66,HANASI_66,CJ HALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANAVEKAL_66,CHORNOOR_66	14:10	14:20	0:10	LINE FAULT
107	22-Jan-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	KUDLIGI_66,KOGALI_66,HANASI_66,CJ HALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANAVEKAL_66,CHORNOOR_66	14:30	14:38	0:08	LINE FAULT
108	22-Jan-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA-400	12:57	16:30	3:33	LINE CLEAR AVAILED
109	22-Jan-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:04	17:17	7:13	LINE CLEAR AVAILED
110	22-Jan-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	17:49	20:42	2:53	LINE FAULT
111	22-Jan-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	17:49	20:42	2:53	LINE FAULT
112	22-Jan-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA-400	17:57	20:47	2:50	LINE CLEAR AVAILED
113	22-Jan-2020	HASSAN	110	HV1	KONAJE_110	10:19	10:22	0:03	HAND TRIPPED
114	22-Jan-2020	HASSAN	110	HV1	KONAJE_110	12:08	17:22	5:14	LINE CLEAR AVAILED
115	22-Jan-2020	HASSAN	110	HV2	KONAJE_110	10:19	10:22	0:03	HAND TRIPPED
116	22-Jan-2020	HASSAN	110	HV2	KONAJE_110	10:55	12:08	1:13	LINE CLEAR AVAILED
117	22-Jan-2020	HASSAN	110	HV2	KONAJE_110	14:35	14:39	0:04	HAND TRIPPED
118	22-Jan-2020	HASSAN	110	HV2	KONAJE_110	17:16	17:26	0:10	TRANSFORMER FAULT
119	22-Jan-2020	HASSAN	110	HV3	KONAJE_110	10:19	10:22	0:03	HAND TRIPPED
120	22-Jan-2020	HASSAN	110	HV3	KONAJE_110	14:36	14:39	0:03	HAND TRIPPED
121	22-Jan-2020	HASSAN	110	SLTR	PUTTUR_220	10:38	14:17	3:39	LINE CLEAR AVAILED
122	22-Jan-2020	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:36	14:24	3:48	NFBC ISSUED
123	22-Jan-2020	HASSAN	110	HV1	SALATHUR_110	16:46	17:08	0:22	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
124	22-Jan-2020	HASSAN	110	HV2	SALATHUR_110	17:06	19:00	1:54	LINE CLEAR AVAILED
125	22-Jan-2020	HASSAN	66	HV1	ARAKALGUD_66	9:42	12:53	3:11	MAIN SUPPLY FAILURE
126	22-Jan-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	9:24	13:40	4:16	LINE CLEAR AVAILED
127	22-Jan-2020	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	12:01	14:00	1:59	LINE CLEAR AVAILED
128	22-Jan-2020	HASSAN	66	HV1	DIDIGA_66	12:01	14:00	1:59	LINE CLEAR AVAILED
129	22-Jan-2020	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN220	8:03	12:05	4:02	LINE CLEAR AVAILED
130	22-Jan-2020	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN220	8:03	12:06	4:03	LINE CLEAR AVAILED
131	22-Jan-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	11:47	16:46	4:59	LINE CLEAR AVAILED
132	22-Jan-2020	HASSAN	66	HANBAL	SAKLESH PURA_66	5:38	5:50	0:12	LINE FAULT
133	22-Jan-2020	MYSORE	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	8:42	8:55	0:12	LINE FAULT
134	22-Jan-2020	MYSORE	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	8:42	8:55	0:12	LINE FAULT
135	22-Jan-2020	MYSORE	66	SHANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	9:36	13:40	4:03	NFBC ISSUED
136	22-Jan-2020	MYSORE	66	SHANIVARSANTHE-YESSLUR	SANIVARASANTHE_66	10:30	13:40	3:09	LINE CLEAR AVAILED
137	22-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	15:09	17:30	2:20	LINE CLEAR AVAILED
138	22-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	0:36	0:46	0:09	HAND TRIPPED
139	22-Jan-2020	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	9:17	13:17	3:59	LINE CLEAR AVAILED
140	22-Jan-2020	TUMKUR	66	TR-2	BELLAVI_66	9:17	13:18	4:00	LINE CLEAR AVAILED
141	22-Jan-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	0:00	0:07	0:06	TRANSFORMER FAULT
142	22-Jan-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	3:23	3:29	0:05	TRANSFORMER FAULT
143	22-Jan-2020	TUMKUR	66	TR-2	CHIKKABANAGERE_66	17:05	18:04	0:58	LINE CLEAR AVAILED
144	22-Jan-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	9:58	10:57	0:58	LINE CLEAR AVAILED
145	22-Jan-2020	TUMKUR	66	TTR-1	DAVANGERE_SRS_220	8:32	8:39	0:07	TRANSFORMER FAULT
146	22-Jan-2020	TUMKUR	66	TR-2	HANAGAL_66	14:14	14:26	0:12	LINE CLEAR AVAILED
147	22-Jan-2020	TUMKUR	66	TR-2	HIREHALLY_66	9:15	9:22	0:06	TRANSFORMER FAULT
148	22-Jan-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	12:05	12:11	0:05	TRANSFORMER FAULT
149	22-Jan-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:49	7:59	0:10	LINE FAULT
150	22-Jan-2020	TUMKUR	66	TR-2	KUKKAWADA_66	23:07	23:17	0:10	TRANSFORMER FAULT
151	22-Jan-2020	TUMKUR	66	TR-2	MELKOTE_66	9:29	18:28	8:58	LINE CLEAR AVAILED
152	22-Jan-2020	TUMKUR	66	TR-1	SHYLAPURA_66	20:30	20:36	0:05	TRANSFORMER FAULT
153	23-Jan-2020	BAGALKOT	110	110/11KV,HV 2	AREMALLAPUR_110	11:44	13:50	2:06	LINE CLEAR AVAILED
154	23-Jan-2020	BAGALKOT	110	110/11KV,HV 1	AREMALLAPUR_110	13:09	13:20	0:11	LINE CLEAR AVAILED
155	23-Jan-2020	BAGALKOT	110	110/11KV,HV 1	AREMALLAPUR_110	15:15	16:20	1:05	LINE CLEAR AVAILED
156	23-Jan-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	22:51	23:46	0:55	HAND TRIPPED
157	23-Jan-2020	BAGALKOT	220	220/110KV,HV1&LV1	BIDNAL_220	12:23	17:27	5:04	LINE CLEAR AVAILED
158	23-Jan-2020	BAGALKOT	220	220/110KV,HV1&LV1	BIDNAL_220,NAVALGUND_110	18:02	23:59	5:57	TRANSFORMER FAULT
159	23-Jan-2020	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	11:58	23:59	12:01	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
160	23-Jan-2020	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMOUND_110	11:57	23:59	12:02	LINE CLEAR AVAILED
161	23-Jan-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	12:00	17:57	5:57	LINE CLEAR AVAILED
162	23-Jan-2020	BAGALKOT	110	110/11KV,HV1&2	BIDNAL_220	18:19	18:21	0:02	HAND TRIPPED
163	23-Jan-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	18:19	23:59	5:40	LINE CLEAR AVAILED
164	23-Jan-2020	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	10:31	15:28	4:57	LINE CLEAR AVAILED
165	23-Jan-2020	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	15:33	17:16	1:43	LINE CLEAR AVAILED
166	23-Jan-2020	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	17:20	20:40	3:20	LINE CLEAR AVAILED
167	23-Jan-2020	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	11:53	20:54	9:01	LINE CLEAR AVAILED
168	23-Jan-2020	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	16:29	17:35	1:06	LINE CLEAR AVAILED
169	23-Jan-2020	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	17:35	23:59	6:24	LINE CLEAR AVAILED
170	23-Jan-2020	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	12:34	13:17	0:43	LINE CLEAR AVAILED
171	23-Jan-2020	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	0:00	11:59	11:59	LINE CLEAR AVAILED
172	23-Jan-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	12:35	13:19	0:44	LINE FAULT
173	23-Jan-2020	BAGALKOT	110	SIRSI220-KUMTA	KUMTA_110	13:21	23:59	10:38	LINE CLEAR AVAILED
174	23-Jan-2020	BAGALKOT	110	110/11KV,HV3	MUDHOL_110	13:03	13:18	0:15	HAND TRIPPED
175	23-Jan-2020	BAGALKOT	110	110/33KV,HV1	MUDHOL_110,YADAWAD_33	16:36	23:59	7:23	LINE CLEAR AVAILED
176	23-Jan-2020	BAGALKOT	110	110/11KV, HV2	YELPARAHATTI_110	18:43	18:47	0:04	TRANSFORMER FAULT
177	23-Jan-2020	BAGALKOT	110	110/11KV, HV2	YELPARAHATTI_110	19:49	19:53	0:04	LINE CLEAR AVAILED
178	23-Jan-2020	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	8:33	8:41	0:08	TRANSFORMER FAULT
179	23-Jan-2020	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	7:28	7:41	0:13	TRANSFORMER FAULT
180	23-Jan-2020	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	9:52	20:03	10:11	LINE CLEAR AVAILED
181	23-Jan-2020	BAGALKOT	110	HUBLI-TARIHAL1	TARIHAL_110	9:11	17:18	8:07	LINE CLEAR AVAILED
182	23-Jan-2020	BAGALKOT	220	220/110KV, HV1	HUBLI_220	8:02	17:03	9:01	LINE CLEAR AVAILED
183	23-Jan-2020	BAGALKOT	220	MAHALINGAPUR-SOUNDATTI	MAHALINGPUR_220	0:00	5:30	5:30	LINE CLEAR AVAILED
184	23-Jan-2020	BAGALKOT	110	CHIKKODI2-RAIBAG	RAIBAG_110	11:37	13:35	1:58	LINE CLEAR AVAILED
185	23-Jan-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, BEVOOR, DASAVARA, SAKALGERE, SHIVANAHALLI	8:12	10:08	1:56	LINE CLEAR AVAILED
186	23-Jan-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, BEVOOR, DASAVARA, SAKALGERE, SHIVANAHALLI	17:00	18:10	1:10	LINE CLEAR AVAILED
187	23-Jan-2020	BENGALURU	66	HV2	THIMMAMPALLI	17:50	18:51	1:01	LINE CLEAR AVAILED
188	23-Jan-2020	BENGALURU	66	HV2	THIMMAMPALLI	19:11	19:35	0:23	LINE CLEAR AVAILED
189	23-Jan-2020	BENGALURU	66	GUDIBANDE - GOWRIBIDANUR 220	GUDIBANDE	10:00	15:15	5:15	LINE CLEAR AVAILED
190	23-Jan-2020	BENGALURU	66	HV1	KYALANUR	16:29	16:42	0:13	LINE CLEAR AVAILED
191	23-Jan-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	9:15	9:25	0:10	LOAD CURTAILMENT
192	23-Jan-2020	BENGALURU	66	HV1	KOLAR 220	15:05	17:02	1:57	LINE CLEAR AVAILED
193	23-Jan-2020	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGLI	13:00	13:43	0:43	LOAD CURTAILMENT
194	23-Jan-2020	GULBARGA	220	HV2	LINGASUGUR_220	9:30	23:59	14:29	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
195	23-Jan-2020	GULBARGA	110	BHALKI-HALBARGA	BHALKI_110,LADHA_110	14:15	16:34	2:19	LINE CLEAR AVAILED
196	23-Jan-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITGUPPA_110, KORWARTEMPLE_110	8:30	8:38	0:08	LINE FAULT
197	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	4:45	4:55	0:10	HAND TRIPPED
198	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	8:20	8:45	0:25	HAND TRIPPED
199	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	11:00	11:05	0:05	HAND TRIPPED
200	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	13:10	13:15	0:05	HAND TRIPPED
201	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	3:10	3:15	0:05	HAND TRIPPED
202	23-Jan-2020	GULBARGA	220	HV2	LINGASUGUR_220	9:30	23:59	14:29	LINE CLEAR AVAILED
203	23-Jan-2020	GULBARGA	110	BHALKI-HALBARGA	BHALKI_110,LADHA_110	14:15	16:34	2:19	LINE CLEAR AVAILED
204	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	4:45	4:55	0:10	HAND TRIPPED
205	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	8:20	8:45	0:25	HAND TRIPPED
206	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	11:00	11:05	0:05	HAND TRIPPED
207	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	13:10	13:15	0:05	HAND TRIPPED
208	23-Jan-2020	GULBARGA	66	HV1	HANASI_66	3:10	3:15	0:05	HAND TRIPPED
209	23-Jan-2020	HASSAN	110	HV1	PUTTUR_110	10:28	17:48	7:20	LINE CLEAR AVAILED
210	23-Jan-2020	HASSAN	110	HV2	PUTTUR_110	10:28	17:48	7:20	LINE CLEAR AVAILED
211	23-Jan-2020	HASSAN	110	HV1	ANAVATTI_110	1:00	1:10	0:10	MAIN SUPPLY FAILURE
212	23-Jan-2020	HASSAN	110	HV2	ANAVATTI_110	1:00	1:10	0:10	MAIN SUPPLY FAILURE
213	23-Jan-2020	HASSAN	110	JADE	ANAVATTI_110	1:00	1:10	0:10	MAIN SUPPLY FAILURE
214	23-Jan-2020	HASSAN	110	HV2	KARAYA_110	3:03	9:41	6:38	TRANSFORMER FAULT
215	23-Jan-2020	HASSAN	66	LINGADAHALLI	bhadra_gen	8:31	8:44	0:13	LINE FAULT
216	23-Jan-2020	HASSAN	66	SHMGA 2	bhadra_gen	13:03	13:16	0:13	LINE FAULT
217	23-Jan-2020	HASSAN	66	BD-2	MRSMSG_220	13:03	13:16	0:13	LINE FAULT
218	23-Jan-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	10:13	12:05	1:52	LINE CLEAR AVAILED
219	23-Jan-2020	HASSAN	66	HV2	SHRAVANABELAGOLA_66	10:13	13:01	2:48	LINE CLEAR AVAILED
220	23-Jan-2020	HASSAN	66	UDAYAPURA	CHANNARAYAPATNA_66	12:36	12:53	0:17	HAND TRIPPED
221	23-Jan-2020	MYSORE	66	HV2	COWDALLI_66	9:21	9:25	0:04	TRANSFORMER FAULT
222	23-Jan-2020	MYSORE	66	HV1	DUNDANAHALLI_66	11:29	12:17	0:47	LINE CLEAR AVAILED
223	23-Jan-2020	MYSORE	66	KADAKOLA-DEVANUR	DEVANOORNGUDU_66 SUTTUR_66	6:41	6:47	0:06	LINE FAULT
224	23-Jan-2020	MYSORE	66	HV1	KIADBMANDYA_66	11:53	23:59	12:05	LINE CLEAR AVAILED
225	23-Jan-2020	MYSORE	66	HV2	KIADBMANDYA_66	8:45	11:50	3:04	LINE CLEAR AVAILED
226	23-Jan-2020	MYSORE	66	HV2	KRNAGARA_66	12:55	17:12	4:17	LINE CLEAR AVAILED
227	23-Jan-2020	MYSORE	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	1:48	1:59	0:11	LINE FAULT
228	23-Jan-2020	MYSORE	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	1:48	1:59	0:11	LINE FAULT
229	23-Jan-2020	MYSORE	66	HV1	SANTHESARAGUR_66	8:03	9:30	1:26	TRANSFORMER FAULT
230	23-Jan-2020	MYSORE	66	SANTESARGUR-KADAKOLA 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	8:15	8:25	0:10	LINE FAULT
231	23-Jan-2020	MYSORE	66	HV2	THALAKADU_66	10:21	10:28	0:06	HAND TRIPPED
232	23-Jan-2020	MYSORE	66	HV1	TARIPURA_66	10:30	13:21	2:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
233	23-Jan-2020	MYSORE	220	HV1	TUBINAKERE_220	10:10	14:09	3:58	LINE CLEAR AVAILED
234	23-Jan-2020	MYSORE	66	VAJMANGALA-JYOTHINAGAR	JYOTHINAGARA_66 FTS_66 BANNIMANTAP_66	8:17	8:27	0:09	LINE FAULT
235	23-Jan-2020	MYSORE	66	HV1	VIRAJPET_66	19:00	19:13	0:12	TRANSFORMER FAULT
236	23-Jan-2020	TUMKUR	110	TR-1	SAMPIGE_110	13:46	14:23	0:37	TRANSFORMER FAULT
237	23-Jan-2020	TUMKUR	66	TR-2	AVAREGERE_66	11:28	16:57	5:29	LINE CLEAR AVAILED
238	23-Jan-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	15:02	15:40	0:37	LINE FAULT
239	23-Jan-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	12:20	13:33	1:12	LINE CLEAR AVAILED
240	23-Jan-2020	TUMKUR	66	TR-1	BELADARA_66	11:53	13:32	1:39	LINE CLEAR AVAILED
241	23-Jan-2020	TUMKUR	66	TR-2	BELADARA_66	12:20	13:33	1:13	LINE CLEAR AVAILED
242	23-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:11	8:47	2:35	LINE CLEAR AVAILED
243	23-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	15:34	15:40	0:06	HAND TRIPPED
244	23-Jan-2020	TUMKUR	66	TR-1	HANAGAL_66	11:58	12:23	0:25	HAND TRIPPED
245	23-Jan-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	10:10	10:13	0:03	TRANSFORMER FAULT
246	23-Jan-2020	TUMKUR	66	SHYLAPURA-PAVAGADA 220KV	SHYLAPURA_66	8:49	8:51	0:01	LINE FAULT
247	23-Jan-2020	TUMKUR	66	SHYLAPURA-PAVAGADA 220KV	SHYLAPURA_66	13:22	13:40	0:17	LINE FAULT
248	23-Jan-2020	TUMKUR	66	SHYLAPURA-PR PURA	SHYLAPURA_66	13:40	13:54	0:14	HAND TRIPPED
249	23-Jan-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	15:21	15:23	0:02	TRANSFORMER FAULT
250	23-Jan-2020	TUMKUR	66	THOVINAKERE-ANTHRASANAHALLI	THOVINAKERE_66	10:26	11:20	0:53	LINE FAULT
251	23-Jan-2020	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP IMAMI_SOLAR_IPP	VENKATAPUR_66	13:23	14:39	1:16	LINE FAULT
252	24-Jan-2020	BAGALKOT	110	110/11KV,HV 2	AMBEWADI_220	10:23	12:16	1:53	LINE CLEAR AVAILED
253	24-Jan-2020	BAGALKOT	110	110/11KV,HV 1	ANAND NAGAR_110	11:12	11:21	0:09	TRANSFORMER FAULT
254	24-Jan-2020	BAGALKOT	110	ANKOLA-KUMTA(L2)	KUMATA_110	16:59	18:14	1:15	LINE CLEAR AVAILED
255	24-Jan-2020	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	16:41	16:48	0:07	HAND TRIPPED
256	24-Jan-2020	BAGALKOT	110	ATHANI220-THAUSHI	THAUSHI_110	22:29	22:36	0:07	LINE FAULT
257	24-Jan-2020	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	7:54	8:17	0:23	LINE FAULT
258	24-Jan-2020	BAGALKOT	110	BABALESHWAR-MAMADAPUR	MAMADAPUR_110	6:41	7:36	0:55	LINE FAULT
259	24-Jan-2020	BAGALKOT	220	BAGEWADI-NANDIHAL 1	BAGEWADI_220	0:00	13:02	13:02	LINE CLEAR AVAILED
260	24-Jan-2020	BAGALKOT	220	BAGEWADI-ADPH 2	BAGEWADI_220	11:06	23:59	12:53	LINE CLEAR AVAILED
261	24-Jan-2020	BAGALKOT	220	220/110KV,HV 1	BIDNAL_220	0:00	14:06	14:06	LINE CLEAR AVAILED
262	24-Jan-2020	BAGALKOT	110	220/110KV,LV 1	BIDNAL_220	0:00	16:13	16:13	LINE CLEAR AVAILED
263	24-Jan-2020	BAGALKOT	110	BIDNAL-P H COMOUND	P H COMPOUND_110	0:00	18:59	18:59	LINE CLEAR AVAILED
264	24-Jan-2020	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	8:21	9:05	0:44	LINE FAULT
265	24-Jan-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	11:23	13:59	2:36	LINE CLEAR AVAILED
266	24-Jan-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	11:27	11:28	0:01	LINE FAULT
267	24-Jan-2020	BAGALKOT	220	220/110KV,HV1 & LV1	CHIKKODI_220	13:39	17:03	3:24	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
268	24-Jan-2020	BAGALKOT	220	220/110KV,HV2 &LV2	CHIKKODI_220	17:05	20:34	3:29	LINE CLEAR AVAILED
269	24-Jan-2020	BAGALKOT	110	110/11KV HV 1	DAMBAL_110	10:30	13:14	2:44	TRANSFORMER FAULT
270	24-Jan-2020	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	0:00	16:42	16:42	LINE CLEAR AVAILED
271	24-Jan-2020	BAGALKOT	110	HAVERI-BYDAGI	BYADAGI_110	3:06	3:56	0:50	LINE FAULT
272	24-Jan-2020	BAGALKOT	110	HAVERI-BYDAGI	BYADAGI_110	11:09	15:53	4:44	LINE CLEAR AVAILED
273	24-Jan-2020	BAGALKOT	110	HAVERI-TILUVALLI	TILUVALLI_110	17:01	19:03	2:02	LINE CLEAR AVAILED
274	24-Jan-2020	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	16:03	18:07	2:04	LINE CLEAR AVAILED
275	24-Jan-2020	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	18:57	19:11	0:14	MAIN SUPPLY FAILURE
276	24-Jan-2020	BAGALKOT	110	110/11KV,HV3	TILUVALI_110,KALAKERI_33,SESAGIRI_33	18:57	19:21	0:24	MAIN SUPPLY FAILURE
277	24-Jan-2020	BAGALKOT	110	220/110KV,LV3	HUBLI_220	11:11	23:59	12:48	LINE CLEAR AVAILED
278	24-Jan-2020	BAGALKOT	110	220/110KV,LV1	HUBLI_220	0:00	11:11	11:11	LINE CLEAR AVAILED
279	24-Jan-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	14:33	15:26	0:53	LINE CLEAR AVAILED
280	24-Jan-2020	BAGALKOT	110	110/11KV,HV2	NANADI_110	17:49	18:28	0:39	LINE CLEAR AVAILED
281	24-Jan-2020	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	16:53	17:04	0:11	HAND TRIPPED
282	24-Jan-2020	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 1	MAHALINGAPUR_220	11:54	11:58	0:04	LINE FAULT
283	24-Jan-2020	BAGALKOT	220	220/110KV,HV3&LV3	MAHALINGAPUR_220,ITNAL_110,RABA KAVI_110,HIDIKAL_110	3:07	4:17	1:10	TRANSFORMER FAULT
284	24-Jan-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMINAGA D_33,MYTRA_33	12:51	12:56	0:05	TRANSFORMER FAULT
285	24-Jan-2020	BAGALKOT	110	HIREKERUR-SHRLKP(BELLIGAVI)	BELLIGAVI_110	9:17	14:42	5:25	LINE CLEAR AVAILED
286	24-Jan-2020	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	4:54	23:59	19:05	LINE CLEAR AVAILED
287	24-Jan-2020	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSSS	9:01	9:06	0:05	LOAD CHANGEOVER
288	24-Jan-2020	BENGALURU	66	HV2	HAROBELA	13:05	13:10	0:05	LINE CLEAR AVAILED
289	24-Jan-2020	BENGALURU	66	HV1	HAROBELA	13:25	13:35	0:10	LINE CLEAR AVAILED
290	24-Jan-2020	BENGALURU	66	HV1	HAROBELA	13:50	14:05	0:15	TRANSFORMER FAULT
291	24-Jan-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITGUPPA_110, KORWARTEMPLE_110	8:30	8:38	0:08	LINE FAULT
292	24-Jan-2020	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	6:18	6:45	0:27	LINE FAULT
293	24-Jan-2020	GULBARGA	220	KUSTIGI-ODPWIND	ODPWIND-IPP	8:10	21:40	13:30	LINE CLEAR AVAILED
294	24-Jan-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	3:10	3:33	0:23	LINE FAULT
295	24-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	4:15	4:23	0:08	LINE FAULT
296	24-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSAGI_110,ASKI_110	5:50	5:57	0:07	LINE FAULT
297	24-Jan-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110	22:50	22:58	0:08	LINE FAULT
298	24-Jan-2020	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	22:50	22:58	0:08	LINE FAULT
299	24-Jan-2020	GULBARGA	66	HV1	HANASI_66	15:30	15:50	0:20	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
300	24-Jan-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1,2	HIREHADAGALI_66,GIRIYAPURA_66,SO VENAHALLI_66,TUNGABHADRA,MAGA L_66	18:26	18:35	0:09	LINE FAULT
301	24-Jan-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA-400	13:41	14:40	0:59	LINE CLEAR AVAILED
302	24-Jan-2020	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	9:41	17:34	7:53	LINE CLEAR AVAILED
303	24-Jan-2020	HASSAN	220	TALAGU-SGS2	TALAGUPPA-400	9:40	17:34	7:54	LINE CLEAR AVAILED
304	24-Jan-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	14:50	16:24	1:34	LINE CLEAR AVAILED
305	24-Jan-2020	HASSAN	110	HV1	SAGARA_110	2:25	6:10	3:45	TRANSFORMER FAULT
306	24-Jan-2020	HASSAN	110	HV2	SAGARA_110	19:00	19:05	0:05	HAND TRIPPED
307	24-Jan-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:35	15:53	3:18	LINE CLEAR AVAILED
308	24-Jan-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	8:14	8:19	0:05	TRANSFORMER FAULT
309	24-Jan-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	12:11	13:02	0:51	LINE CLEAR AVAILED
310	24-Jan-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	10:32	10:59	0:27	LINE CLEAR AVAILED
311	24-Jan-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	11:11	14:07	2:56	LINE CLEAR AVAILED
312	24-Jan-2020	MYSORE	66	HV1	BETTADHAPURA_66	16:43	18:00	1:17	LINE CLEAR AVAILED
313	24-Jan-2020	MYSORE	66	HV2	COWDALLI_66	12:29	12:45	0:15	TRANSFORMER FAULT
314	24-Jan-2020	MYSORE	66	HV2	COWDALLI_66	12:54	13:00	0:05	TRANSFORMER FAULT
315	24-Jan-2020	MYSORE	66	HANNUR-COWDALLI	COWDALLI_66 BANDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	11:40	12:00	0:20	LINE FAULT
316	24-Jan-2020	MYSORE	66	HANNUR-KOTHANUR	HANNUR_66	11:59	12:00	0:01	HAND TRIPPED
317	24-Jan-2020	MYSORE	66	JAKKANAHALLI-NAGMANGLA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	3:00	3:05	0:05	LINE FAULT
318	24-Jan-2020	MYSORE	66	HV1	KADAKOLA_220	12:01	12:07	0:05	TRANSFORMER FAULT
319	24-Jan-2020	MYSORE	220	HV2	KADAKOLA_220	11:09	15:00	3:51	LINE CLEAR AVAILED
320	24-Jan-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	10:48	10:50	0:01	HAND TRIPPED
321	24-Jan-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	12:05	12:17	0:12	HAND TRIPPED
322	24-Jan-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	15:03	15:05	0:01	HAND TRIPPED
323	24-Jan-2020	MYSORE	66	HV1	PANDAVAPURA_66	12:22	12:32	0:10	HAND TRIPPED
324	24-Jan-2020	MYSORE	66	HV2	PANDAVAPURA_66	12:22	12:32	0:10	HAND TRIPPED
325	24-Jan-2020	TUMKUR	110	TR-1	DODDAGUNI_110	9:28	10:15	0:47	TRANSFORMER FAULT
326	24-Jan-2020	TUMKUR	66	TR-2	AVAREGERE_66	11:58	13:53	1:54	LINE CLEAR AVAILED
327	24-Jan-2020	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	11:11	11:21	0:10	HAND TRIPPED
328	24-Jan-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	11:11	11:22	0:10	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
329	24-Jan-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAHALI_66,HALUVAGALU_66,TELAGI_66	11:11	11:29	0:18	HAND TRIPPED
330	25-Jan-2020	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	9:08	19:02	9:54	LINE CLEAR AVAILED
331	25-Jan-2020	BAGALKOT	220	CHIKKODI-TALANDAGE	CHIKKODI_220	10:28	19:54	9:26	LINE CLEAR AVAILED
332	25-Jan-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	22:07	22:23	0:16	LINE FAULT
333	25-Jan-2020	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	11:36	17:44	6:08	LINE CLEAR AVAILED
334	25-Jan-2020	BAGALKOT	110	HAVERI-TILUVALLI	TILUVALLI_110	15:15	15:33	0:18	HAND TRIPPED
335	25-Jan-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	TARIHAL_110	9:40	21:10	11:30	LINE CLEAR AVAILED
336	25-Jan-2020	BAGALKOT	110	ENERCON1&2-SOUDATTI	SOUDATTI_110	12:19	12:24	0:05	LINE FAULT
337	25-Jan-2020	BAGALKOT	110	110/11KV,HV1	SOUDATTI_110	12:19	12:22	0:03	TRANSFORMER FAULT
338	25-Jan-2020	BAGALKOT	220	220/110KV,HV1	SIRSI_220	11:21	13:40	2:19	LINE CLEAR AVAILED
339	25-Jan-2020	BAGALKOT	110	RANEENNUR220-HIREKERUR	HIREKERUR_110	15:04	15:19	0:15	LINE FAULT
340	25-Jan-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	0:00	11:40	11:40	LINE CLEAR AVAILED
341	25-Jan-2020	BAGALKOT	220	220/110KV,HV1&LV1	NARENDRA_220	9:27	14:20	4:53	LINE CLEAR AVAILED
342	25-Jan-2020	BAGALKOT	220	220/110KV,HV2&LV2	NARENDRA_220	14:26	19:45	5:19	LINE CLEAR AVAILED
343	25-Jan-2020	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	10:17	10:28	0:11	TRANSFORMER FAULT
344	25-Jan-2020	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	6:08	6:16	0:08	LINE FAULT
345	25-Jan-2020	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	11:31	23:59	12:28	LINE CLEAR AVAILED
346	25-Jan-2020	BAGALKOT	110	ITNAL-RAIBAG1&2	RAIBAG_110	11:12	18:56	7:44	LINE CLEAR AVAILED
347	25-Jan-2020	BAGALKOT	110	HIREKERUR-SHRLKP(BELLIGAVI)	BELLIGAVI_110	12:32	12:48	0:16	HAND TRIPPED
348	25-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGAR, GRINDWELL (EHT)	8:28	8:52	0:23	LINE FAULT
349	25-Jan-2020	BENGALURU	66	HV2	HAL 220	10:20	11:01	0:41	LINE CLEAR AVAILED
350	25-Jan-2020	BENGALURU	66	HV1	DEVARBEESANAHALLI	11:05	11:30	0:25	LINE CLEAR AVAILED
351	25-Jan-2020	BENGALURU	66	DB PURA 220 - CB PURA 1	CB PURA I/A, NALLIMARADANAHALLI, CB PURA URBAN	7:53	8:05	0:12	LINE FAULT
352	25-Jan-2020	BENGALURU	66	DB PURA 220 - CB PURA 2	TUBUGERE	7:53	8:05	0:12	LINE FAULT
353	25-Jan-2020	BENGALURU	66	HV3	CB PURA I/A	7:53	8:36	0:43	MAIN SUPPLY FAILURE
354	25-Jan-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:04	11:11	0:07	LINE FAULT
355	25-Jan-2020	BENGALURU	66	HV1	VIJAYANAGARA	18:13	18:23	0:10	LOAD CHANGEOVER
356	25-Jan-2020	BENGALURU	66	HV1	VIJAYANAGARA	19:44	19:52	0:08	LOAD CHANGEOVER
357	25-Jan-2020	BENGALURU	66	HV1	PATHPALYA	11:01	11:10	0:09	TRANSFORMER FAULT
358	25-Jan-2020	BENGALURU	66	HV2	SARJAPURA	9:45	10:48	1:03	TRANSFORMER FAULT
359	25-Jan-2020	BENGALURU	220	HV2	HSR 220	11:24	11:30	0:06	LOAD CHANGEOVER
360	25-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	11:22	11:38	0:16	LOAD CHANGEOVER
361	25-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - ELECTRONIC CITY PH2 SEC-1	ELECTRONIC CITY PH2 SEC-1	11:20	11:37	0:17	LOAD CHANGEOVER
362	25-Jan-2020	GULBARGA	110	SINDHANOOOR-NIRLOOTI	NIRLOOTI_IPP	1:48	4:10	2:22	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
363	25-Jan-2020	GULBARGA	110	HV2	HATTI_110	6:25	6:28	0:03	TRANSFORMER FAULT
364	25-Jan-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	15:34	16:02	0:28	LINE FAULT
365	25-Jan-2020	HASSAN	110	KVOOR-BAIKAMPADI	KAVOOR_220	9:40	12:10	2:30	LINE CLEAR AVAILED
366	25-Jan-2020	HASSAN	110	HV2	SAGARA_110	16:15	16:25	0:10	HAND TRIPPED
367	25-Jan-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	10:12	10:32	0:20	LINE FAULT
368	25-Jan-2020	HASSAN	66	HV1	SAKLESH PURA_66	8:12	8:22	0:10	TRANSFORMER FAULT
369	25-Jan-2020	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	1:10	14:25	13:15	LINE FAULT
370	25-Jan-2020	MYSORE	66	HV1	BETTADHAPURA_66	14:31	16:17	1:46	LINE CLEAR AVAILED
371	25-Jan-2020	MYSORE	66	HV1	BETTADHAPURA_66	16:57	18:39	1:42	LINE CLEAR AVAILED
372	25-Jan-2020	MYSORE	66	HV2	JYOTHINAGARA_66	11:17	12:17	1:00	LINE CLEAR AVAILED
373	25-Jan-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	21:10	22:18	1:08	LINE FAULT
374	25-Jan-2020	TUMKUR	66	TR-2	BENNEHALLI_66	22:33	22:40	0:06	TRANSFORMER FAULT
375	25-Jan-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	18:00	18:15	0:14	LINE CLEAR AVAILED
376	26-Jan-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	1:36	1:51	0:15	LINE FAULT
377	26-Jan-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	2:53	10:52	7:59	LINE FAULT
378	26-Jan-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	12:48	14:47	1:59	LINE CLEAR AVAILED
379	26-Jan-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	14:49	15:47	0:58	LINE FAULT
380	26-Jan-2020	BAGALKOT	220	220/110KV,HV2 & LV2	MAHALINGAPUR_220,TERDAL_110,DA VALESHWARA_110	14:57	15:25	0:28	TRANSFORMER FAULT
381	26-Jan-2020	BAGALKOT	220	220/110KV,HV1 & LV1	MAHALINGAPUR_220,BANAHATTI_110 ,RANNABELAGALI_110	14:57	15:40	0:43	TRANSFORMER FAULT
382	26-Jan-2020	BAGALKOT	110	MAHALINGAPUR-GSML2	MAHALINGAPUR_220	15:19	15:40	0:21	LINE FAULT
383	26-Jan-2020	BAGALKOT	110	MAHALINGAPUR-GSML1	MAHALINGAPUR_220	14:57	16:18	1:21	LINE FAULT
384	26-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGAR, GRINDWELL (EHT)	11:01	11:57	0:56	LINE CLEAR AVAILED
385	26-Jan-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TEC PARK, GTRE(EHT)	20:15	21:31	1:16	LINE FAULT
386	26-Jan-2020	BENGALURU	66	HV2	THIMAMPALLI	11:36	11:55	0:19	TRANSFORMER FAULT
387	26-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - ELECTRONIC CITY PH2 SEC-1	ELECTRONIC CITY PH2 SEC-1	10:25	10:37	0:12	LOAD CHANGE OVER
388	26-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	10:26	10:38	0:12	LOAD CHANGE OVER
389	26-Jan-2020	BENGALURU	220	HV2	HSR 220	10:27	10:36	0:09	LOAD CHANGE OVER
390	26-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - ELECTRONIC CITY PH2 SEC-1	ELECTRONIC CITY PH2 SEC-1	14:10	14:20	0:10	LOAD CHANGE OVER
391	26-Jan-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	14:11	14:21	0:10	LOAD CHANGE OVER
392	26-Jan-2020	BENGALURU	220	HV2	HSR 220	14:12	14:19	0:07	LOAD CHANGE OVER
393	26-Jan-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	8:53	9:17	0:24	HAND TRIPPED
394	26-Jan-2020	HASSAN	110	HV2	BAIKAMPADI_110	12:01	12:21	0:20	LINE CLEAR AVAILED
395	26-Jan-2020	HASSAN	110	HV3	BAIKAMPADI_110	11:06	12:10	1:04	LINE CLEAR AVAILED
396	26-Jan-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	2:32	2:38	0:06	LINE FAULT
397	26-Jan-2020	HASSAN	66	HV2	MATTNIVILE_66	9:07	12:02	2:55	LINE CLEAR AVAILED
398	26-Jan-2020	HASSAN	66	HV1	SAKLESH PURA_66	5:31	5:41	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
399	26-Jan-2020	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	17:50	17:58	0:08	LINE FAULT
400	26-Jan-2020	MYSORE	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI	23:42	23:47	0:04	HAND TRIPPED
401	26-Jan-2020	MYSORE	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	18:23	18:32	0:09	LINE FAULT
402	26-Jan-2020	MYSORE	66	MADHUVANAHALLY-MAMBALLY	MAMBALLI_66	18:05	18:09	0:03	LINE FAULT
403	26-Jan-2020	TUMKUR	220	TR-2(HV SIDE)	NEELAGUNDA_220	11:05	11:20	0:15	TRANSFORMER FAULT
404	26-Jan-2020	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	11:36	12:16	0:40	TRANSFORMER FAULT
405	26-Jan-2020	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	4:25	6:14	1:49	MAIN SUPPLY FAILURE
406	26-Jan-2020	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	4:25	6:14	1:49	MAIN SUPPLY FAILURE
407	27-Jan-2020	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	16:11	17:13	1:02	TRANSFORMER FAULT
408	27-Jan-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	9:39	18:58	9:19	LINE CLEAR AVAILED
409	27-Jan-2020	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR_110	11:58	12:15	0:17	LINE CLEAR AVAILED
410	27-Jan-2020	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	3:46	10:12	6:26	TRANSFORMER FAULT
411	27-Jan-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	11:37	16:05	4:28	LINE CLEAR AVAILED
412	27-Jan-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:04	15:15	5:11	LINE CLEAR AVAILED
413	27-Jan-2020	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	8:47	23:59	15:12	NFBC ISSUED
414	27-Jan-2020	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	14:12	14:31	0:19	LINE CLEAR AVAILED
415	27-Jan-2020	BAGALKOT	110	CHIKKODI220-DKSS COGEN	CHIKKODI_220	20:52	21:34	0:42	LINE FAULT
416	27-Jan-2020	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	12:54	13:23	0:29	LINE CLEAR AVAILED
417	27-Jan-2020	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	13:25	17:20	3:55	LINE CLEAR AVAILED
418	27-Jan-2020	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	15:23	16:09	0:46	LINE CLEAR AVAILED
419	27-Jan-2020	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	16:11	17:31	1:20	LINE CLEAR AVAILED
420	27-Jan-2020	BAGALKOT	220	LINGASUR2-BAGEWADI	BAGEWADI_220	10:35	18:05	7:30	LINE CLEAR AVAILED
421	27-Jan-2020	BAGALKOT	220	ADPH1-BAGEWADI	BAGEWADI_220	12:00	13:05	1:05	LINE CLEAR AVAILED
422	27-Jan-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	12:05	13:15	1:10	LINE CLEAR AVAILED
423	27-Jan-2020	BAGALKOT	220	ATRIYA-BAGEWADI	BAGEWADI_220	12:05	13:15	1:10	LINE CLEAR AVAILED
424	27-Jan-2020	BAGALKOT	220	BIJAPUR1-BAGEWADI	BAGEWADI_220	12:05	13:15	1:10	LINE CLEAR AVAILED
425	27-Jan-2020	BAGALKOT	220	LINGASUR1-BAGEWADI	BAGEWADI_220	11:15	14:25	3:10	LINE FAULT
426	27-Jan-2020	BAGALKOT	110	BAGEWADI-MAMDAPUR1&2	MAMADAPUR(B)_110	12:05	13:15	1:10	LINE CLEAR AVAILED
427	27-Jan-2020	BAGALKOT	110	BAGEWADI-ACHANUR(MUDDEBIHAL)	MUDDEBIHAL_110	12:05	13:15	1:10	LINE CLEAR AVAILED
428	27-Jan-2020	BAGALKOT	110	BAGEWADI-RAMPUR (NIDAGUNDI)	NIDAGUNDI_110	12:05	13:15	1:10	LINE CLEAR AVAILED
429	27-Jan-2020	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	12:05	13:15	1:10	LINE CLEAR AVAILED
430	27-Jan-2020	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	3:32	9:49	6:17	LINE CLEAR AVAILED
431	27-Jan-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	15:53	16:45	0:52	TRANSFORMER FAULT
432	27-Jan-2020	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	1:03	1:10	0:07	LINE FAULT
433	27-Jan-2020	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	2:19	14:43	12:24	LINE FAULT
434	27-Jan-2020	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	11:05	13:55	2:50	LINE CLEAR AVAILED
435	27-Jan-2020	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	11:05	15:00	3:55	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
436	27-Jan-2020	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110	11:05	14:05	3:00	LINE CLEAR AVAILED
437	27-Jan-2020	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	6:38	6:57	0:19	TRANSFORMER FAULT
438	27-Jan-2020	BAGALKOT	110	HUBLI-NARENDRA1	HUBLI_220	12:46	13:14	0:28	LINE CLEAR AVAILED
439	27-Jan-2020	BAGALKOT	110	RANEENNUR220-RATTIHALLI (TUMMINKATTI)	TUMMINKATTI_110	16:30	17:23	0:53	LINE CLEAR AVAILED
440	27-Jan-2020	BAGALKOT	110	BALAJI SUGAR-MUDDEBIHAL	MUDDEBIHAL_110	12:17	13:42	1:25	MAIN SUPPLY FAILURE
441	27-Jan-2020	BAGALKOT	110	110/11KV,HV3	MUDALAGI_110	15:50	16:21	0:31	LINE CLEAR AVAILED
442	27-Jan-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	14:00	14:04	0:04	HAND TRIPPED
443	27-Jan-2020	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	15:28	17:02	1:34	LINE CLEAR AVAILED
444	27-Jan-2020	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	16:59	17:26	0:27	LINE CLEAR AVAILED
445	27-Jan-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)-KADANKOPPA	KADANKOPPA_110	10:41	10:46	0:05	LINE CLEAR AVAILED
446	27-Jan-2020	BAGALKOT	110	110/11KV, HV3	JAMKHANDI_110	5:29	11:27	5:58	LINE CLEAR AVAILED
447	27-Jan-2020	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	13:36	14:01	0:25	LINE CLEAR AVAILED
448	27-Jan-2020	BENGALURU	66	HV2	THIMMAMPALLI	15:30	16:52	1:22	LINE CLEAR AVAILED
449	27-Jan-2020	BENGALURU	66	HV1	THIMMAMPALLI	13:30	14:30	1:00	LINE CLEAR AVAILED
450	27-Jan-2020	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	9:26	17:53	8:27	LINE CLEAR AVAILED
451	27-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MASTHI, DEVANAGONDI, LAKKUR	17:04	17:07	0:03	LINE FAULT
452	27-Jan-2020	BENGALURU	66	KOLAR 220 - PGCIL	SUGUTUR, S M MANGALA	9:25	9:35	0:10	LOAD CURTAILMENT
453	27-Jan-2020	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	11:09	15:05	3:56	TRANSFORMER FAULT
454	27-Jan-2020	BENGALURU	66	HV2	HOSKOTE 66	19:26	19:43	0:17	TRANSFORMER FAULT
455	27-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGARA, HENNUR CROSS, GRIND WELL (EHT)	14:43	15:02	0:19	MAIN SUPPLY FAILURE
456	27-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	14:43	15:02	0:19	MAIN SUPPLY FAILURE
457	27-Jan-2020	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	14:43	15:02	0:19	MAIN SUPPLY FAILURE
458	27-Jan-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	14:43	15:02	0:19	MAIN SUPPLY FAILURE
459	27-Jan-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	14:43	15:02	0:19	MAIN SUPPLY FAILURE
460	27-Jan-2020	BENGALURU	220	BEGUR 220 - HOODY 220	BEGUR 220	14:42	15:59	1:17	LINE FAULT
461	27-Jan-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	14:42	14:58	0:16	MAIN SUPPLY FAILURE
462	27-Jan-2020	BENGALURU	220	BEGUR 220 - DB PURA 220	BEGUR 220	14:42	14:53	0:11	MAIN SUPPLY FAILURE
463	27-Jan-2020	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	14:42	14:53	0:11	MAIN SUPPLY FAILURE
464	27-Jan-2020	BENGALURU	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	14:42	14:53	0:11	MAIN SUPPLY FAILURE
465	27-Jan-2020	BENGALURU	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	14:42	14:53	0:11	MAIN SUPPLY FAILURE
466	27-Jan-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	14:42	14:53	0:11	MAIN SUPPLY FAILURE
467	27-Jan-2020	BENGALURU	220	HOODY 220 - BEGUR 220	BEGUR 220	14:42	15:59	1:17	LINE FAULT
468	27-Jan-2020	BENGALURU	66	HV1	POTTERY ROAD	21:15	22:02	0:47	TRANSFORMER FAULT
469	27-Jan-2020	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI2_220	10:11	18:05	7:54	NFBC ISSUED
470	27-Jan-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	1:24	1:30	0:06	LINE FAULT
471	27-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNAL_IPP	4:44	4:53	0:09	LINE FAULT
472	27-Jan-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	6:10	6:17	0:07	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
473	27-Jan-2020	GULBARGA	110	HV2	YELBURGA_110	8:05	8:20	0:15	TRANSFORMER FAULT
474	27-Jan-2020	GULBARGA	110	KUDTINI-BELLARY	KUDITINI_110,TORANGALLU_110	9:05	12:45	3:40	MAIN SUPPLY FAILURE
475	27-Jan-2020	GULBARGA	110	HV4	KUSTIGI_110	16:21	23:59	7:38	TRANSFORMER FAULT
476	27-Jan-2020	GULBARGA	110	KEMBHAVI-UGARSUGAR	UGARSUGAR_IPP	19:40	19:45	0:05	LINE FAULT
477	27-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSAGI_110,ASKI_110	19:41	19:51	0:10	LINE FAULT
478	27-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSAGI_110,ASKI_110	19:59	20:07	0:08	LINE FAULT
479	27-Jan-2020	GULBARGA	110	KEMBHAVI-UGARSUGAR	UGARSUGAR_IPP	20:00	20:40	0:40	LINE FAULT
480	27-Jan-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	21:39	21:50	0:11	LINE FAULT
481	27-Jan-2020	GULBARGA	110	MALLA-BYAGAWAT2	MADAPUR_110,MANVI_110	22:22	22:27	0:05	LINE FAULT
482	27-Jan-2020	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	6:34	9:33	2:59	LINE CLEAR AVAILED
483	27-Jan-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	11:25	23:59	12:34	LINE CLEAR AVAILED
484	27-Jan-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:49	13:13	0:24	LINE FAULT
485	27-Jan-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	2:07	16:40	14:33	LINE CLEAR AVAILED
486	27-Jan-2020	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	12:49	13:13	0:24	LINE FAULT
487	27-Jan-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	2:04	16:41	14:37	NFBC ISSUED
488	27-Jan-2020	HASSAN	220	HASSN22-HASSAN	HASSAN_220	9:40	9:45	0:05	HAND TRIPPED
489	27-Jan-2020	HASSAN	220	HASSN22-PGCL	HASSAN_220	10:15	15:10	4:55	LINE CLEAR AVAILED
490	27-Jan-2020	HASSAN	220	HV2	HASSAN_220	10:17	16:27	6:10	LINE CLEAR AVAILED
491	27-Jan-2020	HASSAN	220	HASSN22-UDDUR	HASSAN_220	10:16	16:37	6:21	LINE CLEAR AVAILED
492	27-Jan-2020	HASSAN	220	HASSN22-BELUR	HASSAN_220	10:15	15:37	5:22	LINE CLEAR AVAILED
493	27-Jan-2020	HASSAN	220	HASSN22-SUZLON	HASSAN_220	10:19	10:59	0:40	HAND TRIPPED
494	27-Jan-2020	HASSAN	220	HASSN22-UDDURKOPLU	HASSAN_220	15:27	15:36	0:09	HAND TRIPPED
495	27-Jan-2020	HASSAN	220	HV2	AJJAMPURA_110	9:56	11:40	1:44	LINE CLEAR AVAILED
496	27-Jan-2020	HASSAN	220	BANTWA-KAVOOR	BANTWAL_110	11:36	11:41	0:05	HAND TRIPPED
497	27-Jan-2020	HASSAN	220	BARANG-ANVATTI	BARANGI_110	15:16	16:12	0:56	LINE CLEAR AVAILED
498	27-Jan-2020	HASSAN	220	HV1	BIRUR_110	12:13	14:12	1:59	LINE CLEAR AVAILED
499	27-Jan-2020	HASSAN	220	HV2	BIRUR_110	12:13	14:12	1:59	LINE CLEAR AVAILED
500	27-Jan-2020	HASSAN	220	KAVOOR-AMR	KAVOOR_220	11:38	11:41	0:03	HAND TRIPPED
501	27-Jan-2020	HASSAN	220	HV1	BALLUPETE_66	10:05	14:00	3:55	LINE CLEAR AVAILED
502	27-Jan-2020	HASSAN	220	HV1	HIRISAVE_66	9:22	9:38	0:16	TRANSFORMER FAULT
503	27-Jan-2020	HASSAN	220	RMWNGR-SHANTI	RAMESHWARNAGAR_66	9:47	9:52	0:05	HAND TRIPPED
504	27-Jan-2020	HASSAN	220	RMWNGR-SHANTI	RAMESHWARNAGAR_66	16:27	16:46	0:19	HAND TRIPPED
505	27-Jan-2020	HASSAN	220	HV1	SAKLESH PURA_66	11:49	15:12	3:23	LINE CLEAR AVAILED
506	27-Jan-2020	HASSAN	220	HV1	TAVARECHANAHALLI_66	14:13	23:59	9:46	LINE CLEAR AVAILED
507	27-Jan-2020	HASSAN	220	UDDURKO-SUZLON	UDDURKOPLU_66	10:51	11:03	0:12	MAIN SUPPLY FAILURE
508	27-Jan-2020	HASSAN	220	UDDURKO-UDDUR	UDDURKOPLU_66	10:51	15:38	4:47	MAIN SUPPLY FAILURE
509	27-Jan-2020	HASSAN	220	UDDURKO-NITTUR1	UDDURKOPLU_66	10:20	11:12	0:52	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
510	27-Jan-2020	HASSAN	220	UDDURKO-NITTUR2	UDDURKOPLU_66	10:20	11:12	0:52	MAIN SUPPLY FAILURE
511	27-Jan-2020	HASSAN	220	KIADBH-RAMESWARNAGAR	KIADB_66	9:37	16:43	7:06	LINE CLEAR AVAILED
512	27-Jan-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:32	6:37	0:04	LINE FAULT
513	27-Jan-2020	MYSORE	66	HV1	COWDALLI_66	17:29	19:23	1:54	LINE CLEAR AVAILED
514	27-Jan-2020	MYSORE	66	HV1	DATTAGALLY_66	11:33	12:00	0:26	LINE CLEAR AVAILED
515	27-Jan-2020	MYSORE	66	DEVNUR(N'GUD)-KADKOLA	DEVANOORNGUDU_66 SUTTUR_66	6:42	7:03	0:20	LINE FAULT
516	27-Jan-2020	MYSORE	66	HV1	DODDINADUVADI_66	8:58	11:26	2:27	LINE CLEAR AVAILED
517	27-Jan-2020	MYSORE	66	HV1	DODDINADUVADI_66	17:03	20:54	3:51	LINE CLEAR AVAILED
518	27-Jan-2020	MYSORE	66	HV2	DODDINADUVADI_66	8:58	9:38	0:39	LINE CLEAR AVAILED
519	27-Jan-2020	MYSORE	66	HV2	DODDINADUVADI_66	11:21	17:02	5:40	LINE CLEAR AVAILED
520	27-Jan-2020	MYSORE	66	HV1	DODDARAYAPET_66	16:29	19:31	3:01	LINE CLEAR AVAILED
521	27-Jan-2020	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:39	15:09	3:29	LINE CLEAR AVAILED
522	27-Jan-2020	MYSORE	66	HV1	HOOTAGALLY_220	20:38	21:14	0:35	HAND TRIPPED
523	27-Jan-2020	MYSORE	66	HV1	HOOTAGALLY_220	21:14	21:21	0:06	HAND TRIPPED
524	27-Jan-2020	MYSORE	66	HV1	PONNAMPET_66	16:25	16:50	0:24	LINE CLEAR AVAILED
525	27-Jan-2020	MYSORE	66	HV1	SFCSHIVA_66	12:25	12:29	0:04	HAND TRIPPED
526	27-Jan-2020	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	13:30	17:20	3:49	LINE CLEAR AVAILED
527	27-Jan-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	13:40	16:57	3:16	LINE CLEAR AVAILED
528	27-Jan-2020	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	11:26	20:05	8:39	LINE CLEAR AVAILED
529	27-Jan-2020	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	13:41	17:02	3:21	NFBC ISSUED
530	27-Jan-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110,	0:17	0:32	0:15	LINE FAULT
531	27-Jan-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	7:14	7:27	0:13	LINE FAULT
532	27-Jan-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:56	12:19	0:23	HAND TRIPPED
533	27-Jan-2020	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	12:30	12:48	0:18	LINE FAULT
534	27-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	19:10	20:24	1:14	LINE FAULT
535	27-Jan-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	11:49	12:02	0:12	LINE CLEAR AVAILED
536	27-Jan-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	16:15	17:53	1:37	LINE CLEAR AVAILED
537	27-Jan-2020	TUMKUR	66	TR-1	LINGADAHALLY_66	14:07	14:27	0:20	TRANSFORMER FAULT
538	27-Jan-2020	TUMKUR	66	TR1	MATHOD_66	17:10	17:28	0:17	TRANSFORMER FAULT
539	27-Jan-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDU RGA_66,JAGALUR_66,PALLAGATTE_66	6:14	6:34	0:20	LINE FAULT
540	27-Jan-2020	TUMKUR	66	TR-1	SHYLAPURA_66	8:07	9:37	1:29	LINE CLEAR AVAILED
541	27-Jan-2020	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	12:30	12:52	0:22	MAIN SUPPLY FAILURE
542	27-Jan-2020	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	12:30	12:52	0:22	MAIN SUPPLY FAILURE
543	27-Jan-2020	TUMKUR	66	TR-1	VENKATAPURA_66	7:10	7:20	0:10	TRANSFORMER FAULT