

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 05.05.2020 to 11.05.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	5-May-20	BAGALKOT	110	110//11KV,HV 1	KHANAPUR_110	23:24	23:51	0:27	HAND TRIPPED
2	5-May-20	BAGALKOT	110	110/11KV, HV1	YELPARAHATTI_110	10:05	10:25	0:20	HAND TRIPPED
3	5-May-20	BAGALKOT	110	110/11KV, HV1	YELPARAHATTI_110	10:42	10:49	0:07	HAND TRIPPED
4	5-May-20	BAGALKOT	110	110/11KV, HV2	UTTUR_110, YADAWAD_33, VANTAGODI_33	14:42	14:47	0:05	TRANSFORMER FAULT
5	5-May-20	BAGALKOT	110	110/11KV,HV2	AIGALI_110	13:07	17:08	4:01	LINE CLEAR AVAILED
6	5-May-20	BAGALKOT	110	110/33KV ,HV4	ZALAKI_110, NEVARAGI_33,DHULKHED_33,HALAS ANGI_33	8:34	8:39	0:05	TRANSFORMER FAULT
7	5-May-20	BAGALKOT	110	110/33KV ,HV4	ZALAKI_110, NEVARAGI_33,DHULKHED_33,HALAS ANGI_33	10:42	10:50	0:08	TRANSFORMER FAULT
8	5-May-20	BAGALKOT	110	110/33KV ,HV4	ZALAKI_110, NEVARAGI_33,DHULKHED_33,HALAS ANGI_33	15:24	15:28	0:04	TRANSFORMER FAULT
9	5-May-20	BAGALKOT	110	110/33KV ,HV4	ZALAKI_110, NEVARAGI_33,DHULKHED_33,HALAS ANGI_33	16:04	16:08	0:04	TRANSFORMER FAULT
10	5-May-20	BAGALKOT	110	110/33KV ,HV4	ZALAKI_110, NEVARAGI_33,DHULKHED_33,HALAS ANGI_33	16:41	16:45	0:04	TRANSFORMER FAULT
11	5-May-20	BAGALKOT	110	110/33KV ,HV4	ZALAKI_110, NEVARAGI_33,DHULKHED_33,HALAS ANGI_33	16:57	17:04	0:07	TRANSFORMER FAULT
12	5-May-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110	5:33(29.4.20)			LINE IS OPEN: LINE CLEAR AVAILED
13	5-May-20	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	10:10	18:26	8:16	LINE CLEAR AVAILED
14	5-May-20	BAGALKOT	110	HIDIKAL-RAIBAG(ITANAL)	ITANAL_110	10:01			LINE IS OPEN: LINE CLEAR AVAILED
15	5-May-20	BAGALKOT	110	MAHALINAPUR-HIDIKAL	HIDIKAL_110	9:28	10:07	0:39	HAND TRIPPED
16	5-May-20	BAGALKOT	110	MAHALINAPUR-TERDAL	TERDAL_110	9:21	9:41	0:20	LINE FAULT
17	5-May-20	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	16:23 (04.05.2020)	13:44	21:21hrs	LINE CHARGED
18	5-May-20	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	9:52	13:44	3:52	NFBC ISSUED
19	5-May-20	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	14:08	14:09	0:01	HAND TRIPPED
20	5-May-20	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	14:51	15:06	0:15	HAND TRIPPED
21	5-May-20	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220	9:21	9:38	0:17	TRANSFORMER FAULT
22	5-May-20	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	14:44			LINE IS OPEN: LINE FAULT
23	5-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	9:15			LINE IS OPEN: LINE CLEAR AVAILED
24	5-May-20	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	18:57 (03.05.2020)	8:30	37:33:00	LINE CHARGED
25	5-May-20	BAGALKOT	220	GADAG-LINGAPUR2(DHONI2)	GADAG_220	18:49			LINE IS OPEN: LINE CLEAR AVAILED
26	5-May-20	BAGALKOT	220	HAVERI220-NARENDRA2	HAVERI_220	10:46	17:35	6:49	LINE CLEAR AVAILED
27	5-May-20	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	15:11	16:02	0:51	LINE FAULT
28	5-May-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	13:37	17:05	3:28	LINE FAULT
29	5-May-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	14:05	20:27	6:22	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	5-May-20	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	14:46	15:55	1:09	LINE CLEAR AVAILED
31	5-May-20	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	15:20	15:42	0:22	LINE FAULT
32	5-May-20	BAGALKOT	220	SIRSI220-SARAVATHI1	SIRSI_220	15:54 (03.05.2020)	14:35	46:41hrs	LINE CHARGED
33	5-May-20	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	7:23	11:38	4:15	LINE CLEAR AVAILED
34	5-May-20	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	14:02	15:31	1:29	LINE CLEAR AVAILED
35	5-May-20	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	23:55			LINE IS OPEN: LINE FAULT
36	5-May-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	5:35	5:41	0:06	LINE FAULT
37	5-May-20	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	14:05	15:10	1:05	LINE CLEAR AVAILED
38	5-May-20	BENGALURU	66	GANJIGUNTE - PALLICHERLU	PALLICHERLU	13:35	15:00	1:25	LINE CLEAR AVAILED
39	5-May-20	BENGALURU	66	HV1	CHATRA	13:54	14:05	0:11	LINE CLEAR AVAILED
40	5-May-20	BENGALURU	66	HV1	CHAKAVELU	23:55(5.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
41	5-May-20	BENGALURU	66	HV1	KYALANUR	10:35	11:20	0:44	LINE CLEAR AVAILED
42	5-May-20	BENGALURU	66	HV2	R R NAGAR	10:29	10:35	0:06	LINE CLEAR AVAILED
43	5-May-20	BENGALURU	66	HV3	HEBBALA 220	14:19	14:25	0:06	TRANSFORMER FAULT
44	5-May-20	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	14:02	16:22	2:20	LINE CLEAR AVAILED
45	5-May-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:30	22:41	0:11	LINE FAULT
46	5-May-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	10:35	10:38	0:03	LOAD CHANGE OVER
47	5-May-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:50	16:56	0:06	LOAD CHANGE OVER
48	5-May-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:36	10:40	0:04	LOAD CHANGE OVER
49	5-May-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:50	16:56	0:05	LOAD CHANGE OVER
50	5-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:03	18:09	0:05	LINE FAULT
51	5-May-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:35	10:38	0:02	LOAD CHANGE OVER
52	5-May-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:50	16:56	0:06	LOAD CHANGE OVER
53	5-May-20	BENGALURU	66	PALLICHERLU - GANJIGUNTE	PALLICHERLU	15:15	16:00	0:45	LINE CLEAR AVAILED
54	5-May-20	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	5:35	5:46	0:10	LINE FAULT
55	5-May-20	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	16:23	16:32	0:09	LOAD CHANGE OVER
56	5-May-20	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	14:05	15:05	1:00	LINE CLEAR AVAILED
57	5-May-20	BENGALURU	66	TUBUGERE - D B PURA 220	TUBUGERE	9:02	14:45	5:43	LINE CLEAR AVAILED
58	5-May-20	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	9:35	9:40	0:05	LOAD CHANGE OVER
59	5-May-20	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	18:25	18:29	0:04	LOAD CHANGE OVER
60	5-May-20	BENGALURU	220	HV2	MALUR 220	10:36	16:54	6:18	LINE CLEAR AVAILED
61	5-May-20	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	14:02	16:05	2:03	LINE CLEAR AVAILED
62	5-May-20	GULBARGA	66	KOGALI-ITTAGI	KOGALI_66, KUDLIGI_66,HANASI_66	10:35	11:05	0:30	LINE CLEAR AVAILED
63	5-May-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_110,KAMALAPUR_110, METRI_110, RBNS SUGARS	4:57	5:05	0:08	LINE FAULT
64	5-May-20	GULBARGA	110	HV1	MANVI_110	13:00	13:10	0:10	TRANSFORMER FAULT
65	5-May-20	GULBARGA	110	HV2	DEODURGA_110	16:15	16:25	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
66	5-May-20	GULBARGA	110	HV3	MANTHAL_110	16:00	16:05	0:05	TRANSFORMER FAULT
67	5-May-20	GULBARGA	110	HV3	BEVOOR_110	10:21	11:07	0:46	LINE CLEAR AVAILED
68	5-May-20	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110	0:02	0:07	0:05	LINE FAULT
69	5-May-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	21:07	21:18	0:11	LINE FAULT
70	5-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.20)			LINE IS OPEN: LINE FAULT
71	5-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.20)			LINE IS OPEN: LINE FAULT
72	5-May-20	GULBARGA	220	LINGAPUR-BTPSG	BTPS_220	15:41	16:51	1:10	LINE FAULT
73	5-May-20	HASSAN	66	HV1	HANGRANAHALLY_66	10:55	12:43	1:48	LINE CLEAR AVAILED
74	5-May-20	HASSAN	66	HV2	UDAYAPURA_66	17:17	17:44	0:27	TRANSFORMER FAULT
75	5-May-20	HASSAN	66	HV2	UDAYAPURA_66	17:53	17:55	0:02	TRANSFORMER FAULT
76	5-May-20	HASSAN	66	HV2	UDAYAPURA_66	20:14	20:26	0:12	TRANSFORMER FAULT
77	5-May-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:33	8:37	0:04	HAND TRIPPED
78	5-May-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	8:24(4.5.20)	8:24	12:24hrs	LINE CHARGED
79	5-May-20	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:00	17:41	8:41	LINE CLEAR AVAILED
80	5-May-20	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:00	17:41	8:41	LINE CLEAR AVAILED
81	5-May-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	18:50	20:20	1:30	MAIN SUPPLY FAILURE
82	5-May-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	18:12	18:21	0:09	LINE FAULT
83	5-May-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	18:31	18:54	0:23	LINE FAULT
84	5-May-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:11	17:41	0:30	LINE FAULT
85	5-May-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:12	17:39	0:27	MAIN SUPPLY FAILURE
86	5-May-20	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:12	17:44	0:32	MAIN SUPPLY FAILURE
87	5-May-20	HASSAN	110	HV1	BRAHMAVARA_110	9:53	14:48	4:55	LINE CLEAR AVAILED
88	5-May-20	HASSAN	110	HV2	AJJAMPURA_110	12:23	13:31	1:08	LINE CLEAR AVAILED
89	5-May-20	HASSAN	110	HV3	BANTWAL_110	10:29	13:40	3:11	LINE CLEAR AVAILED
90	5-May-20	HASSAN	110	HV3	GURUVAYANAKERE_110	14:16	16:30	2:14	LINE CLEAR AVAILED
91	5-May-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:11	17:42	0:31	LINE FAULT
92	5-May-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:11	17:39	0:28	LINE FAULT
93	5-May-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	11:22	12:13	0:51	LINE CLEAR AVAILED
94	5-May-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:00	17:29	0:29	LINE FAULT
95	5-May-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:54	14:46	4:52	LINE CLEAR AVAILED
96	5-May-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	16:58	18:04	1:06	LINE CLEAR AVAILED
97	5-May-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	16:59	18:03	1:04	LINE CLEAR AVAILED
98	5-May-20	HASSAN	220	HASSN22-Shomoga	HASSAN_220	17:32	18:49	1:17	LINE FAULT
99	5-May-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:55	10:53	0:58	LINE CLEAR AVAILED
100	5-May-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:58	11:33	0:35	LINE CLEAR AVAILED
101	5-May-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:30	18:30	5:00	LINE FAULT
102	5-May-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	18:30			LINE IS OPEN: LINE FAULT
103	5-May-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	3:15(3.5.20)	9:02	33:05hrs	LINE CHARGED
104	5-May-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:55	10:52	0:57	LINE CLEAR AVAILED
105	5-May-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:58	11:33	0:35	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
106	5-May-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:30(5.5.20)			LINE IS OPEN: LINE FAULT
107	5-May-20	MYSORE	66	HUNSUR-HOOTAGALLI	NO STATIONS	9:51	10:00	0:08	LINE FAULT
108	5-May-20	MYSORE	66	HV1	SFCSHIVA_66	10:28	12:09	1:40	LINE CLEAR AVAILED
109	5-May-20	MYSORE	66	HV2	AKKIHEBBAL_66	17:10	17:50	0:39	LINE CLEAR AVAILED
110	5-May-20	MYSORE	66	HV2	MANDYA_66	7:12	8:35	1:23	LINE CLEAR AVAILED
111	5-May-20	MYSORE	66	HV5	SFCSHIVA_66	10:57	17:03	6:05	LINE CLEAR AVAILED
112	5-May-20	MYSORE	66	KADAKOLA-SARGUR 1	HURA_66, HULLAHALLI_66, DOORA_66, CHANDRAWADI, JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66,	11:26	11:31	0:05	LINE FAULT
113	5-May-20	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66, CHANDRAWADI, JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66,	11:26	11:31	0:05	LINE FAULT
114	5-May-20	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66 DMG_HALLI_66	5:55	6:01	0:06	LINE FAULT
115	5-May-20	MYSORE	66	KR NAGARA-MYSORE1	KRNAGARA_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	7:05	7:26	0:20	LINE FAULT
116	5-May-20	MYSORE	66	KR NAGARA-MYSORE1	KRNAGARA_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	8:22	8:37	0:14	LINE FAULT
117	5-May-20	MYSORE	66	KR NAGARA-MYSORE1	KRNAGARA_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	8:46	8:53	0:07	LINE FAULT
118	5-May-20	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	KRNAGARA_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	9:44	11:30	1:45	LINE CLEAR AVAILED
119	5-May-20	MYSORE	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	6:35	6:42	0:06	LINE FAULT
120	5-May-20	MYSORE	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	7:32	11:31	3:58	LINE CLEAR AVAILED
121	5-May-20	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	3:33	3:38	0:04	LINE FAULT
122	5-May-20	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS	17:17	19:53	2:36	LINE FAULT
123	5-May-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	16:06	16:31	0:25	LINE FAULT
124	5-May-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	6:00	7:01	1:01	LINE FAULT
125	5-May-20	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	16:38	16:47	0:08	HAND TRIPPED
126	5-May-20	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	16:38	17:23	0:44	HAND TRIPPED
127	5-May-20	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	23:34	23:48	0:13	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
128	5-May-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:02	17:11	0:09	LINE FAULT
129	5-May-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:16	12:26	0:10	LINE FAULT
130	5-May-20	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	19:22	20:07	0:44	LINE FAULT
131	5-May-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:04	17:11	0:07	LINE FAULT
132	5-May-20	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	5:46	12:05	6:18	LINE FAULT
133	5-May-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	12:36	12:50	0:13	LINE FAULT
134	5-May-20	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	17:29	18:05	0:35	LINE FAULT
135	5-May-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	13:35	13:40	0:05	LINE CLEAR AVAILED
136	5-May-20	TUMKUR	66	TR-1	CHAWANAKUPPE_66	11:03	11:28	0:24	LINE CLEAR AVAILED
137	5-May-20	TUMKUR	66	TR-1	LINGDHALLI_66	18:18	18:22	0:04	TRANSFORMER FAULT
138	5-May-20	TUMKUR	66	TR-1	SASALUHALLA_66	12:22	12:58	0:36	LINE CLEAR AVAILED
139	5-May-20	TUMKUR	66	TR-2	BALENAHALLI_66	20:01	20:10	0:09	TRANSFORMER FAULT
140	5-May-20	TUMKUR	66	VENKATAPURA-PAVAGADA	VENKATAPUR_66	17:29	18:09	0:39	MAIN SUPPLY FAILURE
141	5-May-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	11:28	11:33	0:05	LINE FAULT
142	5-May-20	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	11:28	11:34	0:05	LINE FAULT
143	5-May-20	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	20:22	21:16	0:54	MAIN SUPPLY FAILURE
144	5-May-20	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	20:03	20:57	0:54	LINE CLEAR AVAILED
145	5-May-20	TUMKUR	110	TR-1	BANDIHALLI_110	11:28	11:32	0:04	TRANSFORMER FAULT
146	5-May-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	20:02	21:07	1:04	MAIN SUPPLY FAILURE
147	5-May-20	TUMKUR	110	TR-2	BANDIHALLI_110	11:28	11:32	0:04	TRANSFORMER FAULT
148	5-May-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	20:00	21:09	1:09	MAIN SUPPLY FAILURE
149	6-May-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	23:59(6.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
150	6-May-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	17:41	18:19	0:38	TRANSFORMER FAULT
151	6-May-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	18:39	18:58	0:19	TRANSFORMER FAULT
152	6-May-20	BAGALKOT	110	110/11KV, HV2	RON_110	17:09	18:12	1:03	LINE CLEAR AVAILED
153	6-May-20	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	12:22	12:46	0:24	LINE CLEAR AVAILED
154	6-May-20	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	0:44	0:47	0:03	HAND TRIPPED
155	6-May-20	BAGALKOT	110	110/11KV,HV1	ANKOLA_110,VAJRAKOSH_33, ANKOLA_33	10:11	11:06	0:55	LINE CLEAR AVAILED
156	6-May-20	BAGALKOT	110	110/11KV,HV1	KANABARGI LAY OUT_110	8:25	9:30	1:05	LINE CLEAR AVAILED
157	6-May-20	BAGALKOT	110	110/33KV, HV3	MUNVALLI_110, MALLUR_33, MUNVALLI_33	19:37	19:59	0:22	TRANSFORMER FAULT
158	6-May-20	BAGALKOT	110	110/33KV,HV1	ANKOLA_110,VAJRAKOSH_33, ANKOLA_33	11:05	11:55	0:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
159	6-May-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110&KARADI_33, AMINAGAD_33	23:45(6.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
160	6-May-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110	5:33(29.4.20)			LINE IS OPEN: LINE CLEAR AVAILED
161	6-May-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWADA_110	19:12	19:26	0:14	HAND TRIPPED
162	6-May-20	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	21:47	21:58	0:11	LINE FAULT
163	6-May-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR(B)_110	0:23	0:40	0:17	LOAD CURTAILMENT
164	6-May-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	0:23	0:51	0:28	LOAD CURTAILMENT
165	6-May-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	11:07	11:23	0:16	LINE CLEAR AVAILED
166	6-May-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	11:43	12:07	0:24	HAND TRIPPED
167	6-May-20	BAGALKOT	110	BELGUM SOLAR- MAMADAPUR(B)	MAMADAPUR(B)_110	0:45	0:51	0:06	HAND TRIPPED
168	6-May-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	9:07	18:16	9:09	LINE CLEAR AVAILED
169	6-May-20	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	10:22	17:02	6:40	NFBC ISSUED
170	6-May-20	BAGALKOT	110	HUNGUND-KBJNL	HUNGUND_110	23:52(6.5.20)			LINE IS OPEN: LINE FAULT
171	6-May-20	BAGALKOT	110	MAMADAPUR(B)- SHIRBUR	SHIRBUR_110	0:44	0:55	0:11	HAND TRIPPED
172	6-May-20	BAGALKOT	110	MAMADAPUR(B)- TODALBAGI	TODALBAGI_110	13:16	14:47	1:31	LINE CLEAR AVAILED
173	6-May-20	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110, DAVLESHWAR_110	9:35	9:54	0:19	TRANSFORMER FAULT
174	6-May-20	BAGALKOT	220	220/110KV,HV1&LV1	KUDACHI_220	21:47(6.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
175	6-May-20	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	11:27	15:24	3:57	NFBC ISSUED
176	6-May-20	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	14:44(5.5.20)	15:31	24:47hrs	LINE CHARGED
177	6-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	9:15			LINE IS OPEN: LINE CLEAR AVAILED
178	6-May-20	BAGALKOT	220	GADAG-DHONI 1	GADAG_220	9:51	17:41	7:50	LINE CLEAR AVAILED
179	6-May-20	BAGALKOT	220	GADAG-LINGAPUR2(DHONI 2)	GADAG_220	18:49 (3.05.2020)	17:40	70.51hrs	LINE CHARGED
180	6-May-20	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	13:29	18:44	5:15	LINE CLEAR AVAILED
181	6-May-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	14:10	19:20	5:10	LINE CLEAR AVAILED
182	6-May-20	BENGALURU	66	HBR LAYOUT - MANYATHA 220	HBR LAYOUT	19:24	19:29	0:05	LOAD CHANGE OVER
183	6-May-20	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	6:54	7:15	0:21	LINE FAULT
184	6-May-20	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	7:27	7:57	0:30	LINE FAULT
185	6-May-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS(EHT)	17:27	17:43	0:16	LINE FAULT
186	6-May-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	17:43	18:14	0:31	LINE FAULT
187	6-May-20	BENGALURU	66	HV1	ATTUR YELAHANKA	19:37	21:00	1:23	TRANSFORMER FAULT
188	6-May-20	BENGALURU	66	HV1	MALLASANDRA	12:05	13:50	1:45	LINE CLEAR AVAILED
189	6-May-20	BENGALURU	66	HV1	KEMBODI	13:37	15:52	2:14	LINE CLEAR AVAILED
190	6-May-20	BENGALURU	66	HV1	DEVANAHALLI	16:21	16:26	0:05	TRANSFORMER FAULT
191	6-May-20	BENGALURU	66	HV1	CHINTAMANI 66	10:38	12:48	2:10	LINE CLEAR AVAILED
192	6-May-20	BENGALURU	66	HV2	KEMBODI	15:52	17:35	1:42	LINE CLEAR AVAILED
193	6-May-20	BENGALURU	66	HV3	DEVANAHALLI	16:40	16:50	0:10	TRANSFORMER FAULT
194	6-May-20	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	16:25	16:41	0:16	LINE FAULT
195	6-May-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGLI	17:33	17:41	0:08	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
196	6-May-20	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	11:44	11:56	0:12	LINE CLEAR AVAILED
197	6-May-20	HASSAN	66	HV1	DIDIGA_66	11:44	11:57	0:13	LINE CLEAR AVAILED
198	6-May-20	HASSAN	66	HV1	DODDAKA	7:25	7:39	0:14	MAIN SUPPLY FAILURE
199	6-May-20	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	11:08	15:30	4:22	NFBC ISSUED
200	6-May-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:20	14:40	2:20	LINE CLEAR AVAILED
201	6-May-20	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	12:23	14:46	2:23	LINE CLEAR AVAILED
202	6-May-20	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	11:39	11:53	0:14	HAND TRIPPED
203	6-May-20	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	13:13	13:26	0:13	HAND TRIPPED
204	6-May-20	HASSAN	110	HV1	ANAVATTI_110	12:23	14:32	2:09	LINE CLEAR AVAILED
205	6-May-20	HASSAN	110	HV2	ANAVATTI_110	12:23	14:32	2:09	LINE CLEAR AVAILED
206	6-May-20	HASSAN	110	HV2	KONAJE_110	10:36	11:21	0:45	LINE CLEAR AVAILED
207	6-May-20	HASSAN	110	MRSSHM-MPM	MRSMSG_220	16:14	16:24	0:10	LINE FAULT
208	6-May-20	HASSAN	220	KEMAR-UPCL1	KEMAR_220	10:37	13:45	3:08	LINE CLEAR AVAILED
209	6-May-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	18:30(5.5.20)	16:50	22:19hrs	LINE FAULT
210	6-May-20	HASSAN	220	UPCL-KEMAR1	upcl_gen	10:37	13:45	3:08	NFBC ISSUED
211	6-May-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen		16:50	27:19	LINE FAULT
212	6-May-20	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	5:42	5:48	0:05	LINE FAULT
213	6-May-20	MYSORE	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66	5:41	5:47	0:06	LINE FAULT
214	6-May-20	MYSORE	66	HV1	BANNUR_66	10:25	16:30	6:05	LINE CLEAR AVAILED
215	6-May-20	MYSORE	66	HV1	DODDINADUVADI_66	12:00	12:42	0:42	LINE CLEAR AVAILED
216	6-May-20	MYSORE	66	HV1	DODDABYADARAHALLI_66	10:30	11:27	0:57	LINE CLEAR AVAILED
217	6-May-20	MYSORE	66	HV1	KOPPA_66	10:40	11:31	0:51	LINE CLEAR AVAILED
218	6-May-20	MYSORE	66	HV1	RAVANDUR_66	12:55	13:55	1:00	LINE CLEAR AVAILED
219	6-May-20	MYSORE	66	HV2	BETTADHAPURA_66	11:00	11:30	0:30	LINE CLEAR AVAILED
220	6-May-20	MYSORE	66	HV2	BETTADHAPURA_66	16:28	17:55	1:26	LINE CLEAR AVAILED
221	6-May-20	MYSORE	66	HV2	DODDINADUVADI_66	12:00	12:42	0:42	LINE CLEAR AVAILED
222	6-May-20	MYSORE	66	HV2	RAMAPURA_MYS_66	7:00	8:35	1:34	LINE CLEAR AVAILED
223	6-May-20	MYSORE	66	HV3	KIKKERI_66	12:41	13:25	0:43	HAND TRIPPED
224	6-May-20	MYSORE	66	HV5	SFCSHIVA_66	19:17			LINE IS OPEN: LINE CLEAR AVAILED
225	6-May-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	12:43	12:50	0:06	LINE FAULT
226	6-May-20	MYSORE	66	KADAKOLA-SARGUR 2	B MATKERE_66CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	12:43	12:50	0:06	LINE FAULT
227	6-May-20	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	0:21	0:31	0:09	LINE FAULT
228	6-May-20	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	1:03	1:20	0:17	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
229	6-May-20	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS	17:21	17:37	0:16	LINE FAULT
230	6-May-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	15:23	16:26	1:03	LINE FAULT
231	6-May-20	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	16:48	17:31	0:42	LINE FAULT
232	6-May-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	2:43	2:53	0:09	LINE FAULT
233	6-May-20	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	12:37	12:45	0:08	HAND TRIPPED
234	6-May-20	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	18:19	20:56	2:37	MAIN SUPPLY FAILURE
235	6-May-20	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66, YNHOSKOTE_66, LINGDHALLI_66, MANGALWADA_66	15:28	15:42	0:13	LINE FAULT
236	6-May-20	TUMKUR	66	SHYLAPURA-PAVAGADA 220KV	SHYLAPURA_66	15:28	15:45	0:16	LINE FAULT
237	6-May-20	TUMKUR	66	TR-1	BRAHMASANDRA_66	12:03	12:15	0:12	LINE CLEAR AVAILED
238	6-May-20	TUMKUR	66	TR-1	CHANNAGIRI_66	9:14	9:23	0:08	TRANSFORMER FAULT
239	6-May-20	TUMKUR	66	TR-1	HALUVAGALU_66	10:27	10:34	0:06	TRANSFORMER FAULT
240	6-May-20	TUMKUR	66	TR-1	HOLALKERE_66	19:21	19:24	0:02	TRANSFORMER FAULT
241	6-May-20	TUMKUR	66	TR-1	MYLANAHALLI_66	16:07	16:28	0:21	LINE CLEAR AVAILED
242	6-May-20	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	11:50	12:26	0:36	LINE CLEAR AVAILED
243	6-May-20	TUMKUR	66	TR-2	BRAHMASANDRA_66	12:07	12:15	0:07	LINE CLEAR AVAILED
244	6-May-20	TUMKUR	66	TR-2	HINDASGHATTA_66	7:41	8:03	0:21	LINE CLEAR AVAILED
245	6-May-20	TUMKUR	66	TR-2	HOSAKERE_66	12:05	12:20	0:14	LINE CLEAR AVAILED
246	6-May-20	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	12:28	12:53	0:25	LINE CLEAR AVAILED
247	6-May-20	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	14:14	14:25	0:11	LINE CLEAR AVAILED
248	6-May-20	TUMKUR	66	TR-3	HARIYABBE_66	9:06	9:18	0:11	TRANSFORMER FAULT
249	6-May-20	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110, AMMASANDRA_110, SAMPIGE_110	9:59	13:00	3:00	LINE CLEAR AVAILED
250	6-May-20	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	9:59	13:00	3:00	LINE CLEAR AVAILED
251	6-May-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	13:09	13:47	0:38	LINE CLEAR AVAILED
252	6-May-20	TUMKUR	110	TR-1	SAMPIGE_110	9:59	15:56	5:57	LINE CLEAR AVAILED
253	6-May-20	TUMKUR	110	TR-2	SAMPIGE_110	9:59	17:54	7:55	LINE CLEAR AVAILED
254	7-May-20	BAGALKOT	110	110/11KV, HV1	ZALKI_110	23:59 (06.05.2020)	0:05	0:06	LINE CHARGED
255	7-May-20	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	10:53	11:09	0:16	TRANSFORMER FAULT
256	7-May-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	20:58	21:02	0:04	TRANSFORMER FAULT
257	7-May-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110 & KARADI_33, AMINAGAD_33	23:45 (06.05.2020)	0:44	0:59	LINE CHARGED
258	7-May-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110 & KARADI_33, AMINAGAD_33	12:57	13:06	0:09	TRANSFORMER FAULT
259	7-May-20	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110	5:33 (29.04.2020)	18:29	204:56:00	LINE CHARGED
260	7-May-20	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	14:46	14:51	0:05	HAND TRIPPED
261	7-May-20	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR(B)_110	22:24	22:51	0:27	LINE FAULT
262	7-May-20	BAGALKOT	110	BAGEWADI-MAMADAPUR 2	MAMADAPUR(B)_110	22:24	22:51	0:27	LINE FAULT
263	7-May-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	9:11	18:36	9:25	LINE CLEAR AVAILED
264	7-May-20	BAGALKOT	110	BIDNAL-P H COMPOUND	P H COMPOUND_110	10:22	16:42	6:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
265	7-May-20	BAGALKOT	110	GADAG-LAXMESHWAR 2	LAXMESHWAR_110	9:27	12:45	3:18	LINE CLEAR AVAILED
266	7-May-20	BAGALKOT	110	GADAG-SAMBAPUR ROAD	SAMBAPUR ROAD_110	17:48	18:37	0:49	HAND TRIPPED
267	7-May-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	23:54			LINE IS OPEN: LINE FAULT
268	7-May-20	BAGALKOT	110	HIDIKAL-RAIBAG(ITANAL)	ITANAL_110	10:01 (05.05.2020)	18:14	55:73	LINE CHARGED
269	7-May-20	BAGALKOT	110	HUNGUND-ILKAL1&2	HUNGUND_110	0:09	0:41	0:32	HAND TRIPPED
270	7-May-20	BAGALKOT	110	HUNGUND-KBJNL	HUNGUND_110	23:52 (06.05.2020)	1:08	1:16	LINE CLEAR AVAILED
271	7-May-20	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	10:58	11:33	0:35	LINE FAULT
272	7-May-20	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	9:34	12:07	2:33	LINE FAULT
273	7-May-20	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	18:50	19:58	1:08	LINE FAULT
274	7-May-20	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110, DAVLESHWAR_110	10:58	11:29	0:31	TRANSFORMER FAULT
275	7-May-20	BAGALKOT	220	220/110KV,HV1&LV1	KUDACHI_220	21:47			LINE IS OPEN: LINE CLEAR AVAILED
276	7-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	9:16			LINE IS OPEN: LINE CLEAR AVAILED
277	7-May-20	BAGALKOT	220	BELLIGAVI(SHIROLKOPPA)- RANEBENNUR	RANEBENNUR_220	9:03 (04.05.2020)	16:02	78:59:00	LINE CHARGED
278	7-May-20	BAGALKOT	220	GADAG-BAGALKOT 2	GADAG_220	14:35	14:58	0:23	LINE FAULT
279	7-May-20	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	16:02			LINE IS OPEN: LINE CLEAR AVAILED
280	7-May-20	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	11:35	14:45	3:10	LINE CLEAR AVAILED
281	7-May-20	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	9:49	18:11	8:22	LINE FAULT
282	7-May-20	BENGALURU	66	ADDAGAL - LAKSHMIPURA	ADDAGAL	18:37	18:49	0:11	MAIN SUPPLY FAILURE
283	7-May-20	BENGALURU	66	ARMY WELFARE - KADUGODI	ARMY WELFARE ORGANIZATION, KONDASPURA	14:25	16:15	1:50	LINE CLEAR AVAILED
284	7-May-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:35	18:41	0:06	LINE FAULT
285	7-May-20	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	13:52	14:03	0:11	LOAD CHANGE OVER
286	7-May-20	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	15:27	15:39	0:12	LOAD CHANGE OVER
287	7-May-20	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:52	14:03	0:11	LOAD CHANGE OVER
288	7-May-20	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:27	15:39	0:12	LOAD CHANGE OVER
289	7-May-20	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:33	16:40	0:06	LINE FAULT
290	7-May-20	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	13:52	14:03	0:11	LOAD CHANGE OVER
291	7-May-20	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	12:41	12:49	0:08	LOAD CHANGE OVER
292	7-May-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	13:52	14:03	0:11	LOAD CHANGE OVER
293	7-May-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:41	12:49	0:08	LOAD CHANGE OVER
294	7-May-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:52	14:03	0:11	LOAD CHANGE OVER
295	7-May-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	12:41	12:49	0:08	LOAD CHANGE OVER
296	7-May-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:52	14:03	0:11	LOAD CHANGE OVER
297	7-May-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:41	12:48	0:07	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
298	7-May-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:52	14:03	0:11	LOAD CHANGE OVER
299	7-May-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:27	15:39	0:12	LOAD CHANGE OVER
300	7-May-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	13:12	13:53	0:41	LINE FAULT
301	7-May-20	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	13:12	13:49	0:37	MAIN SUPPLY FAILURE
302	7-May-20	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGANATHPURA 220	ELECTRONIC CITY P2 S1	11:09	11:15	0:06	LOAD CHANGE OVER
303	7-May-20	BENGALURU	66	HV1	B G ROAD	22:24	22:34	0:10	LINE CLEAR AVAILED
304	7-May-20	BENGALURU	66	HV1	NANDINI LAYOUT	7:30	7:35	0:05	LINE CLEAR AVAILED
305	7-May-20	BENGALURU	66	HV1	VTG DODDI	22:27	22:35	0:07	TRANSFORMER FAULT
306	7-May-20	BENGALURU	66	HV1	SURYANAGAR	9:10	9:29	0:18	LINE CLEAR AVAILED
307	7-May-20	BENGALURU	66	HV1	SM MANGALA	8:44	10:26	1:41	LINE CLEAR AVAILED
308	7-May-20	BENGALURU	66	HV1	SM MANGALA	12:06	12:46	0:40	LINE CLEAR AVAILED
309	7-May-20	BENGALURU	66	HV1	JIGANI LINK ROAD	22:30	23:30	1:00	MAIN SUPPLY FAILURE
310	7-May-20	BENGALURU	66	HV1	ARMY WELFARE ORGANIZATION	10:55	16:15	5:20	TRANSFORMER FAULT
311	7-May-20	BENGALURU	66	HV2	NANDINI LAYOUT	8:25	8:27	0:02	LINE CLEAR AVAILED
312	7-May-20	BENGALURU	66	HV2	VIJAYANAGARA	11:36	11:46	0:10	LOAD CHANGE OVER
313	7-May-20	BENGALURU	66	HV2	SM MANGALA	6:52	12:50	5:57	TRANSFORMER FAULT
314	7-May-20	BENGALURU	66	HV2	KANAKAPURA 66	11:14	11:20	0:05	TRANSFORMER FAULT
315	7-May-20	BENGALURU	66	HV2	JIGANI LINK ROAD	22:30(7.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
316	7-May-20	BENGALURU	66	JIGANI LINK ROAD - SOMANAHALLI 220	JIGANI 66, JIGANI LINK ROAD	22:30	23:25	0:55	LINE FAULT
317	7-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:36	13:47	0:11	LINE FAULT
318	7-May-20	BENGALURU	66	MINOR IRRIGATION - KONADASAPURA	KONADASAPURA	13:29	14:00	0:30	LINE FAULT
319	7-May-20	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	10:11	10:15	0:04	LOAD CHANGE OVER
320	7-May-20	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	16:15	16:20	0:05	LOAD CHANGE OVER
321	7-May-20	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	13:35	13:40	0:05	LOAD CHANGE OVER
322	7-May-20	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	12:48	13:21	0:33	LINE FAULT
323	7-May-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:45	22:58	0:13	LINE FAULT
324	7-May-20	GULBARGA	66	HAGARIBOMMANAHALLI-ITTAGI	HV1	16:05	16:10	0:05	LINE FAULT
325	7-May-20	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	2:21	2:26	0:05	LINE FAULT
326	7-May-20	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPASAGAR_66, MORAGERE_66, TAMBRAHALLI_66	12:52	12:56	0:04	LINE FAULT
327	7-May-20	GULBARGA	110	GABUR-BPSOLAR_IPP	GABUR_110	5:18	11:25	6:07	LINE FAULT
328	7-May-20	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110	18:50	22:20	3:30	LINE FAULT
329	7-May-20	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	18:50	19:00	0:10	LINE FAULT
330	7-May-20	GULBARGA	110	HV2	BEVOOR_110	18:20	18:35	0:15	LINE CLEAR AVAILED
331	7-May-20	GULBARGA	110	HV2	SHORAPUR_110	7:08	8:59	1:51	LINE CLEAR AVAILED
332	7-May-20	GULBARGA	110	HV3	SHORAPUR_110	17:43	17:50	0:07	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
333	7-May-20	GULBARGA	110	HV4	SHORAPUR_110	16:16	16:35	0:19	TRANSFORMER FAULT
334	7-May-20	GULBARGA	220	HV1	KUSTAGI_220	19:57	21:30	1:33	TRANSFORMER FAULT
335	7-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.20)			LINE IS OPEN: LINE FAULT
336	7-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.20)			LINE IS OPEN: LINE FAULT
337	7-May-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	19:57	20:33	0:36	LINE FAULT
338	7-May-20	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHAPUR_220	18:49			LINE IS OPEN: LINE CLEAR AVAILED
339	7-May-20	GULBARGA	220	SHAHABAD-SHAHPUR	SHAHAPUR_220	12:10	12:30	0:20	LINE FAULT
340	7-May-20	HASSAN	66	HASSN22-ARAKALGUD 2	HASSAN_220	19:18	19:31	0:13	LINE FAULT
341	7-May-20	HASSAN	66	HASSN22-ARAKALGUD 2	HASSAN_220	19:18	19:31	0:13	LINE FAULT
342	7-May-20	HASSAN	66	HV1	DIDIGA_66	12:05	12:25	0:20	LINE CLEAR AVAILED
343	7-May-20	HASSAN	66	HV1	MAGGE_66	15:19	15:43	0:24	MAIN SUPPLY FAILURE
344	7-May-20	HASSAN	66	HV1	SAKLESH PURA_66	15:17	15:38	0:21	TRANSFORMER FAULT
345	7-May-20	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:37	14:54	2:17	LINE CLEAR AVAILED
346	7-May-20	HASSAN	66	HV1	DIDIGA_66	12:05	12:25	0:20	LINE CLEAR AVAILED
347	7-May-20	HASSAN	66	HV1	MAGGE_66	15:19	15:43	0:24	MAIN SUPPLY FAILURE
348	7-May-20	HASSAN	66	HV1	SAKLESH PURA_66	15:17	15:38	0:21	TRANSFORMER FAULT
349	7-May-20	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:37	14:54	2:17	LINE CLEAR AVAILED
350	7-May-20	HASSAN	66	HV2	KANDLI_66	11:01	11:50	0:49	LINE CLEAR AVAILED
351	7-May-20	HASSAN	66	HV2	MAGGE_66	15:19	15:43	0:24	MAIN SUPPLY FAILURE
352	7-May-20	HASSAN	66	HV2	KANDLI_66	11:01	11:50	0:49	LINE CLEAR AVAILED
353	7-May-20	HASSAN	66	HV2	MAGGE_66	15:19	15:43	0:24	MAIN SUPPLY FAILURE
354	7-May-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:19	15:39	0:20	LINE FAULT
355	7-May-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:19	15:39	0:20	LINE FAULT
356	7-May-20	HASSAN	66	SAKALE-HASSAN 1	SAKLESH PURA_66	15:19	15:40	0:21	LINE FAULT
357	7-May-20	HASSAN	66	SAKALE-HASSAN 1	SAKLESH PURA_66	15:19	15:40	0:21	LINE FAULT
358	7-May-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:59	18:13	9:14	LINE CLEAR AVAILED
359	7-May-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:59	18:13	9:14	LINE CLEAR AVAILED
360	7-May-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:59	17:46	8:47	LINE CLEAR AVAILED
361	7-May-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:59	17:46	8:47	LINE CLEAR AVAILED
362	7-May-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:35	12:05	1:30	LINE CLEAR AVAILED
363	7-May-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:35	12:05	1:30	LINE CLEAR AVAILED
364	7-May-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:34	12:05	1:31	LINE CLEAR AVAILED
365	7-May-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:34	12:05	1:31	LINE CLEAR AVAILED
366	7-May-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	21:33	23:34	2:01	LINE FAULT
367	7-May-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	21:33	23:34	2:01	LINE FAULT
368	7-May-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	21:40			LINE IS OPEN: LINE CLEAR AVAILED
369	7-May-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	21:40			LINE IS OPEN: LINE CLEAR AVAILED
370	7-May-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	21:34	23:38	2:04	LINE FAULT
371	7-May-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	21:34	23:38	2:04	LINE FAULT
372	7-May-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	21:33	23:30	1:57	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
373	7-May-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	21:33	23:30	1:57	LINE FAULT
374	7-May-20	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	21:35	23:35	2:00	MAIN SUPPLY FAILURE
375	7-May-20	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	21:35	23:35	2:00	MAIN SUPPLY FAILURE
376	7-May-20	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	10:17	14:06	3:49	LINE CLEAR AVAILED
377	7-May-20	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	10:17	14:06	3:49	LINE CLEAR AVAILED
378	7-May-20	HASSAN	220	KEMAR-UPCL2	KEMAR_220	10:43	14:27	3:44	LINE CLEAR AVAILED
379	7-May-20	HASSAN	220	KEMAR-UPCL2	KEMAR_220	10:43	14:27	3:44	LINE CLEAR AVAILED
380	7-May-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:05	17:33	2:28	LINE CLEAR AVAILED
381	7-May-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	22:27	22:33	0:06	HAND TRIPPED
382	7-May-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:05	17:33	2:28	LINE CLEAR AVAILED
383	7-May-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	22:27	22:33	0:06	HAND TRIPPED
384	7-May-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:56	16:01	4:05	LINE FAULT
385	7-May-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:56	16:01	4:05	LINE FAULT
386	7-May-20	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:16	14:07	3:51	NFBC ISSUED
387	7-May-20	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:16	14:07	3:51	NFBC ISSUED
388	7-May-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:56	16:01	4:05	LINE FAULT
389	7-May-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:56	16:01	4:05	LINE FAULT
390	7-May-20	HASSAN	220	UPCL-KEMAR2	upcl_gen	10:43	14:27	3:44	NFBC ISSUED
391	7-May-20	HASSAN	220	UPCL-KEMAR2	upcl_gen	10:43	14:27	3:44	NFBC ISSUED
392	7-May-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:15			LINE IS OPEN: LINE CLEAR AVAILED
393	7-May-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:15			LINE IS OPEN: LINE CLEAR AVAILED
394	7-May-20	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	9:20	13:55	4:35	LINE CLEAR AVAILED
395	7-May-20	MYSORE	66	HV2	KIADBMANDYA_66	11:06	11:58	0:52	HAND TRIPPED
396	7-May-20	MYSORE	66	KADAKOLA-SARGUR-1	B MATKERE_66, ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	7:44	7:50	0:06	LINE FAULT
397	7-May-20	MYSORE	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	23:57			LINE IS OPEN: LINE FAULT
398	7-May-20	MYSORE	66	KADAKOLA-SARGUR-2	B MATKERE_66, ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	7:44	7:50	0:06	LINE FAULT
399	7-May-20	MYSORE	66	MEGHALAPURA-VAJMANGALA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 MEGALAPURA_66 THUMBLA_66 TNARASIPURA_66 VYASRAJPURA_66	13:02	13:10	0:08	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
400	7-May-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI _66	8:22	8:27	0:05	LINE FAULT
401	7-May-20	MYSORE	220	HV1	HOOTAGALLY_220	10:08	13:36	3:28	LINE CLEAR AVAILED
402	7-May-20	MYSORE	220	KADAKOLA-KANIYANBETTA	NO STATIONS	12:02	14:34	2:32	LINE CLEAR AVAILED
403	7-May-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:12	15:35	0:23	LINE FAULT
404	7-May-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	19:01	19:13	0:12	LINE FAULT
405	7-May-20	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:27	19:13	0:45	LINE FAULT
406	7-May-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	11:05	11:12	0:06	LINE FAULT
407	7-May-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	22:01	22:07	0:06	LINE FAULT
408	7-May-20	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	19:17	19:20	0:02	HAND TRIPPED
409	7-May-20	TUMKUR	66	MADANAYAKANAHALLI-TURUVANUR	MADANAYAKANAHALLI_66	19:22	19:24	0:02	MAIN SUPPLY FAILURE
410	7-May-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	17:56	18:13	0:16	LINE FAULT
411	7-May-20	TUMKUR	66	TR-1	CHAWANAKUPPE_66	12:34	12:58	0:24	LINE CLEAR AVAILED
412	7-May-20	TUMKUR	66	TR-1	PANDARAHALLI_66	14:38	15:07	0:28	HAND TRIPPED
413	7-May-20	TUMKUR	66	TR-1	SHYLAPURA_66	19:55	21:39	1:44	TRANSFORMER FAULT
414	7-May-20	TUMKUR	66	TR-1	YEDIYUR_66	13:03	13:52	0:49	LINE CLEAR AVAILED
415	7-May-20	TUMKUR	66	TR-1	PAVAGADA_66	16:22	16:43	0:21	TRANSFORMER FAULT
416	7-May-20	TUMKUR	66	TR-1	PAVAGADA_66	22:45	22:54	0:09	TRANSFORMER FAULT
417	7-May-20	TUMKUR	66	TR-2	BALENAHALLI_66	14:53	15:04	0:11	TRANSFORMER FAULT
418	7-May-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	20:34	20:40	0:06	TRANSFORMER FAULT
419	7-May-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	21:39	21:41	0:01	TRANSFORMER FAULT
420	7-May-20	TUMKUR	66	TR-2	HULIYURDURGA_66	11:57	12:03	0:06	HAND TRIPPED
421	7-May-20	TUMKUR	66	TR-2	HULIYURDURGA_66	22:44	22:50	0:06	HAND TRIPPED
422	7-May-20	TUMKUR	110	HANDANKERE_110-K B CROSS 220	HANDANKERE_110	14:53	15:13	0:20	HAND TRIPPED
423	7-May-20	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	16:33	23:48	7:15	LINE FAULT
424	7-May-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:08	12:49	0:40	LINE CLEAR AVAILED
425	7-May-20	TUMKUR	110	TR-1	HANDANKERE_110	9:34	9:37	0:03	TRANSFORMER FAULT
426	7-May-20	TUMKUR	110	TR-1	HANDANKERE_110	13:36	15:14	1:37	LINE CLEAR AVAILED
427	7-May-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	14:25	15:35	1:10	LINE CLEAR AVAILED
428	7-May-20	TUMKUR	110	TR-2	SAMPIGE_110	13:41	13:55	0:14	TRANSFORMER FAULT
429	7-May-20	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	20:16	21:27	1:11	LINE FAULT
430	7-May-20	TUMKUR	220	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:22	13:41	1:18	LINE CLEAR AVAILED
431	7-May-20	TUMKUR	220	TR-1	PAVAGADA_220	20:16	21:37	1:21	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
432	7-May-20	TUMKUR	220	TR-2	PAVAGADA_220	20:16(7.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
433	8-May-20	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	19:08	19:12	0:04	TRANSFORMER FAULT
434	8-May-20	BAGALKOT	110	110/11KV,HV3	RATTIHALLI_110	12:14	12:49	0:35	LINE CLEAR AVAILED
435	8-May-20	BAGALKOT	110	110/33KV,HV2	DAMBAL_110,WATER SUPPLY_33	11:29	13:04	1:35	LINE CLEAR AVAILED
436	8-May-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110 &D.GENNUR_33,LINGADALLI_33	13:25	14:14	0:49	HAND TRIPPED
437	8-May-20	BAGALKOT	110	BAGALKOT220-NEERABUDIHAL	NEERABUDIHAL-110	19:45(8.5.20)			LINE IS OPEN: LINE FAULT
438	8-May-20	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	10:01	16:06	6:05	LINE CLEAR AVAILED
439	8-May-20	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	10:19	16:29	6:10	NFBC ISSUED
440	8-May-20	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	8:16	13:50	5:34	LINE CLEAR AVAILED
441	8-May-20	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	16:19(8.5.20)			LINE IS OPEN: LINE CLEAR AVAILED
442	8-May-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	23:54 (07.05.2020)	10:35	10:41	LINE CHARGED
443	8-May-20	BAGALKOT	110	HIDIKAL-RAIBAG(ITANAL)	HIDIKAL_110	1:25	18:00	16:35	LINE CLEAR AVAILED
444	8-May-20	BAGALKOT	110	HUNGUND- KUDALSANGAM	KUDALASANGAM_110	17:46	18:19	0:33	LINE CLEAR AVAILED
445	8-May-20	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	13:30	14:40	1:10	LINE CLEAR AVAILED
446	8-May-20	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	0:23	0:34	0:11	LINE FAULT
447	8-May-20	BAGALKOT	110	SIRSI-KUMATA2	KUMATA_110	10:16	13:08	2:52	LINE CLEAR AVAILED
448	8-May-20	BAGALKOT	220	220/110KV,HV1&LV1	KUDACHI_220	21:47 (06.05.2020)	14:06	16:19	LINE CHARGED
449	8-May-20	BAGALKOT	220	220/110KV,HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110, DAVLESHWAR_110	0:23	0:34	0:11	TRANSFORMER FAULT
450	8-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN: LINE FAULT
451	8-May-20	BENGALURU	66	AVANI - MULBAGLU	MULBAGLU	14:50	15:27	0:37	LINE CLEAR AVAILED
452	8-May-20	BENGALURU	66	AVANI - MULBAGLU	NO STATION AFFECTED	15:27	17:10	1:43	LINE CLEAR AVAILED
453	8-May-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	6:42	7:10	0:27	LINE FAULT
454	8-May-20	BENGALURU	66	HV1	BAGEPALLI	10:54	10:57	0:03	LINE CLEAR AVAILED
455	8-May-20	BENGALURU	66	HV1	MITTEMARI 220	11:49	13:02	1:12	LINE CLEAR AVAILED
456	8-May-20	BENGALURU	66	HV1	RR NAGAR	22:12	22:15	0:03	LOAD CHANGE OVER
457	8-May-20	BENGALURU	66	HV2	BMTC	12:44	12:46	0:02	LINE CLEAR AVAILED
458	8-May-20	BENGALURU	66	HV2	VIJAYANAGARA	12:21	12:28	0:06	LOAD CHANGE OVER
459	8-May-20	BENGALURU	66	HV2	RR NAGAR	22:12	22:15	0:03	LOAD CHANGE OVER
460	8-May-20	BENGALURU	66	HV3	NAGNATHPURA 220	11:20	11:30	0:09	LINE CLEAR AVAILED
461	8-May-20	BENGALURU	66	IISC - NRS 220	IISC	16:48	16:52	0:04	LOAD CHANGE OVER
462	8-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	9:04	9:16	0:12	LINE FAULT
463	8-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:12	13:38	0:25	LINE FAULT
464	8-May-20	BENGALURU	66	MULBAGLU - NANGLI	MULBAGLU	16:55	17:10	0:15	LOAD CHANGE OVER
465	8-May-20	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	22:40	23:25	0:44	MAIN SUPPLY FAILURE
466	8-May-20	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	22:40	22:48	0:07	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
467	8-May-20	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	22:40	23:25	0:45	MAIN SUPPLY FAILURE
468	8-May-20	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 22	RR NAGAR	19:32	19:48	0:16	MAIN SUPPLY FAILURE
469	8-May-20	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	BRINDAVANA	21:51(8.5.20)			LINE IS OPEN: LINE FAULT
470	8-May-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	19:32	21:46	2:14	LINE FAULT
471	8-May-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI	11:40	11:48	0:08	LOAD CHANGE OVER
472	8-May-20	BENGALURU	220	BEGUR 220 - D B PURA 220	NO STATION AFFECTED	16:30	16:41	0:11	LINE FAULT
473	8-May-20	BENGALURU	220	D B PURA 220 - BEGUR 220	NO STATION AFFECTED	21:51	22:27	0:36	LINE FAULT
474	8-May-20	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	21:51	22:24	0:33	LINE FAULT
475	8-May-20	BENGALURU	220	HV1	SRS PEENYA 220	21:51	23:14	1:23	TRANSFORMER FAULT
476	8-May-20	BENGALURU	220	HV5	SRS PEENYA 220	21:51	23:56	2:05	TRANSFORMER FAULT
477	8-May-20	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	23:49(8.5.20)			LINE IS OPEN: LINE FAULT
478	8-May-20	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	21:48	22:32	0:44	MAIN SUPPLY FAILURE
479	8-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1	SRS PEENYA	21:51	22:41	0:50	LINE FAULT
480	8-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA	21:51(8.5.20)			LINE IS OPEN: LINE FAULT
481	8-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4	SRS PEENYA	21:51(8.5.20)			LINE IS OPEN: LINE FAULT
482	8-May-20	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	21:51	22:32	0:41	LINE FAULT
483	8-May-20	BENGALURU	220	SRS PEENYA 220 - NRS 220	NO STATION AFFECTED	22:32(8.5.20)			LINE IS OPEN: LINE FAULT
484	8-May-20	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	14:25	14:35	0:10	TRANSFORMER FAULT
485	8-May-20	GULBARGA	66	ITTAGI-KUDLIGI1,2	KOGALI_66, KUDLIGI_66,HANASI_66,CJHALLI_66, BANAVEKAL_66,CHORNOOR_66,HOS AHALLI_66,GUDEKOTE_66	11:01	11:15	0:14	LINE FAULT
486	8-May-20	GULBARGA	110	CHITAGUPPA-ACMESOLAR_IPP	CHITAGUPPA_110	16:25	17:38	1:13	LINE CLEAR AVAILED
487	8-May-20	GULBARGA	110	GULBARAGNORTH-GULBARGA UNIVERSITY1,2	GULUNI_110	17:40(8.5.20)			LINE IS OPEN: LINE FAULT
488	8-May-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	16:05	16:20	0:15	MAIN SUPPLY FAILURE
489	8-May-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	16:05	16:18	0:13	LINE FAULT
490	8-May-20	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTAPUR-110	17:17(8.5.20)			LINE IS OPEN: LINE FAULT
491	8-May-20	GULBARGA	110	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110	17:10	17:16	0:06	LINE FAULT
492	8-May-20	GULBARGA	110	KAPNOOR-MADIYAL		16:22	16:36	0:14	LINE FAULT
493	8-May-20	GULBARGA	110	KAPNOOR-MADIYAL		19:36	19:52	0:16	LINE FAULT
494	8-May-20	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
495	8-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
496	8-May-20	GULBARGA	220	SHAHABAD-SHAHPUR	SHAHAPUR_220	20:56	21:06	0:10	LINE FAULT
497	8-May-20	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	11:23	13:20	1:57	NFBC ISSUED
498	8-May-20	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	18:03	18:27	0:24	LINE CLEAR AVAILED
499	8-May-20	HASSAN	66	HV1	HALLIMYSORE_66	18:19	18:27	0:08	TRANSFORMER FAULT
500	8-May-20	HASSAN	66	HV1	MAGGE_66	14:17	14:41	0:24	MAIN SUPPLY FAILURE
501	8-May-20	HASSAN	66	HV2	MAGGE_66	14:17	14:41	0:24	MAIN SUPPLY FAILURE
502	8-May-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	14:17	14:40	0:23	LINE CLEAR AVAILED
503	8-May-20	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	1:12	1:26	0:14	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
504	8-May-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:36	17:21	8:45	LINE CLEAR AVAILED
505	8-May-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:36	17:30	8:54	LINE CLEAR AVAILED
506	8-May-20	HASSAN	66	SAKLAE-HASSAN 1	SAKLESH PURA_66	14:17	14:41	0:24	NFBC ISSUED
507	8-May-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	6:41	7:17	0:36	LINE FAULT
508	8-May-20	HASSAN	110	HV1	BAIKAMPADI_110	10:45	16:49	6:04	LINE CLEAR AVAILED
509	8-May-20	HASSAN	110	HV2	BARANGI_110	14:55	18:40	3:45	LINE CLEAR AVAILED
510	8-May-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	12:34	13:40	1:06	NFBC ISSUED
511	8-May-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	21:40 (7.05.2020)	15:44	18:03	LINE CHARGED
512	8-May-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	12:33	13:47	1:14	LINE CLEAR AVAILED
513	8-May-20	HASSAN	110	MANIPAL-KEMAR1	KONAJE_110	12:34	13:34	1:00	LINE CLEAR AVAILED
514	8-May-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:41	12:10	1:29	LINE CLEAR AVAILED
515	8-May-20	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	12:36	13:51	1:15	LINE CLEAR AVAILED
516	8-May-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	2:29	2:44	0:15	LINE FAULT
517	8-May-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	2:29	3:44	1:15	LINE FAULT
518	8-May-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	3:44	10:50	7:06	LINE FAULT
519	8-May-20	HASSAN	220	MRSSHM-KBCRS	MRS MG_220	8:51	15:24	6:33	LINE FAULT
520	8-May-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	2:29	10:57	8:28	LINE FAULT
521	8-May-20	HASSAN	400	UPCL-HASSAN2	NO STATION AFFECTED	18:15 (7.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
522	8-May-20	MYSORE	66	HOOTAGALLI-DATTAGALLY	NO STATIONS	10:46	14:41	3:55	LINE CLEAR AVAILED
523	8-May-20	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	NO STATIONS	9:40	14:37	4:57	LINE CLEAR AVAILED
524	8-May-20	MYSORE	66	KADAKOLA-SARAGUR-2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66,	21:33	21:38	0:05	LINE FAULT
525	8-May-20	MYSORE	66	TUBINAKERE-NAGAMANGALA-1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	7:06	7:15	0:09	LINE FAULT
526	8-May-20	MYSORE	220	HV2	HOOTAGALLY_220	10:50	14:27	3:37	LINE CLEAR AVAILED
527	8-May-20	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VG DODDI_66	10:03	13:36	3:32	LINE CLEAR AVAILED
528	8-May-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:32	12:54	0:21	LINE FAULT
529	8-May-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:03	14:21	0:17	LINE FAULT
530	8-May-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	11:56	12:06	0:09	LINE FAULT
531	8-May-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:11	10:18	0:07	LINE FAULT
532	8-May-20	TUMKUR	66	TR-1	BIDARE_110	12:20	12:50	0:30	LINE CLEAR AVAILED
533	8-May-20	TUMKUR	66	TR-1	HOLALKERE_66	8:13	8:17	0:03	TRANSFORMER FAULT
534	8-May-20	TUMKUR	66	TR-1	MYLANAHALLI_66	10:34	10:49	0:14	TRANSFORMER FAULT
535	8-May-20	TUMKUR	66	TR-2	CHITRADURGA_66	5:20	6:06	0:45	TRANSFORMER FAULT
536	8-May-20	TUMKUR	66	TR-2	HALUVAGALU_66	0:49	0:59	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
537	8-May-20	TUMKUR	66	TR-2	HALUVAGALU_66	1:56	1:57	0:01	HAND TRIPPED
538	8-May-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	12:20	13:03	0:43	TRANSFORMER FAULT
539	8-May-20	TUMKUR	66	TR-2	HULIYURDURGA_66	13:44	13:56	0:12	TRANSFORMER FAULT
540	8-May-20	TUMKUR	110	TR-1	BIDARE_110	10:07	10:11	0:04	LINE CLEAR AVAILED
541	8-May-20	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	21:51	22:18	0:26	LINE FAULT
542	8-May-20	TUMKUR	220	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	8:42	13:41	4:58	LINE CLEAR AVAILED
543	8-May-20	TUMKUR	220	THALLAK 220kV- HIREMALLANAHOLE 2	THALLAKK_220	19:23	19:26	0:03	HAND TRIPPED
544	8-May-20	TUMKUR	220	TR-2	PAVAGADA_220	8:16(7.5.20)	7:40	22;83 hrs	TRANSFORMER FAULT
545	9-May-20	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	10:02	17:06	7:04	LINE CLEAR AVAILED
546	9-May-20	BAGALKOT	110	110/11KV,HV1	SADALAGA_110,	10:35	17:45	7:10	LINE CLEAR AVAILED
547	9-May-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	16:37	16:42	0:05	TRANSFORMER FAULT
548	9-May-20	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	11:18	12:16	0:58	LINE CLEAR AVAILED
549	9-May-20	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	9:25	9:40	0:15	TRANSFORMER FAULT
550	9-May-20	BAGALKOT	110	110/11KV,HV2	SADALAGA_110	12:45	17:35	4:50	LINE CLEAR AVAILED
551	9-May-20	BAGALKOT	110	110/11KV,HV2	PG HUNASYAL_110	17:05	18:04	0:59	LINE CLEAR AVAILED
552	9-May-20	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	10:17	10:31	0:14	TRANSFORMER FAULT
553	9-May-20	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	18:46	18:54	0:08	TRANSFORMER FAULT
554	9-May-20	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	15:22	15:46	0:24	TRANSFORMER FAULT
555	9-May-20	BAGALKOT	110	110/33KV,HV2	SADALAGA_110,BHOJ_33	10:47	16:44	5:57	LINE CLEAR AVAILED
556	9-May-20	BAGALKOT	110	BAGALKOT220-NEERABUDIHAL	NO STATION EFFECTED	19:45(08.05.2020)	14:44	18:59	LINE CHARGED
557	9-May-20	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	20:40(9.5.20)			LINE IS OPEN: LINE FAULT
558	9-May-20	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	20:03(9.5.20)			LINE IS OPEN: LINE FAULT
559	9-May-20	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED	16:19(08.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
560	9-May-20	BAGALKOT	110	HIDIKAL-RAIBAG(ITANAL)	HIDIKAL_110	0:14	20:12	19:58	LINE CLEAR AVAILED
561	9-May-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	11:08	12:12	1:04	LINE CLEAR AVAILED
562	9-May-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	17:00	17:10	0:10	LINE CLEAR AVAILED
563	9-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN: LINE FAULT
564	9-May-20	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	9:41	13:22	3:41	LINE CLEAR AVAILED
565	9-May-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	16:02 (07.05.2020)	7:37	15:35	LINE CHARGED
566	9-May-20	BAGALKOT	220	HUBLI 220-SIRSI 1	HUBLI_220	14:33	19:48	5:15	LINE FAULT
567	9-May-20	BAGALKOT	220	RANEENNUR-SHIRALKOPPA	RANEENNUR_220	7:37(9.5.20)			LINE IS OPEN: LINE CLEAR AVAILED
568	9-May-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	5:05	13:05	8:00	LINE FAULT
569	9-May-20	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	12:35	13:25	0:50	LINE CLEAR AVAILED
570	9-May-20	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	22:40	23:45	1:05	MAIN SUPPLY FAILURE
571	9-May-20	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA	6:28	6:54	0:26	MAIN SUPPLY FAILURE
572	9-May-20	BENGALURU	66	HV1	AREHALLI	10:35	10:38	0:03	LINE CLEAR AVAILED
573	9-May-20	BENGALURU	66	HV1	D CROSS	10:48	12:15	1:27	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
574	9-May-20	BENGALURU	66	HV1	DOMMASANDRA	13:25	13:50	0:25	LINE CLEAR AVAILED
575	9-May-20	BENGALURU	66	HV1	EPIP 220	13:45	16:23	2:38	LINE CLEAR AVAILED
576	9-May-20	BENGALURU	66	HV1	SARJAPURA 220	22:40	23:40	1:00	MAIN SUPPLY FAILURE
577	9-May-20	BENGALURU	66	HV1	MUDIYANUR	13:40	13:49	0:09	TRANSFORMER FAULT
578	9-May-20	BENGALURU	66	HV2	D CROSS	10:48	12:15	1:27	LINE CLEAR AVAILED
579	9-May-20	BENGALURU	66	HV2	DOMMASANDRA	13:25	13:35	0:10	LINE CLEAR AVAILED
580	9-May-20	BENGALURU	66	HV2	EPIP 220	9:40	13:43	4:03	LINE CLEAR AVAILED
581	9-May-20	BENGALURU	66	HV2	SARJAPURA 220	22:40	23:40	1:00	MAIN SUPPLY FAILURE
582	9-May-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	19:28	19:44	0:16	LINE FAULT
583	9-May-20	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	5:55	6:20	0:25	LINE FAULT
584	9-May-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
585	9-May-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
586	9-May-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
587	9-May-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	12:57	13:48	0:51	LINE FAULT
588	9-May-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
589	9-May-20	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
590	9-May-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
591	9-May-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
592	9-May-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	22:42(9.5.20)			LINE IS OPEN: MAIN SUPPLY FAILURE
593	9-May-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	22:40	23:12	0:32	MAIN SUPPLY FAILURE
594	9-May-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	22:40	23:12	0:32	MAIN SUPPLY FAILURE
595	9-May-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:40	23:12	0:32	MAIN SUPPLY FAILURE
596	9-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	22:40	23:12	0:32	MAIN SUPPLY FAILURE
597	9-May-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	22:40	23:12	0:32	MAIN SUPPLY FAILURE
598	9-May-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	22:40	23:12	0:32	MAIN SUPPLY FAILURE
599	9-May-20	BENGALURU	66	MANYATHA 220 - PEENYA 2	SAHAKARINAGAR	7:25	8:15	0:50	LINE FAULT
600	9-May-20	BENGALURU	66	MELAHALLI - JALAMANGALA	JALAMANGALA, KOOTGAL, CHIKGANGANVADI	5:55	6:23	0:28	LINE FAULT
601	9-May-20	BENGALURU	66	MELAHALLI - JALAMANGALA	JALAMANGALA, KOOTGAL, CHIKGANGANVADI	13:24	13:35	0:11	LINE CLEAR AVAILED
602	9-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	5:07	5:10	0:02	LOAD CHANGE OVER
603	9-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	13:28	13:30	0:01	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
604	9-May-20	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	1:33	1:35	0:02	LINE CLEAR AVAILED
605	9-May-20	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	8:35	8:36	0:01	LOAD CHANGE OVER
606	9-May-20	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	6:32	6:50	0:17	MAIN SUPPLY FAILURE
607	9-May-20	BENGALURU	66	RMV - HEBBAL 220	RMV	7:41	7:44	0:03	LOAD CHANGE OVER
608	9-May-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	6:28	6:44	0:15	MAIN SUPPLY FAILURE
609	9-May-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	22:40	23:34	0:54	MAIN SUPPLY FAILURE
610	9-May-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:34	13:28	0:53	LINE CLEAR AVAILED
611	9-May-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	22:40	23:44	1:04	MAIN SUPPLY FAILURE
612	9-May-20	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, NELAMANGALA 66	6:28	7:14	0:46	LINE CLEAR AVAILED
613	9-May-20	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	6:28	7:14	0:46	LINE CLEAR AVAILED
614	9-May-20	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	6:28	7:14	0:46	LINE CLEAR AVAILED
615	9-May-20	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:36	13:53	0:17	MAIN SUPPLY FAILURE
616	9-May-20	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	18:24	18:42	0:18	MAIN SUPPLY FAILURE
617	9-May-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:36	13:53	0:17	MAIN SUPPLY FAILURE
618	9-May-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	18:24	18:42	0:18	MAIN SUPPLY FAILURE
619	9-May-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:36	13:53	0:17	MAIN SUPPLY FAILURE
620	9-May-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	18:24	18:42	0:18	MAIN SUPPLY FAILURE
621	9-May-20	BENGALURU	220	A STATION 220 - NRS 220	A STATION	15:08	15:15	0:07	LOAD CHANGE OVER
622	9-May-20	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	13:34(9.5.20)			LINE IS OPEN: LINE FAULT
623	9-May-20	BENGALURU	220	HV1	VIKAS TECH PARK 220	13:36	13:53	0:17	MAIN SUPPLY FAILURE
624	9-May-20	BENGALURU	220	HV1	VIKAS TECH PARK 220	18:24	18:42	0:18	MAIN SUPPLY FAILURE
625	9-May-20	BENGALURU	220	HV1	SARJAPURA 220	22:40	23:40	1:00	MAIN SUPPLY FAILURE
626	9-May-20	BENGALURU	220	HV2	VIKAS TECH PARK 220	13:36	13:53	0:17	MAIN SUPPLY FAILURE
627	9-May-20	BENGALURU	220	HV2	VIKAS TECH PARK 220	18:24	18:42	0:18	MAIN SUPPLY FAILURE
628	9-May-20	BENGALURU	220	HV2	SARJAPURA 220	22:40	23:42	1:02	MAIN SUPPLY FAILURE
629	9-May-20	BENGALURU	220	HV2	NRS 220	22:40	23:26	0:02	MAIN SUPPLY FAILURE
630	9-May-20	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	22:40	23:11	0:31	MAIN SUPPLY FAILURE
631	9-May-20	BENGALURU	220	KOLAR 220 - PGCIL 1	NO STATION AFFECTED	12:58	18:00	5:02	LINE CLEAR AVAILED
632	9-May-20	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	22:41(9.5.20)			LINE IS OPEN: LINE FAULT
633	9-May-20	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	22:41(9.5.20)			LINE IS OPEN: LINE FAULT
634	9-May-20	BENGALURU	220	NELAMANGALA 400 - HOODY	NO STATION AFFECTED	6:28	7:08	0:40	LINE FAULT
635	9-May-20	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	23:49(8.5.20)	4:52	5:02 hrs	LINE FAULT
636	9-May-20	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	6:28	8:53	2:24	LINE FAULT
637	9-May-20	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	6:30	6:49	0:19	MAIN SUPPLY FAILURE
638	9-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA	6:28	6:54	0:26	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
639	9-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA	21:51(8.5.20)	4:55	7:03 hrs	LINE FAULT
640	9-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA	6:28	7:09	0:41	LINE FAULT
641	9-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4	NO STATION AFFECTED	21:51(8.5.20)	4:55	7:03 hrs	LINE FAULT
642	9-May-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4	NRS 220	6:28	6:49	0:21	LINE FAULT
643	9-May-20	BENGALURU	220	SRS PEENYA 220 - NRS 220	NO STATION AFFECTED	22:32(8.5.20)	4:02	5:29 hrs	LINE FAULT
644	9-May-20	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	6:49	7:01	0:12	LINE FAULT
645	9-May-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_110,KAMALAPUR_110, METRI_110, RBNS SUGARS	20:36	20:45	0:09	LINE FAULT
646	9-May-20	GULBARGA	110	GULBARAGNORTH-GULBARGA UNIVERSITY1,2	GULUNI_110	17:40(8.5.20)	13:51	18:24 hrs	LINE FAULT
647	9-May-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	11:26	11:32	0:06	LINE FAULT
648	9-May-20	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTAPUR-110	17:17(8.5.20)	9:35	19:40 hrs	LINE FAULT
649	9-May-20	GULBARGA	110	HV1	HANUMASAGAR_110	16:40	16:55	0:15	LINE CLEAR AVAILED
650	9-May-20	GULBARGA	110	HV1	HANUMASAGAR_110	17:10	17:20	0:10	TRANSFORMER FAULT
651	9-May-20	GULBARGA	110	HV2	HATTI_110	14:31	14:37	0:06	TRANSFORMER FAULT
652	9-May-20	GULBARGA	110	HV4	SHORAPUR_110	8:07	8:17	0:10	TRANSFORMER FAULT
653	9-May-20	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATGIRI_110, GANGAVATHI_110,SREERAMNAGAR_110,KARTAGI_110	22:48	23:02	0:14	LINE FAULT
654	9-May-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	2:46	10:08	7:22	LINE FAULT
655	9-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
656	9-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
657	9-May-20	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	22:22(8.5.20)			LINE IS OPEN: LINE FAULT
658	9-May-20	GULBARGA	220	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	11:35	13:55	2:20	LINE CLEAR AVAILED
659	9-May-20	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	13:00	15:01	2:01	LINE FAULT
660	9-May-20	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
661	9-May-20	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	15:09	15:17	0:08	LINE FAULT
662	9-May-20	HASSAN	66	HASSN22-ARKD2	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
663	9-May-20	HASSAN	66	HASSN22-BELUR	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
664	9-May-20	HASSAN	66	HASSN22-CRP1	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
665	9-May-20	HASSAN	66	HASSN22-CRP2	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
666	9-May-20	HASSAN	66	HASSN22-HSN66	HASSAN_220	17:43	18:46	1:03	MAIN SUPPLY FAILURE
667	9-May-20	HASSAN	66	HASSN22-SKP1	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
668	9-May-20	HASSAN	66	HASSN22-SKP2	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
669	9-May-20	HASSAN	66	HASSN22-SKPURA	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
670	9-May-20	HASSAN	66	HASSN22-SUZLON	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
671	9-May-20	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	17:43	18:51	1:08	MAIN SUPPLY FAILURE
672	9-May-20	HASSAN	66	HV1	MAGGE_66	17:44	18:53	1:09	MAIN SUPPLY FAILURE
673	9-May-20	HASSAN	66	HV1	SAKLESH PURA_66	16:24	16:38	0:14	TRANSFORMER FAULT
674	9-May-20	HASSAN	66	HV2	MAGGE_66	17:44	18:53	1:09	MAIN SUPPLY FAILURE
675	9-May-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:01	18:52	9:51	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
676	9-May-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:01	18:52	9:51	LINE CLEAR AVAILED
677	9-May-20	HASSAN	110	HV1	NANDIKUR_110	12:55	13:25	0:30	LINE CLEAR AVAILED
678	9-May-20	HASSAN	110	HV2	BARANGI_110	12:55	13:15	0:20	LINE CLEAR AVAILED
679	9-May-20	HASSAN	110	KEMAR-BELMAN	KEMAR_220	15:56	16:31	0:35	LINE CLEAR AVAILED
680	9-May-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	13:26	13:51	0:25	HAND TRIPPED
681	9-May-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	14:39	15:37	0:58	LINE CLEAR AVAILED
682	9-May-20	HASSAN	110	NANDIKUR-KEMAR1	NANDIKUR_110	12:55	13:24	0:29	LINE CLEAR AVAILED
683	9-May-20	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	10:43	11:43	1:00	LINE CLEAR AVAILED
684	9-May-20	HASSAN	220	HASSN22-CHIKMAGALUR	HASSAN_220	17:43 (9.05.2020)			LINE IS OPEN: LINE FAULT
685	9-May-20	HASSAN	220	HASSN22-SHANTHIGRAMA	HASSAN_220	17:43	18:43	1:00	LINE FAULT
686	9-May-20	HASSAN	220	HV1	HASSAN_220	17:43	18:49	1:06	TRANSFORMER FAULT
687	9-May-20	HASSAN	220	HV1	KEMAR_220	14:43	14:47	0:04	HAND TRIPPED
688	9-May-20	HASSAN	220	HV2	HASSAN_220	17:43	18:45	1:02	TRANSFORMER FAULT
689	9-May-20	HASSAN	220	HV2	KEMAR_220	14:48	14:50	0:02	HAND TRIPPED
690	9-May-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	14:59	15:35	0:36	LINE FAULT
691	9-May-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	14:59	15:36	0:37	LINE FAULT
692	9-May-20	HASSAN	400	UPCL-HASSAN2	NO STATION AFFECTED	18:15 (7.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
693	9-May-20	MYSORE	66	MADHUVANAHALLI-HANNUR 2	NO STATIONS	8:02	8:12	0:10	LINE FAULT
694	9-May-20	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	DKMAIDANA_66 JYOTHINAGARA_66	13:17	13:28	0:11	LINE FAULT
695	9-May-20	MYSORE	220	TUBINAKERE-BASTIPURA-2	NO STATIONS	10:30	12:10	1:40	LINE CLEAR AVAILED
696	9-May-20	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	14:42	14:52	0:10	LINE FAULT
697	9-May-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	14:24	14:35	0:10	LINE FAULT
698	9-May-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	17:01	17:06	0:05	LINE FAULT
699	9-May-20	TUMKUR	66	TR-1	BENKIKERE_66	16:09	18:24	2:14	TRANSFORMER FAULT
700	9-May-20	TUMKUR	66	TR-2	HALUVAGALU_66	18:02	18:12	0:09	TRANSFORMER FAULT
701	9-May-20	TUMKUR	66	TR-2	MANGALWADA_66	3:10	3:14	0:03	TRANSFORMER FAULT
702	9-May-20	TUMKUR	66	TR-3	HARIYABBE_66	7:07	7:22	0:14	TRANSFORMER FAULT
703	9-May-20	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	12:56	14:24	1:27	LINE FAULT
704	9-May-20	TUMKUR	110	TR-1	SHETYKERE_110	13:02	13:49	0:47	LINE CLEAR AVAILED
705	9-May-20	TUMKUR	110	TR-2	SAMPIGE_110	9:31	10:25	0:53	TRANSFORMER FAULT
706	9-May-20	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	6:29	6:41	0:11	LINE FAULT
707	9-May-20	TUMKUR	220	GUTUR 66-DAVANGERE SRS-2	GUTUR_66	16:05	16:24	0:19	LINE FAULT
708	9-May-20	TUMKUR	220	THALLAK 220kV- HIREMALLANAHOLE	THALLAKK_220	9:21	12:11	2:50	LINE CLEAR AVAILED
709	10-May-20	BAGALKOT	110	110/11KV,HV1	BILAGI_110	13:34	13:49	0:15	TRANSFORMER FAULT
710	10-May-20	BAGALKOT	110	110/11KV,HV1	CHIKKODI_110	15:00	16:25	1:25	LINE CLEAR AVAILED
711	10-May-20	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	20:13	20:21	0:08	TRANSFORMER FAULT
712	10-May-20	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	9:16	15:57	6:41	LINE CLEAR AVAILED
713	10-May-20	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	19:11	19:15	0:04	TRANSFORMER FAULT
714	10-May-20	BAGALKOT	110	110/11KV,HV1	NAREGALL_110	16:07	16:20	0:13	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
715	10-May-20	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	16:06	16:13	0:07	TRANSFORMER FAULT
716	10-May-20	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110,KABBUR_33,VIJAY NAGAR_33	9:55	11:45	1:50	LINE CLEAR AVAILED
717	10-May-20	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110,KERUR_33,KAROSHI_33	13:56	16:31	2:35	LINE CLEAR AVAILED
718	10-May-20	BAGALKOT	110	110/33KV,HV4	KANABARGI LAYOUT_110, KAKTI_33	9:16	15:57	6:41	LINE CLEAR AVAILED
719	10-May-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110	15:03	15:35	0:06	TRANSFORMER FAULT
720	10-May-20	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	18:43 (10.05.2020)			LINE IS OPEN: LINE FAULT
721	10-May-20	BAGALKOT	110	BELGAUM220KANABARGI LAYOUT	KANABARGI LAYOUT_110	22:03	22:12	0:09	LINE CLEAR AVAILED
722	10-May-20	BAGALKOT	110	BIDNAL220-ANNIGERI	NO STATION EFFECTED	20:40 (09.05.2020)	12:48	15:50	LINE CHARGED
723	10-May-20	BAGALKOT	110	BIDNAL220-NAVALGUND	NO STATION EFFECTED	20:03 (09.05.2020)	10:32	14:29	LINE CHARGED
724	10-May-20	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	21:26 (9.5.2020)	12:03	14:37	LINE CHARGED
725	10-May-20	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	5:52	6:55	1:03	LINE FAULT
726	10-May-20	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	15:04	16:25	1:21	LINE CLEAR AVAILED
727	10-May-20	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	11:44	11:52	0:08	HAND TRIPPED
728	10-May-20	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	18:36	18:54	0:18	LINE CLEAR AVAILED
729	10-May-20	BAGALKOT	110	ENERCON-BIJAPUR	BIJAPUR_220	22:03	22:12	0:09	LINE CLEAR AVAILED
730	10-May-20	BAGALKOT	110	GADAD-ANNIGERI	ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
731	10-May-20	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED	16:19 (08.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
732	10-May-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	14:48	17:51	3:03	LINE FAULT
733	10-May-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	16 (10.05.2020)			LINE IS OPEN: LINE FAULT
734	10-May-20	BAGALKOT	110	HIDIKAL-RAIBAG(ITANAL)	HIDIKAL_110	7:45	17:19	9:34	LINE CLEAR AVAILED
735	10-May-20	BAGALKOT	110	KANABARGI LAYOUT- NEHRU NAGAR	KANABARGI LAYOUT_110	15:57	16:28	0:31	LINE CLEAR AVAILED
736	10-May-20	BAGALKOT	110	MK HUBLI-HIRE BAGEWADI	HIRE BAGEWADI_110	21:58 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
737	10-May-20	BAGALKOT	110	RON-GAMESH	RON_110	8:52	16:56	8:04	LINE CLEAR AVAILED
738	10-May-20	BAGALKOT	110	SANKESHWAR-CHIKKODI	SANKESHWAR_110	11:43 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
739	10-May-20	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110	0:54 (04.05.2020)	12:01	12:07	LINE CHARGED
740	10-May-20	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110,SHIVASAGAR SUGARS_IPP	13:03	17:17	4:14	LINE CLEAR AVAILED
741	10-May-20	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110,SHIVASAGAR SUGARS_IPP	17:44	17:53	0:09	HAND TRIPPED
742	10-May-20	BAGALKOT	110	SOUDATTI-RAMDURGA1	RAMDURGA_110	13:44	14:24	0:40	LINE FAULT
743	10-May-20	BAGALKOT	110	SOUDATTI-RAMDURGA2	RAMDURGA_110	13:44	14:31	0:47	LINE FAULT
744	10-May-20	BAGALKOT	110	SOUDATTI-UDIKERI	UDIKERI_110	13:44	14:31	0:47	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
745	10-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN: LINE FAULT
746	10-May-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	21:15 (14.04.2020)	19:45	646 hrs	LINE CHARGED
747	10-May-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	21:56 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
748	10-May-20	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	22:02 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
749	10-May-20	BAGALKOT	220	GADAG220-DHONI1	GADAG_220	15:07	15:46	0:39	LINE FAULT
750	10-May-20	BAGALKOT	220	RANEENNUR-SHIRALKOPPA	NO STATION EFFECTED RANEENNUR_220	7:37 (09.05.2020)	17:35	9:58	LINE CHARGED
751	10-May-20	BAGALKOT	220	RANEENNUR-SHIRALKOPPA	RANEENNUR_220	21:25 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
752	10-May-20	BENGALURU	66	ALUR - NELAMANAGALA 66	ALUR, BIEC	10:50	10:55	0:05	LOAD CHANGE OVER
753	10-May-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	17:06	17:24	0:18	MAIN SUPPLY FAILURE
754	10-May-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	8:10	8:30	0:20	MAIN SUPPLY FAILURE
755	10-May-20	BENGALURU	66	BRINDAVANA - SRS PEENYA 220	BRINDAVANA	9:04	10:37	1:33	LINE CLEAR AVAILED
756	10-May-20	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI	10:00	16:45	6:45	LINE CLEAR AVAILED
757	10-May-20	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	6:03	6:12	0:09	LINE CLEAR AVAILED
758	10-May-20	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	6:44	7:16	0:32	LINE FAULT
759	10-May-20	BENGALURU	66	DALASANUR - YELDUR	YELDUR, SRINIVASPURA	3:30	3:35	0:05	LINE CLEAR AVAILED
760	10-May-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:13	18:22	0:09	LINE FAULT
761	10-May-20	BENGALURU	66	DOMMASANDRA - YARANDANAHALLI 220	DOMMASANDRA	6:05	6:10	0:05	LOAD CHANGE OVER
762	10-May-20	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA	17:06	17:26	0:20	MAIN SUPPLY FAILURE
763	10-May-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	1:24	1:47	0:23	LINE FAULT
764	10-May-20	BENGALURU	66	HV1	ELECTRONIC CITY PH2 SEC- 2	8:18	8:30	0:12	TRANSFORMER FAULT
765	10-May-20	BENGALURU	66	HV1	RANGANDODDI	12:56	14:16	1:19	LINE CLEAR AVAILED
766	10-May-20	BENGALURU	66	HV2	VIJAYANAGARA	12:21	12:28	0:07	LOAD CHANGE OVER
767	10-May-20	BENGALURU	66	HV2	RANGANDODDI	12:56	14:16	1:19	LINE CLEAR AVAILED
768	10-May-20	BENGALURU	66	HV2	SM MANGALA	16:04	16:22	0:18	LINE CLEAR AVAILED
769	10-May-20	BENGALURU	66	HV3	EPIP 220	9:31	12:27	2:56	LINE CLEAR AVAILED
770	10-May-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	22:42(9.5.20)	3:27	4:45 hrs	LINE CHARGED
771	10-May-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	22:42(9.5.20)	3:27	4:45 hrs	LINE CHARGED
772	10-May-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:42(9.5.20)	3:17	4:35 hrs	LINE CHARGED
773	10-May-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	22:42(9.5.20)	3:29	4:47 hrs	LINE CHARGED
774	10-May-20	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSUR	22:42(9.5.20)	3:17	4:35 hrs	LINE CHARGED
775	10-May-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	22:42(9.5.20)	3:27	4:45 hrs	LINE CHARGED
776	10-May-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	22:42(9.5.20)	3:29	4:47 hrs	LINE CHARGED
777	10-May-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	22:42(9.5.20)	3:16	4:34 hrs	LINE CHARGED
778	10-May-20	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	22:05	22:10	0:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
779	10-May-20	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKHMI LAYOUT	22:05	22:10	0:05	LOAD CHANGE OVER
780	10-May-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	17:06	17:23	0:17	LINE CLEAR AVAILED
781	10-May-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:45	17:05	0:20	LINE FAULT
782	10-May-20	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA	20:44	20:53	0:09	LINE CLEAR AVAILED
783	10-May-20	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	21:46	21:57	0:11	LOAD CHANGE OVER
784	10-May-20	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	21:46	21:51	0:05	LOAD CHANGE OVER
785	10-May-20	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	17:06	17:20	0:14	MAIN SUPPLY FAILURE
786	10-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:23	8:25	0:02	LOAD CHANGE OVER
787	10-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:49	10:51	0:02	LOAD CHANGE OVER
788	10-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:21	17:24	0:02	LOAD CHANGE OVER
789	10-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	21:02	21:04	0:02	LOAD CHANGE OVER
790	10-May-20	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	20:45	20:51	0:05	LOAD CHANGE OVER
791	10-May-20	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	17:08	17:27	0:19	MAIN SUPPLY FAILURE
792	10-May-20	BENGALURU	66	RMV - HEBBAL 220	RMV	21:11	21:16	0:05	LOAD CHANGE OVER
793	10-May-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	17:06	17:19	0:13	MAIN SUPPLY FAILURE
794	10-May-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	17:06	17:10	0:04	MAIN SUPPLY FAILURE
795	10-May-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	21:11	21:16	0:05	LOAD CHANGE OVER
796	10-May-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	6:09	6:11	0:02	LOAD CHANGE OVER
797	10-May-20	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	12:42	12:55	0:12	LINE CLEAR AVAILED
798	10-May-20	BENGALURU	66	SRS PEENYA 220 - DG2	NELAMANGALA 66	8:14	8:30	0:16	LINE FAULT
799	10-May-20	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	17:10	20:35	3:25	LINE CLEAR AVAILED
800	10-May-20	BENGALURU	66	SRS PEENYA 220 - T G HALLI	TAVAREKERE	10:12	16:45	6:33	LINE CLEAR AVAILED
801	10-May-20	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	NO STATION AFFECTED	10:47	12:06	1:18	LINE CLEAR AVAILED
802	10-May-20	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	22:41	23:13	0:32	MAIN SUPPLY FAILURE
803	10-May-20	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	16:10	16:30	0:20	MAIN SUPPLY FAILURE
804	10-May-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	22:41	23:13	0:32	MAIN SUPPLY FAILURE
805	10-May-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	16:10	16:30	0:20	MAIN SUPPLY FAILURE
806	10-May-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	22:41	23:13	0:32	MAIN SUPPLY FAILURE
807	10-May-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:10	16:30	0:20	MAIN SUPPLY FAILURE
808	10-May-20	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	13:34(9.5.20)	11:10	21:35 hrs	LINE FAULT
809	10-May-20	BENGALURU	220	HV1	VIKAS TECH PARK 220	22:41	23:13	0:32	MAIN SUPPLY FAILURE
810	10-May-20	BENGALURU	220	HV1	VIKAS TECH PARK 220	16:10	16:30	0:20	MAIN SUPPLY FAILURE
811	10-May-20	BENGALURU	220	HV2	SRS PEENYA 220	17:10	20:31	3:21	TRANSFORMER FAULT
812	10-May-20	BENGALURU	220	HV2	VIKAS TECH PARK 220	22:41	23:13	0:32	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
813	10-May-20	BENGALURU	220	HV2	VIKAS TECH PARK 220	16:10	16:30	0:20	MAIN SUPPLY FAILURE
814	10-May-20	BENGALURU	220	HV3	SRS PEENYA 220	10:05	16:33	6:28	LINE CLEAR AVAILED
815	10-May-20	BENGALURU	220	HV4	SRS PEENYA 220	17:10	20:32	3:22	TRANSFORMER FAULT
816	10-May-20	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	22:41(9.5.20)	3:15	4:33 hrs	LINE FAULT
817	10-May-20	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	22:41(9.5.20)	3:25	4:43 hrs	LINE FAULT
818	10-May-20	GULBARGA	66	ITTAGI-HIRAHADAGALI1	HIREHADAGALI_66	1:23	18:50	17:27	LINE FAULT
819	10-May-20	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	18:38	18:55	0:17	LINE FAULT
820	10-May-20	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110, NIRNA_110	10:24	10:34	0:10	LOAD CURTAILMENT
821	10-May-20	GULBARGA	110	HV1	CHINCHOLI_110	10:28	10:31	0:03	LINE CLEAR AVAILED
822	10-May-20	GULBARGA	110	HV1	HANUMASAGAR_110	9:40	10:00	0:20	TRANSFORMER FAULT
823	10-May-20	GULBARGA	110	HV1	HANUMASAGAR_110	14:10	14:25	0:15	TRANSFORMER FAULT
824	10-May-20	GULBARGA	110	HV2	SHAHAPUR_220	14:28	14:41	0:13	TRANSFORMER FAULT
825	10-May-20	GULBARGA	110	HV2	SHAHAPUR_220	14:52	15:18	0:26	TRANSFORMER FAULT
826	10-May-20	GULBARGA	110	HV2	SHORAPUR_110	16:30	16:34	0:04	TRANSFORMER FAULT
827	10-May-20	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATGIRI_110, GANGAVATHI_110,SREERAMNAGAR_110,KARTAGI_110	14:10	14:30	0:20	LINE FAULT
828	10-May-20	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	13:26	13:32	0:06	LINE FAULT
829	10-May-20	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	13:26	13:33	0:07	LINE FAULT
830	10-May-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110	3:43	3:48	0:05	LINE FAULT
831	10-May-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110	20:14	20:24	0:10	LINE FAULT
832	10-May-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110	20:17	20:31	0:14	LINE FAULT
833	10-May-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPUR_110	3:00	3:15	0:15	LINE FAULT
834	10-May-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPUR_110	14:44	14:56	0:12	LINE FAULT
835	10-May-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPUR_110	15:00	16:23	1:23	LINE FAULT
836	10-May-20	GULBARGA	220	HV1, HV2	ITTAGI_220	14:50	15:02	0:12	TRANSFORMER FAULT
837	10-May-20	GULBARGA	220	ITTAGI-NEELAGUNDA	ITTAGI_220	14:50	15:22	0:32	LINE FAULT
838	10-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
839	10-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
840	10-May-20	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	22:22(8.5.20)	4:22	5:59 hrs	LINE FAULT
841	10-May-20	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	11:00	11:16	0:16	LINE FAULT
842	10-May-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:00	17:33	8:33	LINE CLEAR AVAILED
843	10-May-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:00	17:33	8:33	LINE CLEAR AVAILED
844	10-May-20	HASSAN	110	HV2	KONAJE_110	10:14	12:12	1:58	LINE CLEAR AVAILED
845	10-May-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	16:59	17:19	0:20	MAIN SUPPLY FAILURE
846	10-May-20	HASSAN	110	KONJE-MANJESWARG	KONAJE_110	17:24	17:59	0:35	LINE FAULT
847	10-May-20	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	8:34	9:36	1:02	LOAD CHANGE OVER
848	10-May-20	HASSAN	110	MRSSHM-BADRAVATY2	MRS MG_220	8:33	9:36	1:03	LOAD CHANGE OVER
849	10-May-20	HASSAN	220	HASSN22-CHIKMAGALUR	HASSAN_220	17:43 (9.05.2020)	1:26	7:42	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
850	10-May-20	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	18:20	21:13	2:53	LINE FAULT
851	10-May-20	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	16:28	16:52	0:24	LINE FAULT
852	10-May-20	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	17:47	20:32	2:45	LINE FAULT
853	10-May-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	17:47	20:32	2:45	LINE FAULT
854	10-May-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	18:20	21:13	2:53	LINE FAULT
855	10-May-20	HASSAN	400	UPCL-HASSAN2	NO STATION AFFECTED	18:15 (7.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
856	10-May-20	MYSORE	66	HV2	HOOTAGALLY_220	23:10:00(10.05.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
857	10-May-20	MYSORE	66	KADAKOLA-SARAGUR-1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66 B MATKERE_66 SANTHESARAGUR_66	7:48	7:53	0:05	LINE FAULT
858	10-May-20	MYSORE	66	KUSHALANAGARA-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	8:00	8:13	0:13	LINE FAULT
859	10-May-20	MYSORE	66	KUSHALANAGARA-MYSORE-1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	8:00	8:09	0:09	LINE FAULT
860	10-May-20	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	DKMAIDANA_66 JYOTHINAGARA_66	6:01	6:21	0:20	LINE FAULT
861	10-May-20	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	11:15	11:27	0:11	LINE FAULT
862	10-May-20	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:33	12:30	1:56	LINE CLEAR AVAILED
863	10-May-20	TUMKUR	66	TR-1	PAVAGADA_220	7:30	8:01	0:30	TRANSFORMER FAULT
864	10-May-20	TUMKUR	66	TR-1	YEDIYUR_66	12:11	12:48	0:36	LINE CLEAR AVAILED
865	10-May-20	TUMKUR	66	TR-1	YEDIYUR_66	14:16	14:41	0:24	TRANSFORMER FAULT
866	10-May-20	TUMKUR	66	TR-1	SHYLAPURA_66	9:02	9:30	0:27	TRANSFORMER FAULT
867	10-May-20	TUMKUR	66	TR-1	SHYLAPURA_66	11:35(10.5.20)			TRANSFORMER IS OPEN :TRANSFORMER FAULT
868	10-May-20	TUMKUR	66	TR-2	MANGALWADA_66	3:10	3:14	0:03	MAIN SUPPLY FAILURE
869	10-May-20	TUMKUR	220	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	18:01	19:06	1:04	LINE FAULT
870	10-May-20	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	14:49	15:08	0:19	LINE FAULT
871	10-May-20	TUMKUR	220	TR-1&TR-2	NEELAGUNDA_220	15:10	15:18	0:08	MAIN SUPPLY FAILURE
872	11-May-20	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	9:51	9:57	0:06	TRANSFORMER FAULT
873	11-May-20	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	10:48	11:18	0:30	TRANSFORMER FAULT
874	11-May-20	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	10:36	13:57	3:21	LINE CLEAR AVAILED
875	11-May-20	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	18:43 (10.05.2020)	11:02	16:19	LINE CHARGED
876	11-May-20	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	8:02	19:04	11:02	LINE CLEAR AVAILED
877	11-May-20	BAGALKOT	110	GADAD-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
878	11-May-20	BAGALKOT	110	GHTAPRABHA-HIDIKAL DAM	NO STATION EFFECTED HIDIKAL DAM_110	16:19 (08.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
879	11-May-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	16:00 (10.05.2020)	13:48	21:48	LINE CHARGED
880	11-May-20	BAGALKOT	110	HIDIKAL-ITNAL(RAIBAG)	ITNAL_110	20:13(11.5.20)			LINE IS OPEN: LINE CLEAR AVAILED
881	11-May-20	BAGALKOT	110	INDI-HIREBEVANUR	HIREBEVANUR_110	15:01(11.5.20)	17:50	2:49	LINE CHARGED
882	11-May-20	BAGALKOT	110	MK HUBLI-HIRE BAGEWADI	HIRE BAGEWADI_110	21:58 (10.05.2020)	6:29	8:31	LINE CHARGED
883	11-May-20	BAGALKOT	110	SANKESHWAR-CHIKKODI	NO STATION EFFECTED SANKESHWAR_110	11:43 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
884	11-May-20	BAGALKOT	110	SHIVAKUMAR SUGAR-HIREBEVANUR	HIREBEVANUR_110	15:01	17:51	2:50	LINE FAULT
885	11-May-20	BAGALKOT	110	SOUBAGYALAXMI-MAMADAPUR(G)	MAMADAPUR(G)_110	14:00	17:13	3:13	LINE CLEAR AVAILED
886	11-May-20	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	22:43(11.5.20)			LINE IS OPEN: LINE FAULT
887	11-May-20	BAGALKOT	110	VAJRAMATTI220-KATARAKI	KATARAKI_110	10:08	11:46	1:38	LINE CLEAR AVAILED
888	11-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE IS OPEN: LINE FAULT
889	11-May-20	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	21:56 (10.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
890	11-May-20	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	22:02 10.05.2020)	6:32	8:30	LINE CHARGED
891	11-May-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	22:19(11.5.20)			LINE IS OPEN: LINE FAULT
892	11-May-20	BAGALKOT	220	RANEBENNUR-SHIRALKOPPA	RANEBENNUR_220	21:25 (10.05.2020)	10:08	12:43	LINE CHARGED
893	11-May-20	BAGALKOT	220	RANEBENNUR-SHIRALKOPPA	RANEBENNUR_220	20:33(11.5.20)			LINE IS OPEN: LINE FAULT
894	11-May-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	NO STATION AFFECTED	9:45	11:00	1:15	LINE CLEAR AVAILED
895	11-May-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	NO STATION AFFECTED	11:00	11:25	0:25	LINE CLEAR AVAILED
896	11-May-20	BENGALURU	66	HEBBAL 220 - L R BANDE	L R BANDE	12:03	12:10	0:07	LINE CLEAR AVAILED
897	11-May-20	BENGALURU	66	HEBBALA 220 - MATHIKERE	NO STATION AFFECTED	11:00	13:19	2:19	LINE CLEAR AVAILED
898	11-May-20	BENGALURU	66	HEBBALA 220 - PEENYA 2	NO STATION AFFECTED	11:31	13:20	1:49	LINE CLEAR AVAILED
899	11-May-20	BENGALURU	66	HEBBALA 220 - POTTERY ROAD	NO STATION AFFECTED	12:45	13:44	0:59	LINE CLEAR AVAILED
900	11-May-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	12:50	13:06	0:16	LINE FAULT
901	11-May-20	BENGALURU	66	HV1	HEBBAL 220	17:04	18:10	1:06	LINE CLEAR AVAILED
902	11-May-20	BENGALURU	66	HV1	HEBBAL 220	15:07	16:58	1:51	LINE CLEAR AVAILED
903	11-May-20	BENGALURU	66	HV1	VOLVO	18:25	18:39	0:13	TRANSFORMER FAULT
904	11-May-20	BENGALURU	66	HV1	PATHPALYA	12:01	13:57	1:55	LINE CLEAR AVAILED
905	11-May-20	BENGALURU	66	HV1	PADMANBHANAGAR	13:33	13:45	0:11	LINE CLEAR AVAILED
906	11-May-20	BENGALURU	66	HV1	PADMANBHANAGAR	15:36	15:56	0:20	LINE CLEAR AVAILED
907	11-May-20	BENGALURU	66	HV1	LEELA VENTURE	14:45	15:57	1:12	LINE CLEAR AVAILED
908	11-May-20	BENGALURU	66	HV1	KEMBODI	14:18	14:35	0:16	LINE CLEAR AVAILED
909	11-May-20	BENGALURU	66	HV2	HOODY 220	10:14	10:17	0:03	LINE CLEAR AVAILED
910	11-May-20	BENGALURU	66	HV2	VOLVO	18:39	18:51	0:12	TRANSFORMER FAULT
911	11-May-20	BENGALURU	66	HV2	PADMANBHANAGAR	13:34	13:45	0:11	LINE CLEAR AVAILED
912	11-May-20	BENGALURU	66	HV2	PADMANBHANAGAR	15:36	15:56	0:20	LINE CLEAR AVAILED
913	11-May-20	BENGALURU	66	HV2	LEELA VENTURE	10:21	10:30	0:08	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
914	11-May-20	BENGALURU	66	HV2	KEMBODI	14:55	15:29	0:34	LINE CLEAR AVAILED
915	11-May-20	BENGALURU	66	HV3	HEBBAL 220	13:30	14:30	1:00	LINE CLEAR AVAILED
916	11-May-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KUMBALAGODU,CHANDRAPPA CIRCLE	10:48	11:18	0:30	LINE FAULT
917	11-May-20	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	6:21	6:25	0:04	LINE FAULT
918	11-May-20	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	13:10	13:12	0:02	LOAD CHANGE OVER
919	11-May-20	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	11:00	15:52	4:52	LINE CLEAR AVAILED
920	11-May-20	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	16:29	16:39	0:10	LINE FAULT
921	11-May-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	12:20	12:25	0:05	LINE FAULT
922	11-May-20	GULBARGA	110	HV1	HANUMASAGAR_110	21:40	22:00	0:20	TRANSFORMER FAULT
923	11-May-20	GULBARGA	110	HV1, HV2	YELBURGA_110	11:48	14:05	2:17	LINE CLEAR AVAILED
924	11-May-20	GULBARGA	110	HV2	SHORAPUR_110	21:25	21:46	0:21	TRANSFORMER FAULT
925	11-May-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	9:00	16:00	7:00	LINE CLEAR AVAILED
926	11-May-20	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	19:24	19:38	0:14	LINE FAULT
927	11-May-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	5:13	5:28	0:15	LINE FAULT
928	11-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
929	11-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE IS OPEN: LINE FAULT
930	11-May-20	GULBARGA	220	KUSTAGI-LINGAPUR	KUSTAGI_220	10:56	14:35	3:39	NFBC ISSUED
931	11-May-20	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	19:05(11.5.20)			LINE IS OPEN: LINE FAULT
932	11-May-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	22:06	22:47	0:41	LINE FAULT
933	11-May-20	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	21:56	23:08	1:12	LINE FAULT
934	11-May-20	HASSAN	66	HV1	AREHALLI_HSN_66	13:39	13:46	0:07	TRANSFORMER FAULT
935	11-May-20	HASSAN	66	HV1	SHRAVANABELAGOLA_66	8:41	8:53	0:12	TRANSFORMER FAULT
936	11-May-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	13:35	13:40	0:05	HAND TRIPPED
937	11-May-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	21:56	23:05	1:09	LINE FAULT
938	11-May-20	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	5:46	6:04	0:18	LINE FAULT
939	11-May-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	5:46	6:08	0:22	LINE FAULT
940	11-May-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	11:02	14:26	3:24	LINE CLEAR AVAILED
941	11-May-20	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	7:39	7:58	0:19	HAND TRIPPED
942	11-May-20	HASSAN	110	HV1	KARAYA_110	13:03	14:48	1:45	LINE CLEAR AVAILED
943	11-May-20	HASSAN	110	HV1	KONAJE_110	10:24	10:27	0:03	HAND TRIPPED
944	11-May-20	HASSAN	110	HV2	KARAYA_110	10:25	12:54	2:29	LINE CLEAR AVAILED
945	11-May-20	HASSAN	110	HV2	KONAJE_110	10:24	10:27	0:03	HAND TRIPPED
946	11-May-20	HASSAN	110	HV3	KONAJE_110	10:24	10:27	0:03	HAND TRIPPED
947	11-May-20	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	12:04	13:54	1:50	LINE CLEAR AVAILED
948	11-May-20	HASSAN	110	KEMAR-BELMAN	KEMAR_220	10:51	12:53	2:02	LINE CLEAR AVAILED
949	11-May-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	21:28	22:55	1:27	LINE FAULT
950	11-May-20	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:31	12:57	2:26	LINE CLEAR AVAILED
951	11-May-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	20:20	21:06	0:46	LINE FAULT
952	11-May-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:05	13:32	0:27	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
953	11-May-20	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	10:03	15:50	5:47	LINE CLEAR AVAILED
954	11-May-20	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	10:26	12:41	2:15	LINE CLEAR AVAILED
955	11-May-20	HASSAN	220	KEMAR-Varahi1	KEMAR-220	11:39	12:15	0:36	LINE FAULT
956	11-May-20	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:03	15:50	5:47	NFBC ISSUED
957	11-May-20	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:27	12:42	2:15	NFBC ISSUED
958	11-May-20	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	9:41	11:17	1:36	LINE FAULT
959	11-May-20	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:18	13:33	2:15	LINE FAULT
960	11-May-20	HASSAN	220	SHRAVTY-TALGUPPA3	sharavathy_gen	11:10	14:55	3:45	LINE FAULT
961	11-May-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	9:41	11:17	1:36	LINE FAULT
962	11-May-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:18	13:33	2:15	LINE FAULT
963	11-May-20	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	11:10	14:55	3:45	LINE FAULT
964	11-May-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:39	12:21	0:42	LINE FAULT
965	11-May-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:15 (7.05.2020)	10:18	16:02	LINE CHARGED
966	11-May-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:13 (11.05.2020)			LINE IS OPEN: LINE CLEAR AVAILED
967	11-May-20	MYSORE	66	DODDINADUVADI-HV2	DODDINADUVADI_66	10:48	11:42	0:53	LINE CLEAR AVAILED
968	11-May-20	MYSORE	66	G UKKADA-TUBINAKERE	NO STATIONS EFFECTED	15:38	16:43	1:05	LINE CLEAR AVAILED
969	11-May-20	MYSORE	66	HV1	ARAKERE_66	9:32	12:35	3:02	LINE CLEAR AVAILED
970	11-May-20	MYSORE	66	HV1	BANNUR_66	12:51	14:10	1:18	LINE CLEAR AVAILED
971	11-May-20	MYSORE	66	HV1	DODDINADUVADI_66	10:48	11:42	0:53	LINE CLEAR AVAILED
972	11-May-20	MYSORE	66	HV1	SANIVARASANTHE_66	14:47	14:49	0:02	TRANSFORMER FAULT
973	11-May-20	MYSORE	66	HV1	HARADANAHALLI(JAK)_66	10:10	14:25	4:15	LINE CLEAR AVAILED
974	11-May-20	MYSORE	66	HV1	JAKKANAHALLY_66	10:10	15:36	5:26	LINE CLEAR AVAILED
975	11-May-20	MYSORE	66	HV1	MADESWARAPURA_66	10:15	14:15	4:00	LINE CLEAR AVAILED
976	11-May-20	MYSORE	66	HV2	HDKOTE_66	8:02	8:56	0:54	LINE CLEAR AVAILED
977	11-May-20	MYSORE	66	HV2	HARADANAHALLI(JAK)_66	10:10	14:25	4:15	LINE CLEAR AVAILED
978	11-May-20	MYSORE	66	HV2	JAKKANAHALLY_66	10:10	15:36	5:26	LINE CLEAR AVAILED
979	11-May-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	6:17	6:27	0:09	LINE FAULT
980	11-May-20	MYSORE	66	KR PET-KIKERI	KIKKERI_66	11:11	15:22	4:11	LINE CLEAR AVAILED
981	11-May-20	MYSORE	66	MAHADESHWARAPURA	MADESWARAPURA_66	9:25	17:20	7:55	LINE CLEAR AVAILED
982	11-May-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	13:48	13:53	0:04	LINE FAULT
983	11-May-20	MYSORE	66	VAJMANGALA-DEVNOOR MYSORE	DEVANOORMYS_66, RAJEEVNAGARA_66	15:46	16:07	0:20	LINE FAULT
984	11-May-20	MYSORE	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66,FTS_66 ,DKMAID ANA_66	12:52	13:06	0:13	LINE FAULT
985	11-May-20	MYSORE	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66, FTS_66, DKMAIDANA_66	15:46	16:05	0:18	LINE FAULT
986	11-May-20	MYSORE	66	VAJMANGALA-KADKOLA 1	AYRALLI_66, MARADIHUNDI_66	18:31	18:39	0:08	LINE FAULT
987	11-May-20	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	8:14	8:17	0:03	HAND TRIPPED
988	11-May-20	TUMKUR	66	BELADADARA-KORATAGERE	BELADARA_66	9:09	9:15	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
989	11-May-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:33	17:24	0:50	HAND TRIPPED
990	11-May-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:31	17:35	3:03	LINE CLEAR AVAILED
991	11-May-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	7:46	7:51	0:05	HAND TRIPPED
992	11-May-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:30	13:37	0:07	LINE FAULT
993	11-May-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	19:57	20:06	0:08	LINE FAULT
994	11-May-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAGIRI_66	12:25	13:37	1:12	LINE CLEAR AVAILED
995	11-May-20	TUMKUR	66	THALLAK 220KV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	7:48	20:25	12:36	LINE CLEAR AVAILED
996	11-May-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	14:07	14:14	0:06	TRANSFORMER FAULT
997	11-May-20	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	11:12	13:29	2:17	LINE CLEAR AVAILED
998	11-May-20	TUMKUR	66	TR-1	KALAMARANAHALLI_66	16:16	18:43	2:27	LINE CLEAR AVAILED
999	11-May-20	TUMKUR	66	TR-1	PANDARAHALLI_66	21:57	21:59	0:01	HAND TRIPPED
1000	11-May-20	TUMKUR	66	TR-1	PAVAGADA_220	11:20	11:28	0:07	TRANSFORMER FAULT
1001	11-May-20	TUMKUR	66	TR-3	HONNALI_66	6:17	6:38	0:21	HAND TRIPPED
1002	11-May-20	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	15:38	16:04	0:25	LINE CLEAR AVAILED
1003	11-May-20	TUMKUR	110	HANDANKERE_110-K B CROSS 220	HANDANKERE_110	16:04	16:06	0:02	LINE CLEAR AVAILED
1004	11-May-20	TUMKUR	110	TR-1	HANDANKERE_110	16:04	16:06	0:02	LINE CLEAR AVAILED
1005	11-May-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:27	13:52	0:24	LINE FAULT
1006	11-May-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:26	13:50	0:24	LINE FAULT