

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 22.01.2019 to 28.01.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	22-Jan-19	BAGALKOT	110	BETAGERI- NAREGAL	NAREGAL_110	9:54	9:59	0:05	HAND TRIPPED
2	22-Jan-19	BAGALKOT	110	220/110KV,LV-1&2	BELAGAUM_220	5:21	13:03	7:42	HAND TRIPPED
3	22-Jan-19	BAGALKOT	110	BELGAUM-HUKKERI(UCHAGOAN)	UCHAGOAN_110	5:41	13:20	7:39	LOAD CURTAILMENT
4	22-Jan-19	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	6:30	6:57	0:27	LINE FAULT
5	22-Jan-19	BAGALKOT	220	CHIKKODI-KOLHAPUR1(TALANADAGE)	CHIKKODI_220	6:57	20:23	13:26	LINE FAULT
6	22-Jan-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA2(KUDACHI 2)	CHIKKODI_220	7:51	8:05	0:14	LINE CLEAR AVAILED
7	22-Jan-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	5:06	23:59	18:53	LINE FAULT
8	22-Jan-19	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	10:13	13:27	3:14	LINE CLEAR AVAILED
9	22-Jan-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	6:02	16:23	10:21	LINE FAULT
10	22-Jan-19	BAGALKOT	220	DHONI 400KV-GADAG1	GADAG_220	5:03	21:19	16:16	LINE FAULT
11	22-Jan-19	BAGALKOT	220	DHONI 400KV-GADAG2	GADAG_220	5:03	21:20	16:17	LINE FAULT
12	22-Jan-19	BAGALKOT	110	GADAG 220-SHIRAHATTI	SHIRAHATTI_110	4:32	14:09	9:37	LINE FAULT
13	22-Jan-19	BAGALKOT	110	GADAG 220-BETAGERI	BETAGERI_110	5:37	9:42	4:05	LINE FAULT
14	22-Jan-19	BAGALKOT	110	110/11KV,HV5	GHATABRABHA_110	11:00	19:41	8:41	HAND TRIPPED
15	22-Jan-19	BAGALKOT	110	HAVERI 220KV-HANGAL	HANGAL_110	2:55	11:40	8:45	LINE FAULT
16	22-Jan-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA 33KV	11:42	11:49	0:07	HAND TRIPPED
17	22-Jan-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110(NO STATION INTERRUPTED)	11:42	11:49	0:07	HAND TRIPPED
18	22-Jan-19	BAGALKOT	110	GOPPANAKOPPA	GOPPANAKOPPA_110	5:41	15:24	9:43	LINE FAULT
19	22-Jan-19	BAGALKOT	110	HATTARGI-DADDI	DADDI_110	0:18	9:40	9:22	LINE FAULT
20	22-Jan-19	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI 33KV	6:02	6:09	0:07	TRANSFORMER FAULT
21	22-Jan-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA 33KV,SULTANPURA_33	18:26	18:40	0:14	LOAD CURTAILMENT
22	22-Jan-19	BAGALKOT	110	HIREHAL-RON	HIREHAL_10	10:07	23:59	13:52	HAND TRIPPED
23	22-Jan-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	6:50	11:35	4:45	LINE FAULT
24	22-Jan-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	6:02	16:48	10:46	LINE FAULT
25	22-Jan-19	BAGALKOT	110	BPCL1-SHIRHATTI	SHIRHATTI_110	4:57	5:06	0:09	MAIN SUPPLY FAILURE
26	22-Jan-19	BAGALKOT	110	BPCL1-SHIRHATTI	SHIRHATTI_110	7:15	8:12	0:57	MAIN SUPPLY FAILURE
27	22-Jan-19	BAGALKOT	110	BPCL2-SHIRHATTI	SHIRHATTI_110	4:57	5:14	0:17	MAIN SUPPLY FAILURE
28	22-Jan-19	BAGALKOT	110	BPCL2-SHIRHATTI	SHIRHATTI_110	8:12	8:19	0:07	MAIN SUPPLY FAILURE
29	22-Jan-19	BAGALKOT	110	GADAG220-SHIRHATTI	SHIRHATTI_110	4:57	23:59	19:02	LINE FAULT
30	22-Jan-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	7:02	15:33	8:31	LINE FAULT
31	22-Jan-19	BAGALKOT	110	RON-GAJENDRAGA1	GAJENDRAGAD_110	7:37	7:38	0:01	MAIN SUPPLY FAILURE
32	22-Jan-19	BAGALKOT	110	RON-GAJENDRAGA2	GAJENDRAGAD_110	7:37	7:39	0:02	MAIN SUPPLY FAILURE
33	22-Jan-19	BAGALKOT	110	GAMESHA-RON	RON_110	7:37	7:42	0:05	MAIN SUPPLY FAILURE
34	22-Jan-19	BAGALKOT	220	NARENDRA-KANBARGI1(BELGAUM2)	NARENDRA_220	5:21	12:57	7:36	LINE FAULT
35	22-Jan-19	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	5:42	6:25	0:43	LINE FAULT
36	22-Jan-19	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	10:43	10:50	0:07	HAND TRIPPED
37	22-Jan-19	BAGALKOT	110	BETAGERI-NARAGAL	NARAGAL_110	7:17	10:02	2:45	MAIN SUPPLY FAILURE
38	22-Jan-19	BAGALKOT	110	RON-NARAGAL	NARAGAL_110	10:02	10:09	0:07	HAND TRIPPED
39	22-Jan-19	BAGALKOT	110	110/11KV,HV1	MUKARTHAL_110	16:53	17:21	0:28	HAND TRIPPED
40	22-Jan-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	16:36	16:50	0:14	TRANSFORMER FAULT
41	22-Jan-19	BAGALKOT	110	ASHOKA IRON PLANT-MACHE	MACHE_110	6:33	7:56	1:23	MAIN SUPPLY FAILURE
42	22-Jan-19	BAGALKOT	110	MK HUBLI 220-BIDI	BIDI_110	8:58	10:03	1:05	LINE FAULT
43	22-Jan-19	BAGALKOT	110	SHIRAHATTI-LAKMESHWAR	LAKMESHWAR_110	4:04	4:47	0:43	LINE FAULT
44	22-Jan-19	BAGALKOT	110	SHIRAHATTI-LAKMESHWAR	LAKMESHWAR_110	4:04	4:47	0:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
45	22-Jan-19	BAGALKOT	110	110/33KV,HV3	KULIGOD_110,AREMALATTI_33, TIGADI_33	15:00	17:02	2:02	HAND TRIPPED
46	22-Jan-19	BAGALKOT	110	BPCL1&2-ITANAL	ITANAL_110	16:35	17:38	1:03	HAND TRIPPED
47	22-Jan-19	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	16:35	17:44	1:09	HAND TRIPPED
48	22-Jan-19	BANGALORE	66	HV1	DALASNUR	7:05	7:07	0:01	HAND TRIPPED
49	22-Jan-19	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:09	8:54	2:44	LINE FAULT
50	22-Jan-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	6:19	8:59	2:39	LINE FAULT
51	22-Jan-19	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	6:09	8:54	2:44	LINE FAULT
52	22-Jan-19	BANGALORE	66	HV1	THIMMAMPALLI	9:43	9:52	0:09	LINE CLEAR AVAILED
53	22-Jan-19	BANGALORE	66	HV2	LAKKUR	12:09	14:00	1:50	LINE CLEAR AVAILED
54	22-Jan-19	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:23	10:30	0:07	LINE FAULT
55	22-Jan-19	BANGALORE	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:24	10:30	0:05	LOAD CHANGE OVER
56	22-Jan-19	BANGALORE	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:25	10:30	0:05	LOAD CHANGE OVER
57	22-Jan-19	BANGALORE	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	5:10	5:14	0:03	LINE CLEAR AVAILED
58	22-Jan-19	BANGALORE	66	HEJJALA - BIDADI 220	HEJJALA	0:00	0:40	0:40	LINE FAULT
59	22-Jan-19	BANGALORE	66	HV2	NRS 220	5:19	5:27	0:07	LINE CLEAR AVAILED
60	22-Jan-19	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	6:35	6:59	0:23	LINE FAULT
61	22-Jan-19	BANGALORE	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA , MANYATA TECH PARK, ABBIGERE	15:35	15:45	0:10	LINE CLEAR AVAILED
62	22-Jan-19	BANGALORE	66	SRS PEENYA 220 - DG2	ALUR, NELAMANGALA 66	6:04	6:27	0:23	LINE FAULT
63	22-Jan-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	6:21	6:24	0:03	LINE CLEAR AVAILED
64	22-Jan-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:44	8:48	0:04	LINE CLEAR AVAILED
65	22-Jan-19	BANGALORE	66	ALUR - NELAMANGALA 66	ALUR	8:44	8:56	0:12	LINE CLEAR AVAILED
66	22-Jan-19	GULBARGA	220	MUNIRABADTR2-LINGAPUR	MUNIRABAD_220	10:02	11:13	1:11	LINE FAULT
67	22-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:45	12:40	0:55	LINE FAULT
68	22-Jan-19	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_110	9:36	13:30	3:54	LINE FAULT
69	22-Jan-19	GULBARGA	110	PDHALLI-CLNMAX	PD_HALLI_110	10:36	13:30	2:54	LINE CLEAR AVAILED
70	22-Jan-19	GULBARGA	110	HV2	BETAGERA_110	10:11	10:14	0:03	TRANSFORMER FAULT
71	22-Jan-19	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	10:02	10:46	0:44	LINE FAULT
72	22-Jan-19	GULBARGA	110	HUMNABAD220-MANEKHALLI	MANEKHALLI_110	9:58	10:08	0:10	LINE CLEAR AVAILED
73	22-Jan-19	GULBARGA	110	HUMNABAD220-HUMNABAD2	HUMNABAD_110	10:02	16:44	6:42	LINE CLEAR AVAILED
74	22-Jan-19	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALLU_11 0	17:19	17:35	0:16	LINE FAULT
75	22-Jan-19	GULBARGA	66	HV2	CHORNOOR_66	12:01	12:10	0:09	TRANSFORMER FAULT
76	22-Jan-19	HASSAN	220	ARSK2-NITTUR	ARSIKERE_220	5:23	14:58	9:35	LINE FAULT
77	22-Jan-19	HASSAN	220	HNPR2-GPLPR1	HOLENARASIPURA_220	8:33	19:24	10:51	LINE CLEAR AVAILED
78	22-Jan-19	HASSAN	220	HNPR2-GPLPR2	HOLENARASIPURA_220	8:33	19:24	10:51	LINE CLEAR AVAILED
79	22-Jan-19	HASSAN	220	HV1	HOLENARASIPURA_220	8:33	19:24	10:51	LINE CLEAR AVAILED
80	22-Jan-19	HASSAN	220	HV2	HOLENARASIPURA_220	8:33	19:24	10:51	LINE CLEAR AVAILED
81	22-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	0:26	11:43	11:17	LINE FAULT
82	22-Jan-19	HASSAN	220	SHRAVITY-SHIMOGA4	SHARAVATHY_GEN	0:25	11:44	11:19	LINE FAULT
83	22-Jan-19	HASSAN	220	SHRAVITY-TALAGUPPA1	SHARAVATHY_GEN	10:01	23:59	13:58	LINE CLEAR AVAILED
84	22-Jan-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	10:00	23:59	13:59	LINE CLEAR AVAILED
85	22-Jan-19	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	8:30	19:13	10:43	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
86	22-Jan-19	HASSAN	220	GOPALAP-HNPUR21	GOPALPURA_220	8:31	19:25	10:54	LINE CLEAR AVAILED
87	22-Jan-19	HASSAN	220	GOPALAP-HNPUR22	GOPALPURA_220	8:31	19:23	10:52	LINE CLEAR AVAILED
88	22-Jan-19	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	8:31	19:18	10:47	LINE CLEAR AVAILED
89	22-Jan-19	HASSAN	220	HV1	GOPALPURA_220	8:46	19:19	10:33	LINE CLEAR AVAILED
90	22-Jan-19	HASSAN	220	HV2	GOPALPURA_220	8:46	19:29	10:43	LINE CLEAR AVAILED
91	22-Jan-19	HASSAN	110	HV2	ARSIKERE_110	17:48	19:40	1:52	TRANSFORMER FAULT
92	22-Jan-19	HASSAN	110	HV2	ARSIKERE_110	19:40	22:50	3:10	TRANSFORMER FAULT
93	22-Jan-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	12:52	13:16	0:24	LINE FAULT
94	22-Jan-19	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	19:28	19:50	0:22	LINE CLEAR AVAILED
95	22-Jan-19	HASSAN	110	HV2	AJJAMPURA_110	10:03	10:27	0:24	LINE CLEAR AVAILED
96	22-Jan-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:55	13:35	0:40	MAIN SUPPLY FAILURE
97	22-Jan-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	12:55	13:19	0:24	MAIN SUPPLY FAILURE
98	22-Jan-19	HASSAN	110	HV3	HIRIYADKA_110	9:28	10:04	0:36	LINE CLEAR AVAILED
99	22-Jan-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	18:45	18:49	0:04	HAND TRIPPED
100	22-Jan-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:00	17:44	0:44	LINE CLEAR AVAILED
101	22-Jan-19	HASSAN	110	HV1	MANIPAL_110	10:34	12:40	2:06	LINE CLEAR AVAILED
102	22-Jan-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	16:57	17:41	0:44	LINE CLEAR AVAILED
103	22-Jan-19	HASSAN	110	HV1	SHIVAPURA_110	12:57	14:20	1:23	TRANSFORMER FAULT
104	22-Jan-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	8:33	9:14	0:41	MAIN SUPPLY FAILURE
105	22-Jan-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	19:30	20:00	0:30	MAIN SUPPLY FAILURE
106	22-Jan-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	13:55	14:10	0:15	MAIN SUPPLY FAILURE
107	22-Jan-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	15:40	17:05	1:25	MAIN SUPPLY FAILURE
108	22-Jan-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	8:33	9:14	0:41	MAIN SUPPLY FAILURE
109	22-Jan-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	19:40	19:45	0:05	MAIN SUPPLY FAILURE
110	22-Jan-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	13:55	14:10	0:15	MAIN SUPPLY FAILURE
111	22-Jan-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	15:40	17:05	1:25	MAIN SUPPLY FAILURE
112	22-Jan-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	8:33	9:14	0:41	MAIN SUPPLY FAILURE
113	22-Jan-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	19:40	19:45	0:05	MAIN SUPPLY FAILURE
114	22-Jan-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	13:55	14:10	0:15	MAIN SUPPLY FAILURE
115	22-Jan-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	15:40	17:05	1:25	MAIN SUPPLY FAILURE
116	22-Jan-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	8:33	9:14	0:41	MAIN SUPPLY FAILURE
117	22-Jan-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	19:03	19:45	0:42	MAIN SUPPLY FAILURE
118	22-Jan-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	13:55	14:10	0:15	MAIN SUPPLY FAILURE
119	22-Jan-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	15:40	17:05	1:25	MAIN SUPPLY FAILURE
120	22-Jan-19	HASSAN	66	Lv1	HOLENARASIPURA_220	8:33	19:24	10:51	LINE CLEAR AVAILED
121	22-Jan-19	HASSAN	66	Lv2	HOLENARASIPURA_220	8:33	19:24	10:51	LINE CLEAR AVAILED
122	22-Jan-19	HASSAN	66	HV2	BELUR_66	10:23	11:12	0:49	LINE CLEAR AVAILED
123	22-Jan-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:20	11:30	1:10	LINE CLEAR AVAILED
124	22-Jan-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	7:52	8:03	0:11	MAIN SUPPLY FAILURE
125	22-Jan-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	19:53	20:04	0:11	MAIN SUPPLY FAILURE
126	22-Jan-19	HASSAN	66	HV1	DODDAKADANUR_66	7:52	8:03	0:11	MAIN SUPPLY FAILURE
127	22-Jan-19	HASSAN	66	HV1	DODDAKADANUR_66	19:53	20:04	0:11	MAIN SUPPLY FAILURE
128	22-Jan-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	7:52	8:03	0:11	MAIN SUPPLY FAILURE
129	22-Jan-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	19:48	20:07	0:19	MAIN SUPPLY FAILURE
130	22-Jan-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	8:11	9:03	0:52	LINE CLEAR AVAILED
131	22-Jan-19	HASSAN	66	HV1	GENDEHALLI_66	8:11	9:03	0:52	LINE CLEAR AVAILED
132	22-Jan-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	8:11	9:03	0:52	LINE CLEAR AVAILED
133	22-Jan-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	10:15	11:40	1:25	NFBC ISSUED
134	22-Jan-19	HASSAN	66	HV1	GENDEHALLI_66	10:15	11:40	1:25	NFBC ISSUED
135	22-Jan-19	HASSAN	66	GENDEHAMUDIGERE	GENDEHALLI_66	10:15	11:40	1:25	NFBC ISSUED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
136	22-Jan-19	HASSAN	66	HV1	HARIHARPURA	7:57	8:19	0:22	MAIN SUPPLY FAILURE
137	22-Jan-19	HASSAN	66	HV1	HARIHARPURA	13:55	14:10	0:15	MAIN SUPPLY FAILURE
138	22-Jan-19	HASSAN	66	HV1	HARIHARPURA	15:39	17:03	1:24	MAIN SUPPLY FAILURE
139	22-Jan-19	HASSAN	66	HV1	HARIHARPURA	19:45	20:00	0:15	MAIN SUPPLY FAILURE
140	22-Jan-19	HASSAN	66	HV1	HNPURA_66	8:25	9:00	0:35	MAIN SUPPLY FAILURE
141	22-Jan-19	HASSAN	66	HV1	HNPURA_66	9:20	11:00	1:40	LINE CLEAR AVAILED
142	22-Jan-19	HASSAN	66	HV1	HNPURA_66	20:15	20:25	0:10	LINE CLEAR AVAILED
143	22-Jan-19	HASSAN	66	HV2	HNPURA_66	8:25	9:00	0:35	MAIN SUPPLY FAILURE
144	22-Jan-19	HASSAN	66	HV2	HNPURA_66	20:15	20:25	0:10	LINE CLEAR AVAILED
145	22-Jan-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	8:25	9:00	0:35	MAIN SUPPLY FAILURE
146	22-Jan-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	20:15	20:25	0:10	LINE CLEAR AVAILED
147	22-Jan-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	8:25	9:00	0:35	MAIN SUPPLY FAILURE
148	22-Jan-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	20:15	20:25	0:10	LINE CLEAR AVAILED
149	22-Jan-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66 ADDIHALLI_66	10:03	10:27	0:24	LINE FAULT
150	22-Jan-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	6:24	6:48	0:23	LINE FAULT
151	22-Jan-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	6:24	6:43	0:18	LINE FAULT
152	22-Jan-19	TUMKUR	110	TR-1	GUBBI_110	18:55	19:02	0:06	TRANSFORMER FAULT
153	22-Jan-19	TUMKUR	110	TR-1	GUBBI_110	20:11	20:21	0:09	TRANSFORMER FAULT
154	22-Jan-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	6:24	6:42	0:17	LINE FAULT
155	22-Jan-19	TUMKUR	66	(dabaspete)	KOLALA_66, URDIGERE_66	6:50	10:08	3:17	LINE FAULT
156	22-Jan-19	TUMKUR	66	TR-1 & TR-2	CHANNAGIRI_66	18:45	19:42	0:56	MAIN SUPPLY FAILURE
157	22-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	15:32	17:04	1:32	TRANSFORMER FAULT
158	22-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:31	17:54	9:22	HAND TRIPPED
159	22-Jan-19	TUMKUR	66	TR-1	HALUVAGALU_66	20:36	21:07	0:31	TRANSFORMER FAULT
160	22-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	13:14	13:17	0:02	LINE FAULT
161	22-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	12:02	12:15	0:12	LINE FAULT
162	22-Jan-19	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:53	7:05	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
163	22-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:33	18:45	0:11	LINE FAULT
164	22-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:53	23:34	4:40	LINE FAULT
165	22-Jan-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	22:30	23:27	0:56	HAND TRIPPED
166	22-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:10	7:24	0:14	HAND TRIPPED
167	22-Jan-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:14	7:24	0:09	LINE FAULT
168	22-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	6:20	6:25	0:04	HAND TRIPPED
169	22-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	16:32	16:37	0:05	HAND TRIPPED
170	22-Jan-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:40	13:05	3:24	LINE FAULT
171	23-Jan-19	BAGALKOT	110	BIJAPUR 220-BAGEWADI(ENERCON)	BIJAPUR_220	16:07	16:15	0:08	LINE FAULT
172	23-Jan-19	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	12:03	15:39	3:36	NFBC ISSUED
173	23-Jan-19	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	0:00	15:40	15:40	LINE CLEAR AVAILED
174	23-Jan-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	1:38	1:44	0:06	TRANSFORMER FAULT
175	23-Jan-19	BAGALKOT	110	110/33KV, HV3	SINDAGI_110,KALKERI_33,MYTR A_33, GOLGERI_33	12:26	14:56	2:30	LINE CLEAR AVAILED
176	23-Jan-19	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRHATTI_110	0:00	12:49	12:49	LINE CLEAR AVAILED
177	23-Jan-19	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	10:50	12:33	1:43	LINE CLEAR AVAILED
178	23-Jan-19	BAGALKOT	110	110/11KV,HV1	MURDESHWAR_110	10:08	11:47	1:39	LINE CLEAR AVAILED
179	23-Jan-19	BAGALKOT	110	DAMBAL-MUNDARGI	MUNDARGI_110	12:08	16:37	4:29	LINE CLEAR AVAILED
180	23-Jan-19	BAGALKOT	110	110/11KV,HV1	MAREGUDDI_110	10:08	14:25	4:17	LINE CLEAR AVAILED
181	23-Jan-19	BAGALKOT	110	110/11KV,HV1	MAREGUDDI_110	14:42	15:24	0:42	TRANSFORMER FAULT
182	23-Jan-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	11:57	12:22	0:25	HAND TRIPPED
183	23-Jan-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	14:26	14:45	0:19	HAND TRIPPED
184	23-Jan-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	11:57	14:45	2:48	HAND TRIPPED
185	23-Jan-19	BAGALKOT	110	220/110KV, LV1	KARWAR_220, ARGA_110, KUMTA_110	11:57	12:22	0:25	HAND TRIPPED
186	23-Jan-19	BAGALKOT	110	220/110KV, LV1	KARWAR_220, ARGA_110, KUMTA_110	14:26	14:45	0:19	HAND TRIPPED
187	23-Jan-19	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	EHT BINAGA_110	11:15	20:19	9:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
188	23-Jan-19	BAGALKOT	220	220/110KV,HV1,HV2,LV1&LV2	BELGAUM_220, VADAGOAN_110, ANKALAGI_110, MACHE_110,UCHAGOAN_110,B ELGAUM_110,KANBARGI_110,H UDLI_110	13:30	13:31	0:01	TRANSFORMER FAULT
189	23-Jan-19	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	10:00	16:17	6:16	LINE CLEAR AVAILED
190	23-Jan-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	8:00	8:30	0:29	LOAD CURTAILMENT
191	23-Jan-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI, YELDUR	7:34	8:00	0:26	LOAD CURTAILMENT
192	23-Jan-19	BANGALORE	66	HV1	DPALYA	11:54	12:36	0:42	LINE CLEAR AVAILED
193	23-Jan-19	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI	10:04	17:48	7:43	LINE CLEAR AVAILED
194	23-Jan-19	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	11:16	16:56	5:40	LINE CLEAR AVAILED
195	23-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	7:39	8:30	0:50	LOAD CURTAILMENT
196	23-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	8:30	9:35	1:05	LOAD CURTAILMENT
197	23-Jan-19	BANGALORE	66	KOLAR 220 - PGCIL	SUGUTUR, SM MANGALA	8:30	9:35	1:05	LOAD CURTAILMENT
198	23-Jan-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	8:30	10:00	1:30	LOAD CURTAILMENT
199	23-Jan-19	BANGALORE	66	THIMMAMPALLI - BAGPALLI	THIMMAMPALLI	15:16	15:21	0:04	LINE FAULT
200	23-Jan-19	BANGALORE	66	HV3	ADUGODI	11:27	11:36	0:09	LINE CLEAR AVAILED
201	23-Jan-19	BANGALORE	66	HAL 220 - HOODY 1	ISRO(EHT)	12:07	14:56	2:48	LINE CLEAR AVAILED
202	23-Jan-19	BANGALORE	66	KADABISANAHALLI - HAL 220	KADUBISANAHALLI	12:05	12:10	0:05	LINE CLEAR AVAILED
203	23-Jan-19	BANGALORE	66	KADUBISANAHALLI - CESSNO	KADUBISANAHALLI	14:50	14:55	0:05	LINE CLEAR AVAILED
204	23-Jan-19	BANGALORE	66	HV2	KENGARI SATELLITE TOWN	14:04	14:15	0:10	LINE CLEAR AVAILED
205	23-Jan-19	BANGALORE	66	HV2	VR DODDI	8:20	8:25	0:04	TRANSFORMER FAULT
206	23-Jan-19	BANGALORE	66	HV2	VR DODDI	13:58	14:22	0:23	LINE CLEAR AVAILED
207	23-Jan-19	BANGALORE	66	HV2	VR DODDI	16:06	17:31	1:25	LINE CLEAR AVAILED
208	23-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENHALLI, HUKUNDA, BIJJALLI	12:17	12:30	0:12	LINE FAULT
209	23-Jan-19	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	10:00	16:17	6:16	LINE CLEAR AVAILED
210	23-Jan-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	8:00	8:30	0:29	LOAD CURTAILMENT
211	23-Jan-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI, YELDUR	7:34	8:00	0:26	LOAD CURTAILMENT
212	23-Jan-19	BANGALORE	66	HV1	DPALYA	11:54	12:36	0:42	LINE CLEAR AVAILED
213	23-Jan-19	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI	10:04	17:48	7:43	LINE CLEAR AVAILED
214	23-Jan-19	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	11:16	16:56	5:40	LINE CLEAR AVAILED
215	23-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	7:39	8:30	0:50	LOAD CURTAILMENT
216	23-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	8:30	9:35	1:05	LOAD CURTAILMENT
217	23-Jan-19	BANGALORE	66	KOLAR 220 - PGCIL	SUGUTUR, SM MANGALA	8:30	9:35	1:05	LOAD CURTAILMENT
218	23-Jan-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	8:30	10:00	1:30	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
219	23-Jan-19	BANGALORE	66	THIMMAMPALLI - BAGPALLI	THIMMAMPALLI	15:16	15:21	0:04	LINE FAULT
220	23-Jan-19	BANGALORE	66	HV3	ADUGODI	11:27	11:36	0:09	LINE CLEAR AVAILED
221	23-Jan-19	BANGALORE	66	HAL 220 - HOODY 1	ISRO(EHT)	12:07	14:56	2:48	LINE CLEAR AVAILED
222	23-Jan-19	BANGALORE	66	KADABISANAHALLI - HAL 220	KADUBISANAHALLI	12:05	12:10	0:05	LINE CLEAR AVAILED
223	23-Jan-19	BANGALORE	66	KADUBISANAHALLI - CESSNO	KADUBISANAHALLI	14:50	14:55	0:05	LINE CLEAR AVAILED
224	23-Jan-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	14:04	14:15	0:10	LINE CLEAR AVAILED
225	23-Jan-19	BANGALORE	66	HV2	VR DODDI	8:20	8:25	0:04	TRANSFORMER FAULT
226	23-Jan-19	BANGALORE	66	HV2	VR DODDI	13:58	14:22	0:23	LINE CLEAR AVAILED
227	23-Jan-19	BANGALORE	66	HV2	VR DODDI	16:06	17:31	1:25	LINE CLEAR AVAILED
228	23-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	12:17	12:30	0:12	LINE FAULT
229	23-Jan-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	22:52	23:22	0:30	LINE CLEAR AVAILED
230	23-Jan-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	11:23	12:09	0:46	LINE CLEAR AVAILED
231	23-Jan-19	GULBARGA	110	HV4	ALAND_110	7:35	8:00	0:25	LOAD CURTAILMENT
232	23-Jan-19	GULBARGA	110	HV2	BETAGERA_110	8:25	8:30	0:05	TRANSFORMER FAULT
233	23-Jan-19	GULBARGA	110	HV1	DEODURGA_110	12:05	13:25	1:20	LINE CLEAR AVAILED
234	23-Jan-19	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	0:35	0:46	0:11	LINE FAULT
235	23-Jan-19	GULBARGA	110	KUDITINI-TORANGALLU	KUDITINI_110	0:35	0:56	0:21	LINE FAULT
236	23-Jan-19	GULBARGA	110	HV1,HV2,HV3	LINGASUGUR_220	7:33	7:47	0:14	LOAD CURTAILMENT
237	23-Jan-19	GULBARGA	110	HV1	WADAGERA_110	7:30	7:40	0:10	LOAD CURTAILMENT
238	23-Jan-19	GULBARGA	110	HV1,HV2	YADGIR_110	7:33	7:45	0:12	LOAD CURTAILMENT
239	23-Jan-19	GULBARGA	110	HV4	YELBURGA_110	7:33	7:43	0:10	LOAD CURTAILMENT
240	23-Jan-19	GULBARGA	110	HV1	KAMPLI_GLB_110	11:02	21:17	10:15	LINE CLEAR AVAILED
241	23-Jan-19	GULBARGA	110	HV2	SHAKTINAGAR_110	1:06	1:20	0:14	TRANSFORMER FAULT
242	23-Jan-19	GULBARGA	110	HV2	SHAKTINAGAR_110	1:24	2:04	0:40	TRANSFORMER FAULT
243	23-Jan-19	GULBARGA	110	HV2	SHAKTINAGAR_110	7:01	9:10	2:09	LINE CLEAR AVAILED
244	23-Jan-19	GULBARGA	110	HV2	HANUMANAL_110	8:20	8:30	0:10	TRANSFORMER FAULT
245	23-Jan-19	GULBARGA	110	HV2	HANUMANAL_110	14:05	14:45	0:40	LINE CLEAR AVAILED
246	23-Jan-19	GULBARGA	110	HV2	KOLHAR_110	7:32	7:40	0:08	LOAD CURTAILMENT
247	23-Jan-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	9:00	23:59	14:59	NFBC ISSUED
248	23-Jan-19	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	9:00	23:59	14:59	LINE CLEAR AVAILED
249	23-Jan-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:35	15:27	4:52	LINE CLEAR AVAILED
250	23-Jan-19	HASSAN	220	SHRAVITY-SHIMOGA4	SHARAVATHY_GEN	7:25	11:37	4:12	LINE CLEAR AVAILED
251	23-Jan-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	0:00	16:50	16:50	LINE CLEAR AVAILED
252	23-Jan-19	HASSAN	220	VARAHI-SHMG3	VARAHI_GEN	10:35	15:27	4:52	LINE CLEAR AVAILED
253	23-Jan-19	HASSAN	110	HV3	BANTWALA_110	18:09	18:29	0:20	TRANSFORMER FAULT
254	23-Jan-19	HASSAN	110	HV3	BANTWALA_110	18:48	19:08	0:20	TRANSFORMER FAULT
255	23-Jan-19	HASSAN	110	HV2	GANDASI_110	7:20	7:29	0:09	MAIN SUPPLY FAILURE
256	23-Jan-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	11:36	17:41	6:05	LINE CLEAR AVAILED
257	23-Jan-19	HASSAN	110	HULICA-KVR	HULICAL_110	18:12	18:18	0:06	HAND TRIPPED
258	23-Jan-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:38	13:29	1:51	LINE CLEAR AVAILED
259	23-Jan-19	HASSAN	110	HV1	KONDENALU_110	7:21	7:29	0:08	MAIN SUPPLY FAILURE
260	23-Jan-19	HASSAN	66	HV1	DODDAKADNUR_66	17:59	18:02	0:03	TRANSFORMER FAULT
261	23-Jan-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	13:45	14:05	0:20	LINE CLEAR AVAILED
262	23-Jan-19	HASSAN	66	HV1	HANGARAHALLY_66	7:20	7:30	0:10	MAIN SUPPLY FAILURE
263	23-Jan-19	HASSAN	66	HV2	HIRISAVE_66	13:20	13:55	0:35	LINE CLEAR AVAILED
264	23-Jan-19	HASSAN	66	HV2	HIRISAVE_66	9:40	10:00	0:20	MAIN SUPPLY FAILURE
265	23-Jan-19	HASSAN	66	HV2	HIRISAVE_66	10:20	13:05	2:45	MAIN SUPPLY FAILURE
266	23-Jan-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:42	6:59	0:17	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
267	23-Jan-19	HASSAN	66	MATNAV-DIDGTHL	MATTANAVILE_66	13:05	13:15	0:10	MAIN SUPPLY FAILURE
268	23-Jan-19	HASSAN	66	MATNAV-DIDGTHL	MATTANAVILE_66	9:40	13:00	3:20	MAIN SUPPLY FAILURE
269	23-Jan-19	HASSAN	66	HV1	MATTANAVILE_66	9:40	13:00	3:20	MAIN SUPPLY FAILURE
270	23-Jan-19	HASSAN	66	HV1	MATTANAVILE_66	13:05	13:15	0:10	MAIN SUPPLY FAILURE
271	23-Jan-19	HASSAN	66	HV1	RAMNATHPURA_66	7:10	7:20	0:10	TRANSFORMER FAULT
272	23-Jan-19	HASSAN	66	HV2	RAMNATHPURA_66	0:51	0:57	0:06	TRANSFORMER FAULT
273	23-Jan-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	7:35	7:40	0:05	LOAD CURTAILMENT
274	23-Jan-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	17:15	17:20	0:05	LOAD CURTAILMENT
275	23-Jan-19	HASSAN	66	HV2	SALAGAME_66	17:15	17:20	0:05	LOAD CURTAILMENT
276	23-Jan-19	HASSAN	66	HV2	SALAGAME_66	7:35	7:40	0:05	LOAD CURTAILMENT
277	23-Jan-19	HASSAN	66	HV1	SATHENAHALLY_66	9:10	9:20	0:10	MAIN SUPPLY FAILURE
278	23-Jan-19	HASSAN	66	HV2	SATHENAHALLY_66	7:30	7:40	0:10	LOAD CURTAILMENT
279	23-Jan-19	HASSAN	66	HV2	SATHENAHALLY_66	9:10	9:20	0:10	MAIN SUPPLY FAILURE
280	23-Jan-19	HASSAN	66	HV1	S.BELAGOLA_66	7:30	7:55	0:25	LOAD CURTAILMENT
281	23-Jan-19	HASSAN	66	HV2	SHANTHIGRAMA_66	7:35	7:40	0:05	LOAD CURTAILMENT
282	23-Jan-19	HASSAN	66	HV2	SHANTHIGRAMA_66	17:15	17:20	0:05	LOAD CURTAILMENT
283	23-Jan-19	HASSAN	66	SOMNHL-GDNEHALI	SOMANAHALLY_66	3:45	7:45	4:00	LINE FAULT
284	23-Jan-19	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	9:15	9:30	0:15	LINE FAULT
285	23-Jan-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	9:15	9:20	0:05	LINE FAULT
286	23-Jan-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	7:25	7:30	0:05	LOAD CURTAILMENT
287	23-Jan-19	HASSAN	66	HV2	BASAVAGHATTA_66	7:18	7:32	0:14	LOAD CURTAILMENT
288	23-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	7:18	7:25	0:07	LOAD CURTAILMENT
289	23-Jan-19	MYSORE	66	HV2	AKKIHEBBAL_66	7:18	7:23	0:05	LOAD CURTAILMENT
290	23-Jan-19	MYSORE	66	HV1	BGNAGARA_66	7:18	7:23	0:05	LOAD CURTAILMENT
291	23-Jan-19	MYSORE	66	HV1	BILIKERE_66	7:18	7:31	0:13	LOAD CURTAILMENT
292	23-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	7:18	7:29	0:11	LOAD CURTAILMENT
293	23-Jan-19	MYSORE	66	HV2	CHINAKURALI_66	7:18	7:32	0:14	LOAD CURTAILMENT
294	23-Jan-19	MYSORE	66	HV1	DODDINADUVADI_66	7:19	7:24	0:05	LOAD CURTAILMENT
295	23-Jan-19	MYSORE	66	HV2	DODDARAYAPET_66	7:18	7:30	0:11	LOAD CURTAILMENT
296	23-Jan-19	MYSORE	66	HV2	HANNUR_66	7:19	7:35	0:15	LOAD CURTAILMENT
297	23-Jan-19	MYSORE	66	HV2	HDKOTE_66	7:19	7:40	0:20	LOAD CURTAILMENT
298	23-Jan-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66	6:02	6:18	0:15	LINE FAULT
299	23-Jan-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66	6:18	6:53	0:35	LINE FAULT
300	23-Jan-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66	7:02	7:04	0:02	HAND TRIPPED
301	23-Jan-19	MYSORE	66	HV2	JAIPUR_66	7:19	7:50	0:30	LOAD CURTAILMENT
302	23-Jan-19	MYSORE	66	HV2	KIRUGAVALU_66	7:20	7:50	0:30	LOAD CURTAILMENT
303	23-Jan-19	MYSORE	66	HV2	KMDODDI_66	7:20	7:40	0:20	LOAD CURTAILMENT
304	23-Jan-19	MYSORE	66	HV2	KOLLEGALA_66	7:20	7:47	0:27	LOAD CURTAILMENT
305	23-Jan-19	MYSORE	66	HV2	MADIKERI_66	15:19	17:37	2:18	LINE CLEAR AVAILED
306	23-Jan-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 KOPPA_66 HAMPAPURA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	16:15	16:26	0:11	LINE FAULT
307	23-Jan-19	MYSORE	66	HV1	NAGAMANGALA_66	7:20	7:25	0:04	LOAD CURTAILMENT
308	23-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	7:20	7:36	0:15	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
309	23-Jan-19	MYSORE	66	PERIAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	3:44	3:50	0:06	LINE FAULT
310	23-Jan-19	MYSORE	66	HV1	PGPALYA_66	18:04	18:46	0:42	TRANSFORMER FAULT
311	23-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	7:20	7:28	0:07	LOAD CURTAILMENT
312	23-Jan-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:21	7:34	0:13	LOAD CURTAILMENT
313	23-Jan-19	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	10:35	14:21	3:46	LINE CLEAR AVOID
314	23-Jan-19	MYSORE	220	VAJAMANGALA-HOOTAGALLI	VAJAMANGALA_220	12:09	21:29	9:19	HAND TRIPPED
315	23-Jan-19	MYSORE	220	VAJAMANGALA-TK HALLI	VAJAMANGALA_220	12:07	20:34	8:27	HAND TRIPPED
316	23-Jan-19	MYSORE	66	HV1	VAJAMANGALA_220	10:42	18:46	8:03	LINE CLEAR AVOID
317	23-Jan-19	MYSORE	220	HV1	VAJAMANGALA_220	20:14	20:46	0:31	HAND TRIPPED
318	23-Jan-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	10:40	18:41	8:01	LINE CLEAR AVOID
319	23-Jan-19	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 1	ANCHEPALYA_220	17:01	17:36	0:34	LINE CLEAR AVOID
320	23-Jan-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:06	14:50	3:44	HAND TRIPPED
321	23-Jan-19	TUMKUR	220		DAVANGERE_SRS_220	7:42	14:24	6:42	LINE FAULT
322	23-Jan-19	TUMKUR	110	TR1	CHIKKANAYAKANAHALLI_110	14:15	15:30	1:15	HAND TRIPPED
323	23-Jan-19	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:40	14:02	1:22	HAND TRIPPED
324	23-Jan-19	TUMKUR	110	TR-1	GUBBI_110	19:49	20:11	0:21	TRANSFORMER FAULT
325	23-Jan-19	TUMKUR	110	TR-2	NITTUR_220	16:05	19:28	3:23	LINE CLEAR AVOID
326	23-Jan-19	TUMKUR	66	ANCHEPALYA 220kv- KUNIGAL	KUNIGAL_66	11:04	19:22	8:17	LINE CLEAR AVOID
327	23-Jan-19	TUMKUR	66		BHAKTHARAHALLI_66	17:30	17:46	0:16	LINE CLEAR AVOID
328	23-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	9:01	9:05	0:03	TRANSFORMER FAULT
329	23-Jan-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:38	8:04	0:25	LINE FAULT
330	23-Jan-19	TUMKUR	66	TR-2	HOLALKERE_66	15:09	15:10	0:01	HAND TRIPPED
331	23-Jan-19	TUMKUR	66	TR-2	HOLALKERE_66	19:34	19:45	0:10	LINE CLEAR AVOID
332	23-Jan-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	7:28	7:45	0:17	LOAD CURTAILMENT
333	23-Jan-19	TUMKUR	66	TR-2	HOSADURGA_66	19:19	22:49	3:29	TRANSFORMER FAULT
334	23-Jan-19	TUMKUR	66	TR-1	LINGADAHALLY_66	7:28	8:00	0:31	LINE CLEAR AVOID
335	23-Jan-19	TUMKUR	66	LINGADAHALLI- P R PURA	LINGADAHALLI_TM2_66	9:49	16:22	6:32	LINE CLEAR AVOID
336	23-Jan-19	TUMKUR	66	TR-2	RAMPURA_66	13:32	14:05	0:32	LINE CLEAR AVOID
337	23-Jan-19	TUMKUR	66	SHYLA PURA- MADHUGIRI	SHYLA PURA_66, YNHOSKOTE_66, MANGALWADA_66	21:59	22:03	0:04	LINE CLEAR AVOID
338	23-Jan-19	TUMKUR	66	TR-1	THOVINAKERE_66	11:01	11:04	0:03	MAIN SUPPLY FAILURE
339	23-Jan-19	TUMKUR	66		AGALKOTE_66	15:31	16:11	0:39	LINE CLEAR AVOID
340	24-Jan-19	BAGALKOT	110	110/11KV, HV1	ACHNUR_110	7:27	7:35	0:08	LOAD CURTAILMENT
341	24-Jan-19	BAGALKOT	110	110/11KV, HV1	ACHNUR_110	7:41	8:00	0:19	LOAD CURTAILMENT
342	24-Jan-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	7:27	7:29	0:02	LOAD CURTAILMENT
343	24-Jan-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	7:41	7:45	0:04	LOAD CURTAILMENT
344	24-Jan-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	10:38	10:44	0:06	TRANSFORMER FAULT
345	24-Jan-19	BAGALKOT	110	110/11KV,HV2	ANKALI_110	12:30	14:18	1:48	LINE CLEAR AVOID
346	24-Jan-19	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	7:42	7:55	0:13	LOAD CURTAILMENT
347	24-Jan-19	BAGALKOT	110	110/11KV,HV2	HANGAL_110	7:43	8:21	0:38	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
348	24-Jan-19	BAGALKOT	220	CHIKKODI 220-BELGAUM (BELGAUM1)	CHIKKODI_220	8:33	23:59	15:26	NFBC ISSUED
349	24-Jan-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	7:27	8:02	0:35	LOAD CURTAILMENT
350	24-Jan-19	BAGALKOT	110	INDI220-ATHARGA	ATHARGA_110	8:02	8:17	0:15	LOAD CURTAILMENT
351	24-Jan-19	BAGALKOT	110	110/33 KV,HV3	BAGALKOT_220,KATAGRI_33	7:43	8:22	0:39	LOAD CURTAILMENT
352	24-Jan-19	BAGALKOT	110	NAGAR)	BELGAUM_110	18:52	19:10	0:18	LINE FAULT
353	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	TODALABAGI_110	7:14	7:21	0:07	LOAD CURTAILMENT
354	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	TODALABAGI_110	7:31	7:34	0:03	LOAD CURTAILMENT
355	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	TODALABAGI_110	7:42	9:05	1:23	LOAD CURTAILMENT
356	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	SIDDAPUR_110	10:13	16:11	5:58	HAND TRIPPED
357	24-Jan-19	BAGALKOT	110	110/33KV,HV-2	SAVALAGI_110,KALABILAGI_33 & PADASALAGI_33	7:27	7:35	0:08	LOAD CURTAILMENT
358	24-Jan-19	BAGALKOT	110	110/33KV,HV-2	SAVALAGI_110,KALABILAGI_33 & PADASALAGI_33	7:41	8:15	0:34	LOAD CURTAILMENT
359	24-Jan-19	BAGALKOT	220	HUBLI-NARENDRA 1	HUBLI_220	13:32	16:09	2:37	LINE FAULT
360	24-Jan-19	BAGALKOT	220	RANEENNUR	RANEENNUR_220	0:00	9:19	9:19	LINE CLEAR AVAILED
361	24-Jan-19	BAGALKOT	220	SHIRALKOPPA(ALLIGAVI)-RANEENNUR	RANEENNUR_220	9:22	23:59	14:37	HAND TRIPPED
362	24-Jan-19	BAGALKOT	110	110/33KV,HV-3	RANEENNUR_220&33KV KUELLUR&R S NAGAR	7:42	11:13	3:31	LOAD CURTAILMENT
363	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	RAIBAG_110	7:43	8:00	0:17	LOAD CURTAILMENT
364	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	MK HUBLI_110	12:23	13:25	1:02	HAND TRIPPED
365	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	LAXMESHWAR_110	7:27	7:46	0:19	LOAD CURTAILMENT
366	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	LAXMESHWAR_110	7:50	8:19	0:29	LOAD CURTAILMENT
367	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	JAMBAGI_110	11:52	11:54	0:02	TRANSFORMER FAULT
368	24-Jan-19	BAGALKOT	110	110/33KV,HV-3	HIDIKAL_110&33KV KOLIGUDDA	7:27	7:38	0:11	LOAD CURTAILMENT
369	24-Jan-19	BAGALKOT	110	110/33KV,HV-3	HIDIKAL_110&33KV KOLIGUDDA	7:42	7:57	0:15	LOAD CURTAILMENT
370	24-Jan-19	BAGALKOT	110	110/33KV,HV-3	HIDIKAL_110&33KV KOLIGUDDA	12:31	13:57	1:26	TRANSFORMER FAULT
371	24-Jan-19	BAGALKOT	110	11/11KV,HV-1	GAJENDRAGAD_110	7:27	7:42	0:15	LOAD CURTAILMENT
372	24-Jan-19	BAGALKOT	110	110/11KV,HV-1	GAJENDRAGAD_110	7:46	8:20	0:34	LOAD CURTAILMENT
373	24-Jan-19	BANGALORE	66	HV2	BAIRAKUR	11:19	11:51	0:32	LINE CLEAR AVAILED
374	24-Jan-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:11	6:20	0:08	LINE FAULT
375	24-Jan-19	BANGALORE	66	KOLAR 220 - NANAGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	5:32	5:45	0:13	LINE FAULT
376	24-Jan-19	BANGALORE	66	KOLAR 220 - NANAGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:30	8:10	0:40	LOAD CURTAILMENT
377	24-Jan-19	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	7:30	8:13	0:43	LOAD CURTAILMENT
378	24-Jan-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	7:27	8:03	0:36	LOAD CURTAILMENT
379	24-Jan-19	BANGALORE	66	HV1	VG DODDI	9:47	13:28	3:41	LINE CLEAR AVAILED
380	24-Jan-19	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE, AMARJYOTHI	16:53	17:39	0:46	LINE FAULT
381	24-Jan-19	BANGALORE	66	IISC - HEBBAL 220	IISC	12:48	12:52	0:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
382	24-Jan-19	BANGALORE	66	IISC - NRS 220	IISC	14:35	14:39	0:04	LINE CLEAR AVAILED
383	24-Jan-19	BANGALORE	66	C STATION - A STATION 220	C STATION	14:28	14:31	0:03	LINE CLEAR AVAILED
384	24-Jan-19	BANGALORE	66	C STATION - HEBBAL 220	C STATION	12:48	12:55	0:07	LINE CLEAR AVAILED
385	24-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	11:02	11:12	0:09	LINE FAULT
386	24-Jan-19	BANGALORE	66	HV1	POTTERY ROAD	10:51	10:59	0:07	LINE CLEAR AVAILED
387	24-Jan-19	BANGALORE	66	HV1	SIR MV LAYOUT	15:36	17:04	1:27	LINE CLEAR AVAILED
388	24-Jan-19	BANGALORE	66	HV2	VR DODDI	7:48	7:54	0:05	TRANSFORMER FAULT
389	24-Jan-19	BANGALORE	66	HV2	VR DODDI	7:58	8:05	0:07	TRANSFORMER FAULT
390	24-Jan-19	BANGALORE	66	HV2	VR DODDI	12:45	13:25	0:40	TRANSFORMER FAULT
391	24-Jan-19	BANGALORE	66	HV1	YARANDANAHALLI 220	3:40	3:55	0:15	TRANSFORMER FAULT
392	24-Jan-19	BANGALORE	220	BIDADI 220 - SOMANAHALLI 1	SOMANAHALLI 220	20:44	21:22	0:37	LINE FAULT
393	24-Jan-19	BANGALORE	220	BIDADI 220 - SOMANAHALLI 2	SOMANAHALLI 220	20:44	21:28	0:44	LINE FAULT
394	24-Jan-19	BANGALORE	220	HV1	SOMANAHALLI 220	20:44	21:23	0:38	MAIN SUPPLY FAILURE
395	24-Jan-19	BANGALORE	220	HV2	SOMANAHALLI 220	20:44	21:28	0:44	MAIN SUPPLY FAILURE
396	24-Jan-19	BANGALORE	220	HV3	SOMANAHALLI 220	20:44	21:29	0:45	MAIN SUPPLY FAILURE
397	24-Jan-19	BANGALORE	66	YEDAMADU - SOMANAHALLI 220	YEDAMADU	20:44	22:07	1:23	MAIN SUPPLY FAILURE
398	24-Jan-19	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	20:44	21:35	0:50	MAIN SUPPLY FAILURE
399	24-Jan-19	BANGALORE	66	ISKON - SOMANAHALLI 220	ISKON	20:44	21:07	0:23	MAIN SUPPLY FAILURE
400	24-Jan-19	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	SHOBHA FOREST, BRIGADE MEADOWS	20:44	21:42	0:57	MAIN SUPPLY FAILURE
401	24-Jan-19	BANGALORE	66	SOMANAHALLI 220 - HAROHALI 2	HAROHALI I/A(EHT), AO SMITH (EHT), INDIA GYPSUM (EHT), HAROHALI BWSSB(EHT)	20:44	21:43	0:58	MAIN SUPPLY FAILURE
402	24-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	20:44	21:38	0:53	MAIN SUPPLY FAILURE
403	24-Jan-19	BANGALORE	66	HV1	SOMANAHALLI 220	20:44	21:35	0:50	MAIN SUPPLY FAILURE
404	24-Jan-19	BANGALORE	66	HV2	SOMANAHALLI 220	20:44	21:35	0:50	MAIN SUPPLY FAILURE
405	24-Jan-19	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	20:44	21:35	0:50	MAIN SUPPLY FAILURE
406	24-Jan-19	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	20:44	21:20	0:35	MAIN SUPPLY FAILURE
407	24-Jan-19	BANGALORE	66	220	SUBRAMANYAPURA 66	20:44	21:15	0:30	MAIN SUPPLY FAILURE
408	24-Jan-19	GULBARGA	110	HV4	ALAND_110	7:15	8:22	1:07	LOAD CURTAILMENT
409	24-Jan-19	GULBARGA	110	HV2	BETAGERA_110	12:45	15:02	2:17	LINE CLEAR AVAILED
410	24-Jan-19	GULBARGA	110	HV1	CHINCHOLI_110	7:14	7:35	0:21	LOAD CURTAILMENT
411	24-Jan-19	GULBARGA	110	HV2	CHINCHOLI_110	12:45	12:55	0:10	LINE CLEAR AVAILED
412	24-Jan-19	GULBARGA	110	HV1	DEODURGA_110	7:14	7:22	0:08	LOAD CURTAILMENT
413	24-Jan-19	GULBARGA	110	HV1	DEODURGA_110	7:30	7:40	0:10	LOAD CURTAILMENT
414	24-Jan-19	GULBARGA	110	HV3	HANUMASAGAR_110	7:31	7:40	0:09	TRANSFORMER FAULT
415	24-Jan-19	GULBARGA	110	HV3	HANUMASAGAR_110	7:15	7:30	0:15	LOAD CURTAILMENT
416	24-Jan-19	GULBARGA	110	HV2	HATTI_110	7:27	7:31	0:04	TRANSFORMER FAULT
417	24-Jan-19	GULBARGA	110	HV2	HATTI_110	7:42	7:55	0:13	TRANSFORMER FAULT
418	24-Jan-19	GULBARGA	110	KEMBHAVI-SHAHPUR	KEMBHAVI_110,HUNASGI_110	6:30	6:35	0:05	LINE FAULT
419	24-Jan-19	GULBARGA	110	HV1	KEMBHAVI_110	7:26	7:35	0:09	LOAD CURTAILMENT
420	24-Jan-19	GULBARGA	110	HV2	KEMBHAVI_110	13:25	15:40	2:15	TRANSFORMER FAULT
421	24-Jan-19	GULBARGA	110	HV2	KEMBHAVI_110	17:41	20:24	2:43	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
422	24-Jan-19	GULBARGA	110	HV2	KOLHAR_110	15:54	17:12	1:18	LINE CLEAR AVAILED
423	24-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SOLAR_IPP	KOLHAR_110	10:30	10:46	0:16	LINE FAULT
424	24-Jan-19	GULBARGA	110	HV1,HV2,HV3	LINGASUGUR_220	7:16	7:34	0:18	LOAD CURTAILMENT
425	24-Jan-19	GULBARGA	110	HV2	LINGASUGUR_220	11:34	11:57	0:23	LINE CLEAR AVAILED
426	24-Jan-19	GULBARGA	110	HV1,HV2,HV3	LINGASUGUR_220	7:50	8:16	0:26	LOAD CURTAILMENT
427	24-Jan-19	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	18:55	19:35	0:40	LINE CLEAR AVAILED
428	24-Jan-19	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	18:07	18:16	0:09	LINE FAULT
429	24-Jan-19	GULBARGA	110	HV1	MANTHAL_110	7:14	7:45	0:31	LOAD CURTAILMENT
430	24-Jan-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	7:27	7:50	0:23	LOAD CURTAILMENT
431	24-Jan-19	GULBARGA	110	HV1	SIRWAR_110	7:15	7:22	0:07	LOAD CURTAILMENT
432	24-Jan-19	GULBARGA	110	HV1	SIRWAR_110	7:31	8:11	0:40	LOAD CURTAILMENT
433	24-Jan-19	GULBARGA	110	HV1	WADAGERA_110	7:16	7:25	0:09	LOAD CURTAILMENT
434	24-Jan-19	GULBARGA	110	HV1	TEKKALAKOTE_110	7:35	7:40	0:05	LOAD CURTAILMENT
435	24-Jan-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS_WATERWORKS	23:34	23:42	0:08	LINE FAULT
436	24-Jan-19	GULBARGA	110	HV4	YELBURGA_110	7:33	8:06	0:33	LOAD CURTAILMENT
437	24-Jan-19	GULBARGA	110	HV4	YELBURGA_110	7:16	7:28	0:12	LOAD CURTAILMENT
438	24-Jan-19	GULBARGA	110	HV3	YELBURGA_110	7:27	8:08	0:41	LOAD CURTAILMENT
439	24-Jan-19	GULBARGA	110	HV1	KURKUNTA_110	7:16	7:25	0:09	LOAD CURTAILMENT
440	24-Jan-19	GULBARGA	110	HV1	KURKUNTA_110	7:31	7:45	0:14	LOAD CURTAILMENT
441	24-Jan-19	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	5:50	6:20	0:30	LINE FAULT
442	24-Jan-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS_WATERWORKS	0:39	0:50	0:11	LINE FAULT
443	24-Jan-19	GULBARGA	66	HV1	CJHALLI_66	7:15	8:29	1:14	LOAD CURTAILMENT
444	24-Jan-19	GULBARGA	66	HV1	SOVENAHALLI_66	7:25	7:30	0:05	LOAD CURTAILMENT
445	24-Jan-19	GULBARGA	66	HV1	SOVENAHALLI_66	7:41	7:50	0:09	LOAD CURTAILMENT
446	24-Jan-19	HASSAN	220	GERUSOPPA-TALGUPA1	GERUSOPPA_GEN	6:41	8:28	1:47	LINE FAULT
447	24-Jan-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	0:00	14:55	14:55	LINE CLEAR AVAILED
448	24-Jan-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	16:35	23:59	7:24	LINE CLEAR AVAILED
449	24-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	6:41	8:27	1:46	LINE FAULT
450	24-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	4:25	6:41	2:16	LINE FAULT
451	24-Jan-19	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	0:00	14:57	14:57	NFBC ISSUED
452	24-Jan-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	16:33	23:59	7:26	NFBC ISSUED
453	24-Jan-19	HASSAN	220	SHRAVITY-SHIMOGA4	SHARAVATHY_GEN	6:43	8:20	1:37	LINE FAULT
454	24-Jan-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:23	13:30	2:07	LINE CLEAR AVAILED
455	24-Jan-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	5:23	7:49	2:26	LINE FAULT
456	24-Jan-19	HASSAN	110	HV1	HALADY_110	7:27	7:40	0:13	LOAD CURTAILMENT
457	24-Jan-19	HASSAN	110	HV1	HALADY_110	7:42	8:31	0:49	LOAD CURTAILMENT
458	24-Jan-19	HASSAN	110	HV2	ARASIKERE_110	21:29	23:37	2:08	TRANSFORMER FAULT
459	24-Jan-19	HASSAN	110	HV2	BARANGI_110	8:12	8:52	0:40	LINE CLEAR AVAILED
460	24-Jan-19	HASSAN	110	HV1	BHADRAVATHY_110	11:03	11:58	0:55	LINE CLEAR AVAILED
461	24-Jan-19	HASSAN	110	HV1	GANDASI_110	7:31	12:06	4:35	LINE CLEAR AVAILED
462	24-Jan-19	HASSAN	110	HV2	GERUMARA_110	7:40	8:10	0:30	LOAD CURTAILMENT
463	24-Jan-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	11:23	13:30	2:07	LINE CLEAR AVAILED
464	24-Jan-19	HASSAN	110	HV1	HIRIYADKA_110	11:35	13:05	1:30	LINE CLEAR AVAILED
465	24-Jan-19	HASSAN	110	HV3	HIRIYADKA_110	13:08	15:15	2:07	LINE CLEAR AVAILED
466	24-Jan-19	HASSAN	110	HV1	KALLUSADARAHALLY_66	16:10	16:33	0:23	LINE CLEAR AVAILED
467	24-Jan-19	HASSAN	110	HV1	SHIVAPURA_110	12:00	12:15	0:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
468	24-Jan-19	HASSAN	66	LV1	MRSMG_220	11:40	14:12	2:32	LINE CLEAR AVAILED
469	24-Jan-19	HASSAN	66	HASSN22-BELUR	HASSAN_220	11:00	12:21	1:21	LINE CLEAR AVAILED
470	24-Jan-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	12:00	13:51	1:51	LINE CLEAR AVAILED
471	24-Jan-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	12:50	14:26	1:36	LINE CLEAR AVAILED
472	24-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:08	18:01	10:53	LINE CLEAR AVAILED
473	24-Jan-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	12:01	13:37	1:36	LINE FAULT
474	24-Jan-19	HASSAN	66	HV1	HANGARAHALLY_66	7:40	7:51	0:11	LOAD CURTAILMENT
475	24-Jan-19	HASSAN	66	HV1	HANGARAHALLY_66	7:51	8:42	0:51	LOAD CURTAILMENT
476	24-Jan-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	3:42	3:49	0:07	LINE FAULT
477	24-Jan-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	12:50	14:27	1:37	LINE CLEAR AVAILED
478	24-Jan-19	HASSAN	66	MALALI-HASSAN	MALALI_66	12:06	13:30	1:24	LINE CLEAR AVAILED
479	24-Jan-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	7:26	7:39	0:13	LOAD CURTAILMENT
480	24-Jan-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	7:51	8:10	0:19	LOAD CURTAILMENT
481	24-Jan-19	HASSAN	66	SALAGAME-HIREMANGLUR	SALAGAME_66	10:34	15:08	4:34	LINE CLEAR AVAILED
482	24-Jan-19	HASSAN	66	HV2	SALAGAME_66	7:26	7:30	0:04	LOAD CURTAILMENT
483	24-Jan-19	HASSAN	66	HV2	SALAGAME_66	7:31	7:41	0:10	LOAD CURTAILMENT
484	24-Jan-19	HASSAN	66	HV2	SALAGAME_66	7:51	8:11	0:20	LOAD CURTAILMENT
485	24-Jan-19	HASSAN	66	HV1	SATHENAHALLY_66	7:26	7:38	0:12	LOAD CURTAILMENT
486	24-Jan-19	HASSAN	66	HV1	SATHENAHALLY_66	7:51	7:55	0:04	LOAD CURTAILMENT
487	24-Jan-19	HASSAN	66	HV1	S.BELAGOLA_66	7:40	7:58	0:18	LOAD CURTAILMENT
488	24-Jan-19	HASSAN	66	HV1	S.BELAGOLA_66	10:17	17:47	7:30	LOAD CURTAILMENT
489	24-Jan-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	7:14	7:19	0:05	LOAD CURTAILMENT
490	24-Jan-19	HASSAN	66	HV2	BASAVAGHATTA_66	7:40	8:01	0:21	LOAD CURTAILMENT
491	24-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	7:26	7:41	0:14	LOAD CURTAILMENT
492	24-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	7:50	7:55	0:04	LOAD CURTAILMENT
493	24-Jan-19	MYSORE	66	HV2	AKKIHEBBAL_66	7:14	7:25	0:11	LOAD CURTAILMENT
494	24-Jan-19	MYSORE	66	HV2	AKKIHEBBAL_66	7:30	8:01	0:30	LOAD CURTAILMENT
495	24-Jan-19	MYSORE	66	HV1	BGNAGARA_66	7:40	7:46	0:06	LOAD CURTAILMENT
496	24-Jan-19	MYSORE	66	HV1	BGNAGARA_66	7:50	7:55	0:05	LOAD CURTAILMENT
497	24-Jan-19	MYSORE	66	HV1	BILIKERE_66	7:40	8:11	0:30	LOAD CURTAILMENT
498	24-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	7:14	7:29	0:14	LOAD CURTAILMENT
499	24-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	7:30	7:45	0:14	LOAD CURTAILMENT
500	24-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	7:50	7:59	0:09	LOAD CURTAILMENT
501	24-Jan-19	MYSORE	66	HV2	CHINAKURALI_66	7:14	7:42	0:28	LOAD CURTAILMENT
502	24-Jan-19	MYSORE	66	HV2	CHINAKURALI_66	7:44	7:58	0:14	LOAD CURTAILMENT
503	24-Jan-19	MYSORE	66	HV1	DODDINADUVADI_66	7:40	7:55	0:14	LOAD CURTAILMENT
504	24-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	13:55	18:02	4:07	TRANSFORMER FAULT
505	24-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	18:08	18:36	0:28	HAND TRIPPED
506	24-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	18:36	19:09	0:33	TRANSFORMER FAULT
507	24-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	19:09	23:59	4:50	TRANSFORMER FAULT
508	24-Jan-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66 DEVANOORMYS_66	7:25	7:52	0:26	LINE FAULT
509	24-Jan-19	MYSORE	66	HV1	HANAGODU_66	7:14	7:21	0:07	LOAD CURTAILMENT
510	24-Jan-19	MYSORE	66	HV1	HANAGODU_66	7:31	8:07	0:36	LOAD CURTAILMENT
511	24-Jan-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	MARTAHALLI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66	16:00	18:15	2:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
512	24-Jan-19	MYSORE	66	HANNUR-MADHUVANAHALLI 2	MARTAHALLI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66	16:00	18:15	2:15	LINE CLEAR AVAIED
513	24-Jan-19	MYSORE	66	HANNUR-DODDINDUVADI	MARTAHALLI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66	16:00	18:15	2:15	LINE CLEAR AVAIED
514	24-Jan-19	MYSORE	66	HV2	HANNUR_66	7:14	7:50	0:36	LOAD CURTAILMENT
515	24-Jan-19	MYSORE	66	HV2	HDKOTE_66	7:40	8:05	0:24	LOAD CURTAILMENT
516	24-Jan-19	MYSORE	66	HV2	JAIPUR_66	7:40	8:01	0:20	LOAD CURTAILMENT
517	24-Jan-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66	2:12	2:21	0:08	LINE FAULT
518	24-Jan-19	MYSORE	66	HV1	KIKKERI_66	11:24	13:00	1:35	LINE CLEAR AVAIED
519	24-Jan-19	MYSORE	66	HV2	KIKKERI_66	11:24	13:00	1:35	LINE CLEAR AVAIED
520	24-Jan-19	MYSORE	66	HV2	KIKKERI_66	15:44	16:52	1:08	LINE CLEAR AVAIED
521	24-Jan-19	MYSORE	66	HV3	KIKKERI_66	13:10	14:00	0:50	LINE CLEAR AVAIED
522	24-Jan-19	MYSORE	66	HV2	KIRUGAVALU_66	7:31	8:04	0:32	LOAD CURTAILMENT
523	24-Jan-19	MYSORE	66	HV1	KALAMANDIR_66	12:04	17:04	5:00	LINE CLEAR AVAIED
524	24-Jan-19	MYSORE	66	HV2	KMDODDI_66	7:40	8:29	0:48	LOAD CURTAILMENT
525	24-Jan-19	MYSORE	66	HV2	KOLLEGALA_66	7:40	8:09	0:28	LOAD CURTAILMENT
526	24-Jan-19	MYSORE	66	HV1	MADIKERI_66	12:03	16:23	4:19	LINE CLEAR AVAIED
527	24-Jan-19	MYSORE	66	HV2	MALAVALLI_66	13:05	15:00	1:55	TRANSFORMER FAULT
528	24-Jan-19	MYSORE	66	HV1	NAGAMANGALA_66	7:41	7:45	0:03	LOAD CURTAILMENT
529	24-Jan-19	MYSORE	66	HV1	NAGAMANGALA_66	7:50	7:55	0:05	LOAD CURTAILMENT
530	24-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	7:31	7:52	0:20	LOAD CURTAILMENT
531	24-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	7:52	8:14	0:21	LOAD CURTAILMENT
532	24-Jan-19	MYSORE	66	HV1	SATHEGALA_66	7:14	8:10	0:55	LOAD CURTAILMENT
533	24-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	7:30	7:36	0:05	LOAD CURTAILMENT
534	24-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	7:41	7:57	0:16	LOAD CURTAILMENT
535	24-Jan-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:30	7:44	0:13	LOAD CURTAILMENT
536	24-Jan-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:51	7:59	0:08	LOAD CURTAILMENT
537	24-Jan-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA -1	ANCHEPALYA_220	14:07	14:12	0:05	LINE CLEAR AVAIED
538	24-Jan-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA -1	ANCHEPALYA_220	15:33	18:56	3:22	LINE CLEAR AVAIED
539	24-Jan-19	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	9:50	14:53	5:03	LINE CLEAR AVAIED
540	24-Jan-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	17:06	17:20	0:14	LINE CLEAR AVAIED
541	24-Jan-19	TUMKUR	110	TR-1	GUBBI_110	19:07	19:15	0:08	TRANSFORMER FAULT
542	24-Jan-19	TUMKUR	110	TR-1	KALLUR_110	15:01	18:17	3:15	LINE CLEAR AVAIED
543	24-Jan-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	5:12	8:00	2:48	LOAD CURTAILMENT
544	24-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	12:27	15:36	3:08	LINE CLEAR AVAIED
545	24-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	9:22	20:13	10:50	LINE CLEAR AVAIED
546	24-Jan-19	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	9:49	14:55	5:05	LINE CLEAR AVAIED
547	24-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	9:22	20:13	10:50	LINE CLEAR AVAIED
548	24-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:26	8:05	0:38	LINE CLEAR AVAIED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
549	24-Jan-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	13:37	13:56	0:18	LINE CLEAR AVAILED
550	24-Jan-19	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66	6:18	6:26	0:08	LINE CLEAR AVAILED
551	24-Jan-19	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALI_220	17:06	17:22	0:16	LINE CLEAR AVAILED
552	24-Jan-19	TUMKUR	66	TR-1 & TR-2	BRAHMASANDRA_66	11:35	16:06	4:30	LINE CLEAR AVAILED
553	24-Jan-19	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	11:39	15:54	4:14	LINE CLEAR AVAILED
554	24-Jan-19	TUMKUR	66	BRAHMASANDRA- THOVINKERE	THOVINAKERE_66, KORA_66	11:36	16:05	4:29	LINE CLEAR AVAILED
555	24-Jan-19	TUMKUR	66	CHITRADURGA 66KV- CHITRADURGA 1	CHITRADURGA_66	8:31	8:33	0:01	HAND TRIPPED
556	24-Jan-19	TUMKUR	66	DYAVARANAHALI-RANGENAHALI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:23	17:56	9:32	HAND TRIPPED
557	24-Jan-19	TUMKUR	66	TR-2	HARAPPANAHALI_66	9:45	10:01	0:15	TRANSFORMER FAULT
558	24-Jan-19	TUMKUR	66	TR-2	HOSADURGA_66	10:04	10:05	0:01	HAND TRIPPED
559	24-Jan-19	TUMKUR	66	TR-1 & TR-2	HULIYURDURGA_66	15:10	18:08	2:57	LINE CLEAR AVAILED
560	24-Jan-19	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	13:21	16:05	2:44	LINE CLEAR AVAILED
561	24-Jan-19	TUMKUR	66		HALUVAGALU_66	16:18	16:35	0:17	LINE FAULT
562	25-Jan-19	BAGALKOT	110	110/11,HV1	ACHANUR_110	7:12	7:18	0:06	LOAD CURTAILMENT
563	25-Jan-19	BAGALKOT	110	110/11,HV2	AINAPUR_110	7:11	7:22	0:11	LOAD CURTAILMENT
564	25-Jan-19	BAGALKOT	110	110/11,HV2	AREMALLAPUR_110	7:12	7:23	0:11	LOAD CURTAILMENT
565	25-Jan-19	BAGALKOT	110	110/11,HV1	ATHARGA_110	7:12	7:41	0:29	LOAD CURTAILMENT
566	25-Jan-19	BAGALKOT	110	110/11,HV3	BAGALKOT_220	7:12	7:18	0:06	LOAD CURTAILMENT
567	25-Jan-19	BAGALKOT	110	BIJAPUR220-ENERCON	BIJAPUR_220	15:51	15:56	0:05	LINE FAULT
568	25-Jan-19	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	18:33	18:47	0:14	LINE FAULT
569	25-Jan-19	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	7:12	7:28	0:16	LOAD CURTAILMENT
570	25-Jan-19	BAGALKOT	110	110/33KV, HV2	HANGAL_110	7:12	8:21	1:09	LOAD CURTAILMENT
571	25-Jan-19	BAGALKOT	110	110/33KV, HV5	INDI_110, TAMBA_33	5:31	5:43	0:12	TRANSFORMER FAULT
572	25-Jan-19	BAGALKOT	220	CHIKKODI-BELGAUM(BELGAUM2)	CHIKKODI_220	0:00	17:29	17:29	LINE CLEAR AVAILED
573	25-Jan-19	BAGALKOT	220	CHIKKODI-BELGAUM1(BELGAUM1)	CHIKKODI_220	8:50	17:28	8:38	LINE CLEAR AVAILED
574	25-Jan-19	BAGALKOT	110	KUDUCHI220-YALLAPARHATTI	YALLAPARHATTI_110	16:13	16:19	0:06	HAND TRIPPED
575	25-Jan-19	BAGALKOT	110	110/33KV,HV3	YARAGATTI_110,SHIVPURA33KV ,CHUNCHANUR LIS	7:11	9:40	2:29	TRANSFORMER FAULT
576	25-Jan-19	BAGALKOT	110	110/11KV,HV1	UTTUR_110	7:14	7:24	0:10	LOAD CURTAILMENT
577	25-Jan-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	7:12	7:20	0:08	LOAD CURTAILMENT
578	25-Jan-19	BAGALKOT	110	110/11KV,HV2	TODALBAGI_110	7:15	7:20	0:05	LOAD CURTAILMENT
579	25-Jan-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	13:41	13:50	0:09	HAND TRIPPED
580	25-Jan-19	BAGALKOT	110	110/11KV,HV1	SHIRGUPPI_110	7:12	7:22	0:10	LOAD CURTAILMENT
581	25-Jan-19	BAGALKOT	110	110/33KV,HV-3	RANEENNUR_220& 33KV KUPPELLUR , RS NAGAR	7:12	7:49	0:37	LOAD CURTAILMENT
582	25-Jan-19	BAGALKOT	110	110/11KV,HV-2	RAIBAG_110	7:12	7:18	0:06	LOAD CURTAILMENT
583	25-Jan-19	BAGALKOT	110	110/33KV,HV-3	LOKAPUR_110&33KV BHATAKURKI,RS.KHARKANE	2:39	2:52	0:13	TRANSFORMER FAULT
584	25-Jan-19	BAGALKOT	66	66/33KV,HV-3	HOSPET_66	7:20	12:49	5:29	MAIN SUPPLY FAILURE
585	25-Jan-19	BANGALORE	220	HV2	DB PURA 220	6:44	6:55	0:11	TRANSFORMER FAULT
586	25-Jan-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	6:44	6:55	0:11	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
587	25-Jan-19	BANGALORE	66	DB PURA 220 - CB PURA 1 & 2	TUBUGERE, CB PURA I/A, CB PURA URBAN, NALLIMARADANAHALLI	6:44	6:55	0:11	MAIN SUPPLY FAILURE
588	25-Jan-19	BANGALORE	66	DB PURA 220 - DG 2	AIR (EHT)	6:44	6:55	0:11	MAIN SUPPLY FAILURE
589	25-Jan-19	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	7:27	7:35	0:07	LOAD CURTAILMENT
590	25-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	9:17	9:40	0:22	LOAD CURTAILMENT
591	25-Jan-19	BANGALORE	66	HV2	KEMBODI	16:23	16:54	0:31	LINE CLEAR AVAILED
592	25-Jan-19	BANGALORE	220	HV2	CHINTAMANI 220	9:57	10:26	0:28	TRANSFORMER FAULT
593	25-Jan-19	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	10:02	10:20	0:18	MAIN SUPPLY FAILURE
594	25-Jan-19	BANGALORE	220	HV1	MAGADI 220	17:30	17:35	0:05	LINE CLEAR AVAILED
595	25-Jan-19	BANGALORE	220	HV1	MAGADI 220	10:30	10:35	0:05	LINE CLEAR AVAILED
596	25-Jan-19	BANGALORE	220	HV2	MAGADI 220	17:30	17:35	0:05	LINE CLEAR AVAILED
597	25-Jan-19	BANGALORE	66	YEDUMADU - KANAKAPURA 220	YEDUMADU	7:48	7:58	0:10	LINE CLEAR AVAILED
598	25-Jan-19	BANGALORE	66	HV1	AMARJYOTHI	11:05	11:20	0:15	MAIN SUPPLY FAILURE
599	25-Jan-19	BANGALORE	66	HV1	AMARJYOTHI	13:15	13:20	0:05	LINE CLEAR AVAILED
600	25-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	0:16	0:28	0:12	LINE CLEAR AVAILED
601	25-Jan-19	BANGALORE	66	HV2	BMT	15:31	15:37	0:06	LINE CLEAR AVAILED
602	25-Jan-19	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	11:05	13:13	2:08	LINE CLEAR AVAILED
603	25-Jan-19	BANGALORE	66	HV1	KHB	9:28	9:30	0:02	LINE CLEAR AVAILED
604	25-Jan-19	BANGALORE	66	HV2	KHB	14:35	14:37	0:02	LINE CLEAR AVAILED
605	25-Jan-19	BANGALORE	66	KHB - YELAHANKA 220	KHB	15:50	15:58	0:08	LINE CLEAR AVAILED
606	25-Jan-19	BANGALORE	66	KHB - SRS PEENYA 220	KHB	16:45	16:55	0:10	LINE CLEAR AVAILED
607	25-Jan-19	BANGALORE	66	HV2	MELEHALLI	11:05	11:14	0:09	TRANSFORMER FAULT
608	25-Jan-19	BANGALORE	66	HV2	MELEHALLI	12:00	12:08	0:08	TRANSFORMER FAULT
609	25-Jan-19	BANGALORE	66	HV1	NRS 220	15:31	15:38	0:07	LINE CLEAR AVAILED
610	25-Jan-19	BANGALORE	66	HV1	NRS 220	17:35	18:43	1:07	LINE CLEAR AVAILED
611	25-Jan-19	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	6:15	6:25	0:10	LINE CLEAR AVAILED
612	25-Jan-19	BANGALORE	66	HV1	SIR MV LAYOUT	15:43	16:18	0:34	LINE CLEAR AVAILED
613	25-Jan-19	BANGALORE	66	HV1	SOLADEVANAHALLI	9:40	9:45	0:04	LINE CLEAR AVAILED
614	25-Jan-19	BANGALORE	66	HV2	SOLADEVANAHALLI	10:33	10:45	0:12	LINE CLEAR AVAILED
615	25-Jan-19	BANGALORE	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	6:07	6:11	0:04	LINE CLEAR AVAILED
616	25-Jan-19	BANGALORE	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI, SRIGANDAKAVAL	14:36	15:08	0:32	LINE FAULT
617	25-Jan-19	BANGALORE	66	SUBRAMANYAPURA 1	ISKON	11:30	12:30	1:00	LINE FAULT
618	25-Jan-19	BANGALORE	66	220	SUBRAMANYAPURA 66	11:30	11:56	0:26	MAIN SUPPLY FAILURE
619	25-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	16:29	16:34	0:05	LINE CLEAR AVAILED
620	25-Jan-19	BANGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	16:10	16:15	0:05	LINE CLEAR AVAILED
621	25-Jan-19	BANGALORE	66	HV1	TK HALLI 220	13:21	13:25	0:04	TRANSFORMER FAULT
622	25-Jan-19	BANGALORE	66	HV1	TK HALLI 220	14:46	14:50	0:04	TRANSFORMER FAULT
623	25-Jan-19	BANGALORE	66	HV2	ATTUR YELAHANKA	14:15	17:26	3:11	LINE CLEAR AVAILED
624	25-Jan-19	BANGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	1:09	1:17	0:08	LINE CLEAR AVAILED
625	25-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	1:08	1:18	0:10	LINE CLEAR AVAILED
626	25-Jan-19	GULBARGA	220	LINGAPUR-MUNIRABAD TR2	MUNIRABAD POWER HOUSE	9:09	9:43	0:34	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
627	25-Jan-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	19:29	19:49	0:20	LINE CLEAR AVAILED
628	25-Jan-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	21:02	21:21	0:19	LINE CLEAR AVAILED
629	25-Jan-19	GULBARGA	110	HV3	YELBURGA_110	7:11	7:30	0:19	LOAD CURTAILMENT
630	25-Jan-19	GULBARGA	110	HV1	TEKKALAKOTE_110	7:40	7:50	0:10	LOAD CURTAILMENT
631	25-Jan-19	GULBARGA	110	HV1	SOVENAHALLI_110	7:11	7:15	0:04	LOAD CURTAILMENT
632	25-Jan-19	GULBARGA	110	HV1	SIRWAR_110	7:25	7:30	0:05	LOAD CURTAILMENT
633	25-Jan-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	7:11	7:33	0:22	LOAD CURTAILMENT
634	25-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPL I_110	0:32	0:42	0:10	LINE FAULT
635	25-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPL I_110	4:16	4:26	0:10	LINE FAULT
636	25-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPL I_110	5:15	7:10	1:55	LINE FAULT
637	25-Jan-19	GULBARGA	110	SINDHANOOR-SUZLON2	SIDHANOOR_220	3:35	3:45	0:10	LINE FAULT
638	25-Jan-19	GULBARGA	110	HV1	BEVOOR_110	7:45	8:30	0:45	LINE CLEAR AVAILED
639	25-Jan-19	GULBARGA	110	HV2	HATTI_110	15:45	16:00	0:15	TRANSFORMER FAULT
640	25-Jan-19	GULBARGA	110	HV2	CHINCHOLI_110	7:30	7:40	0:10	LOAD CURTAILMENT
641	25-Jan-19	GULBARGA	110	HV1	CHINCHOLI_110	10:05	10:15	0:10	TRANSFORMER FAULT
642	25-Jan-19	GULBARGA	110	HV1	GANADAL_110	7:12	7:20	0:08	LOAD CURTAILMENT
643	25-Jan-19	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	18:22	18:37	0:15	LINE CLEAR AVAILED
644	25-Jan-19	GULBARGA	66	HV1	CJHALLI_66	11:05	12:10	1:05	LINE CLEAR AVAILED
645	25-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	23:09	23:59	0:50	LINE CLEAR AVAILED
646	25-Jan-19	HASSAN	110	HV1	KITTADAHALLI_110	10:31	17:43	7:12	LINE CLEAR AVAILED
647	25-Jan-19	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	10:31	17:43	7:12	LINE CLEAR AVAILED
648	25-Jan-19	HASSAN	110	HV2	MRSMG_220	16:28	16:54	0:26	LINE CLEAR AVAILED
649	25-Jan-19	HASSAN	110	HV3	PUTTUR_110	20:02	20:11	0:09	TRANSFORMER FAULT
650	25-Jan-19	HASSAN	66	HV1	KANDLI_66	7:10	7:11	0:01	LOAD CURTAILMENT
651	25-Jan-19	HASSAN	66	LV2	MRSMG_220	16:28	16:55	0:27	HAND TRIPPED
652	25-Jan-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	7:18	7:56	0:38	LOAD CURTAILMENT
653	25-Jan-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	7:56	15:44	7:48	LINE CLEAR AVAILED
654	25-Jan-19	HASSAN	66	HV2	SALAGAME_66	7:18	7:24	0:06	LOAD CURTAILMENT
655	25-Jan-19	HASSAN	66	HV1	SATHENAHALLY_66	7:18	7:29	0:11	LOAD CURTAILMENT
656	25-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	7:10	7:24	0:13	LOAD CURTAILMENT
657	25-Jan-19	MYSORE	66	HV1	AKKIHEBBAL_66	11:38	11:50	0:11	TRANSFORMER FAULT
658	25-Jan-19	MYSORE	66	HV2	AKKIHEBBAL_66	7:10	7:20	0:09	LOAD CURTAILMENT
659	25-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	7:10	7:20	0:09	LOAD CURTAILMENT
660	25-Jan-19	MYSORE	66	HV2	ELAVALA_66	12:09	12:11	0:01	HAND TRIPPED
661	25-Jan-19	MYSORE	66	HV2	HULLAHALLI_66	11:10	19:21	8:11	LINE CLEAR AVAILED
662	25-Jan-19	MYSORE	66	HV1	KOLKARANADODDI_66	16:13	16:19	0:05	HAND TRIPPED
663	25-Jan-19	MYSORE	66	HV2	KOLKARANADODDI_66	16:13	16:19	0:05	HAND TRIPPED
664	25-Jan-19	MYSORE	66	K HONNALAGERE-MADDUR	MADDUR_66	10:10	16:13	6:03	HAND TRIPPED
665	25-Jan-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66	10:17	15:17	5:00	LINE CLEAR AVAILED
666	25-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	23:05	23:17	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
667	25-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	23:17	23:59	0:41	LINE FAULT
668	25-Jan-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	0:01	0:09	0:07	LINE FAULT
669	25-Jan-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	8:53	13:54	5:01	LINE CLEAR AVAILED
670	25-Jan-19	TUMKUR	110	HUNSEGHATTA_11-KBCROSS_66	HUNSEGHATTA_110,	17:10	17:55	0:44	LINE FAULT
671	25-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:32	15:46	0:14	LINE FAULT
672	25-Jan-19	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	17:51	18:12	0:21	HAND TRIPPED
673	25-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	22:40	22:57	0:17	HAND TRIPPED
674	25-Jan-19	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	17:08	17:46	0:38	HAND TRIPPED
675	25-Jan-19	TUMKUR	66	TR-2	BENKIKERE_66	16:09	16:15	0:05	HAND TRIPPED
676	25-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:34	8:36	0:01	TRANSFORMER FAULT
677	25-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	19:00	19:01	0:01	TRANSFORMER FAULT
678	25-Jan-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:21	8:33	1:11	LOAD CURTAILMENT
679	25-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:16	17:34	9:18	HAND TRIPPED
680	25-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:42	8:37	0:55	HAND TRIPPED
681	25-Jan-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	6:37	6:58	0:21	LINE FAULT
682	26-Jan-19	BAGALKOT	110	ATHANI220-HALIYAL	HALIYAL_110	5:12	5:29	0:17	LINE FAULT
683	26-Jan-19	BAGALKOT	110	ATHANI220-HALIYAL	HALIYAL_110	6:15	6:25	0:10	LINE FAULT
684	26-Jan-19	BAGALKOT	110	220/110KV, LV2	BELGAUM_220	22:04	23:59	1:55	HAND TRIPPED
685	26-Jan-19	BAGALKOT	220	CHIKKODI-BELGAUM(BELGAUM2)	CHIKKODI_220	20:55	23:59	3:04	HAND TRIPPED
686	26-Jan-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	14:18	15:40	1:22	HAND TRIPPED
687	26-Jan-19	BAGALKOT	110	110/11KV,HV-3	MUDEBIHAL_110	8:24	8:28	0:04	TRANSFORMER FAULT
688	26-Jan-19	BAGALKOT	110	110/33KV,HV-4	KULIGOD_110	15:12	18:01	2:49	HAND TRIPPED
689	26-Jan-19	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	17:47	18:01	0:14	HAND TRIPPED
690	26-Jan-19	BANGALORE	66	HV2	NALLIMARADANAHALLI	21:29	21:41	0:11	TRANSFORMER FAULT
691	26-Jan-19	BANGALORE	66	HV1	SIDDALAGATTA	9:59	10:15	0:15	TRANSFORMER FAULT
692	26-Jan-19	BANGALORE	66	HV2	SIDDALAGATTA	11:10	12:40	1:30	LINE CLEAR AVAILED
693	26-Jan-19	BANGALORE	66	HV2	NGEF	11:02	11:07	0:05	LINE CLEAR AVAILED
694	26-Jan-19	BANGALORE	66	HV1	NGEF	14:56	15:05	0:08	LINE CLEAR AVAILED
695	26-Jan-19	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), K&C VALLEY, NAL(EHT)	9:37	9:46	0:08	LINE CLEAR AVAILED
696	26-Jan-19	BANGALORE	66	HV5	NRS 220	7:50	7:54	0:03	TRANSFORMER FAULT
697	26-Jan-19	BANGALORE	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA (EHT)	16:05	16:35	0:29	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
698	26-Jan-19	BANGALORE	66	HV1	WIDIA	16:05	18:29	2:24	LINE CLEAR AVAILED
699	26-Jan-19	BANGALORE	66	HV2	BMTC	10:48	10:54	0:06	LINE CLEAR AVAILED
700	26-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	9:37	9:37	LINE CLEAR AVAILED
701	26-Jan-19	HASSAN	220	SHRAVATHY-SHIMOGA4	SHARAVATHY_GEN	11:16	13:00	1:44	LINE CLEAR AVAILED
702	26-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:16	13:00	1:44	LINE CLEAR AVAILED
703	26-Jan-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:25	17:35	0:10	HAND TRIPPED
704	26-Jan-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:20	16:35	0:15	LINE FAULT
705	26-Jan-19	HASSAN	110	HV3	MRSMSG_220	18:17	18:40	0:23	LINE CLEAR AVAILED
706	26-Jan-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	10:11	13:44	3:33	LINE CLEAR AVAILED
707	26-Jan-19	HASSAN	66	LV3	MRSMSG_220	18:17	18:41	0:24	LINE CLEAR AVAILED
708	26-Jan-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	0:49	1:06	0:17	LINE FAULT
709	26-Jan-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	23:46	23:59	0:13	LINE FAULT
710	26-Jan-19	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA_GEN	15:49	15:55	0:06	LINE FAULT
711	26-Jan-19	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	0:59	1:16	0:17	MAIN SUPPLY FAILURE
712	26-Jan-19	HASSAN	66	GORUR-HASSAN	GORUR_66	0:58	1:14	0:16	MAIN SUPPLY FAILURE
713	26-Jan-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	23:46	23:59	0:13	LINE FAULT
714	26-Jan-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	23:46	23:59	0:13	LINE FAULT
715	26-Jan-19	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	10:03	12:17	2:14	LINE FAULT
716	26-Jan-19	MYSORE	66	HV1	MADDUR_66 K_HONNALGERE_66	3:23	3:28	0:05	HAND TRIPPED
717	26-Jan-19	MYSORE	66	HV2	MADDUR_66 K_HONNALGERE_66	3:23	3:28	0:05	HAND TRIPPED
718	26-Jan-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66	9:04	9:12	0:08	LINE FAULT
719	26-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66	1:12	3:13	2:00	NFBC ISSUED
720	26-Jan-19	MYSORE	66	KR PET 220-MADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66, GUDDENAHALLI_66, BOGADHI MANDYA_66 & NAGAMANGALA_66	10:19	10:25	0:06	LINE FAULT
721	26-Jan-19	MYSORE	66	HV1	PGPALYA_66	22:18	22:27	0:08	TRANSFORMER FAULT
722	26-Jan-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:30	10:44	0:14	TRANSFORMER FAULT
723	26-Jan-19	MYSORE	66	HV2	TUBINAKERE_220	11:05	12:01	0:56	TRANSFORMER FAULT
724	26-Jan-19	TUMKUR	110	TR-1	KALLUR_110	7:30	9:21	1:51	TRANSFORMER FAULT
725	26-Jan-19	TUMKUR	66	NAGAR)	YEDIYUR_66	17:34	22:26	4:52	LINE FAULT
726	26-Jan-19	TUMKUR	66	TR-2	BELLAVI_66	16:28	17:02	0:33	LINE CLEAR AVAILED
727	26-Jan-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	6:40	7:13	0:33	LINE FAULT
728	26-Jan-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	21:22	21:33	0:10	LINE FAULT
729	26-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:29	18:05	9:35	HAND TRIPPED
730	26-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:01	16:08	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
731	26-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:51	6:55	0:03	HAND TRIPPED
732	26-Jan-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:43	6:51	0:07	LINE FAULT
733	27-Jan-19	BAGALKOT	110	KNI SOLAR-ATHARGA	ATHARGA_110	14:32	16:48	2:16	LINE CLEAR AVAILED
734	27-Jan-19	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	12:52	18:49	5:57	LINE CLEAR AVAILED
735	27-Jan-19	BAGALKOT	220	BAGEWADI-BIJAPUR2	BAGEWADI_220	12:52	18:52	6:00	LINE CLEAR AVAILED
736	27-Jan-19	BAGALKOT	220	ALAMATTI2-BAGEWADI	BAGEWADI_220	13:01	18:38	5:37	LINE CLEAR AVAILED
737	27-Jan-19	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	13:07	18:30	5:23	LINE CLEAR AVAILED
738	27-Jan-19	BAGALKOT	220	FORTUNEFIVE1-BAGEWADI	BAGEWADI_220	12:56	18:58	6:02	LINE CLEAR AVAILED
739	27-Jan-19	BAGALKOT	220	FORTUNEFIVE2-BAGEWADI	BAGEWADI_220	12:57	19:00	6:03	LINE CLEAR AVAILED
740	27-Jan-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	13:09	18:33	5:24	LINE CLEAR AVAILED
741	27-Jan-19	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	13:03	18:28	5:25	LINE CLEAR AVAILED
742	27-Jan-19	BAGALKOT	110	BAGEWADI-MAMDAPUR1&2	MAMDAPUR(B)_110	13:06	18:27	5:21	LINE CLEAR AVAILED
743	27-Jan-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	13:05	18:52	5:47	LINE CLEAR AVAILED
744	27-Jan-19	BAGALKOT	110	220/110KV, LV2	BELGAUM_220	0:00	7:07	7:07	LINE CLEAR AVAILED
745	27-Jan-19	BAGALKOT	110	110/33KV, HV4	GOPPANAKOPPA_110,KMC_33, KUSGAL_33	21:35	22:03	0:28	TRANSFORMER FAULT
746	27-Jan-19	BAGALKOT	220	CHIKKODI-BELGAUM(BELGAUM2)	CHIKKODI_220	0:00	17:31	17:31	LINE CLEAR AVAILED
747	27-Jan-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	9:02	9:12	0:10	HAND TRIPPED
748	27-Jan-19	BAGALKOT	110	SADALAGA- VPPL	SADALAGA_110	6:50	8:29	1:39	LINE FAULT
749	27-Jan-19	BAGALKOT	110	110/33KV,HV-2	RANNABELAGALI_110	12:34	13:01	0:27	TRANSFORMER FAULT
750	27-Jan-19	BAGALKOT	110	MAMADAPUR-TODALABAGI	TODALABAGI_110	18:30	18:34	0:04	MAIN SUPPLY FAILURE
751	27-Jan-19	BAGALKOT	110	MAMADAPUR-BLGM SOLAR	MAMADAPUR_110	18:30	18:35	0:05	MAIN SUPPLY FAILURE
752	27-Jan-19	BANGALORE	66	HV2	DODDABELAVANGALA	21:04	21:17	0:13	TRANSFORMER FAULT
753	27-Jan-19	BANGALORE	66	HV2	ANEKAL	11:35	11:40	0:05	LINE CLEAR AVAILED
754	27-Jan-19	BANGALORE	66	DOMMASANDRA - SHAMRAJ TECH PARK	DOMMASANDRA	17:05	17:25	0:20	LINE FAULT
755	27-Jan-19	BANGALORE	66	KOLAR 220 - MULBAGAL	MULBAGAL, AVANI	6:25	6:33	0:07	LOAD CURTAILMENT
756	27-Jan-19	BANGALORE	66	HV2	VR DODDI	7:17	7:45	0:27	TRANSFORMER FAULT
757	27-Jan-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	7:26	7:36	0:10	LINE FAULT
758	27-Jan-19	BANGALORE	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), K&C VALLEY, NAL (EHT)	10:58	13:01	2:02	LINE CLEAR AVAILED
759	27-Jan-19	BANGALORE	66	HV2	BIDADI 220	14:28	15:13	0:44	TRANSFORMER FAULT
760	27-Jan-19	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	10:29	13:38	3:09	LINE CLEAR AVAILED
761	27-Jan-19	GULBARGA	110	HV1	SIRWAR_110	7:35	8:02	0:27	TRANSFORMER FAULT
762	27-Jan-19	GULBARGA	110	HV1	SRERAMANAGAR_110	9:04	10:58	1:54	LINE CLEAR AVAILED
763	27-Jan-19	GULBARGA	110	HV1	SRERAMANAGAR_110	11:01	11:28	0:27	LINE CLEAR AVAILED
764	27-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:08	9:19	9:11	LINE CLEAR AVAILED
765	27-Jan-19	HASSAN	110	HV2	GANDSI_110	0:40	0:45	0:05	TRANSFORMER FAULT
766	27-Jan-19	HASSAN	110	HV2	GANDSI_110	0:49	0:50	0:01	TRANSFORMER FAULT
767	27-Jan-19	HASSAN	110	HV2	GANDSI_110	7:04	7:09	0:05	TRANSFORMER FAULT
768	27-Jan-19	HASSAN	110	HV2	GANDSI_110	9:19	9:22	0:03	TRANSFORMER FAULT
769	27-Jan-19	HASSAN	110	HV2	GANDSI_110	9:40	9:41	0:01	TRANSFORMER FAULT
770	27-Jan-19	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	8:53	14:53	6:00	LINE CLEAR AVAILED
771	27-Jan-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	6:59	7:22	0:23	LINE FAULT
772	27-Jan-19	HASSAN	110	HV1	KONAJE_110	8:53	8:56	0:03	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
773	27-Jan-19	HASSAN	110	HV1	KONAJE_110	14:53	14:57	0:04	HAND TRIPPED
774	27-Jan-19	HASSAN	110	HV2	KONAJE_110	8:53	8:56	0:03	HAND TRIPPED
775	27-Jan-19	HASSAN	110	HV2	KONAJE_110	14:53	14:58	0:05	HAND TRIPPED
776	27-Jan-19	HASSAN	110	HV3	KONAJE_110	8:53	8:56	0:03	HAND TRIPPED
777	27-Jan-19	HASSAN	110	HV3	KONAJE_110	14:53	14:57	0:04	HAND TRIPPED
778	27-Jan-19	HASSAN	110	HV4	MRSMSG_220	18:30	18:51	0:21	LINE CLEAR AVOID
779	27-Jan-19	HASSAN	110	HV4	MRSMSG_220	21:59	22:14	0:15	HAND TRIPPED
780	27-Jan-19	HASSAN	66	LV4	MRSMSG_220	18:30	18:51	0:21	LINE CLEAR AVOID
781	27-Jan-19	HASSAN	66	LV4	MRSMSG_220	21:59	22:15	0:16	HAND TRIPPED
782	27-Jan-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	0:00	0:06	0:06	LINE FAULT
783	27-Jan-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	11:55	12:04	0:09	LINE FAULT
784	27-Jan-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLY_66	8:14	9:35	1:21	LINE CLEAR AVOID
785	27-Jan-19	HASSAN	66	HV1	BYACHANAHALLY_66	7:38	9:35	1:57	TRANSFORMER FAULT
786	27-Jan-19	HASSAN	66	HV1	GENDEHALLY_66	7:02	10:01	2:59	LINE CLEAR AVOID
787	27-Jan-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	0:00	0:09	0:09	LINE FAULT
788	27-Jan-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	0:00	0:16	0:16	LINE FAULT
789	27-Jan-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	18:09	18:53	0:44	LINE CLEAR AVOID
790	27-Jan-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	12:34	12:42	0:08	HAND TRIPPED
791	27-Jan-19	MYSORE	66	HV1	ANEGOLAL_66	17:43	18:14	0:30	LINE CLEAR AVOID
792	27-Jan-19	MYSORE	66	KR PET 220-KR PET 2	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	6:14	6:25	0:11	LINE FAULT
793	27-Jan-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	16:08	16:16	0:08	LINE FAULT
794	27-Jan-19	TUMKUR	110	TR-1	GUBBI_110	7:04	7:10	0:05	TRANSFORMER FAULT
795	27-Jan-19	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	9:58	18:15	8:17	MAIN SUPPLY FAILURE
796	27-Jan-19	TUMKUR	66	TR-2	AVAREGERE_66	9:57	18:16	8:19	MAIN SUPPLY FAILURE
797	27-Jan-19	TUMKUR	66	TR-3	AVAREGERE_66	9:54	18:24	8:30	MAIN SUPPLY FAILURE
798	27-Jan-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	7:00	8:33	1:32	MAIN SUPPLY FAILURE
799	27-Jan-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	9:53	18:14	8:21	LINE CLEAR AVOID
800	27-Jan-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:34	17:28	1:54	LINE CLEAR AVOID
801	27-Jan-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:54	17:36	7:41	LINE CLEAR AVOID
802	27-Jan-19	TUMKUR	66		GUTUR_66	15:48	17:04	1:16	MAIN SUPPLY FAILURE
803	27-Jan-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	16:30	16:40	0:09	LINE FAULT
804	27-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	16:45	16:58	0:12	LINE FAULT
805	27-Jan-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	17:34	18:01	0:26	HAND TRIPPED
806	27-Jan-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	15:56	16:06	0:09	LINE FAULT
807	27-Jan-19	TUMKUR	66		HARAPPANAHALLI_66	18:47	19:05	0:18	LINE FAULT
808	28-Jan-19	BAGALKOT	220	TALANDAGE-CHIKKODI	CHIKKODI_220	10:29	18:54	8:25	NFBC ISSUED
809	28-Jan-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	17:45	17:54	0:09	LINE FAULT
810	28-Jan-19	BAGALKOT	110	BAGEWADI220-MAMDAPUR1	MAMDAPUR_110	14:46	18:09	3:23	HAND TRIPPED
811	28-Jan-19	BAGALKOT	110	220/110KV, LV2	BELGAUM_220	0:41	7:00	6:19	HAND TRIPPED
812	28-Jan-19	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	17:37	18:26	0:49	LINE FAULT
813	28-Jan-19	BAGALKOT	220	GHATAPRABHA220-CHIKKODI1	GHATAPRABHA_220	17:36	19:50	2:14	LINE FAULT
814	28-Jan-19	BAGALKOT	220	220/110KV, HV2&LV2	GHATAPRABHA_220	15:33	16:23	0:50	HAND TRIPPED
815	28-Jan-19	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	17:57	18:00	0:03	MAIN SUPPLY FAILURE
816	28-Jan-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	17:02	18:34	1:32	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
817	28-Jan-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVA R_33	11:31	16:14	4:43	LINE CLEAR AVAILED
818	28-Jan-19	BAGALKOT	220	220/110,HV1,LV1	KARWAR_220	10:31	23:59	13:28	LINE CLEAR AVAILED
819	28-Jan-19	BANGALORE	66	HV2	BMTC	17:11	19:51	2:39	LINE CLEAR AVAILED
820	28-Jan-19	BANGALORE	66	BMTC - EDC 220	BMTC, NATIONAL COLLEGE	11:55	12:35	0:40	LINE FAULT
821	28-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	9:16	15:50	6:34	LINE CLEAR AVAILED
822	28-Jan-19	BANGALORE	66	HV1	VIJAYANAGARA	0:24	0:43	0:18	LINE CLEAR AVAILED
823	28-Jan-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	13:14	14:30	1:16	LINE CLEAR AVAILED
824	28-Jan-19	BANGALORE	66	HV1	NRS 220	0:36	0:38	0:01	HAND TRIPPED
825	28-Jan-19	BANGALORE	66	HV2	NRS 220	0:58	2:12	1:13	MAIN SUPPLY FAILURE
826	28-Jan-19	BANGALORE	66	HV3	NRS 220	0:55	2:11	1:16	LINE CLEAR AVAILED
827	28-Jan-19	BANGALORE	66	HV4	NRS 220	0:55	2:12	1:16	LINE CLEAR AVAILED
828	28-Jan-19	BANGALORE	66	HV5	NRS 220	0:56	2:12	1:16	LINE CLEAR AVAILED
829	28-Jan-19	BANGALORE	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	0:39	2:18	1:38	LINE CLEAR AVAILED
830	28-Jan-19	BANGALORE	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	0:39	2:18	1:38	LINE CLEAR AVAILED
831	28-Jan-19	BANGALORE	66	NRS 220 - SRS 2	NRS 220	0:58	2:12	1:13	LINE FAULT
832	28-Jan-19	BANGALORE	66	HV1	NRS 220	0:58	2:12	1:13	MAIN SUPPLY FAILURE
833	28-Jan-19	BANGALORE	66	HV2	NRS 220	11:59	12:03	0:03	LINE CLEAR AVAILED
834	28-Jan-19	BANGALORE	66	HV1	CHELUR	9:40	9:45	0:04	TRANSFORMER FAULT
835	28-Jan-19	BANGALORE	66	CHELUR - YENNIGADALE	CHELUR	15:54	18:24	2:30	LINE FAULT
836	28-Jan-19	BANGALORE	66	HV1	CHELUR	15:54	18:30	2:35	TRANSFORMER FAULT
837	28-Jan-19	BANGALORE	66	HV2	CHELUR	15:54	18:30	2:35	TRANSFORMER FAULT
838	28-Jan-19	BANGALORE	66	HV1	CB PURA URBAN	12:05	12:15	0:09	LINE CLEAR AVAILED
839	28-Jan-19	BANGALORE	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASNUR	11:40	12:30	0:50	MAIN SUPPLY FAILURE
840	28-Jan-19	BANGALORE	66	HV2	DEVANGONDHI	14:30	14:38	0:08	LINE CLEAR AVAILED
841	28-Jan-19	BANGALORE	66	HV1	DEVANGONDHI	19:45	19:55	0:10	TRANSFORMER FAULT
842	28-Jan-19	BANGALORE	66	KOLAR 220 - NANAGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:25	3:36	0:10	LINE FAULT
843	28-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:20	11:25	0:05	LINE CLEAR AVAILED
844	28-Jan-19	BANGALORE	66	KOLAR 220 - PGCIL	SUGUTUR, SM MANGALA	12:00	12:32	0:32	LINE CLEAR AVAILED
845	28-Jan-19	GULBARGA	400	JSWL400-GUTTUR	GUTTUR_400	7:15	23:59	16:44	LINE FAULT
846	28-Jan-19	GULBARGA	110	HV2	BETAGERA_110	11:10	11:56	0:46	LINE CLEAR AVAILED
847	28-Jan-19	GULBARGA	110	HV2	HANUMANAL_110	7:10	8:30	1:20	LINE CLEAR AVAILED
848	28-Jan-19	GULBARGA	110	TEKKALAKOTE-RNWSLR	TEKALAKOTE_110	18:17	18:38	0:21	LINE CLEAR AVAILED
849	28-Jan-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:18	16:31	2:13	NFBC ISSUED
850	28-Jan-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:28	13:07	1:39	LINE CLEAR AVAILED
851	28-Jan-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	0:00	16:40	16:40	NFBC ISSUED
852	28-Jan-19	HASSAN	220	MESSHM-KBCRS	MRSMSG_220	10:50	14:27	3:37	LINE CLEAR AVAILED
853	28-Jan-19	HASSAN	220	HV2	PUTTUR_220	11:50	12:39	0:49	LINE CLEAR AVAILED
854	28-Jan-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:00	16:40	16:40	NFBC ISSUED
855	28-Jan-19	HASSAN	220	SHRAVITY-TALAGUPPA1	SHARAVATHY_GEN	11:29	13:10	1:41	LINE CLEAR AVAILED
856	28-Jan-19	HASSAN	110	LV2	PUTTUR_220	11:50	12:40	0:50	LINE CLEAR AVAILED
857	28-Jan-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	10:21	14:34	4:13	LINE CLEAR AVAILED
858	28-Jan-19	HASSAN	110	HV1	HIRIYADKA_110	9:30	10:20	0:50	LINE CLEAR AVAILED
859	28-Jan-19	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	0:00	19:13	19:13	LINE CLEAR AVAILED
860	28-Jan-19	HASSAN	110	HV1	KONAJE_110	10:04	10:07	0:03	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
861	28-Jan-19	HASSAN	110	HV2	KONAJE_110	10:04	10:07	0:03	HAND TRIPPED
862	28-Jan-19	HASSAN	110	HV3	KONAJE_110	10:04	10:07	0:03	HAND TRIPPED
863	28-Jan-19	HASSAN	110	HV1	KONAJE_110	14:47	14:48	0:01	HAND TRIPPED
864	28-Jan-19	HASSAN	110	HV2	KONAJE_110	14:47	14:48	0:01	HAND TRIPPED
865	28-Jan-19	HASSAN	110	HV3	KONAJE_110	14:47	14:48	0:01	HAND TRIPPED
866	28-Jan-19	HASSAN	110	HV1	SAGARA_110	11:00	14:25	3:25	TRANSFORMER FAULT
867	28-Jan-19	HASSAN	110	HV2	SAGARA_110	10:15	12:40	2:25	LINE CLEAR AVAILED
868	28-Jan-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:20	14:45	4:25	LINE CLEAR AVAILED
869	28-Jan-19	HASSAN	110	HV1	SHIVPURA_110	7:25	9:10	1:45	LINE CLEAR AVAILED
870	28-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:15	18:34	11:19	LINE CLEAR AVAILED
871	28-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	18:39	18:48	0:09	HAND TRIPPED
872	28-Jan-19	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	11:00	13:05	2:05	LINE CLEAR AVAILED
873	28-Jan-19	HASSAN	66	HV2	HOLEHONNUR_66	15:00	15:49	0:49	LINE CLEAR AVAILED
874	28-Jan-19	MYSORE	220	HV3	HOOTAGALLY_220	13:47	14:21	0:34	LINE CLEAR AVAILED
875	28-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	9:20	9:27	0:07	MAIN SUPPLY FAILURE
876	28-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	9:20	9:27	0:07	MAIN SUPPLY FAILURE
877	28-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	15:59	16:13	0:13	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
878	28-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	15:59	16:13	0:14	MAIN SUPPLY FAILURE
879	28-Jan-19	MYSORE	66	K HONNALAGERE-MADDUR	MADDUR_66 KIADBMANDYA_66	9:27	9:35	0:07	MAIN SUPPLY FAILURE
880	28-Jan-19	MYSORE	66	K HONNALAGERE-MADDUR	MADDUR_66	16:01	16:13	0:12	MAIN SUPPLY FAILURE
881	28-Jan-19	MYSORE	66	HV1	KIADBMANDYA_66	15:55	16:01	0:05	MAIN SUPPLY FAILURE
882	28-Jan-19	MYSORE	66	HV2	KIADBMANDYA_66	15:55	16:04	0:09	MAIN SUPPLY FAILURE
883	28-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	9:15	15:51	6:36	NFBC ISSUED
884	28-Jan-19	MYSORE	66	KM DODDI-SCSL	YELANDUR_66	9:17	9:32	0:15	HAND TRIPPED
885	28-Jan-19	MYSORE	66	HV3	KRPET_66	14:28	14:37	0:09	HAND TRIPPED
886	28-Jan-19	MYSORE	66	HV2	KRPET_66	14:16	14:48	0:31	HAND TRIPPED
887	28-Jan-19	MYSORE	66	KR PETE 220-BOOKANAKERE	SHEELUNERE_66 GANJIGERE_66 BOOKANAKERE_66 CHINAKURALI_66 & BANANGADI_66	11:27	11:38	0:11	LINE FAULT
888	28-Jan-19	MYSORE	66	MANDYA-M2	MALAVALLI & HADLI	9:30	17:09	7:39	LINE CLEAR AVAILED
889	28-Jan-19	MYSORE	66	MEGALAPURA-SFC	MEGALAPURA_66	3:02	4:02	1:00	LINE FAULT
890	28-Jan-19	MYSORE	66	MEGALAPURA-VAJAMANGALA	MEGALAPURA_66	1:59	2:04	0:04	LINE FAULT
891	28-Jan-19	MYSORE	66	MEGALAPURA-VAJAMANGALA	MEGALAPURA_66	2:04	2:29	0:25	LINE FAULT
892	28-Jan-19	MYSORE	66	MEGALAPURA-VAJAMANGALA	MEGALAPURA_66	2:29	23:59	21:29	LINE FAULT
893	28-Jan-19	MYSORE	66	PERIAPATNA-HANAGUDU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	12:20	12:30	0:10	LINE FAULT
894	28-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	13:35	13:44	0:09	LINE CLEAR AVAILED
895	28-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	14:05	23:59	9:54	HAND TRIPPED
896	28-Jan-19	MYSORE	66	HV2	TUBINAKERE_220	13:15	13:46	0:31	LINE CLEAR AVAILED
897	28-Jan-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66ADICHUNCHANA GIRI_66 & VADERALLI_66	17:59	18:07	0:08	LINE FAULT
898	28-Jan-19	MYSORE	66	MUGUR-THAYURU	THAYURU_66 TNARASIPURA_66 THUMLA_66,MEGALAPURA_66T HUMLA_66	9:45	9:55	0:10	LINE FAULT
899	28-Jan-19	MYSORE	66	MUGUR-THAYURU	THAYURU, TNARASIPURA_66 THUMLA_66 TN PURA, MEGALAPURA_66 THUMLA_66	12:05	12:10	0:05	LINE FAULT
900	28-Jan-19	TUMKUR	110	TR-1	SAMPIGE_110	15:35	15:40	0:05	TRANSFORMER FAULT
901	28-Jan-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	12:10	12:32	0:22	MAIN SUPPLY FAILURE
902	28-Jan-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	16:28	22:48	6:19	LINE CLEAR AVAILED
903	28-Jan-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_66	17:40	17:51	0:11	LINE FAULT
904	28-Jan-19	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:05	12:14	0:08	LINE FAULT
905	28-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:15	17:23	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
906	28-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	21:58	22:04	0:05	HAND TRIPPED