

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:10.03.2020 TO 16.03.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	10-Mar-2020	BAGALKOT	110	110/11KV, HV2	AIGALI_110	16:44	17:33	0:49	TRANSFORMER FAULT
2	10-Mar-2020	BAGALKOT	110	110/11KV, HV1	DAMBAL_110	18:30	23:59	5:29	TRANSFORMER FAULT
3	10-Mar-2020	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	11:50	14:19	2:29	LINE CLEAR AVAILED
4	10-Mar-2020	BAGALKOT	110	110/33KV, HV3	GADAG_110, GOKAK MILLS_33, KALLOLI_33	10:21	11:39	1:18	LINE CLEAR AVAILED
5	10-Mar-2020	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BOMMANAHALLI_33, BELAGALPET_33	10:15	10:27	0:12	TRANSFORMER FAULT
6	10-Mar-2020	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BOMMANAHALLI_33, BELAGALPET_33	11:37	11:45	0:08	TRANSFORMER FAULT
7	10-Mar-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	17:26	17:31	0:05	TRANSFORMER FAULT
8	10-Mar-2020	BAGALKOT	110	110/11KV, HV2	ITANAL_110	8:01	8:08	0:07	TRANSFORMER FAULT
9	10-Mar-2020	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	11:52	12:23	0:31	LINE FAULT
10	10-Mar-2020	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	13:06	14:47	1:41	LINE FAULT
11	10-Mar-2020	BAGALKOT	110	RANNABELAGALI-MUDHOL(UTTUR)	RANNABELAGALI_110	9:29	9:45	0:16	LINE FAULT
12	10-Mar-2020	BAGALKOT	110	RANNABELAGALI-MUDHOL(UTTUR)	RANNABELAGALI_110	9:49	23:59	14:10	LINE CLEAR AVAILED
13	10-Mar-2020	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	11:52	11:58	0:06	LINE FAULT
14	10-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	16:12	16:15	0:03	TRANSFORMER FAULT
15	10-Mar-2020	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	10:38	16:18	5:40	LINE CLEAR AVAILED
16	10-Mar-2020	BENGALURU	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	6:42	7:00	0:17	LINE FAULT
17	10-Mar-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	8:55	8:58	0:03	LOAD CHANGE OVER
18	10-Mar-2020	BENGALURU	66	WELCAST STEEL - YELAHANKA 220	WELCAST STEEL	12:32	12:37	0:05	LOAD CHANGE OVER
19	10-Mar-2020	BENGALURU	66	HV1	KEMPANAHALLI	12:00	13:20	1:19	LINE CLEAR AVAILED
20	10-Mar-2020	BENGALURU	66	VIDHURASHWATA - BAGEPALLI	BAGEPALLI, SOMNATHPURA, PATHPALYA, THIMMAPALLI	11:45	11:50	0:05	LINE CLEAR AVAILED
21	10-Mar-2020	BENGALURU	66	VIDHURASHWATA - BAGEPALLI	BAGEPALLI	12:47	12:54	0:07	LINE CLEAR AVAILED
22	10-Mar-2020	BENGALURU	66	BAGEPALLI -	SOMNATHPURA, PATHPALYA, THIMMAPALLI	12:47	12:54	0:07	LINE FAULT
23	10-Mar-2020	BENGALURU	66	HV1	ATTIBELE	16:35	16:55	0:20	LOAD CHANGE OVER
24	10-Mar-2020	BENGALURU	66	HV1	ATTIBELE	17:35	17:40	0:05	LOAD CHANGE OVER
25	10-Mar-2020	BENGALURU	66	ANEKAL - YARANADANAHALLI 220	ANEKAL	16:34	17:17	0:43	LINE CLEAR AVAILED
26	10-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	7:47	19:05	11:18	MAIN SUPPLY FAILURE
27	10-Mar-2020	BENGALURU	66	HV2	MEI LAYOUT	14:23	14:25	0:02	LINE CLEAR AVAILED
28	10-Mar-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	8:55	9:00	0:05	LOAD CHANGE OVER
29	10-Mar-2020	BENGALURU	66	PLATINUM CITY - PUTTENAHALLI 220	PLATINUM CITY	12:40	12:45	0:05	LOAD CHANGE OVER
30	10-Mar-2020	BENGALURU	66	HV2	SHAMARAJU TECH PARK	4:47	4:54	0:07	TRANSFORMER FAULT
31	10-Mar-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	10:58	14:54	3:56	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
32	10-Mar-2020	BENGALURU	66	HV1	T K HALLI 220	12:34	12:48	0:14	TRANSFORMER FAULT
33	10-Mar-2020	GULBARGA	220	HUMANBAD-SEDAM 2	SEDAM_220	9:55	12:15	2:20	LINE CLEAR AVAILED
34	10-Mar-2020	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	10:00	12:27	2:27	LINE CLEAR AVAILED
35	10-Mar-2020	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	12:01	13:25	1:24	LINE CLEAR AVAILED
36	10-Mar-2020	GULBARGA	220	HUMNABAD-SEDAM 1	SEDAM_220	12:01	18:20	6:19	LINE CLEAR AVAILED
37	10-Mar-2020	GULBARGA	220	HV1	HUMNABAD_220	13:15	14:19	1:04	LINE CLEAR AVAILED
38	10-Mar-2020	GULBARGA	220	HV2	HUMNABAD_220	14:35	16:50	2:15	LINE CLEAR AVAILED
39	10-Mar-2020	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	18:35	18:59	0:24	LINE CLEAR AVAILED
40	10-Mar-2020	GULBARGA	220	HUMNABAD-HALBARGA2	HALBARGA_220	19:08	21:05	1:57	LINE CLEAR AVAILED
41	10-Mar-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR 1	MASKI_110,MUDDAPUR_110	0:16	0:37	0:21	LINE CLEAR AVAILED
42	10-Mar-2020	GULBARGA	110	HV2	DEODURGA_110	1:05	13:45	12:40	TRANSFORMER FAULT
43	10-Mar-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	1:15	1:19	0:04	LINE FAULT
44	10-Mar-2020	GULBARGA	110	HV1	MARUGUTTI_110	12:15	12:55	0:40	LINE CLEAR AVAILED
45	10-Mar-2020	GULBARGA	110	SINDHANOOR-KAMPLI	KAMPLI_110	12:55	15:25	2:30	MAIN SUPPLY FAILURE
46	10-Mar-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRNAGAR_110,MALLAPURA_110	13:02	13:10	0:08	LINE FAULT
47	10-Mar-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRNAGAR_110,MALLAPURA_110	14:30	15:16	0:46	LINE CLEAR AVAILED
48	10-Mar-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRNAGAR_110,MALLAPURA_110	15:17	18:18	3:01	LINE CLEAR AVAILED
49	10-Mar-2020	GULBARGA	110	HV1 & HV2	KAMPLI_110	15:27	16:00	0:33	LINE CLEAR AVAILED
50	10-Mar-2020	GULBARGA	110	HV2	MADIYAL_110	16:35	16:55	0:20	LINE CLEAR AVAILED
51	10-Mar-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD1	KARATAGI_110,SR NAGAR_110,GANGAVATHI_110,VENKAT AGIRI_110	16:52	18:22	1:30	LINE CLEAR AVAILED
52	10-Mar-2020	GULBARGA	110	HATTI-SOMMANAMARDI	HATTI_110	20:28	20:36	0:08	LINE FAULT
53	10-Mar-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRNAGAR_110,MALLAPURA_110	20:55	21:07	0:12	LINE FAULT
54	10-Mar-2020	GULBARGA	110	GABUR-BPSLR	GABUR_110	22:30	22:35	0:05	LINE FAULT
55	10-Mar-2020	GULBARGA	66	HV1	HANASI_66	11:15	11:40	0:25	HAND TRIPPED
56	10-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:38	23:59	10:21	LINE FAULT
57	10-Mar-2020	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	0:00	19:21	19:21	NFBC ISSUED
58	10-Mar-2020	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	19:49	23:59	4:10	LINE FAULT
59	10-Mar-2020	HASSAN	220	MRSSHM-VARAH11	MRSMG_220	0:00	19:21	19:21	NFBC ISSUED
60	10-Mar-2020	HASSAN	220	MRSSHM-VARAH11	MRSMG_220	19:23	23:59	4:36	LINE FAULT
61	10-Mar-2020	HASSAN	220	HV2	MSEZ_220	9:38	14:19	4:41	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
62	10-Mar-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:38	23:59	10:21	LINE FAULT
63	10-Mar-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	0:00	19:21	19:21	NFBC ISSUED
64	10-Mar-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	19:23	23:59	4:36	LINE FAULT
65	10-Mar-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	0:00	19:21	19:21	NFBC ISSUED
66	10-Mar-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	19:49	23:59	4:10	LINE FAULT
67	10-Mar-2020	HASSAN	110	LV2	MSEZ_220	9:38	14:19	4:41	LINE CLEAR AVOIDED
68	10-Mar-2020	HASSAN	110	HV2	HALADY_110	12:33	13:36	1:03	LINE CLEAR AVOIDED
69	10-Mar-2020	HASSAN	110	HV2	AJJAMPURA_110	12:54	13:41	0:47	LINE CLEAR AVOIDED
70	10-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	3:10	3:15	0:05	LINE FAULT
71	10-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	3:25	3:30	0:05	LINE FAULT
72	10-Mar-2020	HASSAN	110	HV1	GANDASI_110	11:56	14:13	2:17	LINE CLEAR AVOIDED
73	10-Mar-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	10:28	11:19	0:51	LINE CLEAR AVOIDED
74	10-Mar-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:23	14:33	0:10	LINE FAULT
75	10-Mar-2020	HASSAN	66	HV1	HANGARANAHALLY_66	8:40	13:15	4:35	LINE CLEAR AVOIDED
76	10-Mar-2020	HASSAN	66	HV2	HANGARANAHALLY_66	8:40	14:00	5:20	LINE CLEAR AVOIDED
77	10-Mar-2020	HASSAN	66	HV2	HOLEHONNUR_66	12:16	13:24	1:08	LINE CLEAR AVOIDED
78	10-Mar-2020	HASSAN	66	HV1	KANDLI_66	12:00	12:05	0:05	TRANSFORMER FAULT
79	10-Mar-2020	HASSAN	66	HV1	RAMPURA_66	10:57	15:06	4:09	LINE CLEAR AVOIDED
80	10-Mar-2020	HASSAN	66	HV2	RAMPURA_66	14:59	18:14	3:15	LINE CLEAR AVOIDED
81	10-Mar-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	14:26	14:36	0:10	LINE FAULT
82	10-Mar-2020	MYSORE	66	HV1	ATTIGULIPURA_66	11:59	17:32	5:33	LINE CLEAR AVOIDED
83	10-Mar-2020	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	6:28	6:39	0:10	LINE FAULT
84	10-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	8:01	8:07	0:06	TRANSFORMER FAULT
85	10-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	21:05	21:13	0:07	TRANSFORMER FAULT
86	10-Mar-2020	MYSORE	66	HV2	HANAGODU_66	15:07	15:48	0:40	LINE CLEAR AVOIDED
87	10-Mar-2020	MYSORE	66	HD KOTE-KADAKOLA	HDKOTE_66 ANTHARSANTHE_66	12:04	12:08	0:03	LINE FAULT
88	10-Mar-2020	MYSORE	66	HV1	HONNALLY_MYS_66	8:02	13:48	5:45	LINE CLEAR AVOIDED
89	10-Mar-2020	MYSORE	66	HV2	KIRUGAVALU_66	15:16	16:51	1:35	LINE CLEAR AVOIDED
90	10-Mar-2020	MYSORE	66	HV2	MEGALAPURA_66	12:29	15:09	2:40	LINE CLEAR AVOIDED
91	10-Mar-2020	MYSORE	66	HV3	SFCSHIVA_66	9:47	9:53	0:06	TRANSFORMER FAULT
92	10-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:52	16:56	0:04	LINE FAULT
93	10-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:56	16:58	0:01	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
94	10-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:57	17:03	0:06	LINE FAULT
95	10-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:03	17:19	0:15	LINE FAULT
96	10-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:19	21:01	3:42	LINE FAULT
97	10-Mar-2020	TUMKUR	220	TR-2	MADHUGIRI_220	12:36	13:08	0:31	LINE CLEAR AVAILED
98	10-Mar-2020	TUMKUR	110	TR-1	TURUVEKERE_110	12:08	12:59	0:51	LINE CLEAR AVAILED
99	10-Mar-2020	TUMKUR	110	TR-2	SAMPIGE_110	12:04	13:58	1:54	LINE CLEAR AVAILED
100	10-Mar-2020	TUMKUR	66	TR-1	BAGUR_66	15:55	16:27	0:31	LINE CLEAR AVAILED
101	10-Mar-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	13:47	14:11	0:23	LINE FAULT
102	10-Mar-2020	TUMKUR	66	TR-1	BUKKAPATNA_66	13:02	13:15	0:13	LINE CLEAR AVAILED
103	10-Mar-2020	TUMKUR	66	TR-1	BUKKAPATNA_66	14:02	14:19	0:16	LINE CLEAR AVAILED
104	10-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	8:04	8:35	0:31	LINE FAULT
105	10-Mar-2020	TUMKUR	66	TR-2	DAVANAGERE_66	10:10	10:16	0:06	LINE CLEAR AVAILED
106	10-Mar-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:28	19:18	0:49	LINE FAULT
107	10-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:11	12:27	0:15	LINE FAULT
108	10-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:09	15:35	0:25	LINE FAULT
109	10-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:13	16:43	0:30	LINE FAULT
110	10-Mar-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	6:07	6:18	0:10	MAIN SUPPLY FAILURE
111	10-Mar-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	11:20	11:31	0:11	HAND TRIPPED
112	10-Mar-2020	TUMKUR	66	DYAVARANAHALLI-THALLAK	DYAVARANAHALLI_66	6:07	11:20	5:12	LINE CLEAR AVAILED
113	10-Mar-2020	TUMKUR	66	TR-1	HANGLA_66	7:52	10:38	2:45	LINE CLEAR AVAILED
114	10-Mar-2020	TUMKUR	66	TR-2	HANGLA_66	7:52	8:24	0:31	LINE CLEAR AVAILED
115	10-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	20:44	20:55	0:10	TRANSFORMER FAULT
116	10-Mar-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	13:56	18:33	4:37	TRANSFORMER FAULT
117	10-Mar-2020	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	9:58	17:56	7:58	LINE CLEAR AVAILED
118	10-Mar-2020	TUMKUR	66	TR-2	LINGADAHALLY_66	14:35	15:07	0:32	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
119	10-Mar-2020	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	12:36	13:08	0:32	LINE CLEAR AVOIDED
120	10-Mar-2020	TUMKUR	66	TR-1	MANGALWADA_66	15:48	15:50	0:01	LINE CLEAR AVOIDED
121	10-Mar-2020	TUMKUR	66	TR-1	MATHOD_66	4:03	4:06	0:03	TRANSFORMER FAULT
122	10-Mar-2020	TUMKUR	66	TR-2	MATHOD_66	7:33	7:46	0:13	TRANSFORMER FAULT
123	10-Mar-2020	TUMKUR	66	TR-2	MYLANAHALLI_66	14:09	14:18	0:08	TRANSFORMER FAULT
124	10-Mar-2020	TUMKUR	66	NEELAGUNDA 220KV-HULUVAGALU	HALUVAGALU_66	6:30	6:41	0:10	LINE FAULT
125	10-Mar-2020	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	13:22	14:09	0:46	LINE CLEAR AVOIDED
126	11-Mar-2020	BAGALKOT	110	ANAKALGI-HIDIKAL DAM	HIDIKAL DAM_110	16:40	17:06	0:26	LINE CLEAR AVOIDED
127	11-Mar-2020	BAGALKOT	110	ANKOLA-ARGA	ARGA_110	9:48	11:52	2:04	LINE CLEAR AVOIDED
128	11-Mar-2020	BAGALKOT	110	110/11KV, HV2	HANGAL_110, BOMMANAHALLI_33, LAXMIPURA_33	10:15	10:26	0:11	TRANSFORMER FAULT
129	11-Mar-2020	BAGALKOT	110	HAVERI220-TILUVALLI(HANGAL)	HANGAL_110	22:08	22:12	0:04	LINE FAULT
130	11-Mar-2020	BAGALKOT	110	HAVERI220-TILUVALLI(HANGAL)	HANGAL_110	22:24	22:29	0:05	LINE FAULT
131	11-Mar-2020	BAGALKOT	220	220/110KV, HV1&LV1	KARWAR_220	11:55	14:39	2:44	LINE CLEAR AVOIDED
132	11-Mar-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:46	11:30	1:44	LINE CLEAR AVOIDED
133	11-Mar-2020	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEVARGENNUR_33	19:03	19:11	0:08	TRANSFORMER FAULT
134	11-Mar-2020	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	6:02	6:32	0:30	LINE FAULT
135	11-Mar-2020	BAGALKOT	110	RANNABELAGAI-MUDHOL(UTTUR)	RANNABELAGALI_110	0:00	11:02	11:02	LINE CLEAR AVOIDED
136	11-Mar-2020	BAGALKOT	110	110/33KV, HV2	SAVANUR_110, HULGUR_33	8:11	9:15	1:04	LINE CLEAR AVOIDED
137	11-Mar-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:29	18:23	0:54	LINE CLEAR AVOIDED
138	11-Mar-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:34	16:51	0:17	TRANSFORMER FAULT
139	11-Mar-2020	BENGALURU	66	HV2	NANGLI	2:35	3:10	0:35	TRANSFORMER FAULT
140	11-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	9:25	19:20	9:55	MAIN SUPPLY FAILURE
141	11-Mar-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:30	14:16	0:46	LINE FAULT
142	11-Mar-2020	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	16:05	16:10	0:05	LOAD CHANGE OVER
143	11-Mar-2020	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI	16:30	16:35	0:05	LOAD CHANGE OVER
144	11-Mar-2020	BENGALURU	66	ELECTRONIC CITY PH 2 SEC 2 - NAGANATHPURA 220	ELECTRONIC CITY PH 2 SEC 2,BIOCON	6:55	7:48	0:53	LINE CLEAR AVOIDED
145	11-Mar-2020	BENGALURU	66	HV1	MELLAHALLI	11:55	12:01	0:06	LINE CLEAR AVOIDED
146	11-Mar-2020	BENGALURU	66	HV2	MELLAHALLI	17:56	18:02	0:06	LINE CLEAR AVOIDED
147	11-Mar-2020	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	11:02	17:25	6:23	LINE CLEAR AVOIDED
148	11-Mar-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	13:01	13:44	0:43	NFBC ISSUED
149	11-Mar-2020	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	13:50	14:45	0:55	NFBC ISSUED
150	11-Mar-2020	GULBARGA	220	HV1	SEDAM_220	12:45	17:10	4:25	LINE CLEAR AVOIDED
151	11-Mar-2020	GULBARGA	220	HV1 AND HV2	LINGASUGUR_220	16:03	16:08	0:05	TRANSFORMER FAULT
152	11-Mar-2020	GULBARGA	220	HV1 AND HV2	LINGASUGUR_220	17:32	17:37	0:05	TRANSFORMER FAULT
153	11-Mar-2020	GULBARGA	220	HV1 AND HV2	LINGASUGUR_220	18:40	18:45	0:05	TRANSFORMER FAULT
154	11-Mar-2020	GULBARGA	220	KAPNOOR-SHAHAPUR 1	SHAHAPUR_220	19:50	23:59	4:09	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
155	11-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	1:48	1:54	0:06	LINE FAULT
156	11-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	1:57	2:08	0:11	LINE FAULT
157	11-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	2:47	3:08	0:21	LINE FAULT
158	11-Mar-2020	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110	5:28	5:38	0:10	LINE FAULT
159	11-Mar-2020	GULBARGA	110	KUDTINI-BELLARY(SHATHAVAHANA_IPP)	KUDITINI_110,TORANGALLU_110	6:32	6:45	0:13	LINE FAULT
160	11-Mar-2020	GULBARGA	110	KUDTINI-ALIPUR	KUDITINI_110,TORANGALLU_110	5:28	5:37	0:09	LINE FAULT
161	11-Mar-2020	GULBARGA	110	HV2	HATTI_110	16:08	16:15	0:07	TRANSFORMER FAULT
162	11-Mar-2020	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	14:24	15:05	0:41	LINE FAULT
163	11-Mar-2020	GULBARGA	110	HV1	RAJESHWAR_110	14:42	18:40	3:58	LINE CLEAR AVAILED
164	11-Mar-2020	GULBARGA	110	HV2	RAJESHWAR_110	16:42	18:50	2:08	LINE CLEAR AVAILED
165	11-Mar-2020	GULBARGA	110	YELBURGA-PRPJSLR_IPP	YELBURGA_110	9:10	17:45	8:35	LINE CLEAR AVAILED
166	11-Mar-2020	GULBARGA	110	YELBURGA-TALTSLR_IPP	YELBURGA_110	9:19	17:45	8:26	LINE CLEAR AVAILED
167	11-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIREHADAGALLI_66	0:51	1:02	0:11	LINE FAULT
168	11-Mar-2020	GULBARGA	66	TBHALLI-ITTAGGI	TAMBRAHALLI_66,HAMPASAGAR_66,MORAGERE_66	13:55	14:10	0:15	LINE FAULT
169	11-Mar-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	0:00	10:16	10:16	LINE FAULT
170	11-Mar-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	10:17	13:10	2:53	LINE FAULT
171	11-Mar-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:15	16:06	2:51	LINE FAULT
172	11-Mar-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	0:00	11:06	11:06	LINE FAULT
173	11-Mar-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	12:52	17:34	4:42	LINE FAULT
174	11-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:14	13:18	0:04	LINE FAULT
175	11-Mar-2020	HASSAN	220	HV1	MSEZ_220	10:02	14:15	4:13	LINE CLEAR AVAILED
176	11-Mar-2020	HASSAN	110	LV1	MSEZ_220	10:02	14:15	4:13	LINE CLEAR AVAILED
177	11-Mar-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	0:00	18:38	18:38	LINE FAULT
178	11-Mar-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	0:00	10:30	10:30	LINE FAULT
179	11-Mar-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	11:06	18:50	7:44	LINE FAULT
180	11-Mar-2020	HASSAN	110	HV2	KADUR_220	10:40	11:40	1:00	LINE CLEAR AVAILED
181	11-Mar-2020	HASSAN	66	A;LDUR-BALEHONNUR	ALDUR_66	11:59	15:00	3:01	LINE CLEAR AVAILED
182	11-Mar-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:59	14:59	3:00	LINE CLEAR AVAILED
183	11-Mar-2020	HASSAN	66	HV1	ALDUR_66	11:59	15:01	3:02	LINE CLEAR AVAILED
184	11-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	12:03	14:58	2:55	LINE CLEAR AVAILED
185	11-Mar-2020	HASSAN	66	HV1	KANDLI_66	11:31	11:36	0:05	TRANSFORMER FAULT
186	11-Mar-2020	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	11:02	13:44	2:42	LINE CLEAR AVAILED
187	11-Mar-2020	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:02	13:46	2:44	LINE CLEAR AVAILED
188	11-Mar-2020	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	9:00	11:55	2:55	LINE CLEAR AVAILED
189	11-Mar-2020	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	12:38	13:34	0:56	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
190	11-Mar-2020	HASSAN	66	HV1	RAMPURA_66	9:00	11:58	2:58	LINE CLEAR AVAILED
191	11-Mar-2020	HASSAN	66	HV1	RAMPURA_66	12:32	13:34	1:02	LINE CLEAR AVAILED
192	11-Mar-2020	HASSAN	66	HV2	RAMPURA_66	9:00	11:58	2:58	LINE CLEAR AVAILED
193	11-Mar-2020	HASSAN	66	HV2	RAMPURA_66	12:32	13:34	1:02	LINE CLEAR AVAILED
194	11-Mar-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	15:28	15:30	0:02	HAND TRIPPED
195	11-Mar-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	15:28	15:30	0:02	HAND TRIPPED
196	11-Mar-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	14:51	15:26	0:35	MAIN SUPPLY FAILURE
197	11-Mar-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	14:50	15:25	0:35	MAIN SUPPLY FAILURE
198	11-Mar-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	14:50	15:25	0:35	MAIN SUPPLY FAILURE
199	11-Mar-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	14:50	15:25	0:35	MAIN SUPPLY FAILURE
200	11-Mar-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:17	6:26	0:08	LINE FAULT
201	11-Mar-2020	MYSORE	66	HV2	GVGUDI_66	13:46	14:10	0:23	HAND TRIPPED
202	11-Mar-2020	MYSORE	66	HV2	HANAGODU_66	12:01	13:34	1:33	LINE CLEAR AVAILED
203	11-Mar-2020	MYSORE	66	HV1	HARVEY_66	13:47	17:12	3:25	LINE CLEAR AVAILED
204	11-Mar-2020	MYSORE	66	HV2	HARVEY_66	8:39	14:12	5:33	LINE CLEAR AVAILED
205	11-Mar-2020	MYSORE	66	HOOTAGALLI-ELWALA	ELAVALA_66, GAVADAGERE_66, HANAGODU_66, HUNSUR_66	8:00	8:12	0:11	LINE FAULT
206	11-Mar-2020	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	7:37	10:55	3:18	NFBC ISSUED
207	11-Mar-2020	MYSORE	66	KOLLEGALA-TALKADU	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	22:27	22:36	0:09	LINE FAULT
208	11-Mar-2020	MYSORE	66	HV3	PONNAMPET_66	18:55	18:59	0:04	TRANSFORMER FAULT
209	11-Mar-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	11:02	11:18	0:16	LINE CLEAR AVAILED
210	11-Mar-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	16:04	16:14	0:09	LINE CLEAR AVAILED
211	11-Mar-2020	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	17:26	18:02	0:36	LINE CLEAR AVAILED
212	11-Mar-2020	TUMKUR	66	TR-2	AVAREGERE_66	10:18	12:41	2:23	LINE CLEAR AVAILED
213	11-Mar-2020	TUMKUR	66	TR-2	AVAREGERE_66	18:02	18:04	0:01	LINE CLEAR AVAILED
214	11-Mar-2020	TUMKUR	66	TR-3	AVAREGERE_66	10:16	18:18	8:02	LINE CLEAR AVAILED
215	11-Mar-2020	TUMKUR	66	TR-1	BAGUR_TMK_66	20:12	20:15	0:02	HAND TRIPPED
216	11-Mar-2020	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	12:27	15:39	3:12	LINE CLEAR AVAILED
217	11-Mar-2020	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	12:27	15:40	3:13	LINE CLEAR AVAILED
218	11-Mar-2020	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	18:23	18:29	0:06	LINE CLEAR AVAILED
219	11-Mar-2020	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	12:12	16:28	4:16	LINE CLEAR AVAILED
220	11-Mar-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	2:58	3:00	0:01	TRANSFORMER FAULT
221	11-Mar-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	14:49	14:57	0:08	LINE FAULT
222	11-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:46	12:59	0:12	LINE FAULT
223	11-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:49	14:58	0:08	LINE FAULT
224	11-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:06	9:07	0:01	LINE FAULT
225	11-Mar-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	15:44	15:54	0:09	MAIN SUPPLY FAILURE
226	11-Mar-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	11:13	12:46	1:33	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
227	11-Mar-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	14:02	15:23	1:20	LINE CLEAR AVAILED
228	11-Mar-2020	TUMKUR	66	TR-1	IDHALLY_66	13:02	14:25	1:23	LINE CLEAR AVAILED
229	11-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDUR GA_66,JAGALUR_66,PALLAGATTE_66	12:29	15:08	2:38	LINE CLEAR AVAILED
230	11-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDUR GA_66,JAGALUR_66,PALLAGATTE_66	18:10	18:18	0:08	LINE FAULT
231	11-Mar-2020	TUMKUR	66	TR-1	SHYLAPURA_66	7:26	7:35	0:08	HAND TRIPPED
232	11-Mar-2020	TUMKUR	66	TR-2	SHYLAPURA_66	7:26	7:35	0:08	HAND TRIPPED
233	11-Mar-2020	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	12:05	16:01	3:56	LINE FAULT
234	11-Mar-2020	TUMKUR	66	TR-1	SIRA_66	15:32	17:54	2:21	LINE CLEAR AVAILED
235	11-Mar-2020	TUMKUR	66	TR-2	THOVINAKERE_66	15:52	18:12	2:20	LINE CLEAR AVAILED
236	11-Mar-2020	TUMKUR	66	TR-1	TYAVANAGI_66	12:47	13:37	0:49	LINE CLEAR AVAILED
237	12-Mar-2020	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	9:29	13:24	3:55	LINE CLEAR AVAILED
238	12-Mar-2020	BAGALKOT	220	220/110KV, HV2&LV2	BAGEWADI_220	11:40	17:35	5:55	LINE CLEAR AVAILED
239	12-Mar-2020	BAGALKOT	110	110/11KV, HV2	BIDNAL_220	14:42	14:54	0:12	LINE CLEAR AVAILED
240	12-Mar-2020	BAGALKOT	110	110/11KV, HV2	BIDNAL_220	15:07	17:20	2:13	LINE CLEAR AVAILED
241	12-Mar-2020	BAGALKOT	110	HAVERI220-GUTTAL	GUTTAL_110	10:36	16:24	5:48	LINE CLEAR AVAILED
242	12-Mar-2020	BAGALKOT	110	110/11KV, HV1	GUTTAL_110	10:36	16:24	5:48	LINE CLEAR AVAILED
243	12-Mar-2020	BAGALKOT	110	110/11KV, HV2	GUTTAL_110	10:35	18:09	7:34	LINE CLEAR AVAILED
244	12-Mar-2020	BAGALKOT	110	110/33KV, HV3	GUTTAL_110, NIRALGI_33, HOSRATTI_33	10:35	18:10	7:35	LINE CLEAR AVAILED
245	12-Mar-2020	BAGALKOT	110	110/33KV, HV1&HV2	HANGAL_110, LAXMIPURA_33, BOMMANAHALLI_33, BELAGALPET_33, AKKIALUR_33	9:51	10:06	0:15	TRANSFORMER FAULT
246	12-Mar-2020	BAGALKOT	110	110/33KV, HV1&HV2	HANGAL_110, LAXMIPURA_33, BOMMANAHALLI_33, BELAGALPET_33, AKKIALUR_33	11:15	11:27	0:12	TRANSFORMER FAULT
247	12-Mar-2020	BAGALKOT	110	HAVERI220-TILUVALLI (HANGAL)	HANGAL_110,	22:02	22:15	0:13	LINE FAULT
248	12-Mar-2020	BAGALKOT	220	HARTI1-GADAG	GADAG_220	12:27	19:17	6:50	LINE CLEAR AVAILED
249	12-Mar-2020	BAGALKOT	220	GADAG-DHONI1	GADAG_220	13:05	13:44	0:39	LINE CLEAR AVAILED
250	12-Mar-2020	BAGALKOT	220	GADAG-DHONI2	GADAG_220	13:46	14:07	0:21	LINE CLEAR AVAILED
251	12-Mar-2020	BAGALKOT	110	110/33KV, HV3	MAMDAPUR(B)_110, DEVARGENNUR_33	12:45	13:20	0:35	TRANSFORMER FAULT
252	12-Mar-2020	BAGALKOT	110	110/33KV, HV3	MAMDAPUR(B)_110, DEVARGENNUR_33	14:54	15:02	0:08	TRANSFORMER FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
253	12-Mar-2020	BAGALKOT	110	110/33KV, HV3	MAMDAPUR(B)_110, DEVARGENNUR_33	15:34	15:37	0:03	TRANSFORMER FAULT
254	12-Mar-2020	BAGALKOT	110	110/11KV, HV2	RANEBENNUR_220	14:13	16:49	2:36	LINE CLEAR AVAILED
255	12-Mar-2020	BAGALKOT	110	110/11KV, HV2	RANEBENNUR_220	17:43	23:59	6:16	TRANSFORMER FAULT
256	12-Mar-2020	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	12:59	16:23	3:24	LINE FAULT
257	12-Mar-2020	BAGALKOT	110	INDI 2-ZALKI	ZALKI_110	15:31	15:33	0:02	HAND TRIPPED
258	12-Mar-2020	BAGALKOT	110	INDI 2-ZALKI	ZALKI_110	15:35	15:40	0:05	HAND TRIPPED
259	12-Mar-2020	BAGALKOT	110	ZALKI-INCHGERI	INCHGERI_110	16:26	16:27	0:01	HAND TRIPPED
260	12-Mar-2020	BAGALKOT	110	ZALKI-CHDCHAN	CHDCHAN_110	16:50	16:52	0:02	HAND TRIPPED
261	12-Mar-2020	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	17:22	18:53	1:31	LINE CLEAR AVAILED
262	12-Mar-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	7:37	7:53	0:16	TRANSFORMER FAULT
263	12-Mar-2020	BAGALKOT	110	TODALBAGI-RSP SOLAR	RSP_IPP,TODALBAGI_110	12:45	12:52	0:07	LINE FAULT
264	12-Mar-2020	BAGALKOT	110	TODALBAGI-RSP SOLAR	RSP_IPP,TODALBAGI_110	18:47	18:49	0:02	LINE FAULT
265	12-Mar-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	7:54	8:27	0:33	LINE CLEAR AVAILED
266	12-Mar-2020	BAGALKOT	110	110/11KV,HV1	SHIROL_110	9:35	9:40	0:05	TRANSFORMER FAULT
267	12-Mar-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	12:01	12:35	0:34	LINE CLEAR AVAILED
268	12-Mar-2020	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	16:45	16:54	0:09	LINE FAULT
269	12-Mar-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	16:45	16:54	0:09	LINE FAULT
270	12-Mar-2020	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	11:00	11:45	0:45	LINE FAULT
271	12-Mar-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	10:40	15:24	4:44	LINE FAULT
272	12-Mar-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	13:44	14:18	0:34	MAIN SUPPLY FAILURE
273	12-Mar-2020	BENGALURU	66	ELECTRONIC CITY 1 - NAGANATHPURA 220	ELECTRONIC CITY, INFOSYS (EHT)	15:08	15:24	0:16	LOAD CHANGE OVER
274	12-Mar-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	11:09	11:49	0:40	LINE FAULT
275	12-Mar-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT)	11:49	15:11	3:22	LINE FAULT
276	12-Mar-2020	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	11:10	12:30	1:20	MAIN SUPPLY FAILURE
277	12-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:07	13:15	0:08	LINE FAULT
278	12-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY,RBI	14:30	14:45	0:15	LINE FAULT
279	12-Mar-2020	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	10:21	10:36	0:15	LINE CLEAR AVAILED
280	12-Mar-2020	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:21	10:36	0:15	LINE CLEAR AVAILED
281	12-Mar-2020	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	16:45	17:06	0:21	LINE CLEAR AVAILED
282	12-Mar-2020	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	16:45	17:06	0:21	LINE CLEAR AVAILED
283	12-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	3:38	4:19	0:41	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
284	12-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:54	19:04	0:10	LINE CLEAR AVAILED
285	12-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:54	19:04	0:10	LINE CLEAR AVAILED
286	12-Mar-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	18:54	19:04	0:10	LINE CLEAR AVAILED
287	12-Mar-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	18:54	19:04	0:10	LINE CLEAR AVAILED
288	12-Mar-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	V R DODDI	18:54	19:13	0:19	LINE FAULT
289	12-Mar-2020	BENGALURU	66	HV1	BAGEPALLI	10:28	13:59	3:31	LINE CLEAR AVAILED
290	12-Mar-2020	BENGALURU	66	HV1	CHIKKABALLAPURA IND URBAN	12:55	14:20	1:25	LINE CLEAR AVAILED
291	12-Mar-2020	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	17:23	19:05	1:42	LINE FAULT
292	12-Mar-2020	BENGALURU	66	HV1	HULLENAHALLI	11:57	12:06	0:09	TRANSFORMER FAULT
293	12-Mar-2020	BENGALURU	66	HV2	JIGANI LINK ROAD	13:04	14:15	1:10	LINE CLEAR AVAILED
294	12-Mar-2020	BENGALURU	66	HV3	JIGANI LINK ROAD	13:04	14:12	1:08	LINE CLEAR AVAILED
295	12-Mar-2020	BENGALURU	66	HV2	KIADB DB PURA 220	7:16	7:58	0:41	TRANSFORMER FAULT
296	12-Mar-2020	BENGALURU	66	HV1	SURYANAGAR	9:51	10:12	0:20	LINE CLEAR AVAILED
297	12-Mar-2020	BENGALURU	66	HV1	THAYALUR	16:50	17:04	0:14	LINE CLEAR AVAILED
298	12-Mar-2020	BENGALURU	66	HV2	SARJAPURA 220	16:20	17:43	1:23	MAIN SUPPLY FAILURE
299	12-Mar-2020	BENGALURU	66	HV1	MUDIYANUR	7:25	7:43	0:17	TRANSFORMER FAULT
300	12-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	7:43	17:26	9:43	MAIN SUPPLY FAILURE
301	12-Mar-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:51	12:13	2:21	LINE CLEAR AVAILED
302	12-Mar-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	11:13	11:20	0:07	LINE FAULT
303	12-Mar-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:04	12:12	0:07	LINE FAULT
304	12-Mar-2020	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	11:13	11:22	0:09	LINE FAULT
305	12-Mar-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:29	18:34	0:04	LINE FAULT
306	12-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	16:17	17:30	1:13	LINE CLEAR AVAILED
307	12-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	16:17	17:30	1:13	LINE CLEAR AVAILED
308	12-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:17	17:36	1:19	MAIN SUPPLY FAILURE
309	12-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:17	17:36	1:19	MAIN SUPPLY FAILURE
310	12-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	16:17	17:37	1:20	MAIN SUPPLY FAILURE
311	12-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	16:17	17:35	1:18	MAIN SUPPLY FAILURE
312	12-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	16:17	17:35	1:18	MAIN SUPPLY FAILURE
313	12-Mar-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	16:17	17:35	1:18	MAIN SUPPLY FAILURE
314	12-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:17	17:37	1:20	MAIN SUPPLY FAILURE
315	12-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	16:17	17:37	1:20	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
316	12-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	16:17	17:36	1:19	MAIN SUPPLY FAILURE
317	12-Mar-2020	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	16:17	17:52	1:35	MAIN SUPPLY FAILURE
318	12-Mar-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	16:17	17:51	1:34	MAIN SUPPLY FAILURE
319	12-Mar-2020	BENGALURU	220	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:17	17:55	1:38	MAIN SUPPLY FAILURE
320	12-Mar-2020	BENGALURU	220	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:17	17:58	1:41	MAIN SUPPLY FAILURE
321	12-Mar-2020	BENGALURU	220	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:17	17:58	1:41	MAIN SUPPLY FAILURE
322	12-Mar-2020	BENGALURU	220	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:17	17:58	1:41	MAIN SUPPLY FAILURE
323	12-Mar-2020	BENGALURU	220	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:17	17:55	1:38	MAIN SUPPLY FAILURE
324	12-Mar-2020	BENGALURU	220	MALUR 220 - MALUR 66	MALUR 66	16:17	17:55	1:38	MAIN SUPPLY FAILURE
325	12-Mar-2020	BENGALURU	220	HV1	MALUR 220	16:17	17:51	1:34	MAIN SUPPLY FAILURE
326	12-Mar-2020	BENGALURU	220	HV2	MALUR 220	16:17	17:51	1:34	MAIN SUPPLY FAILURE
327	12-Mar-2020	BENGALURU	220	HV1	SARJAPURA 220	16:17	17:51	1:34	MAIN SUPPLY FAILURE
328	12-Mar-2020	BENGALURU	220	HV2	SARJAPURA 220	16:17	17:51	1:34	MAIN SUPPLY FAILURE
329	12-Mar-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:17	17:52	1:35	MAIN SUPPLY FAILURE
330	12-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:17	17:52	1:35	MAIN SUPPLY FAILURE
331	12-Mar-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:17	17:52	1:35	MAIN SUPPLY FAILURE
332	12-Mar-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	16:17	17:52	1:35	MAIN SUPPLY FAILURE
333	12-Mar-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	16:17	17:52	1:35	MAIN SUPPLY FAILURE
334	12-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:17	17:52	1:35	MAIN SUPPLY FAILURE
335	12-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	16:17	17:52	1:35	MAIN SUPPLY FAILURE
336	12-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:17	17:52	1:35	MAIN SUPPLY FAILURE
337	12-Mar-2020	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	9:26	14:15	4:49	LINE CLEAR AVAILED
338	12-Mar-2020	GULBARGA	220	KAPNOOR-SHAHAPUR 1	SHAHAPUR_220	0:00	23:59	23:59	LINE CLEAR AVAILED
339	12-Mar-2020	GULBARGA	220	HV1	ITTAGI_220	13:50	13:55	0:05	LINE CLEAR AVAILED
340	12-Mar-2020	GULBARGA	220	HV2	ITTAGI_220	13:50	13:55	0:05	TRANSFORMER FAULT
341	12-Mar-2020	GULBARGA	220	HV2	ITTAGI_220	14:30	14:35	0:05	TRANSFORMER FAULT
342	12-Mar-2020	GULBARGA	110	SIDHANOOR220-PGLR_WIND	SIDHANNOOR_220	12:10	12:20	0:10	LINE FAULT
343	12-Mar-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	SIDHANNOOR_220	14:02	14:20	0:18	HAND TRIPPED
344	12-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	6:03	6:07	0:04	LINE FAULT
345	12-Mar-2020	GULBARGA	110	PDHALLI-JANAKIPWRPLANT	PD_HALLI_110	9:11	9:22	0:11	MAIN SUPPLY FAILURE
346	12-Mar-2020	GULBARGA	110	HV2	HANUMNAL_110	7:50	8:25	0:35	LINE CLEAR AVAILED
347	12-Mar-2020	GULBARGA	110	HV2	HATTI_110	15:06	15:12	0:06	TRANSFORMER FAULT
348	12-Mar-2020	GULBARGA	110	HV2	CHITAGUPPA_110	15:39	15:44	0:05	TRANSFORMER FAULT
349	12-Mar-2020	GULBARGA	110	HV1	LADHA_110	17:30	17:40	0:10	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
350	12-Mar-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	KOGALI_66,KUDLIGI_66,HANASI_66,CJH ALLI_66, GUDEKOTE_66, BANAVEKAL_66, CHORNOOR, HOSAHALLI_66	17:56	18:20	0:24	LINE CLEAR AVAILED
351	12-Mar-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	9:40	9:45	0:05	TRANSFORMER FAULT
352	12-Mar-2020	HASSAN	220	GERSOPA-SMG	gerusoppa_gen	14:16	17:03	2:47	LINE CLEAR AVAILED
353	12-Mar-2020	HASSAN	220	MRSSHM-STRP1	MRSMG_220	14:15	17:03	2:48	LINE CLEAR AVAILED
354	12-Mar-2020	HASSAN	220	HV1	MSEZ_220	9:41	13:34	3:53	LINE CLEAR AVAILED
355	12-Mar-2020	HASSAN	110	LV1	MSEZ_220	9:41	13:34	3:53	LINE CLEAR AVAILED
356	12-Mar-2020	HASSAN	110	HV3	ALKOLA_110	7:08	7:47	0:39	LINE CLEAR AVAILED
357	12-Mar-2020	HASSAN	110	HV2	SORABA_110	13:16	13:25	0:09	LINE CLEAR AVAILED
358	12-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMG_220	0:00	18:55	18:55	NFBC ISSUED
359	12-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMG_220	19:23	23:59	4:36	LINE FAULT
360	12-Mar-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	0:00	19:00	19:00	LINE CLEAR AVAILED
361	12-Mar-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	19:23	23:59	4:36	LINE FAULT
362	12-Mar-2020	HASSAN	66	HV1	DUDDA_66	10:40	11:33	0:53	MAIN SUPPLY FAILURE
363	12-Mar-2020	HASSAN	66	HAGARE-CKMG	HAGARE_66	9:47	13:46	3:59	LINE CLEAR AVAILED
364	12-Mar-2020	HASSAN	66	HV1	KANDLI_66	16:15	16:18	0:03	TRANSFORMER FAULT
365	12-Mar-2020	HASSAN	66	HV1	SAKALESH PURA_66	17:44	17:53	0:09	TRANSFORMER FAULT
366	12-Mar-2020	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	7:15	7:20	0:04	LINE FAULT
367	12-Mar-2020	MYSORE	66	HV1	KOPPA_66	10:05	10:11	0:06	HAND TRIPPED
368	12-Mar-2020	MYSORE	66	HV2	KOPPA_66	10:05	10:11	0:06	HAND TRIPPED
369	12-Mar-2020	MYSORE	66	HV2	KOPPA_66	12:11	12:42	0:30	LINE CLEAR AVAILED
370	12-Mar-2020	MYSORE	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66, HARIYALADAMMA_66	6:37	6:48	0:11	LINE FAULT
371	12-Mar-2020	MYSORE	66	HV1	MADDUR_66	18:57	19:04	0:07	HAND TRIPPED
372	12-Mar-2020	MYSORE	66	HV2	MADDUR_66	18:57	19:05	0:07	HAND TRIPPED
373	12-Mar-2020	MYSORE	66	HV2	MADHUVANAHALLI_220	13:13	13:17	0:04	TRANSFORMER FAULT
374	12-Mar-2020	MYSORE	66	SUNTIKOPPA-KUSHALNAGAR	SUNTIKOPPA_66	12:10	13:13	1:03	LINE CLEAR AVAILED
375	12-Mar-2020	MYSORE	66	SUNTIKOPPA-KUSHALNAGAR	SUNTIKOPPA_66	13:16	16:51	3:34	LINE CLEAR AVAILED
376	12-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:46	17:51	0:04	LINE FAULT
377	12-Mar-2020	MYSORE	66	HV1	YELANDUR_66	12:29	12:38	0:08	TRANSFORMER FAULT
378	12-Mar-2020	TUMKUR	220	TR-1	HIRIYUR_220	6:29	7:07	0:38	HAND TRIPPED
379	12-Mar-2020	TUMKUR	220	TR-1	KBCROSS_220	17:03	17:08	0:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
380	12-Mar-2020	TUMKUR	220	TR-1	KBCROSS_220	20:06	20:16	0:09	LINE CLEAR AVAILED
381	12-Mar-2020	TUMKUR	220	TR-2	KBCROSS_220	17:03	17:08	0:05	LINE CLEAR AVAILED
382	12-Mar-2020	TUMKUR	220	TR-2	KBCROSS_220	20:06	20:16	0:10	LINE CLEAR AVAILED
383	12-Mar-2020	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	16:21	16:36	0:15	LINE CLEAR AVAILED
384	12-Mar-2020	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	18:01	18:18	0:16	LINE CLEAR AVAILED
385	12-Mar-2020	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	16:21	16:34	0:13	LINE CLEAR AVAILED
386	12-Mar-2020	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	18:01	18:18	0:16	LINE CLEAR AVAILED
387	12-Mar-2020	TUMKUR	110	TR-1	HONNAVALLI_110	16:21	18:20	1:59	LINE CLEAR AVAILED
388	12-Mar-2020	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	16:21	16:31	0:10	LINE CLEAR AVAILED
389	12-Mar-2020	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	18:02	18:18	0:16	LINE CLEAR AVAILED
390	12-Mar-2020	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	17:03	17:33	0:30	MAIN SUPPLY FAILURE
391	12-Mar-2020	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	17:03	17:33	0:30	MAIN SUPPLY FAILURE
392	12-Mar-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:05	17:11	0:05	MAIN SUPPLY FAILURE
393	12-Mar-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_111	18:05	18:11	0:05	MAIN SUPPLY FAILURE
394	12-Mar-2020	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	17:03	17:08	0:05	LINE CLEAR AVAILED
395	12-Mar-2020	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	20:06	20:16	0:10	LINE CLEAR AVAILED
396	12-Mar-2020	TUMKUR	110	TR-1(LV 2)	KBCROSS_220	17:03	17:12	0:09	LINE CLEAR AVAILED
397	12-Mar-2020	TUMKUR	110	TR-1(LV 2)	KBCROSS_220	20:06	20:30	0:23	LINE CLEAR AVAILED
398	12-Mar-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	17:06	17:13	0:07	MAIN SUPPLY FAILURE
399	12-Mar-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	20:11	20:22	0:10	MAIN SUPPLY FAILURE
400	12-Mar-2020	TUMKUR	66	TR-1	SAMPIGE_110	15:35	15:58	0:23	TRANSFORMER FAULT
401	12-Mar-2020	TUMKUR	66	TR-1	BUKKAPATNA_66	15:14	16:02	0:48	LINE CLEAR AVAILED
402	12-Mar-2020	TUMKUR	66	TR-1	BUKKAPATNA_66	18:01	18:36	0:35	LINE CLEAR AVAILED
403	12-Mar-2020	TUMKUR	66	TR-2	BUKKAPATNA_66	16:05	16:28	0:23	LINE CLEAR AVAILED
404	12-Mar-2020	TUMKUR	66	TR-2	BUKKAPATNA_66	17:11	19:52	2:41	LINE CLEAR AVAILED
405	12-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	14:44	14:48	0:04	TRANSFORMER FAULT
406	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:35	12:04	1:28	LINE CLEAR AVAILED
407	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:25	12:33	0:07	LINE FAULT
408	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	10:35	10:49	0:13	HAND TRIPPED
409	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	12:35	12:41	0:05	HAND TRIPPED
410	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:35	12:17	1:41	LINE CLEAR AVAILED
411	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:21	18:35	0:13	LINE FAULT
412	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:36	12:06	1:30	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
413	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:40	13:42	0:01	LINE FAULT
414	12-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:01	17:06	0:05	LINE FAULT
415	12-Mar-2020	TUMKUR	66	HARIHARA-DAVANGERE SRS	HARIHAR_66	10:36	12:09	1:32	MAIN SUPPLY FAILURE
416	12-Mar-2020	TUMKUR	66	TR-1	HARIHAR_66	10:36	12:08	1:31	MAIN SUPPLY FAILURE
417	12-Mar-2020	TUMKUR	66	TR-2	HARIHAR_66	10:36	12:08	1:31	MAIN SUPPLY FAILURE
418	12-Mar-2020	TUMKUR	66	TR-1(LV SIDE )	HIRIYUR_220	6:28	7:07	0:38	HAND TRIPPED
419	12-Mar-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	17:34	18:08	0:33	LINE CLEAR AVAILED
420	12-Mar-2020	TUMKUR	66	TR-1	KUNDUR_66	10:03	22:34	12:31	LINE CLEAR AVAILED
421	12-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	9:10	9:54	0:43	LINE FAULT
422	12-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:38	11:50	1:12	LINE FAULT
423	12-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	12:53	13:59	1:06	LINE FAULT
424	12-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:36	15:44	0:07	LINE FAULT
425	12-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	19:25	19:30	0:05	LINE FAULT
426	12-Mar-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	9:59	10:08	0:09	TRANSFORMER FAULT
427	12-Mar-2020	TUMKUR	66	RANGENAHALLI- I/CLINEHIRIYUR	RANGENAHALLI_66	6:27	7:30	1:03	MAIN SUPPLY FAILURE
428	12-Mar-2020	TUMKUR	66	TR-1	THIMMASANDRA_66	15:16	15:17	0:01	TRANSFORMER FAULT
429	12-Mar-2020	TUMKUR	66	TR-2	THOVINAKERE_66	10:02	10:14	0:11	TRANSFORMER FAULT
430	12-Mar-2020	TUMKUR	66	TR-2	THOVINAKERE_66	16:05	18:01	1:55	LINE CLEAR AVAILED
431	12-Mar-2020	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	13:04	13:12	0:08	LINE FAULT
432	12-Mar-2020	TUMKUR	66	TR-1	TYAVANAGI_66	11:45	12:17	0:32	LINE CLEAR AVAILED
433	12-Mar-2020	TUMKUR	66	TR-1	TYAVANAGI_66	16:32	17:43	1:10	LINE CLEAR AVAILED
434	13-Mar-2020	BAGALKOT	110	110/11KV,HV2	AIGALI_110	18:01	18:08	0:07	TRANSFORMER FAULT
435	13-Mar-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	12:31	13:40	1:09	LINE CLEAR AVAILED
436	13-Mar-2020	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	15:58	18:09	2:11	LINE CLEAR AVAILED
437	13-Mar-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI&SINDAGI	NIDAGUNDI_110,SINDAG_110	14:11	14:26	0:15	LINE CLEAR AVAILED
438	13-Mar-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI&SINDAGI	NIDAGUNDI_110,SINDAG_110	16:39	16:47	0:08	LINE CLEAR AVAILED
439	13-Mar-2020	BAGALKOT	110	GHATAPRABHA220-MANTUR	MANTUR_110	6:36	6:53	0:17	LINE FAULT
440	13-Mar-2020	BAGALKOT	220	220/110KV,HV3,LV3	GADAG_220	10:33	17:57	7:24	LINE CLEAR AVAILED
441	13-Mar-2020	BAGALKOT	110	HAVERI220-HANAGAL(TILUVALI)	HANAGAL_110	22:04	22:15	0:11	LINE FAULT
442	13-Mar-2020	BAGALKOT	110	110/33KV,HV 3&HV2	HANAGAL_110,BELAGALPET_33,AKKIALUR_33,LAXMIPUR_33,BOMMANALLI_33,BASAPUR_33	9:10	9:21	0:11	TRANSFORMER FAULT
443	13-Mar-2020	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	9:09	19:04	9:55	LINE CLEAR AVAILED
444	13-Mar-2020	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	10:44	10:48	0:04	LINE CLEAR AVAILED
445	13-Mar-2020	BAGALKOT	110	110/11KV,HV2	RANEBENNUR_220	0:00	14:46	14:46	LINE CLEAR AVAILED
446	13-Mar-2020	BAGALKOT	110	110/11KV,HV1	ZALKI_110	6:40	6:50	0:10	TRANSFORMER FAULT
447	13-Mar-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	6:44	7:02	0:18	TRANSFORMER FAULT
448	13-Mar-2020	BAGALKOT	110	ATHANI 220-TODALBAGI	TODALBAGI_110	8:55	10:25	1:30	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
449	13-Mar-2020	BAGALKOT	110	TODALBAGI-RSP_SOLAR	TODALBAGI_110,RSP_SOLAR	10:27	10:29	0:02	LINE CLEAR AVAILED
450	13-Mar-2020	BAGALKOT	220	SRSHUBLI-SIRSI2	SRSHUBLI_220	15:12	17:28	2:16	LINE FAULT
451	13-Mar-2020	BAGALKOT	110	110/11KV,HV1	SIRSI_110	7:33	8:04	0:31	LINE CLEAR AVAILED
452	13-Mar-2020	BAGALKOT	110	110/11KV,HV1	SIRSI_110	8:13	11:29	3:16	LINE CLEAR AVAILED
453	13-Mar-2020	BAGALKOT	110	110/11KV,HV1	SIRSI_110	11:31	11:54	0:23	LINE CLEAR AVAILED
454	13-Mar-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	11:15	11:46	0:31	LINE CLEAR AVAILED
455	13-Mar-2020	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110,HUKKERI_110	12:13	12:19	0:06	LINE FAULT
456	13-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	17:03	17:49	0:46	MAIN SUPPLY FAILURE
457	13-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:03	17:49	0:46	MAIN SUPPLY FAILURE
458	13-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	17:03	17:41	0:38	MAIN SUPPLY FAILURE
459	13-Mar-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	17:03	17:49	0:46	MAIN SUPPLY FAILURE
460	13-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	17:03	17:49	0:46	MAIN SUPPLY FAILURE
461	13-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIIRAKURU, NANGALI	17:03	17:49	0:46	MAIN SUPPLY FAILURE
462	13-Mar-2020	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	17:10	17:47	0:37	MAIN SUPPLY FAILURE
463	13-Mar-2020	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	21:11	21:26	0:15	MAIN SUPPLY FAILURE
464	13-Mar-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	17:10	17:50	0:40	MAIN SUPPLY FAILURE
465	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:10	17:50	0:40	MAIN SUPPLY FAILURE
466	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:10	17:50	0:40	MAIN SUPPLY FAILURE
467	13-Mar-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:10	17:50	0:40	MAIN SUPPLY FAILURE
468	13-Mar-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	17:10	17:50	0:40	MAIN SUPPLY FAILURE
469	13-Mar-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:10	17:50	0:40	MAIN SUPPLY FAILURE
470	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:10	17:50	0:40	MAIN SUPPLY FAILURE
471	13-Mar-2020	BENGALURU	220	HV1	MALUR 220	17:10	17:49	0:39	MAIN SUPPLY FAILURE
472	13-Mar-2020	BENGALURU	220	HV2	MALUR 220	17:10	17:49	0:39	MAIN SUPPLY FAILURE
473	13-Mar-2020	BENGALURU	220	HV1	MALUR 220	21:11	21:29	0:18	MAIN SUPPLY FAILURE
474	13-Mar-2020	BENGALURU	220	HV2	MALUR 220	21:11	21:29	0:18	MAIN SUPPLY FAILURE
475	13-Mar-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	21:11	21:30	0:19	MAIN SUPPLY FAILURE
476	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:11	21:30	0:19	MAIN SUPPLY FAILURE
477	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:11	21:30	0:19	MAIN SUPPLY FAILURE
478	13-Mar-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	21:11	21:30	0:19	MAIN SUPPLY FAILURE
479	13-Mar-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:11	21:30	0:19	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
480	13-Mar-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	21:11	21:30	0:19	MAIN SUPPLY FAILURE
481	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:11	21:30	0:19	MAIN SUPPLY FAILURE
482	13-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	21:11	21:30	0:19	MAIN SUPPLY FAILURE
483	13-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	21:11	21:30	0:19	MAIN SUPPLY FAILURE
484	13-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	21:11	21:30	0:19	MAIN SUPPLY FAILURE
485	13-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:11	21:28	0:17	MAIN SUPPLY FAILURE
486	13-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:11	21:28	0:17	MAIN SUPPLY FAILURE
487	13-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	21:11	21:28	0:17	MAIN SUPPLY FAILURE
488	13-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	21:11	22:04	0:53	MAIN SUPPLY FAILURE
489	13-Mar-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	21:11	21:28	0:17	MAIN SUPPLY FAILURE
490	13-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	21:11	21:27	0:16	MAIN SUPPLY FAILURE
491	13-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:11	21:27	0:16	MAIN SUPPLY FAILURE
492	13-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	21:11	21:27	0:16	MAIN SUPPLY FAILURE
493	13-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:10	22:14	0:04	LOAD CURTAILMENT
494	13-Mar-2020	BENGALURU	66	HV1	VOLVO	15:06	15:37	0:30	TRANSFORMER FAULT
495	13-Mar-2020	BENGALURU	66	HV2	SIDDALAGATTA	15:38	16:27	0:48	LINE CLEAR AVAILED
496	13-Mar-2020	BENGALURU	66	HV1	MUDIYANUR	15:32	15:40	0:07	TRANSFORMER FAULT
497	13-Mar-2020	BENGALURU	66	HV1	MUDIYANUR	17:50	18:01	0:11	TRANSFORMER FAULT
498	13-Mar-2020	BENGALURU	66	HV1	MUDIYANUR	18:21	18:30	0:08	TRANSFORMER FAULT
499	13-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	7:02	19:15	12:13	LINE CLEAR AVAILED
500	13-Mar-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:24	13:27	0:02	LINE CLEAR AVAILED
501	13-Mar-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	13:27	13:29	0:01	LINE CLEAR AVAILED
502	13-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	16:57	17:39	0:41	LINE FAULT
503	13-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	21:09	21:22	0:12	LINE FAULT
504	13-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:28	23:40	2:11	LOAD CURTAILMENT
505	13-Mar-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	3:28	3:36	0:07	LINE FAULT
506	13-Mar-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT)	15:51	17:32	1:41	LINE CLEAR AVAILED
507	13-Mar-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	17:52	17:55	0:03	LOAD CHANGE OVER
508	13-Mar-2020	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	19:50	20:50	1:00	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
509	13-Mar-2020	BENGALURU	66	HV1	KHODAYS 220	10:53	10:55	0:02	LINE CLEAR AVAILED
510	13-Mar-2020	GULBARGA	220	KAPNOOR-SHAHAPUR 1	SHAHAPUR_220	0:00	23:59	23:59	LINE CLEAR AVAILED
511	13-Mar-2020	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	1:24	23:59	22:35	LINE CLEAR AVAILED
512	13-Mar-2020	GULBARGA	110	HATTI-SOMMANAMARDI	SOMMANAMARDI_IPP	6:18	6:29	0:11	LINE FAULT
513	13-Mar-2020	GULBARGA	66	HBHALLI-ITTAGGI	HAGARIBOMMANAHALLI_66	5:40	5:55	0:15	MAIN SUPPLY FAILURE
514	13-Mar-2020	GULBARGA	66	KOTTUR-BENNAHALLI	KOTTUR_66	12:10	12:14	0:04	LINE FAULT
515	13-Mar-2020	GULBARGA	110	HV1,HV2	MANVI_110	11:56	12:06	0:10	LINE CLEAR AVAILED
516	13-Mar-2020	GULBARGA	110	HV4	YELBURGA_110	14:37	14:50	0:13	TRANSFORMER FAULT
517	13-Mar-2020	GULBARGA	220	HV2	SHAHAPUR_220	1:24	2:00	0:36	TRANSFORMER FAULT
518	13-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	1:24	2:06	0:42	LINE FAULT
519	13-Mar-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	1:42	2:08	0:26	LINE FAULT
520	13-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	4:42	4:49	0:07	LINE FAULT
521	13-Mar-2020	GULBARGA	110	HV1	JEWARGI_110	16:45	16:55	0:10	LINE CLEAR AVAILED
522	13-Mar-2020	HASSAN	220	HV2	SHIRALKOPPA_220	12:45	13:25	0:40	LINE CLEAR AVAILED
523	13-Mar-2020	HASSAN	110	LV2	SHIRALKOPPA_220	12:46	13:28	0:42	LINE CLEAR AVAILED
524	13-Mar-2020	HASSAN	110	HV1	MOODABIDRE_110	2:51	3:00	0:09	TRANSFORMER FAULT
525	13-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	0:00	9:01	9:01	LINE FAULT
526	13-Mar-2020	HASSAN	66	HV1	ALDUR_66	14:15	16:06	1:51	LINE CLEAR AVAILED
527	13-Mar-2020	HASSAN	66	HV1	ALDUR_66	16:20	17:01	0:41	LINE CLEAR AVAILED
528	13-Mar-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	0:00	9:01	9:01	LINE FAULT
529	13-Mar-2020	HASSAN	66	HV1	KANDLI_66	15:45	15:51	0:06	TRANSFORMER FAULT
530	13-Mar-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	13:37	13:48	0:11	LINE FAULT
531	13-Mar-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	7:30	7:47	0:17	TRANSFORMER FAULT
532	13-Mar-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	12:45	13:06	0:21	LINE CLEAR AVAILED
533	13-Mar-2020	HASSAN	66	HV2	BASAVAGHATTA_66	11:41	12:14	0:33	LINE CLEAR AVAILED
534	13-Mar-2020	MYSORE	66	HV1	ATTIGULIPURA_66	10:41	12:02	1:21	LINE CLEAR AVAILED
535	13-Mar-2020	MYSORE	66	HV2	HDKOTE_66	17:59	19:02	1:02	LINE CLEAR AVAILED
536	13-Mar-2020	MYSORE	66	HV2	HDKOTE_66	19:08	19:20	0:11	LINE CLEAR AVAILED
537	13-Mar-2020	MYSORE	220	HV1	KRPET_220	9:05	9:10	0:04	HAND TRIPPED
538	13-Mar-2020	MYSORE	220	HV2	KRPET_220	9:03	9:05	0:02	TRANSFORMER FAULT
539	13-Mar-2020	MYSORE	220	HV2	KRPET_220	9:05	17:56	8:50	LINE CLEAR AVAILED
540	13-Mar-2020	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	14:06	14:10	0:03	LINE FAULT
541	13-Mar-2020	MYSORE	66	TUBINKERE-MANDYA2	CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66 KOPPA_66 BESAGARAHALLI_66	10:48	10:58	0:09	LINE FAULT
542	13-Mar-2020	MYSORE	66	TUBINKERE-MANDYA4	MANDYA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	10:48	10:58	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
543	13-Mar-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:12	22:21	0:08	HAND TRIPPED
544	13-Mar-2020	TUMKUR	110	TR-1	TURUVEKERE_110	12:06	12:54	0:48	LINE CLEAR AVAILED
545	13-Mar-2020	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	10:33	10:55	0:22	HAND TRIPPED
546	13-Mar-2020	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	15:16	16:06	0:50	MAIN SUPPLY FAILURE
547	13-Mar-2020	TUMKUR	66	TR-2	AVAREGERE_66	10:33	10:35	0:01	HAND TRIPPED
548	13-Mar-2020	TUMKUR	66	TR-3	AVAREGERE_66	10:33	11:08	0:35	TRANSFORMER FAULT
549	13-Mar-2020	TUMKUR	66	TR-3	AVAREGERE_66	16:06	16:11	0:04	MAIN SUPPLY FAILURE
550	13-Mar-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	11:21	11:46	0:24	LINE CLEAR AVAILED
551	13-Mar-2020	TUMKUR	66	TR-1	BELADARA_66	11:21	11:47	0:26	LINE CLEAR AVAILED
552	13-Mar-2020	TUMKUR	66	TR-2	BELADARA_66	11:21	11:48	0:26	LINE CLEAR AVAILED
553	13-Mar-2020	TUMKUR	66	TR-1	BUKKAPATNA_66	15:26	16:12	0:45	LINE CLEAR AVAILED
554	13-Mar-2020	TUMKUR	66	TR-1	BUKKAPATNA_66	15:26	16:12	0:45	LINE CLEAR AVAILED
555	13-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	18:27	18:38	0:10	MAIN SUPPLY FAILURE
556	13-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	18:27	18:38	0:10	MAIN SUPPLY FAILURE
557	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	16:55	17:05	0:09	HAND TRIPPED
558	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:04	16:23	0:19	LINE FAULT
559	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:57	9:10	0:12	LINE FAULT
560	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:14	15:13	0:58	LINE FAULT
561	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:42	20:55	0:13	LINE FAULT
562	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:39	8:41	0:02	LINE CLEAR AVAILED
563	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:05	15:05	3:00	LINE CLEAR AVAILED
564	13-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:36	16:55	0:18	LINE CLEAR AVAILED
565	13-Mar-2020	TUMKUR	66	TR-1	HARIHAR_66	7:50	8:12	0:21	TRANSFORMER FAULT
566	13-Mar-2020	TUMKUR	66	TR-2	HOLAVINAHALLY_66	10:18	11:41	1:23	LINE CLEAR AVAILED
567	13-Mar-2020	TUMKUR	66	TR-1	HONNALLI_220	13:52	17:51	3:58	LINE CLEAR AVAILED
568	13-Mar-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:12	9:33	0:21	HAND TRIPPED
569	13-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:28	18:38	0:09	LINE FAULT
570	14-Mar-2020	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	17:24	17:50	0:26	TRANSFORMER FAULT
571	14-Mar-2020	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	10:50	11:30	0:40	LINE CLEAR AVAILED
572	14-Mar-2020	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	2:11	2:27	0:16	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
573	14-Mar-2020	BAGALKOT	110	EILS (SOLAR)-DAMBAL	DAMBAL_110	13:05	14:02	0:57	LINE FAULT
574	14-Mar-2020	BAGALKOT	110	LAXMESHVAR-BELLATTI	BELLATTI_110	8:31	9:12	0:41	LINE FAULT
575	14-Mar-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN_110	9:27	10:00	0:33	LINE CLEAR AVOIDED
576	14-Mar-2020	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B),LINGADALLI_33,DEVAR GENNUR_33	9:54	9:59	0:05	TRANSFORMER FAULT
577	14-Mar-2020	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B),LINGADALLI_33,DEVAR GENNUR_33	10:04	10:08	0:04	TRANSFORMER FAULT
578	14-Mar-2020	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B),LINGADALLI_33,DEVAR GENNUR_33	10:29	10:32	0:03	TRANSFORMER FAULT
579	14-Mar-2020	BAGALKOT	220	GSML1-MAHALINGAPUR	MAHALINGAPUR_220	6:16	6:54	0:38	LINE FAULT
580	14-Mar-2020	BAGALKOT	110	MK HUBLI220-KHANAPUR	KHANAPUR_110	10:00	17:10	7:10	LINE CLEAR AVOIDED
581	14-Mar-2020	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	10:33	12:11	1:38	LINE CLEAR AVOIDED
582	14-Mar-2020	BAGALKOT	110	110/11KV,HV1	ZALKI_110	15:38	16:08	0:30	HAND TRIPPED
583	14-Mar-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	6:40	7:05	0:25	LINE CLEAR AVOIDED
584	14-Mar-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	16:31	17:23	0:52	MAIN SUPPLY FAILURE
585	14-Mar-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	16:31	17:24	0:53	MAIN SUPPLY FAILURE
586	14-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:31	17:24	0:53	MAIN SUPPLY FAILURE
587	14-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	16:31	17:24	0:53	MAIN SUPPLY FAILURE
588	14-Mar-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:31	17:24	0:53	MAIN SUPPLY FAILURE
589	14-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	4:00	9:00	5:00	MAIN SUPPLY FAILURE
590	14-Mar-2020	BENGALURU	66	SUGUTURU - SM MANGALA	SM MANGALLA	4:00	9:45	5:45	MAIN SUPPLY FAILURE
591	14-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	3:52	5:13	1:21	MAIN SUPPLY FAILURE
592	14-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	3:52	5:13	1:21	MAIN SUPPLY FAILURE
593	14-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	4:02	5:18	1:16	MAIN SUPPLY FAILURE
594	14-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	3:52	5:12	1:20	MAIN SUPPLY FAILURE
595	14-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:52	5:12	1:20	MAIN SUPPLY FAILURE
596	14-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	3:52	5:12	1:20	MAIN SUPPLY FAILURE
597	14-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:45	15:45	1:00	LINE CLEAR AVOIDED
598	14-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:45	15:45	1:00	LINE CLEAR AVOIDED
599	14-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:45	15:45	1:00	LINE CLEAR AVOIDED
600	14-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	14:45	15:40	0:55	LINE CLEAR AVOIDED
601	14-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:45	15:40	0:55	LINE CLEAR AVOIDED
602	14-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	14:45	15:40	0:55	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
603	14-Mar-2020	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	16:31	17:30	0:59	MAIN SUPPLY FAILURE
604	14-Mar-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	16:31	17:05	0:34	MAIN SUPPLY FAILURE
605	14-Mar-2020	BENGALURU	220	HV1	SARJAPURA 220	16:31	17:22	0:51	MAIN SUPPLY FAILURE
606	14-Mar-2020	BENGALURU	220	HV2	SARJAPURA 220	16:31	17:22	0:51	MAIN SUPPLY FAILURE
607	14-Mar-2020	BENGALURU	66	HV1	SARJAPURA 220	16:31	17:22	0:51	MAIN SUPPLY FAILURE
608	14-Mar-2020	BENGALURU	66	HV2	SARJAPURA 220	16:31	17:24	0:53	MAIN SUPPLY FAILURE
609	14-Mar-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:31	17:25	0:54	MAIN SUPPLY FAILURE
610	14-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:31	17:25	0:54	MAIN SUPPLY FAILURE
611	14-Mar-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:31	17:48	1:17	MAIN SUPPLY FAILURE
612	14-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:40	17:33	0:53	MAIN SUPPLY FAILURE
613	14-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:40	17:33	0:53	MAIN SUPPLY FAILURE
614	14-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	16:40	17:33	0:53	MAIN SUPPLY FAILURE
615	14-Mar-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	16:40	17:33	0:53	MAIN SUPPLY FAILURE
616	14-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	16:40	17:33	0:53	MAIN SUPPLY FAILURE
617	14-Mar-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	16:40	17:33	0:53	MAIN SUPPLY FAILURE
618	14-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:40	17:33	0:53	MAIN SUPPLY FAILURE
619	14-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	16:40	17:33	0:53	MAIN SUPPLY FAILURE
620	14-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	16:40	17:33	0:53	MAIN SUPPLY FAILURE
621	14-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	19:15	19:30	0:15	LOAD CURTAILMENT
622	14-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:32	20:05	0:33	LOAD CURTAILMENT
623	14-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:20	21:25	0:05	LOAD CURTAILMENT
624	14-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	21:50	22:30	0:40	LOAD CURTAILMENT
625	14-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	22:13	22:29	0:16	LOAD CURTAILMENT
626	14-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	7:55	19:05	11:10	LINE CLEAR AVAILED
627	14-Mar-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	14:14	16:02	1:48	LINE FAULT
628	14-Mar-2020	BENGALURU	66	HV2	SARJAPURA 220	0:49	1:02	0:12	TRANSFORMER FAULT
629	14-Mar-2020	BENGALURU	66	HV1	KOLAR 220	16:02	16:17	0:15	TRANSFORMER FAULT
630	14-Mar-2020	BENGALURU	66	HV1	KOLAR 220	18:40	18:42	0:02	TRANSFORMER FAULT
631	14-Mar-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	6:15	6:57	0:41	LINE FAULT
632	14-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	22:29	23:32	1:03	LOAD CURTAILMENT
633	14-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	16:30	17:28	0:57	LINE FAULT
634	14-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	3:52	5:09	1:16	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
635	14-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	14:44	15:18	0:33	LINE CLEAR AVAILED
636	14-Mar-2020	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	19:01	19:09	0:07	LOAD CHANGE OVER
637	14-Mar-2020	BENGALURU	66	NAGANATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	8:35	9:09	0:34	LINE FAULT
638	14-Mar-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	10:16	12:24	2:08	LINE CLEAR AVAILED
639	14-Mar-2020	BENGALURU	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	10:52	11:10	0:18	LINE FAULT
640	14-Mar-2020	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	20:35	21:10	0:35	TRANSFORMER FAULT
641	14-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA	10:35	10:53	0:18	LOAD CHANGE OVER
642	14-Mar-2020	BENGALURU	66	HV1	VIJAYANAGARA	13:11	14:08	0:57	LINE CLEAR AVAILED
643	14-Mar-2020	BENGALURU	66	HV2	VIJAYANAGARA	14:11	14:59	0:48	LINE CLEAR AVAILED
644	14-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	5:57	6:09	0:12	LINE FAULT
645	14-Mar-2020	GULBARGA	220	KAPNOOR-SHAHAPUR 1	SHAHAPUR_220	0:00	19:33	19:33	LINE CLEAR AVAILED
646	14-Mar-2020	GULBARGA	220	HUMNABAD220-SEDAM2	KAPNOOR_220	10:58	11:15	0:17	LINE FAULT
647	14-Mar-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	8:22	11:14	2:52	LINE FAULT
648	14-Mar-2020	GULBARGA	110	SEDAM-VICATSAGAR	SEDAM_220	23:05	23:59	0:54	LINE FAULT
649	14-Mar-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	17:12	17:20	0:08	LINE FAULT
650	14-Mar-2020	GULBARGA	110	SEDAM-VICATSAGAR	SEDAM_220	0:00	0:06	0:06	LINE FAULT
651	14-Mar-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDA PUR_110,CORE GREEN SUGAR_IPP,SANNATHI_IPP	0:03	0:13	0:10	LINE FAULT
652	14-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	6:08	6:17	0:09	LINE FAULT
653	14-Mar-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	6:08	6:35	0:27	LINE FAULT
654	14-Mar-2020	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	0:00	23:59	23:59	LINE CLEAR AVAILED
655	14-Mar-2020	GULBARGA	110	HV2	HATT_110	9:12	9:16	0:04	TRANSFORMER FAULT
656	14-Mar-2020	GULBARGA	110	BYAGAWAT-ACME_SLR	BYAGAWAT_110	6:13	6:26	0:13	MAIN SUPPLY FAILURE
657	14-Mar-2020	GULBARGA	110	HV1	KURKUNTA_110	4:35	17:49	13:14	TRANSFORMER FAULT
658	14-Mar-2020	GULBARGA	110	HV1	KEMBHAVI_110	14:45	14:50	0:05	TRANSFORMER FAULT
659	14-Mar-2020	GULBARGA	110	HV1	KEMBHAVI_110	15:00	15:10	0:10	TRANSFORMER FAULT
660	14-Mar-2020	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110	15:30	15:40	0:10	LINE CLEAR AVAILED
661	14-Mar-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:12	13:11	2:59	LINE CLEAR AVAILED
662	14-Mar-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	9:44	12:32	2:48	LINE CLEAR AVAILED
663	14-Mar-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	9:44	12:31	2:47	NFBC ISSUED
664	14-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:04	13:12	0:08	LINE FAULT
665	14-Mar-2020	HASSAN	110	KADUR-YGTI	KADUR_220	10:46	11:51	1:05	LINE FAULT
666	14-Mar-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:11	11:14	0:03	HAND TRIPPED
667	14-Mar-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	7:33	7:38	0:05	LINE FAULT
668	14-Mar-2020	HASSAN	66	HV1	ALDUR_66	22:32	22:42	0:10	TRANSFORMER FAULT
669	14-Mar-2020	HASSAN	66	HV1	KANDLI_66	17:00	17:04	0:04	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
670	14-Mar-2020	HASSAN	66	KUDIGE-ANVRPP	KUDLIGERE_66	18:58	19:04	0:06	LINE FAULT
671	14-Mar-2020	MYSORE	66	HV1	BOOKANAKERE_66	8:07	8:12	0:05	HAND TRIPPED
672	14-Mar-2020	MYSORE	66	HV2	BOOKANAKERE_66	8:07	8:12	0:05	HAND TRIPPED
673	14-Mar-2020	MYSORE	66	HV2	KMDODDI_66	22:30	22:46	0:16	TRANSFORMER FAULT
674	14-Mar-2020	MYSORE	220	HV1	KRPET_220	9:02	19:26	10:24	LINE CLEAR AVAILED
675	14-Mar-2020	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	8:34	8:39	0:04	LINE FAULT
676	14-Mar-2020	MYSORE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	18:24	18:27	0:03	LINE FAULT
677	14-Mar-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:27	12:34	0:07	LINE FAULT
678	14-Mar-2020	MYSORE	66	HV1	MADIKERI_66	11:32	12:44	1:12	LINE CLEAR AVAILED
679	14-Mar-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:22	15:14	1:52	LINE CLEAR AVAILED
680	14-Mar-2020	TUMKUR	66	TR-3	AVAREGERE_66	12:21	12:28	0:06	TRANSFORMER FAULT
681	14-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	8:28	8:39	0:11	MAIN SUPPLY FAILURE
682	14-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	12:28	12:39	0:10	MAIN SUPPLY FAILURE
683	14-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:06	16:51	0:45	MAIN SUPPLY FAILURE
684	14-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	8:28	8:39	0:11	MAIN SUPPLY FAILURE
685	14-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	12:28	12:39	0:10	MAIN SUPPLY FAILURE
686	14-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	16:06	16:51	0:45	MAIN SUPPLY FAILURE
687	14-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:58	10:13	0:14	LINE FAULT
688	14-Mar-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:15	10:25	0:09	LINE FAULT
689	14-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:22	13:32	0:10	LINE FAULT
690	14-Mar-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:07	16:17	0:09	LINE FAULT
691	14-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:28	8:39	0:11	LINE FAULT
692	15-Mar-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	2:55	3:16	0:21	LINE FAULT
693	15-Mar-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	2:55	3:16	0:21	LINE FAULT
694	15-Mar-2020	BAGALKOT	110	BAGEWADI-CHIMMALAGI	CHIMMALAGI LIS _110	2:30	3:23	0:53	LINE FAULT
695	15-Mar-2020	BAGALKOT	110	110/11KV,HV3&2	GULEDAGUDDA_110	12:04	12:07	0:03	HAND TRIPPED
696	15-Mar-2020	BAGALKOT	110	110/33KV,HV1	GULEDAGUDDA_110,SHIRUR_33,KAMAT AGI_33	12:04	12:08	0:04	HAND TRIPPED
697	15-Mar-2020	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	11:37	11:55	0:18	LINE FAULT
698	15-Mar-2020	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	12:23	12:40	0:17	LINE FAULT
699	15-Mar-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,MYTRA SOLAR_33	10:31	19:04	8:33	LINE CLEAR AVAILED
700	15-Mar-2020	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAVADI_33	10:31	19:04	8:33	LINE CLEAR AVAILED
701	15-Mar-2020	BAGALKOT	110	110/11KV,HV1&2	HIDIKAL_110	10:31	19:02	8:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
702	15-Mar-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	10:11	17:50	7:39	LINE CLEAR AVAILED
703	15-Mar-2020	BAGALKOT	110	ITNAL-HIDIKAL(RAIBAG)	HIDIKAL_110	10:10	17:50	7:40	LINE CLEAR AVAILED
704	15-Mar-2020	BAGALKOT	110	HUNGUND-KUDALA SANGAM	KUDALA SANGAM_110	6:24	6:33	0:09	LINE FAULT
705	15-Mar-2020	BAGALKOT	220	GSML1-MAHALINGAPUR	MAHALINGAPUR_220	11:35	11:51	0:16	LINE FAULT
706	15-Mar-2020	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	11:35	13:53	2:18	LINE FAULT
707	15-Mar-2020	BAGALKOT	110	110/11KV,HV1	MK HUBLI_220	10:12	11:09	0:57	LINE CLEAR AVAILED
708	15-Mar-2020	BAGALKOT	110	NARAGAL-RON	RON_110	10:51	23:59	13:08	LINE CLEAR AVAILED
709	15-Mar-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	20:57	21:22	0:25	TRANSFORMER FAULT
710	15-Mar-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	21:28	21:37	0:09	TRANSFORMER FAULT
711	15-Mar-2020	BAGALKOT	110	110/11KV,HV1	ZALKI_110	7:30	7:45	0:15	TRANSFORMER FAULT
712	15-Mar-2020	BAGALKOT	110	TODALBAGI-RSP_SOLAR	TODALBAGI_110,RSP_SOLAR	12:18	12:23	0:05	LINE FAULT
713	15-Mar-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110,RSP_SOLAR	21:50	21:57	0:07	TRANSFORMER FAULT
714	15-Mar-2020	BAGALKOT	110	TERDAL-SOVERIGN	TERDAL_110	13:35	23:59	10:24	LINE FAULT
715	15-Mar-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	7:55	10:13	2:18	LINE CLEAR AVAILED
716	15-Mar-2020	BAGALKOT	110	SAVANUR-SHIGGOAN	SHIGGOAN_110	22:03	22:23	0:20	LINE FAULT
717	15-Mar-2020	BAGALKOT	110	SANKESHWAR-IPP SOLAR	ACME SOLAR_IPP	8:20	9:10	0:50	LINE FAULT
718	15-Mar-2020	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL, KYALANUR	8:05	19:02	10:57	LINE CLEAR AVAILED
719	15-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	7:57	19:50	11:53	LINE CLEAR AVAILED
720	15-Mar-2020	BENGALURU	66	TUBUGERE - DB PURA 220	TUBUGERE	9:58	19:45	9:46	LINE CLEAR AVAILED
721	15-Mar-2020	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	9:42	17:45	8:03	LINE CLEAR AVAILED
722	15-Mar-2020	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	9:43	11:36	1:53	LINE CLEAR AVAILED
723	15-Mar-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:00	12:29	1:29	LINE CLEAR AVAILED
724	15-Mar-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	7:00	10:00	3:00	LINE CLEAR AVAILED
725	15-Mar-2020	BENGALURU	66	SIR M V LAYOUT - VRISHABHAVATHI 220	SIR M V LAYOUT,KENGERI SATELLITE TOWN,KUMBALAGODU	11:01	11:14	0:13	LINE FAULT
726	15-Mar-2020	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	8:45	8:50	0:05	LOAD CHANGE OVER
727	15-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	15:02	15:25	0:23	LINE CLEAR AVAILED
728	15-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	10:02	10:25	0:23	LINE CLEAR AVAILED
729	15-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	10:02	10:25	0:23	LINE CLEAR AVAILED
730	15-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	15:02	15:25	0:23	LINE CLEAR AVAILED
731	15-Mar-2020	BENGALURU	66	SOMANAHALLI 66 - SUBRAMANYAPURA 220	SOMANAHALLI 66	10:23	10:29	0:06	LOAD CHANGE OVER
732	15-Mar-2020	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	7:25	7:30	0:05	LOAD CHANGE OVER
733	15-Mar-2020	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	19:25	19:35	0:10	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
734	15-Mar-2020	GULBARGA	110	HV2	HATT_110	17:17	17:24	0:07	TRANSFORMER FAULT
735	15-Mar-2020	GULBARGA	110	HATTI-SINDHANOOR	HATT_110	21:12	23:59	2:47	LINE FAULT
736	15-Mar-2020	GULBARGA	110	BYAGAWAT-VALKAMDINNI	BYAGAWAT_110	3:00	3:10	0:10	LINE FAULT
737	15-Mar-2020	GULBARGA	110	BYAGAWAT-VALKAMDINNI	VALKAMDINNI_110	5:05	5:15	0:10	LINE FAULT
738	15-Mar-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	11:40	11:45	0:05	TRANSFORMER FAULT
739	15-Mar-2020	GULBARGA	110	HUMNABAD220-ALAND	ALAND_110	6:20	6:30	0:10	LINE FAULT
740	15-Mar-2020	GULBARGA	220	LINGAPUR-ARREASTEEL	LINGAPUR_220	15:40	17:59	2:19	LINE FAULT
741	15-Mar-2020	GULBARGA	110	MALLAT-MADALAPUR	`MADALAPUR_110	3:15	3:25	0:10	LINE FAULT
742	15-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	1:18	1:20	0:02	LINE FAULT
743	15-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	4:40	4:50	0:10	LINE FAULT
744	15-Mar-2020	GULBARGA	220	HUMNABAD220-SEDAM1	HALBARGA_220	18:06	18:20	0:14	LINE FAULT
745	15-Mar-2020	GULBARGA	220	HUMNABAD220-SEDAM2	KAPNOOR_220	18:06	18:20	0:14	LINE FAULT
746	15-Mar-2020	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	0:00	23:59	23:59	LINE CLEAR AVAILED
747	15-Mar-2020	GULBARGA	110	SEDAM-TANDUR	TANDUR_220	18:07	19:46	1:39	LINE FAULT
748	15-Mar-2020	GULBARGA	110	HV2	BETAGERA_110	11:17	11:36	0:19	LINE CLEAR AVAILED
749	15-Mar-2020	GULBARGA	110	HV3	BETAGERA_110	11:20	11:34	0:14	LINE CLEAR AVAILED
750	15-Mar-2020	GULBARGA	110	HV2	HATT_110	17:17	17:24	0:07	TRANSFORMER FAULT
751	15-Mar-2020	GULBARGA	110	HATTI-SINDHANOOR	HATT_110	21:12	23:59	2:47	LINE FAULT
752	15-Mar-2020	GULBARGA	110	BYAGAWAT-VALKAMDINNI	BYAGAWAT_110	3:00	3:10	0:10	LINE FAULT
753	15-Mar-2020	GULBARGA	110	BYAGAWAT-VALKAMDINNI	VALKAMDINNI_110	5:05	5:15	0:10	LINE FAULT
754	15-Mar-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	11:40	11:45	0:05	TRANSFORMER FAULT
755	15-Mar-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	15:49	17:01	1:12	LINE CLEAR AVAILED
756	15-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:00	18:39	18:39	LINE FAULT
757	15-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	18:41	23:59	5:18	LINE FAULT
758	15-Mar-2020	HASSAN	220	HV1	KAVOOR_220	12:20	13:18	0:58	LINE CLEAR AVAILED
759	15-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	15:49	17:01	1:12	LINE CLEAR AVAILED
760	15-Mar-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	0:00	18:35	18:35	LINE FAULT
761	15-Mar-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:41	23:59	5:18	LINE FAULT
762	15-Mar-2020	HASSAN	110	LV1	KAVOOR_220	12:20	14:15	1:55	LINE CLEAR AVAILED
763	15-Mar-2020	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	13:29	14:40	1:11	LINE CLEAR AVAILED
764	15-Mar-2020	HASSAN	110	HV1	GANDASI_110	7:15	7:32	0:17	LINE CLEAR AVAILED
765	15-Mar-2020	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	12:03	14:40	2:37	LINE CLEAR AVAILED
766	15-Mar-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	10:20	16:44	6:24	LINE CLEAR AVAILED
767	15-Mar-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:12	15:22	0:10	LINE FAULT
768	15-Mar-2020	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	10:36	16:25	5:49	LINE CLEAR AVAILED
769	15-Mar-2020	HASSAN	66	HV1	BYACHANAHALLI_66	10:15	16:48	6:33	LINE CLEAR AVAILED
770	15-Mar-2020	HASSAN	66	HV2	HALEBEEDU_66	11:47	12:02	0:15	LINE CLEAR AVAILED
771	15-Mar-2020	HASSAN	66	HV1	KIADB_66	10:25	18:10	7:45	LINE CLEAR AVAILED
772	15-Mar-2020	HASSAN	66	HV2	KIADB_66	18:10	19:25	1:15	LINE CLEAR AVAILED
773	15-Mar-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	10:15	10:30	0:15	HAND TRIPPED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
774	15-Mar-2020	MYSORE	66	HV1	JAKKANAHALLY_66	15:09	15:18	0:09	TRANSFORMER FAULT
775	15-Mar-2020	MYSORE	66	KR PETE 220-SNTBCL	SANTHEBACHALLI_66, HARIYALADAMMA_66	10:47	10:55	0:07	LINE FAULT
776	15-Mar-2020	MYSORE	66	HV1	DODDINADUVADI_66	10:27	16:48	6:21	LINE CLEAR AVAILED
777	15-Mar-2020	MYSORE	66	HV2	DODDINADUVADI_66	10:27	16:48	6:21	LINE CLEAR AVAILED
778	15-Mar-2020	MYSORE	66	ELWALA-HUNSUR	GAVADAGERE_66	20:32	20:44	0:11	LINE FAULT
779	15-Mar-2020	MYSORE	66	HV1	SUNTIKOPPA_66	14:25	16:00	1:34	LINE CLEAR AVAILED
780	15-Mar-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:03	14:34	1:30	LINE FAULT
781	15-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	10:02	14:38	4:35	LINE CLEAR AVAILED
782	15-Mar-2020	TUMKUR	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	10:15	10:16	0:01	MAIN SUPPLY FAILURE
783	15-Mar-2020	TUMKUR	66	TR-1	BENKIKERE_66	9:17	10:15	0:57	MAIN SUPPLY FAILURE
784	15-Mar-2020	TUMKUR	66	TR-2	BENKIKERE_66	9:17	10:15	0:57	MAIN SUPPLY FAILURE
785	15-Mar-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	18:42	18:57	0:15	LINE FAULT
786	15-Mar-2020	TUMKUR	66	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	8:43	18:33	9:50	MAIN SUPPLY FAILURE
787	15-Mar-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	8:42	18:37	9:54	MAIN SUPPLY FAILURE
788	15-Mar-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	8:42	18:37	9:55	MAIN SUPPLY FAILURE
789	15-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:03	11:22	0:19	LINE FAULT
790	15-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:32	12:47	0:15	LINE FAULT
791	15-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:07	19:15	0:07	LINE FAULT
792	15-Mar-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:01	9:12	0:11	HAND TRIPPED
793	15-Mar-2020	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:16	18:53	10:37	LINE CLEAR AVAILED
794	15-Mar-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	8:16	18:53	10:37	LINE CLEAR AVAILED
795	15-Mar-2020	TUMKUR	66	TR-2	THOVINAKERE_66	15:37	18:14	2:37	LINE CLEAR AVAILED
796	16-Mar-2020	BAGALKOT	110	110/11KV,HV-2	AINAPUR_110	7:34	7:39	0:05	HAND TRIPPED
797	16-Mar-2020	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	9:36	15:38	6:02	LINE CLEAR AVAILED
798	16-Mar-2020	BAGALKOT	110	AMBEWADI-NK1	KAVALWAD_110	9:24	15:39	6:15	LINE CLEAR AVAILED
799	16-Mar-2020	BAGALKOT	110	ANKALI-HERMS	ANKALI_110	0:00	17:34	17:34	LINE CLEAR AVAILED
800	16-Mar-2020	BAGALKOT	110	110/11KV,HV-2	BANAHATTI_110	16:59	17:06	0:07	LINE CLEAR AVAILED
801	16-Mar-2020	BAGALKOT	110	110/11KV,HV 1	BIDNAL_110	15:07	17:41	2:34	LINE CLEAR AVAILED
802	16-Mar-2020	BAGALKOT	110	GHATAPRABHA-MUDALAGI(MANTUR)	MANTUR_110	5:55	6:04	0:09	LINE FAULT
803	16-Mar-2020	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	22:07	22:14	0:07	TRANSFORMER FAULT
804	16-Mar-2020	BAGALKOT	110	110/33KV, HV2	RATTIHALLI_110, MASUR_33, HALLUR_33	21:42	23:59	2:17	TRANSFORMER FAULT
805	16-Mar-2020	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(B)_110	17:20	17:47	0:27	LINE CLEAR AVAILED
806	16-Mar-2020	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	16:24	16:31	0:07	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
807	16-Mar-2020	BAGALKOT	110	110/11KV, HV1	MALGHAN(B)_110	9:23	9:26	0:03	TRANSFORMER FAULT
808	16-Mar-2020	BAGALKOT	110	110/11KV, HV1	MALGHAN(B)_110	9:38	9:40	0:02	TRANSFORMER FAULT
809	16-Mar-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, RABKAVI_110, TERDAL_110, HIDIKAL_110, ITANAL_110	7:25	7:53	0:28	TRANSFORMER FAULT
810	16-Mar-2020	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	19:20	19:25	0:05	LINE FAULT
811	16-Mar-2020	BAGALKOT	110	110/11KV, HV1	ITANAL_110	9:47	9:51	0:04	TRANSFORMER FAULT
812	16-Mar-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	16:25	16:32	0:07	TRANSFORMER FAULT
813	16-Mar-2020	BAGALKOT	110	110/11KV, HV2	HALIYAL_110	1:57	2:17	0:20	TRANSFORMER FAULT
814	16-Mar-2020	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220	10:42	11:00	0:18	TRANSFORMER FAULT
815	16-Mar-2020	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220	11:37	11:50	0:13	TRANSFORMER FAULT
816	16-Mar-2020	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	10:42	12:47	2:05	TRANSFORMER FAULT
817	16-Mar-2020	BAGALKOT	110	VAJRAMATTI220-BILAGI,MANTUR1&2	BILAGI_110,MANTUR_110	10:45	11:10	0:25	HAND TRIPPED
818	16-Mar-2020	BAGALKOT	110	VAJRAMATTI220-MANTUR1&2,VAJRAMATTI	MANTUR_110,VAJRAMATTI_110	11:42	12:48	1:06	LINE CLEAR AVAILED
819	16-Mar-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR,KATARAKI,BILAGI	LOKAPUR_110,KATARAKI_110,BILAGI_110	11:42	12:50	1:08	LINE CLEAR AVAILED
820	16-Mar-2020	BAGALKOT	110	VAJRAMATTI220-MELLIGERI	MELLIGERI_110	11:42	13:00	1:18	LINE CLEAR AVAILED
821	16-Mar-2020	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	10:22	18:52	8:30	LINE CLEAR AVAILED
822	16-Mar-2020	BAGALKOT	220	BAGEWADI-NANDIHAL1	BAGEWADI_220	17:54	19:09	1:15	LINE CLEAR AVAILED
823	16-Mar-2020	BAGALKOT	220	FFHTL 2-BAGEWADI	BAGEWADI_220	11:12	14:40	3:28	LINE CLEAR AVAILED
824	16-Mar-2020	BAGALKOT	220	FFHTL 1-BAGEWADI	BAGEWADI_220	15:35	17:41	2:06	LINE CLEAR AVAILED
825	16-Mar-2020	BAGALKOT	220	BAGEWADI-BALUTI	BAGEWADI_220	18:40	19:05	0:25	LINE CLEAR AVAILED
826	16-Mar-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	8:30	9:04	0:33	LINE FAULT
827	16-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:54	16:28	0:33	LINE FAULT
828	16-Mar-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:07	12:19	1:12	LINE FAULT
829	16-Mar-2020	BENGALURU	66	HV2	CHAKAVELU	8:30	9:04	0:33	TRANSFORMER FAULT
830	16-Mar-2020	BENGALURU	66	HV1	KIADB DB PURA 220	12:15	12:20	0:04	LINE CLEAR AVAILED
831	16-Mar-2020	BENGALURU	66	HV2	KIADB DB PURA 220	15:26	15:37	0:10	LINE CLEAR AVAILED
832	16-Mar-2020	BENGALURU	66	HV1	ELECTRONIC CIT	17:14	18:48	1:34	LINE CLEAR AVAILED
833	16-Mar-2020	BENGALURU	66	HV1	MALLASANDRA	10:53	11:46	0:53	LINE CLEAR AVAILED
834	16-Mar-2020	BENGALURU	66	HV2	TELECOM LAYOUT	15:02	15:46	0:44	LINE CLEAR AVAILED
835	16-Mar-2020	BENGALURU	66	HV1	MITTEMARI 220	7:43	17:20	9:37	LINE CLEAR AVAILED
836	16-Mar-2020	BENGALURU	66	HV1	BAIRKUR	15:05	15:10	0:05	LINE CLEAR AVAILED
837	16-Mar-2020	BENGALURU	66	HV2	BANASHANKARI	13:45	13:50	0:05	LINE CLEAR AVAILED
838	16-Mar-2020	BENGALURU	66	HV3	BANASHANKARI	10:47	10:49	0:02	LINE CLEAR AVAILED
839	16-Mar-2020	BENGALURU	66	CHANDRAPPA CIRCLE - KUMBALAGODU	CHANDRAPPA CIRCLE	23:18	23:22	0:04	LINE FAULT
840	16-Mar-2020	BENGALURU	220	LV2	CHINTAMANI 220	10:10	10:13	0:03	TRANSFORMER FAULT
841	16-Mar-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	10:10	10:25	0:15	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
842	16-Mar-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:13	17:46	0:33	LINE CLEAR AVAILED
843	16-Mar-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	8:17	8:53	0:36	LINE FAULT
844	16-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:31	10:58	0:27	LINE FAULT
845	16-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:04	11:15	0:11	LINE FAULT
846	16-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:42	16:20	1:38	LINE CLEAR AVAILED
847	16-Mar-2020	GULBARGA	220	ITTAGI-HARKANAL	ITTAGI_220	9:30	16:15	6:45	LINE CLEAR AVAILED
848	16-Mar-2020	GULBARGA	220	LINGAPUR-GADAG	LINGAPUR_220	11:43	14:29	2:46	LINE FAULT
849	16-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	1:18	1:28	0:10	LINE FAULT
850	16-Mar-2020	GULBARGA	110	MALLAT-MADALAPUR	MADLAPUR_110, MANVI_110	3:15	3:25	0:10	LINE FAULT
851	16-Mar-2020	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	1:48	2:08	0:20	LINE FAULT
852	16-Mar-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRNAGAR_110,MALLAPURA_110	3:10	3:22	0:12	LINE FAULT
853	16-Mar-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNASIGI_110,ASKI_110	11:20	11:30	0:10	LINE FAULT
854	16-Mar-2020	GULBARGA	110	KEMBHAVI-UGARSUGAR_IPP	KEMBHAVI_110	11:20	11:40	0:20	LINE FAULT
855	16-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	11:20	11:32	0:12	LINE FAULT
856	16-Mar-2020	GULBARGA	110	GURGUNTA-LJVL_IPP,KHEL_IPP	LJVL_IPP,KHEL_IPP	17:50	18:54	1:04	LINE CLEAR AVAILED
857	16-Mar-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	CJ HALLI_66,GUDEKOTE_66,HOSAHALLI_66 ,BANVEKAL_66,CHORNOOR_66	18:05	21:10	3:05	LINE CLEAR AVAILED
858	16-Mar-2020	GULBARGA	66	ITTAGI-HBHALLI	UPHALLI_66,HBHALLI_66	10:05	18:25	8:20	LINE FAULT
859	16-Mar-2020	GULBARGA	66	ITTAGI-HBHALLI	UPHALLI_66,HBHALLI_66	18:30	18:45	0:15	HAND TRIPPED
860	16-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI	HIREHADAGALLI_66	21:20	21:35	0:15	LINE FAULT
861	16-Mar-2020	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	18:05	19:00	0:55	MAIN SUPPLY FAILURE
862	16-Mar-2020	GULBARGA	66	HV1	KUDLIGI_66	8:55	9:35	0:40	LINE CLEAR AVAILED
863	16-Mar-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	13:21	13:39	0:18	HAND TRIPPED
864	16-Mar-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:22	11:30	0:08	LINE FAULT
865	16-Mar-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:52	12:02	1:10	LINE CLEAR AVAILED
866	16-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:48	12:52	0:04	LINE FAULT
867	16-Mar-2020	HASSAN	110	JOG-JLT3	MGHE JOG	16:44	18:32	1:48	LINE CLEAR AVAILED
868	16-Mar-2020	HASSAN	110	JOG-JST1	MGHE JOG	16:44	18:34	1:50	LINE CLEAR AVAILED
869	16-Mar-2020	HASSAN	110	JOG110-MGHE	JOG_110	16:50	18:20	1:30	LINE CLEAR AVAILED
870	16-Mar-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	16:53	18:25	1:32	LINE CLEAR AVAILED
871	16-Mar-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	9:13	9:28	0:15	LINE FAULT
872	16-Mar-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	9:40	13:17	3:37	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
873	16-Mar-2020	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_HSN_66	15:10	16:30	1:20	NFBC ISSUED
874	16-Mar-2020	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	12:20	15:00	2:40	NFBC ISSUED
875	16-Mar-2020	HASSAN	66	HV1	BYACHANAHALLI_66	11:26	11:36	0:10	TRANSFORMER FAULT
876	16-Mar-2020	HASSAN	66	HV1	BYACHANAHALLI_66	11:56	12:00	0:04	TRANSFORMER FAULT
877	16-Mar-2020	HASSAN	66	GANGUR-HASSAN	GANGUR_66	9:45	13:52	4:07	MAIN SUPPLY FAILURE
878	16-Mar-2020	HASSAN	66	HAGARE-HASSAN	HAGARE_66	11:34	13:42	2:08	MAIN SUPPLY FAILURE
879	16-Mar-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	15:13	16:37	1:24	NFBC ISSUED
880	16-Mar-2020	HASSAN	66	HV1	MATNAVILE_66	8:25	8:35	0:10	TRANSFORMER FAULT
881	16-Mar-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	15:09	16:29	1:20	LINE CLEAR AVAILED
882	16-Mar-2020	HASSAN	66	HV1	SALAGAME_66	11:34	11:44	0:10	TRANSFORMER FAULT
883	16-Mar-2020	MYSORE	66	KIRUGAVALU-SFC	KIRUGAVALU_66 VADKEPURA_66	6:09	6:23	0:13	HAND TRIPPED
884	16-Mar-2020	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 TUMBEKERE_66 MADDUR_66 SOMANAHALLI_66	11:07	11:33	0:25	HAND TRIPPED
885	16-Mar-2020	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 TUMBEKERE_66 MADDUR_66 SOMANAHALLI_66	14:53	16:23	1:30	NFBC ISSUED
886	16-Mar-2020	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 TUMBEKERE_66 MADDUR_66 SOMANAHALLI_66	10:31	10:57	0:25	LINE FAULT
887	16-Mar-2020	MYSORE	66	HV2	KRPET_66	13:01	13:23	0:21	LINE CLEAR AVAILED
888	16-Mar-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	JAKKANAHALLY_66 MADESWARAPURA_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	10:43	10:48	0:05	LINE FAULT
889	16-Mar-2020	MYSORE	66	KUSHALNAGAR 220-MYSORE-1	MIRLE_66 BHERYA_66 KRNAGARA_66	11:54	12:08	0:13	LINE FAULT
890	16-Mar-2020	MYSORE	66	KUSHALNAGAR 220-MYSORE-2	BETTADHAPURA_66 RAVANDUR_66 KITTUR_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	11:55	12:08	0:13	LINE FAULT
891	16-Mar-2020	MYSORE	66	MUGUR-MADHUVANAHALLI	SANTHEMARAHALLI_66	10:25	12:31	2:05	NFBC ISSUED
892	16-Mar-2020	MYSORE	66	HV2	PANDAVAPURA_66	14:46	14:50	0:03	HAND TRIPPED
893	16-Mar-2020	MYSORE	66	HV2	PANDAVAPURA_66	18:01	18:04	0:02	HAND TRIPPED
894	16-Mar-2020	MYSORE	66	HV2	THALAKADU_66	9:20	9:59	0:39	LINE CLEAR AVAILED
895	16-Mar-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:29	14:31	2:01	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
896	16-Mar-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:22	14:32	2:10	LINE CLEAR AVAILED
897	16-Mar-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	14:55	17:48	2:53	TRANSFORMER FAULT
898	16-Mar-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	11:57	12:06	0:09	LINE CLEAR AVAILED
899	16-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:32	12:48	0:16	LINE FAULT
900	16-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:07	19:15	0:07	LINE FAULT
901	16-Mar-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	8:17	8:40	0:23	TRANSFORMER FAULT
902	16-Mar-2020	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:26	13:14	2:47	LINE FAULT
903	16-Mar-2020	TUMKUR	66	TR-1	KALAMARANAHALLI_66	17:26	17:34	0:07	HAND TRIPPED
904	16-Mar-2020	TUMKUR	66	TR-1	KATTIGE_66	15:36	15:45	0:09	TRANSFORMER FAULT
905	16-Mar-2020	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:47	19:07	0:19	LINE FAULT
906	16-Mar-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:16	17:32	9:15	LINE CLEAR AVAILED
907	16-Mar-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	16:01	16:04	0:02	MAIN SUPPLY FAILURE