

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM: 02.03.2021 TO 08.03.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	2-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
2	2-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
3	2-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
4	2-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
5	2-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
6	2-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
7	2-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
8	2-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
9	2-Mar-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI 110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
10	2-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
11	2-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI 110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
12	2-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
13	2-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
14	2-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
15	2-Mar-2021	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG 220	10:13 (24.02.2021)	16:39 (02.03.2021)	30:26HRS	LINE CHARGED
16	2-Mar-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
17	2-Mar-2021	BAGALKOT	220	VAJRAMATTI MAHALINGAPUR2-	VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
18	2-Mar-2021	BAGALKOT	220	VAJRAMATTI MAHALINGAPUR1	VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
19	2-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
20	2-Mar-2021	BAGALKOT	220	GADAG- HARTI2	GADAG_220	17:16 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
21	2-Mar-2021	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT 110	4:32 (26.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
22	2-Mar-2021	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE 110	17:42 (28.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
23	2-Mar-2021	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA 110	16:17 (01.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
24	2-Mar-2021	BAGALKOT	110	110/11KV,HV3(HV1)	BAILHONGAL_110	22:45 (01.03.2021)	0:18 (02.03.2021)	1:33HRS	TRANSFORMER CHARGED
25	2-Mar-2021	BAGALKOT	220	CHIKKODI220-MUDASHINGI	STATION NOT AFFECTED CHIKKODI_220	09:36	16:49	7:13	LINE CLEAR AVOIDED
26	2-Mar-2021	BAGALKOT	220	220/110KV,HV3	STATION NOT AFFECTED CHIKKODI_220	10:05	18:42	8:37	LINE CLEAR AVOIDED
27	2-Mar-2021	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG 220	16:49	16:51	0:02	HAND TRIPPED
28	2-Mar-2021	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG 220	17:26 (02.03.2021)			LINE OPEN,LINE FAULT
29	2-Mar-2021	BAGALKOT	110	110/33KV,HV2	GANESHGUDI_110,JOIDA_33	13:06	13:46	0:40	LINE CLEAR AVOIDED
30	2-Mar-2021	BAGALKOT	110	110/11KV,HV1	MALGHAN(S)_110	14:14	14:48	0:34	LINE CLEAR AVOIDED
31	2-Mar-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	14:48	15:05	0:17	LINE CLEAR AVOIDED
32	2-Mar-2021	BAGALKOT	110	RON-NAREGAL	NAREGAL_110	16:45	17:12	0:27	HAND TRIPPED
33	2-Mar-2021	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED VAJRAMATTI 220	15:46	17:05	1:19	LINE CLEAR AVOIDED
34	2-Mar-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED VAJRAMATTI 220	15:45	17:05	1:20	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
35	2-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED UGARKHUD_110	08:10	08:15	0:05	TRANSFORMER FAULT
36	2-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TIKOTA_110	13:08	13:11	0:03	TRANSFORMER FAULT
37	2-Mar-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI2	STATION NOT AFFECTED SOUDATTI_220	10:46	13:41	2:55	LINE CLEAR AVAILED
38	2-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	14:12	14:20	0:08	LINE CLEAR AVAILED
39	2-Mar-2021	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	17:44 (02.03.2021)			LINE OPEN, LINE FAULT
40	2-Mar-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	0:17	0:21	0:04	LOAD CHANGE OVER
41	2-Mar-2021	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI_220	BRIGADE MEADOWS	13:36	13:42	0:06	LOAD CHANGE OVER
42	2-Mar-2021	BENGALURU	66	HV2	HOODY_220	11:02	12:01	0:59	LINE CLEAR AVAILED
43	2-Mar-2021	BENGALURU	66	HV1	HOODY_220	12:45	13:25	0:40	LINE CLEAR AVAILED
44	2-Mar-2021	BENGALURU	66	ISCON - SOMANAHALLI_220	ISCON	14:28	14:32	0:04	LOAD CHANGE OVER
45	2-Mar-2021	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	14:41	14:50	0:09	TRANSFORMER FAULT
46	2-Mar-2021	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	16:07	16:20	0:13	TRANSFORMER FAULT
47	2-Mar-2021	BENGALURU	66	RBI - KHODAYS_220	RBI	6:07	6:11	0:04	LOAD CHANGE OVER
48	2-Mar-2021	BENGALURU	66	TK HALLI_220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	10:10	10:14	0:04	LINE FAULT
49	2-Mar-2021	BENGALURU	66	V R DODDI - SOMANAHALLI_220	V R DODDI	13:27	13:34	0:07	LOAD CHANGE OVER
50	2-Mar-2021	BENGALURU	66	HOSKOTE_220 - HOSKOTE_1	GRINDWELL (EHT)	15:18	16:09	0:51	LINE FAULT
51	2-Mar-2021	BENGALURU	66	HV2	MAASTHI	19:00	19:04	0:04	TRANSFORMER FAULT
52	2-Mar-2021	BENGALURU	66	MALUR_220 - KGF_1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:07	5:15	0:08	LINE FAULT
53	2-Mar-2021	BENGALURU	66	MALUR_220 - KGF_1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:40	18:32	2:52	LINE CLEAR AVAILED
54	2-Mar-2021	BENGALURU	66	MALUR_220 - KGF_2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:05	21:40	0:35	LINE FAULT
55	2-Mar-2021	BENGALURU	66	HV1	TUBUGERE	16:11	16:15	0:04	LINE CLEAR AVAILED
56	2-Mar-2021	BENGALURU	66	HV1	HUKUNDA	13:50	13:55	0:05	TRANSFORMER FAULT
57	2-Mar-2021	BENGALURU	66	GODUR - MARALWADI	GODUR	12:47	13:07	0:20	MAIN SUPPLY FAILURE
58	2-Mar-2021	BENGALURU	220	EDC_220 - NIMHANS_220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN, LINE FAULT
59	2-Mar-2021	GULBARGA	220	HV2	MUNIRABAD_220	08:50	15:15	06:25	LINE CLEAR AVAILED
60	2-Mar-2021	GULBARGA	220	MUNIRABAD-LINGAPUR2	MUNIRABAD_220	09:35	16:47	07:12	NFBC ISSUED
61	2-Mar-2021	GULBARGA	110	TEKKALKOTE-RENEW SOLAR_IPP	TEKKALKOTE_110	19:14(01.03.2021)	2:30(02.03.2021)	7:16 HRS	LINE CHARGED
62	2-Mar-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,KER EHALLI_110,MALLAPUR_110	08:50	09:05	00:15	MAIN SUPPLY FAILURE
63	2-Mar-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,KER EHALLI_110,MALLAPUR_110	11:10	11:25	00:15	LINE FAULT
64	2-Mar-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,KER EHALLI_110,MALLAPUR_110	11:40	11:50	00:10	LINE FAULT
65	2-Mar-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,KER EHALLI_110,MALLAPUR_110	17:35	17:45	00:10	MAIN SUPPLY FAILURE
66	2-Mar-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,KER EHALLI_110,MALLAPUR_110	18:38	18:48	00:10	LINE FAULT
67	2-Mar-2021	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	06:11	06:17	00:06	LINE FAULT
68	2-Mar-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	21:54	22:04	00:10	LINE FAULT
69	2-Mar-2021	GULBARGA	110	GULBARGA SOUTH-GULBARGA UNIVERSITY	GULBARGA UNIVERSITY_110	16:10(02.03.2021)			LINE OPEN, LINE CLEAR AVAILED
70	2-Mar-2021	GULBARGA	110	HV3	HATTI_110	06:45	06:48	00:03	LINE CLEAR AVAILED
71	2-Mar-2021	GULBARGA	110	HV3	HATTI_110	09:29	19:00	09:31	LINE CLEAR AVAILED
72	2-Mar-2021	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALU_110	09:05	11:33	02:28	LINE CLEAR AVAILED
73	2-Mar-2021	GULBARGA	110	HV2	MADIYAL_110	13:31	13:45	00:14	TRANSFORMER FAULT
74	2-Mar-2021	GULBARGA	110	HV2	SANKLAPUR_110	16:28	16:33	00:05	TRANSFORMER FAULT
75	2-Mar-2021	GULBARGA	110	SANKLAPUR-MUNIRABAD	SANKLAPUR_110	08:23	08:48	00:25	MAIN SUPPLY FAILURE
76	2-Mar-2021	GULBARGA	66	CJ_HALLI-HOSAHALLI	HOSAHALLI_66	13:20	17:35	04:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
77	2-Mar-2021	GULBARGA	66	HOSAHALLI-CJ_HALLI	HOSAHALLI_66	11:55	17:40	05:45	MAIN SUPPLY FAILURE
78	2-Mar-2021	GULBARGA	66	HV2	MYLAR_66	12:25	12:27	00:02	TRANSFORMER FAULT
79	2-Mar-2021	GULBARGA	66	HV2	MYLAR_66	15:10	16:14	01:04	TRANSFORMER FAULT
80	2-Mar-2021	GULBARGA	66	HV1	HAMPASAGAR_66	07:20	07:23	00:03	TRANSFORMER FAULT
81	2-Mar-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	18:03 (1.03.2021)	13:15 (2.03.2021)	18:32HRS	LINE CHARGED
82	2-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
83	2-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
84	2-Mar-2021	HASSAN	66	HV3	BALEHONNUR_66	20:18(28.02.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
85	2-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:57 (1.03.2021)			LINE OPEN, LINE CLEAR AVAILED
86	2-Mar-2021	HASSAN	110	HV2	ESSUR_110	10:23 (1.03.2021)			LINE OPEN, LINE CLEAR AVAILED
87	2-Mar-2021	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:24	19:10	06:46	LINE FAULT
88	2-Mar-2021	HASSAN	220	TALAGU-STRP1	gerusoppa_gen	15:26	16:05	00:39	LINE CLEAR AVAILED
89	2-Mar-2021	HASSAN	220	TALAGU-STRP1	gerusoppa_gen	16:52	18:11	01:19	LINE CLEAR AVAILED
90	2-Mar-2021	HASSAN	220	TALAGU-STRP2	gerusoppa_gen	12:23	19:14	06:51	LINE FAULT
91	2-Mar-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	16:51	18:11	01:20	LINE CLEAR AVAILED
92	2-Mar-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:07	18:04	04:57	LINE FAULT
93	2-Mar-2021	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	13:07	18:05	04:58	LINE FAULT
94	2-Mar-2021	HASSAN	110	HV1	BAIKAMPADI_110	15:28	15:49	00:21	LINE CLEAR AVAILED
95	2-Mar-2021	HASSAN	110	HV2	BAIKAMPADI_110	12:56	15:26	02:30	LINE CLEAR AVAILED
96	2-Mar-2021	HASSAN	110	HV1	GANDSI_110	13:13	14:21	01:08	LINE CLEAR AVAILED
97	2-Mar-2021	HASSAN	110	HV2	GANDSI_110	12:18	13:40	01:22	LINE CLEAR AVAILED
98	2-Mar-2021	HASSAN	110	HV1	KONDENALU_110	12:13	12:24	00:11	LINE CLEAR AVAILED
99	2-Mar-2021	HASSAN	110	HV2	KONDENALU_110	11:01	12:13	01:12	LINE CLEAR AVAILED
100	2-Mar-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:06	13:20	03:14	LINE CLEAR AVAILED
101	2-Mar-2021	HASSAN	110	MSEZ-GSS31	MSEZ_220	10:38	17:19	06:41	NFBC ISSUED
102	2-Mar-2021	HASSAN	110	HV1	BRAHMAVARA_110	09:41	14:03	04:22	LINE CLEAR AVAILED
103	2-Mar-2021	HASSAN	110	HV2	BRAHMAVARA_110	09:41	13:34	03:53	LINE CLEAR AVAILED
104	2-Mar-2021	HASSAN	66	HASSN22-BELUR	HASSAN_220	07:59	08:38	00:39	LINE FAULT
105	2-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:47	17:28	06:41	NFBC ISSUED
106	2-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:47	17:39	06:52	NFBC ISSUED
107	2-Mar-2021	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA_66	10:56	11:44	00:48	LINE CLEAR AVAILED
108	2-Mar-2021	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	10:56	11:44	00:48	LINE CLEAR AVAILED
109	2-Mar-2021	HASSAN	66	HV1	HALLIMYSORE_66	15:26	16:01	00:35	LINE CLEAR AVAILED
110	2-Mar-2021	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	13:01	13:08	00:07	HAND TRIPPED
111	2-Mar-2021	HASSAN	66	HV1	MAGGE_66	11:06	11:50	00:44	LINE CLEAR AVAILED
112	2-Mar-2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	14:30	14:40	00:10	HAND TRIPPED
113	2-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:42	17:38	06:56	LINE CLEAR AVAILED
114	2-Mar-2021	MYSURU	66	DR PETE-KUNTHUR	SANTHEBACHALLI_66 MUGUR_66 JANNUR_66 THAYURU_66 TNARASIPURA_66	6:20	6:30	0:10	LINE FAULT
115	2-Mar-2021	MYSURU	66	HV1	DEVANOORMYS_66	10:29 (02/03/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
116	2-Mar-2021	MYSURU	66	ELWALA-HOOTAGALLI	ELAVALA_66 GAVADAGERE_66	10:52	11:51	0:59	HAND TRIPPED
117	2-Mar-2021	MYSURU	66	ELWALA-HUNSUR	ELAVALA_66 GAVADAGERE_66	10:52	11:52	1:00	LINE CLEAR AVAILED
118	2-Mar-2021	MYSURU	66	HV1	GUDDENAHALLI_66	16:34	16:40	0:06	HAND TRIPPED
119	2-Mar-2021	MYSURU	66	JAIPURA-KADAKOLA	JAIPUR_66	14:05	14:15	0:10	LINE FAULT
120	2-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	6:53	20:06	13:13	LINE CLEAR AVAILED
121	2-Mar-2021	MYSURU	66	HV1	K_HONNALGERE_66	10:06	10:15	0:09	MAIN SUPPLY FAILURE
122	2-Mar-2021	MYSURU	66	HV2	K_HONNALGERE_66	10:06	10:15	0:09	MAIN SUPPLY FAILURE
123	2-Mar-2021	MYSURU	66	KR PETE 220-SB HALLI	SANTHEMARAHALLI_66 HARIYALDAMMATEMPLE_66	7:32	7:43	0:11	LINE FAULT
124	2-Mar-2021	MYSURU	66	HV1	NANJANGUDU_66	11:30	14:27	2:57	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
125	2-Mar-2021	MYSURU	66	HV2	PONNAMPET_66	11:09	11:13	0:03	TRANSFORMER FAULT
126	2-Mar-2021	MYSURU	66	HV2	PONNAMPET_66	12:26	13:55	1:28	LINE CLEAR AVAILED
127	2-Mar-2021	MYSURU	66	HV2	SANTHEBACHALLI_66	10:35	10:53	0:18	LINE CLEAR AVAILED
128	2-Mar-2021	MYSURU	66	VAJMANGALA-DEVNOOR MYSORE	DEVANOORMYS_66 RAJEEVNAGARA_66	6:24	6:34	0:10	LINE FAULT
129	2-Mar-2021	MYSURU	66	VAJMANGALA-MEGALAPURA	NO STATION EFFECTED	6:30	6:56	0:25	LINE FAULT
130	2-Mar-2021	MYSURU	66	HV1	ELAVALA_66	22:26 (27/02/2021)	12:10 (02/03/2021)	61:44 HRS	TRANSFORMER CHARGED
131	2-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
132	2-Mar-2021	TUMKUR	110	TR-2	KADEHALLI_110	13:09	13:42	0:33	LINE CLEAR AVAILED
133	2-Mar-2021	TUMKUR	110	TR-2	SAMPIGE_110	15:03	15:59	0:56	LINE CLEAR AVAILED
134	2-Mar-2021	TUMKUR	110	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	6:09	6:27	0:17	LINE FAULT
135	2-Mar-2021	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR(BG NAGAR)	YEDIYUR_66	15:01	15:13	0:11	LINE FAULT
136	2-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	9:03	9:23	0:19	LINE FAULT
137	2-Mar-2021	TUMKUR	66	BELADADARA-KORATAGERE	BELADARA_66	15:05	15:17	0:11	LINE FAULT
138	2-Mar-2021	TUMKUR	66	TR-1	BELLAVI_66	15:41	15:50	0:09	LINE CLEAR AVAILED
139	2-Mar-2021	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	21:02	21:17	0:15	TRANSFORMER FAULT
140	2-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:06	7:17	0:10	LINE FAULT
141	2-Mar-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:03	9:10	0:06	HAND TRIPPED
142	2-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:16	12:28	0:11	LINE FAULT
143	2-Mar-2021	TUMKUR	66	TR-2	GUTTUR_66	11:15	14:16	3:00	LINE CLEAR AVAILED
144	2-Mar-2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHPURA_66	5:19	9:48	4:29	LINE CLEAR AVAILED
145	2-Mar-2021	TUMKUR	66	TR-1	KORA_66	15:29	15:40	0:11	TRANSFORMER FAULT
146	2-Mar-2021	TUMKUR	66	TR-2	LINGADAHALLI_TM2_66	16:32	16:43	0:11	LINE CLEAR AVAILED
147	2-Mar-2021	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	12:16	13:50	1:33	LINE FAULT
148	2-Mar-2021	TUMKUR	66	TR-2	URDIGERE_66	5:36	6:10	0:34	TRANSFORMER FAULT
149	2-Mar-2021	TUMKUR	66	TR-2	URDIGERE_66	14:10	14:15	0:05	LINE CLEAR AVAILED
150	3-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
151	3-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
152	3-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
153	3-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
154	3-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
155	3-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
156	3-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
157	3-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
158	3-Mar-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
159	3-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
160	3-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVAILED
161	3-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVAILED
162	3-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVAILED
163	3-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
164	3-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
165	3-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
166	3-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
167	3-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
168	3-Mar-2021	BAGALKOT	220	GADAG- HARTI2	STATION NOT AFFECTED GADAG_220	17:16 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
169	3-Mar-2021	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT_110	4:32 (26.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
170	3-Mar-2021	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:42 (28.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
171	3-Mar-2021	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	16:17 (01.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
172	3-Mar-2021	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	17:26 (02.03.2021)	15:24 (03.03.2021)	21:58HRS	LINE CHARGED
173	3-Mar-2021	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	17:44 (02.03.2021)			LINE OPEN, LINE FAULT
174	3-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	09:03	18:55	9:52	NFBC ISSUED
175	3-Mar-2021	BAGALKOT	220	BELGAUM-KANABARGI1	STATION NOT AFFECTED BELGAUM_220	13:12	15:36	2:24	NFBC ISSUED
176	3-Mar-2021	BAGALKOT	110	BAGALKOT-KERUR	STATION NOT AFFECTED BAGALKOT_220	14:02	15:37	1:35	LINE CLEAR AVOIDED
177	3-Mar-2021	BAGALKOT	110	BETAGERI-GADAG	BETAGERI_110	16:58 (03.03.2021)			LINE OPEN, LINE FAULT
178	3-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	04:29	04:45	0:16	HAND TRIPPED
179	3-Mar-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	04:30	04:46	0:16	HAND TRIPPED
180	3-Mar-2021	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	04:29	4:45	0:16	HAND TRIPPED
181	3-Mar-2021	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	04:30	4:45	0:15	HAND TRIPPED
182	3-Mar-2021	BAGALKOT	110	BAGEWADI-UKKALI	UKKALI_110	04:29	4:45	0:16	HAND TRIPPED
183	3-Mar-2021	BAGALKOT	110	BAGEWADI-CHIMMALAGI	CHIMMALAGI LIS_110	04:29	4:45	0:16	HAND TRIPPED
184	3-Mar-2021	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTED CHIKKODI_220	12:27	20:01	7:34	LINE CLEAR AVOIDED
185	3-Mar-2021	BAGALKOT	110	110/11KV,HV1	DAVALESHWAR_110	10:37	11:55	1:18	LINE CLEAR AVOIDED
186	3-Mar-2021	BAGALKOT	220	220/110KV,HV2,LV2	GADAG_220	16:21	16:34	0:13	TRANSFORMER FAULT
187	3-Mar-2021	BAGALKOT	220	220/110KV,HV3,LV3	GADAG_220	16:21	16:45	0:24	TRANSFORMER FAULT
188	3-Mar-2021	BAGALKOT	220	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	16:21	19:50	3:29	LINE FAULT
189	3-Mar-2021	BAGALKOT	220	220/110KV,HV1,LV1	GADAG_220	16:52	18:42	1:50	LINE CLEAR AVOIDED
190	3-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
191	3-Mar-2021	BAGALKOT	110	BADAMI-HIREHAL	STATION NOT AFFECTED HIREHAL_110	15:50	16:35	0:45	LINE CLEAR AVOIDED
192	3-Mar-2021	BAGALKOT	110	110/33KV,HV1	HUNAGUND_110,AMINAGAD_33,KARA DI_33,MYTRA SOLAR_33	17:25	17:32	0:07	TRANSFORMER FAULT
193	3-Mar-2021	BAGALKOT	110	JAMAKHANDI- MAHALINGAPUR(NAVALAGI)	STATION NOT AFFECTED JAMAKHANDI_110	11:11	11:59	0:48	LINE CLEAR AVOIDED
194	3-Mar-2021	BAGALKOT	110	BAGALKOT-KERUR	STATION NOT AFFECTED KERUR_110	14:10	15:38	1:28	LINE CLEAR AVOIDED
195	3-Mar-2021	BAGALKOT	110	BADAMI-KERUR	BADAMI_110	14:10	15:39	1:29	LINE CLEAR AVOIDED
196	3-Mar-2021	BAGALKOT	110	KONNUR-KERUR	KERUR_110	15:16	15:39	0:23	HAND TRIPPED
197	3-Mar-2021	BAGALKOT	110	110/11KV,HV2	KULIGERE CROSS_110	11:55	12:24	0:29	LINE CLEAR AVOIDED
198	3-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ZALKI_110	15:02	15:47	0:45	LINE CLEAR AVOIDED
199	3-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TIKOTA_110	12:35	14:40	2:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
200	3-Mar-2021	BAGALKOT	110	RON-HIREHAL	HRIEHAL_110	15:25	15:30	0:05	HAND TRIPPED
201	3-Mar-2021	BAGALKOT	110	RON-GAMESHA	RON_110, GAMESHA IPP_110	14:00	15:40	1:40	LINE CLEAR AVAILED
202	3-Mar-2021	BAGALKOT	110	RON-GAMESHA	RON_110, GAMESHA IPP_110	15:41	17:13	1:32	LINE CLEAR AVAILED
203	3-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110,	15:25	15:30	0:05	HAND TRIPPED
204	3-Mar-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110,	15:25	15:51	0:26	HAND TRIPPED
205	3-Mar-2021	BAGALKOT	110	NAREGAL-BETAGERI	STATION NOT AFFECTED BETAGERI_110	16:40	16:55	0:15	HAND TRIPPED
206	3-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MURDESHWER_110	10:01	12:23	2:22	LINE CLEAR AVAILED
207	3-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	12:20	12:41	0:21	LINE CLEAR AVAILED
208	3-Mar-2021	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	10:59	15:43	4:44	LINE CLEAR AVAILED
209	3-Mar-2021	BAGALKOT	110	MUDDEBIHAL-BALAJISUGARS	MUDDEBIHAL_110, BALAJISUGARS_110	11:14	15:40	4:26	LINE CLEAR AVAILED
210	3-Mar-2021	BAGALKOT	110	MUDDEBIHAL-KN SOLAR	MUDDEBIHAL_110, KN SOLAR_110	11:10	15:40	4:30	LINE CLEAR AVAILED
211	3-Mar-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	10:10	20:07	9:57	NFBC ISSUED
212	3-Mar-2021	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	9:02	18:55	9:53	LINE CLEAR AVAILED
213	3-Mar-2021	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED NARENDRA_220	20:58	22:24	1:26	LINE CLEAR AVAILED
214	3-Mar-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	12:40	18:25	5:45	LINE CLEAR AVAILED
215	3-Mar-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	12:40	18:25	5:45	LINE CLEAR AVAILED
216	3-Mar-2021	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	10:10	20:06	9:56	LINE CLEAR AVAILED
217	3-Mar-2021	BAGALKOT	110	MAHALINGAPUR-GSML	STATION NOT AFFECTED MAHALINGAPUR_220 GSML_110	6:45	8:18	1:33	LINE FAULT
218	3-Mar-2021	BENGALURU	66	HOSKOTE 220 - KIADB HARD WARE PARK 1	HOSKOTE 220	13:30	14:34	01:04	LINE CLEAR AVAILED
219	3-Mar-2021	BENGALURU	66	HOSKOTE 220 - KIADB HARD WARE PARK 1	HOSKOTE 220	13:30	15:12	01:42	LINE CLEAR AVAILED
220	3-Mar-2021	BENGALURU	66	HV1	SM MANGALA	12:20	13:25	01:04	LINE CLEAR AVAILED
221	3-Mar-2021	BENGALURU	66	HV1	MUDIYANUR	12:28	12:34	00:06	TRANSFORMER FAULT
222	3-Mar-2021	BENGALURU	66	HV1	MUDIYANUR	12:34	12:40	00:05	TRANSFORMER FAULT
223	3-Mar-2021	BENGALURU	66	HV2	DOMMASANDRA	11:51	11:56	00:04	TRANSFORMER FAULT
224	3-Mar-2021	BENGALURU	66	HV1	HUKUNDA	12:23	12:34	00:11	TRANSFORMER FAULT
225	3-Mar-2021	BENGALURU	66	HV1	GANJIGUNTE	12:20	12:30	00:10	LINE CLEAR AVAILED
226	3-Mar-2021	BENGALURU	66	HV2	GANJIGUNTE	16:25	16:30	00:05	LINE CLEAR AVAILED
227	3-Mar-2021	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	13:30	15:37	02:07	LINE CLEAR AVAILED
228	3-Mar-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	13:30	15:52	02:22	LINE CLEAR AVAILED
229	3-Mar-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	15:39	15:43	00:04	LINE CLEAR AVAILED
230	3-Mar-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	13:28	17:39	04:11	LINE FAULT
231	3-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	10:03	18:22	08:18	LINE CLEAR AVAILED
232	3-Mar-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	10:03	18:22	08:19	LINE CLEAR AVAILED
233	3-Mar-2021	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	10:24	11:06	00:41	LOAD CURTAILMENT
234	3-Mar-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:41	17:48	00:07	LOAD CHANGE OVER
235	3-Mar-2021	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	13:25	13:35	00:10	LOAD CHANGE OVER
236	3-Mar-2021	BENGALURU	66	SRINIVASPURA - DALASNUR	YELDUR	12:40	12:50	00:09	LINE FAULT
237	3-Mar-2021	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	17:10	17:18	00:08	LINE FAULT
238	3-Mar-2021	BENGALURU	66	BTM 4 TH PHASE - KHODAYS 220	BTM 4TH PHASE	16:02	16:22	00:20	MAIN SUPPLY FAILURE
239	3-Mar-2021	BENGALURU	66	BTM 4 TH PHASE - KHODAYS 220	BTM 4TH PHASE	17:30	17:37	00:07	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
240	3-Mar-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	16:12	16:44	00:32	MAIN SUPPLY FAILURE
241	3-Mar-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	18:10	18:18	00:08	LOAD CHANGE OVER
242	3-Mar-2021	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	16:02	16:17	00:15	MAIN SUPPLY FAILURE
243	3-Mar-2021	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA	ISRO LAYOUT	16:35	16:40	00:05	LOAD CHANGE OVER
244	3-Mar-2021	BENGALURU	66	ISRO LAYOUT - SARAKKI	ISRO LAYOUT	17:58	18:02	00:04	LOAD CHANGE OVER
245	3-Mar-2021	BENGALURU	66	HV2	ISRO LAYOUT	13:30	13:35	00:05	LINE CLEAR AVAILED
246	3-Mar-2021	BENGALURU	66	HV1	ISRO LAYOUT	10:55	11:00	00:05	LINE CLEAR AVAILED
247	3-Mar-2021	BENGALURU	66	HV1	ISRO LAYOUT	13:25	13:30	00:05	LINE CLEAR AVAILED
248	3-Mar-2021	BENGALURU	66	HV2	ISRO LAYOUT	10:55	11:00	00:05	LINE CLEAR AVAILED
249	3-Mar-2021	BENGALURU	66	HV2	ISRO LAYOUT	13:25	13:30	00:05	LINE CLEAR AVAILED
250	3-Mar-2021	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	16:02	16:19	00:17	MAIN SUPPLY FAILURE
251	3-Mar-2021	BENGALURU	220	HV1	KHODAYS 220	16:02	16:19	00:17	MAIN SUPPLY FAILURE
252	3-Mar-2021	BENGALURU	220	HV2	KHODAYS 220	16:02	16:19	00:17	MAIN SUPPLY FAILURE
253	3-Mar-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	16:02	16:22	00:20	MAIN SUPPLY FAILURE
254	3-Mar-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	16:38	16:48	00:10	LOAD CHANGE OVER
255	3-Mar-2021	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	16:02	16:20	00:18	MAIN SUPPLY FAILURE
256	3-Mar-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	16:02	16:21	00:19	MAIN SUPPLY FAILURE
257	3-Mar-2021	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	17:57	18:00	00:03	LOAD CHANGE OVER
258	3-Mar-2021	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDUMADU	15:35	15:54	00:19	LINE CLEAR AVAILED
259	3-Mar-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI	15:40	16:00	00:20	LINE CLEAR AVAILED
260	3-Mar-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	15:40	16:00	00:20	LINE CLEAR AVAILED
261	3-Mar-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	15:41	15:55	00:14	LINE CLEAR AVAILED
262	3-Mar-2021	BENGALURU	220	SOMANAHALLI 220 - KHODAYS 220	KHODAYS 220, SUBRAMANYAPURA 220	16:02	16:10	00:08	LINE FAULT
263	3-Mar-2021	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	16:12	16:48	00:36	LINE FAULT
264	3-Mar-2021	BENGALURU	220	HV1	SUBRAMANYAPURA 220	16:02	16:10	00:08	MAIN SUPPLY FAILURE
265	3-Mar-2021	BENGALURU	220	HV2	SUBRAMANYAPURA 220	16:02	16:10	00:08	MAIN SUPPLY FAILURE
266	3-Mar-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	16:02	16:10	00:08	MAIN SUPPLY FAILURE
267	3-Mar-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	16:02	16:10	00:08	MAIN SUPPLY FAILURE
268	3-Mar-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 1	SUBRAMANYAPURA 66	16:02	16:10	00:08	MAIN SUPPLY FAILURE
269	3-Mar-2021	BENGALURU	66	V R DODDI - T K HALLI 220	V R DODDI	17:43	17:52	00:09	LOAD CHANGE OVER
270	3-Mar-2021	BENGALURU	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YARANDANAHALLI 220	16:12	16:48	00:36	MAIN SUPPLY FAILURE
271	3-Mar-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	16:12	17:10	00:58	MAIN SUPPLY FAILURE
272	3-Mar-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	16:12	17:00	00:48	MAIN SUPPLY FAILURE
273	3-Mar-2021	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	16:12	17:00	00:48	MAIN SUPPLY FAILURE
274	3-Mar-2021	BENGALURU	220	HV2	YARANDANAHALLI 220	16:12	16:58	00:46	MAIN SUPPLY FAILURE
275	3-Mar-2021	BENGALURU	220	HV3	YARANDANAHALLI 220	16:12	16:58	00:46	MAIN SUPPLY FAILURE
276	3-Mar-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	16:12	16:33	00:21	MAIN SUPPLY FAILURE
277	3-Mar-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	16:12	16:33	00:21	MAIN SUPPLY FAILURE
278	3-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
279	3-Mar-2021	GULBARGA	220	KUSTAGI-LINGAPUR	KUSTAGI_220	13:57	14:57	01:00	LINE FAULT
280	3-Mar-2021	GULBARGA	220	HV1	KUSTAGI_220	13:57	15:33	01:36	TRANSFORMER FAULT
281	3-Mar-2021	GULBARGA	220	HV2	KUSTAGI_220	13:57	15:34	01:37	TRANSFORMER FAULT
282	3-Mar-2021	GULBARGA	110	GULBARGA SOUTH-GULBARGA UNIVERSITY	GULBARGA UNIVERSITY_110	16:10(02.03.2021)	8:25(03.03.2021)	16:15hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
283	3-Mar-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	16:00			LINE OPEN, LINE CLEAR AVAILED
284	3-Mar-2021	GULBARGA	110	HUMNABAD-HUMNABAD1	HUMNABAD_110	12:10	12:22	00:12	LINE FAULT
285	3-Mar-2021	GULBARGA	110	ITTAGI-KOTTUR	KOTTUR_110	11:50	13:45	01:55	LINE CLEAR AVAILED
286	3-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	06:30	06:35	00:05	LINE FAULT
287	3-Mar-2021	GULBARGA	110	HV1	NIRNA_110	15:49	15:55	00:06	TRANSFORMER FAULT
288	3-Mar-2021	GULBARGA	110	HV2,HV1	MYLAR_110	11:01	18:01	07:00	LINE CLEAR AVAILED
289	3-Mar-2021	GULBARGA	110	MYLAR-I/C LINE(GUTLA)	MYLAR_110	11:05	11:30	00:25	MAIN SUPPLY FAILURE
290	3-Mar-2021	GULBARGA	110	HV1	LINGASUGUR_220	10:05	15:10	01:25	LINE CLEAR AVAILED
291	3-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	17:50(3.3.2021)			LINE OPEN, LINE CLEAR AVAILED
292	3-Mar-2021	GULBARGA	66	KOTTUR-KUDLIGI	UJJANI_66	18:22	18:26	00:04	LINE CLEAR AVAILED
293	3-Mar-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
294	3-Mar-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
295	3-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:57 (1.03.2021)			LINE OPEN, LINE CLEAR AVAILED
296	3-Mar-2021	HASSAN	110	HV2	ESSUR_110	10:23 (1.03.2021)	16:02 (3.03.2021)	53:39hrs	TRANSFORMER CHARGED
297	3-Mar-2021	HASSAN	66	HV3	BALEHONNUR_66	20:18(28.02.2021)	16:03 (3.03.2021)	67:45hrs	TRANSFORMER CHARGED
298	3-Mar-2021	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	13:15	15:53	02:38	LINE FAULT
299	3-Mar-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	01:58	15:32	13:34	LINE FAULT
300	3-Mar-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	13:28	14:20	00:52	HAND TRIPPED
301	3-Mar-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	14:30	17:15	02:45	LINE FAULT
302	3-Mar-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	14:30	17:15	02:45	LINE FAULT
303	3-Mar-2021	HASSAN	110	HV1	ARASIKERE_110	12:41	13:22	00:41	LINE CLEAR AVAILED
304	3-Mar-2021	HASSAN	110	HV1	ARASIKERE_220	14:57	17:05	02:08	LINE CLEAR AVAILED
305	3-Mar-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	00:26	00:43	00:17	MAIN SUPPLY FAILURE
306	3-Mar-2021	HASSAN	110	HV3	BHADARAVATHY_110	16:58	17:01	00:03	HAND TRIPPED
307	3-Mar-2021	HASSAN	110	HV1	ESSUR_110	14:22	14:53	00:31	LINE CLEAR AVAILED
308	3-Mar-2021	HASSAN	110	HV1	GANDASI_110	10:58	13:36	02:38	LINE CLEAR AVAILED
309	3-Mar-2021	HASSAN	110	HV1	KONAJE_110	07:46	07:50	00:04	HAND TRIPPED
310	3-Mar-2021	HASSAN	110	HV1	KONAJE_110	17:20	17:23	00:03	HAND TRIPPED
311	3-Mar-2021	HASSAN	110	HV2	KONAJE_110	07:46	07:50	00:04	HAND TRIPPED
312	3-Mar-2021	HASSAN	110	HV2	KONAJE_110	17:20	17:23	00:03	HAND TRIPPED
313	3-Mar-2021	HASSAN	110	HV3	KONAJE_110	07:46	07:50	00:04	HAND TRIPPED
314	3-Mar-2021	HASSAN	110	HV3	KONAJE_110	17:20	17:23	00:03	HAND TRIPPED
315	3-Mar-2021	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:05	17:14	07:09	LINE CLEAR AVAILED
316	3-Mar-2021	HASSAN	110	HV1	MANIPAL_110	10:44	13:09	02:25	LINE CLEAR AVAILED
317	3-Mar-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	07:50	17:17	09:27	NFBC ISSUED
318	3-Mar-2021	HASSAN	110	HV1	TALAGUPPA_400	15:57	16:54	00:57	TRANSFORMER FAULT
319	3-Mar-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	17:55	18:12	00:17	LINE FAULT
320	3-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:41	17:44	07:03	LINE CLEAR AVAILED
321	3-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:38	17:50	07:12	LINE CLEAR AVAILED
322	3-Mar-2021	HASSAN	66	HV4	BALEHONNUR_66	15:36	15:59	00:23	HAND TRIPPED
323	3-Mar-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	13:43	13:47	00:04	HAND TRIPPED
324	3-Mar-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	15:57	17:08	01:11	LINE CLEAR AVAILED
325	3-Mar-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	16:50	18:36	01:46	LINE CLEAR AVAILED
326	3-Mar-2021	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA-66	11:42	14:03	02:21	LINE CLEAR AVAILED
327	3-Mar-2021	HASSAN	66	DUDDA-CKNDGL	DUDDA-66	11:42	13:52	02:10	LINE CLEAR AVAILED
328	3-Mar-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:37	15:11	04:34	LINE CLEAR AVAILED
329	3-Mar-2021	HASSAN	66	HV1	MAGGE_66	10:44	15:22	04:38	NFBC ISSUED
330	3-Mar-2021	HASSAN	66	HV2	MAGGE_66	10:44	15:22	04:38	NFBC ISSUED
331	3-Mar-2021	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	17:55	18:12	00:17	LINE FAULT
332	3-Mar-2021	HASSAN	66	SAKALE-HASSAN	SAKALESHUPURA_66	10:37	15:11	04:34	NFBC ISSUED
333	3-Mar-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	13:30	13:55	00:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
334	3-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:37	18:16	07:39	LINE CLEAR AVAILED
335	3-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:33	17:47	07:14	LINE CLEAR AVAILED
336	3-Mar-2021	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATION EFFECTED	10:13 (03/03/2021)			LINE OPEN, LINE CLEAR AVAILED
337	3-Mar-2021	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	10:15	16:48	6:32	NFBC ISSUED
338	3-Mar-2021	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66	10:46	16:31	5:45	NFBC ISSUED
339	3-Mar-2021	MYSURU	66	KALAMANDIR-BOGADHI	BOGADHI_66	10:12	16:40	6:27	NFBC ISSUED
340	3-Mar-2021	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATION EFFECTED	13:07	16:08	3:00	LINE CLEAR AVAILED
341	3-Mar-2021	MYSURU	220	HOOTAGALLI-BASTIPURA1	NO STATION EFFECTED	14:44	15:56	1:12	LINE CLEAR AVAILED
342	3-Mar-2021	MYSURU	220	HOOTAGALLI-BASTIPURA2	NO STATION EFFECTED	12:22	14:32	2:10	LINE CLEAR AVAILED
343	3-Mar-2021	MYSURU	66	HV2	KADAKOLA_220	8:51	9:07	0:15	TRANSFORMER FAULT
344	3-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	7:06	20:06	13:00	LINE CLEAR AVAILED
345	3-Mar-2021	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATION EFFECTED	11:35	11:44	0:09	LINE FAULT
346	3-Mar-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	3:38	3:46	0:07	LINE FAULT
347	3-Mar-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	13:23	13:35	0:12	LINE FAULT
348	3-Mar-2021	MYSURU	66	PERIYAPATNA-HUNSUR	NO STATION EFFECTED	12:23	13:21	0:57	LINE CLEAR AVAILED
349	3-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	18:10 (03/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
350	3-Mar-2021	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	18:46	18:50	0:03	LINE FAULT
351	3-Mar-2021	MYSURU	66	SINDUVALLIPURA-BEGUR	SINDHUVALLI_66	10:02	17:55	7:52	LINE CLEAR AVAILED
352	3-Mar-2021	MYSURU	66	SINDUVALLIPURA-NANJANGUDU	SINDHUVALLI_66	10:02	17:55	7:52	LINE CLEAR AVAILED
353	3-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	21:24	21:30	0:05	LINE FAULT
354	3-Mar-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	14:25	14:30	0:05	LINE FAULT
355	3-Mar-2021	MYSURU	66	VAJMANGALA-BANNUR	NO STATION EFFECTED	14:09	15:35	1:26	NFBC ISSUED
356	3-Mar-2021	MYSURU	66	YELANDUR-CR NAGARA	NO STATION EFFECTED	12:10	13:23	1:13	LINE CLEAR AVAILED
357	3-Mar-2021	MYSURU	66	HV1	YELANDUR_66	12:10	13:18	1:08	LINE CLEAR AVAILED
358	3-Mar-2021	MYSURU	66	HV2	YELANDUR_66	10:43	12:18	1:35	LINE CLEAR AVAILED
359	3-Mar-2021	MYSURU	66	HV1	DEVANOORMYS_66	10:29 (02/03/2021)	17:32 (03/03/2021)	31:02 HRS	TRANSFORMER CHARGED
360	3-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
361	3-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	10:57	15:37	4:40	LINE CLEAR AVAILED
362	3-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	14:32	18:11	3:38	LINE FAULT
363	3-Mar-2021	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	14:32	16:07	1:35	LINE CLEAR AVAILED
364	3-Mar-2021	TUMKUR	220	HONNALLI 220kv-DAVANAGERE SRS	HONNALLI_220	14:39	16:40	2:00	MAIN SUPPLY FAILURE
365	3-Mar-2021	TUMKUR	220	HONNALLI 220kv- SHIMOGA 220kv	HONNALLI_220	14:39	16:40	2:00	MAIN SUPPLY FAILURE
366	3-Mar-2021	TUMKUR	110	TR-1	BANDIHALLI_110	8:11	9:07	0:55	LINE CLEAR AVAILED
367	3-Mar-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:25	13:03	0:37	LINE CLEAR AVAILED
368	3-Mar-2021	TUMKUR	110	TR-2	HULIYAR_110	14:00	16:36	2:35	LINE CLEAR AVAILED
369	3-Mar-2021	TUMKUR	110	TR-1	KBCROSS_220	12:14	12:27	0:13	TRANSFORMER FAULT
370	3-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	16:44	17:07	0:22	HAND TRIPPED
371	3-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	17:07	17:09	0:01	HAND TRIPPED
372	3-Mar-2021	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	17:07	17:09	0:01	HAND TRIPPED
373	3-Mar-2021	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	17:07	17:09	0:01	HAND TRIPPED
374	3-Mar-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	17:07	17:08	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
375	3-Mar-2021	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALI_66, HONNUDIKE_66, HIREHALLY_66	16:44	17:08	0:23	HAND TRIPPED
376	3-Mar-2021	TUMKUR	66	ANTHRASANAHALI 220KV- TUMKUR	TUMKUR_66	17:07	17:09	0:01	HAND TRIPPED
377	3-Mar-2021	TUMKUR	66	TR-2	BALENAHALI_66	13:56	14:08	0:12	TRANSFORMER FAULT
378	3-Mar-2021	TUMKUR	66	BELADADARA-KORATAGERE	BELADARA_66	12:04	12:09	0:04	LINE FAULT
379	3-Mar-2021	TUMKUR	66	BENNEHALI-ITTAGI	BENNEHALI_66	11:51	12:01	0:10	HAND TRIPPED
380	3-Mar-2021	TUMKUR	66	BENNEHALI-SUZLON	SUZLON1_IPP_66	12:01	13:50	1:48	LINE CLEAR AVAILED
381	3-Mar-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	12:35	12:50	0:15	MAIN SUPPLY FAILURE
382	3-Mar-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	14:32	14:37	0:04	MAIN SUPPLY FAILURE
383	3-Mar-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	14:32	14:36	0:03	MAIN SUPPLY FAILURE
384	3-Mar-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJIHALI_66	14:32	14:37	0:04	MAIN SUPPLY FAILURE
385	3-Mar-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:32	14:35	0:02	MAIN SUPPLY FAILURE
386	3-Mar-2021	TUMKUR	66	TR-2(LV SIDE)	DAVANGERE_SRS_220	14:32	14:34	0:01	MAIN SUPPLY FAILURE
387	3-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:32	14:43	0:10	MAIN SUPPLY FAILURE
388	3-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:32	14:34	0:01	MAIN SUPPLY FAILURE
389	3-Mar-2021	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	13:38	13:52	0:13	HAND TRIPPED
390	3-Mar-2021	TUMKUR	66	TR-1	DYAVARANAHALLI_66	8:32	8:58	0:25	TRANSFORMER FAULT
391	3-Mar-2021	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	13:34	13:47	0:13	HAND TRIPPED
392	3-Mar-2021	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	DYAVARANAHALLI_66	13:39	16:57	3:18	LINE CLEAR AVAILED
393	3-Mar-2021	TUMKUR	66	TR-1	GOWRASAMUDRA_66	9:39	10:05	0:25	LINE CLEAR AVAILED
394	3-Mar-2021	TUMKUR	66	TR-2	HANAGAL_66	12:23	12:45	0:21	LINE CLEAR AVAILED
395	3-Mar-2021	TUMKUR	66	TR-2	HANAGAL_66	14:12	14:56	0:44	LINE CLEAR AVAILED
396	3-Mar-2021	TUMKUR	66	TR-3	HOLALKERE_66	15:18	16:22	1:04	LINE CLEAR AVAILED
397	3-Mar-2021	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	12:58	13:12	0:13	LINE FAULT
398	3-Mar-2021	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	16:38	16:42	0:03	LINE FAULT
399	3-Mar-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66, CHANNAGIRI_66, BASAVAPATNA_66	12:08	13:19	1:11	LINE CLEAR AVAILED
400	3-Mar-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66, CHANNAGIRI_66, BASAVAPATNA_66	17:24	17:36	0:12	LINE FAULT
401	3-Mar-2021	TUMKUR	66	TR-2	MALEBENNUR_66	12:41	15:46	3:05	LINE CLEAR AVAILED
402	3-Mar-2021	TUMKUR	66	TR-1	PAVAGADA_220	14:34	14:39	0:04	TRANSFORMER FAULT
403	3-Mar-2021	TUMKUR	66	TR-2	RAMPURA_66	11:11	11:15	0:03	TRANSFORMER FAULT
404	3-Mar-2021	TUMKUR	66	TR-2	RAMPURA_66	12:23	12:28	0:04	TRANSFORMER FAULT
405	3-Mar-2021	TUMKUR	66	TR-2	SASALUHALLA_66	10:00	10:35	0:35	LINE CLEAR AVAILED
406	3-Mar-2021	TUMKUR	66	TR-1	SASALUHALLA_66	11:58	12:38	0:40	LINE CLEAR AVAILED
407	3-Mar-2021	TUMKUR	66	TR-2	TAVAREKERE(H)_66	18:35	18:55	0:19	LINE CLEAR AVAILED
408	3-Mar-2021	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	4:13	6:32	2:18	LINE CLEAR AVAILED
409	3-Mar-2021	TUMKUR	66	THALLAK 220kv- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	18:29	18:45	0:15	LINE FAULT
410	4-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
411	4-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
412	4-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
413	4-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
414	4-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
415	4-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
416	4-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
417	4-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
418	4-Mar-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
419	4-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
420	4-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
421	4-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
422	4-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
423	4-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
424	4-Mar-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
425	4-Mar-2021	BAGALKOT	220	VAJRAMATTI MAHALINGAPUR2-	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
426	4-Mar-2021	BAGALKOT	220	VAJRAMATTI MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
427	4-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
428	4-Mar-2021	BAGALKOT	220	GADAG- HARTI2	STATION NOT AFFECTED GADAG_220	17:16 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
429	4-Mar-2021	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT_110	4:32 (26.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
430	4-Mar-2021	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:42 (28.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
431	4-Mar-2021	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	16:17 (01.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
432	4-Mar-2021	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	17:44 (02.03.2021)	13:33 (04.03.2021)	43:49HRS	LINE CHARGED
433	4-Mar-2021	BAGALKOT	110	BETAGERI-GADAG	BETAGERI_110	16:58 (03.03.2021)	17:42 (04.03.2021)	24:44hrs	LINE CHARGED
434	4-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
435	4-Mar-2021	BAGALKOT	110	110/11KV HV2	AMBEWADI_220	15:16	15:23	0:07	LINE CLEAR AVOIDED
436	4-Mar-2021	BAGALKOT	110	NAREGAL-BETAGERI	BETAGERI_110	09:55	17:42	7:47	LINE CLEAR AVOIDED
437	4-Mar-2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110	10:58	11:02	0:04	TRANSFORMER FAULT
438	4-Mar-2021	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	12:27	14:06	1:39	LINE CLEAR AVOIDED
439	4-Mar-2021	BAGALKOT	110	ITNAL-RAIBAG1&2	STATION NOT AFFECTED ITNAL_110	17:42	18:29	0:47	LINE CLEAR AVOIDED
440	4-Mar-2021	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110,HIPPARGI_33	11:08	16:15	5:07	LINE CLEAR AVOIDED
441	4-Mar-2021	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI_110,HIPPARGI_33	11:07	16:15	5:08	LINE CLEAR AVOIDED
442	4-Mar-2021	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	10:55	18:18	7:23	LINE CLEAR AVOIDED
443	4-Mar-2021	BAGALKOT	110	BPCL-SHIRAHATTI	STATION NOT AFFECTED SHIRATTI_110	17:15	18:01	0:46	LINE FAULT
444	4-Mar-2021	BAGALKOT	110	110/11KV HV2	SHIROL_110	22:01	22:12	0:11	TRANSFORMER FAULT
445	4-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATH I1	STATION NOT AFFECTED SIRSI_220	10:45	11:46	1:01	LINE CLEAR AVOIDED
446	4-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATH I2	SIRSI_220	10:45	11:47	1:02	LINE CLEAR AVOIDED
447	4-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	22:16 (04.03.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
448	4-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	22:16 (04.03.2021)			LOAD CURTAILMENT
449	4-Mar-2021	BAGALKOT	110	HUBLI-BIDNAL2	STATION NOT AFFECTED HUBLI_220	10:22	13:29	3:07	LINE FAULT
450	4-Mar-2021	BAGALKOT	110	110/11KV HV2	TIKOTA_110	14:25	14:31	0:06	TRANSFORMER FAULT
451	4-Mar-2021	BAGALKOT	110	110/11KV,HV1	BIJAPUR_110	13:09	14:26	1:17	LINE CLEAR AVOIDED
452	4-Mar-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	16:16	18:41	2:25	LINE CLEAR AVOIDED
453	4-Mar-2021	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	STATION NOT AFFECTED BAGALKOT_220	16:16	18:41	2:25	NFBC ISSUED
454	4-Mar-2021	BENGALURU	220	HOODY 400 - HAL 2	NO STATION AFFECTED	15:43	16:59	01:16	LINE FAULT
455	4-Mar-2021	BENGALURU	66	HV1	DODDABELAVANGALA	06:53	18:45	11:52	TRANSFORMER FAULT
456	4-Mar-2021	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI,BIJAHALLI	16:32	16:42	00:10	LINE FAULT
457	4-Mar-2021	BENGALURU	66	HV1	MITTEMARI 220	08:26	08:33	00:07	TRANSFORMER FAULT
458	4-Mar-2021	BENGALURU	66	HV1	MITTEMARI 220	09:04	09:11	00:07	TRANSFORMER FAULT
459	4-Mar-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	14:15	14:26	00:11	LINE CLEAR AVOIDED
460	4-Mar-2021	BENGALURU	66	HV1	S M MANGALA	13:15	14:15	01:00	LINE CLEAR AVOIDED
461	4-Mar-2021	BENGALURU	66	HV2	S M MANGALA	13:15	14:15	01:00	LINE CLEAR AVOIDED
462	4-Mar-2021	BENGALURU	66	HV1	HUKUNDA	06:59	07:05	00:06	TRANSFORMER FAULT
463	4-Mar-2021	BENGALURU	66	HV1	HUKUNDA	11:48	11:54	00:06	TRANSFORMER FAULT
464	4-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
465	4-Mar-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	16:00(3.3.2021)			LINE OPEN, LINE CLEAR AVOIDED
466	4-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	17:50(3.3.2021)			LINE OPEN, LINE CLEAR AVOIDED
467	4-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR1	NALWAR_110	10:30(4.3.2021)			LINE OPEN, LINE CLEAR AVOIDED
468	4-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	00:05	00:10	00:05	LINE FAULT
469	4-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	03:05	03:10	00:05	LINE FAULT
470	4-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	06:25	06:30	00:05	LINE FAULT
471	4-Mar-2021	GULBARGA	110	HV1	HANUMANAL_110	05:35	05:44	00:09	TRANSFORMER FAULT
472	4-Mar-2021	GULBARGA	110	HV1	RAJESHWAR_110	10:05	10:15	00:10	TRANSFORMER FAULT
473	4-Mar-2021	GULBARGA	110	GABUR-RAICHUR	GABBUR_110,DEODURGA_110	03:16	03:18	00:02	MAIN SUPPLY FAILURE
474	4-Mar-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	10:30	13:35	03:05	NFBC ISSUED
475	4-Mar-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRRAMNAGAR_110,MALLAPUR A_110	10:58	11:18	00:20	LINE FAULT
476	4-Mar-2021	GULBARGA	110	HANASI-KUDLIGI	HANASI_66	10:35	10:40	00:05	LINE CLEAR AVOIDED
477	4-Mar-2021	GULBARGA	110	HV1	HANASI_66	09:50	10:40	00:50	LINE CLEAR AVOIDED
478	4-Mar-2021	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	11:43	18:07	06:24	LINE CLEAR AVOIDED
479	4-Mar-2021	GULBARGA	110	LINGASUGUR-CHAYADEVI_IPP	CHAYADEVI_IPP	06:10	06:20	00:10	LINE FAULT
480	4-Mar-2021	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110,KHEL_IPP,LIVL_IPP	12:15	14:42	02:27	LINE CLEAR AVOIDED
481	4-Mar-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
482	4-Mar-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
483	4-Mar-2021	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:22	14:56	01:34	LINE CLEAR AVOIDED
484	4-Mar-2021	HASSAN	220	GOPALAP-HSN400	GOPALAPURA_220	06:30	15:15	08:45	LINE FAULT
485	4-Mar-2021	HASSAN	110	HV2	ESSUR_110	15:12	15:30	00:18	LINE CLEAR AVOIDED
486	4-Mar-2021	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	10:21	16:30	06:09	LINE CLEAR AVOIDED
487	4-Mar-2021	HASSAN	110	HV1	SORABA_110	13:42	17:47	04:05	LINE CLEAR AVOIDED
488	4-Mar-2021	HASSAN	110	HV2	SORABA_110	13:42	17:49	04:07	LINE CLEAR AVOIDED
489	4-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:51	19:17	08:26	LINE CLEAR AVOIDED
490	4-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:51	19:17	08:26	LINE CLEAR AVOIDED
491	4-Mar-2021	HASSAN	66	CHIKABO-SIDPR	CHIKKABOMMENAHALLI_66	10:18	16:31	06:13	LINE CLEAR AVOIDED
492	4-Mar-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:32	16:52	05:20	LINE FAULT
493	4-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:51	19:13	08:22	NFBC ISSUED
494	4-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:45	19:11	08:26	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
495	4-Mar-2021	MYSURU	66	HV1	BANNUR_66	14:25	15:20	0:55	LINE CLEAR AVAILED
496	4-Mar-2021	MYSURU	66	HV2	DUNDANAHALLI_66	11:10	12:10	0:59	LINE CLEAR AVAILED
497	4-Mar-2021	MYSURU	66	HV1	KIADBMANDYA_66	10:59	12:45	1:46	LINE CLEAR AVAILED
498	4-Mar-2021	MYSURU	66	KIKKERI-KR PETE	KIKKERI_66	14:54	15:33	0:39	LINE CLEAR AVAILED
499	4-Mar-2021	MYSURU	66	HV1	KOPPA_66	16:57	17:04	0:07	HAND TRIPPED
500	4-Mar-2021	MYSURU	66	HV2	KOPPA_66	16:57	17:05	0:07	HAND TRIPPED
501	4-Mar-2021	MYSURU	66	HV3	KUSHALANAGARA_66	11:10	14:09	2:59	LINE CLEAR AVAILED
502	4-Mar-2021	MYSURU	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	11:50	12:46	0:56	LINE CLEAR AVAILED
503	4-Mar-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	20:55	21:04	0:09	LINE FAULT
504	4-Mar-2021	MYSURU	66	HV2	SANTHEBACHALLI_66	9:08	12:50	3:41	LINE CLEAR AVAILED
505	4-Mar-2021	MYSURU	66	HV1	SFCSHIVA_66	10:15	12:42	2:27	LINE CLEAR AVAILED
506	4-Mar-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATION EFFECTED	8:04	20:44	12:40	LINE CLEAR AVAILED
507	4-Mar-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	15:35	15:40	0:05	LINE FAULT
508	4-Mar-2021	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATION EFFECTED	10:13 (03/03/2021)	8:07 (04/02/2021)	21:53 HRS	LINE CHARGED
509	4-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	18:10 (03/03/2021)	2:00 (04/02/2021)	7:49 HRS	TRANSFORMER CHARGED
510	4-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
511	4-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:53	11:59	0:05	MAIN SUPPLY FAILURE
512	4-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	11:53	11:59	0:06	MAIN SUPPLY FAILURE
513	4-Mar-2021	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:53	12:15	0:22	MAIN SUPPLY FAILURE
514	4-Mar-2021	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	13:47	13:56	0:09	MAIN SUPPLY FAILURE
515	4-Mar-2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	11:53	12:14	0:20	MAIN SUPPLY FAILURE
516	4-Mar-2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	13:47	13:54	0:06	MAIN SUPPLY FAILURE
517	4-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	10:56	11:32	0:36	LINE FAULT
518	4-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:56	11:32	0:36	LINE FAULT
519	4-Mar-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	10:56	13:43	2:47	LINE FAULT
520	4-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	11:41	12:00	0:18	LINE FAULT
521	4-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	11:41	12:00	0:19	LINE FAULT
522	4-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	12:18	13:38	1:19	LINE FAULT
523	4-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	12:18	13:38	1:19	LINE FAULT
524	4-Mar-2021	TUMKUR	110	TR-1	HUNSEGATTA_110	13:23	13:40	0:17	TRANSFORMER FAULT
525	4-Mar-2021	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	12:06	13:31	1:25	MAIN SUPPLY FAILURE
526	4-Mar-2021	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	14:50	14:53	0:03	MAIN SUPPLY FAILURE
527	4-Mar-2021	TUMKUR	66	TR-1	THOVINAKERE_66	15:01	18:05	3:04	LINE CLEAR AVAILED
528	4-Mar-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	8:00	8:16	0:16	TRANSFORMER FAULT
529	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:53	11:54	0:00	MAIN SUPPLY FAILURE
530	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:53	11:55	0:01	MAIN SUPPLY FAILURE
531	4-Mar-2021	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	13:47	14:07	0:19	TRANSFORMER FAULT
532	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:02	15:07	0:05	LINE FAULT
533	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:19	16:25	0:06	LINE FAULT
534	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:28	16:40	0:11	LINE FAULT
535	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:53	12:00	0:06	LINE FAULT
536	4-Mar-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:53	12:00	0:06	LINE FAULT
537	4-Mar-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	6:51	11:55	5:04	LINE CLEAR AVAILED
538	4-Mar-2021	TUMKUR	66	TR-1	HANAGAL_66	6:40	11:55	5:15	LINE CLEAR AVAILED
539	4-Mar-2021	TUMKUR	66	TR-2	HANAGAL_66	6:51	11:55	5:04	LINE CLEAR AVAILED
540	4-Mar-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:48	11:55	0:07	LINE FAULT
541	4-Mar-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:00	12:16	0:15	LINE FAULT
542	4-Mar-2021	TUMKUR	66	TR-1	MADHUGIRI_66	19:28	19:33	0:05	TRANSFORMER FAULT
543	4-Mar-2021	TUMKUR	66	TR-2	MATHOD_66	10:15	10:24	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
544	4-Mar-2021	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	IPP_SOLAR_66	6:42	12:31	5:49	LINE CLEAR AVAILED
545	4-Mar-2021	TUMKUR	66	TR-1	SASALUHALLA_66	11:04	11:29	0:25	LINE CLEAR AVAILED
546	4-Mar-2021	TUMKUR	66	TR-2	SIRA_66	12:05	15:10	3:05	LINE CLEAR AVAILED
547	5-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
548	5-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
549	5-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
550	5-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
551	5-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
552	5-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
553	5-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
554	5-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
555	5-Mar-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI 110	12:49 (18.01.2021)	11:05 (05.03.2021)	1102:66HRS	LINE CHARGED
556	5-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
557	5-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI 110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVAILED
558	5-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVAILED
559	5-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI 220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVAILED
560	5-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
561	5-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
562	5-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
563	5-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
564	5-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL 220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVAILED
565	5-Mar-2021	BAGALKOT	220	GADAG- HARTI2	STATION NOT AFFECTED GADAG 220	17:16 (25.02.2021)			LINE OPEN, LINE CLEAR AVAILED
566	5-Mar-2021	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT 110	4:32 (26.02.2021)			LINE OPEN, LINE CLEAR AVAILED
567	5-Mar-2021	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE 110	17:42 (28.02.2021)			LINE OPEN, LINE CLEAR AVAILED
568	5-Mar-2021	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA 110	16:17 (01.03.2021)	6:38 (05.03.2021)	86:21HRS	LINE CHARGED
569	5-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD 110	16:57 (03.03.2021)			LINE OPEN, LINE CLEAR AVAILED
570	5-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	22:16 (04.03.2021)			LOAD CURTAILMENT
571	5-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	22:16 (04.03.2021)			LOAD CURTAILMENT
572	5-Mar-2021	BAGALKOT	110	ANKOLA-KUUMTA2	STATION NOT AFFECTED ANKOLA 110	09:23	14:53	5:30	LINE FAULT
573	5-Mar-2021	BAGALKOT	110	110/11KV,HV1	ARGA 110	08:53	19:16	10:23	LINE CLEAR AVAILED
574	5-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI 220	07:52	18:29	10:37	LINE CLEAR AVAILED
575	5-Mar-2021	BAGALKOT	220	ATHANI -MAHALINGAPUR	STATION NOT AFFECTED ATHANI 220	12:51	18:37	5:46	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
576	5-Mar-2021	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED CHIKKODI_220	09:46	10:15	0:29	LINE CLEAR AVOIDED
577	5-Mar-2021	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,SHIRUR_33,KAMA TAGI_33,ACME SOLAR_33	13:58	14:05	0:07	TRANSFORMER FAULT
578	5-Mar-2021	BAGALKOT	110	110/33KV,HV2	HIDIKAL DAM_110,RUSTUMPUR LIS_33,BELGAUM W/S 1_33,BELGAUM W/S 2ND& 3RD_33,	10:22	18:39	8:17	LINE CLEAR AVOIDED
579	5-Mar-2021	BAGALKOT	110	HIDIKAL-RAIBAG	STATION NOT AFFECTED HIDIKAL_110	7:20 (23.02.2021)	21:22 (5.03.2021)	254:02HRS	LINE CHARGED
580	5-Mar-2021	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:23 (23.02.2021)	19:12 (05.03.2021)	247:49HRS	LINE CHARGED
581	5-Mar-2021	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	13:25 (25.02.2021)	9:47 (05.03.2021)	164:22HRS	LINE CHARGED
582	5-Mar-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	15:12 (23.02.2021)	9:45 (05.03.2021)	235:32HRS	LINE CHARGED
583	5-Mar-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:07 (05.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
584	5-Mar-2021	BAGALKOT	220	KUDUCHI-MAHALINGAPUR2	STATION NOT AFFECTED KUDUCHI_220	10:41	12:46	2:05	NFBC ISSUED
585	5-Mar-2021	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	STATION NOT AFFECTED MAHALINGAPUR_220	10:39	11:10	0:31	HAND TRIPPED
586	5-Mar-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	10:34	10:36	0:02	TRANSFORMER FAULT
587	5-Mar-2021	BAGALKOT	110	VIJAYA SUGAR-MUNDARGI	STATION NOT AFFECTED MUNDARGI_110	0:54	2:24	1:30	LINE FAULT
588	5-Mar-2021	BAGALKOT	220	BAGEWADI-LINGASUR1	BAGEWADI_220	13:27	15:13	1:46	LINE FAULT
589	5-Mar-2021	BAGALKOT	220	BAGEWADI-LINGASUR2	BAGEWADI_220	13:27	15:11	1:44	LINE FAULT
590	5-Mar-2021	BAGALKOT	220	BAGEWADI-ADPH1	BAGEWADI_220	13:27	16:05	2:38	LINE FAULT
591	5-Mar-2021	BAGALKOT	220	BAGEWADI-ADPH2	BAGEWADI_220	13:47	16:07	2:20	LINE CLEAR AVOIDED
592	5-Mar-2021	BAGALKOT	220	BAGEWADI-FORTUNE1	BAGEWADI_220	13:27	15:21	1:54	LINE CLEAR AVOIDED
593	5-Mar-2021	BAGALKOT	220	BAGEWADI-FORTUNE2	BAGEWADI_220	13:16	15:21	2:05	LINE CLEAR AVOIDED
594	5-Mar-2021	BAGALKOT	220	BAGEWADI-ATRIA1	BAGEWADI_220	13:19	15:15	1:56	LINE FAULT
595	5-Mar-2021	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	13:27	15:58	2:31	LINE CLEAR AVOIDED
596	5-Mar-2021	BAGALKOT	220	BAGEWADI-RBRK1&2	BAGEWADI_220	13:28	15:24	1:56	LINE CLEAR AVOIDED
597	5-Mar-2021	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	13:37	15:21	1:44	LINE CLEAR AVOIDED
598	5-Mar-2021	BAGALKOT	220	BAGEWADI-BIJAPUR2	BAGEWADI_220	13:37	15:22	1:45	LINE CLEAR AVOIDED
599	5-Mar-2021	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2,HV3,LV 3	BAGEWADI_220,MAMADAPUR_110,M UDDEBIHAL_110,NIDAGUNDI_110,UKK ALI_110,SINDAGI_110,CHIMMALAGI LIS_110,MASUTI LIS_110,BALUTI LIS_110	13:27	15:15	1:48	LINE CLEAR AVOIDED
600	5-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	23:42	23:54	0:12	LINE FAULT
601	5-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	23:42	23:54	0:12	LINE FAULT
602	5-Mar-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	7:38	18:29	10:51	LINE CLEAR AVOIDED
603	5-Mar-2021	BAGALKOT	400	DHONI-GUTTUR	DHONI_400	14:19 (04.03.2021)	15:58 (05.03.2021)	1:39HRS	LINE CHARGED
604	5-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_110	12:03	15:11	3:08	LINE CLEAR AVOIDED
605	5-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJRAMATTI_110	12:03	15:11	3:08	LINE CLEAR AVOIDED
606	5-Mar-2021	BAGALKOT	110	UDYAMBAG-UCHAGAON	UDYAMBAG_110	12:20	12:37	0:17	LINE CLEAR AVOIDED
607	5-Mar-2021	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED SOUDATTI_220	06:12	07:06	0:54	TRANSFORMER FAULT
608	5-Mar-2021	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED SOUDATTI_220	06:12	07:10	0:58	TRANSFORMER FAULT
609	5-Mar-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED SOUDATTI_220	06:12	07:11	0:59	TRANSFORMER FAULT
610	5-Mar-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED SOUDATTI_220	06:12	07:35	1:23	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
611	5-Mar-2021	BAGALKOT	110	SODATTI220-SODATTI1	SODATTI_110	7:07	07:24	0:17	HAND TRIPPED
612	5-Mar-2021	BAGALKOT	110	SODATTI220-SODATTI2	SODATTI_110	7:07	07:25	0:18	HAND TRIPPED
613	5-Mar-2021	BAGALKOT	110	SODATTI220-YARAGATTI	YARAGATTI_110	7:07	07:27	0:20	HAND TRIPPED
614	5-Mar-2021	BAGALKOT	110	SODATTI220-MUNAVALLI	MUNAVALLI_110	7:07	07:38	0:31	HAND TRIPPED
615	5-Mar-2021	BAGALKOT	110	SODATTI220-NARAGUND	STATION NOT AFFECTED NARAGUND_110	7:07	13:24	6:17	LINE CLEAR AVOIDED
616	5-Mar-2021	BAGALKOT	110	SODATTI220-RAMADURG1	RAMADURG_110	7:08	07:44	0:36	HAND TRIPPED
617	5-Mar-2021	BAGALKOT	110	SODATTI220-RAMADURG2	STATION NOT AFFECTED RAMADURG_110	7:07	13:12	6:05	LINE CLEAR AVOIDED
618	5-Mar-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL_110	9:26	9:35	0:09	TRANSFORMER FAULT
619	5-Mar-2021	BAGALKOT	110	SAVANUR-RAMANAKOPPA	RAMANAKOPPA_110	22:24	22:56	0:32	LINE FAULT
620	5-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
621	5-Mar-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	12:15	17:54	5:39	LINE CLEAR AVOIDED
622	5-Mar-2021	BAGALKOT	110	NAREGAL-RON	STATION NOT AFFECTED RON_110	9:14	19:15	10:01	LINE CLEAR AVOIDED
623	5-Mar-2021	BAGALKOT	110	INTAL-RAIBAG1	STATION NOT AFFECTED ITANAL_110	10:25	11:20	0:55	LINE CLEAR AVOIDED
624	5-Mar-2021	BAGALKOT	110	INTAL-RAIBAG2	STATION NOT AFFECTED ITANAL_110	10:25	11:20	0:55	LINE CLEAR AVOIDED
625	5-Mar-2021	BAGALKOT	110	110/33KV,HV1	NO STATION NO AFFECTED HUBLI_220	11:35	20:09	8:34	LINE CLEAR AVOIDED
626	5-Mar-2021	BAGALKOT	110	HUBLI-RAMANAKOPPA	STATION NOT AFFECTED HUBLI_220	20:09	23:09	3:00	LINE FAULT
627	5-Mar-2021	BENGALURU	66	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	10:59	14:30	03:30	LINE CLEAR AVOIDED
628	5-Mar-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	11:00	14:30	03:30	LINE CLEAR AVOIDED
629	5-Mar-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	11:00	16:55	05:55	LINE CLEAR AVOIDED
630	5-Mar-2021	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	16:26	23:59	07:32	LINE FAULT
631	5-Mar-2021	BENGALURU	66	HV2	DOMMASANDRA	13:03	13:30	00:26	LINE CLEAR AVOIDED
632	5-Mar-2021	BENGALURU	66	HV1	HOSUR RAMAPURA	10:25	10:40	00:14	LINE CLEAR AVOIDED
633	5-Mar-2021	BENGALURU	66	HV2	HOSUR RAMAPURA	17:20	17:30	00:09	LINE CLEAR AVOIDED
634	5-Mar-2021	BENGALURU	66	HV1	KEMBODI	15:15	16:00	00:45	LINE CLEAR AVOIDED
635	5-Mar-2021	BENGALURU	66	HV2	MAASTHI	04:59	05:07	00:07	TRANSFORMER FAULT
636	5-Mar-2021	BENGALURU	66	HV2	MAASTHI	18:48	18:52	00:04	TRANSFORMER FAULT
637	5-Mar-2021	BENGALURU	66	HV2	MAASTHI	14:05	14:10	00:05	TRANSFORMER FAULT
638	5-Mar-2021	BENGALURU	66	HV1	ISRO LAYOUT	07:45	07:55	00:10	TRANSFORMER FAULT
639	5-Mar-2021	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	NATIONAL COLLEGE	17:01	17:19	00:18	LINE FAULT
640	5-Mar-2021	BENGALURU	66	HV2	NAGANATHPURA 220	11:34	11:37	00:03	LINE CLEAR AVOIDED
641	5-Mar-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	17:01	17:17	00:16	LINE FAULT
642	5-Mar-2021	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	17:01	18:07	01:06	MAIN SUPPLY FAILURE
643	5-Mar-2021	BENGALURU	66	HV2	TELECOM LAYOUT	16:28	17:05	00:37	TRANSFORMER FAULT
644	5-Mar-2021	BENGALURU	66	HV1	TELECOM LAYOUT	18:37	18:40	00:03	LINE CLEAR AVOIDED
645	5-Mar-2021	BENGALURU	66	HV1	ANDERSONPETE	12:09	12:23	00:14	LINE CLEAR AVOIDED
646	5-Mar-2021	BENGALURU	66	HV2	ANDERSONPETE	12:24	13:25	01:01	LINE CLEAR AVOIDED
647	5-Mar-2021	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	15:05	16:27	01:22	LINE FAULT
648	5-Mar-2021	BENGALURU	66	HV1	DODDABELAVANGALA	11:40	11:45	00:05	TRANSFORMER FAULT
649	5-Mar-2021	BENGALURU	66	HV1	DODDABELAVANGALA	12:45	13:00	00:15	LINE CLEAR AVOIDED
650	5-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
651	5-Mar-2021	BENGALURU	66	HV3	NELEMANGALA 66	22:03 (05 MAR 2021)			LINE CLEAR AVOIDED
652	5-Mar-2021	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	08:30	12:47	04:17	LINE CLEAR AVOIDED
653	5-Mar-2021	GULBARGA	220	HV1	SINDHANOOR_220	12:05	13:05	01:00	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
654	5-Mar-2021	GULBARGA	220	HV2	SINDHANOOR_220	12:07	12:15	00:08	TRANSFORMER FAULT
655	5-Mar-2021	GULBARGA	220	HV2	SINDHANOOR_220	12:57	13:07	00:10	TRANSFORMER FAULT
656	5-Mar-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	01:13	01:30	00:17	LINE FAULT
657	5-Mar-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	VICATSAGAR CEMENTS_IPP	05:22	05:49	00:27	LINE FAULT
658	5-Mar-2021	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110	07:18	07:24	00:06	MAIN SUPPLY FAILURE
659	5-Mar-2021	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110	07:34	13:11	05:37	MAIN SUPPLY FAILURE
660	5-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR1	NALWAR_110	10:30(4.3.2021)	13:55(05.03.2021)	27:25HRS	LINE CHARGED
661	5-Mar-2021	GULBARGA	110	HV2	GINIGERA_110	12:15	12:30	00:15	LINE CLEAR AVOIDED
662	5-Mar-2021	GULBARGA	110	HV3	KUSHTAGI_220	14:30	14:40	00:10	TRANSFORMER FAULT
663	5-Mar-2021	GULBARGA	110	HV3	HATTI_110	14:43	14:50	00:07	TRANSFORMER FAULT
664	5-Mar-2021	GULBARGA	110	HV2	MYLAR_110	15:44	15:46	00:02	TRANSFORMER FAULT
665	5-Mar-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	21:45	21:55	00:10	LINE FAULT
666	5-Mar-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:42	23:02	00:20	LINE FAULT
667	5-Mar-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	23:50	23:59	00:09	LINE FAULT
668	5-Mar-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	16:00(3.3.2021)	14:20(5.03.21)	46:20HRS	LINE CHARGED
669	5-Mar-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	17:50(3.3.2021)	14:10(05.03.2021)	44:20HRS	LINE CHARGED
670	5-Mar-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
671	5-Mar-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
672	5-Mar-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	09:39	12:41	03:02	LINE CLEAR AVOIDED
673	5-Mar-2021	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	09:41	12:41	03:00	LINE CLEAR AVOIDED
674	5-Mar-2021	HASSAN	66	HV1	ALDUR_66	11:56	14:29	02:33	LINE CLEAR AVOIDED
675	5-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	11:09	17:30	06:21	LINE CLEAR AVOIDED
676	5-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:02	17:36	06:34	LINE CLEAR AVOIDED
677	5-Mar-2021	HASSAN	66	HV2	HOLALUR_66	18:07	18:55	00:48	LINE CLEAR AVOIDED
678	5-Mar-2021	HASSAN	66	HV2	HOLEHONNUR_66	12:14	12:39	00:25	LINE CLEAR AVOIDED
679	5-Mar-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	13:43	20:55	07:12	LINE CLEAR AVOIDED
680	5-Mar-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	13:43	20:55	07:12	LINE CLEAR AVOIDED
681	5-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	11:01	17:39	06:38	NFBC ISSUED
682	5-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:59	17:32	06:33	LINE CLEAR AVOIDED
683	5-Mar-2021	MYSURU	66	HV1	ARAKERE_66	7:00	7:04	0:03	TRANSFORMER FAULT
684	5-Mar-2021	MYSURU	66	CR NAGARA-KABBALI	NO STATIONS EFFECTED	12:55	15:34	2:38	LINE CLEAR AVOIDED
685	5-Mar-2021	MYSURU	66	CR NAGARA-DR PETE 2	NO STATIONS EFFECTED	16:49	17:01	0:12	HAND TRIPPED
686	5-Mar-2021	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	11:05	12:21	1:16	NFBC ISSUED
687	5-Mar-2021	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	9:39	11:04	1:25	NFBC ISSUED
688	5-Mar-2021	MYSURU	66	DATAGALLI-RK NAGARA	RKNAGARA_66	9:36	17:43	8:07	NFBC ISSUED
689	5-Mar-2021	MYSURU	66	HV1	GAMANAHALLY_66	19:09	19:16	0:06	LINE CLEAR AVOIDED
690	5-Mar-2021	MYSURU	66	GAMANAHALLI-TUBINKERE	GAMANAHALLY_66	14:20	18:50	4:29	LINE CLEAR AVOIDED
691	5-Mar-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	10:16	16:47	6:30	LINE CLEAR AVOIDED
692	5-Mar-2021	MYSURU	220	HV2	KADAKOLA_220	10:42	16:31	5:49	LINE CLEAR AVOIDED
693	5-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	6:52	20:51	13:59	LINE CLEAR AVOIDED
694	5-Mar-2021	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	10:09	16:35	6:26	LINE CLEAR AVOIDED
695	5-Mar-2021	MYSURU	66	HV3	KUSHALANAGARA_66	11:15	13:38	2:23	LINE CLEAR AVOIDED
696	5-Mar-2021	MYSURU	220	KUSHALNAGARA-BASTIPURA 1	NO STATIONS EFFECTED	14:44	17:21	2:37	LINE CLEAR AVOIDED
697	5-Mar-2021	MYSURU	220	HV2	MADHUVANAHALLI_220	15:15	16:44	1:29	LINE CLEAR AVOIDED
698	5-Mar-2021	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	12:26	13:30	1:04	LINE CLEAR AVOIDED
699	5-Mar-2021	MYSURU	220	MADHUVANAHALLI-HEBBANI 2	NO STATIONS EFFECTED	13:36	14:33	0:57	LINE CLEAR AVOIDED
700	5-Mar-2021	MYSURU	66	MYSORE SOUTH-GIS	MYSORESOUTH_66	10:15	16:56	6:41	LINE CLEAR AVOIDED
701	5-Mar-2021	MYSURU	66	HV1	NAGAMANGALA_66	8:37	8:40	0:02	TRANSFORMER FAULT
702	5-Mar-2021	MYSURU	66	HV2	SATHEGALA_66	11:00	11:12	0:12	LINE CLEAR AVOIDED
703	5-Mar-2021	MYSURU	66	HV2	SFCSHIVA_66	10:05	12:42	2:37	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
704	5-Mar-2021	MYSURU	66	TUBINKERE-G UKKADE	GARUDANAUKADDA_66 SRIRANGAPATNA 66	10:22	10:27	0:04	HAND TRIPPED
705	5-Mar-2021	MYSURU	66	HV2	TUBINAKERE 220	11:13	13:01	1:47	LINE CLEAR AVOIDED
706	5-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVOIDED
707	5-Mar-2021	TUMKUR	110	HONNAVALI 110-ADAN SOLAR IPP 66	ADAN SOLAR_IPP_110	18:53	23:26	4:32	LINE CLEAR AVOIDED
708	5-Mar-2021	TUMKUR	110	TR-1	MAYASANDRA_110	8:00	9:13	1:12	TRANSFORMER FAULT
709	5-Mar-2021	TUMKUR	110	SAMPIGE- RENEWIND_IPP_110	RENEW_WIND_IPP_110	18:52	19:22	0:30	LINE CLEAR AVOIDED
710	5-Mar-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:18	13:31	0:13	LINE FAULT
711	5-Mar-2021	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	14:41	14:54	0:13	HAND TRIPPED
712	5-Mar-2021	TUMKUR	66	TR-2	BELLAVI_66	11:10	12:01	0:50	LINE CLEAR AVOIDED
713	5-Mar-2021	TUMKUR	66	TR-2	BELLAVI_66	14:03	14:52	0:49	LINE CLEAR AVOIDED
714	5-Mar-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	8:58	15:14	6:15	LINE CLEAR AVOIDED
715	5-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:32	7:43	0:11	LINE FAULT
716	5-Mar-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	4:59	5:13	0:13	LINE FAULT
717	5-Mar-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA 66, SANTEBENNUR 66	15:53	16:03	0:10	LINE FAULT
718	5-Mar-2021	TUMKUR	66	TR-3	HOLALKERE_66	12:12	12:40	0:27	TRANSFORMER FAULT
719	5-Mar-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	7:06	7:17	0:10	LINE FAULT
720	5-Mar-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA 66	3:53	4:04	0:10	LINE FAULT
721	5-Mar-2021	TUMKUR	66	TR-2	HOSADURGA_66	7:10	7:16	0:06	LINE CLEAR AVOIDED
722	5-Mar-2021	TUMKUR	66	TR-2	KOLALA_66	12:03	14:43	2:40	LINE CLEAR AVOIDED
723	5-Mar-2021	TUMKUR	66	TR-2	LINGADAHALLI_TM2_66	10:49	10:52	0:03	TRANSFORMER FAULT
724	5-Mar-2021	TUMKUR	66	TR-1	MAYASANDRA_110	18:16	19:55	1:38	TRANSFORMER FAULT
725	5-Mar-2021	TUMKUR	66	NEELAGUNDA 220KV-TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA 66, OBAJJIHALLI 66	7:47	8:04	0:16	LINE FAULT
726	5-Mar-2021	TUMKUR	66	THALLAK 220KV- SEI DIAMOND SOLAR IPP 66	SEL DIAMOND SOLAR_IPP_66	18:49	22:23	3:33	LINE CLEAR AVOIDED
727	5-Mar-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	15:21	15:26	0:05	LINE FAULT
728	6-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
729	6-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
730	6-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
731	6-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
732	6-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
733	6-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
734	6-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
735	6-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
736	6-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
737	6-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI 110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
738	6-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
739	6-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI 220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
740	6-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
741	6-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
742	6-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
743	6-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
744	6-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVAILED
745	6-Mar-2021	BAGALKOT	220	GADAG- HARTI2	STATION NOT AFFECTED GADAG_220	17:16 (25.02.2021)			LINE OPEN, LINE CLEAR AVAILED
746	6-Mar-2021	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:42 (28.02.2021)			LINE OPEN, LINE CLEAR AVAILED
747	6-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN, LINE CLEAR AVAILED
748	6-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	22:16 (04.03.2021)	13:55 (06.03.2021)	39:39hrs	LINE CHARGED
749	6-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	22:16 (04.03.2021)	13:55 (06.03.2021)	39:39hrs	LINE CHARGED
750	6-Mar-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:07 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
751	6-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
752	6-Mar-2021	BAGALKOT	220	220/110KV, HV2,LV2	CHIKKODI_220	10:36 (06.03.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
753	6-Mar-2021	BAGALKOT	400	DHONI 400-HALVARTHI 2 (LGPR1)	DHONI_400	10:08	14:29	4:21	NFBC ISSUED
754	6-Mar-2021	BAGALKOT	220	220/110KV,HV1 & LV1	GADAG_220	14:54	19:48	4:54	LINE CLEAR AVAILED
755	6-Mar-2021	BAGALKOT	220	220/110KV,HV1 & LV1	HAVERI_220,BYADAGI_110,HANGAL_110, SAVANUR_110,BASAVAN KATTI_110 ,TILUVALI_110,GM SUGARS_110 ,PNNL_110 ,	14:50	15:20	0:30	HAND TRIPPED
756	6-Mar-2021	BAGALKOT	110	HAVERI220-BYADGI/RNBNR	BYADAGI_110	15:20	15:23	0:03	HAND TRIPPED
757	6-Mar-2021	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	15:20	15:24	0:04	HAND TRIPPED
758	6-Mar-2021	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	15:20	15:24	0:04	HAND TRIPPED
759	6-Mar-2021	BAGALKOT	110	HAVERI220-BASAVANKATTI	BASAVAN KATTI_110	14:44	15:30	0:46	HAND TRIPPED
760	6-Mar-2021	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	15:20	15:21	0:01	HAND TRIPPED
761	6-Mar-2021	BAGALKOT	110	HAVERI220-GM SUGARS,PNNL	GM SUGARS_110 ,PNNL_110	14:44	15:30	0:46	HAND TRIPPED
762	6-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA 1	HAVERI_220	14:44	14:50	0:06	LINE FAULT
763	6-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA 1	HAVERI_220	17:01 (06.03.2021)			LINE OPEN, LINE CLEAR AVAILED
764	6-Mar-2021	BAGALKOT	220	HAVER-GUTTUR 1	HAVERI_220	14:46	15:20	0:34	LINE FAULT
765	6-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA1&2	AMBEWADI_220	08:01	17:17	9:16	NFBC ISSUED
766	6-Mar-2021	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	14:54	17:56	3:02	LINE CLEAR AVAILED
767	6-Mar-2021	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	AMBEWADI_220	14:54	17:00	2:06	LINE CLEAR AVAILED
768	6-Mar-2021	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	15:34	16:04	0:30	HAND TRIPPED
769	6-Mar-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	09:02	14:05	5:03	LINE FAULT
770	6-Mar-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	14:49	15:23	0:34	HAND TRIPPED
771	6-Mar-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	16:10	21:47	5:37	LINE CLEAR AVAILED
772	6-Mar-2021	BAGALKOT	110	SUPA 1 &2-AMBEWADI	AMBEWADI_220	09:02	9:19	0:17	HAND TRIPPED
773	6-Mar-2021	BAGALKOT	110	SUPA 1&2-AMBEWADI	AMBEWADI_220	14:51	16:24	1:33	LINE CLEAR AVAILED
774	6-Mar-2021	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	9:11	09:20	0:09	LINE FAULT
775	6-Mar-2021	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	9:32	18:17	8:45	LINE CLEAR AVAILED
776	6-Mar-2021	BAGALKOT	110	110/11KV,HV3	BAILHONGAL_110	11:05	11:36	0:31	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
777	6-Mar-2021	BAGALKOT	110	110/33KV,HV1	BAILHONGAL_110 &NEGINAL,SAMPAGOAN,MURGOD_33	22:06	22:43	0:37	TRANSFORMER FAULT
778	6-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	2:34	2:44	0:10	LINE FAULT
779	6-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	3:29	3:48	0:19	LINE FAULT
780	6-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	14:01	15:09	1:08	LINE CLEAR AVAILED
781	6-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	18:10	20:27	2:17	LINE CLEAR AVAILED
782	6-Mar-2021	BAGALKOT	220	BIDNAL220-SOUDATTI	BIDNAL_220	12:23	16:20	3:57	LINE FAULT
783	6-Mar-2021	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	14:44 (6.32021)			LINE OPEN,LINE FAULT
784	6-Mar-2021	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	15:33	15:37	0:04	HAND TRIPPED
785	6-Mar-2021	BAGALKOT	220	BIDNAL-NAGJHARI 2	BIDNAL_220	15:33	16:08	0:35	HAND TRIPPED
786	6-Mar-2021	BAGALKOT	220	BIDNAL-TADAS1	BIDNAL_220	15:33	15:45	0:12	HAND TRIPPED
787	6-Mar-2021	BAGALKOT	220	BIDNAL-TADAS1	BIDNAL_220	15:33	17:32	1:59	LINE CLEAR AVAILED
788	6-Mar-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	15:33	15:38	0:05	HAND TRIPPED
789	6-Mar-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	15:50	16:18	0:28	HAND TRIPPED
790	6-Mar-2021	BAGALKOT	110	BIDNAL-GADAG	GADAG_110	15:33	15:39	0:06	HAND TRIPPED
791	6-Mar-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	15:33	15:40	0:07	HAND TRIPPED
792	6-Mar-2021	BAGALKOT	110	BIDNAL-PH COMPUND	PH COMPUND_110	15:33	15:41	0:08	HAND TRIPPED
793	6-Mar-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	15:50	16:23	0:33	HAND TRIPPED
794	6-Mar-2021	BAGALKOT	110	KIADB -BHUTANAL	BHUTANAL_110	7:58	8:01	0:03	LINE FAULT
795	6-Mar-2021	BAGALKOT	110	TORVI-TIKOTA	TIKOTA_110	9:00	10:49	1:49	LINE CLEAR AVAILED
796	6-Mar-2021	BAGALKOT	110	GOPANAKOPPA -GADG ROAD	GADAG ROAD_110	14:52	15:40	0:48	HAND TRIPPED
797	6-Mar-2021	BAGALKOT	110	110/11KV,HV3	HALIYAL_110	15:00	18:19	3:19	LINE CLEAR AVAILED
798	6-Mar-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	05:35	05:40	0:05	TRANSFORMER FAULT
799	6-Mar-2021	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	12:17	15:48	3:31	LINE CLEAR AVAILED
800	6-Mar-2021	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	13:46 (06.03.2021)			LINE OPEN,LINE FAULT
801	6-Mar-2021	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	14:20	19:48	5:28	LINE FAULT
802	6-Mar-2021	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	14:25	19:41	5:16	LINE FAULT
803	6-Mar-2021	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	14:45	15:46	1:01	LINE CLEAR AVAILED
804	6-Mar-2021	BAGALKOT	110	HUBLI- ANANDNAGAR	ANANDNAGAR_110	14:45	15:41	0:56	HAND TRIPPED
805	6-Mar-2021	BAGALKOT	220	SOUDATT220I- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	12:23	16:19	3:56	LINE FAULT
806	6-Mar-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	11:19	11:47	0:28	HAND TRIPPED
807	6-Mar-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:17	15:48	3:31	LINE CLEAR AVAILED
808	6-Mar-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	13:48 (06.03.2021)			LINE OPEN, LINE CLEAR AVAILED
809	6-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
810	6-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
811	6-Mar-2021	BAGALKOT	110	110/11KV, HV2	SATTI_110	9:22	16:57	7:35	LINE CLEAR AVAILED
812	6-Mar-2021	BAGALKOT	110	CHIKKODI220- NANADI	NANADI_110	12:33	17:08	4:35	LINE CLEAR AVAILED
813	6-Mar-2021	BAGALKOT	110	DODDANNAVAR- NANADI	NANADI_110	12:30	18:31	6:01	LINE CLEAR AVAILED
814	6-Mar-2021	BAGALKOT	110	110/11KV, HV1	NANADI_110	12:04	17:09	5:05	LINE CLEAR AVAILED
815	6-Mar-2021	BAGALKOT	110	110/11KV, HV2	NANADI_110	9:58	17:12	7:14	LINE CLEAR AVAILED
816	6-Mar-2021	BAGALKOT	110	NARAGUND- BPCL	NARAGUND_110	16:26	18:29	2:03	LINE FAULT
817	6-Mar-2021	BAGALKOT	110	BASAVASUGARS- MALGHAN(B)	MALGHAN(B)_110	15:26	16:24	0:58	LINE CLEAR AVAILED
818	6-Mar-2021	BAGALKOT	110	110/33KV, HV3	MACHE_110	7:50	8:51	1:01	LINE CLEAR AVAILED
819	6-Mar-2021	BAGALKOT	110	110/33KV, HV3	MACHE_110	9:14	9:32	0:18	LINE CLEAR AVAILED
820	6-Mar-2021	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	9:01	22:05	13:04	LINE FAULT
821	6-Mar-2021	BAGALKOT	110	KD JAMBAGI- MUDHOL (HALKI)	HALKI_110	13:56	14:10	0:14	LINE CLEAR AVAILED
822	6-Mar-2021	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	12:46	13:05	0:19	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
823	6-Mar-2021	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	12:53	13:41	0:48	TRANSFORMER FAULT
824	6-Mar-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	8:03	17:16	9:13	LINE CLEAR AVAILED
825	6-Mar-2021	BAGALKOT	220	NARENDRA- HAVERI1	NARENDRA_220	14:45 (06.03.2021)			LINE OPEN,LINE FAULT
826	6-Mar-2021	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	14:19	19:41	5:22	LINE FAULT
827	6-Mar-2021	BENGALURU	66	HV1	B G ROAD	10:23	10:27	00:04	LINE CLEAR AVAILED
828	6-Mar-2021	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	13:50	14:30	00:40	MAIN SUPPLY FAILURE
829	6-Mar-2021	BENGALURU	66	HAMUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	07:45	07:55	00:10	LOAD CHANGE OVER
830	6-Mar-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	13:50	14:40	00:50	MAIN SUPPLY FAILURE
831	6-Mar-2021	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	13:36	17:35	03:59	LINE FAULT
832	6-Mar-2021	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	13:32	16:38	03:06	LINE FAULT
833	6-Mar-2021	BENGALURU	66	HV1	IISc	09:17	09:24	00:07	LINE CLEAR AVAILED
834	6-Mar-2021	BENGALURU	66	HV2	KADUGODI	18:00	18:37	00:37	TRANSFORMER FAULT
835	6-Mar-2021	BENGALURU	66	KODIGEHALLI - BYADRAHALLI	T G HALLI, TAVAREKERE	07:01	07:15	00:14	LINE FAULT
836	6-Mar-2021	BENGALURU	66	KODIGEHALLI - BYADRAHALLI	T G HALLI, TAVAREKERE	09:21	09:34	00:13	LINE FAULT
837	6-Mar-2021	BENGALURU	66	KODIGEHALLI - BYADRAHALLI	T G HALLI, TAVAREKERE	19:25	19:27	00:02	LINE FAULT
838	6-Mar-2021	BENGALURU	220	HV2	MANYATHA TECH PARK 220	13:37	13:58	00:21	LINE CLEAR AVAILED
839	6-Mar-2021	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	SHOBHA CITY	13:38	14:02	00:24	LINE CLEAR AVAILED
840	6-Mar-2021	BENGALURU	66	HV1	MANYATHA TECH PARK 220	13:39	14:12	00:33	LINE CLEAR AVAILED
841	6-Mar-2021	BENGALURU	66	HV1	NAGANATHPURA 220	12:03	12:08	00:05	LINE CLEAR AVAILED
842	6-Mar-2021	BENGALURU	66	HV1	NIMHANS 220	12:07	12:12	00:05	LINE CLEAR AVAILED
843	6-Mar-2021	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	13:50	14:05	00:15	LOAD CHANGE OVER
844	6-Mar-2021	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	15:05	15:10	00:05	LOAD CHANGE OVER
845	6-Mar-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	05:48	06:03	00:15	LINE FAULT
846	6-Mar-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	06:03	06:46	00:43	LINE FAULT
847	6-Mar-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	06:46	13:05	06:19	LINE CLEAR AVAILED
848	6-Mar-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	14:40	15:03	00:23	LINE FAULT
849	6-Mar-2021	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	11:30	11:35	00:05	TRANSFORMER FAULT
850	6-Mar-2021	BENGALURU	66	HV3	DIVYASHREE TECH PARK	12:40	14:59	02:19	LINE CLEAR AVAILED
851	6-Mar-2021	BENGALURU	220	BEGUR 220 - KIADB HARDWARE PARK 1	BEGUR 220	13:50	14:21	00:31	LINE FAULT
852	6-Mar-2021	BENGALURU	220	BEGUR 220 - KIADB HARDWARE PARK 1	BEGUR 220	13:50	14:21	00:31	LINE FAULT
853	6-Mar-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:06	22:15	00:08	LINE FAULT
854	6-Mar-2021	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	13:50	14:25	00:35	MAIN SUPPLY FAILURE
855	6-Mar-2021	BENGALURU	220	KIADB HARDWARE PARK 220 - BIAL 1	BIAL 220	13:50	14:22	00:32	MAIN SUPPLY FAILURE
856	6-Mar-2021	BENGALURU	220	KIADB HARDWARE PARK 220 - BIAL 2	BIAL 220	13:50	14:25	00:35	MAIN SUPPLY FAILURE
857	6-Mar-2021	BENGALURU	220	KIADB HARDWARE PARK 220 - DEVANAHALLI 1	KIADB HARDWARE PARK 220	13:50	14:15	00:25	MAIN SUPPLY FAILURE
858	6-Mar-2021	BENGALURU	220	KIADB HARDWARE PARK 220 - DEVANAHALLI 1	KIADB HARDWARE PARK 220	13:50	14:15	00:25	MAIN SUPPLY FAILURE
859	6-Mar-2021	BENGALURU	220	KIADB HARDWARE PARK 220 - HOSKOTE 1	HOSKOTE 220	13:50	14:19	00:29	MAIN SUPPLY FAILURE
860	6-Mar-2021	BENGALURU	220	KIADB HARDWARE PARK 220 - HOSKOTE 2	HOSKOTE 220	13:50	14:19	00:29	MAIN SUPPLY FAILURE
861	6-Mar-2021	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	13:50	14:28	00:38	MAIN SUPPLY FAILURE
862	6-Mar-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	13:50	14:26	00:36	MAIN SUPPLY FAILURE
863	6-Mar-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:50	14:27	00:37	MAIN SUPPLY FAILURE
864	6-Mar-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	13:50	14:27	00:37	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
865	6-Mar-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:50	14:24	00:34	MAIN SUPPLY FAILURE
866	6-Mar-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	11:40	12:18	00:38	LINE FAULT
867	6-Mar-2021	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	13:50	17:36	03:46	LINE FAULT
868	6-Mar-2021	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 1	KIADB HARDWARE PARK 220	13:50	14:14	00:24	LINE FAULT
869	6-Mar-2021	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 2	KIADB HARDWARE PARK 220	13:50	14:15	00:24	LINE FAULT
870	6-Mar-2021	BENGALURU	66	HV2	SM MANGALA	14:40	16:11	01:31	LINE CLEAR AVOIDED
871	6-Mar-2021	BENGALURU	66	HV1	HUKUNDA	17:05	17:10	00:05	TRANSFORMER FAULT
872	6-Mar-2021	BENGALURU	66	HV1	SM MANGALA	13:20	14:45	01:25	LINE CLEAR AVOIDED
873	6-Mar-2021	BENGALURU	66	HV1	MAASTHI	11:55	12:00	00:05	TRANSFORMER FAULT
874	6-Mar-2021	BENGALURU	66	HV1	KAMASAMUDRA	11:00	13:07	02:07	LINE CLEAR AVOIDED
875	6-Mar-2021	BENGALURU	66	HV1	HOSKOTE 66	11:45	12:05	00:20	LINE CLEAR AVOIDED
876	6-Mar-2021	BENGALURU	66	HV3	HOSKOTE 66	11:30	11:45	00:15	TRANSFORMER FAULT
877	6-Mar-2021	BENGALURU	66	HV2	BEGUR 220	13:50	14:27	00:37	MAIN SUPPLY FAILURE
878	6-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
879	6-Mar-2021	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)			LINE OPEN,LINE FAULT
880	6-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN,LINE FAULT
881	6-Mar-2021	GULBARGA	220	LINGAPUR-GDHALLI2	LINGAPUR_220	07:50	13:43	05:53	MAIN SUPPLY FAILURE
882	6-Mar-2021	GULBARGA	220	SHAHAPUR-KAPNOOR1	KAPNOOR_220	07:25	20:56	13:31	LINE FAULT
883	6-Mar-2021	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	07:25	19:30	12:05	LINE FAULT
884	6-Mar-2021	GULBARGA	220	SEDAM-RTPS1	RTPS_220	15:47	16:48	01:01	LINE FAULT
885	6-Mar-2021	GULBARGA	110	HUMNABAD-ALAND	ALAND_110	11:15	15:55	04:40	LINE CLEAR AVOIDED
886	6-Mar-2021	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	13:32	13:52	00:20	LINE CLEAR AVOIDED
887	6-Mar-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	14:50	14:59	00:09	LINE FAULT
888	6-Mar-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	06:30	06:35	00:05	LINE FAULT
889	6-Mar-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	15:44	15:50	00:06	LINE FAULT
890	6-Mar-2021	GULBARGA	110	HV2	BISLIHALLI_110	09:35	09:45	00:10	TRANSFORMER FAULT
891	6-Mar-2021	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	12:02	12:16	00:14	MAIN SUPPLY FAILURE
892	6-Mar-2021	GULBARGA	110	HV2	MYLAR_110	13:20	13:25	00:05	TRANSFORMER FAULT
893	6-Mar-2021	GULBARGA	110	HV1	NIRNA_110	14:00	14:05	00:05	TRANSFORMER FAULT
894	6-Mar-2021	GULBARGA	110	HV1	NIRNA_110	14:15	14:20	00:05	TRANSFORMER FAULT
895	6-Mar-2021	GULBARGA	110	HV3	VALKAMDINI_110	15:20	18:40	03:20	LINE CLEAR AVOIDED
896	6-Mar-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_IPP,UGARSUGAR_IPP	07:21	07:31	00:10	LINE FAULT
897	6-Mar-2021	GULBARGA	110	SHAHAPUR-KEMBHA	KEMBHAVI_IPP,UGARSUGAR_IPP	17:27	19:45	02:18	LINE FAULT
898	6-Mar-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:03	21:13	00:10	LINE FAULT
899	6-Mar-2021	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	14:20	14:31	00:11	LINE FAULT
900	6-Mar-2021	GULBARGA	110	HV3	HANUMASAGAR_110	18:55	19:20	00:25	TRANSFORMER FAULT
901	6-Mar-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
902	6-Mar-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVOIDED
903	6-Mar-2021	HASSAN	66	HASSN220-HN PURA	HASSAN_220	07:20	07:33	00:13	LINE FAULT
904	6-Mar-2021	HASSAN	66	HASSN220-HN PURA	HASSAN_220	07:35	08:22	00:47	LINE FAULT
905	6-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:44	16:07	05:23	LINE CLEAR AVOIDED
906	6-Mar-2021	HASSAN	220	KEMAR-Varahi3	KEMAR_220	05:49	17:43	11:54	LINE CLEAR AVOIDED
907	6-Mar-2021	HASSAN	66	MRSSHM-BD-1	MRSMG_220	08:19	13:01	04:42	LINE FAULT
908	6-Mar-2021	HASSAN	66	MRSSHM-BD-2	MRSMG_220	10:53	13:02	02:09	LINE CLEAR AVOIDED
909	6-Mar-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	10:48	12:55	02:07	LINE CLEAR AVOIDED
910	6-Mar-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	14:54	15:02	00:08	LINE FAULT
911	6-Mar-2021	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:44	16:07	05:23	NFBC ISSUED
912	6-Mar-2021	HASSAN	110	HV1	ARASIKERE_110	12:21	13:43	01:22	LINE CLEAR AVOIDED
913	6-Mar-2021	HASSAN	110	HV1	HULICAL_110	12:00	15:20	03:20	LINE CLEAR AVOIDED
914	6-Mar-2021	HASSAN	110	HV1	KONAJE_110	07:34	07:37	00:03	HAND TRIPPED
915	6-Mar-2021	HASSAN	110	HV2	KONAJE_110	07:34	07:38	00:04	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
916	6-Mar-2021	HASSAN	110	HV3	KONAJE_110	07:34	07:37	00:03	HAND TRIPPED
917	6-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	14:05	18:18	04:13	NFBC ISSUED
918	6-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	14:05	18:18	04:13	NFBC ISSUED
919	6-Mar-2021	HASSAN	66	HV3	BALEHONNUR_66	14:11	15:13	01:02	LINE CLEAR AVAILED
920	6-Mar-2021	HASSAN	66	HV4	BALEHONNUR_66	14:11	15:13	01:02	LINE CLEAR AVAILED
921	6-Mar-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:32	14:16	00:44	LINE CLEAR AVAILED
922	6-Mar-2021	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	08:18	13:40	05:22	LINE FAULT
923	6-Mar-2021	HASSAN	66	BHADRA-SHMG 2	bhadra_gen	10:05	13:39	03:34	NFBC ISSUED
924	6-Mar-2021	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	14:00	18:06	04:06	LINE CLEAR AVAILED
925	6-Mar-2021	HASSAN	66	HV1	DUDDA_66	22:29	22:39	00:10	TRANSFORMER FAULT
926	6-Mar-2021	HASSAN	66	HV2	HOLALUR_66	09:55	13:09	03:14	MAIN SUPPLY FAILURE
927	6-Mar-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	13:47	16:20	02:33	LINE CLEAR AVAILED
928	6-Mar-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	13:47	16:20	02:33	LINE CLEAR AVAILED
929	6-Mar-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	09:55	12:55	03:00	MAIN SUPPLY FAILURE
930	6-Mar-2021	MYSURU	66	KUSHALNAGARA-HV1	SOMWARPETE_33	10:20	13:20	3:00	LINE CLEAR AVAILED
931	6-Mar-2021	MYSURU	220	KUSHALNAGARA-BASTIPURA 2	NO STATIONS EFFECTED	14:41	16:57	2:16	LINE CLEAR AVAILED
932	6-Mar-2021	MYSURU	66	HV3	KUSHALANAGARA_66	10:20	13:20	3:00	LINE CLEAR AVAILED
933	6-Mar-2021	MYSURU	66	HV2	BILIKERE_66	11:37	11:58	0:20	TRANSFORMER FAULT
934	6-Mar-2021	MYSURU	66	HV2	DUNDANAHALLI_66	13:30	15:18	1:48	LINE CLEAR AVAILED
935	6-Mar-2021	MYSURU	66	HV2	DUNDANAHALLI_66	17:45	17:50	0:05	TRANSFORMER FAULT
936	6-Mar-2021	MYSURU	66	HV2	DUNDANAHALLI_66	18:30	18:41	0:11	HAND TRIPPED
937	6-Mar-2021	MYSURU	66	HV2	DEVANOORMYS_66	11:52	17:06	5:14	LINE CLEAR AVAILED
938	6-Mar-2021	MYSURU	66	HANAGODU-HUNSUR	NO STATIONS EFFECTED	20:20	20:47	0:27	HAND TRIPPED
939	6-Mar-2021	MYSURU	66	HV1	HANNUR_66	17:07	18:05	0:57	LINE CLEAR AVAILED
940	6-Mar-2021	MYSURU	66	HV2	HANNUR_66	15:50	17:01	1:11	LINE CLEAR AVAILED
941	6-Mar-2021	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	10:38	19:30	8:51	LINE CLEAR AVAILED
942	6-Mar-2021	MYSURU	220	HV1	HOOTAGALLY_220	12:23 (06/03/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
943	6-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	6:56	21:36	14:39	LINE CLEAR AVAILED
944	6-Mar-2021	MYSURU	66	HV1	K_HONNALGERE_66	5:49	7:00	1:11	MAIN SUPPLY FAILURE
945	6-Mar-2021	MYSURU	66	HV2	K_HONNALGERE_66	5:49	7:00	1:11	MAIN SUPPLY FAILURE
946	6-Mar-2021	MYSURU	66	K_HONNALGERE-IGLOOR	K_HONNALGERE_66	15:30	16:56	1:26	LINE CLEAR AVAILED
947	6-Mar-2021	MYSURU	66	K_HONNALGERE-MADDUR	K_HONNALGERE_66	15:30	16:45	1:15	LINE CLEAR AVAILED
948	6-Mar-2021	MYSURU	66	HV1	RAMAPURA_MYS_66	13:48	14:18	0:30	LINE CLEAR AVAILED
949	6-Mar-2021	MYSURU	66	HV4	SFCSHIVA_66	10:33	12:40	2:06	LINE CLEAR AVAILED
950	6-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	13:06 (06/03/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
951	6-Mar-2021	MYSURU	66	SFCSIVA-PPCL	NO STATIONS EFFECTED	6:05	11:50	5:45	LINE CLEAR AVAILED
952	6-Mar-2021	MYSURU	66	VIJAYANAGARA-BANNIMANTAP	NO STATIONS EFFECTED	19:22 (06/03/2021)			LINE OPEN, LINE CLEAR AVAILED
953	6-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
954	6-Mar-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:06	17:53	6:46	LINE CLEAR AVAILED
955	6-Mar-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:06	17:53	6:47	LINE CLEAR AVAILED
956	6-Mar-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:30	12:26	0:55	LINE CLEAR AVAILED
957	6-Mar-2021	TUMKUR	110	TR-2	SAMPIGE_110	7:45	9:06	1:21	LINE CLEAR AVAILED
958	6-Mar-2021	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	21:35	21:47	0:11	LINE CLEAR AVAILED
959	6-Mar-2021	TUMKUR	66	BELADADARA-KORATAGERE	BELADARA_66	21:46	21:49	0:02	LINE CLEAR AVAILED
960	6-Mar-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	12:02	12:04	0:01	TRANSFORMER FAULT
961	6-Mar-2021	TUMKUR	66	TR-1	BUKKAPATNA_66	10:54	16:05	5:10	LINE CLEAR AVAILED
962	6-Mar-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	15:40	16:17	0:37	TRANSFORMER FAULT
963	6-Mar-2021	TUMKUR	66	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	9:10	9:27	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
964	6-Mar-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:09	18:22	0:12	LINE FAULT
965	6-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:48	14:06	0:18	LINE CLEAR AVAILED
966	6-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:56	19:07	0:10	LINE FAULT
967	6-Mar-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:24	19:32	0:08	LINE FAULT
968	6-Mar-2021	TUMKUR	66	TR-1	DYAVARANAHALLI_66	13:32	13:36	0:04	TRANSFORMER FAULT
969	6-Mar-2021	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	13:27	13:40	0:12	LINE FAULT
970	6-Mar-2021	TUMKUR	66	TR-2	KOLALA_66	16:06	18:46	2:40	LINE CLEAR AVAILED
971	6-Mar-2021	TUMKUR	66	MELKOTE-ANTHRASANAHALLI	MELKOTE_66	10:42	11:35	0:52	MAIN SUPPLY FAILURE
972	6-Mar-2021	TUMKUR	66	THALLAK 220kv- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	15:35	16:40	1:04	LINE CLEAR AVAILED
973	6-Mar-2021	TUMKUR	66	TR-2	TAVAREKERE(C)_66	9:01	9:31	0:29	TRANSFORMER FAULT
974	7-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
975	7-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
976	7-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
977	7-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
978	7-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
979	7-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
980	7-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
981	7-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
982	7-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVAILED
983	7-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVAILED
984	7-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVAILED
985	7-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVAILED
986	7-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVAILED
987	7-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
988	7-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
989	7-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
990	7-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVAILED
991	7-Mar-2021	BAGALKOT	220	GADAG- HARTI2	STATION NOT AFFECTED GADAG_220	17:16 (25.02.2021)	11:13 (07.03.2021)	233:57hrs	LINE CHARGED
992	7-Mar-2021	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:42 (28.02.2021)	8:16 (07.03.2021)	158:34hrs	LINE CHARGED
993	7-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN, LINE CLEAR AVAILED
994	7-Mar-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:07 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED
995	7-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
996	7-Mar-2021	BAGALKOT	220	220/110KV, HV2, LV2	CHIKKODI_220	10:36 (06.03.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILABLE
997	7-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA 1	HAVERI_220	17:01 (06.03.2021)			LINE OPEN, LINE CLEAR AVAILABLE
998	7-Mar-2021	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	14:44 (6.3.2021)	16:25 (7.3.2021)	25:41hrs	LINE CHARGED
999	7-Mar-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	13:48 (06.03.2021)	14:49 (07.03.2021)	25:01hrs	LINE CHARGED
1000	7-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1001	7-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1002	7-Mar-2021	BAGALKOT	220	NARENDRA- HAVERI1	NARENDRA_220	14:45 (06.03.2021)			LINE OPEN, LINE FAULT
1003	7-Mar-2021	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	13:46 (06.03.2021)	14:48 (07.03.2021)	25:02hrs	LINE CHARGED
1004	7-Mar-2021	BAGALKOT	220	CHIKKODI 220-KUDACHI	STATION NOT AFFECTED CHIKKODI_220	11:31	15:55	4:24	LINE CLEAR AVAILABLE
1005	7-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA1&2	AMBEWADI_220	07:28	17:21	9:53	NFBC ISSUED
1006	7-Mar-2021	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	5:36	12:12	6:36	LINE FAULT
1007	7-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	16:52 (25.02.2021)	16:25 (7.3.2021)	239:33hrs	LINE CHARGED
1008	7-Mar-2021	BAGALKOT	110	110/11KV, HV2	BYADAGI_110	7:28	19:26	11:58	LINE CLEAR AVAILABLE
1009	7-Mar-2021	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	5:36	12:23	6:47	LINE FAULT
1010	7-Mar-2021	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED SOUDATTI_220	11:13	13:03	1:50	LINE CLEAR AVAILABLE
1011	7-Mar-2021	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED SOUDATTI_220	13:20	15:23	2:03	LINE CLEAR AVAILABLE
1012	7-Mar-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	10:04	16:14	6:10	LINE CLEAR AVAILABLE
1013	7-Mar-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI1	SOUDATTI_110	10:04	20:20	10:16	LINE CLEAR AVAILABLE
1014	7-Mar-2021	BAGALKOT	110	SOUDATTI220- MUNAVALLI	MUNAVALLI_110	10:05	17:59	7:54	LINE CLEAR AVAILABLE
1015	7-Mar-2021	BAGALKOT	110	110/11KV, HV1	SOUDATTI_110	9:08	16:42	7:34	LINE CLEAR AVAILABLE
1016	7-Mar-2021	BAGALKOT	110	110/11KV, HV3	SOUDATTI_110	10:04	16:58	6:54	LINE CLEAR AVAILABLE
1017	7-Mar-2021	BAGALKOT	110	SOUDATTI- ENERCON1	SOUDATTI_110	9:59	19:55	9:56	LINE CLEAR AVAILABLE
1018	7-Mar-2021	BAGALKOT	110	SOUDATTI- ENERCON2	SOUDATTI_110	9:59	19:55	9:56	LINE CLEAR AVAILABLE
1019	7-Mar-2021	BAGALKOT	110	MKHUBLI220- MKHUBLI2	STATION NOT AFFECTED MKHUBLI_220	9:23	13:29	4:06	LINE CLEAR AVAILABLE
1020	7-Mar-2021	BAGALKOT	110	110/33KV, HV3	MACHE_110, ASHOK IRON PLANT_33, AKP_33	10:43	11:50	1:07	LINE CLEAR AVAILABLE
1021	7-Mar-2021	BAGALKOT	110	110/33KV, HV4	MACHE_110	8:24	17:49	9:25	LINE CLEAR AVAILABLE
1022	7-Mar-2021	BAGALKOT	110	110/11KV, HV2	KUDACHI_110	18:38	19:03	0:25	TRANSFORMER FAULT
1023	7-Mar-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	7:27	17:21	9:54	LINE CLEAR AVAILABLE
1024	7-Mar-2021	BAGALKOT	220	NARENDRA- KANABARGI1 (BELGAUM1)	NARENDRA_220	12:41	15:37	2:56	LINE CLEAR AVAILABLE
1025	7-Mar-2021	BENGALURU	66	HV2	AMAR JYOTHI	23:00	23:40	00:40	TRANSFORMER FAULT
1026	7-Mar-2021	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	15:17	15:28	00:11	LOAD CHANGE OVER
1027	7-Mar-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	18:18	18:35	00:17	LOAD CHANGE OVER
1028	7-Mar-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	23:19	23:48	00:29	LINE FAULT
1029	7-Mar-2021	BENGALURU	220	HV2	BIDADI 220	23:19	23:36	00:17	TRANSFORMER FAULT
1030	7-Mar-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	09:57	10:05	00:08	LOAD CHANGE OVER
1031	7-Mar-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	14:50	14:58	00:08	LOAD CHANGE OVER
1032	7-Mar-2021	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	15:25	15:43	00:18	LOAD CHANGE OVER
1033	7-Mar-2021	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	18:00	18:05	00:05	LOAD CHANGE OVER
1034	7-Mar-2021	BENGALURU	220	HAL 220 - HOODY 2	NO STATION AFFECTED	11:24	16:28	05:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1035	7-Mar-2021	BENGALURU	220	HAL 220 - HOODY 1	NO STATION AFFECTED	15:24	17:32	02:08	LINE CLEAR AVOIDED
1036	7-Mar-2021	BENGALURU	66	HV2	HAL 220	01:44	02:15	00:31	TRANSFORMER FAULT
1037	7-Mar-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	21:08	21:23	00:15	MAIN SUPPLY FAILURE
1038	7-Mar-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	22:04	22:07	00:03	LOAD CHANGE OVER
1039	7-Mar-2021	BENGALURU	220	HOODY 400 - HAL 2	NO STATION AFFECTED	11:24	12:54	01:30	LINE FAULT
1040	7-Mar-2021	BENGALURU	220	HOODY 400 - HAL 2	NO STATION AFFECTED	12:54	16:29	03:35	LINE FAULT
1041	7-Mar-2021	BENGALURU	220	HOODY 400 - HAL 1	NO STATION AFFECTED	15:24	16:29	01:05	LINE CLEAR AVOIDED
1042	7-Mar-2021	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	15:20	17:07	01:47	MAIN SUPPLY FAILURE
1043	7-Mar-2021	BENGALURU	66	HV1	VIJAYANAGARA	11:34	14:32	02:58	LINE CLEAR AVOIDED
1044	7-Mar-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	10:13	10:16	00:03	LINE CLEAR AVOIDED
1045	7-Mar-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	13:51	14:07	00:16	LINE CLEAR AVOIDED
1046	7-Mar-2021	BENGALURU	66	HV2	TELECOM LAYOUT	07:14	07:31	00:17	TRANSFORMER FAULT
1047	7-Mar-2021	BENGALURU	66	JIGANI - JIGANI 220	JIGANI	14:42	14:50	00:08	LOAD CHANGE OVER
1048	7-Mar-2021	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	21:08	22:00	00:51	LINE FAULT
1049	7-Mar-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:03	12:12	00:09	LINE FAULT
1050	7-Mar-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	02:14	02:22	00:08	LINE FAULT
1051	7-Mar-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	08:18	08:27	00:09	LINE FAULT
1052	7-Mar-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	06:45	06:59	00:14	LINE FAULT
1053	7-Mar-2021	BENGALURU	66	JIGANI 66 - SOMANAHALLI 220	JIGANI 66	10:43	10:57	00:13	LOAD CHANGE OVER
1054	7-Mar-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:06	17:29	00:23	LINE FAULT
1055	7-Mar-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	06:39	06:53	00:14	LINE FAULT
1056	7-Mar-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	20:31	20:36	00:05	LOAD CHANGE OVER
1057	7-Mar-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	16:10	16:14	00:04	LINE FAULT
1058	7-Mar-2021	BENGALURU	66	HV1	SURYANAGAR	09:50	17:04	07:14	LINE CLEAR AVOIDED
1059	7-Mar-2021	BENGALURU	66	HV2	TEMAGONDALU	10:35	10:55	00:20	LINE CLEAR AVOIDED
1060	7-Mar-2021	BENGALURU	66	HV1	TEMAGONDALU	09:35	09:40	00:05	LINE CLEAR AVOIDED
1061	7-Mar-2021	BENGALURU	66	HV1	MAASTHI	15:11	15:14	00:02	TRANSFORMER FAULT
1062	7-Mar-2021	BENGALURU	66	HV2	MAASTHI	21:12	21:16	00:04	TRANSFORMER FAULT
1063	7-Mar-2021	BENGALURU	66	HV1	GUDIBAND3E	12:57	13:00	00:03	LINE CLEAR AVOIDED
1064	7-Mar-2021	BENGALURU	66	HV2	GUDIBAND3E	11:56	11:58	00:02	LINE CLEAR AVOIDED
1065	7-Mar-2021	BENGALURU	66	HV2	DODDABELAVANGALA	01:20	01:33	00:13	TRANSFORMER FAULT
1066	7-Mar-2021	BENGALURU	66	HV1	DEVANAHALLI	19:39	20:00	00:20	TRANSFORMER FAULT
1067	7-Mar-2021	BENGALURU	66	HV1	KIADB DB PURA 220	10:15	16:37	06:22	LINE CLEAR AVOIDED
1068	7-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
1069	7-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
1070	7-Mar-2021	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATION AFFECTED	13:50 (6 MAR 2021)			LINE OPEN,LINE FAULT
1071	7-Mar-2021	GULBARGA	220	LINGAPUR-BMMISPAT	BMMISPAT_220	14:43	16:57	02:14	LINE FAULT
1072	7-Mar-2021	GULBARGA	220	HV2	ITTAGI_220	14:45	15:15	00:30	TRANSFORMER FAULT
1073	7-Mar-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_IPP,UGARSUGAR_IPP	23:08	23:16	00:08	LINE FAULT
1074	7-Mar-2021	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110,MANVI_110	03:45	03:55	00:10	LINE FAULT
1075	7-Mar-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	11:41	11:50	00:09	LINE FAULT
1076	7-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	SHAHAPUR_110	00:34	00:43	00:09	LINE FAULT
1077	7-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	SHAHAPUR_110	18:45	18:50	00:05	LINE FAULT
1078	7-Mar-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	SHAHAPUR_110	21:41	21:48	00:07	LINE FAULT
1079	7-Mar-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRRAMNAGAR_110,MALLAPUR A_110	05:54	06:04	00:10	LINE FAULT
1080	7-Mar-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRRAMNAGAR_110,MALLAPUR A_110	15:15	15:23	00:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1081	7-Mar-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADON A_110,SRERAMNAGAR_110,MALLAPUR A_110	15:02	15:12	00:10	LINE FAULT
1082	7-Mar-2021	GULBARGA	110	FARTHABAD-GULBARGASOUTH	GULBARGA_SOUTH	17:40	18:25	00:45	LINE CLEAR AVAILED
1083	7-Mar-2021	GULBARGA	110	HV1	MASKI_110	18:22	19:18	00:56	TRANSFORMER FAULT
1084	7-Mar-2021	GULBARGA	110	SINDHANOOR_MASKI	MASKI_110	19:56	20:18	00:22	MAIN SUPPLY FAILURE
1085	7-Mar-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1086	7-Mar-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1087	7-Mar-2021	HASSAN	220	CRPATNA2-HSN400	CRPATNA_220	09:39	13:00	03:21	LINE CLEAR AVAILED
1088	7-Mar-2021	HASSAN	220	HASSN220-SHANTHIGRAMA	HASSAN_220	09:34	16:14	06:40	LINE FAULT
1089	7-Mar-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	09:21	09:25	00:04	LINE FAULT
1090	7-Mar-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	09:41	09:45	00:04	LINE FAULT
1091	7-Mar-2021	HASSAN	220	VARAHI-KEMAR3	varahi_gen	05:49	17:43	11:54	NFBC ISSUED
1092	7-Mar-2021	HASSAN	110	HV2	ESSUR_110	16:34	17:20	00:46	LINE CLEAR AVAILED
1093	7-Mar-2021	HASSAN	110	HV1	PUTTUR_110	08:52	08:56	00:04	TRANSFORMER FAULT
1094	7-Mar-2021	HASSAN	66	HV1	BAGUR_66	10:30	14:47	04:17	MAIN SUPPLY FAILURE
1095	7-Mar-2021	HASSAN	66	HV2	BAGUR_66	10:30	14:47	04:17	MAIN SUPPLY FAILURE
1096	7-Mar-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	10:30	14:44	04:14	MAIN SUPPLY FAILURE
1097	7-Mar-2021	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	10:30	14:43	04:13	MAIN SUPPLY FAILURE
1098	7-Mar-2021	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	10:29	14:35	04:06	LINE CLEAR AVAILED
1099	7-Mar-2021	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	10:29	14:35	04:06	LINE CLEAR AVAILED
1100	7-Mar-2021	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	10:29	14:40	04:11	LINE CLEAR AVAILED
1101	7-Mar-2021	HASSAN	66	HV1	CHANNARAYAPATNA_66	10:29	14:36	04:07	LINE CLEAR AVAILED
1102	7-Mar-2021	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:29	14:37	04:08	LINE CLEAR AVAILED
1103	7-Mar-2021	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	10:28	14:41	04:13	LINE CLEAR AVAILED
1104	7-Mar-2021	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	10:29	19:29	09:00	LINE CLEAR AVAILED
1105	7-Mar-2021	HASSAN	66	HV1	RAMPURA_66	10:30	14:47	04:17	MAIN SUPPLY FAILURE
1106	7-Mar-2021	HASSAN	66	HV2	RAMPURA_66	10:30	14:47	04:17	MAIN SUPPLY FAILURE
1107	7-Mar-2021	HASSAN	66	HV1	S.BELAGOLA_66	06:54	07:08	00:14	TRANSFORMER FAULT
1108	7-Mar-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	13:00	13:35	00:35	LINE CLEAR AVAILED
1109	7-Mar-2021	HASSAN	66	HV1	SINGAPURA_66	08:27	08:50	00:23	HAND TRIPPED
1110	7-Mar-2021	HASSAN	66	HV2	SINGAPURA_66	08:27	08:50	00:23	HAND TRIPPED
1111	7-Mar-2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:40	14:10	03:30	LINE CLEAR AVAILED
1112	7-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	7:06	21:18	14:12	LINE CLEAR AVAILED
1113	7-Mar-2021	MYSURU	66	HV1	K_HONNALGERE_66	14:41	14:48	0:07	MAIN SUPPLY FAILURE
1114	7-Mar-2021	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	14:28	14:42	0:14	LINE FAULT
1115	7-Mar-2021	MYSURU	66	HV1	KOPPA_66	9:56	10:18	0:22	HAND TRIPPED
1116	7-Mar-2021	MYSURU	66	HV1	KOPPA_66	17:00	17:26	0:26	MAIN SUPPLY FAILURE
1117	7-Mar-2021	MYSURU	66	HV1	KOPPA_66	21:03	21:15	0:12	MAIN SUPPLY FAILURE
1118	7-Mar-2021	MYSURU	66	HV2	KOPPA_66	9:56	17:27	7:31	LINE CLEAR AVAILED
1119	7-Mar-2021	MYSURU	66	HV2	KOPPA_66	21:03	21:15	0:12	MAIN SUPPLY FAILURE
1120	7-Mar-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	8:00	8:04	0:04	LINE FAULT
1121	7-Mar-2021	MYSURU	66	HV1	NAGAMANGALA_66	11:28	11:30	0:01	TRANSFORMER FAULT
1122	7-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	12:19	18:04	5:44	LINE CLEAR AVAILED
1123	7-Mar-2021	MYSURU	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	6:00	12:40	6:40	LINE CLEAR AVAILED
1124	7-Mar-2021	MYSURU	220	HV1	TUBINAKERE_220	10:20	16:03	5:43	LINE CLEAR AVAILED
1125	7-Mar-2021	MYSURU	220	HV2	TUBINAKERE_220	10:20	18:11	7:51	LINE CLEAR AVAILED
1126	7-Mar-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	21:02	21:09	0:06	HAND TRIPPED
1127	7-Mar-2021	MYSURU	66	HV5	SFCSHIVA_66	13:06 (06/03/2021)	2:01 (07/03/2021)	12:54 HRS	TRANSFORMER CHARGED
1128	7-Mar-2021	MYSURU	220	HV1	HOOTAGALLY_220	12:23 (06/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1129	7-Mar-2021	MYSURU	66	VIJAYANAGARA-BANNIMANTAP	NO STATIONS EFFECTED	19:22 (06/03/2021)			LINE OPEN, LINE CLEAR AVOIDED
1130	7-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVOIDED
1131	7-Mar-2021	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	12:05	17:34	5:29	LOAD CURTAILMENT
1132	7-Mar-2021	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	16:17	16:35	0:17	LINE FAULT
1133	7-Mar-2021	TUMKUR	66	TR-1	BALENAHALI_66	8:05	8:31	0:25	LINE CLEAR AVOIDED
1134	7-Mar-2021	TUMKUR	66	BALENAHALI-CHITRADURGA	BALENAHALI_66	8:05	8:31	0:25	LINE CLEAR AVOIDED
1135	7-Mar-2021	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	16:17	16:35	0:17	LINE FAULT
1136	7-Mar-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	13:04	17:03	3:58	LINE CLEAR AVOIDED
1137	7-Mar-2021	TUMKUR	66	TR-3	HOLALKERE_66	15:03	15:07	0:04	TRANSFORMER FAULT
1138	7-Mar-2021	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:18	6:28	0:10	LINE FAULT
1139	7-Mar-2021	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:53	10:04	0:11	LINE FAULT
1140	7-Mar-2021	TUMKUR	66	TR-1	KATTIGE_66	6:12	6:45	0:33	LINE CLEAR AVOIDED
1141	7-Mar-2021	TUMKUR	66	TR-1	KATTIGE_66	22:02	22:07	0:04	TRANSFORMER FAULT
1142	7-Mar-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:13	8:32	0:18	LINE FAULT
1143	7-Mar-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:07	10:32	0:25	LINE FAULT
1144	7-Mar-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:38	14:28	1:50	LINE CLEAR AVOIDED
1145	7-Mar-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:52	15:06	0:14	LINE FAULT
1146	7-Mar-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:07	23:40	0:33	LINE CLEAR AVOIDED
1147	7-Mar-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	8:13	8:28	0:15	LINE FAULT
1148	7-Mar-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	10:07	10:29	0:22	LINE FAULT
1149	7-Mar-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:46	14:55	0:09	LINE FAULT
1150	8-Mar-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
1151	8-Mar-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
1152	8-Mar-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
1153	8-Mar-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
1154	8-Mar-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
1155	8-Mar-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
1156	8-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
1157	8-Mar-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
1158	8-Mar-2021	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1159	8-Mar-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1160	8-Mar-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	10:47 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED
1161	8-Mar-2021	BAGALKOT	220	CHIKKODI -BELGAUM 1	STATION NOT AFFECTED CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN, LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1162	8-Mar-2021	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1163	8-Mar-2021	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1164	8-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1165	8-Mar-2021	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
1166	8-Mar-2021	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	16:52 (25.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
1167	8-Mar-2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	16:57 (03.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1168	8-Mar-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:07 (05.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1169	8-Mar-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1170	8-Mar-2021	BAGALKOT	220	220/110KV, HV2, LV2	CHIKKODI_220	10:36 (06.03.2021)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
1171	8-Mar-2021	BAGALKOT	220	HAVERI-NARENDRA 1	HAVERI_220	17:01 (06.03.2021)			LINE OPEN, LINE CLEAR AVOIDED
1172	8-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1173	8-Mar-2021	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1174	8-Mar-2021	BAGALKOT	220	NARENDRA- HAVERI1	NARENDRA_220	14:45 (06.03.2021)			LINE OPEN, LINE FAULT
1175	8-Mar-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	22:16	22:25	0:09	LINE FAULT
1176	8-Mar-2021	BAGALKOT	110	SIRGUPPI(KATARAKI)-BILAGI	BILAGI_110	12:18	12:22	0:04	HAND TRIPPED
1177	8-Mar-2021	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	06:36	09:29	2:53	LINE CLEAR AVOIDED
1178	8-Mar-2021	BAGALKOT	110	BELGAUM-SANKESHWAR	SANKESHWAR_110	17:01	17:11	0:10	LINE FAULT
1179	8-Mar-2021	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	07:55	07:57	0:02	TRANSFORMER FAULT
1180	8-Mar-2021	BAGALKOT	110	110/11KV,HV 1	HATTARAGI_110	18:55 (08.03.2021)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
1181	8-Mar-2021	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	13:47	14:11	0:24	HAND TRIPPED
1182	8-Mar-2021	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	17:26	17:39	0:13	HAND TRIPPED
1183	8-Mar-2021	BAGALKOT	110	HUKKERI-VS	HUKKERI_110	17:26	17:34	0:08	LINE FAULT
1184	8-Mar-2021	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	17:55	18:01	0:06	HAND TRIPPED
1185	8-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA1&2	AMBEWADI_220	8:23	17:31	9:08	NFBC ISSUED
1186	8-Mar-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	18:16	19:04	0:48	HAND TRIPPED
1187	8-Mar-2021	BAGALKOT	110	ITANAL-SULTANPUR(HIDIKAL)	SULTANPUR_110	11:13	16:49	5:36	LINE CLEAR AVOIDED
1188	8-Mar-2021	BAGALKOT	110	110/11KV,HV2	KALGHATGI_110	13:01	13:13	0:12	TRANSFORMER FAULT
1189	8-Mar-2021	BAGALKOT	110	110/11KV,HV2	KALGHATGI_110	13:33	13:40	0:07	TRANSFORMER FAULT
1190	8-Mar-2021	BAGALKOT	220	220/110KV,HV3	MAHALINGAPUR_220	4:26	4:27	0:01	TRANSFORMER FAULT
1191	8-Mar-2021	BAGALKOT	110	220/110KV, LV3	MAHALINGAPUR_220	4:26	4:33	0:07	TRANSFORMER FAULT
1192	8-Mar-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	08:53	08:59	0:06	TRANSFORMER FAULT
1193	8-Mar-2021	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	14:47	14:48	0:01	TRANSFORMER FAULT
1194	8-Mar-2021	BAGALKOT	110	HUBLI220- TARIHAL	TARIHAL_110	10:55	11:03	0:08	HAND TRIPPED
1195	8-Mar-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI1	SOUDATTI_110	11:22	11:36	0:14	LINE CLEAR AVOIDED
1196	8-Mar-2021	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	10:18	10:42	0:24	LINE CLEAR AVOIDED
1197	8-Mar-2021	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110, HATTARGI_110	17:14	17:23	0:09	HAND TRIPPED
1198	8-Mar-2021	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33, JATRAT_33	13:38	15:07	1:29	LINE CLEAR AVOIDED
1199	8-Mar-2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	8:22	17:30	9:08	LINE CLEAR AVOIDED
1200	8-Mar-2021	BAGALKOT	110	BPCL- NARAGUND	NARAGUND_110	22:42 (08.03.2021)			LINE OPEN, LINE FAULT
1201	8-Mar-2021	BAGALKOT	110	110/11KV, HV2	MUDEBIHAL_110	8:33	08:49	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1202	8-Mar-2021	BAGALKOT	110	BAGEWADI1- MAMADAPUR(B)	MAMADAPUR(B)_110	22:15	22:36	0:21	LINE FAULT
1203	8-Mar-2021	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	16:12	16:15	00:03	MAIN SUPPLY FAILURE
1204	8-Mar-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	16:12	16:22	00:10	MAIN SUPPLY FAILURE
1205	8-Mar-2021	BENGALURU	66	A STATION 220 - KANTEERAVA	KANTEERAVA STADIUM	16:12	16:23	00:11	MAIN SUPPLY FAILURE
1206	8-Mar-2021	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	08:47	09:17	00:30	LINE FAULT
1207	8-Mar-2021	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	12:05	12:10	00:05	LINE CLEAR AVAILED
1208	8-Mar-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	13:20	13:23	00:03	LOAD CHANGE OVER
1209	8-Mar-2021	BENGALURU	220	KANAKAPURA 220 - BWSSB 220	KANAKAPURA 220	16:38	17:04	00:26	LINE FAULT
1210	8-Mar-2021	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	16:38	17:10	00:32	LINE CLEAR AVAILED
1211	8-Mar-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	16:38	17:10	00:32	LINE CLEAR AVAILED
1212	8-Mar-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	16:38	17:10	00:32	LINE CLEAR AVAILED
1213	8-Mar-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	16:38	17:10	00:32	LINE CLEAR AVAILED
1214	8-Mar-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:38	17:10	00:32	LINE CLEAR AVAILED
1215	8-Mar-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	16:38	17:10	00:32	LINE CLEAR AVAILED
1216	8-Mar-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	06:59	07:10	00:11	LINE FAULT
1217	8-Mar-2021	BENGALURU	220	NRS 220 - SRS 220	NRS 220	16:13	16:27	00:14	MAIN SUPPLY FAILURE
1218	8-Mar-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	16:13	16:30	00:17	MAIN SUPPLY FAILURE
1219	8-Mar-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	16:13	16:30	00:17	MAIN SUPPLY FAILURE
1220	8-Mar-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1	NO STATION AFFECTED	15:40	16:25	00:45	LINE FAULT
1221	8-Mar-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	NO STATION AFFECTED	16:13	16:24	00:11	LINE FAULT
1222	8-Mar-2021	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	16:13	16:27	00:14	LINE FAULT
1223	8-Mar-2021	BENGALURU	220	HV5	SRS PEENYA 220	16:13	16:48	00:35	TRANSFORMER FAULT
1224	8-Mar-2021	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	NO STATION AFFECTED	16:13	16:51	00:38	LINE FAULT
1225	8-Mar-2021	BENGALURU	66	V G DODDI - SOMANAHALLI 220	V G DODDI	13:50	16:30	02:40	LINE CLEAR AVAILED
1226	8-Mar-2021	BENGALURU	66	HV2	VIJAYANAGARA	16:12	16:41	00:29	MAIN SUPPLY FAILURE
1227	8-Mar-2021	BENGALURU	66	HV1	HUKUNDA	14:55	15:00	00:05	TRANSFORMER FAULT
1228	8-Mar-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:58	22:11	00:12	LINE FAULT
1229	8-Mar-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:17	12:36	00:18	LINE CLEAR AVAILED
1230	8-Mar-2021	BENGALURU	66	HV1	HUKUNDA	14:55	15:00	00:04	TRANSFORMER FAULT
1231	8-Mar-2021	BENGALURU	220	HV2	BIDADI 220	20:11(08/03/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1232	8-Mar-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN, LINE FAULT
1233	8-Mar-2021	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	13:08(06/03/2021)			LINE OPEN, LINE FAULT
1234	8-Mar-2021	GULBARGA	220	LINGAPUR-BMMISPAT	BMMISPAT_220	09:30	18:08	08:38	LINE CLEAR AVAILED
1235	8-Mar-2021	GULBARGA	110	GABUR-RAICHUR	GABBUR_110, DEODURGA_110	11:40	12:00	00:20	LINE FAULT
1236	8-Mar-2021	GULBARGA	110	SINDHNOOR-RAICHUR2(IDLE LINE)	ADAVIAMARESHWARA_110	20:15	20:30	00:15	LINE FAULT
1237	8-Mar-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_IPP, UGARSUGAR_IPP	20:38	20:46	00:08	LINE FAULT
1238	8-Mar-2021	GULBARGA	110	HV1	NIRNA_110	16:20	16:25	00:05	TRANSFORMER FAULT
1239	8-Mar-2021	GULBARGA	110	HV1	NIRNA_110	19:30	19:35	00:05	TRANSFORMER FAULT
1240	8-Mar-2021	GULBARGA	110	HV1	VALKMADINI_10	18:25	19:25	01:00	LINE CLEAR AVAILED
1241	8-Mar-2021	GULBARGA	66	HV1	HAMPASAGAR_66	07:33	07:38	00:05	TRANSFORMER FAULT
1242	8-Mar-2021	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1243	8-Mar-2021	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
1244	8-Mar-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:55	12:48	02:53	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1245	8-Mar-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:43	18:15	07:32	LINE CLEAR AVAILED
1246	8-Mar-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	09:56	12:48	02:52	LINE CLEAR AVAILED
1247	8-Mar-2021	HASSAN	110	HV3	ALKOLA_110	16:09	16:12	00:03	TRANSFORMER FAULT
1248	8-Mar-2021	HASSAN	110	HV1	ESSUR_110	10:17	10:49	00:32	LINE CLEAR AVAILED
1249	8-Mar-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:18	14:05	00:47	MAIN SUPPLY FAILURE
1250	8-Mar-2021	HASSAN	110	HV1	KONAJE_110	07:57	08:01	00:04	HAND TRIPPED
1251	8-Mar-2021	HASSAN	110	HV1	KONAJE_110	14:09	14:14	00:05	HAND TRIPPED
1252	8-Mar-2021	HASSAN	110	HV2	KONAJE_110	07:57	08:02	00:05	HAND TRIPPED
1253	8-Mar-2021	HASSAN	110	HV2	KONAJE_110	14:09	14:15	00:06	HAND TRIPPED
1254	8-Mar-2021	HASSAN	110	HV3	KONAJE_110	07:57	08:02	00:05	HAND TRIPPED
1255	8-Mar-2021	HASSAN	110	HV3	KONAJE_110	14:09	14:14	00:05	HAND TRIPPED
1256	8-Mar-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	12:52	13:58	01:06	LINE FAULT
1257	8-Mar-2021	HASSAN	110	HV5	MRSMSG_220	17:19	17:23	00:04	HAND TRIPPED
1258	8-Mar-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	12:36	12:41	00:05	LINE FAULT
1259	8-Mar-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	08:02	14:07	06:05	NFBC ISSUED
1260	8-Mar-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	14:17	14:33	00:16	LINE FAULT
1261	8-Mar-2021	HASSAN	66	CRPATNA-HNPURA	CRPATNA_66	06:48	07:25	00:37	LINE FAULT
1262	8-Mar-2021	HASSAN	66	HV1	ALDUR_66	11:12	11:33	00:21	LINE CLEAR AVAILED
1263	8-Mar-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	11:45	19:12	07:27	NFBC ISSUED
1264	8-Mar-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:42	19:28	07:46	NFBC ISSUED
1265	8-Mar-2021	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALY_66	03:20	03:26	00:06	LINE FAULT
1266	8-Mar-2021	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	06:50	07:10	00:20	MAIN SUPPLY FAILURE
1267	8-Mar-2021	HASSAN	66	HNPUR2-CRPTN	HOLENARASIPURA_220	06:48	07:09	00:21	LINE FAULT
1268	8-Mar-2021	HASSAN	66	HV1	SAKLESHUPURA_66	11:58	12:34	00:36	LINE CLEAR AVAILED
1269	8-Mar-2021	HASSAN	66	HV1	SINGAPURA_66	06:50	07:33	00:43	LINE CLEAR AVAILED
1270	8-Mar-2021	HASSAN	66	HV2	SINGAPURA_66	06:50	07:33	00:43	LINE CLEAR AVAILED
1271	8-Mar-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:43	12:48	00:05	MAIN SUPPLY FAILURE
1272	8-Mar-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	14:57	15:12	00:15	LINE FAULT
1273	8-Mar-2021	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	11:42	20:28	08:46	LINE CLEAR AVAILED
1274	8-Mar-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:41	19:27	07:46	LINE CLEAR AVAILED
1275	8-Mar-2021	MYSURU	66	HV2	BOOKANAKERE_66	15:25	15:33	0:08	TRANSFORMER FAULT
1276	8-Mar-2021	MYSURU	66	CR NAGARA-HONNAHALI	HONNALLY_MYS_66 ATTIGULIPURA_66	10:16	14:06	3:49	NFBC ISSUED
1277	8-Mar-2021	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	15:55	15:57	0:02	LINE FAULT
1278	8-Mar-2021	MYSURU	66	HV1	HOOTAGALLY_220	17:14(8.3.21)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1279	8-Mar-2021	MYSURU	66	HV2	HOOTAGALLY_220	16:56	17:14	0:18	LINE CLEAR AVAILED
1280	8-Mar-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	7:03	20:18	13:15	LINE CLEAR AVAILED
1281	8-Mar-2021	MYSURU	66	HV1	NAGAMANGALA_66	8:15	8:18	0:03	TRANSFORMER FAULT
1282	8-Mar-2021	MYSURU	66	HV5	SFCHIVA_66	6:18	14:37	8:19	LINE CLEAR AVAILED
1283	8-Mar-2021	MYSURU	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	11:40	11:45	0:05	LOAD CURTAILMENT
1284	8-Mar-2021	MYSURU	66	TUBINKERE-NAGAMGALA 2	SHIVALLY_66	10:01	10:03	0:01	LOAD CURTAILMENT
1285	8-Mar-2021	MYSURU	66	MADHUVANAHALLI-DODDINADUWADI	NO STATIONS EFFECTED	11:42	12:56	1:14	NFBC ISSUED
1286	8-Mar-2021	MYSURU	66	DODDINADUWADI-KOTTANUR	DODDINADUVADI_66	12:15	12:55	0:40	NFBC ISSUED
1287	8-Mar-2021	MYSURU	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66	10:01	10:17	0:16	LINE FAULT
1288	8-Mar-2021	MYSURU	220	HV1	HOOTAGALLY_220	12:23 (06/03/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1289	8-Mar-2021	MYSURU	66	VIJAYANAGARA-BANNIMANTAP	NO STATIONS EFFECTED	19:22 (06/03/2021)	10:05 (08/03/2021)	38:43 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1290	8-Mar-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
1291	8-Mar-2021	TUMKUR	110	SAMPIGE- RENEWIND_IPP_110	RENEW_WIND_IPP_110	18:54:23 (08.03.2021)			LINE OPEN, LINE CLEAR AVAILED
1292	8-Mar-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:32	13:36	2:03	LINE CLEAR AVAILED
1293	8-Mar-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	11:33	13:36	2:03	LINE CLEAR AVAILED
1294	8-Mar-2021	TUMKUR	110	TR-1	KALLUR_110	9:37	10:12	0:34	MAIN SUPPLY FAILURE
1295	8-Mar-2021	TUMKUR	110	TR-1	KALLUR_110	12:06	12:10	0:03	MAIN SUPPLY FAILURE
1296	8-Mar-2021	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	12:06	12:10	0:03	MAIN SUPPLY FAILURE
1297	8-Mar-2021	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	12:25	12:38	0:13	LINE CLEAR AVAILED
1298	8-Mar-2021	TUMKUR	110	TR-1	SHETYKERE_110	18:09	18:13	0:04	TRANSFORMER FAULT
1299	8-Mar-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	12:17	12:27	0:10	LINE FAULT
1300	8-Mar-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	9:20	9:57	0:37	LINE CLEAR AVAILED
1301	8-Mar-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:48	18:40	4:51	LINE CLEAR AVAILED
1302	8-Mar-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	8:47	14:23	5:36	LINE CLEAR AVAILED
1303	8-Mar-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:46	18:57	0:10	LINE FAULT
1304	8-Mar-2021	TUMKUR	66	TR-3	HARIYABBE_66	13:59	14:06	0:07	TRANSFORMER FAULT
1305	8-Mar-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	12:47	17:22	4:35	LINE CLEAR AVAILED
1306	8-Mar-2021	TUMKUR	66	TR-1	KUKKAWADA_66	13:41	14:24	0:42	LINE CLEAR AVAILED
1307	8-Mar-2021	TUMKUR	66	TR-1	KUKKAWADA_66	20:23	21:08	0:44	LINE CLEAR AVAILED
1308	8-Mar-2021	TUMKUR	66	TR-2	KUKKAWADA_66	11:31	13:44	2:12	LINE CLEAR AVAILED
1309	8-Mar-2021	TUMKUR	66	TR-1	KUNDUR_66	11:20	11:28	0:07	LINE CLEAR AVAILED
1310	8-Mar-2021	TUMKUR	66	TR-1	MAYAKONDA_66	13:55	14:42	0:47	TRANSFORMER FAULT