

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 17.11.20 TO 23.11.20

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	17-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	17-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
3	17-Nov-20	BAGALKOT	110	110/11KV, HV1	GUTTAL_110	6:20	7:20	1:00	TRANSFORMER FAULT
4	17-Nov-20	BAGALKOT	110	110/33KV, HV3	GADAG_110, MALSAMUDRA_33, NAGAVI_33, PIONEER_33	15:06	15:50	0:44	LINE CLEAR AVOIDED
5	17-Nov-20	BAGALKOT	110	220/110KV, LV1	NO STATION AFFECTED MK HUBLI_220	3:38	13:26	9:48	LINE CLEAR AVOIDED
6	17-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED
7	17-Nov-20	BAGALKOT	110	BIDNAL220- ANNIGERI	NO STATION AFFECTED ANNIGERI_110	11:04	14:53	3:49	LINE CLEAR AVOIDED
8	17-Nov-20	BAGALKOT	110	DAMBAL- MUNDARGI1	MUNDARGI_110	22:54	23:33	0:39	LINE FAULT
9	17-Nov-20	BAGALKOT	110	DAMBAL- MUNDARGI2	MUNDARGI_110	23:12	23:29	0:17	HAND TRIPPED
10	17-Nov-20	BAGALKOT	110	ENERCON- DAMBAL	DAMBAL_110	23:12	23:40	0:28	HAND TRIPPED
11	17-Nov-20	BAGALKOT	110	GADAG220- DAMBAL	DAMBAL_110	22:54	23:22	0:28	LINE FAULT
12	17-Nov-20	BAGALKOT	110	GADAG220- SAMBAPUR ROAD	SAMBAPUR ROAD_110	22:54	23:20	0:26	LINE FAULT
13	17-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR1	NO STATION AFFECTED GOPANAKOPPA_110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
14	17-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR2	NO STATION AFFECTED GOPANAKOPPA_110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
15	17-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
16	17-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
17	17-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
18	17-Nov-20	BAGALKOT	110	RANEBENNUR- AREMALLAPUR	HONNATTI_110, AREMALLAUR_110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
19	17-Nov-20	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	SIDDAPUR_110	14:02	16:46	2:44	LINE FAULT
20	17-Nov-20	BAGALKOT	110	SIRSI- JOG2	SIRSI_110	15:36	16:23	0:47	LINE CLEAR AVOIDED
21	17-Nov-20	BAGALKOT	110	SUZLON1&2- DAMBAL	DAMBAL_110	23:12	23:38	0:26	HAND TRIPPED
22	17-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
23	17-Nov-20	BAGALKOT	220	220/110KV, HV2&LV2	NO STATION AFFECTED HUBLI_220	8:52	16:34	7:42	LINE CLEAR AVOIDED
24	17-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
25	17-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
26	17-Nov-20	BAGALKOT	220	AMBEWADI- NARENDRA2	NO STATION AFFECTED AMBEWADI_220	12:11	16:41	4:30	LINE CLEAR AVOIDED
27	17-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
28	17-Nov-20	BAGALKOT	220	BELGAUM- CHIKKODI1	NO STATION AFFECTED BELGAUM_220	20:30 (16.11.2020)	7:41 (17.11.2020)	10:34 hrs	LINE CHARGED
29	17-Nov-20	BAGALKOT	220	BELGAUM- NARENDRA1	NO STATION AFFECTED BELGAUM_220	3:20	7:40	4:20	LINE CLEAR AVOIDED
30	17-Nov-20	BAGALKOT	220	HUBLI- ANAND NAGAR	ANAND NAGAR_110	23:27 (17.11.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
31	17-Nov-20	BAGALKOT	220	SHARAVATHY 1-SIRSI	NO STATION AFFECTED SIRSI_220	16:49 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
32	17-Nov-20	BAGALKOT	220	SHARAVATHY 2-SIRSI	NO STATION AFFECTED SIRSI_220	16:50 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
33	17-Nov-20	BENGALURU	66	ANEKAL - YERANDANAHALLI 220	ANEKAL	7:47	9:14	1:27	MAIN SUPPLY FAILURE
34	17-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
35	17-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
36	17-Nov-20	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	15:54	16:00	0:06	MAIN SUPPLY FAILURE
37	17-Nov-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, INFOSYS (EHT)	17:33	17:50	0:17	LINE FAULT
38	17-Nov-20	BENGALURU	66	HV1	KADUGODI	21:12	21:20	0:08	TRANSFORMER FAULT
39	17-Nov-20	BENGALURU	66	HV1	DODDALAHALLI	16:16	17:23	1:07	LINE CLEAR AVOID
40	17-Nov-20	BENGALURU	66	HV1	HUKUNDA	15:26	16:51	1:24	LINE CLEAR AVOID
41	17-Nov-20	BENGALURU	66	HV2	NELAKADRENHALLI	16:25	16:38	0:13	TRANSFORMER FAULT
42	17-Nov-20	BENGALURU	66	HV2	KIADB DB PURA 220	13:00	13:54	0:54	LINE CLEAR AVOID
43	17-Nov-20	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	9:30	9:36	0:06	LOAD CHANGE OVER
44	17-Nov-20	BENGALURU	66	JIGANI 220 - JIGANI	JIGANI,JIGANI LINK ROAD	7:47	9:14	1:27	MAIN SUPPLY FAILURE
45	17-Nov-20	BENGALURU	66	JIGANI 220 - JIGANI	JIGANI,JIGANI LINK ROAD	11:30	11:38	0:08	MAIN SUPPLY FAILURE
46	17-Nov-20	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	7:47	9:14	1:27	MAIN SUPPLY FAILURE
47	17-Nov-20	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	11:30	11:38	0:08	MAIN SUPPLY FAILURE
48	17-Nov-20	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	7:46	8:15	0:29	LINE CLEAR AVOID
49	17-Nov-20	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	7:46	8:15	0:29	LINE CLEAR AVOID
50	17-Nov-20	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	7:46	8:15	0:29	LINE CLEAR AVOID
51	17-Nov-20	BENGALURU	66	KHODAYS 220 - SHOBHA FOREST	SHOBHA FOREST, HENNUR CROSS	7:46	8:15	0:29	LINE CLEAR AVOID
52	17-Nov-20	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	7:46	8:08	0:22	MAIN SUPPLY FAILURE
53	17-Nov-20	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	8:20	8:25	0:05	LOAD CHANGE OVER
54	17-Nov-20	BENGALURU	66	SOMANAHALLI 220 -SUBRAMANYAPURA 66	SUBRAMANYAPURA 66, ISKON	7:45	8:05	0:20	MAIN SUPPLY FAILURE
55	17-Nov-20	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	12:05	12:20	0:15	LINE CLEAR AVOID
56	17-Nov-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	7:45	8:05	0:20	MAIN SUPPLY FAILURE
57	17-Nov-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	7:45	8:05	0:20	MAIN SUPPLY FAILURE
58	17-Nov-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	7:45	8:05	0:20	MAIN SUPPLY FAILURE
59	17-Nov-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	7:45	8:05	0:20	MAIN SUPPLY FAILURE
60	17-Nov-20	BENGALURU	66	SURYANAGAR - YERANDANAHALLI 220	SURYANAGAR	7:47	9:14	1:27	MAIN SUPPLY FAILURE
61	17-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
62	17-Nov-20	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	7:46	8:07	0:21	LINE FAULT
63	17-Nov-20	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	7:47	9:14	1:27	LINE FAULT
64	17-Nov-20	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	11:30	11:36	0:06	LINE CLEAR AVOID
65	17-Nov-20	BENGALURU	220	SUBRAMANYAPURA 220 - SOMANAHALLI 220	SUBRAMANYAPURA 220	7:45	8:05	0:20	LINE CLEAR AVOID
66	17-Nov-20	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	1:45	1:57	0:12	LINE FAULT
67	17-Nov-20	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	2:02	2:10	0:08	LINE FAULT
68	17-Nov-20	GULBARGA	110	HV1	HANUMANAL_110	13:20	13:30	0:10	TRANSFORMER FAULT
69	17-Nov-20	GULBARGA	110	HV2	HATTI_110	14:20	14:56	0:36	LINE CLEAR AVOID
70	17-Nov-20	GULBARGA	110	HV2	HATTI_110	15:50	16:11	0:21	LINE CLEAR AVOID
71	17-Nov-20	GULBARGA	110	HV2	HATTI_110	14:19	14:55	0:36	LINE CLEAR AVOID
72	17-Nov-20	GULBARGA	110	HV2	HATTI_110	15:49	16:10	0:21	LINE CLEAR AVOID
73	17-Nov-20	GULBARGA	110	HV4	YELBURGA_110	20:25	20:37	0:12	TRANSFORMER FAULT
74	17-Nov-20	GULBARGA	110	KUSHTAGI_ILKAL1	ILKAL_110	9:58(15.11.2020)	13:30(17.11.2020)	51:32HRS	LINE CHARGED
75	17-Nov-20	GULBARGA	110	KUSHTAGI_ILKAL2	ILKAL_110	8:28	13:30	5:02	LINE CLEAR AVOID

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	17-Nov-20	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	4:40	4:45	0:05	LINE FAULT
77	17-Nov-20	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	11:35	11:40	0:05	LINE FAULT
78	17-Nov-20	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	12:15	12:23	0:08	LINE FAULT
79	17-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
80	17-Nov-20	GULBARGA	110	SEDAM-RTPS1	SEDAM_220	20:18	20:28	0:10	LINE FAULT
81	17-Nov-20	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, KORWAR_TEMPLE_110, RAJSHREE_CEMENTS,	11:40(17.11.20)			LINE OPEN:LINE CLEAR AVAILED
82	17-Nov-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASGI_110, ASKI_110,UGAR SUGAR IPP	22:36	22:45	0:09	LINE FAULT
83	17-Nov-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110, SANNATHI_110,CORE GREEN SUGAR IPP, NALWAR_110	22:15	22:40	0:25	LINE FAULT
84	17-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
85	17-Nov-20	GULBARGA	400	BTPS-RTPS	RTPS_400	0:13	7:01	6:48	LINE CHARGED
86	17-Nov-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:30 (13.11.2020)	13:30 (17.11.2020)	97:00hrs	LINE CHARGED
87	17-Nov-20	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	20:40	21:10	0:30	LINE FAULT
88	17-Nov-20	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	20:40	21:10	0:30	HAND TRIPPED
89	17-Nov-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	20:40	21:50	1:10	LINE CLEAR AVOIDED
90	17-Nov-20	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	20:40	21:10	0:30	HAND TRIPPED
91	17-Nov-20	HASSAN	66	CRPATNA2-CRPTNA1	CRPATNA_220	20:41	21:00	0:19	LINE FAULT
92	17-Nov-20	HASSAN	66	CRPATNA2-CRPTNA2	CRPATNA_220	20:41	21:00	0:19	LINE FAULT
93	17-Nov-20	HASSAN	66	HV1	CHANNARAYAPATNA_66	20:40	21:15	0:35	HAND TRIPPED
94	17-Nov-20	HASSAN	66	HV1	MATTANAVILE_66	12:10	15:40	3:30	LINE CLEAR AVOIDED
95	17-Nov-20	HASSAN	66	HV1	MOSALEHOSAHALLY_66	22:01	22:25	0:24	HAND TRIPPED
96	17-Nov-20	HASSAN	66	HV2	CHANNARAYAPATNA_66	20:40	21:15	0:35	HAND TRIPPED
97	17-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
98	17-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
99	17-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
100	17-Nov-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	1:45	1:50	0:05	LINE FAULT
101	17-Nov-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:23	13:49	3:26	LINE CLEAR AVOIDED
102	17-Nov-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	10:16	10:21	0:05	LINE FAULT
103	17-Nov-20	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:35	11:15	0:40	LINE CLEAR AVOIDED
104	17-Nov-20	HASSAN	110	HV1	NAVUNDA_110	11:25	12:41	1:16	LINE CLEAR AVOIDED
105	17-Nov-20	HASSAN	110	HV2	NAVUNDA_110	10:44	12:47	2:03	LINE CLEAR AVOIDED
106	17-Nov-20	HASSAN	220	CRPATNA2-HUYGNH	CRPATNA_220	10:34	11:09	0:35	LINE FAULT
107	17-Nov-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:16	11:47	1:31	LINE FAULT
108	17-Nov-20	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	10:31	11:45	1:14	LINE CLEAR AVOIDED
109	17-Nov-20	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	19:28 (16.11.2020)	12:44 (17.11.2020)	17:16hrs	LINE CHARGED
110	17-Nov-20	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	19:28 (16.11.2020)	12:44 (17.11.2020)	17:16hrs	LINE CHARGED
111	17-Nov-20	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	10:31	11:45	1:14	LINE CLEAR AVOIDED
112	17-Nov-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	10:16	11:47	1:31	LINE FAULT
113	17-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:36 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
114	17-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
115	17-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:30 (16.11.2020)	6:56 (17.11.2020)	9:26hrs	LINE CHARGED
116	17-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:49 (17.11.2020)			LINE OPEN:LINE CLEAR AVAILED
117	17-Nov-20	MYSORE	66	CHANDAKAWADI-CR NAGARA	CHANDAKAVADI_66	15:48	17:40	1:51	LINE CLEAR AVAILED
118	17-Nov-20	MYSORE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	7:32	7:37	0:05	LINE FAULT
119	17-Nov-20	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	7:32	7:35	0:03	LINE FAULT
120	17-Nov-20	MYSORE	66	HV1	ARAKERE_66	14:02	16:41	2:38	LINE CLEAR AVAILED
121	17-Nov-20	MYSORE	66	HV1	BANANGADI_66	14:55	15:03	0:07	LINE CLEAR AVAILED
122	17-Nov-20	MYSORE	66	HV1	BANANGADI_66	15:33	17:08	1:34	LINE CLEAR AVAILED
123	17-Nov-20	MYSORE	66	HV1	CHUNCHUNKATTE_66	18:12	18:18	0:06	TRANSFORMER FAULT
124	17-Nov-20	MYSORE	66	HV1	KABHALLY_66	16:00	16:44	0:43	LINE CLEAR AVAILED
125	17-Nov-20	MYSORE	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	8:10	17:42	9:32	LINE CLEAR AVAILED
126	17-Nov-20	MYSORE	66	KADAKOLA-RK NAGARA	NO STATIONS EFFECTED	8:14	18:14	10:00	LINE CLEAR AVAILED
127	17-Nov-20	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	12:06	12:15	0:09	LINE FAULT
128	17-Nov-20	MYSORE	66	KUSHALNAGARA 220-PERIYAPATNA-1	NO STATIONS EFFECTED	17:36	17:44	0:08	LINE FAULT
129	17-Nov-20	MYSORE	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	15:31	15:35	0:03	LINE FAULT
130	17-Nov-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66 BASARALU_66	18:03	18:11	0:07	LINE FAULT
131	17-Nov-20	MYSORE	66	VAJMANGALA-MEGALAPURA	NO STATIONS EFFECTED	14:05	14:23	0:17	LINE FAULT
132	17-Nov-20	MYSORE	220	KADAKOLA-BASTIPURA1	NO STATIONS EFFECTED	10:03	17:09	7:06	LINE CLEAR AVAILED
133	17-Nov-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	6:22	6:39	0:16	LINE FAULT
134	17-Nov-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	1:17	1:26	0:09	LINE FAULT
135	17-Nov-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:24	12:45	0:20	MAIN SUPPLY FAILURE
136	17-Nov-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:25	12:32	0:07	HAND TRIPPED
137	17-Nov-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	20:17	20:28	0:10	LINE FAULT
138	17-Nov-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	22:00	22:09	0:08	LINE FAULT
139	17-Nov-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:59	13:14	0:14	LINE FAULT
140	17-Nov-20	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	6:03	6:17	0:14	LINE FAULT
141	17-Nov-20	TUMKUR	66	NEELAGUNDA 220kv-TELAGE	TELAGE_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	0:55	1:05	0:09	LINE FAULT
142	17-Nov-20	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	12:32	12:40	0:08	MAIN SUPPLY FAILURE
143	17-Nov-20	TUMKUR	66	SOKKE-JAGLUR	JAGALUR_66	17:49	18:20	0:30	LINE FAULT
144	17-Nov-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:19	13:50	0:31	LINE CLEAR AVAILED
145	17-Nov-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	7:53	8:03	0:09	TRANSFORMER FAULT
146	17-Nov-20	TUMKUR	66	TR-3	HARIYABBE_66	10:35	10:55	0:20	TRANSFORMER FAULT
147	17-Nov-20	TUMKUR	66	TR-3	HARIYABBE_66	11:01	11:04	0:02	TRANSFORMER FAULT
148	17-Nov-20	TUMKUR	110	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	6:22	6:39	0:16	LINE FAULT
149	17-Nov-20	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUNSEGHA TTA_110	13:57	15:54	1:57	LINE CLEAR AVAILED
150	17-Nov-20	TUMKUR	110	TR-1	BANDIHALLI_110	16:54	17:08	0:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	17-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
152	17-Nov-20	TUMKUR	110	TR-2	BANDIHALLI_110	3:03:40 AM(14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
153	17-Nov-20	TUMKUR	110	TR-2	SHETYKERE_110	8:02	8:47	0:44	LINE CLEAR AVAILED
154	17-Nov-20	TUMKUR	220	TR-1	HIRIYUR_220	12:15	12:28	0:12	TRANSFORMER FAULT
155	18-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
156	18-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
157	18-Nov-20	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	11:25	12:11	0:46	LINE CLEAR AVAILED
158	18-Nov-20	BAGALKOT	110	110/11KV, HV2	PH COMPOUND_110	16:23	17:15	0:52	LINE CLEAR AVAILED
159	18-Nov-20	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	10:00	10:15	0:15	TRANSFORMER FAULT
160	18-Nov-20	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	0:59	1:02	0:03	TRANSFORMER FAULT
161	18-Nov-20	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	11:09	12:55	1:46	LINE CLEAR AVAILED
162	18-Nov-20	BAGALKOT	110	ANKOLA- KUMATA(L2)	KUMATA_110	13:15	16:39	3:24	LINE FAULT
163	18-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED
164	18-Nov-20	BAGALKOT	110	GHATAPRABHA-NAGARMUNAVALLI(KABBUR)	NAGAMUNAVALLI_110 (KABBUR_110)	7:09	7:17	0:08	LINE FAULT
165	18-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR1	NO STATION AFFECTED GOPANAKOPPA_110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
166	18-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR2	NO STATION AFFECTED GOPANAKOPPA_110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
167	18-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
168	18-Nov-20	BAGALKOT	110	HUBLI- ANAND NAGAR	ANAND NAGAR_110	23:27 (17.11.2020)	1:16 (18.11.2020)	1:49hrs	LINE CHARGED
169	18-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
170	18-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
171	18-Nov-20	BAGALKOT	110	RANEBENNUR- AREMALLAPUR	NO STATION AFFECTED HONNATTI_110,AREMALLAUR_110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
172	18-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
173	18-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
174	18-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
175	18-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
176	18-Nov-20	BAGALKOT	220	SHARAVATHY 1-SIRSI	NO STATION AFFECTED SIRSI_220	16:49 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
177	18-Nov-20	BAGALKOT	220	SHARAVATHY 2-SIRSI	NO STATION AFFECTED SIRSI_220	16:50 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
178	18-Nov-20	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	9:25	16:00	6:35	LINE CLEAR AVAILED
179	18-Nov-20	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	11:25	11:34	00:09	LOAD CHANGE OVER
180	18-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
181	18-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
182	18-Nov-20	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	17:30	17:35	00:05	LOAD CHANGE OVER
183	18-Nov-20	BENGALURU	66	HV1	JIGANI LINK ROAD	00:35	00:40	00:05	TRANSFORMER FAULT
184	18-Nov-20	BENGALURU	66	HV1	KOLAR 220	10:02	13:25	03:23	LINE CLEAR AVAILED
185	18-Nov-20	BENGALURU	66	HV1	KUNDANA	12:50	13:05	00:15	LINE CLEAR AVAILED
186	18-Nov-20	BENGALURU	66	HV1	M GOLLAHALLI	08:29	09:30	01:00	LINE CLEAR AVAILED
187	18-Nov-20	BENGALURU	66	HV2	KOLAR 220	10:02	13:25	03:23	LINE CLEAR AVAILED
188	18-Nov-20	BENGALURU	66	HV2	M GOLLAHALLI	14:40	14:45	00:05	LINE CLEAR AVAILED
189	18-Nov-20	BENGALURU	66	HV3	ADUGODI	12:02	12:37	00:35	LINE CLEAR AVAILED
190	18-Nov-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	10:20	11:17	00:57	LINE CLEAR AVAILED
191	18-Nov-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:15	18:20	01:05	LINE CLEAR AVAILED
192	18-Nov-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	10:01	14:05	04:04	LINE CLEAR AVAILED
193	18-Nov-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	10:01	14:05	04:04	LINE CLEAR AVAILED
194	18-Nov-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:01	14:20	04:19	LINE CLEAR AVAILED
195	18-Nov-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:01	14:08	04:07	LINE CLEAR AVAILED
196	18-Nov-20	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	10:01	13:41	03:40	LINE CLEAR AVAILED
197	18-Nov-20	BENGALURU	66	KOLAR 220 - NARASAPURA 2	MALUR I/A, JADIGENAHALLI	10:01	13:41	03:40	LINE CLEAR AVAILED
198	18-Nov-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	10:01	13:47	03:46	LINE CLEAR AVAILED
199	18-Nov-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:01	13:45	03:44	LINE CLEAR AVAILED
200	18-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:01	13:49	03:48	LINE CLEAR AVAILED
201	18-Nov-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:01	13:30	03:29	LINE CLEAR AVAILED
202	18-Nov-20	BENGALURU	66	TG HALLI - ANCHEPALYA	TG HALLI	10:50	12:05	01:15	MAIN SUPPLY FAILURE
203	18-Nov-20	BENGALURU	66	TG HALLI - BYADRAHALLI	TG HALLI	20:10	20:15	00:05	LOAD CHANGE OVER
204	18-Nov-20	BENGALURU	66	VIDYANAGAR - LINE 2	NO STATION AFFECTED	07:15	09:21	02:06	LINE FAULT
205	18-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
206	18-Nov-20	BENGALURU	220	HV1	KOLAR 220	10:01	13:20	03:19	LINE CLEAR AVAILED
207	18-Nov-20	BENGALURU	220	HV2	KOLAR 220	10:01	13:20	03:19	LINE CLEAR AVAILED
208	18-Nov-20	BENGALURU	220	HV3	KOLAR 220	10:02	13:20	03:18	LINE CLEAR AVAILED
209	18-Nov-20	GULBARGA	66	HV1	CHORNOOR_66	07:05	07:10	00:05	TRANSFORMER FAULT
210	18-Nov-20	GULBARGA	110	HUMNABAD-SASTAPUR	SASTAPUR_110	21:10	21:22	00:12	LINE FAULT
211	18-Nov-20	GULBARGA	110	HV1	HAMPASAGAR_110	15:15	15:20	00:05	TRANSFORMER FAULT
212	18-Nov-20	GULBARGA	110	HV2	NALWAR_110	13:20	13:45	00:25	TRANSFORMER FAULT
213	18-Nov-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	17:35	17:55	00:20	LINE CLEAR AVAILED
214	18-Nov-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	05:49	05:58	00:09	LINE FAULT
215	18-Nov-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	06:18	06:27	00:09	LINE FAULT
216	18-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
217	18-Nov-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	12:14	18:30	06:16	LINE CLEAR AVAILED
218	18-Nov-20	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	20:10	20:22	00:12	LINE FAULT
219	18-Nov-20	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, KORWAR_TEMPLE_110, RAJSHREE_CEMENTS,	11:40(17.11.2020)			LINE OPEN:LINE CLEAR AVAILED
220	18-Nov-20	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_110	23:22	23:28	00:06	LINE FAULT
221	18-Nov-20	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	11:11	11:20	00:09	LINE FAULT
222	18-Nov-20	GULBARGA	110	YELBURGA-PRPJSLR_IPP	YELBURGA_110	07:45	07:55	00:10	LINE FAULT
223	18-Nov-20	GULBARGA	220	HUMNABAD-KAPNOOR	KAPNOOR_220	15:39	17:15	01:36	LINE CLEAR AVAILED
224	18-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
225	18-Nov-20	GULBARGA	220	HV1,LV1	HALBARGA_220	11:53	12:02	00:09	TRANSFORMER FAULT
226	18-Nov-20	GULBARGA	220	HV2	HALBARGA_220	11:50	17:40	05:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
227	18-Nov-20	GULBARGA	220	LINGAPUR-HALWARTH1_IPP	LINGAPUR_220	11:11	14:16	03:05	LINE FAULT
228	18-Nov-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	23:17(17.11.2020)	06:37(18.11.2020)	7:20hrs	LINE CHARGED
229	18-Nov-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	08:55	09:08	00:13	LINE FAULT
230	18-Nov-20	HASSAN	66	HV1	MALALI_66	08:57	09:10	00:13	MAIN SUPPLY FAILURE
231	18-Nov-20	HASSAN	66	HV1	YESLUR_66	06:05	06:16	00:11	TRANSFORMER FAULT
232	18-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
233	18-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
234	18-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
235	18-Nov-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	09:01	09:10	00:09	LINE FAULT
236	18-Nov-20	HASSAN	110	HV1	MSEZ_220	09:41	16:00	06:19	LINE CLEAR AVAILED
237	18-Nov-20	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
238	18-Nov-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	07:57	18:33	10:36	LINE CLEAR AVAILED
239	18-Nov-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	07:57	18:33	10:36	NFBC ISSUED
240	18-Nov-20	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	23:16 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
241	18-Nov-20	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	23:16 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
242	18-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:36 (14.11.2020)	8:01(18.11.2020)	103:24 hrs	LINE CHARGED
243	18-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	8:08 (18.11.2020)			LINE OPEN:LINE FAULT
244	18-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
245	18-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:49 (17.11.2020)	6:41 (18.11.2020)	7:51 hrs	LINE CHARGED
246	18-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
247	18-Nov-20	MYSORE	66	BEGUR 220-HARVE	HARVEY_66	5:15	5:50	0:35	LINE FAULT
248	18-Nov-20	MYSORE	66	HV1	KOPPA_66	14:00	14:22	0:22	LINE CLEAR AVAILED
249	18-Nov-20	MYSORE	66	HV1	SANTHESARAGUR_66	16:35	17:10	0:35	LINE CLEAR AVAILED
250	18-Nov-20	MYSORE	66	HV2	AKKIHEBBAL_66	10:06	10:12	0:05	TRANSFORMER FAULT
251	18-Nov-20	MYSORE	66	HV2	AKKIHEBBAL_66	11:05	11:14	0:08	TRANSFORMER FAULT
252	18-Nov-20	MYSORE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	8:29	8:36	0:06	LINE FAULT
253	18-Nov-20	MYSORE	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	8:40	18:05	9:25	LINE CLEAR AVAILED
254	18-Nov-20	MYSORE	66	KUSHALNAGARA 220-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	12:02	16:05	4:02	LINE CLEAR AVAILED
255	18-Nov-20	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	12:02	16:05	4:02	LINE CLEAR AVAILED
256	18-Nov-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	9:57	10:02	0:05	LINE FAULT
257	18-Nov-20	MYSORE	66	PARINAMIPURA -KOLLEGALA	PARINAMIPURA_66	13:10	16:20	3:10	LINE CLEAR AVAILED
258	18-Nov-20	MYSORE	66	TALKADU-CHANDALLY	THALAKADU_66	13:00	16:25	3:25	LINE CLEAR AVAILED
259	18-Nov-20	MYSORE	66	TALKADU-PARINAMIPURA	THALAKADU_66	13:16	16:25	3:09	LINE CLEAR AVAILED
260	18-Nov-20	MYSORE	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	18:03	18:09	0:06	LINE FAULT
261	18-Nov-20	MYSORE	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	8:08	12:39	4:31	NFBC ISSUED
262	18-Nov-20	MYSORE	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	8:08	12:37	4:29	NFBC ISSUED
263	18-Nov-20	MYSORE	220	HV1	MADHUVANAHALLI_220	8:01	16:04	8:02	LINE CLEAR AVAILED
264	18-Nov-20	MYSORE	220	HV2	MADHUVANAHALLI_220	7:59	16:04	8:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
265	18-Nov-20	MYSORE	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	10:17	13:47	3:29	LINE CLEAR AVAILED
266	18-Nov-20	MYSORE	220	MADHUVANAHALLI-TK HALLI 1	NO STATIONS EFFECTED	8:02	15:58	7:55	LINE CLEAR AVAILED
267	18-Nov-20	MYSORE	220	MADHUVANAHALLI-TK HALLI 2	NO STATIONS EFFECTED	8:02	15:53	7:50	LINE CLEAR AVAILED
268	18-Nov-20	MYSORE	220	MADHUVANAHALLI-WARDA SOLAR	NO STATIONS EFFECTED	8:02	12:41	4:38	LINE CLEAR AVAILED
269	18-Nov-20	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:41	17:17	0:36	MAIN SUPPLY FAILURE
270	18-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	0:26	0:35	0:08	HAND TRIPPED
271	18-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	1:34	1:44	0:09	HAND TRIPPED
272	18-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	4:16	4:29	0:13	HAND TRIPPED
273	18-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	5:46	5:59	0:13	HAND TRIPPED
274	18-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	17:16	17:18	0:02	HAND TRIPPED
275	18-Nov-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:16	17:21	0:04	HAND TRIPPED
276	18-Nov-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	17:16	17:18	0:01	HAND TRIPPED
277	18-Nov-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	18:08	18:16	0:08	LINE FAULT
278	18-Nov-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	18:33	18:37	0:03	LINE FAULT
279	18-Nov-20	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	23:33	23:42	0:08	LINE FAULT
280	18-Nov-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	1:51	2:00	0:08	LINE CLEAR AVAILED
281	18-Nov-20	TUMKUR	66	TR-1	BELADARA_66	10:00	13:55	3:55	LINE CLEAR AVAILED
282	18-Nov-20	TUMKUR	66	TR-1	DEVARAHALLI_66	16:41	17:17	0:36	MAIN SUPPLY FAILURE
283	18-Nov-20	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	17:00	17:15	0:15	LINE CLEAR AVAILED
284	18-Nov-20	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	17:16	17:54	0:38	TRANSFORMER FAULT
285	18-Nov-20	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	15:59	16:55	0:55	LINE CLEAR AVAILED
286	18-Nov-20	TUMKUR	66	TR-2	BELADARA_66	10:00	13:56	3:55	LINE CLEAR AVAILED
287	18-Nov-20	TUMKUR	66	TR-2	HONNALLI_220	17:16	17:18	0:01	TRANSFORMER FAULT
288	18-Nov-20	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	15:51	16:22	0:31	LINE CLEAR AVAILED
289	18-Nov-20	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	15:51	16:22	0:31	LINE CLEAR AVAILED
290	18-Nov-20	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUNSEGHA TTA_110	14:32	17:25	2:52	LINE CLEAR AVAILED
291	18-Nov-20	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110,DODDAGUNI_110	15:51	16:24	0:32	LINE CLEAR AVAILED
292	18-Nov-20	TUMKUR	110	TR-1	DODDAGUNI_110	16:22	16:25	0:03	TRANSFORMER FAULT
293	18-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
294	18-Nov-20	TUMKUR	110	TR-2	BANDIHALLI_110	3:03(14.11.2020)	14:43(18.11.20)	92:56hrs	TRANSFORMER CHARGED
295	18-Nov-20	TUMKUR	220	HONNALLI 220kV- DAVANAGERE 220kV	HONNALLI_220	16:20	17:16	0:55	LINE FAULT
296	18-Nov-20	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	17:16	17:25	0:09	HAND TRIPPED
297	18-Nov-20	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	17:16	17:25	0:08	HAND TRIPPED
298	18-Nov-20	TUMKUR	220	TR-1	NEELAGUNDA_220	15:59	16:53	0:54	LINE CLEAR AVAILED
299	19-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
300	19-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
301	19-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
302	19-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR1	NO STATION AFFECTED GOPANAKOPPA_110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
303	19-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR2	NO STATION AFFECTED GOPANAKOPPA_110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
304	19-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
305	19-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
306	19-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
307	19-Nov-20	BAGALKOT	110	RANEENNUR- AREMALLAPUR	NO STATION AFFECTED HONNATTI_110, AREMALLAUR_110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
308	19-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
309	19-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
310	19-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
311	19-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
312	19-Nov-20	BAGALKOT	220	SHARAVATHY 1-SIRSI	NO STATION AFFECTED SIRSI_220	16:49 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
313	19-Nov-20	BAGALKOT	220	SHARAVATHY 2-SIRSI	NO STATION AFFECTED SIRSI_220	16:50 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
314	19-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
315	19-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
316	19-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
317	19-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	9:12	9:21	0:09	TRANSFORMER FAULT
318	19-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	9:04	9:09	0:05	TRANSFORMER FAULT
319	19-Nov-20	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	3:52	4:21	0:29	LINE FAULT
320	19-Nov-20	GULBARGA	110	HV1	TEKKALKOTE_110	12:23	13:47	1:24	LINE CLEAR AVAILED
321	19-Nov-20	GULBARGA	110	HV2	HATTI_110	12:31	13:09	0:38	LINE CLEAR AVAILED
322	19-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
323	19-Nov-20	GULBARGA	110	RAICHUR-SHAHAPUR	GABBUR_110,DEODURGA_110	4:46	4:56	0:10	LINE FAULT
324	19-Nov-20	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, KORWAR_TEMPLE_110, RAJSHREE_CEMENTS,	11:40(17.11.2020)			LINE OPEN:LINE CLEAR AVAILED
325	19-Nov-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPU R_110,COREGREEN SUGAR IPP	3:29	3:38	0:09	LINE FAULT
326	19-Nov-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPU R_110,COREGREEN SUGAR IPP	4:07	4:16	0:09	LINE FAULT
327	19-Nov-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:15	2:21	0:06	LINE FAULT
328	19-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
329	19-Nov-20	GULBARGA	220	HV1	RAICHUR_220	10:24	11:17	0:53	LINE CLEAR AVAILED
330	19-Nov-20	GULBARGA	220	HV1	HUMNABAD_220	13:09	15:36	2:27	LINE CLEAR AVAILED
331	19-Nov-20	GULBARGA	220	HV1	HALBARGA_220	11:06	17:15	6:09	LINE CLEAR AVAILED
332	19-Nov-20	GULBARGA	220	HV2	RAICHUR_220	11:47	13:38	1:51	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
333	19-Nov-20	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	14:55(19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
334	19-Nov-20	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	9:14	17:31	8:17	LINE CLEAR AVAILED
335	19-Nov-20	HASSAN	66	HV1	BELUR_66	6:30	6:45	0:15	MAIN SUPPLY FAILURE
336	19-Nov-20	HASSAN	66	HV1	BELUR_66	10:50	10:55	0:05	HAND TRIPPED
337	19-Nov-20	HASSAN	66	HV1	SALAGAME_66	11:28	12:35	1:07	LINE CLEAR AVAILED
338	19-Nov-20	HASSAN	66	HV2	BELUR_66	6:30	6:45	0:15	MAIN SUPPLY FAILURE
339	19-Nov-20	HASSAN	66	HV2	BELUR_66	10:50	10:55	0:05	HAND TRIPPED
340	19-Nov-20	HASSAN	66	HV2	BELUR_66	7:45	8:00	0:15	TRANSFORMER FAULT
341	19-Nov-20	HASSAN	66	HV2	KANDLI_66	15:58	16:21	0:23	LINE CLEAR AVAILED
342	19-Nov-20	HASSAN	66	HV2	SALAGAME_66	10:48	11:54	1:06	LINE CLEAR AVAILED
343	19-Nov-20	HASSAN	66	HV2	UDAYAPURA_66	11:59	12:06	0:07	LINE CLEAR AVAILED
344	19-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
345	19-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
346	19-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
347	19-Nov-20	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:28	11:29	0:01	HAND TRIPPED
348	19-Nov-20	HASSAN	110	HV1	ARASIKERE_220	17:35	17:47	0:12	TRANSFORMER FAULT
349	19-Nov-20	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
350	19-Nov-20	HASSAN	110	MSEZ-GSS31	MSEZ_110	11:31	11:48	0:17	LINE FAULT
351	19-Nov-20	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	14:10	14:35	0:25	LINE FAULT
352	19-Nov-20	HASSAN	220	MRSSH-M-SHANTHIGRAMA	MRSMSG_220	14:33	14:58	0:25	LINE FAULT
353	19-Nov-20	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	14:10	14:35	0:25	LINE FAULT
354	19-Nov-20	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	23:16 (18.11.2020)	11:57(19.11.2020)	12:41hrs	LINE CHARGED
355	19-Nov-20	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	23:16 (18.11.2020)	11:57(19.11.2020)	12:41hrs	LINE CHARGED
356	19-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	8:08 (18.11.2020)	15:33(19.11.2020)	31:25hrs	LINE CHARGED
357	19-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
358	19-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41 (18.11.2020)	7:17(19.11.2020)	8:36hrs	LINE CHARGED
359	19-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:37(19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
360	19-Nov-20	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66	10:07	16:53	6:46	NFBC ISSUED
361	19-Nov-20	MYSORE	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	10:01	17:24	7:23	LINE CLEAR AVAILED
362	19-Nov-20	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:08	11:47	0:38	LINE CLEAR AVAILED
363	19-Nov-20	MYSORE	66	HV1	K_HONNALGERE_66	6:12	6:28	0:16	MAIN SUPPLY FAILURE
364	19-Nov-20	MYSORE	66	HV1	VAJAMANGALA_220	9:57	14:49	4:52	LINE CLEAR AVAILED
365	19-Nov-20	MYSORE	66	HV2	BGPURA_66	12:38	14:23	1:44	LINE CLEAR AVAILED
366	19-Nov-20	MYSORE	66	HV2	K_HONNALGERE_66	6:11	6:29	0:17	MAIN SUPPLY FAILURE
367	19-Nov-20	MYSORE	66	HV2	KOPPA_66	15:08	15:51	0:43	LINE CLEAR AVAILED
368	19-Nov-20	MYSORE	66	HV2	VAJAMANGALA_220	10:08	15:08	5:00	LINE CLEAR AVAILED
369	19-Nov-20	MYSORE	66	HV3	KRPET_66	12:09	17:17	5:07	LINE CLEAR AVAILED
370	19-Nov-20	MYSORE	66	KR NAGARA-BHERYA	BHERYA_66	4:45			LINE OPEN:LINE FAULT
371	19-Nov-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	6:12	6:18	0:05	LINE FAULT
372	19-Nov-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	6:25	6:39	0:13	LINE FAULT
373	19-Nov-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:57	14:01	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
374	19-Nov-20	MYSORE	66	TUNINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA 66	17:49	17:59	0:10	LINE FAULT
375	19-Nov-20	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR 66, HULLENAHALLI 66	10:30	16:01	5:30	LINE CLEAR AVAILED
376	19-Nov-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA 66	4:28	4:40	0:12	LINE FAULT
377	19-Nov-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR 66	5:14	5:26	0:12	LINE FAULT
378	19-Nov-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI 66	3:26	3:41	0:15	LINE FAULT
379	19-Nov-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR 66,MALEBENNUR 66	12:03	12:06	0:02	LINE FAULT
380	19-Nov-20	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA 66	17:45	17:58	0:13	LINE FAULT
381	19-Nov-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-1	CHALLAKERE 66, SANIKERE 66	7:22	7:34	0:12	LINE FAULT
382	19-Nov-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1 IPP 66	11:10	15:37	4:26	LINE FAULT
383	19-Nov-20	TUMKUR	66	TR-1	CHITRADURGA 66	18:18	19:06	0:48	TRANSFORMER FAULT
384	19-Nov-20	TUMKUR	66	TR-1	NEELAGUNDA 220	15:35	15:58	0:23	TRANSFORMER FAULT
385	19-Nov-20	TUMKUR	66	TR-1	RANGANATHAPURA 66	13:11	13:27	0:15	LINE CLEAR AVAILED
386	19-Nov-20	TUMKUR	66	TR-2	RANGANATHAPURA 66	12:58	13:10	0:12	LINE CLEAR AVAILED
387	19-Nov-20	TUMKUR	66	TR-2(LV SIDE)	HONNALLI 220	12:14	14:44	2:30	LINE CLEAR AVAILED
388	19-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
389	19-Nov-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	18:04	18:15	0:10	TRANSFORMER FAULT
390	19-Nov-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE SRS 220	15:42	17:53	2:11	LINE CLEAR AVAILED
391	19-Nov-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE SRS 220	11:34	11:37	0:03	HAND TRIPPED
392	20-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
393	20-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
394	20-Nov-20	BAGALKOT	110	110/11KV,HV2	SATTI_110	9:40	10:14	0:34	HAND TRIPPED
395	20-Nov-20	BAGALKOT	110	110/11KV,HV2	SATTI 110	12:20	12:52	0:32	HAND TRIPPED
396	20-Nov-20	BAGALKOT	110	110/11KV,HV2	SATTI 110	15:00	17:15	2:15	LINE CLEAR AVAILED
397	20-Nov-20	BAGALKOT	110	220/110KV, LV3	BAGALKOT_220, KALADAGI_110, NEERBUDIHAL 110	15:26	15:40	0:14	LINE CLEAR AVAILED
398	20-Nov-20	BAGALKOT	110	220/110KV,LV2	MKHubli 220	2:08	6:35	4:27	LINE CLEAR AVAILED
399	20-Nov-20	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA 110	12:20	12:53	0:33	LINE FAULT
400	20-Nov-20	BAGALKOT	110	BAGALKOT220- NEERBUDIHAL	NEERBUDIHAL 110	15:16	15:42	0:26	LINE CLEAR AVAILED
401	20-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED
402	20-Nov-20	BAGALKOT	110	CHIKKODI220- RAIBAG	NO STATION AFFECTED RAIBAG 110	10:24	11:45	1:21	LINE CLEAR AVAILED
403	20-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR1	NO STATION AFFECTED GOPANAKOPPA 110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
404	20-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR2	NO STATION AFFECTED GOPANAKOPPA 110	15:34 (12.11.2020)			LINE OPEN:LINE CLEAR AVAILED
405	20-Nov-20	BAGALKOT	110	HALSIDDANATH (HSSSK)- NIPPANI	NIPPANI 110	13:00	13:10	0:10	HAND TRIPPED
406	20-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
407	20-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
408	20-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
409	20-Nov-20	BAGALKOT	110	RANEBENNUR- AREMALLAPUR	NO STATION AFFECTED HONNATTI 110, AREMALLAUR 110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
410	20-Nov-20	BAGALKOT	110	UMACHAGI-SIRSI	UMACHAGI_110	12:20	12:44	0:24	LINE FAULT
411	20-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
412	20-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
413	20-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
414	20-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
415	20-Nov-20	BAGALKOT	220	MKHUBLI- NARENDRA1	MKHUBLI_220	5:31	6:29	0:58	LINE FAULT
416	20-Nov-20	BAGALKOT	220	SHARAVATHY 1-SIRSI	NO STATION AFFECTED SIRSI_220	16:49 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
417	20-Nov-20	BAGALKOT	220	SHARAVATHY 2-SIRSI	NO STATION AFFECTED SIRSI_220	16:50 (13.11.2020)			LINE OPEN:LINE CLEAR AVAILED
418	20-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
419	20-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
420	20-Nov-20	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	13:42	13:55	00:13	LINE CLEAR AVAILED
421	20-Nov-20	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	13:07	13:41	00:34	LINE CLEAR AVAILED
422	20-Nov-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	10:01	10:15	00:14	LINE FAULT
423	20-Nov-20	BENGALURU	66	HV3	ADUGODI	13:00	13:10	00:10	LINE CLEAR AVAILED
424	20-Nov-20	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY	17:07	17:27	00:20	LINE FAULT
425	20-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
426	20-Nov-20	GULBARGA	66	HV1	HANASI_66	16:23	16:38	00:15	TRANSFORMER FAULT
427	20-Nov-20	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	11:30	18:20	06:50	NFBC ISSUED
428	20-Nov-20	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	23:10	23:25	00:15	LINE FAULT
429	20-Nov-20	GULBARGA	110	HV1	SHAHPUR_220	07:25	07:35	00:10	TRANSFORMER FAULT
430	20-Nov-20	GULBARGA	110	HV1	MANVI_110	15:21	15:42	00:21	TRANSFORMER FAULT
431	20-Nov-20	GULBARGA	110	HV1	TEKKALKOTE_110	11:38	14:44	03:06	LINE CLEAR AVAILED
432	20-Nov-20	GULBARGA	110	HV1 & HV2	HAMPASAGAR_110	11:20	16:05	04:45	LINE CLEAR AVAILED
433	20-Nov-20	GULBARGA	110	HV2	HAMPASAGAR_110	16:10	16:40	00:30	LINE CLEAR AVAILED
434	20-Nov-20	GULBARGA	110	HV2	YELBURGA_110	17:40	18:50	01:10	LINE CLEAR AVAILED
435	20-Nov-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	04:14	04:21	00:07	LINE FAULT
436	20-Nov-20	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, KORWAR_TEMPLE_110, RAJSHREE_CEMENTS,	11:40(17.11.2020)			LINE OPEN:LINE CLEAR AVAILED
437	20-Nov-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	23:50(20.11.2020)			LINE OPEN:LINE FAULT
438	20-Nov-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110, SANNATHI_110,CORE GREEN SUGAR_IPP, NALWAR_110	17:04	17:36	00:32	LINE CLEAR AVAILED
439	20-Nov-20	GULBARGA	110	SHAHAPUR220-SHORAPUR	SHORAPUR_110	05:41	05:52	00:11	LINE FAULT
440	20-Nov-20	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110,NSL SUGAR_IPP	15:52	16:52	01:00	MAIN SUPPLY FAILURE
441	20-Nov-20	GULBARGA	220	HALBURGA-CHIDRI2	CHIDRI_110	11:30	16:05	04:35	LINE CLEAR AVAILED
442	20-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
443	20-Nov-20	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	14:55(19.11.2020)	15:52(20.11.2020)	24:57HRS	LINE CHARGED
444	20-Nov-20	GULBARGA	220	LINGAPUR-GADAG	GADAG_220,DHRUVADESH_IPP	13:14	17:20	04:06	LINE FAULT
445	20-Nov-20	GULBARGA	220	LINGAPUR-HARTHI	ARESS STEELS_IPP	13:35	17:23	03:48	LINE FAULT
446	20-Nov-20	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	10:30	13:15	02:45	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
447	20-Nov-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	10:32	13:16	02:44	LINE CLEAR AVAILED
448	20-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
449	20-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
450	20-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
451	20-Nov-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:50	12:00	00:10	LINE FAULT
452	20-Nov-20	HASSAN	110	HV1	KEMAR_220	08:56	15:52	06:56	LINE CLEAR AVAILED
453	20-Nov-20	HASSAN	110	HV1	ANANDAPURA_110	06:54	07:06	00:12	TRANSFORMER FAULT
454	20-Nov-20	HASSAN	110	HV1	KALLUSADARAHALLY_110	18:40	20:18	01:38	LINE CLEAR AVAILED
455	20-Nov-20	HASSAN	110	HV1	SAGARA_110	07:55	08:03	00:08	TRANSFORMER FAULT
456	20-Nov-20	HASSAN	110	HV1	SINGATGERE_110	10:10	10:37	00:27	LINE CLEAR AVAILED
457	20-Nov-20	HASSAN	110	HV3	SAGARA_110	15:13	18:35	03:22	LINE CLEAR AVAILED
458	20-Nov-20	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
459	20-Nov-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:16	14:25	03:09	LINE CLEAR AVAILED
460	20-Nov-20	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	11:20	12:00	00:40	MAIN SUPPLY FAILURE
461	20-Nov-20	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	11:56	12:06	00:10	MAIN SUPPLY FAILURE
462	20-Nov-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	09:49	09:54	00:05	HAND TRIPPED
463	20-Nov-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	09:49	09:52	00:03	HAND TRIPPED
464	20-Nov-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	09:49	09:50	00:01	HAND TRIPPED
465	20-Nov-20	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	09:59	16:10	06:11	LINE CLEAR AVAILED
466	20-Nov-20	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	09:47	16:14	06:27	NFBC ISSUED
467	20-Nov-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:28	13:28	03:00	NFBC ISSUED
468	20-Nov-20	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	13:27	13:55	00:28	LINE FAULT
469	20-Nov-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:22	13:29	03:07	LINE CLEAR AVAILED
470	20-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
471	20-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:37(19.11.2020)	7:24(20.11.2020)	8:46 hrs	LINE CHARGED
472	20-Nov-20	MYSORE	66	BANNUR-MALIYUR	MALIYURU_66	10:48	18:40	7:51	NFBC ISSUED
473	20-Nov-20	MYSORE	66	BANNUR-VAJMANGALA	BANNUR_66	10:47	18:40	7:52	LINE CLEAR AVAILED
474	20-Nov-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:47	14:56	0:08	LINE FAULT
475	20-Nov-20	MYSORE	66	HV1	BASARALU_66	11:51	14:53	3:01	LINE CLEAR AVAILED
476	20-Nov-20	MYSORE	66	HV1	MADESWARAPURA_66	12:32	14:28	1:55	LINE CLEAR AVAILED
477	20-Nov-20	MYSORE	66	HV1	MADESWARAPURA_66	10:30	12:30	2:00	LINE CLEAR AVAILED
478	20-Nov-20	MYSORE	66	HV1	MADIKERI_66	14:45	16:10	1:25	LINE CLEAR AVAILED
479	20-Nov-20	MYSORE	66	HV1	NAGAMANGALA_66	11:39	12:30	0:51	LINE CLEAR AVAILED
480	20-Nov-20	MYSORE	66	HV1	NAGAMANGALA_66	16:41	17:22	0:41	LINE CLEAR AVAILED
481	20-Nov-20	MYSORE	66	HV1	PONNAMPET_66	9:00	12:50	3:50	LINE CLEAR AVAILED
482	20-Nov-20	MYSORE	66	HV2	BASARALU_66	10:16	16:38	6:21	LINE CLEAR AVAILED
483	20-Nov-20	MYSORE	66	HV2	KHBCOLONY_66	11:02	11:11	0:08	LINE CLEAR AVAILED
484	20-Nov-20	MYSORE	66	HV2	KIRUGAVALU_66	13:31	14:37	1:06	LINE CLEAR AVAILED
485	20-Nov-20	MYSORE	66	HV2	KOLLEGALA_66	15:39	15:45	0:06	HAND TRIPPED
486	20-Nov-20	MYSORE	66	HV2	MADIKERI_66	10:30	14:45	4:15	LINE CLEAR AVAILED
487	20-Nov-20	MYSORE	66	HV2	NAGAMANGALA_66	11:39	12:30	0:51	LINE CLEAR AVAILED
488	20-Nov-20	MYSORE	66	HV2	NAGAMANGALA_66	16:41	17:23	0:41	LINE CLEAR AVAILED
489	20-Nov-20	MYSORE	66	HV2	PONNAMPET_66	9:06	13:01	3:54	LINE CLEAR AVAILED
490	20-Nov-20	MYSORE	66	HV3	PONNAMPET_66	15:55	17:20	1:25	LINE CLEAR AVAILED
491	20-Nov-20	MYSORE	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66	11:35	11:50	0:15	LINE CLEAR AVAILED
492	20-Nov-20	MYSORE	66	MADHUVANAHALLI-DODDINADUVADI	DODDINADUVADI_66	10:01	16:54	6:52	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
493	20-Nov-20	MYSORE	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	16:00	17:08	1:08	LINE CLEAR AVAILED
494	20-Nov-20	MYSORE	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	10:34	14:07	3:33	NFBC ISSUED
495	20-Nov-20	MYSORE	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	1:50	1:59	0:08	LINE FAULT
496	20-Nov-20	MYSORE	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	10:48	18:02	7:14	LINE CLEAR AVAILED
497	20-Nov-20	MYSORE	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	12:39	12:51	0:12	HAND TRIPPED
498	20-Nov-20	MYSORE	220	HV1	CRNAGAR_220	14:09	16:32	2:22	LINE CLEAR AVAILED
499	20-Nov-20	MYSORE	220	HV2	CRNAGAR_220	10:34	14:04	3:30	LINE CLEAR AVAILED
500	20-Nov-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	6:09	6:57	0:48	LINE FAULT
501	20-Nov-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	14:03	14:29	0:26	MAIN SUPPLY FAILURE
502	20-Nov-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	14:03	14:23	0:20	MAIN SUPPLY FAILURE
503	20-Nov-20	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	15:28	17:37	2:08	LINE CLEAR AVAILED
504	20-Nov-20	TUMKUR	66	TR-1	DAVANGERE_SRS_220	9:45	10:35	0:50	HAND TRIPPED
505	20-Nov-20	TUMKUR	66	TR-2	BEVINAHALLI_66	13:04	15:36	2:31	LINE CLEAR AVAILED
506	20-Nov-20	TUMKUR	110	MAYASANDRA-KB CROSS	MAYASANDRA_110	14:35	14:36	0:01	LINE CLEAR AVAILED
507	20-Nov-20	TUMKUR	110	TR-1	MAYASANDRA_110	10:18	10:28	0:09	LINE CLEAR AVAILED
508	20-Nov-20	TUMKUR	110	TR-1	MAYASANDRA_110	13:40	14:05	0:24	LINE CLEAR AVAILED
509	20-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
510	20-Nov-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:18	12:32	0:13	LINE CLEAR AVAILED
511	20-Nov-20	TUMKUR	110	TR-2	MAYASANDRA_110	3:07	3:24	0:16	HAND TRIPPED
512	21-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
513	21-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
514	21-Nov-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
515	21-Nov-20	BAGALKOT	110	110/11KV, HV1	HIDAKAL_110	17:50	18:00	0:10	LINE CLEAR AVAILED
516	21-Nov-20	BAGALKOT	110	110/11KV, HV1	RATTIHALLI_110	17:10	17:43	0:33	LINE CLEAR AVAILED
517	21-Nov-20	BAGALKOT	110	110/11KV, HV1	RATTIHALLI_110	17:53	17:55	0:02	LINE CLEAR AVAILED
518	21-Nov-20	BAGALKOT	110	110/11KV, HV2	GOKAK_110	14:52	15:05	0:13	TRANSFORMER FAULT
519	21-Nov-20	BAGALKOT	110	110/11KV, HV2	HIDAKAL_110	17:46	17:57	0:11	LINE CLEAR AVAILED
520	21-Nov-20	BAGALKOT	110	110/11KV, HV2	HIDAKAL_110	20:59	21:06	0:07	LINE CLEAR AVAILED
521	21-Nov-20	BAGALKOT	110	110/11KV, HV3	MUDHOL_110	8:48	9:40	0:52	LINE CLEAR AVAILED
522	21-Nov-20	BAGALKOT	110	110/33KV, HV3	HIDAKAL_110 KOLIGUDDA_33 & MYTRA SOLAR_33	17:46	18:00	0:14	LINE CLEAR AVAILED
523	21-Nov-20	BAGALKOT	110	110/33KV, HV4	HIDAKAL_110 ALAGAWADI_33	17:44	18:01	0:17	LINE CLEAR AVAILED
524	21-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED
525	21-Nov-20	BAGALKOT	110	BIDNAL-GADAG ROAD	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
526	21-Nov-20	BAGALKOT	110	GADAG ROAD-BIDNAL220	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
527	21-Nov-20	BAGALKOT	110	GADAG ROAD-GOPANKOPPA	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
528	21-Nov-20	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA-1	GHATAPRABHA_110	9:01	9:02	0:01	HAND TRIPPED
529	21-Nov-20	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA-2	GHATAPRABHA_110	9:04	9:08	0:04	HAND TRIPPED
530	21-Nov-20	BAGALKOT	110	GHATAPRABHA-GDPH(BELAGAUM)	STATION NOT AFFECTED GHATAPRABHA_110	8:15	9:25	1:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
531	21-Nov-20	BAGALKOT	110	GHATAPRABHA-GHATAPRABHA220-1	STATION NOT AFFECTED GHATAPRABHA 110	8:15	9:20	1:05	LINE FAULT
532	21-Nov-20	BAGALKOT	110	GOPANAKOPPA-GADAGROAD	GADAG ROAD 110	6:05 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
533	21-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR1	NO STATION AFFECTED GOPANAKOPPA 110	15:34 (12.11.2020)	06:05 (21.11.2020)	206:31hrs	LINE CHARGED
534	21-Nov-20	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAYNAGAR2	NO STATION AFFECTED GOPANAKOPPA 110	15:34 (12.11.2020)	06:05 (21.11.2020)	206:31hrs	LINE CHARGED
535	21-Nov-20	BAGALKOT	110	GOPANAKOPPA-NAVALAGUND(BIDNAL)	NAVALAGUND 110	10:40	15:09	4:29	LINE CLEAR AVOIDED
536	21-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
537	21-Nov-20	BAGALKOT	110	HIREBEVANUR-DS SHIVKUMAR SHUGARS	DS SHIVKUMAR SHUGARS	13:56	14:46	0:50	HAND TRIPPED
538	21-Nov-20	BAGALKOT	110	HIREBEVANUR-LACHYAN(INDI220)	HIREBEVANUR 110	13:10	14:00	0:50	HAND TRIPPED
539	21-Nov-20	BAGALKOT	110	HIREBEVANUR-LACHYAN(INDI220)	HIREBEVANUR 110	17:05	17:10	0:05	LINE FAULT
540	21-Nov-20	BAGALKOT	110	HUDLI-BELGAUM220	STATION NOT AFFECTED HUDLI 110	21:10 (02.11.2020)	8:52 (21.11.2020)	443:22hrs	LINE CHARGED
541	21-Nov-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
542	21-Nov-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
543	21-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
544	21-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
545	21-Nov-20	BAGALKOT	110	NOKAR SOLAR- NAVALGUND	NO STATION AFFECTED NAVALGUND 110	15:41	22:41	7:00	LINE CLEAR AVOIDED
546	21-Nov-20	BAGALKOT	110	RANEENNUR- AREMALLAPUR	NO STATION AFFECTED HONNATTI 110, AREMALLAUR 110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
547	21-Nov-20	BAGALKOT	110	SIRSI220- UMMACHAGI	NO STATION AFFECTED UMMACHAGI 110	11:20	11:54	0:34	LINE CLEAR AVOIDED
548	21-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR 220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
549	21-Nov-20	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED GADAG 220	11:09 (21.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
550	21-Nov-20	BAGALKOT	220	220/110KV, HV3	NO STATION AFFECTED HUBLI 220	13:15	17:39	4:24	LINE CLEAR AVOIDED
551	21-Nov-20	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED GADAG 220	11:09 (21.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
552	21-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR 220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
553	21-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT 220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
554	21-Nov-20	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI 220	18:15 (21.11.2020)			LINE OPEN:LINE FAULT
555	21-Nov-20	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI 220	11:18	14:27	3:09	LINE FAULT
556	21-Nov-20	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI 220	17:39 (14.11.2020)	17:52 (21.11.2020)	144:13hrs	LINE CHARGED
557	21-Nov-20	BAGALKOT	220	ATHANI-RAVI URJA 2	ATHANI 220	15:13	17:53	2:40	LINE CLEAR AVOIDED
558	21-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI 220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
559	21-Nov-20	BAGALKOT	220	BELGAUM-KANABARGI	STATION NOT AFFECTED KANABARGI 220	11:20	15:05	3:45	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
560	21-Nov-20	BAGALKOT	220	GADAG-BAGALKOT 1	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
561	21-Nov-20	BAGALKOT	220	GADAG-BAGALKOT 1&2	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
562	21-Nov-20	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
563	21-Nov-20	BAGALKOT	220	GADAG-HARTI 1	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
564	21-Nov-20	BAGALKOT	220	GADAG-HARTI 1&2	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
565	21-Nov-20	BAGALKOT	220	GADAG-HARTI 2	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
566	21-Nov-20	BAGALKOT	220	HUBLI- SIRSI2	NO STATION AFFECTED HUBLI_220	9:10	16:27	7:17	LINE CLEAR AVALIED
567	21-Nov-20	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	16:55 (21.11.2020)			LINE OPEN:LINE FAULT
568	21-Nov-20	BAGALKOT	220	KARWAR-KADRA2	STATION NOT AFFECTED KARWAR_220	16:10	16:22	0:12	LINE FAULT
569	21-Nov-20	BAGALKOT	220	NARENDRA-KANABARGI1&2	NARENDRA_220	8:15 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
570	21-Nov-20	BAGALKOT	220	NARENDRA-KANABARGI1&2	NARENDRA_220	8:15 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
571	21-Nov-20	BAGALKOT	220	SHARAVATHY 1-SIRSI	NO STATION AFFECTED SIRSI_220	16:49 (13.11.2020)	4:36 (21.11.2020)	179:47hrs	LINE CHARGED
572	21-Nov-20	BAGALKOT	220	SHARAVATHY 2-SIRSI	NO STATION AFFECTED SIRSI_220	16:50 (13.11.2020)	4:37 (21.11.2020)	179:47hrs	LINE CHARGED
573	21-Nov-20	BAGALKOT	220	SIRSI- HUBLI1	NO STATION AFFECTED SIRSI_220	5:39	16:26	10:47	LINE CLEAR AVALIED
574	21-Nov-20	BAGALKOT	220	SIRSI- HUBLI2	NO STATION AFFECTED SIRSI_220	5:39	16:26	10:47	LINE CLEAR AVALIED
575	21-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY1	NO STATION AFFECTED SIRSI_220	16:24 (21.11.2020)			LOAD CURTAILMENT
576	21-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY1	NO STATION AFFECTED SIRSI_220	16:24 (21.11.2020)			LOAD CURTAILMENT
577	21-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY2	NO STATION AFFECTED SIRSI_220	16:24 (21.11.2020)			LOAD CURTAILMENT
578	21-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY2	NO STATION AFFECTED SIRSI_220	16:24 (21.11.2020)			LOAD CURTAILMENT
579	21-Nov-20	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	NO STATION AFFECTED	06:10	06:35	00:25	LINE FAULT
580	21-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
581	21-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
582	21-Nov-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	18:01	18:10	00:09	LINE FAULT
583	21-Nov-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	11:42	11:47	00:05	LOAD CHANGE OVER
584	21-Nov-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	05:50	05:57	00:07	LOAD CHANGE OVER
585	21-Nov-20	BENGALURU	66	HV1	SIR M V LAYOUT	14:00	15:40	01:40	LINE CLEAR AVALIED
586	21-Nov-20	BENGALURU	66	HV1	VIJAYANAGARA	08:18	08:35	00:17	MAIN SUPPLY FAILURE
587	21-Nov-20	BENGALURU	66	HV1	KEMBODI	13:04	13:27	00:23	LINE CLEAR AVALIED
588	21-Nov-20	BENGALURU	66	HV1	SIDDALAGATTA	15:53	16:01	00:07	TRANSFORMER FAULT
589	21-Nov-20	BENGALURU	66	HV1	SIDDALAGATTA	09:12	09:17	00:05	TRANSFORMER FAULT
590	21-Nov-20	BENGALURU	66	HV2	EPIP 220	01:47	01:52	00:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
591	21-Nov-20	BENGALURU	66	HV2	R R NAGAR	13:13	13:22	00:09	TRANSFORMER FAULT
592	21-Nov-20	BENGALURU	66	HV2	DODDABELAVANGALA	18:00	18:13	00:13	TRANSFORMER FAULT
593	21-Nov-20	BENGALURU	66	HV2	KEMBODI	12:22	13:06	00:44	LINE CLEAR AVOIDED
594	21-Nov-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	06:10	06:36	00:26	LINE FAULT
595	21-Nov-20	BENGALURU	66	VRISHABHAVAHTI 220 - BANASHANKARI	BANASHANKARI	08:18	08:50	00:32	LINE CLEAR AVOIDED
596	21-Nov-20	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	08:18	08:50	00:32	LINE CLEAR AVOIDED
597	21-Nov-20	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	08:18	08:53	00:35	LINE CLEAR AVOIDED
598	21-Nov-20	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	08:18	08:52	00:34	LINE CLEAR AVOIDED
599	21-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVOIDED
600	21-Nov-20	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI 220	VRISHABHAVATHI 220	08:18	08:38	00:20	LINE FAULT
601	21-Nov-20	BENGALURU	220	VRISHABHAVAHTI 220 - SOMANAHALLI 220	VRISHABHAVATHI 220	08:18	08:48	00:30	MAIN SUPPLY FAILURE
602	21-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	09:13	09:18	00:05	TRANSFORMER FAULT
603	21-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	10:58	11:03	00:05	TRANSFORMER FAULT
604	21-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	12:29	12:34	00:05	TRANSFORMER FAULT
605	21-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	15:32	15:36	00:04	TRANSFORMER FAULT
606	21-Nov-20	GULBARGA	66	HV1	ITTAGI_220	17:35	17:40	00:05	TRANSFORMER FAULT
607	21-Nov-20	GULBARGA	66	ITTAGI-HIREHADGALLI	HIREHADAGALLI_66	18:12	18:20	00:08	LINE FAULT
608	21-Nov-20	GULBARGA	66	ITTAGI-HIREHADGALLI	HIREHADAGALLI_66	21:17	21:23	00:06	LINE FAULT
609	21-Nov-20	GULBARGA	66	ITTAGI-HIREHADGALLI	HIREHADAGALLI_66	22:30	22:35	00:05	LINE FAULT
610	21-Nov-20	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALLI_66	16:33	16:49	00:16	LINE FAULT
611	21-Nov-20	GULBARGA	110	HV1	KUDITINI_110	20:33	22:55	02:22	TRANSFORMER FAULT
612	21-Nov-20	GULBARGA	110	MALLAT-BYGAWAT	BYGAWAT_110	12:28	12:36	00:08	LINE FAULT
613	21-Nov-20	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	04:50	05:00	00:10	MAIN SUPPLY FAILURE
614	21-Nov-20	HASSAN	66	HV2	HIRISAVE_66	12:30	13:54	01:24	LINE CLEAR AVOIDED
615	21-Nov-20	HASSAN	66	HV2	HIRISAVE_66	14:17	14:26	00:09	LINE CLEAR AVOIDED
616	21-Nov-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	08:19	10:23	02:04	MAIN SUPPLY FAILURE
617	21-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
618	21-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
619	21-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
620	21-Nov-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	7:32(21.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
621	21-Nov-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	08:27	11:01	02:34	LINE CLEAR AVOIDED
622	21-Nov-20	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	7:34(21.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
623	21-Nov-20	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	10:23	14:11	03:48	LINE CLEAR AVOIDED
624	21-Nov-20	HASSAN	110	HV1	MRSMSG_220	12:20	12:34	00:14	HAND TRIPPED
625	21-Nov-20	HASSAN	110	HV1	GURUPURA_110	16:55	17:11	00:16	TRANSFORMER FAULT
626	21-Nov-20	HASSAN	110	HV1	KADUR_220	10:41	12:47	02:06	LINE CLEAR AVOIDED
627	21-Nov-20	HASSAN	110	HV1	SAGARA_110	10:26	10:54	00:28	LINE CLEAR AVOIDED
628	21-Nov-20	HASSAN	110	HV1	SHIVAPURA_110	11:02	11:56	00:54	LINE CLEAR AVOIDED
629	21-Nov-20	HASSAN	110	HV1	SHIVAPURA_110	13:28	13:36	00:08	LINE CLEAR AVOIDED
630	21-Nov-20	HASSAN	110	HV1	SHIVAPURA_110	13:58	14:59	01:01	LINE CLEAR AVOIDED
631	21-Nov-20	HASSAN	110	HV2	BAIKAMPADI_110	15:33	15:40	00:07	TRANSFORMER FAULT
632	21-Nov-20	HASSAN	110	HV5	BAIKAMPADI_110	15:33	15:40	00:07	TRANSFORMER FAULT
633	21-Nov-20	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
634	21-Nov-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:41	11:18	00:37	MAIN SUPPLY FAILURE
635	21-Nov-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	07:53	18:07	10:14	LINE CLEAR AVAILED
636	21-Nov-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	07:53	18:10	10:17	NFBC ISSUED
637	21-Nov-20	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	13:05	13:37	00:32	HAND TRIPPED
638	21-Nov-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:06	13:35	00:29	HAND TRIPPED
639	21-Nov-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	09:19	11:59	02:40	NFBC ISSUED
640	21-Nov-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:34	15:03	00:29	LINE FAULT
641	21-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:05	13:37	00:32	HAND TRIPPED
642	21-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:12	13:48	01:36	LINE CLEAR AVAILED
643	21-Nov-20	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	12:11	13:45	01:34	LINE CLEAR AVAILED
644	21-Nov-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:06	13:35	00:29	HAND TRIPPED
645	21-Nov-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	09:19	11:59	02:40	LINE CLEAR AVAILED
646	21-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	00:07	07:03	06:56	LINE CLEAR AVAILED
647	21-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
648	21-Nov-20	MYSURU	66	DEVNUR(MYS)-RAJEEV NAGARA	DEVANOORMYS_66	10:25	17:05	6:40	LINE CLEAR AVAILED
649	21-Nov-20	MYSURU	66	DEVNUR(MYS)-VAJMANAGALA	DEVANOORMYS_66	10:19	17:05	6:45	LINE CLEAR AVAILED
650	21-Nov-20	MYSURU	66	DK MAIDANA-JYOTHINAGARA	DKMAIDANA_66	10:09	17:20	7:11	LINE CLEAR AVAILED
651	21-Nov-20	MYSURU	66	DK MAIDANA-KADAKOLA	DKMAIDANA_66	10:09	17:47	7:37	LINE CLEAR AVAILED
652	21-Nov-20	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	9:56	12:00	2:04	LINE CLEAR AVAILED
653	21-Nov-20	MYSURU	66	HV1	KADABALLY_66	10:52	12:45	1:53	LINE CLEAR AVAILED
654	21-Nov-20	MYSURU	66	HV1	MADESWARAPURA_66	11:06	14:47	3:40	LINE CLEAR AVAILED
655	21-Nov-20	MYSURU	66	HV1	SANIVARASANTHE_66	15:02	15:09	0:07	TRANSFORMER FAULT
656	21-Nov-20	MYSURU	66	HV1	SRIRANGAPATNA_66	15:22	16:53	1:30	LINE CLEAR AVAILED
657	21-Nov-20	MYSURU	66	HV2	SRIRANGAPATNA_66	15:22	17:13	1:50	LINE CLEAR AVAILED
658	21-Nov-20	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	10:40	12:35	1:55	LINE CLEAR AVAILED
659	21-Nov-20	MYSURU	66	KADAKOLA-NANJIANGUDU 1	NO STATIONS EFFECTED	11:26	11:42	0:16	HAND TRIPPED
660	21-Nov-20	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	6:18	6:22	0:04	LINE FAULT
661	21-Nov-20	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	18:12	18:18	0:06	LINE FAULT
662	21-Nov-20	MYSURU	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	10:11	12:29	2:17	LINE CLEAR AVAILED
663	21-Nov-20	MYSURU	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	18:13	18:21	0:08	LINE FAULT
664	21-Nov-20	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	15:08	15:19	0:11	LINE FAULT
665	21-Nov-20	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	17:26	17:42	0:16	LINE FAULT
666	21-Nov-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 TARIPURA_66 GAMANAHALLY_66	8:30	8:35	0:05	LINE FAULT
667	21-Nov-20	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66	13:41	14:01	0:19	LINE FAULT
668	21-Nov-20	MYSURU	66	VAJMANGALA-DEVNUR(MYS)	DEVANOORMYS_66	10:08	16:41	6:32	LINE CLEAR AVAILED
669	21-Nov-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	15:56	16:56	0:59	MAIN SUPPLY FAILURE
670	21-Nov-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	17:03	17:04	0:01	MAIN SUPPLY FAILURE
671	21-Nov-20	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	17:59	18:06	0:06	LINE FAULT
672	21-Nov-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	18:11	18:31	0:20	LINE FAULT
673	21-Nov-20	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:11	18:31	0:20	LINE FAULT
674	21-Nov-20	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:04	16:54	0:50	MAIN SUPPLY FAILURE
675	21-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	12:08	18:26	6:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
676	21-Nov-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	15:54	16:53	0:59	LINE CLEAR AVAILED
677	21-Nov-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	17:03	17:12	0:09	LINE FAULT
678	21-Nov-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	23:02	23:07	0:05	LINE FAULT
679	21-Nov-20	TUMKUR	66	KUNDUR- HONNALI	KUNDUR_66	16:00	16:37	0:36	LINE FAULT
680	21-Nov-20	TUMKUR	66	TR-1	DEVARAHALLI_66	16:04	16:54	0:50	MAIN SUPPLY FAILURE
681	21-Nov-20	TUMKUR	66	TR-1	LINGADAHALLI TMK2_66	16:49	17:29	0:40	LINE CLEAR AVAILED
682	21-Nov-20	TUMKUR	66	TR-1	PAVAGADA_220	19:12	19:20	0:07	TRANSFORMER FAULT
683	21-Nov-20	TUMKUR	66	TR-2	HOLALKERE_66	13:02	13:05	0:03	TRANSFORMER FAULT
684	21-Nov-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	15:13	15:51	0:37	LINE CLEAR AVAILED
685	21-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
686	21-Nov-20	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	15:13	15:50	0:37	LINE CLEAR AVAILED
687	22-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
688	22-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
689	22-Nov-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)	13:30 (22.11.2020)	30:40hrs	TRANSFORMER CHARGED
690	22-Nov-20	BAGALKOT	110	110/11KV, HV1	ITNAL_110	11:50	11:55	0:05	HAND TRIPPED
691	22-Nov-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	15:16	17:28	2:12	LINE CLEAR AVAILED
692	22-Nov-20	BAGALKOT	110	110/11KV, HV1&2	GAJENDRAGAD_110	14:11	15:39	1:28	LINE CLEAR AVAILED
693	22-Nov-20	BAGALKOT	110	110/33KV, HV3	RANEENNUR_220	10:31	11:35	1:04	TRANSFORMER FAULT
694	22-Nov-20	BAGALKOT	110	110/33KV, HV3	RANEENNUR_220, KUPPELUR_33, GUDUR- MAIDUR_33, HALGERI_33	14:46	14:51	0:05	TRANSFORMER FAULT
695	22-Nov-20	BAGALKOT	110	110/33KV, HV3	NO STATION AFFECTED RANEENNUR_220	15:26	19:49	4:23	LINE CLEAR AVAILED
696	22-Nov-20	BAGALKOT	110	110/33KV, HV4	RANEENNUR_220	10:08	10:48	0:40	TRANSFORMER FAULT
697	22-Nov-20	BAGALKOT	110	110/33KV, HV4	RANEENNUR_220, KUPPELUR_33, GUDUR- MAIDUR_33, HALGERI_33	14:46	14:50	0:04	TRANSFORMER FAULT
698	22-Nov-20	BAGALKOT	110	220/110 KV, LV1	STATION NOT AFFECTED BELGAUM_220	10:50	14:13	3:23	LINE CLEAR AVAILED
699	22-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED
700	22-Nov-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	13:59	15:34	1:35	LINE CLEAR AVAILED
701	22-Nov-20	BAGALKOT	110	BIDNAL-GADAG ROAD	STATION NOT AFFECTED GADAG ROAD_110	6:50:00 AM (21.11.2020)	13:02 (22.11.2020)	30:52hrs	LINE CHARGED
702	22-Nov-20	BAGALKOT	110	GADAGROAD-BIDNAL220	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)	13:10 (22.11.2020)	30:20hrs	LINE CHARGED
703	22-Nov-20	BAGALKOT	110	GADAGROAD-GOPANAKOPPA	STATION NOT AFFECTED GADAG ROAD_110	6:50 (21.11.2020)	13:08 (22.11.2020)	30:18hrs	LINE CHARGED
704	22-Nov-20	BAGALKOT	110	GAJENDRAGAD-HANAMSAGAR(KUSHATAGI)	STATION NOT AFFECTED GAJENDRAGAD_110	12.05 (08.11.2020)	13:53 (22.11.2020)	337:48hrs	LINE CHARGED
705	22-Nov-20	BAGALKOT	110	GAJENDRAGAD-HANAMSAGAR(KUSHATAGI)	STATION NOT AFFECTED GAJENDRAGAD_110	15:24	16:03	0:39	HAND TRIPPED
706	22-Nov-20	BAGALKOT	110	GAJENDRAGAD-RON1&2	GAJENDRAGAD_110	14:10	15:35	1:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
707	22-Nov-20	BAGALKOT	110	GOPANAKOPPA-GADAGROAD	GADAG ROAD_110	6:05 (21.11.2020)	13:18 (22.11.2020)	31:13hrs	LINE CHARGED
708	22-Nov-20	BAGALKOT	110	GOPANAKOPPA-NAVALAGUND(BIDNAL)	NAVALAGUND_110	9:52	13:08	3:16	LINE CLEAR AVAILED
709	22-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
710	22-Nov-20	BAGALKOT	110	ITNAL-RAIBAG1 (HIDAKAL2)	RAIBAG_110	0:33	0:40	0:07	LINE FAULT
711	22-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
712	22-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
713	22-Nov-20	BAGALKOT	110	NAREGAL- RON	NO STATION AFFECTED RON_110	13:53	15:21	1:28	LINE CLEAR AVAILED
714	22-Nov-20	BAGALKOT	110	NOKAR SOLAR- NAVALGUND	NO STATION AFFECTED NAVALGUND_110	15:32	19:29	3:57	LINE CLEAR AVAILED
715	22-Nov-20	BAGALKOT	110	RANEENNUR- AREMALLAPUR	NO STATION AFFECTED HONNATTI_110, AREMALLAUR_110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
716	22-Nov-20	BAGALKOT	220	220/110 KV, HV1	STATION NOT AFFECTED BELGAUM_220	10:50	14:12	3:22	LINE CLEAR AVAILED
717	22-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
718	22-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
719	22-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
720	22-Nov-20	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	18:15 (21.11.2020)	17:45 (22.11.2020)	23:30hrs	LINE CHARGED
721	22-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
722	22-Nov-20	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	16:55 (21.11.2020)	13:57 (22.11.2020)	21:02hrs	LINE CHARGED
723	22-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
724	22-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
725	22-Nov-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	17:08	17:18	00:10	LOAD CHANGE OVER
726	22-Nov-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	10:46	10:55	00:09	LOAD CHANGE OVER
727	22-Nov-20	BENGALURU	66	HV1	YARANDANAHALLI 220	10:55	10:58	00:03	LOAD CHANGE OVER
728	22-Nov-20	BENGALURU	66	HV1	YARANDANAHALLI 220	13:53	14:10	00:17	LOAD CHANGE OVER
729	22-Nov-20	BENGALURU	66	HV1	SANKALGERE	09:00	17:32	08:32	LINE CLEAR AVAILED
730	22-Nov-20	BENGALURU	66	HV1	D CROSS	08:26	08:38	00:12	TRANSFORMER FAULT
731	22-Nov-20	BENGALURU	66	HV1	BANGARPET	15:57	16:47	00:50	LINE CLEAR AVAILED
732	22-Nov-20	BENGALURU	66	HV2	GUNDAMGERE	19:49	20:02	00:13	TRANSFORMER FAULT
733	22-Nov-20	BENGALURU	66	HV3	HSR LAYOUT 220	23:10	23:25	00:15	TRANSFORMER FAULT
734	22-Nov-20	BENGALURU	66	HV3	YARANDANAHALLI 220	10:55	10:58	00:03	LOAD CHANGE OVER
735	22-Nov-20	BENGALURU	66	HV3	YARANDANAHALLI 220	13:53	14:10	00:17	LOAD CHANGE OVER
736	22-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	03:47	03:53	00:06	LINE FAULT
737	22-Nov-20	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	09:00	17:32	08:32	LINE CLEAR AVAILED
738	22-Nov-20	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	10:55	10:58	00:03	LOAD CHANGE OVER
739	22-Nov-20	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	13:53	14:10	00:17	LOAD CHANGE OVER
740	22-Nov-20	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA	TIMES OF INDIA	10:55	10:58	00:03	LOAD CHANGE OVER
741	22-Nov-20	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA	TIMES OF INDIA	13:47	13:51	00:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
742	22-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVALIED
743	22-Nov-20	BENGALURU	220	HV2	YARANDANAHALLI 220	10:55	10:58	00:03	LOAD CHANGE OVER
744	22-Nov-20	BENGALURU	220	HV2	YARANDANAHALLI 220	13:47	13:51	00:04	LOAD CHANGE OVER
745	22-Nov-20	BENGALURU	220	HV3	YARANDANAHALLI 220	10:55	10:58	00:03	LOAD CHANGE OVER
746	22-Nov-20	BENGALURU	220	HV3	YARANDANAHALLI 220	13:47	13:51	00:04	LOAD CHANGE OVER
747	22-Nov-20	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	NO STATION AFFECTED	11:32	13:47	02:15	LINE CLEAR AVALIED
748	22-Nov-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	07:40	08:50	01:10	LINE FAULT
749	22-Nov-20	GULBARGA	66	HV1	HAMPASAGAR_66	09:25	09:32	00:07	TRANSFORMER FAULT
750	22-Nov-20	GULBARGA	66	HV1	HANASI_66	18:03	18:33	00:30	TRANSFORMER FAULT
751	22-Nov-20	GULBARGA	66	HV1	HANASI_66	07:40	09:00	01:20	TRANSFORMER FAULT
752	22-Nov-20	GULBARGA	66	HV1	HANASI_66	09:10	09:25	00:15	TRANSFORMER FAULT
753	22-Nov-20	GULBARGA	66	ITTAGI-HIREHADGALLI	HIREHADAGALLI_66	22:25	22:37	00:12	LINE FAULT
754	22-Nov-20	GULBARGA	110	HANUMNAL-HIREGONNAGAR	HANUMANAL_110	04:35	05:15	00:40	MAIN SUPPLY FAILURE
755	22-Nov-20	GULBARGA	110	HANUMNAL-HIREGONNAGAR	HANUMANAL_110	14:05	16:05	02:00	MAIN SUPPLY FAILURE
756	22-Nov-20	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	04:27	04:37	00:10	MAIN SUPPLY FAILURE
757	22-Nov-20	GULBARGA	110	HV1	ALIPUR_220	18:38	18:51	00:13	TRANSFORMER FAULT
758	22-Nov-20	GULBARGA	110	HV2	SINDHANOOR_110	09:33	09:47	00:14	TRANSFORMER FAULT
759	22-Nov-20	GULBARGA	110	HV2	SINDHANOOR_110	09:47	09:50	00:03	TRANSFORMER FAULT
760	22-Nov-20	GULBARGA	110	HV2	SINDHANOOR_110	09:50	09:57	00:07	TRANSFORMER FAULT
761	22-Nov-20	GULBARGA	110	HV2	NALWAR_110	12:26	13:12	00:46	TRANSFORMER FAULT
762	22-Nov-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	01:55	02:03	00:08	LINE FAULT
763	22-Nov-20	GULBARGA	110	KAPNOOR-HBD2	ALAND_110,KADGANCHI_110	04:25	04:33	00:08	LINE FAULT
764	22-Nov-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	14:45			LINE OPEN:LINE CLEAR AVALIED
765	22-Nov-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	04:25	04:33	00:08	LINE FAULT
766	22-Nov-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	14:10	14:45	00:35	LINE FAULT
767	22-Nov-20	GULBARGA	110	MALLAT-BYGAWAT1	BYGAWAT_110	06:52	07:02	00:10	LINE FAULT
768	22-Nov-20	GULBARGA	110	MALLAT-BYGAWAT2	MADLAPUR_110,MANVI_110	02:39	02:49	00:10	LINE FAULT
769	22-Nov-20	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110,KORWAR_TEMPLE_110, RAJSHREE_CEMENTS,	11:40(17.11.2020)			LINE OPEN:LINE CLEAR AVALIED
770	22-Nov-20	GULBARGA	110	SEDAM-VICATASGAR CEMENTS	VICATASAGAR CEMENTS_IPP	03:15	03:29	00:14	LINE FAULT
771	22-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
772	22-Nov-20	GULBARGA	220	SHAHPUR-LINGSUGUR	SHAHPUR_220	05:25	14:25	09:00	LINE CLEAR AVALIED
773	22-Nov-20	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	20:45(22.11.2020)			LINE OPEN:LINE CLEAR AVALIED
774	22-Nov-20	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	20:45	20:55	00:10	MAIN SUPPLY FAILURE
775	22-Nov-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	20:47	20:54	00:07	LINE FAULT
776	22-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
777	22-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
778	22-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
779	22-Nov-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	7:32(21.11.2020)	15:23 (22.11.2020)	31:50 hrs	LINE CHARGED
780	22-Nov-20	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	05:18	05:33	00:15	LINE FAULT
781	22-Nov-20	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	7:34(21.11.2020)	15:24(22.11.2020)	31:49 hrs	NFBC ISSUED
782	22-Nov-20	HASSAN	110	HV1	ANANDAPURA_110	09:12	09:19	00:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
783	22-Nov-20	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
784	22-Nov-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:12	15:12	02:00	LINE FAULT
785	22-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
786	22-Nov-20	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	5:27	5:38	0:10	LINE FAULT
787	22-Nov-20	MYSURU	66	HV1	MANDGERE_66	10:31	11:10	0:38	LINE CLEAR AVAILED
788	22-Nov-20	MYSURU	66	KADAKOLA-MANTAGALLI	NO STATIONS EFFECTED	5:04	16:45	11:40	LINE CLEAR AVAILED
789	22-Nov-20	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	5:00	16:48	11:48	LINE CLEAR AVAILED
790	22-Nov-20	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	10:15	15:47	5:32	NFBC ISSUED
791	22-Nov-20	MYSURU	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	5:13	10:43	5:29	LINE CLEAR AVAILED
792	22-Nov-20	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	KOLLEGALA_66	10:31	10:32	0:01	HAND TRIPPED
793	22-Nov-20	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:52	14:53	5:01	LINE CLEAR AVAILED
794	22-Nov-20	MYSURU	66	KOLLEGALA-THALKADU	NO STATIONS EFFECTED	10:28	14:58	4:30	LINE CLEAR AVAILED
795	22-Nov-20	MYSURU	66	KR PETE-MAHADESHWARAPURA	G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66 BOGADHI MANDYA_66	1:03	1:13	0:09	LINE FAULT
796	22-Nov-20	MYSURU	66	MADHUVANAHALLI -PG PALYA	PGPALYA_66	5:58	6:06	0:08	LINE FAULT
797	22-Nov-20	MYSURU	66	MADHUVANAHALLI -PG PALYA	PGPALYA_66	9:58	10:05	0:07	LINE FAULT
798	22-Nov-20	MYSURU	66	THANDYA-KADAKOLA	THANDYA_66	10:00	17:44	7:44	LINE CLEAR AVAILED
799	22-Nov-20	MYSURU	66	THANDYA-NANJUNGUD	THANDYA_66	10:00	17:46	7:45	LINE CLEAR AVAILED
800	22-Nov-20	MYSURU	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:01	17:07	0:05	LINE FAULT
801	22-Nov-20	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	2:34	2:44	0:10	LINE FAULT
802	22-Nov-20	MYSURU	220	HV1	KADAKOLA_220	10:30	13:33	3:03	LINE CLEAR AVAILED
803	22-Nov-20	TUMKUR	66	AVAREGERE_66kv-DAVANGERE SRS	AVAREGERE_66	8:00	8:22	0:21	LINE FAULT
804	22-Nov-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	8:00	8:18	0:17	LINE FAULT
805	22-Nov-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:31	12:54	0:23	LINE FAULT
806	22-Nov-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	1:53	4:44	2:50	LINE FAULT
807	22-Nov-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:57	4:59	0:01	LINE FAULT
808	22-Nov-20	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	18:08	18:18	0:09	LINE FAULT
809	22-Nov-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:23	8:26	0:03	MAIN SUPPLY FAILURE
810	22-Nov-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:24	11:19	0:55	LINE FAULT
811	22-Nov-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:58	10:07	0:08	LINE FAULT
812	22-Nov-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	21:20	21:28	0:07	LINE FAULT
813	22-Nov-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	1:53	3:28	1:35	LINE FAULT
814	22-Nov-20	TUMKUR	66	TR-1	CHAWANAKUPPE_66	6:55	11:34	4:39	TRANSFORMER FAULT
815	22-Nov-20	TUMKUR	66	TR-1	DYAVARANAHALLI_66	1:06	1:18	0:12	TRANSFORMER FAULT
816	22-Nov-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	18:27	18:34	0:07	TRANSFORMER FAULT
817	22-Nov-20	TUMKUR	66	TR-1	RANGENAHALLI_66	9:30	10:21	0:51	HAND TRIPPED
818	22-Nov-20	TUMKUR	66	TR-2	AVAREGERE_66	8:00	8:22	0:21	TRANSFORMER FAULT
819	22-Nov-20	TUMKUR	66	TR-2	AVAREGERE_66	12:30	12:55	0:25	TRANSFORMER FAULT
820	22-Nov-20	TUMKUR	66	TR-2	KORA_66	16:09	16:19	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
821	22-Nov-20	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	7:55	18:58	11:02	LINE CLEAR AVAILED
822	22-Nov-20	TUMKUR	110	SHETTIKERE- HANDANKERE	SHETYKERE_110	10:07	15:00	4:52	LINE CLEAR AVAILED
823	22-Nov-20	TUMKUR	110	TR-1	SHETYKERE_110	10:10	15:08	4:58	LINE CLEAR AVAILED
824	22-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
825	22-Nov-20	TUMKUR	110	TR-2	SHETYKERE_110	10:07	15:03	4:55	LINE CLEAR AVAILED
826	23-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
827	23-Nov-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:05 (14.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
828	23-Nov-20	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAYNAGAR_110	18:02	18:17	0:15	TRANSFORMER FAULT
829	23-Nov-20	BAGALKOT	110	110/11KV, HV2	BYADAGI_110	10:52	12:37	1:45	TRANSFORMER FAULT
830	23-Nov-20	BAGALKOT	110	110/11KV, HV2	BYADAGI_110	12:38	12:41	0:03	LINE CLEAR AVAILED
831	23-Nov-20	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,RSNG_33,KUPPELLUR_3 3,GUDGUR MAIDUR_33,HALAGERI_33	10:10	10:20	0:10	TRANSFORMER FAULT
832	23-Nov-20	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,RSNG_33,KUPPELLUR_3 3,GUDGUR MAIDUR_33,HALAGERI_33	10:40	10:50	0:10	TRANSFORMER FAULT
833	23-Nov-20	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,RSNG_33,KUPPELLUR_3 3,GUDGUR MAIDUR_33,HALAGERI_33	14:12	14:15	0:03	TRANSFORMER FAULT
834	23-Nov-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
835	23-Nov-20	BAGALKOT	110	220/110KV, LV2	NARENDRA_220	13:44	14:47	1:03	LINE CLEAR AVAILED
836	23-Nov-20	BAGALKOT	110	BAGALKOT220-KALADAGI	KALADAGI_110	16:44	16:55	0:11	HAND TRIPPED
837	23-Nov-20	BAGALKOT	110	BAGALKOT220-NEERBUDIHAL	NEERABUDIHAL_110	16:44	16:55	0:11	HAND TRIPPED
838	23-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN:LINE CLEAR AVAILED
839	23-Nov-20	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	12:46	12:53	0:07	HAND TRIPPED
840	23-Nov-20	BAGALKOT	110	GAMESH-RON	RON_110	11:33	11:59	0:26	HAND TRIPPED
841	23-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
842	23-Nov-20	BAGALKOT	110	HUBLI220-BIDNAL2	STATION NOT AFFECTED HUBLI_220	10:59	13:44	2:45	LINE CLEAR AVAILED
843	23-Nov-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
844	23-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
845	23-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
846	23-Nov-20	BAGALKOT	110	NAREGAL-RON	RON_110	11:39	11:43	0:04	HAND TRIPPED
847	23-Nov-20	BAGALKOT	110	NARENDRA220-KUD DHARWAD1	STATION NOT AFFECTED KUD DHARWAD_110	13:08	14:52	1:44	LOAD CURTAILMENT
848	23-Nov-20	BAGALKOT	110	RANEENNUR- AREMALLAPUR	NO STATION AFFECTED HONNATTI_110, AREMALLAUR_110	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
849	23-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
850	23-Nov-20	BAGALKOT	220	220/110KV, HV2	NARENDRA_220	13:44	14:46	1:02	LINE CLEAR AVAILED
851	23-Nov-20	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)	20:07 (23.11.2020)	77:05hrs	TRANSFORMER CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
852	23-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)	16:54 (23.11.2020)	1030:19hrs	TRANSFORMER CHARGED
853	23-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
854	23-Nov-20	BAGALKOT	220	GADAG-BAGALKOT 1	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)	20:02 (23.11.2020)	76:55hrs	LINE CHARGED
855	23-Nov-20	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)	20:02 (23.11.2020)	76:55hrs	LINE CHARGED
856	23-Nov-20	BAGALKOT	220	GADAG-HARTI 1	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)	20:06 (23.11.2020)	77:03hrs	LINE CHARGED
857	23-Nov-20	BAGALKOT	220	GADAG-HARTI 2	STATION NOT AFFECTED GADAG_220	11:09 (21.11.2020)	20:06 (23.11.2020)	77:03hrs	LINE CHARGED
858	23-Nov-20	BAGALKOT	220	NARENDRA-KANABARGI1&2	NARENDRA_220	8:15 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
859	23-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY1	NO STATION AFFECTED SIRSI_220	16:24 (21.11.2020)			LOAD CURTAILMENT
860	23-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY2	NO STATION AFFECTED SIRSI_220	16:24 (21.11.2020)			LOAD CURTAILMENT
861	23-Nov-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
862	23-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
863	23-Nov-20	BENGALURU	66	HENNUR CORSS - SHOBHA CITY	HENNUR CROSS	17:03	17:06	00:03	LOAD CHANGE OVER
864	23-Nov-20	BENGALURU	66	HV1	GOKULA	10:12	10:15	00:03	LINE CLEAR AVOIDED
865	23-Nov-20	BENGALURU	66	HV2	GOKULA	12:30	12:35	00:05	LINE CLEAR AVOIDED
866	23-Nov-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
867	23-Nov-20	GULBARGA	66	ITTAGI-HIREHADAGALLI	HIREHADAGALLI_66	03:55	04:00	00:05	LINE FAULT
868	23-Nov-20	GULBARGA	66	ITTAGI-HIREHADAGALLI	HIREHADAGALLI_66	06:30	06:45	00:15	LINE FAULT
869	23-Nov-20	GULBARGA	66	ITTAGI-HIREHADAGALLI	HIREHADAGALLI_66	14:07	14:25	00:18	LINE CLEAR AVOIDED
870	23-Nov-20	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110	19:33	19:40	00:07	LINE FAULT
871	23-Nov-20	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	11:40	11:50	00:10	MAIN SUPPLY FAILURE
872	23-Nov-20	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	12:30	12:40	00:10	MAIN SUPPLY FAILURE
873	23-Nov-20	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	11:40	11:50	00:10	MAIN SUPPLY FAILURE
874	23-Nov-20	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	12:30	12:40	00:10	MAIN SUPPLY FAILURE
875	23-Nov-20	GULBARGA	110	HUMNABAD-SASTAPUR	SASTAPUR_110	23:30	23:40	00:10	LINE FAULT
876	23-Nov-20	GULBARGA	110	HV1	HANUMANAL_110	11:40	11:55	00:15	TRANSFORMER FAULT
877	23-Nov-20	GULBARGA	110	HV1	HANUMANAL_110	11:40	11:55	00:15	TRANSFORMER FAULT
878	23-Nov-20	GULBARGA	110	HV1	HALBARGA_220	15:40	18:50	03:10	LINE CLEAR AVOIDED
879	23-Nov-20	GULBARGA	110	HV2	HANUMANAL_110	11:45	11:55	00:10	TRANSFORMER FAULT
880	23-Nov-20	GULBARGA	110	HV2	HANUMANAL_110	11:45	11:55	00:10	TRANSFORMER FAULT
881	23-Nov-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	14:45			LINE OPEN:LINE CLEAR AVAILED
882	23-Nov-20	GULBARGA	110	MALLAT-BYGAWAT1	BYGAWAT_110	21:25	21:35	00:10	LINE FAULT
883	23-Nov-20	GULBARGA	110	MALLAT-BYGAWAT2	MADLAPUR_110,MANVI_110	21:12	21:22	00:10	LINE FAULT
884	23-Nov-20	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110,ALKOD_11,BYAGWAT_110,VAL KAMDINNI_110	04:20	04:37	00:17	LINE FAULT
885	23-Nov-20	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110,ALKOD_11,BYAGWAT_110,VAL KAMDINNI_110	04:20	04:37	00:17	LINE FAULT
886	23-Nov-20	GULBARGA	110	RAICHUR-SINDHNOOR2	KURUDICROSS_110,MADALAPUR_110,MAN VI_110	04:20	04:35	00:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
887	23-Nov-20	GULBARGA	110	RAICHUR-SINDHNOOR2	KURUDICROSS_110,MADALAPUR_110,MAN VI_110	04:20	04:35	00:15	LINE FAULT
888	23-Nov-20	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	23:30	23:40	00:10	MAIN SUPPLY FAILURE
889	23-Nov-20	GULBARGA	110	RAJESHWAR-WARDHA	RAJESHWAR_110	17:53	23:29	05:36	LINE CLEAR AVAILED
890	23-Nov-20	GULBARGA	110	SANKLAPUR-MUNIRABAD	SANKLAPUR_110	08:50	14:50	06:00	MAIN SUPPLY FAILURE
891	23-Nov-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	00:30	00:40	00:10	LINE FAULT
892	23-Nov-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	05:10	05:15	00:05	LINE FAULT
893	23-Nov-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	00:30	00:40	00:10	LINE FAULT
894	23-Nov-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	05:10	05:15	00:05	LINE FAULT
895	23-Nov-20	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, KORWAR_TEMPLE_110, RAJSHREE CEMENTS,	11:40(17.11.2020)			LINE OPEN:LINE CLEAR AVAILED
896	23-Nov-20	GULBARGA	220	HALBURGA-HUMNABAD2	HALBURGA_220	20:30	20:48	00:18	LINE FAULT
897	23-Nov-20	GULBARGA	220	HALBURGA-HUMNABAD2	HALBURGA_220	21:14	21:17	00:03	LINE FAULT
898	23-Nov-20	GULBARGA	220	HALBURGA-HUMNABAD2	HALBURGA_220	20:30	21:50	01:20	LINE FAULT
899	23-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
900	23-Nov-20	GULBARGA	220	HV1	HALBURGA_220	20:30	20:55	00:25	TRANSFORMER FAULT
901	23-Nov-20	GULBARGA	220	HV2	RAICHUR_220	10:42	14:14	03:32	LINE CLEAR AVAILED
902	23-Nov-20	GULBARGA	220	HV2	RAICHUR_220	10:42	14:14	03:32	LINE CLEAR AVAILED
903	23-Nov-20	GULBARGA	220	LINGAPUR-JVSL-2	JVSL_220	09:11	15:12	06:01	LINE CLEAR AVAILED
904	23-Nov-20	GULBARGA	220	LINGAPUR-JVSL-2	JVSL_220	09:11	15:12	06:01	LINE CLEAR AVAILED
905	23-Nov-20	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	10:25			LINE OPEN:LINE CLEAR AVAILED
906	23-Nov-20	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	10:25	18:43	08:18	LINE CLEAR AVAILED
907	23-Nov-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	17:26	18:06	00:40	LINE CLEAR AVAILED
908	23-Nov-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	18:50	19:09	00:19	LINE CLEAR AVAILED
909	23-Nov-20	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	20:45(22.11.2020)	12:24(23.11.2020)	15:38 hrs	LINE CHARGED
910	23-Nov-20	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	16:09	16:56	00:47	LINE CLEAR AVAILED
911	23-Nov-20	HASSAN	66	HASSN220-BELUR	HASSAN_220	10:26	16:15	05:49	LINE CLEAR AVAILED
912	23-Nov-20	HASSAN	66	HASSN220-HN PURA	HASSAN_220	16:09	17:02	00:53	LINE CLEAR AVAILED
913	23-Nov-20	HASSAN	66	HASSN220-HSN66	HASSAN_220	15:58	16:06	00:08	LINE CLEAR AVAILED
914	23-Nov-20	HASSAN	66	HASSN220-MALLALI	HASSAN_220	16:09	16:59	00:50	LINE CLEAR AVAILED
915	23-Nov-20	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	11:06	11:50	00:44	HAND TRIPPED
916	23-Nov-20	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	15:58	16:55	00:57	LINE CLEAR AVAILED
917	23-Nov-20	HASSAN	66	HASSN220-SKPURA	HASSAN_220	16:09	17:03	00:54	LINE CLEAR AVAILED
918	23-Nov-20	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	10:25	10:38	00:13	LINE CLEAR AVAILED
919	23-Nov-20	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	15:05	16:13	01:08	LINE CLEAR AVAILED
920	23-Nov-20	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	12:38	13:31	00:53	LINE CLEAR AVAILED
921	23-Nov-20	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	14:37	15:13	00:36	LINE CLEAR AVAILED
922	23-Nov-20	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	12:38	13:30	00:52	LINE CLEAR AVAILED
923	23-Nov-20	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	14:36	15:12	00:36	LINE CLEAR AVAILED
924	23-Nov-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	12:38	13:30	00:52	LINE CLEAR AVAILED
925	23-Nov-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	14:36	15:12	00:36	LINE CLEAR AVAILED
926	23-Nov-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	12:38	13:30	00:52	LINE CLEAR AVAILED
927	23-Nov-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	14:36	15:12	00:36	LINE CLEAR AVAILED
928	23-Nov-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	12:39	13:31	00:52	LINE CLEAR AVAILED
929	23-Nov-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	14:37	15:13	00:36	LINE CLEAR AVAILED
930	23-Nov-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:38	13:31	00:53	LINE CLEAR AVAILED
931	23-Nov-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	14:37	15:13	00:36	LINE CLEAR AVAILED
932	23-Nov-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:38	13:31	00:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
933	23-Nov-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	14:37	15:13	00:36	LINE CLEAR AVAILED
934	23-Nov-20	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	12:39	13:30	00:51	LINE CLEAR AVAILED
935	23-Nov-20	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	14:37	15:12	00:35	LINE CLEAR AVAILED
936	23-Nov-20	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	12:39	13:31	00:52	LINE CLEAR AVAILED
937	23-Nov-20	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	14:37	15:13	00:36	LINE CLEAR AVAILED
938	23-Nov-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	12:41	13:47	01:06	MAIN SUPPLY FAILURE
939	23-Nov-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	14:49	15:18	00:29	MAIN SUPPLY FAILURE
940	23-Nov-20	HASSAN	66	HV1	HOLENARASIPURA_220	12:40	13:28	00:48	LINE CLEAR AVAILED
941	23-Nov-20	HASSAN	66	HV1	HOLENARASIPURA_220	14:37	15:11	00:34	LINE CLEAR AVAILED
942	23-Nov-20	HASSAN	66	HV1	HNPURA_66	12:40	13:34	00:54	MAIN SUPPLY FAILURE
943	23-Nov-20	HASSAN	66	HV1	HNPURA_66	14:40	15:13	00:33	MAIN SUPPLY FAILURE
944	23-Nov-20	HASSAN	66	HV1	HOLEHONNUR_66	11:05	12:12	01:07	LINE CLEAR AVAILED
945	23-Nov-20	HASSAN	66	HV1	MAGGE_66	16:10	17:04	00:54	MAIN SUPPLY FAILURE
946	23-Nov-20	HASSAN	66	HV1	MALALI_66	12:40	13:32	00:52	MAIN SUPPLY FAILURE
947	23-Nov-20	HASSAN	66	HV1	MALALI_66	14:38	15:20	00:42	MAIN SUPPLY FAILURE
948	23-Nov-20	HASSAN	66	HV1	MATTNVILE_66	14:55	15:20	00:25	LINE CLEAR AVAILED
949	23-Nov-20	HASSAN	66	HV2	HIRISAVE_66	12:21	14:52	02:31	LINE CLEAR AVAILED
950	23-Nov-20	HASSAN	66	HV2	HNPURA_66	12:40	13:34	00:54	MAIN SUPPLY FAILURE
951	23-Nov-20	HASSAN	66	HV2	HNPURA_66	14:40	15:16	00:36	MAIN SUPPLY FAILURE
952	23-Nov-20	HASSAN	66	HV2	MAGGE_66	16:10	17:04	00:54	MAIN SUPPLY FAILURE
953	23-Nov-20	HASSAN	66	LV1	HASSAN_220	16:10	16:55	00:45	LINE CLEAR AVAILED
954	23-Nov-20	HASSAN	66	Lv1	HOLENARASIPURA_220	12:39	15:10	02:31	LINE CLEAR AVAILED
955	23-Nov-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
956	23-Nov-20	HASSAN	66	LV2	HASSAN_220	10:26	15:58	05:32	LINE CLEAR AVAILED
957	23-Nov-20	HASSAN	66	Lv2	HOLENARASIPURA_220	12:40	13:28	00:48	LINE CLEAR AVAILED
958	23-Nov-20	HASSAN	66	Lv2	HOLENARASIPURA_220	14:38	15:11	00:33	LINE CLEAR AVAILED
959	23-Nov-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
960	23-Nov-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
961	23-Nov-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	14:32	14:39	00:07	LINE FAULT
962	23-Nov-20	HASSAN	110	HV1	BAIKAMPADI_110	10:21	15:02	04:41	LINE CLEAR AVAILED
963	23-Nov-20	HASSAN	110	HV1	HIENALLUR_110	15:58	17:51	01:53	LINE CLEAR AVAILED
964	23-Nov-20	HASSAN	110	HV2	SORABA_110	11:46	13:51	02:05	LINE CLEAR AVAILED
965	23-Nov-20	HASSAN	110	HV3	MRSMSG_220	9:15 (23.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
966	23-Nov-20	HASSAN	110	JOG-JLT4	mghejog_gen	9:23 (18.11.2020)			LINE OPEN:LINE CLEAR AVAILED
967	23-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:37 (14.11.2020)			LINE OPEN:LINE CLEAR AVAILED
968	23-Nov-20	MYSORE	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	6:55	7:04	0:09	LINE FAULT
969	23-Nov-20	MYSORE	66	HV1	MADDUR_66	12:54	15:12	2:18	LINE CLEAR AVAILED
970	23-Nov-20	MYSORE	66	HV2	MADDUR_66	12:05	12:59	0:54	LINE CLEAR AVAILED
971	23-Nov-20	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	16:09	16:20	0:11	LINE FAULT
972	23-Nov-20	MYSORE	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	16:09	16:20	0:11	LINE FAULT
973	23-Nov-20	MYSORE	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	3:45	3:50	0:05	LINE FAULT
974	23-Nov-20	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66 SOMANAHALLI_66	10:39	10:50	0:11	LINE FAULT
975	23-Nov-20	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66	14:15	15:12	0:57	LINE CLEAR AVAILED
976	23-Nov-20	MYSORE	66	MADDUR-SOMANAHALLI	SOMANAHALLI	13:46	15:12	1:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
977	23-Nov-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	18:01	18:06	0:05	LINE FAULT
978	23-Nov-20	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:13	6:18	0:05	LINE FAULT
979	23-Nov-20	MYSORE	66	MEGHALAPURA-SFC	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALI_66 BGPURA_66	13:10	13:29	0:18	LINE FAULT
980	23-Nov-20	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66 MALIYURU_66	9:10	9:24	0:14	LINE FAULT
981	23-Nov-20	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	15:41	17:36	1:54	LINE CLEAR AVAILED
982	23-Nov-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR IPP_66	21:31	21:54	0:22	MAIN SUPPLY FAILURE
983	23-Nov-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:00	17:02	0:02	LINE FAULT
984	23-Nov-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	16:18	16:43	0:24	LINE FAULT
985	23-Nov-20	TUMKUR	66	SOKKE-JAGLUR	JAGALUR_66	12:29	14:52	2:22	LINE CLEAR AVAILED
986	23-Nov-20	TUMKUR	66	TR-1	PAVAGADA_66	13:29	13:37	0:08	TRANSFORMER FAULT
987	23-Nov-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	17:11	17:37	0:25	LINE CLEAR AVAILED
988	23-Nov-20	TUMKUR	66	TR-1	SHYLAPURA_66	16:18	16:43	0:25	TRANSFORMER FAULT
989	23-Nov-20	TUMKUR	66	TR-1	SOKKE_66	12:29	14:54	2:24	LINE CLEAR AVAILED
990	23-Nov-20	TUMKUR	66	TR-2	HOLALKERE_66	13:41	13:45	0:04	TRANSFORMER FAULT
991	23-Nov-20	TUMKUR	66	TR-2	HOSADURGA_66	9:50	9:52	0:02	TRANSFORMER FAULT
992	23-Nov-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	16:06	18:25	2:18	LINE CLEAR AVAILED
993	23-Nov-20	TUMKUR	110	TR-1	SAMPIGE_110	13:10	13:28	0:17	HAND TRIPPED
994	23-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)	15:08:38(23.11.2020)	4154:48hrs	TRANSFORMER CHARGED